

APPENDIX A

NOTICE OF VIOLATION

Duquesne Light Company
Beaver Valley Power Station, Unit 1

Docket No. 50-334
License No. DPR-66

As a result of the inspection conducted on August 1-27, 1986, and in accordance with the "General Statement of Policy and Procedures for NRC Enforcement Actions," 10 CFR Part 2, Appendix C (1985), the following violation was identified:

Technical Specification 6.12.2, High Radiation Area, requires that entry into high radiation areas be controlled with locked doors to prevent unauthorized access and that the keys be maintained under the administrative controls of the shift supervisor on duty and/or facility health physics supervisor. Operating Manual Chapter 1.48.5.c, Padlock/Locking Devices Administrative Requirement, requires the shift supervisor to control entry into the NSS key cabinet.

Contrary to the above, on July 29, 1986, three individuals obtained access to the unlocked NSS key cabinet containing keys to the high radiation area. Entries into the NSS key cabinet were not controlled in that these individuals removed keys while the shift supervisor was not in the office containing the key cabinet.

This is a Severity Level IV Violation (Supplement 1).

Pursuant to the provisions of 10 CFR 2.201, Duquesne Light Company is hereby required to submit to this Office within thirty days of the date of the letter which transmitted this Notice, a written statement or explanation in reply, including (1) the corrective steps which have been taken and the results achieved; (2) corrective steps which will be taken to avoid further violations; and (3) the date when full compliance will be achieved. Where good cause is shown, consideration will be given to extending this response time.

8609230146 860909
PDR ADOCK 05000334
Q PDR