



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

COMMONWEALTH EDISON COMPANY

DOCKET NO. 50-237

DRESDEN NUCLEAR POWER STATION, UNIT NO. 2

AMENDMENT TO PROVISIONAL OPERATING LICENSE

Amendment No. 92  
License No. DPR-19

1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by the Commonwealth Edison Company (the licensee) dated March 10, 1986 complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 3.B. of Provisional Operating License No. DPR-19 is hereby amended to read as follows:

B. Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 92, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

A handwritten signature in dark ink, appearing to read 'J A Zll', is written over the typed name of John A. Zwolinski.

John A. Zwolinski, Director  
RWR Project Directorate #1  
Division of BWR Licensing

Attachment:  
Changes to the Technical  
Specifications

Date of Issuance: April 28, 1986

ATTACHMENT TO LICENSE AMENDMENT NO. 92

PROVISIONAL OPERATING LICENSE DPR-19

DOCKET NO. 50-237

Revise Appendix A Technical Specifications by removing the pages identified below and inserting the attached pages. The revised pages are identified by the captioned amendment number and contain marginal lines indicating the area of change.

REMOVE

3/4.9-4

INSERT

3/4.9-4

3.9 LIMITING CONDITION FOR OPERATION  
(Cont'd.)

operable, provided that during such seven days the operable diesel generator shall be demonstrated to be operable at least once each day and two off-site lines are available.

The specified 7 day outage period will apply except for spring of 1986, at which time an additional 7 days (14 total) will be allowed, on a one time only basis, to complete 10CFR 50 Appendix R modifications to the 2/3 Diesel Generator.

3. From and after the date that one of the two 125 or 250V battery systems is made or found to be inoperable, except as specified in 3.9.B.4a or b, Unit shutdown shall be initiated within 2 hours and the unit shall be in cold shutdown in 24 hours unless the failed battery can be sooner made operable.
4. a. Each 125 or 250 volt battery may be inoperable for a maximum of 7 days per operating cycle for maintenance and testing.
- b. If it is determined that a battery need be replaced as a result of maintenance or testing, a specific battery may be inoperable for an additional 7 days per operating cycle.

4.9 SURVEILLANCE REQUIREMENT  
(Cont'd.)