

April 16, 1986

Docket Nos. 50-313
50-368

Mr. John M. Griffin
Senior Vice President
of Energy Supply
Arkansas Power and Light Company
P. O. Box 551
Little Rock, Arkansas 72203

Dear Mr. Griffin:

We have reviewed your letter of February 13, 1986, which responded to our letter of December 12, 1985, concerning Generic Letter 83-28, Items 4.2.1 and 4.2.2, Preventive Maintenance Program for Reactor Trip Breakers/Maintenance and Trending. We have determined that your response is acceptable and, thus, completes the issue.

Sincerely,

*ORIGINAL SIGNED BY

JOHN F. STOLZ*
John F. Stolz, Director
PWR Project Directorate #6
Division of PWR Licensing - B

ORIGINAL SIGNED BY
George Knighton, Director
PWR Project Directorate #7
Division of PWR Licensing - B

cc: See next page

DISTRIBUTION	ACRS-10
<u>Docket File</u>	BGrimes
NRC PDR	JPartlow
L PDR	GVising
PBD-6 Rdg	RIngram
FMiraglia	Gray File
OELD	EBrach
EJordan	HOrnstein

PBD-6
GVising;jak
4/14/86

PBD-6
JStolz
4/14/86

PBD-6
CMcCracken
4/14/86

PBD-7
RLea
4/15/86

PBD-7
Knighton
4/16/86

8605060455 860416
PDR ADOCK 05000313
PDR

Document Name:
AP&L LTR ON 4.2.1

Requestor's ID:
VISSING

Author's Name:
Guy S, Vissing


Document Comments:
Letter to AP&L concerning Items 4.2.1 & 4.2.1


CONCURRENCES

GVissing  _____

JStolz  _____

CMcCracken  _____

RLee  _____

GKnighton  _____

delete



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

APR 02 1986

Docket Nos.: 50-313/368

MEMORANDUM FOR: **Guy Vissing**, Project Manager
PWR Project Directorate #6
Division of PWR Licensing-B

FROM: Dennis Crutchfield, Assistant Director
for Technical Support
Division of PWR Licensing-B

SUBJECT: REVISED SER FOR ARKANSAS NUCLEAR ONE, UNITS 1 AND 2
GENERIC LETTER 83-28 ITEMS 4.2.1 AND 4.2.2 - PREVENTATIVE
MAINTENANCE PROGRAM FOR REACTOR TRIP BREAKERS/MAINTENANCE
AND TRENDING (MPA B-81) (TAC NOS. 53112 AND 53113)

On November 22, 1985 the Equipment Qualification Branch transmitted to the Division of Licensing a Safety Evaluation Report (SER) on the above subject. That SER indicated that the licensee must confirm that the Undervoltage Trip Device roller rivet-armature clearance is measured with the armature in the energized position.

By letter to J. F. Stolz of NRC from J. Ted Enos of Arkansas Power and Light Company, dated February 13, 1986, the licensee for Arkansas Nuclear One Units 1 and 2 provided the requested confirmation.

The staff finds that the licensee's response is acceptable and closes the confirmatory issue identified in the November 22, 1985 SER. This SER completes the staff review under TAC NOS. 53112 and 53113. The SALP input for this review was provided with the November 22, 1985 SER.

Dennis W. Pan
Dennis Crutchfield, Assistant Director
for Technical Support
Division of PWR Licensing-B

cc: G. Lainas
C. Rossi
R. Ballard
G. Bagchi
J. Bradfute
J. Stolz
C. Y. Cheng
L. Magleby, INEL
R. Wright
N. Romney

Contact: N. Romney
X-24709

8624080133

Mr. J. M. Griffin
Arkansas Power & Light Company

Arkansas Nuclear One, Unit 1

cc:
Mr. J. Ted Enos
Manager, Licensing
Arkansas Power & Light Company
P. O. Box 551
Little Rock, Arkansas 72203

Mr. James M. Levine
General Manager
Arkansas Nuclear One
P. O. Box 608
Russellville, Arkansas 72801

Mr. Nicholas S. Reynolds
Bishop, Liberman, Cook, Purcell & Reynolds
1200 Seventeenth Street, N.W.
Washington, D.C. 20036

Mr. Robert B. Borsum
Babcock & Wilcox
Nuclear Power Generation Division
Suite 220, 7910 Woodmont Avenue
Bethesda, Maryland 20814

Resident Inspector
U.S. Nuclear Regulatory Commission
P. O. Box 2090
Russellville, Arkansas 72801

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
Office of Executive Director
for Operations
611 Ryan Plaza Drive, Suite 1000
Arlington, Texas 76011

Mr. Frank Wilson, Director
Division of Environmental Health
Protection
Department of Health
Arkansas Department of Health
4815 West Markham Street
Little Rock, Arkansas 72201

Honorable Ermil Grant
Acting County Judge of Pope County
Pope County Courthouse
Russellville, Arkansas 72801