

VPNPD-86-332 NRC-86-75

July 25, 1986

Mr. James G. Keppler, Regional Administrator U. S. NUCLEAR REGULATORY COMMISSION Region III 799 Roosevelt Road Glen Ellyn, Illinois 60137

Dear Mr. Keppler:

DOCKETS 50-266 AND 50-301 RESPONSE TO IE BULLETIN 86-02 POINT BEACH NUCLEAR PLANT, UNITS 1 AND 2

In accordance with the requirements of IE Bulletin 86-02, "Static 'O' Ring Differential Pressure Switches", we have determined that SOR Model 102 or 103 differential pressure switches are not installed, or planned to be used, in safety-related applications at our Point Beach Nuclear Plant.

In conjunction with our evaluation of IE Information Notice 86-47, we further determined that these pressure switches are not utilized in any applications at Point Beach.

Very truly yours,

C. W. Fay Vice President Nuclear Power

Subscribed and sworn to before me this 25th day of _____, 1986

Notary Public, State of Wisconsin

Rowski

My Commission expires May 27, 1990 .

Copy to Resident Inspector

8608010184 860725 PDR ADOCK 05000266 Q PDR

JUL 2 8 1986 1/0

MB