

DUKE POWER COMPANY

P.O. BOX 33189
CHARLOTTE, N.C. 28242

HAL B. TUCKER
VICE PRESIDENT
NUCLEAR PRODUCTION

TELEPHONE
(704) 373-4531

July 28, 1986

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Attention: Mr. B. J. Youngblood, Project Director
PWR Project Directorate No. 4


Re: Catawba Nuclear Station, Units 1 and 2
Docket Nos. 50-413 and 50-414
Technical Specification Amendment for Diesel Generators

Dear Mr. Denton:

Per conversations with members of your Staff, attached is a revised insert for page 3/4 8-1 ACTION "C". This page was included in my letter of June 30, 1986 which clarified several Technical Specification amendments requested in my March 24, 1986 letter.

Pursuant to 10 CFR 50.91 (b) (1) the appropriate South Carolina State Official is being provided a copy of this clarification to our amendment request.

Very truly yours,



Hal B. Tucker

RWO/05/slb

Attachment

xc: Dr. J. Nelson Grace, Regional Administrator
U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

Mr. Heyward Shealy, Chief
Bureau of Radiological Health
South Carolina Department of Health &
Environmental Control
2600 Bull Street
Columbia, South Carolina 29201

8608040253 860728
PDR ADOCK 05000413
P PDR

Aool

Mr. Harold R. Denton, Director
July 28, 1986
Page Two

xc: INPO Records Center
Suite 1500
1100 Circle 75 Parkway
Atlanta, Georgia 30339

American Nuclear Insurers
c/o Dottie Sherman, ANI Library
The Exchange, Suite 245
270 Farmington Avenue
Farmington, CT 06032

M&M Nuclear Consultants
1221 Avenue of the Americas
New York, New York 10020

Mr. P. H. Skinner
NRC Resident Inspector
Catawba Nuclear Station

INSERT FOR PAGE 3/4 B-1 .

ACTION "c."

With a diesel generator of the above required A.C. electrical power sources inoperable, demonstrate the OPERABILITY of the A.C. offsite sources by performing Surveillance Requirement 4.8.1.1.1a within 1 hour and at least once per 8 hours thereafter; and unless the inoperability of the diesel was due to preplanned testing or maintenance, demonstrate the operability of the remaining diesel generator by performing Surveillance Requirement 4.8.1.1.2a.4, within 24 hours; restore diesel generators to OPERABLE status within 72 hours or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours. *and 4.8.1.1.2a.5*