

APR 11 1983

Docket No. 50-305

Wisconsin Public Service
Corporation
ATTN: Mr. C. W. Giesler
Vice President-Nuclear Power
Post Office Box 1200
Green Bay, WI 54305

Gentlemen:

This refers to the routine safety inspection conducted by Mr. R. L. Nelson of this office during the period of January 1 - March 2, 1983, of activities at the Kewaunee Nuclear Power Plant authorized by DPR-43 and to the discussion of our findings with Mr. D. C. Hintz at the conclusion of the inspection.

The enclosed copy of our inspection report identifies areas examined during the inspection. Within these areas, the inspection consisted of a selective examination of procedures and representative records, observations, and interviews with personnel.

During this inspection, certain of your activities appeared to be in noncompliance with NRC requirements, as specified in the enclosed Appendix. A written response is required. With regard to Item 4, your responses should describe steps you have taken to assure that Type 2 and 3 components are not installed in Type 1 systems without documentary evidence that the items conform to Type 1 requirements. Your description should include information such as the number and identifying number of design changes, modifications, and maintenance work requests reviewed, results of review, and any corrective actions resulting from the review.

In accordance with 10 CFR 2.790(a), a copy of this letter and the enclosure(s) will be placed in the NRC Public Document Room unless you notify this office, by telephone, within ten days of the date of this letter and submit written application to withhold information contained therein within thirty days of the date of this letter. Such application must be consistent with the requirements of 2.790(b)(1). If we do not hear from you in this regard within the specified periods noted above, a copy of this letter, the enclosure(s), and your response to this letter will be placed in the Public Document Room.

8305020349 830411
PDR ADOCK 05000305
Q PDR

IE01

The responses directed by this letter (and the accompanying Notice) are not subject to the clearance procedures of the Office of Management and Budget as required by the Paperwork Reduction Act of 1980, PL 96-511.

We will gladly discuss any questions you have concerning this inspection.

Sincerely,

Original signed by C. E. Norelius


C. E. Norelius, Director
Division of Projects and
Resident Programs


Enclosures:


1. Appendix, Notice
of Violation
2. Inspection Report
No. 50-305/83-01(DPRP)


cc w/encls:

D. C. Hintz, Plant
Superintendent
DMB/Document Control Desk (RIDS)
Resident Inspector, RIII
John J. Duffy, Chief
Boiler Section
Stanley York, Chairman
Public Service Commission

RIII

Nelson/jp
4/4/83

RIII

Jackiw

RIII

Streeter
4/4

RIII

Norelius
4/4/83