

**Detroit
Edison**

Harry Tauber
Group Vice President

2000 Second Avenue
Detroit, Michigan 48226
(313) 237-8000

April 25, 1983
EF2 - 62,427

Director of Nuclear Reactor Regulation
Attention: Mr. B. J. Youngblood, Chief
Licensing Branch No. 1
Division of Licensing
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Dear Mr. Youngblood:

Reference: (1) Enrico Fermi Atomic Power Plant Unit 2
NRC Docket No. 50-341

(2) NRC to H. Tauber letter, "Unqualified
Electrical Components in Safety-Related
Systems", March 16, 1983


Subject: Unqualified Electrical Components

The referenced NRC letter requested that we indicate within 10 days of receipt of the letter when we could address the subject issue. On March 15, 1983, Mr. L. Fron, Supervising Engineer of our Equipment Qualification Group had a phone conversation with J. Kennedy, the NRC reviewer for Fermi 2 in the Equipment Qualification Branch. It was decided at that time that our EQ report update would be the appropriate place to address the concerns. The report update (and appropriate justifications for interim operation) is scheduled for submittal to the NRC by July 1, 1983.

Should you have any additional questions, please contact Larry E. Schuerman, (313) 649-7617.

Sincerely,

cc: Mr. P. Byron
Mr. D. Lynch



8305020370 830425
PDR ADDCK 05000341
A PDR

A048



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

K. Chon
NRC KSVF

MAR 16 1983

2.206?

LCF-Action
cc: MLB
OKE
Doc Control

Docket No.: 50-341

ISI
IWW/IWP

Mr. Harry Tauber
Engineering & Construction
Detroit Edison Company
2000 Second Avenue
Detroit, Michigan 48226

Dear Mr. Tauber:

Subject: Unqualified Electrical Components in Safety-Related Systems

It has recently come to our attention that there are two components which may be installed in safety-related systems of the Fermi-2 facility and which may not be environmentally qualified. Specifically, these are items of electrical equipment whose qualification documentation demonstrates significant deficiencies which would affect the ability of the equipment to perform its intended safety function. These components are:

GE switch, Type CR 2940

Marathon 6000 series terminal blocks

We request that you review the safety-related systems of the Fermi-2 facility to determine whether these two components are installed or will be installed and state your proposed approach for resolving this matter. We further request that you indicate within ten days after receipt of this letter when you can address this issue.

If you have any questions on this matter, please contact the Fermi-2 project manager, M. D. Lynch, at (301)492-7050.

Sincerely,

B. J. Youngblood, Chief
Licensing Branch No. 1
Division of Licensing

cc: See next page

Dupe 8303290714