March 22, 1999

Mr. William T. Cottle President and Chief Executive Officer STP Nuclear Operating Company South Texas Project Electric Generating Station P. O. Box 289 Wadsworth, Texas 77483

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION ON PROPOSED AMENDMENT TO COLD OVERPRESSURE MITIGATION CURVES IN TECHNICAL SPECIFICATION FIGURE 3.4-4, SOUTH TEXAS PROJECT, UNITS 1 AND 2 (STP) (TAC NOS. MA3519 AND MA3520)

Dear Mr. Cottle:

The Nuclear Regulatory Commission staff is reviewing STP Nuclear Operating Company's (STPNOC's) August 31, 1998, application on the above subject. This amendment is associated with the Replacement Steam Generator Project.

Based on its review, the staff has determined that additional information is needed, as discussed in the enclosed request for additional information (RAI). This request was discussed with Mr. Mark VanNoy of your staff on February 24, 1999, and a mutually agreeable target date of a response to the RAI by April 19, 1999, was established. The staff appreciates the efforts expended with respect to this matter.

Sincerely,

ORIGINAL SIGNED BY: Thomas W. Alexion, Project Manager Project Directorate IV-1 Division of Licensing Project Management Office of Nuclear Reactor Regulation

Docket Nos. 50-498 and 50-499

Enclosure: As stated

cc w/encl: See next page

DISTRIBUTION:	ACRS		
Docket File	J.Zwolinski/S.Black		
PUBLIC	K.Brockman, RIV		
PDIV-1 Reading	OGC		

Document Name:G:\STPFINAL\RAIA3519.WPD

OFC	PM/PD4-1	LA/PD4-1	SL/SR'(B	(A)D/PD4-1
NAME	TAlexion	L.Berry	Finiss	G.Dick
DATE	3, 6,99	3/15/99	31/8/99	3,192,199
COPY	YES	YES	YES/NO	YES

X2

OFFICIAL RECORD COPY 9903290117 990322 PDR ADOCK 05000498 PDR PDR



UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D.C. 20555-0001

SHINGTON, D.C. 20505-0001

March 22, 1999

Mr. William T. Cottle President and Chief Executive Officer STP Nuclear Operating Company South Texas Project Electric Generating Station P. O. Box 289 Wadsworth, Texas 77483

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION ON PROPOSED AMENDMENT TO COLD OVERPRESSURE MITIGATION CURVES IN TECHNICAL SPECIFICATION FIGURE 3.4-4, SOUTH TEXAS PROJECT, UNITS 1 AND 2 (STP) (TAC NOS. MA3519 AND MA3520)

Dear Mr. Cottle:

The Nuclear Regulatory Commission staff is reviewing STP Nuclear Operating Company's (STPNOC's) August 31, 1998, application on the above subject. This amendment is associated with the Replacement Steam Generator Project.

Based on its review, the staff has determined that additional information is needed, as discussed in the enclosed request for additional information (RAI). This request was discussed with Mr. Mark VanNoy of your staff on February 24, 1999, and a mutually agreeable target date of a response to the RAI by April 19, 1999, was established. The staff appreciates the efforts expended with respect to this matter.

Sincerely,

Thomas W. Alexion, Project Manager Project Directorate IV-1 Division of Licensing Project Management Office of Nuclear Reactor Regulation

Docket Nos. 50-498 and 50-499

Enclosure: As stated

cc w/encl: See next page

Mr. William T. Cottle STP Nuclear Operating Company

CC:

Mr. Cornelius F. O'Keefe Senior Resident Inspector U.S. Nuclear Regulatory Commission P. O. Box 910 Bay City, TX 77414

A. Ramirez/C. M. Canady City of Austin Electric Utility Department 721 Barton Springs Road Austin, TX 78704

Mr. M. T. Hardt Mr. W. C. Gunst City Public Service Board P. O. Box 1771 San Antonio, TX 78296

Mr. G. E. Vaughn/C. A. Johnson Central Power and Light Company P. O. Box 289 Mail Code: N5012 Wadsworth, TX 74483

INPO Records Center 700 Galleria Parkway Atlanta, GA 30339-3064

Regional Administrator, Region IV U.S. Nuclear Regulatory Commission 611 Ryan Plaza Drive, Suite 400 Arlington, TX 76011

D. G. Tees/R. L. Balcom Houston Lighting & Power Co. P. O. Box 1700 Houston, TX 77251

Judge, Matagorda County Matagorda County Courthouse 1700 Seventh Street Bay City, TX 77414 South Texas, Units 1 & 2

Jack R. Newman, Esq. Morgan, Lewis & Bockius 1800 M Street, N.W. Washington, DC 20036-5869

Mr. T. H. Cloninger Vice President Engineering & Technical Services STP Nuclear Operating Company P. O. Box 289 Wadsworth, TX 77483

Office of the Governor ATTN: John Howard, Director Environmenta! and Natural Resources Policy P. O. Box 12428 Justin, TX 78711

Jon C. Wood Matthews & Branscomb One Alamo Center 106 S. St. Mary's Street, Suite 700 San Antonio, TX 78205-3692

Arthur C. Tate, Director Division of Compliance & Inspection Bureau of Radiation Control Texas Department of Health 1100 West 49th Street Austin, TX 78756

Jim Calloway Public Utility Commission of Texas Electric Industry Analysis P. O. Box 13326 Austin, TX 78711-3326

Request for Additional Information

Cold Overpressure Mitigating System Curves for

Replacement Steam Generators

South Texas Project, Units 1 and 2

- 1. In your submittal of August 31, 1998, you stated that the new Model Δ91 steam generator design results in an increase in the reactor coolant system (RCS) volume. For the mass injection limited regions this is expected to have a relaxing effect on the cold overpressure mitigating system (COMS) setpoints. However, in your submittal you stated that the new setpoint curves for the Δ94 steam generators are more bounding than your existing curves. During a conference call on January 14, 1999, you stated that while the increase in RCS volume had a relaxing effect on the setpoint, the increase in RCS flow as a result of the steam generator replacement had the opposite effect because of the increase in hydraulic pressure drop between the beltline region and the pressure instrument. Please provide a quantitative justification for your conclusion that the new curves for the new steam generators bound the existing curves in the mass injection limited regions. In your justification, please also include a discussion of the assumption for the amount of tubes plugged in the new analyses and the effects of this assumption.
- 2. As described in your submittal of August 31, 1998, your assumptions for the mass injection transients include flow from one charging pump with letdown isolated and the charging control valve in its normal position. In WCAP-13782, the methodology referenced for determining the COMS power-operated relief valve (PORV) setpoints, the assumptions for the mass injection transients include the maximum deliverable flow from one centrifugal charging pump with letdown isolation and charging control valve fully open. In addition, WCAP-13782 includes Figures 2.1 and 2.3, which provide the maximum credible flow rates at a given pressure for the two cases analyzed (RCS temperature < 200 °F and RCS temperature ≥ 200 °F). There appears to be a discrepancy between the assumptions stated in your submittal dated August 31, 1998. and the assumptions listed in WCAP-13782 with the assumptions listed in the WCAP being more conservative with respect to injection flow rates. Please address this apparent discrepancy and provide the flow rates used for the two cases (RCS temperature < 200 °F and RCS temperature > 200 °F). Also, please provide a discussion of how this is conservative with respect to the mass injection analyses.
- 3. In the August 31, 1998, submittal you indicated that the proposed COMS setpoint curve (proposed TS Figure 3.4-4) considers overshoot and undershoot and valve stroke times. Your submittal also indicated that pressure instrument uncertainty was not accounted for in the development of the proposed setpoint curve. Section 50.36(c)(2)(i) of 10 CFR defines limiting conditions for operation (LCOs) as the lowest functional capability of equipment required for safe operation of the facility. Section 50.36(c)(2)(ii)(C) requires LCOs for components that actuate to mitigate a design-basis transient that presents a challenge to the integrity of a fission product barrier. Section 50.36(c)(3) requires

Enclosure

-2-

surveillance requirements for calibration of components to assure that the LCOs will be met. The pressure instrument uncertainty in the COMS system, if not accounted for, can lead to a delay in the actuation of COMS, consequently causing system pressure to exceed the Appendix G pressure temperature limit. Therefore, in order to assure that Appendix G pressure temperature limits are not exceeded, instrument uncertainty must be accounted for. Please address this apparent deficiency.

In your mass addition analyses you did not account for injection from the safety injection accumulators. In addition, only one of the charging pumps was assumed to inject. The staff has reviewed your proposed technical specifications and could not find the corresponding restrictions to isolate the safety injection accumulators and to disable all but one charging pump. Section 50.36(c)(2)(ii)(B) requires that an operating restriction that is an initial condition of a design-basis transient analysis that presents a challenge to the integrity of a fission product barrier be included in technical specification LCOs. Please address this apparent inconsistency.

4