

NAME GPU NUCLEAR
 ADDRESS 100 INTERPACE PARKWAY
PASSIPPANY NE NJ 07054

NJ0005500
 PERMIT NUMBER

HEC A
 DISCHARGE NUMBER

F - FINAL LIMITS

FACILITY _____
 LOCATION _____

MONITORING PERIOD							
FROM	YEAR	MO	DAY	TO	YEAR	MO	DAY
	85	01	01		85	01	31
	(20-21)	(22-23)	(24-25)		(26-27)	(28-29)	(30-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	X	(1 Card Only) QUANTITY OR LOADING (46-51)			(4 Card Only) QUALITY OR CONCENTRATION (46-51)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM			
TEMPERATURE, WATER DEG. CENTIGRADE 00010 1 0 EFFLUENT GROSS VALUE		*****	*****	*****	10.6	13.1	15.6	0	2/31	GRAB
		*****	*****	*****	*****	*****	45		TWICE/MONTH	GRAB
TEMPERATURE, WATER DEG. CENTIGRADE 00010 7 0 INTAKE FROM STREAM		*****	*****	*****	-1.2	4.5	11.2	0	2/31	
		*****	*****	*****	*****	*****	*****		SEE PERMIT	
THERMAL DISCHARGE MILLION BTUS PER HR. 00015 2 0 EFFLUENT NET VALUE		8.6	11.7	MBTU/HR	*****	*****	*****	0	2/31	
		*****	49.40	HR	*****	*****	*****		SEE PERMIT	
TEMP. DIFF. BETWEEN SAMPLE AND UPSTREAM 00016 2 0 EFFLUENT NET VALUE		*****	*****	*****	-.7	8	16.7	1	2/31	
		*****	*****	*****	*****	*****	15		SEE PERMIT	
PH 00400 1 0 EFFLUENT GROSS VALUE		*****	*****	*****	7.8	*****	7.9	0	2/31	GRAB
		*****	*****	*****	6.50 MINIMUM	*****	8.50 MAXIMUM		TWICE/MONTH	GRAB
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 EFFLUENT GROSS VALUE		2.88	2.88		*****	*****	*****	0	2/31	
		*****	*****	MGD	*****	*****	*****		TWICE/MONTH	
CHLORINE, TOTAL RESIDUAL 50000 1 0 EFFLUENT GROSS VALUE		*****	NOT	KG/DAY	*****	0.20	0.50		SEE PERMIT	
		*****	*****	DAY	*****	*****	*****		SEE PERMIT	

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER
 Peter B. Fiedler
 Vice President and Director
 Oyster Creek
 TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION I BELIEVE THE SUBMITTED INFORMATION IS TRUE ACCURATE AND COMPLETE I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT SEE 18 USC § 1001 AND 33 USC § 1319 (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

Peter B. Fiedler
 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE
 609 971-4796
 DATE
 85 04 12

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

01'S REC IS HEAT EXCHANGE COOLING WATER

8504250010 850412
 PDR ADOCK 05000219
 R PDR