

July 10, 1986

Tennessee Valley Authority  
✓ATTN: Mr. S. A. White  
Manager of Nuclear Power  
6N 38A Lookout Place  
1101 Market Street  
Chattanooga, TN 37402-2801

Gentlemen:

SUBJECT: NRC INSPECTION REPORT NO. 50-328/84-18

We have concluded our evaluation of your response of October 19, 1984, to our Notice of Violation issued on September 11, 1984, and of unresolved item 50-328/84-18-03, concerning activities conducted at your Sequoyah facility. We will examine the implementation of your corrective actions to Violation 1 during future inspections.

After a comprehensive review of your denial of Violation 2, we have determined that existing regulatory requirements do not clearly warrant enforcement action in this matter; therefore, we have deleted this violation from our records. However, we remain concerned that the steam supply transfer feature rendered the turbine driven auxiliary feedwater pump inoperable. In light of this experience, we request that you evaluate the benefit of this design feature to overall plant safety and consider its possible deletion.

With regard to unresolved item 50-328/84-18-03, concerning the inoperability of main feed pump "A" control circuitry on June 30, 1984, we have reviewed this matter and have concluded that your interpretation of applicable Technical Specifications was correct. This unresolved item will be administratively closed.

We appreciate your cooperation in these matters.

Sincerely,

(original signed by SP Weise for)

Gary G. Zech  
Director, TVA Projects

cc: ✓H. L. Abercrombie, Sequoyah  
Site Director  
✓P. R. Wallace, Plant Manager  
✓W. Whitt, Director, Nuclear  
Managers Review Group  
✓D. L. Williams, Jr., Supervisor  
Licensing Section  
✓B. Kirk, Compliance Staff Supervisor  
✓E. Wills, Project Engineer

bcc (see page 2)

8608110087 860710  
PDR ADOCK 05000328  
G PDR

10 IE01

July 10, 1986

bcc: ✓ R. D. Walker  
✓ H. R. Denton, NRR  
✓ H. L. Thompson, NRR  
✓ J. M. Taylor, IE  
✓ B. B. Hayes, OI  
✓ S. R. Connelly, OIA  
✓ G. G. Zech  
✓ S. P. Weise  
✓ Document Control Desk  
State of Tennessee  
✓ NRC Resident Inspector

RII

*DF*  
DFalconer:btm  
6/26/86

RII

*BW*  
BWilson  
6/26/86

RII

*CJ*  
CJulian  
6/30/86

RII

*AG*  
AGibson  
6/1/86

RII

*B*  
BDebs  
6/7/86

RII

*SW*  
SWeise  
6/7/86

~~RII~~

~~LR~~  
~~Reyes~~  
~~6/7/86~~

~~RII~~

~~GG~~  
~~G~~enkins  
~~6/7/86~~

~~RII~~

~~R~~Walker  
~~6/7/86~~

RII

G. ZECH  
7/1/86