



Log # TXX-88729
File # 10110
908.3
Ref. # 10CFR50.55(e)

October 20, 1988

William G. Council
Executive Vice President

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555

SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION (CPSES)
DOCKET NOS. 50-445 AND 50-446
ELECTRICAL PENETRATION OVERLOAD PROTECTION
SDAR: CP-88-09 (SUPPLEMENTAL REPORT)

Gentlemen:

On January 11, 1988, TU Electric letter logged TXX-88068 notified you of a reportable deficiency involving the overloading of and the absence of backup protection devices for Class 1 and non-Class 1E electrical penetrations. The purpose of this supplemental report is to revise the corrective action implementation schedule.

The new estimated completion date for Unit 1 corrective actions as specified in TXX-88068 is now May 1, 1989. Unit 2 activities will be completed prior to Unit 2 fuel load.

Very truly yours,

W. G. Council

W. G. Council

By: *D. R. Woodlan*
D. R. Woodlan
Docket Licensing Manager

HJH/mlh

c - Mr. R. D. Martin, Region IV
Resident Inspectors, CPS(S) (3)

8810250345 881020
PDR ADUCK 05000445
S PNU