



Log # TXX-88746  
File # 10110  
910.4  
Ref. # 10CFR50.55(e)

October 20, 1988

William G. Council  
Executive Vice President

U. S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, D. C. 20555

SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION (CPSES)  
DOCKET NOS. 50-445 AND 50-446  
AUXILIARY FEEDWATER SYSTEM AIR ACCUMULATORS  
SDAR: CP-88-13 (SUPPLEMENTAL REPORT)

Gentlemen:

On January 27, 1988, we notified you via our report logged TXX-88138 of a deficiency involving inadequately sized air accumulators for the Auxiliary Feedwater (AFW) System flow control and recirculation valves. The purpose of this supplemental report is to revise the corrective action implementation schedule for this issue.

The estimated completion date has been rescheduled for the design modification required to increase the capacity of the Unit 1 AFW air accumulators. The new estimated completion date is January 27, 1989. The Unit 2 design modifications will be completed prior to Unit 2 fuel load.

Very truly yours,

*W. G. Council*

W. G. Council

By: *J. S. Marshall*  
J. S. Marshall  
Generic Licensing Manager

MCP/gj  
c - Mr. R. D. Martin, Region IV  
Resident Inspectors, CPSES (3)

8810260167 881020  
PDR ADOCK 05000445  
S PNU