

DCS No: 56277860807
Date: August 7, 1986

PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE--PNO-I-86-62

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. The information is as initially received without verification or evaluation, and is basically all that is known by the Region I staff on this date.

Facility:
Philadelphia Electric Co.
Peach Bottom Unit 2
Delta, Pennsylvania
DN 50-177

Licensee Emergency Classification:
☐ Notification of Unusual Event
☐ Alert
☐ Site Area Emergency
☐ General Emergency
☒ Not Applicable

Subject: UNSCHEDULED SHUTDOWN GREATER THEN 48 HOURS

Peach Bottom Unit 2 began a shutdown at 1:55 a.m. on August 7, 1986 due to a packing leak on RCIC testable check valve AO-22. The unit was placed in shutdown by a manual scram from 30% power at 4:04 a.m. As of 8 a.m. the unit is at 200 psig reactor pressure and proceeding to cold shutdown. When the reactor has reached cold shutdown the licensee will repair and test the valve. The licensee expects to restart the reactor on August 11, 1986.

There was no release of radiation to the environment.

The State of Pennsylvania has been notified.

CONTACT: R. Gallo (488-1234)

DISTRIBUTION:

H. St.	MNBB	Phillips	E/W	Willste	Mail: ADM:DMB
Chairman Zech	EDD	NRR	IE	NMSS	DOT:Trans only
	PA		OIA	RES	
Comm. Bernthal	ELD		AEOD		
Comm. Roberts					
Comm. Asselstine					
ACRS	Air Rights		INPO-11:07		
SECY	SP		NSAC-11:07		
CA					
PDR	Regional Offices				

TMI Resident Section 11:09
RI Resident Office

Licensee: 11:07
(Reactor Licensees)

Region I Form 83
(Rev. July, 1986)

8608110524 860807
PDR I&E
PNO-I-86-062 PDR

IE-340/1