# U.S NUCLEAR REQULATORY COMMISSION APPROVED BY OME 3150-0120 Expires 6-80-90

#### APPLICATION FOR MATERIAL LICENSE

OF THE ENTIRE COMPLETED APPLICATION TO THE NRC OFFICE SPECIFIED BEI	
APPLICATIONS FOR DISTRIBUTION OF EXEMPT PRODUCTS FILE APPLICATIONS WITH.	IF YOU ARE LOCATED IN
U.S. NUCLEAR REGULATORY COMMISSION DIVISION OF FUEL CYCLE AND MATERIAL SAFETY, NMSS WASHINGTON, DC 20066	ILLINOIS, INDIANA, IOMA, MICHIGAN, MINNESOTA, MISSOURI, OMIO, OR MISCONSIN, SEND APPLICATIONS TO
ALL OTHER PERSONS FILE APPLICATIONS AS POLLOWS. IF YOU ARE LOCATED IN	U.S. NUCLEAR REGULATORY COMMISSION, REGION III MATERIALS LICENSING SECTION 199 RODES VEL! ROAD GLEN ELLYN IL 40127
CONNECTICUT, DELAWARE DISTRICT OF COLUMBIA MAINE MARYLAND MASSACHUSETTS, NEW HAMPSHIRE, NEW JERSEY, NEW YORK, PENNSYLVANIA, RHODE ISLAND, OR VERMONT, SEND APPLICATIONS TO	ARKANSAS COLORADO, IDANO, KANSAS, LOUISIANA, MONTANA, NESRASKA, NEN MEXICO, NORTH DAKOTA, OKLAHOMA, BOUTH DAKOTA, TEXAS, UTAH, OR WYOMING, SEND APPLICATIONS TO
U.S. NUCLEAR REGULATORY COMMISSION, REGION I NUCLEAR MATERIALS SAFETY SECTION 8 831 PARK AYENUE KING OF PRUSSIA, PA 19408	US NUCLEAR REGULATORY COMMISSION REGION IV MATERIAL RADIATION PROTECTION SECTION 61) RYAN PLAZA DRIVE, SUITE 1000
ALABAMA PLORIDA GEORGIA RENTUCKY MISSISSIPPI NORTH CAROLINA, PUERTO RICO SOUTH CAROLINA TENNESSEE VIRGINIA VIRGIN ISLANDS OR WEST VIRGINIA. SEND APPLICATIONS TO	ARLINGTON, TX 78011  ALASKA, ARIZONA, CALIFORNIA HAWAII, NEVADA, OREGON, WASHINGTON, AND U.S. TERRITORIES AND POSSESSIONS IN THE PACIFIC, BEND APPLICATIONS
U.S. NUCLEAR REGULATORY COMMISSION, REGION II NUCEAR MATERIALS SAFETY SECTION 10: MARIETTA STREET, SUITE 2800 ATLANTA, GA 20020	U.S. NUCLEAR REQULATORY COMMISSION, REGION V. NUCLEAR MATERIALS SAFETY SECTION 1400 MARIA LANS, SUTT 210 WALNUT CREEK, CA BROKE
PERSONS LOCATED IN AGREEMENT STATES SEND APPLICATIONS TO THE U.S. NUCLEAR P.	REGULATORY COMMISSION ONLY IF THEY W O POSSESS AND USE LICENSED MATERIAL
1 THIS IS AN APPLICATION FOR ICNEX appropriate INTO	2 NAME AND MAILING ADDRESS OF APPLICANT (INCIDE 20 Code)
A NEW LICENSE  X & AMENDMENT TO LICENSE NUMBER 21-16754-01	Radiology Associates, P.C. #1 Ajax Drive, Suite 130
C RENEWAL OF LICENSE NUMBER	Madison Heights, MI 48071
concentration control procedures are  A NAME OF PERSON TO BE CONTACTED ABOUT THIS APPLICATION  David Close, Consultant, NMA - Clev  BURNITITEMS & THROUGH II ON BY . II PAPER THE TYPE AND SCOPE OF INFORMATION	eland, OH (216) 641-5799
8 RADIDACTIVE MATERIAL	& PURPOSE'S FOR WHICH LICENSED MATERIAL WILL BE USED
which will be possessed at any one time	
1. INDIVIDUALIS RESPONSIBLE FOR RADIATION SAFETY PROGRAM AND THEIR TRAINING AND EXPERIENCE	& TRAINING FOR INDIVIDUALS WORKING IN OR PREQUENTING RESTRICTED AREAS
# FACILITIES AND EQUIPMENT.	10 RADIATION SAFÉTY PROGRAM
11. WASTE MANAGEMENT	13 LIC INSEE FEES (See 10 CFR 170 and Section 170 31) FEE CATEGORY 7C   ENCLOSED \$120.00
13 CERTIFICATION (MUS) IN COMPOSITION SY ADDICANT THE APPLICANT UNDERSTANDS THAT ALL ET ATEMENTS AND REPRESENTATIONS MADE IN THIS APPLICATION ARE BINDING UPON THE APPLICANT THE APPLICANT AND ANY OFFICIAL EXECUTING THIS CERTIFICATION ON BEHALF OF THE APPLICANT NAMED IN ITEM 2. CERTIFY THIS APPLICATION IS PREPARED IN CONFORMITY WITH TITLE 10. CODE OF FEDERAL REDULATIONS, PARTS 30, 32, 33, 34, 35, AND AD AND THAT ALL INJOH VATION CONTAINED HEREIN. IS TRUE AND COMPRICAT TO THIS BEST OF THEIR KNOWLEDGE AND BELIEF WARNING AS U.S. & SECTION 1001 ACT OF JUNE 28. IBME 62 STAT 749 MAKES IT A CRIMINAL OFFENSE TO MAKE A WILLFULLY FALSE STATEMENT OR REPRESENTATION. TO ANY BEFARTWON'T OF AGENCY OF THE UNITED STATES AS TO ANY MATTER WITHIN ITS JURISDICTION  SIGNATURE—CERTY YING CAPICER  TYPED-PRINTED NAME   TITLE  CATE  TO HAD  MELICAL  PRESIDENT  TO LES  T	
8810270144 880623 REG3 L 1C30	
21-16754-01 PNU	
TYPE OF SEE FEE LUG FEE CATEGORY COMMENTS APPROVED BY	
Aud Jun- 516 70 CONTROL NO. 8550 2 MAY 3 1 1933 My Miceria	
\$120 1004 BEGION IN	

#### Air Concentration Control

#### 700 South Main Lapeer

10.13.1 Worker Nose from Nobel Gases O.1: We will collect spent noble gas in a shielded container and will check the trap effluent according to the procedure that follows. We will follow the model procedure for calculating worker dose from nobel gases that was published in Appendix O.1 to Regulatory Guide 10.8, Revision 2.

We will follow the model procedure for checking trap effluent as described in Appendix 0.3 to Regulatory Guide 10.8, Revision 2. As an alternative, after every 20 procedures, the trapping efficiency of the charcoal trap will be evaluated. A low level G-M probe will be placed against the inlet tube of the trap during the equilibrium phase of the study and a reading taken. The probe will then be placed against the outlet from the trap at the initiation of the washout phase. If the maximum exhaust reading exceeds 10% of the inlet reading, taking background into consideration, the trap will be considered saturated and the cartridge will be replaced.

- 10.13.2 Worker dose from aerosols: We will collect spent aerosol in a shielded trap, and for reusable traps, monitor the traps effluent with an air contamination monitor that we will check regularly according to the manufacturer's instructions.
- 10.13.3 Airborn Effluents: We will not directly vent spent aerosols and gases to the atmosphere and therefore no effluent estimation is necessary.
- 10.13.4 Clearance Time, Appendix 0.4: We will calculate spilled gas clearance times according to the procedure only that was published in Appendix 0.1 to Regulatory Guide 10.8, Revision 2.

Individual Responsible for Radiation Safety Programs: Their Training and Experience

Authorized Users for Medical Use

ATT 7.1

Amend to add:

Authorized User

Edmund Dennis Harris, M.D.

Authorization

Material in 35.100 and 35.200

Refer to NRC license # 21\_20440\_01 for evidence of user qualification for the above physician.

Item #7
Page 1 of 1
Proposed 5/20/88
License # 21-16754-01

#### APPENDIX C

#### INSTRUMENTATION

#### 700 South Main Lapeer

1. Survey meters

a. Manufacturer's name: Eberline

Manufacturer's model number: E-520

Number of instruments available: 1

Minimum range: 0 mR/hr to 0.2 mR/hr

Maximum range: 0 mR/hr to 2000 mR/hr

b. Manufacturer's name:

Manufacturer's model number:

Number of instruments available:

Minimum range: mR/hr to mR/hr

Maximum range: mR/hr to mR/hr

2. Dose Calibrator(s)

Manufacturer's name: Capintec

Manufacturer's model number: CRC-4

Number of instruments available: 1

3. Instruments used for diagnostic procedures

Type of Instrument Manufacturer's Name Model No.

Scintillation Camera G.E. Maxicamera


Uptake Probe Picker Spectroscaler

 Other (e.g., liquid scintillation counter, area monitor, velometer)

> Item #9 l of l page Prepared:5/20/88 Lic. #21-16754-01

Facilities and Equipment Diagram Sink Air Supply Lead Castle Air Exhaust Adjacent Areas Lead Shielding Scanner Uptake/Well 5 L-Shield Camera 16" L x16" W x 22" H x 1/2T Lockable Door Receipt Area Generator Lx Wx Hx T Kit Preparation Isotope Storage Lx Wx Hx T Dose Preparation 5 Waste Storage 6 Dose Calibrator Lx Wx Hx T Refrigerator

> 700 South Main Lapeer, MI



Exterior

Item #11 1 of 1 pages Prepared 5/20/88 Lic: #21-16754-01

APPENDIX O Model Procedure for Monitoring, Calculating, and Controlling Air Concentrations (See §§ 20.103, 20.106, 20.201, 35.90, and 35.205.) 0.1 MODEL PROCEDURE FOR CALCULATING WORKER DOSE FROM CONCENTRATIONS OF GASES AND AEROSOLS IN WORK AREAS Collect the following data: 1. Estimated number of studies per week; Activity to be administered per study; Estimated activity lost to the work areas per study (you may assume 20 percent loss); Measured airflow supplied by each vent in the imaging room (if different during heating and cooling seasons, use the lesser value); Measured airflow exhausted by each vent in the imaging room (the exhaust should be vented and not recirculated within the facility); f. Measured airflow exhaust at the storage site (e.g., a fume hood); and Maximum permissible air concentrations in restricted and unrestricted areas. For Xe-133, the maximum permissible values are 1 x 10-5 µCi/ml in restricted areas and 3 x 10-7 µCi/ml in unrestricted areas. For soluble Tc-99m, the maximum permissible values are 4 x 10-5 µCi/ml in restricted areas and 1 x 10-6 µCi/ml in unrestricted areas. For other gases or aerosols, see Appendix B to 10 CFR Part 20. 2. The following calculations must be made: The sum of all measured exhaust rates and the sum of all measured supply rates. If the former is larger than the latter, this ensures that the imaging room is at negative pressure. The estimated average concentration in restricted areas. (1) The total activity released to the restricted area (activity used each week multiplied by estimated fractional loss per study) divided by the total air exhausted (sum of all exhaust rates multiplied by the length of the work week) must be less than the applicable maximum permissible value for a restricted area. (2) If this is not the case, plan for fewer studies. (An increase in the ventilation rate will not significantly reduce the downwind effluent concentration because it is primarily a function of the natural dispersion in the atmosphere.)

#### APPENDIX O

Model Procedure for Monitoring, Calculating, and Controlling Air Concentrations (See §§ 20.103, 20.106, 20.201, 35.90, and 35.205.)

### 0.2 MODEL PROCEDURE FOR CALCULATING AIRBORNE EFFLUENT CONCENTRATION

- Divide the total activity released to an unrestricted area (activity used each week that is released in an exhaust system) by the total volume of air exhausted over the week ("on" time multiplied by measured airflow rate). The quotient must be less than the applicable maximum permissible value for an unrestricted area.
- 2. If this is not the case, plan for fewer studies and do the calculation again. Alternatively, you may consider collection and decay-in-storage for waste, or restriction of access to the release point and calculation of concentration at the boundary of the restricted area.

#### APPENDIX O

Model Procedure for Monitoring, Calculating, and Controlling Air Concentrations (See §§ 20.103, 20.106, 20.201, 35.90, and 35.205.)

## 0.3 MODEL PROCEDURE FOR MONITORING OR CHECKING TRAP EFFLUENT

Charcoal traps can significantly reduce air contamination. They can also become saturated or be spoiled by improper use, humidity, chemicals, or inadequate maintenance.

- If the trap effluent is monitored by a radiation detector designed to monitor effluent gas, check the detector according to the manufacturer's instructions and keep a record of the checks.
- 2. If you do not monitor the trap effluent, check it on receipt and once each month. Collect the effluent from the trap during one patient study in a plastic bag and then monitor the activity in the pag by holding the bag against a camera, with the camera adjusted to detect the noble gas, and compare its counts per minute (cpm) to background cpm with no other radioactivity in the area. Keep a record of the date, background cpm, and bag cpm.
- The RSO will establish an action level based on cpm or a multiple of background cpm. If you measure a significant increase in the bag cpm, the trap is breaking down and must be replaced.
- 4. Follow the trap manufacturer's instructions for replacing the trap.

#### APPENDIX O

Model Procedure for Monitoring, Calculating, and Controlling Air Concentrations (See §§ 20.103, 20.106, 20.201, 35.90, and 35.205.)

## SPILLED GAS CLEARANCE TIME (Item 10.13.4)

## 0.4 MODEL PROCEDURE FOR CALCULATING SPILLED GAS CLEARANCE TIME

- 1. Collect the following data:
  - a. A, the highest activity of gas in a single container, in microcuries;
  - b. Measured airflow supply from each vent in the room (if different during heating and cooling seasons, use the lesser value), in milliliters per minute;
  - c. Q, the total room air exhaust determined by measuring, in milliliters per minute, the airflow to each exhaust vent in the room (the exhaust should be vented and not recirculated within the facility); this may be either the normal air exhaust or a specially installed gas exhaust system;
  - d. C, the maximum permissible air concentrations in restricted and unrestricted areas. For Xe-133, the maximum permissible values are 1 x  $10^{-5}$  µCi/ml in restricted areas and 3 x  $10^{-7}$  µCi/ml in unrestricted areas. For other gases, see Appendix B to 10 CFR Part 20; and
  - e. V, the volume of the room in milliliters.
  - 2. For each room make the following calculations:
    - a. The airflow supply should be less than the airflow exhaust to ensure the room is at negative pressure.
    - b. The evacuation time  $t = \frac{-V}{Q} \times \ln (C \times V/A)$ .