

NUREG-0020  
Vol. 10, No. 3  
March 1986

---

# LICENSED OPERATING REACTORS

STATUS SUMMARY REPORT  
DATA AS OF 02-28-86

---

UNITED STATES NUCLEAR REGULATORY COMMISSION



8605210414 860430  
PDR NUREG  
0020 R  
PDR

Available from

NRC/GPO Sales Program

Superintendent of Documents  
Government Printing Office  
Washington, D. C. 20402

A year's subscription consists of 12 issues for  
this publication.

Single copies of this publication  
are available from National Technical  
Information Service, Springfield, VA 22161

Microfiche of single copies are  
available from NRC/GPO Sales Program  
Washington, D. C. 20555

NUREG-0020  
Vol. 10, No. 3  
March 1986

---

---

# LICENSED OPERATING REACTORS

## STATUS SUMMARY REPORT

DATA AS OF 02-28-86

---

---

Manuscript Completed: April 1986  
Date Published: April 1986

OFFICE OF RESOURCE MANAGEMENT  
U.S. NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555



#### STATEMENT OF PURPOSE

The U.S. Nuclear Regulatory Commission's monthly LICENSED OPERATING REACTORS Status Summary Report provides data on the operation of nuclear units as timely and accurately as possible. This information is collected by the Office of Resource Management, from the Headquarters Staff of NRC's Office of Inspection and Enforcement, from NRC's Regional Offices, and from utilities. Since all of the data concerning operation of the units is provided by the utility operators less than two weeks after the end of the month, necessary corrections to published information are shown on the ERRATA page.

This report is divided into three sections: the first contains monthly highlights and statistics for commercial operating units, and errata from previously reported data; the second is a compilation of detailed information on each unit, provided by NRC Regional Offices, IE Headquarters and the Utilities; and the third section is an appendix for miscellaneous information such as spent fuel storage capability, reactor years of experience and non-power reactors in the United States.

The percentage computations, Items 20 through 24 in Section 2, the vendor capacity factors on page 1-7, and actual vs. potential energy production on Page 1-2 are computed using actual data for the period of consideration. The percentages listed in power generation on Page 1-2 are computed as an arithmetic average. The factors for the life-span of each unit (the "Cumulative" column) are reported by the utility and are not entirely re-computed by NRC. Utility power production data is checked for consistency with previously submitted statistics.

It is hoped this status report proves informative and helpful to all agencies and individuals interested in analyzing trends in the nuclear industry which might have safety implications, or in maintaining an awareness of the U.S. energy situation as a whole.

## TABLE OF CONTENTS

	PAGE
GLOSSARY	ii
INDEX TO LICENSED UNITS	vii

SECTION 1 - CURRENT DATA SUMMARIES

MONTHLY HIGHLIGHTS OF COMMERCIAL NUCLEAR POWER UNITS	1-2
Licensed Power Reactors	1-2
Power Generation	1-2
Actual vs. Potential Energy Production	1-2
Outage Data	1-2
Reasons for Shutdown	1-3
Derated Units	1-3
Shutdowns Greater Than 72 Hours Each	1-3
UNIT AVAILABILITY, CAPACITY, AND FORCED OUTAGE RATE PLOT	1-4
AVERAGE DAILY POWER LEVEL FOR ALL COMMERCIAL OPERATING UNITS	1-5
AVERAGE CAPACITY FACTORS BY VENDOR	
Vendor Plot	1-6
Statistics	1-7
MEMORANDA - SPECIAL INFORMATION	1-8
ERRATA - CORRECTIONS TO PREVIOUSLY REPORTED DATA	1-9

SECTION 2 - OPERATING POWER REACTORS

ARKANSAS 1 THROUGH ZION 2	2-002 through 2-410
For each reactor:	
Operating Status	
Average Daily Power Level (MWe) Plot	
Unit Shutdowns/Reductions	
Summary	
Facility Data	
Inspection Status	
Licensee Reports	

SECTION 3 - APPENDIX

STATUS OF SPENT FUEL STORAGE CAPABILITY	3-2
REACTOR-YEARS OF OPERATION	3-6
NON-POWER REACTORS IN THE U.S.	3-7

## G L O S S A R Y

AVERAGE DAILY POWER LEVEL (MWe)	The net electrical energy generated during the day (measured from 0001 to 2400 hours inclusive) in megawatts hours, divided by 24 hours.
LICENSED THERMAL POWER (Mwt)	The maximum thermal power of the reactor authorized by the NRC, expressed in megawatts.
DATE OF COMMERCIAL OPERATION	Date unit was declared by utility owner to be available for the regular production of electricity; usually related to satisfactory completion of qualification tests as specified in the purchase contract and to accounting policies and practices of utility.
DESIGN ELECTRICAL RATING (DER) (NET MWe)	The nominal net electrical output of the unit specified by the utility and used for the purpose of plant design.
FORCED OUTAGE	An outage required to be initiated no later than the weekend following discovery of an offnormal condition.
FORCED OUTAGE HOURS	The clock hours during the report period that a unit is unavailable due to forced outages.
GROSS ELECTRICAL ENERGY GENERATED (MWh)	Electrical output of the unit during the report period as measured at the output terminals of the turbine generator, in megawatts hours.
GROSS HOURS	The clock hours from the beginning of a specified situation until its end. For outage durations, the clock hours during which the unit is not in power production.
GROSS THERMAL ENERGY GENERATED (MWh)	The thermal energy produced by the unit during the report period as measured or computed by the licensee in megawatt hours.
HOURS GENERATOR ON-LINE	Also, "Unit Service Hours." The total clock hours in the report period during which the unit operated with breakers closed to the station bus. These hours added to the total outage hours experienced by the unit during the report period, shall equal the hours in the report period.
HOURS IN REPORTING PERIOD	For units in power ascension at the end of the period, the gross hours from the beginning of the period or the first electrical production, whichever comes last, to the end of the period.
	For units in commercial operation at the end of the period, the gross hours from the beginning of the period or of commercial operation, whichever comes last, to the end of the period or decommissioning, whichever comes first.

G L O S S A R Y (continued)

HOURS REACTOR CRITICAL	The total clock hours in the report period during which the reactor sustained a controlled chain reaction.
MAXIMUM DEPENDABLE CAPACITY (GROSS) (MDC Gross) (Gross MWe)	Dependable main-unit gross capacity, winter or summer, whichever is smaller. The dependable capacity varies because the unit efficiency varies during the year due to cooling water temperature variations. It is the gross electrical output as measured at the output terminals of the turbine generator during the most restrictive seasonal conditions (usually summer).
MAXIMUM DEPENDABLE CAPACITY (NET) (MDC Net) (Net MWe)	Maximum Dependable Capacity (Gross) less the normal station service loads.
NAMEPLATE RATING (Gross MWe)	The nameplate power designation of the generator in megavolt amperes (MVA) times the nameplate power factor of the generator. NOTE: The nameplate rating of the generator may not be indicative of the maximum or dependable capacity, since some other item of equipment of a lesser rating (e.g., turbine) may limit unit output.
NET ELECTRICAL ENERGY GENERATED	Gross electrical output of the unit measured at the output terminals of the turbine generator during the reporting period, minus the normal station service electrical energy utilization. If this quantity is less than zero, a negative number should be recorded.
OUTAGE	A situation in which no electrical production takes place.
OUTAGE DATE	As reported on Appendix D of Reg. Guide 1.16, the date of the start of the outage. If continued from a previous month, report the same outage date but change "Method of Shutting Down Reactor" to "4 (continuations)" and add a note: "Continued from previous month."
OUTAGE DURATION	The Total clock hours of the outage measured from the beginning of the report period or the outage, whichever comes last, to the end of the report period or the outage, whichever comes first.
OUTAGE NUMBER	A number unique to the outage assigned by the licensee. The same number is reported each month in which the outage is in progress. One format is "76-05" for the fifth outage to occur in 1976.
PERIOD HOURS	See "Hours in Reporting Period."
POWER REDUCTION	A reduction in the Average Daily Power Level of more than 20% from the previous day. All power reductions are defined as outage of zero hours durations for the purpose of computing unit service and availability factors, and forced outage rate.

G L O S S A R Y (continued)

REACTOR AVAILABLE HOURS	The Total clock hours in the report period during which the reactor was critical or was capable of being made critical. (Reactor Reserve Shutdown Hours + Hours Reactor Critical.)
REACTOR AVAILABILITY FACTOR	$\frac{\text{Reactor Available Hours} \times 100}{\text{Period Hours}}$
REACTOR RESERVE SHUTDOWN	The cessation of criticality in the reactor for administrative or other similar reasons when operation could have been continued.
REACTOR RESERVE SHUTDOWN HOURS	The total clock hours in the report period that the reactor is in reserve shutdown mode. NOTE: No credit is given for NRC imposed shutdowns.
REACTOR SERVICE FACTOR	$\frac{\text{Hours Reactor Critical} \times 100}{\text{Period Hours}}$
REPORT PERIOD	Usually, the preceding calender month. Can also be the preceding calendar year, (Year-to-Date), or the life-span of a unit (cumulative).
RESTRICTED POWER LEVEL	Maximum net electrical generation to which the unit is restricted during the report period due to the state of equipment, external conditions, administrative reasons, or a direction by NRC.
SCHEDULED OUTAGE	Planned removal of a unit from service for refueling, inspection, training, or maintenance. Those outages which do not fit the definition of "Forced Outage" perforce are "Scheduled Outages."
STARTUP AND POWER ASCENSION TEST PHASE	Period following initial criticality during which the unit is tested at successively higher levels, culminating with operation at full power for a sustained period and completion of warranty runs. Following this phase, the utility generally considers the unit to be available for commercial operation.
UNIT	The set of equipment uniquely associated with the reactor, including turbine generators, and ancillary equipment, considered as a single electrical energy production facility.
UNIT AVAILABLE HOURS	The total clock hours in the report period during which the unit operated on-line or was capable of such operation. (Unit Reserve Shutdown Hours + Hours Generator On-Line.)

G L O S S A R Y (continued)

UNIT AVAILABILITY FACTOR	<u>Unit Available Hours x 100</u> Period Hours
UNIT CAPACITY FACTORS	
- Using Licensed Thermal Power	<u>Gross Thermal Energy Generated x 100</u> Period Hours x Lic. Thermal Power
- Using Nameplate Rating	<u>Gross Electrical Energy Generated x 100</u> Period Hours x Nameplate Rating
- Using DER	<u>Net Electrical Energy Generated x 100</u> Period Hours x DER
- Using MDC Gross	<u>Gross Electrical Energy Generated x 100</u> Period Hours x MDC Gross
- Using MDC Net	<u>Net Electrical Energy Generated x 100</u> Period Hours x MDC Net
NOTE: if MDC GROSS and/or MDC NET have not been determined, the DER is substituted for this quantity for Unit Capacity Factor calculations.	
UNIT FORCED OUTAGE RATE	<u>Forced Outage Hours</u> Unit Service Hours + Forced Outage Hours
UNIT RESERVE SHUTDOWN	The removal of the unit from on-line operation for economic or other similar reasons when operation could have been continued.
UNIT RESERVE SHUTDOWN HOURS	The total clock hours in the report period during which the unit was in reserve shutdown mode.
UNIT SERVICE FACTOR	<u>Unit Service Hours x 100</u> Period Hours
UNIT SERVICE HOURS	See "Hours Generator On-Line."

NOTE:

At the end of each statement in the Enforcement Summary for any given facility may be found numbers in parentheses. These numbers are related to the inspection, e.g., 8111 (the 11th inspection of the plant in 1981); and the severity level, e.g., 4 (severity level IV). Violations are ranked by severity levels from I through V with level I being the most serious. The severity level is used in the determination of any resulting enforcement action. Gray Book lists severity level by Arabic numbers corresponding to the Roman numerals. Details on the various severity levels and enforcement actions can be found in Appendix C to 10 CFR Part 2 published in the Federal Register of March 9, 1982 pages 9987 through 9995, and as corrected April 14, 1982.

INDEX TO OPERATING POWER REACTORS

PAGE	PAGE		
ARKANSAS 1	2-002	MONTICELLO	2-204
ARKANSAS 2	2-006	NINE MILE POINT 1	2-208
BEAVER VALLEY 1	2-010	NORTH ANNA 1	2-212
BIG ROCK POINT 1	2-014	NORTH ANNA 2	2-216
BROWNS FERRY 1	2-018	OCONEE 1	2-220
BROWNS FERRY 2	2-022	OCONEE 2	2-224
BROWNS FERRY 3	2-026	OCONEE 3	2-228
BRUNSWICK 1	2-030	OYSTER CREEK 1	2-232
BRUNSWICK 2	2-036	PALISADES	2-236
BYRON 1	2-040	PALO VERDE 1	2-242
CALLAWAY 1	2-046	PEACH BOTTOM 2	2-246
CALVERT CLIFFS 1	2-050	PEACH BOTTOM 3	2-250
CALVERT CLIFFS 2	2-054	PILGRIM 1	2-254
CATAWBA 1	2-058	POINT BEACH 1	2-258
COOK 1	2-064	POINT BEACH 2	2-262
COOK 2	2-070	PRAIRIE ISLAND 1	2-266
COOPER STATION	2-074	PRAIRIE ISLAND 2	2-270
CRYSTAL RIVER 3	2-078	QUAD CITIES 1	2-274
DAVIS-BESSE 1	2-082	QUAD CITIES 2	2-278
DIABLO CANYON 1	2-086	RANCHO SECO 1	2-282
DIABLO CANYON 2	2-092	RIVER BEND 1	2-288
DRESDEN 2	2-096	ROBINSON 2	2-292
DRESDEN 3	2-100	SALEM 1	2-296
DUANE ARNOLD	2-104	SALEM 2	2-300
FARLEY 1	2-108	SAN ONOFRE 1	2-304
FARLEY 2	2-112	SAN ONOFRE 2	2-310
FITZPATRICK	2-116	SAN ONOFRE 3	2-316
FORT CALHOUN 1	2-120	SEQUOYAH 1	2-322
FORT ST VRAIN	2-124	SEQUOYAH 2	2-328
GINNA	2-128	ST LUCIE 1	2-334
GRAND GULF 1	2-132	ST LUCIE 2	2-338
HADDAM NECK	2-136	SUMMER 1	2-342
HATCH 1	2-140	SURRY 1	2-346
HATCH 2	2-144	SURRY 2	2-350
INDIAN POINT 2	2-148	SUSQUEHANNA 1	2-354
INDIAN POINT 3	2-152	SUSQUEHANNA 2	2-358
KEWAUNEE	2-156	THREE MILE ISLAND 1	2-362
LA CROSSE	2-160	TROJAN	2-368
LASALLE 1	2-164	TURKEY POINT 3	2-374
LASALLE 2	2-170	TURKEY POINT 4	2-378
LIMERICK 1	2-176	VERMONT YANKEE 1	2-382
MAINE YANKEE	2-180	WASHINGTON NUCLEAR 2	2-386
MCGUIRE 1	2-184	WATERFORD 3	2-390
MCGUIRE 2	2-188	WOLF CREEK 1	2-394
MILLSTONE 1	2-192	YANKEE-ROWE 1	2-398
MILLSTONE 2	2-196	ZION 1	2-402
MILLSTONE 3	2-200	ZION 2	2-406

## **SECTION 1**

### **CURRENT DATA SUMMARIES**

M O N T H L Y   H I G H L I G H T S

*****	91 IN COMMERCIAL OPERATION . . . . .	75,475 CAPACITY MWe (Net)	--Based upon maximum dependable capacity; design elec. rating used if MDC not determined
* LICENSED * (a) 4 IN POWER ASCENSION. . . . .	4,291		
* POWER * ---			
* REACTORS * (b) 95 LICENSED TO OPERATE . . . . .	79,766 TOTAL		
***** (c) 3 LICENSED FOR FUEL LOADING AND LOW POWER TESTING			

MDC NET		DER	DATE	DER
(a) ENRICO FERMI 2 ... 1093	(b) Excludes these plants licensed for operation which are shut down indefinitely	1. DRESDEN 1 ..... 200 2. HUMBOLDT BAY ..... 65 3. TMI 2 ..... 906	(c) SHOREHAM ..... PALO VERDE 2 ..... CATAWBA 2 .....	07/03/85 ..... 820 12/09/85 ..... 1304 02/27/86 ..... 1145
DIABLO CANYON 2 ... 1106				
RIVER BEND ... 936				
MILLSTONE 3 ..... 1156				

*****	REPORT MONTH	PREVIOUS MONTH	YEAR-TO-DATE
* POWER *	1. GROSS ELECTRICAL (MWHE) . . . . .	33,783,723	70,766,130
* GENERATION *	2. NET ELECTRICAL (MWHE). . . . .	32,216,081	67,474,543
*****	3. AVG. UNIT SERVICE FACTOR (%) . . . . .	68.7	69.1
	4. AVG. UNIT AVAILABILITY FACTOR (%) . . . . .	68.7	69.1
	5. AVG. UNIT CAPACITY FACTOR (MDC) (%) . . . . .	64.2	64.6
	6. AVG. UNIT CAPACITY FACTOR (DER) (%) . . . . .	62.7	63.2
	7. FORCED OUTAGE RATE (%). . . . .	10.0	11.0

*****	% OF POTENTIAL PRODUCTION	
* ACTUAL VS. *	1. ENERGY ACTUALLY PRODUCED DURING THIS REPORT PERIOD. . . . . 32,216,081 NET 64.0	
* POTENTIAL *	2. ENERGY NOT PRODUCED DUE TO SCHEDULED OUTAGES (NET). . . . . 10,545,240 MWHe 20.9	
* ENERGY *	3. ENERGY NOT PRODUCED DUE TO FORCED OUTAGES (NET) . . . . . 5,273,377 MWHe 10.5	
* PRODUCTION *	4. ENERGY NOT PRODUCED FOR OTHER REASONS (NET) . . . . . 2,338,902 MWHe 4.6	
POTENTIAL ENERGY PRODUCTION IN THIS PERIOD BY UNITS IN COMMERCIAL OPERATION (Using Maximum Dependable Capacity Net)	50,373,600 MWHe	100.0% TOTAL
5. ENERGY NOT PRODUCED DUE TO NRC-REQUIRED OUTAGES . . . . . 221,760 MWHe		
6. ENERGY NOT PRODUCED DUE TO NRC RESTRICTED POWER LEVELS. . . . . MWHe		0 UNIT(S) WITH NRC RESTRICTION

*****	NUMBER	HOURS	PERCENT OF CLOCK TIME	MWHE LOST PRODUCTION
* OUTAGE *	1. FORCED OUTAGES DURING REPORT PERIOD . . . . . 42	6,031.9	9.9	5,273,377
* DATA *	2. SCHEDULED OUTAGES DURING REPORT PERIOD. . . . . 29	13,105.3	21.5	10,545,240
*****	TOTAL 71	19,137.2	31.4	15,818,617

MWHE LOST PRODUCTION = Down time X maximum dependable capacity net

M O N T H L Y H I G H L I G H T S


			NUMBER	HOURS LOST
*****	A - Equipment Failure . . . . .		32	3,678.8
* REASONS *	B - Maintenance or Test . . . . .		5	645.4
* FOR *	C - Refueling . . . . .		22	11,576.1
* SHUTDOWNS *	D - Regulatory Restriction . . . . .		1	672.0
*****	E - Operator Training & License Examination . . . . .		0	0.0
	F - Administrative . . . . .		2	1,344.0
	G - Operational Error . . . . .		3	85.3
	H - Other . . . . .		6	1,135.6
		TOTAL	71	19,137.2

*****		MDC (MWe Net)	POWER LIMIT (MWe Net)	TYPE
* DERATED *	ARKANSAS 1	836	762	Self-imposed
* UNITS *	BYRON 1	*29	*52	Self-imposed
*****	FORT ST VRAIN	330	115	Self-imposed
	GRAND GULF 1	*08	700	Self-imposed
	SAN ONOFRE 1	436	390	Self-imposed
	WASHINGTON NUCLEAR*	*95	775	Self-imposed

*****	UNIT	REASON	UNIT	REASON	UNIT	REASON	UNIT	REASON
* SHUTDOWNS *	BIG ROCK POINT 1	A	BROWNS FERRY 1	C	BROWNS FERRY 2	C	BROWNS FERRY 3	H
* GREATER *	BRUNSWICK 2	C	BYRON 1	B	COOK 2	A	CRYSTAL RIVER 3	A
* THAN 72 HRS *	DAVIS-BESSE 1	A	DRESDEN 2	A	DRESDEN 3	C	FORT ST VRAIN	D
* EACH *	GINNA	C	GRAND GULF 1	H	HADDAM NECK	C	HATCH 1	C
*****	INDIAN POINT 2	C	LASALLE 1	C	MAINE YANKEE	B	NORTH ANNA 2	C
	OCONEE 1	C	PALISADES	C	PEACH BOTTOM 2	A	PEACH BOTTOM 3	C
	QUAD CITIES 1	C	QUAD CITIES 2	B	RANCHO SECO 1	A	ROBINSON 2	C
	SAN ONOFRE 1	C	SAN ONOFRE 3	A	SEQUOYAH 1	F	SEQUOYAH 2	F
	SURRY 1	A	SURRY 2	H	SUSQUEHANNA 1	C	THREE MILE ISLAND 1	A
	TURKEY POINT 4	C	VERMONT YANKEE 1	C	ZION 2	C		

# Unit Availability, Capacity, Forced Outage

Avg. Unit Percentage as of 02-28-86




## AVERAGE DAILY POWER LEVEL FOR ALL COMMERCIALY OPERATING UNITS

This chart depicts the average daily power level for the units in commercial operation during the month.

The straight line on the graph labelled "SUM OF MDC" is plotted at the value shown by summing the separate maximum dependable capacities of the commercially operating units (in Net MWe). The plot shown below the line is calculated by summing the separate average daily power levels of the same units for each day of the month.

The scale on the left vertical axis runs in 1,000 MWe increments from 0 to 55,000 MWe (Net). The right vertical axis shows the percentage in 10% increments, up to 100% of the "SUM OF MDC".


It should be recognized that the 100% line would be obtainable only if all of the commercially operating units operated at 100% capacity, 24 hours per day, for the entire month. In other words, since any power generator must occasionally shut down to refuel and/or perform needed maintenance, and also since 100% capacity production is not always required by power demands, the 100% line is a theoretical goal and not a practical one.



FEBRUARY 1986

## Vendor Average Capacity Factors

As Of 02-28-86



NOTE: This display of average capacity factors provides a general performance comparison of plants supplied by the four nuclear steam supply system vendors. One must be careful when drawing conclusions regarding the reasons for the performance levels indicated, since plant performance may be affected by unspecified factors such as: (1) various plant designs and models are included for each vendor; (2) turbine/generators and (3) different architect/engineers are also involved.

A V E R A G E   C A P A C I T Y   F A C T O R S   B Y   V E N D O R S

CFMDC	CFMDC	CFMDC	CFMDC
* GENERAL * 0.0 BROWNS FERRY 1	0.0 BROWNS FERRY 2	0.0 BROWNS FERRY 3	97.6 BRUNSWICK 1
* ELECTRIC * 0.0 BRUNSWICK 2	93.0 COOPER STATION	74.0 DRESDEN 2	0.0 DRESDEN 3
***** 77.3 DUANE ARNOLD	100.9 FITZPATRICK	48.6 GRAND GULF 1	0.0 HATCH 1
83.6 HATCH 2	0.0 LASALLE 1	83.7 LASALLE 2	95.1 LIMERICK 1
92.5 MILLSTONE 1	87.3 MONTICELLO	73.6 NINE MILE POINT 1	97.2 OYSTER CREEK 1
73.1 PEACH BOTTOM 2	0.0 PEACH BOTTOM 3	97.7 PILGRIM 1	0.0 QUAD CITIES 1
73.1 QUAD CITIES 2	47.8 SUSQUEHANNA 1	99.6 SUSQUEHANNA 2	0.0 VERMONT YANKEE 1
67.7 WASHINGTON NUCLEAR 2			

CFMDC	CFMDC	CFMDC	CFMDC
* BABCOCK & * 79.3 ARKANSAS 1	0.0 CRYSTAL RIVER 3	0.0 DAVIS-BESSE 1	41.8 OCONEE 1
* WILCOX * 95.1 OCONEE 2	99.1 OCONEE 3	0.0 RANCHO SECO 1	88.5 THREE MILE ISLAND 1
*****			

CFMDC	CFMDC	CFMDC	CFMDC
* COMBUSTION * 96.4 ARKANSAS 2	106.1 CALVERT CLIFFS 1	98.5 CALVERT CLIFFS 2	83.5 FORT CALHOUN 1
* ENGINEERING * 73.7 MAINE YANKEE	98.4 MILLSTONE 2	0.0 PALISADES	102.1 PALO VERDE 1
***** 90.0 SAN ONOFRE 2	38.9 SAN ONOFRE 3	102.0 ST LUCIE 1	102.2 ST LUCIE 2
97.2 WATERFORD 3			

CFMDC	CFMDC	CFMDC	CFMDC
* WESTINGHOUSE* 87.2 BEAVER VALLEY 1	50.5 BYRON 1	93.7 CALLAWAY 1	95.5 CATAWBA 1
***** 89.3 COOK 1	58.7 COOK 2	91.7 DIABLO CANYON 1	99.0 FARLEY 1
100.1 FARLEY 2	19.7 GINNA	0.0 HADDAM NECK	0.0 INDIAN POINT 2
98.4 INDIAN POINT 3	101.1 KEWAUNEE	88.1 MCGUIRE 1	99.6 MCGUIRE 2
90.9 NORTH ANNA 1	61.1 NORTH ANNA 2	101.0 POINT BEACH 1	100.1 POINT BEACH 2
65.1 PRAIRIE ISLAND 1	106.1 PRAIRIE ISLAND 2	0.0 ROBINSON 2	79.1 SALEM 1
88.5 SALEM 2	0.0 SAN ONOFRE 1	0.0 SEQUOYAH 1	0.0 SEQUOYAH 2
88.1 SUMMER 1	69.4 SURRY 1	65.5 SURRY 2	94.3 TROJAN
94.1 TURKEY POINT 3	0.0 TURKEY POINT 4	89.9 WOLF CREEK 1	103.2 YANKEE-ROWE 1
97.8 ZION 1	65.4 ZION 2		

Units excluded are:

\*\*\*\*\*  
 \* OTHER INFO \* BIG ROCK POINT  
 DRESDEN 1  
 FORT ST VRAIN  
 HUMBOLDT BAY  
 LACROSSE  
 THREE MILE ISLAND 2

Capacity factor in this page, denoted as CFMDC, is a function of the net maximum dependable capacity. See the corresponding definition in the glossary. The vendor averages are computed by the formula:

Net Electrical Energy Produced by Vendor  $\times 100\%$   
 Potential Electrical Production by Vendor in this Month

	GE BWRS	West PWRs	Comb PWRs	B&W PWRs	All PWRs
NET ELECTRICAL PRODUCTION.....	8,489,779	15,207,111	6,189,583	2,271,147	23,667,841
MDC NET.....	24,552	32,229	11,501	6,746	50,476
CFMDC.....	51.5	70.2	83.8	50.1	70.5

MEMORANDA

THE FOLLOWING UNITS USE WEIGHTED AVERAGES TO CALCULATE CAPACITY FACTORS:

ITEM 22

BIG ROCK POINT 1  
CALVERT CLIFFS 1 & 2  
FARLEY 1  
FITZPATRICK  
FORT CALHOUN 1  
INDIAN POINT 2\*  
KEWAUNEE  
OYSTER CREEK 1  
POINT BEACH 1 & 2  
THREE MILE ISLAND 1  
TURKEY POINT 3 & 4

ITEM 22 & 23

GINNA  
HADDAM NECK (CONNECTICUT YANKEE)  
MAINE YANKEE  
MILLSTONE 2  
OCONEE 1, 2, & 3  
YANKEE-ROWE 1

\*COMPUTED SINCE 7/1/74, THE DATE OF COMPLETION OF A 100 DAY - 100% POWER OPERATION TEST.

THE FOLLOWING UNITS USE THE DATE OF FIRST ELECTRICAL GENERATION INSTEAD OF COMMERCIAL OPERATION,  
FOR THEIR CUMULATIVE DATA:

ITEMS 20 THROUGH 24

COOK 1 & 2  
BEAVER VALLEY 1  
SAN ONOFRE 1

ITEM 24 ONLY

BIG ROCK POINT 1

ERRATA  
CORRECTIONS TO PREVIOUSLY REPORTED DATA

NOTE: THESE CHANGES ARE REFLECTED IN THE DATA CONTAINED IN THE CURRENT REPORT

REVISED MONTHLY HIGHLIGHTS

Report Period DEC 1985

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* POINT BEACH 2 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	IER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
3	12/28/85	F	28.1	B			WB	ZZZZZ	UNIT SHUT DOWN TO REPAIR A WELD CRACK IN THE COMPONENT COOLING WATER SUPPLY LINE TO THE "A" REACTOR COOLANT PUMP LUBE OIL COOLER.
4	12/31/85	F	19.6	A	3	85-005	EB	ZZZZZ	PHASE-TO-GROUND FAULT IN THE A0 POWER SURGE ARRESTER OF BUS SECTION 4 RESULTING IN A UNIT TRIP.

Report Period FEB 1986

PAGE 1-9

**SECTION 2**

**OPERATING  
POWER  
REACTORS**

1. Docket: 50-313 OPERATING STATUS  
2. Reporting Period: 02/01/86 Outage + On-line Hrs: 672.0  
3. Utility Contact: J. N. GOBELL (501) 964-3251  
4. Licensed Thermal Power (MWt): 2568  
5. Nameplate Rating (Gross MWe): 1003 X 0.9 = 903  
6. Design Electrical Rating (Net MWe): 850  
7. Maximum Dependable Capacity (Gross MWe): 883  
8. Maximum Dependable Capacity (Net MWe): 836  
9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE  
10. Power Level To Which Restricted, If Any (Net MWe): 762

10. Power Level To Which Restricted, If Any (Net MWe): 762

11. Reasons for Restrictions, If Any: \_\_\_\_\_

## TUBE SUPPORT PLATE CREVICE.

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	672.0	1,416.0	98,155.0
13. Hours Reactor Critical	618.4	984.0	66,647.1
14. Rx Reserve Shtdwn Hrs	.0	.0	5,044.0
15. Hrs Generator On-Line	612.6	975.8	65,233.9
16. Unit Reserve Shtdwn Hrs	.0	.0	817.5
17. Gross Therm Ener (MWH)	1,363,892	2,134,426	154,719,188
18. Gross Elec Ener (MWH)	467,708	729,145	51,163,870
19. Net Elec Ener (MWH)	445,375	691,623	48,744,499
20. Unit Service Factor	91.2	68.9	66.5
21. Unit Avail Factor	91.2	68.9	67.3
22. Unit Cap Factor (MDC Net)	79.3	58.4	59.4
23. Unit Cap Factor (DER Net)	78.0	57.5	58.4
24. Unit Forced Outage Rate	8.8	31.1	15.5
25. Forced Outage Hours	59.4	440.2	12,000.7
26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):			
REFUELING: 08/22/86 - 10 WEEKS.			


27. If currently shutdown estimated startup date: 10/1

REFUELING: 08/22/86 - 10 WEEKS.

\*\*\*\*\*  
\* ARKANSAS 1 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MW<sub>e</sub>) PLOT

ARKANSAS 1



FEBRUARY 1986

Report Period FEB 1986

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* ARKANSAS 1 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
8603	01/15/86	F	59.4	A	4	86-001	EK	DG	STARTED MONTH OFF-LINE COMPLETING REPAIRS TO THE EMERGENCY DIESEL GENERATOR.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*

Type	Reason	Method	System & Component	
F-Forced	A-Equip Failure	F-Admin	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	2-Manual Scram	Instructions for
	C-Refueling	H-Other	3-Auto Scram	Preparation of
	D-Regulatory Restriction		4-Continued	Data Entry Sheet
	E-Operator Training		5-Reduced Load	Licensee Event Report
	& License Examination		9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* ARKANSAS 1 \*  
\*\*\*\*\*

#### FACILITY DATA

Report Period FEB 1986

#### FACILITY DESCRIPTION

LOCATION STATE.....ARKANSAS  
COUNTY.....POPE  
DIST AND DIRECTION FROM NEAREST POPULATION CTR...6 MI WNW OF RUSSELLVILLE, AR  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...AUGUST 6, 1974  
DATE ELEC ENER 1ST GENER...AUGUST 17, 1974  
DATE COMMERCIAL OPERATE....DECEMBER 19, 1974  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER....DARDANELLE RESERVOIR  
ELECTRIC RELIABILITY COUNCIL.....SOUTHWEST POWER POOL

#### UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....ARKANSAS POWER & LIGHT  
CORPORATE ADDRESS.....NINTH & LOUISIANA STREETS  
LITTLE ROCK, ARKANSAS 72203  
CONTRACTOR  
ARCHITECT/ENGINEER.....BECHTEL  
NUC STEAM SYS SUPPLIER...BABCOCK & WILCOX  
CONSTRUCTOR.....BECHTEL  
TURBINE SUPPLIER.....WESTINGHOUSE

#### REGULATORY INFORMATION

IE REGION RESPONSIBLE.....IV  
IE RESIDENT INSPECTOR.....B. JOHNSON  
LICENSING PROJ MANAGER.....G. VISSING  
DOCKET NUMBER.....50-313  
LICENSE & DATE ISSUANCE....DPR-51, MAY 21, 1974  
PUBLIC DOCUMENT ROOM.....ARKANSAS TECH UNIVERSITY  
RUSSELLVILLE, ARKANSAS 72801

#### I N S P E C T I O N     S T A T U S

#### INSPECTION SUMMARY

INSPECTION CONDUCTED ON JAN. 1-31, 1986 (86-02) ROUTINE, UNANNOUNCED INSPECTION INCLUDING OPERATIONAL SAFETY VERIFICATION, MAINTENANCE, SURVEILLANCE, SEISMIC PIPE SUPPORT REVIEW, CONDENSATE STORAGE TANK CONSTRUCTION, AND FOLLOWUP ON THREE MILE ISLAND ACTION PLAN REQUIREMENTS. WITHIN THE AREAS INSPECTED, ONE VIOLATION WAS IDENTIFIED (FAILURE TO FOLLOW A QUALITY CONTROL PROCEDURE IN SEISMIC PIPE SUPPORT INSPECTION).

#### ENFORCEMENT SUMMARY

CONTRARY TO TECHNICAL SPECIFICATION 6.8.1, THE LICENSEE FAILED TO ESTABLISH CONSISTENT PROCEDURES FOR THE OPERATION OF THE OUTSIDE AIR DAMPERS ON THE CONTROL ROOM EMERGENCY RECIRCULATION AND FILTRATION UNITS. CONTRARY TO TECHNICAL SPECIFICATION 6.8.1, THE LICENSEE FAILED TO ESTABLISH CONSISTENT PROCEDURES FOR THE OPERATION OF THE OUTSIDE AIR DAMPERS ON THE CONTROL ROOM EMERGENCY RECIRCULATION AND FILTRATION UNITS.  
(8502 4)

#### OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

Report Period FEB 1986

I N S P E C T I O N      S T A T U S - (CONTINUED)

\*\*\*\*\*  
X                   ARKANSAS 1  
\*\*\*\*\*

OTHER ITEMS

POWER LIMITED TO ABOUT 88% DUE TO HIGH INDICATED WATER LEVEL IN THE A OTSG CAUSED BY SECOUNDARY SIDE FOULING.  
FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

POWER OPERATION.

LAST IE SITE INSPECTION DATE: JANUARY 1-31, 1986

INSPECTION REPORT NO: 50-313/86-02

R E P O R T S   F R O M   L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
85-012	11/21/85	1/9/86	FIRE SUPPERSSIORY SYSTEM SPRINKLER HEAD MISSING.


=====

1. Docket: 50-368 OPERATING STATUS  
 2. Reporting Period: 02/01/86 Outage + On-line Hrs: 672.0  
 3. Utility Contact: D. F. HARRISON (501) 964-3743  
 4. Licensed Thermal Power (MWh): 2815  
 5. Nameplate Rating (Gross MWe): 943  
 6. Design Electrical Rating (Net MWe): 912  
 7. Maximum Dependable Capacity (Gross MWe): 897  
 8. Maximum Dependable Capacity (Net MWe): 858  
 9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE  
 10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_  
 11. Reasons for Restrictions, If Any:  
NONE  
 12. Report Period Hrs 672.0 MONTH 1,416.0 YEAR 51,984.0 CUMULATIVE  
 13. Hours Reactor Critical 627.7 1,371.7 37,053.7  
 14. Rx Reserve Shtdwn Hrs .0 .0 1,430.1  
 15. Hrs Generator On-Line 626.2 1,370.2 35,805.9  
 16. Unit Reserve Shtdwn Hrs .0 .0 75.0  
 17. Gross Therm Ener (MWH) 1,745,079 3,836,038 90,873,388  
 18. Gross Elec Ener (MWH) 582,420 1,282,239 29,771,481  
 19. Net Elec Ener (MWH) 555,757 1,225,353 28,334,469  
 20. Unit Service Factor 93.2 96.8 68.9  
 21. Unit Avail Factor 93.2 96.8 69.0  
 22. Unit Cap Factor (MDC Net) 96.4 100.9 63.5  
 23. Unit Cap Factor (DER Net) 90.7 94.9 59.8  
 24. Unit Forced Outage Rate 6.8 3.2 16.4  
 25. Forced Outage Hours 45.8 45.8 7,003.0  
 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
REFUELING: 06/13/86 - 7 WEEKS.  
 27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\* ARKANSAS 2 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

ARKANSAS 2



FEBRUARY 1986

Report Period FEB 1986

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* ARKANSAS 2 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
8601	02/11/86	F	45.8	A	3	86-01	SB	ISV	THE UNIT TRIPPED ON LOW DNBR FOLLOWING THE INADVERTENT CLOSURE OF AN MSIV. THE CLOSURE WAS APPARENTLY CAUSED BY THE FAILURE OF A MOTOR DRIVEN RELAY.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*

ARKANSAS 2 OPERATED WITH 1 OUTAGE DUE TO EQUIPMENT FAILURE IN FEBRUARY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	Instructions for Preparation of
	C-Refueling	H-Other	Data Entry Sheet
	D-Regulatory Restriction	4-Continued	Licensee Event Report
	E-Operator Training & License Examination	5-Reduced Load 9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* ARKANSAS 2 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1986

FACILITY DESCRIPTION

LOCATION  
STATE.....ARKANSAS  
COUNTY.....POPE  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...6 MI WNW OF  
RUSSELLVILLE, AR  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...DECEMBER 5, 1978  
DATE ELEC ENER 1ST GENER...DECEMBER 26, 1978  
DATE COMMERCIAL OPERATE....MARCH 26, 1980  
CONDENSER COOLING METHOD...COOLING TOWER  
CONDENSER COOLING WATER....DARDANELLE RESERVOIR  
ELECTRIC RELIABILITY  
COUNCIL.....SOUTHWEST POWER POOL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....ARKANSAS POWER & LIGHT  
CORPORATE ADDRESS.....NINTH & LOUISIANA STREETS  
LITTLE ROCK, ARKANSAS 72203

CONTRACTOR  
ARCHITECT/ENGINEER.....BECHTEL  
NUC STEAM SYS SUPPLIER...COMBUSTION ENGINEERING  
CONSTRUCTOR.....BECHTEL  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....IV  
IE RESIDENT INSPECTOR.....W. JOHNSON  
LICENSING PROJ MANAGER.....R. LEE  
DOCKET NUMBER.....50-368  
LICENSE & DATE ISSUANCE....NPF-6, SEPTEMBER 1, 1978  
PUBLIC DOCUMENT ROOM.....ARKANSAS TECH UNIVERSITY  
RUSSELLVILLE, ARKANSAS 72801

I N S P E C T I O N     S T A T U S

INSPECTION SUMMARY

INSPECTION CONDUCTED JANUARY 1-31, 1986 (86-02) ROUTINE, UNANNOUNCED INSPECTION INCLUDING OPERATIONAL SAFETY VERIFICATION, MAINTENANCE, SURVEILLANCE, FOLLOWUP ON A PREVIOUSLY IDENTIFIED ITEM, FOLLOWUP ON A LICENSEE EVENT REPORT, CONDENSATE STORAGE TANK CONSTRUCTION, AND FOLLOWUP ON THREE MILE ISLAND ACTION PLAN REQUIREMENTS. WITHIN THE AREAS INSPECTED, ONE VIOLATION WAS IDENTIFIED (PUMP TEST PROCEDURE DID NOT MEET REQUIREMENTS OF ASME SECTION XI).

ENFORCEMENT SUMMARY

CONTRARY TO TECHNICAL SPECIFICATION 6.8.1, THE LICENSEE FAILED TO MAINTAIN A MANUAL VALVE LOCKED AS REQUIRED, IN THAT THE CHAIN WAS SEVERED.  
(8502 5)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

Report Period FEB 1986

I N S P E C T I O N      S T A T U S - (CONTINUED)

\*\*\*\*\*  
\*                   ARKANSAS 2           \*  
\*\*\*\*\*

OTHER ITEMS

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

POWER OPERATION

LAST IE SITE INSPECTION DATE: JANUARY 1-31, 1986

INSPECTION REPORT NO: 50-368/86-02

R E P O R T S   F R O M   L I C E N S E E

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
85-027	12/17/85	01/18/86	REACTOR TRIP CIRCUIT BREAKER UNDervoltage DEVICES OUND IN MID-POSITION. F

1. Docket: 50-334 OPERATING STATUS  
 2. Reporting Period: 02/01/86 Outage + On-line Hrs: 672.0  
 3. Utility Contact: P. A. SMITH (412) 643-1825  
 4. Licensed Thermal Power (MWh): 2652  
 5. Nameplate Rating (Gross MWe): 1026 X 0.9 = 923  
 6. Design Electrical Rating (Net MWe): 835  
 7. Maximum Dependable Capacity (Gross MWe): 860  
 8. Maximum Dependable Capacity (Net MWe): 810  
 9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_  
 11. Reasons for Restrictions, If Any:  
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>672.0</u>	<u>1,416.0</u>	<u>86,184.0</u>
13. Hours Reactor Critical	<u>628.6</u>	<u>1,372.6</u>	<u>46,977.5</u>
14. Rx Reserve Shtdn Hrs	<u>.0</u>	<u>.0</u>	<u>4,482.7</u>
15. Hrs Generator On-Line	<u>627.3</u>	<u>1,371.3</u>	<u>45,506.2</u>
16. Unit Reserve Shtdn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,543,257</u>	<u>3,492,824</u>	<u>105,516,246</u>
18. Gross Elec Ener (MWH)	<u>504,280</u>	<u>1,143,920</u>	<u>33,925,360</u>
19. Net Elec Ener (MWH)	<u>474,900</u>	<u>1,080,250</u>	<u>31,616,463</u>
20. Unit Service Factor	<u>93.3</u>	<u>96.8</u>	<u>55.3</u>
21. Unit Avail Factor	<u>93.3</u>	<u>96.8</u>	<u>55.3</u>
22. Unit Cap Factor (MDC Net)	<u>87.2</u>	<u>94.2</u>	<u>48.8</u>
23. Unit Cap Factor (DER Net)	<u>84.6</u>	<u>91.4</u>	<u>47.7</u>
24. Unit Forced Outage Rate	<u>6.7</u>	<u>3.2</u>	<u>23.4</u>
25. Forced Outage Hours	<u>44.7</u>	<u>44.7</u>	<u>18,534.9</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


FIFTH REFUELING, 05/19/86, SCHEDULED 93 DAYS.

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\* BEAVER VALLEY 1 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

BEAVER VALLEY 1



FEBRUARY 1986

Report Period FEB 1986

## UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* BEAVER VALLEY 1 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
1	02/07/86	S	0.0	B	5		CD	VALVEX	THE STATION REDUCED POWER TO PERFORM THE MAIN STEAM TRIP VALVE TEST. THE TEST RESULTS WERE SATISFACTORY AND THE STATION WAS RETURNED TO A NOMINAL 100 PERCENT POWER LEVEL.
2	02/10/86	F	44.7	A	3	86-001	EG	ELECON	AT 1927 HOURS ON THE 10TH, A TURBINE TRIP/REACTOR TRIP OCCURRED CAUSED BY A FAILURE OF VITAL BUS #3. THE REACTOR WAS RETURNED TO CRITICALITY AT 1450 HOURS AND THE STATION RETURNED TO SERVICE AT 1610 HOURS ON THE 12TH.
3	02/12/86	F	0.0	A	5		HF	PIPEXX	POWER LEVEL WAS HELD AT A REDUCED LEVEL DUE TO A LEAKING TURBINE PLANT COMPONENT COOLING WATERLINE. THE LINE WAS REPAIRED AND POWER LEVEL HAS RETURNED TO A NOMINAL 100 PERCENT.
4	02/14/86	F	0.0	B	5		CH	PUMPXX	POWER LEVEL WAS REDUCED SO THAT MAINTENANCE COULD BE PERFORMED ON FEEDWATER PUMP (FW-P-1B). REPAIRS WERE COMPLETED AT 0913 HOURS ON THE 18TH AND POWER LEVEL HAS RETURNED TO A NOMINAL 100 PERCENT.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	Instructions for Preparation of Data Entry Sheet
	C-Refueling	H-Other	4-Continued
	D-Regulatory Restriction		5-Reduced Load
	E-Operator Training & License Examination	9-Other	Licensee Event Report (LER) File (NUREG-0161)

\*\*\*\*\*  
\* BEAVER VALLEY 1 \*  
\*\*\*\*\*

#### FACILITY DATA

Report Period FEB 1986

##### FACILITY DESCRIPTION

LOCATION  
STATE.....PENNSYLVANIA  
  
COUNTY.....BEAVER  
  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...5 MI E OF  
E. LIVERPOOL, OH  
  
TYPE OF REACTOR.....PWR  
  
DATE INITIAL CRITICALITY...MAY 10, 1976  
  
DATE ELEC ENER 1ST GENER...JUNE 14, 1976  
  
DATE COMMERCIAL OPERATE....OCTOBER 1, 1976  
  
CONDENSER COOLING METHOD...COOLING TOWER  
  
CONDENSER COOLING WATER....OHIO RIVER  
  
ELECTRIC RELIABILITY  
COUNCIL.....EAST CENTRAL AREA  
RELIABILITY COORDINATION  
AGREEMENT

##### UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....DUQUESNE LIGHT  
  
CORPORATE ADDRESS.....ONE OXFORD CENTRE, 301 GRANT STREET  
PITTSBURGH, PENNSYLVANIA 15279  
  
CONTRACTOR  
ARCHITECT/ENGINEER.....STONE & WEBSTER  
  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
  
CONSTRUCTOR.....STONE & WEBSTER  
  
TURBINE SUPPLIER.....WESTINGHOUSE

##### REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I  
  
IE RESIDENT INSPECTOR.....W. TROSKOSKI  
  
LICENSING PROJ MANAGER.....P. TAM  
DOCKET NUMBER.....50-334  
  
LICENSE & DATE ISSUANCE....DPR-66, JULY 2, 1976  
  
PUBLIC DOCUMENT ROOM.....B.F. JONES MEMORIAL LIBRARY  
633 FRANKLIN AVENUE  
ALIQUIPPA, PA 15001

##### INSPECTION STATUS

##### INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

##### ENFORCEMENT SUMMARY

10 CFR 50, APPENDIX R, SECTION III.J, REQUIRES THAT EMERGENCY LIGHTING UNITS WITH AT LEAST AN 8-HOUR BATTERY POWER SUPPLY SHALL BE PROVIDED IN ALL AREAS NEEDED FOR OPERATION OF SAFE SHUTDOWN EQUIPMENT AND IN ACCESS AND EGRESS ROUTES THERETO. CONTRARY TO THE ABOVE, AS OF NOVEMBER 22, 1985, THE EMERGENCY LIGHTING UNITS WITH AT LEAST AN 8-HOUR BATTERY POWER SUPPLY WERE NOT PROVIDED IN THE FOLLOWING SAFE SHUTDOWN ACCESS AND EGRESS ROUTES: 1) CLEAN SHOP (FIRE AREA SH-1); 2) STAIRWAY VESTIBULE IMMEDIATELY OUTSIDE THE CONTROL ROOM IN THE SERVICE BUILDING; 3) THE CORRIDOR BETWEEN THE AFOREMENTIONED STAIRWAY (ITEM 2) AND THE SERVICE BUILDING ROOF; 4) THE SERVICE BUILDING ROOF AND THE YARD AREA BETWEEN THE SERVICE BUILDING AND THE DIESEL GENERATOR BUILDING.  
(8502 4)

##### OTHER ITEMS

SYSTEMS AND COMPONENTS:

Report Period FEB 1986

I N S P E C T I O N      S T A T U S - (CONTINUED)

\*\*\*\*\*  
\* BEAVER VALLEY 1 \*  
\*\*\*\*\*

OTHER ITEMS

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S   F R O M   L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
-----			
NO INPUT PROVIDED.			
-----			


=====

1. Docket: 50-155 OPERATING STATUS  
 2. Reporting Period: 02/01/86 Outage + On-line Hrs: 672.0  
 3. Utility Contact: LINDA BALCH (616) 547-6537  
 4. Licensed Thermal Power (MWe): 240  
 5. Nameplate Rating (Gross MWe): 70.6 X 0.85 = 60  
 6. Design Electrical Rating (Net MWe): 72  
 7. Maximum Dependable Capacity (Gross MWe): 73  
 8. Maximum Dependable Capacity (Net MWe): 69  
 9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE  
 10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_  
 11. Reasons for Restrictions, If Any:  
NONE  
 12. Report Period Hrs      MONTH      YEAR      CUMULATIVE  
672.0      1,416.0      200,947.0  
 13. Hours Reactor Critical      544.4      1,288.4      142,520.2  
 14. Rx Reserve Shtdwn Hrs      .0      .0      .0  
 15. Hrs Generator On-Line      534.8      1,278.8      139,919.8  
 16. Unit Reserve Shtdwn Hrs      .0      .0      .0  
 17. Gross Therm Ener (MMH)      110,767      270,363      26,315,632  
 18. Gross Elec Ener (MMH)      35,301      85,754      8,326,942  
 19. Net Elec Ener (MMH)      33,431      81,761      7,873,924  
 20. Unit Service Factor      79.6      90.3      69.6  
 21. Unit Avail Factor      79.6      90.3      67.6  
 22. Unit Cap Factor (MDC Net)      72.1      83.7      58.3\*  
 23. Unit Cap Factor (DER Net)      69.1      80.2      54.4  
 24. Unit Forced Outage Rate      20.4      9.7      15.1  
 25. Forced Outage Hours      137.2      137.2      11,486.3  
 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE  
 27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\* BIG ROCK POINT 1 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

BIG ROCK POINT 1



FEBRUARY 1986

\* Item calculated with a Weighted Average

Report Period FEB 1986

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* BIG ROCK POINT 1 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System Component	Cause & Corrective Action to Prevent Recurrence
86-01	02/11/86	F	137.2	A	1	86-02		PLANT EXCEEDED TECHNICAL SPECIFICATION UNIDENTIFIED LEAKAGE RATE. REACTOR DEPRESSURIZATION SYSTEM VALVES WERE FOUND TO BE THE SOURCE OF LEAKAGE. VALVE WERE REPAIRED AND PLANT RETURNED TO SERVICE.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*

BIG ROCK POINT 1 OPERATED WITH 1 OUTAGE DUE TO EQUIPMENT FAILURE IN FEBRUARY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	Instructions for Preparation of
	C-Refueling	H-Other	Data Entry Sheet
	D-Regulatory Restriction	4-Continued	Licensee Event Report
	E-Operator Training & License Examination	5-Reduced Load	(LER) File (NUREG-0161)
		9-Other	

\*\*\*\*\*  
\* BIG ROCK POINT 1 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1986

FACILITY DESCRIPTION

LOCATION  
STATE.....MICHIGAN

COUNTY.....CHARLEVOIX

DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...4 MI NE OF  
CHARLEVOIX, MICH

TYPE OF REACTOR.....BWR

DATE INITIAL CRITICALITY...SEPTEMBER 27, 1962

DATE ELEC ENER 1ST GENER...DECEMBER 8, 1962

DATE COMMERCIAL OPERATE....MARCH 29, 1963

CONDENSER COOLING METHOD...ONCE THRU

CONDENSER COOLING WATER....LAKE MICHIGAN

ELECTRIC RELIABILITY

COUNCIL.....EAST CENTRAL AREA  
RELIABILITY COORDINATION  
AGREEMENT

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....CONSUMERS POWER

CORPORATE ADDRESS.....212 WEST MICHIGAN AVENUE  
JACKSON, MICHIGAN 49201

CONTRACTOR  
ARCHITECT/ENGINEER.....BECHTEL

NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC

CONSTRUCTOR.....BECHTEL

TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III

IE RESIDENT INSPECTOR.....S. GUTHRIE

LICENSING PROJ MANAGER.....T. ROTELLA  
DOCKET NUMBER.....50-155

LICENSE & DATE ISSUANCE....DPR-6, AUGUST 30, 1962

PUBLIC DOCUMENT ROOM.....NORTH CENTRAL MICHIGAN COLLEGE  
1515 HOWARD STREET  
PETOSKEY, MICHIGAN 49770

I N S P E C T I O N     S T A T U S

INSPECTION SUMMARY

INSPECTION ON JULY 30 - OCTOBER 31 (85014): ROUTINE, UNANNOUNCED INSPECTION CONDUCTED BY THE SENIOR RESIDENT INSPECTOR AND A REGION III INSPECTOR OF LICENSEE ACTIONS ON PREVIOUS INSPECTION FINDINGS, OPERATIONAL SAFETY, MAINTENANCE OPERATION, LICENSEE EVENT REPORT FOLLOWUP, LICENSING ACTIVITIES, HEADQUARTERS REQUESTS, AND TMI ACTION ITEM FOLLOWUP. THE INSPECTION INVOLVED A TOTAL OF 280 INSPECTOR HOURS BY TWO NRC INSPECTORS. OF THE SIX AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED IN FIVE AREAS. SEVERAL VIOLATIONS WERE IDENTIFIED IN THE REMAINING AREA AND THESE WERE DISCUSSED WITH THE LICENSEE IN AN ENFORCEMENT CONFERENCE. THESE VIOLATIONS AND THE RESULTANT ENFORCEMENT ACTION WILL BE ADDRESSED UNDER SEPARATE COVER.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

Report Period FEB 1986

I N S P E C T I O N      S T A T U S - (CONTINUED)

\*\*\*\*\*  
\* BIG ROCK POINT 1 \*  
\*\*\*\*\*

OTHER ITEMS

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

OPERATING ROUTINELY

LAST IE SITE INSPECTION DATE: FEBRUARY 18 - 21, 1986

INSPECTION REPORT NO: 86005

R E P O R T S   F R O M   L I C E N S E E


NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
85-09	12/07/85	01/06/86	MANUAL REACTOR TRIP

1. Docket: 50-259 OPERATING STATUS  
 2. Reporting Period: 02/01/86 Outage + On-line Hrs: 672.0  
 3. Utility Contact: TED THOM (205) 729-0834  
 4. Licensed Thermal Power (MWt): 3293  
 5. Nameplate Rating (Gross MWe): 1280 X 0.9 = 1152  
 6. Design Electrical Rating (Net MWe): 1065  
 7. Maximum Dependable Capacity (Gross MWe): 1098  
 8. Maximum Dependable Capacity (Net MWe): 1065  
 9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE  
 10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_  
 11. Reasons for Restrictions, If Any:  
NONE  
 12. Report Period Hrs MONTH 672.0 YEAR 1,416.0 CUMULATIVE 101,522.0  
 13. Hours Reactor Critical .0 .0 59,520.9  
 14. Rx Reserve Shtdwn Hrs .0 .0 6,996.8  
 15. Hrs Generator On-Line .0 .0 58,276.4  
 16. Unit Reserve Shtdwn Hrs .0 .0 .0  
 17. Gross Therm Ener (MWH) 0 0 167,963,338  
 18. Gross Elec Ener (MWH) 0 0 55,398,130  
 19. Net Elec Ener (MWH) -3,501 -8,072 53,708,937  
 20. Unit Service Factor .0 .0 57.4  
 21. Unit Avail Factor .0 .0 57.4  
 22. Unit Cap Factor (MDC Net) .0 .0 49.7  
 23. Unit Cap Factor (DER Net) .0 .0 49.7  
 24. Unit Forced Outage Rate .0 .0 23.6  
 25. Forced Outage Hours .0 .0 18,041.1  
 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE  
 27. If Currently Shutdown Estimated Startup Date: 09/14/86

\*\*\*\*  
 \* BROWNS FERRY 1 \*  
 \*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

BROWNS FERRY 1



FEBRUARY 1986

Report Period FEB 1986

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* BROWNS FERRY 1 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System Component	Cause & Corrective Action to Prevent Recurrence
315	06/01/85	S	672.0	C	4			END OF CYCLE 6 REFUEL OUTAGE CONTINUES.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
BROWNS FERRY 1 REMAINS SHUTDOWN IN A CONTINUING REFUELING OUTAGE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	1-Manual
S-Sched	B-Maint or Test	G-Oper Error	2-Manual Scram
	C-Refueling	H-Other	3-Auto Scram
	D-Regulatory Restriction		4-Continued
	E-Operator Training & License Examination		5-Reduced Load
		9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161)

\*\*\*\*\*  
\* BROWNS FERRY 1 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1986

FACILITY DESCRIPTION

LOCATION  
STATE.....ALABAMA  
COUNTY.....LIMESTONE  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...10 MI NW OF  
DECATUR, ALA  
TYPE OF REACTOR.....BWR  
DATE INITIAL CRITICALITY...AUGUST 17, 1973  
DATE ELEC ENER 1ST GENER...OCTOBER 15, 1973  
DATE COMMERCIAL OPERATE....AUGUST 1, 1974  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER....TENNESSEE RIVER  
ELECTRIC RELIABILITY  
COUNCIL.....SOUTHEASTERN ELECTRIC  
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....TENNESSEE VALLEY AUTHORITY  
CORPORATE ADDRESS.....500A CHESTNUT STREET TOWER II  
CHATTANOOGA, TENNESSEE 37401  
CONTRACTOR  
ARCHITECT/ENGINEER.....TENNESSEE VALLEY AUTHORITY  
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC  
CONSTRUCTOR.....TENNESSEE VALLEY AUTHORITY  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II  
IE RESIDENT INSPECTOR.....J. PAULK  
LICENSING PROJ MANAGER.....R. CLARK  
DOCKET NUMBER.....50-259  
LICENSE & DATE ISSUANCE....DPR-33, DECEMBER 20, 1973  
PUBLIC DOCUMENT ROOM.....ATHENS PUBLIC LIBRARY  
SOUTH AND FORREST  
ATHENS, ALABAMA 35611

I N S P E C T I O N     S T A T U S

INSPECTION SUMMARY

+ INSPECTION NOVEMBER 21 - DECEMBER 31 (85-57): THIS ROUTINE INSPECTION INVOLVED 93 RESIDENT INSPECTOR-HOURS IN THE AREAS OF OPERATIONAL SAFETY; MAINTENANCE OBSERVATION; SURVEILLANCE TESTING; REPORTABLE OCCURRENCES; RECEIPT, STORAGE AND HANDLING OF EQUIPMENT PROGRAM; AND EMERGENCY DRILL. FOUR VIOLATIONS WERE IDENTIFIED: 1) 10CFR 50.59 FOR FAILURE TO HAVE PRIOR NRC APPROVAL FOR CHANGING A SECONDARY CONTAINMENT ISOLATION DAMPER TIMING; 2) TECHNICAL SPECIFICATION 6.3.A.6 FOR FAILURE TO CONDUCT SIXTEEN SURVEILLANCE INSTRUCTIONS DURING SHUTDOWN AND REFUELING. 3) 10CFR 50, APPENDIX B, CRITERION V FOR FOUR EXAMPLES: A) FAILURE TO HAVE 4160 VOLT SHUTDOWN BOARD A CONTROL POWER CONNECTED PER PLANT DRAWING; B) FAILURE TO HAVE DIESEL GENERATOR OIL PRESSURE SWITCH FUNCTIONAL AS PER PLANT DRAWING; C) FAILURE TO HAVE AN ADEQUATE PROCEDURE TO CONDUCT LPRM CHANGEOUT; D) FAILURE TO CONDUCT CHARCOAL BED IODINE REMOVAL ANALYSIS IN ACCORDANCE WITH THE TEST REQUIREMENTS AND 4) 10CFR 50, APPENDIX B, CRITERION II FOR FAILURE TO CARRY OUT THE QUALITY ASSURANCE PROGRAM IN ACCORDANCE WITH WRITTEN PROCEDURES AFTER THE DISCOVERY OF NONCONFORMING FUEL CHANNELS.

INSPECTION JANUARY 6-10 (86-01): THIS ROUTINE, UNANNOUNCED INSPECTION ENTAILED 24 INSPECTOR-HOURS ON SITE DURING NORMAL DUTY HOURS, IN THE AREA OF EMERGENCY PREPAREDNESS. OF THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JANUARY 13-17 (86-03): THIS ROUTINE, UNANNOUNCED INSPECTION ENTAILED 11 INSPECTOR-HOURS ON SITE IN THE AREAS OF OBSERVATION OF LIQUID PENETRANT EXAMINATIONS, REVIEW OF RADIOGRAPHIC FILM, FOLLOWUP ON ITEMS OF NONCOMPLIANCE AND UNRESOLVED ITEMS, FOLLOWUP ON IE BULLETINS, AND FOLLOWUP ON INSPECTOR IDENTIFIED PROBLEMS. TWO VIOLATIONS WERE IDENTIFIED - FAILURE TO FOLLOW PROCEDURES FOR HOUSEKEEPING IN RADIATION AND CONTAMINATED AREAS AND FAILURE TO FOLLOW PROCEDURE FOR REMOVAL OF TEMPORARY ATTACHMENTS ON RECIRCULATION SYSTEM PIPE SPOOL PIECE.

Report Period FEB 1986

I N S P E C T I O N      S T A T U S - (CONTINUED)

\*\*\*\*\*  
\*            BROWNS FERRY 1            \*  
\*\*\*\*\*

INSPECTION SUMMARY

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

ENVIRONMENTAL QUALIFICATION WORK.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

SHUTDOWN FOR REPAIRS ON 03/19.

LAST IE SITE INSPECTION DATE: JANUARY 13-17, 1986 +

INSPECTION REPORT NO: 50-259/86-03 +

R E P O R T S   F R O M   L I C E N S E E


NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
85-052	09/24/85	01/14/86	STATUS OF FUSE IDENTIFICATION PROGRAM. DESCRIBE THE FUSE IDENTIFICATION AND LABELING PROGRAM.

1. Docket: 50-260 OPERATING STATUS  
 2. Reporting Period: 02/01/86 Outage + On-line Hrs: 672.0  
 3. Utility Contact: TED THOM (205) 729-0834  
 4. Licensed Thermal Power (MWt): 3293  
 5. Nameplate Rating (Gross MWe): 1280 X 0.9 = 1152  
 6. Design Electrical Rating (Net MWe): 1065  
 7. Maximum Dependable Capacity (Gross MWe): 1098  
 8. Maximum Dependable Capacity (Net MWe): 1065  
 9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE  
 10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_  
 11. Reasons for Restrictions, If Any:  
NONE  
 12. Report Period Hrs      MONTH      YEAR      CUMULATIVE  
672.0      1,416.0      96,433.0  
 13. Hours Reactor Critical      .0      .0      55,859.6  
 14. Rx Reserve Shtdwn Hrs      .0      .0      14,200.4  
 15. Hrs Generator On-Line      .0      .0      54,338.5  
 16. Unit Reserve Shtdwn Hrs      .0      .0      .0  
 17. Gross Therm Ener (MWH)      .0      .0      153,245,167  
 18. Gross Elec Ener (MWH)      .0      .0      50,771,798  
 19. Net Elec Ener (MWH)      -4,302      -8,586      49,256,778  
 20. Unit Service Factor      .0      .0      56.3  
 21. Unit Avail Factor      .0      .0      56.3  
 22. Unit Cap Factor (MDC Net)      .0      .0      48.0  
 23. Unit Cap Factor (DER Net)      .0      .0      48.0  
 24. Unit Forced Outage Rate      .0      .0      23.0  
 25. Forced Outage Hours      .0      .0      16,304.4  
 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE  
 27. If Currently Shutdown Estimated Startup Date: 06/04/86

\*\*\*\*\*  
\*      BROWNS FERRY 2      \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

BROWNS FERRY 2



FEBRUARY 1986

Report Period FEB 1986

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* BROWNS FERRY 2 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System Component	Cause & Corrective Action to Prevent Recurrence
305	09/15/84	S	672.0	C	4			EOC-5 REFUEL & MAINTENANCE OUTAGE CONTINUES.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
BROWNS FERRY 2 REMAINS SHUTDOWN IN A CONTINUING REFUELING/MAINTENANCE OUTAGE.

Type	Reason	Method	System & Component	
F-Forced	A-Equip Failure	F-Admin	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	2-Manual Scram	Instructions for
	C-Refueling	H-Other	3-Auto Scram	Preparation of
	D-Regulatory Restriction		4-Continued	Data Entry Sheet
	E-Operator Training		5-Reduced Load	Licensee Event Report
	& License Examination		9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* BROWNS FERRY 2 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1986

FACILITY DESCRIPTION

LOCATION  
STATE.....ALABAMA  
COUNTY.....LIMESTONE  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...10 MI NW OF  
DECATUR, ALA  
TYPE OF REACTOR.....BWR  
DATE INITIAL CRITICALITY...JULY 20, 1974  
DATE ELEC ENER 1ST GENER...AUGUST 28, 1974  
DATE COMMERCIAL OPERATE....MARCH 1, 1975  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER....TENNESSEE RIVER  
ELECTRIC RELIABILITY  
COUNCIL.....SOUTHEASTERN ELECTRIC  
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....TENNESSEE VALLEY AUTHORITY  
CORPORATE ADDRESS.....500A CHESTNUT STREET TOWER II  
CHATTANOOGA, TENNESSEE 37401  
CONTRACTOR  
ARCHITECT/ENGINEER.....TENNESSEE VALLEY AUTHORITY  
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC  
CONSTRUCTOR.....TENNESSEE VALLEY AUTHORITY  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II  
IE RESIDENT INSPECTOR.....J. PAULK  
LICENSING PROJ MANAGER.....R. CLARK  
DOCKET NUMBER.....50-260  
LICENSE & DATE ISSUANCE....DPR-52, AUGUST 2, 1974  
PUBLIC DOCUMENT ROOM.....ATHENS PUBLIC LIBRARY  
SOUTH AND FORREST  
ATHENS, ALABAMA 35611

I N S P E C T I O N     S T A T U S

INSPECTION SUMMARY

+ INSPECTION NOVEMBER 21 - DECEMBER 31 (85-57): THIS ROUTINE INSPECTION INVOLVED 93 RESIDENT INSPECTOR-HOURS IN THE AREAS OF OPERATIONAL SAFETY; MAINTENANCE OBSERVATION; SURVEILLANCE TESTING; REPORTABLE OCCURRENCES; RECEIPT, STORAGE AND HANDLING OF EQUIPMENT PROGRAM; AND EMERGENCY DRILL. FOUR VIOLATIONS WERE IDENTIFIED: 1) 10CFR 50.59 FOR FAILURE TO HAVE PRIOR NRC APPROVAL FOR CHANGING A SECONDARY CONTAINMENT ISOLATION DAMPER TIMING; 2) TECHNICAL SPECIFICATION 6.3.A.6 FOR FAILURE TO CONDUCT SIXTEEN SURVEILLANCE INSTRUCTIONS DURING SHUTDOWN AND REFUELING. 3) 10CFR 50, APPENDIX B, CRITERION V FOR FOUR EXAMPLES: A) FAILURE TO HAVE 4160 VOLT SHUTDOWN BOARD A CONTROL POWER CONNECTED PER PLANT DRAWING; B) FAILURE TO HAVE DIESEL GENERATOR OIL PRESSURE SWITCH FUNCTIONAL AS PER PLANT DRAWING; C) FAILURE TO HAVE AN ADEQUATE PROCEDURE TO CONDUCT LPRM CHANGEOUT; D) FAILURE TO CONDUCT CHARCOAL BED IODINE REMOVAL ANALYSIS IN ACCORDANCE WITH THE TEST REQUIREMENTS AND 4) 10CFR 50, APPENDIX B, CRITERION II FOR FAILURE TO CARRY OUT THE QUALITY ASSURANCE PROGRAM IN ACCORDANCE WITH WRITTEN PROCEDURES AFTER THE DISCOVERY OF NONCONFORMING FUEL CHANNELS.

INSPECTION JANUARY 6-10 (86-01): THIS ROUTINE, UNANNOUNCED INSPECTION ENTAILED 25 INSPECTOR-HOURS ON SITE DURING NORMAL DUTY HOURS, IN THE AREA OF EMERGENCY PREPAREDNESS. OF THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JANUARY 13-17 (86-03): THIS ROUTINE, UNANNOUNCED INSPECTION ENTAILED 12 INSPECTOR-HOURS ON SITE IN THE AREAS OF OBSERVATION OF LIQUID PENETRANT EXAMINATIONS, REVIEW OF RADIOGRAPHIC FILM, FOLLOWUP ON ITEMS OF NONCOMPLIANCE AND UNRESOLVED ITEMS, FOLLOWUP ON IE BULLETINS, AND FOLLOWUP ON INSPECTOR IDENTIFIED PROBLEMS. TWO VIOLATIONS WERE IDENTIFIED - FAILURE TO FOLLOW PROCEDURES FOR HOUSEKEEPING IN RADIATION AND CONTAMINATED AREAS AND FAILURE TO FOLLOW PROCEDURE FOR REMOVAL OF TEMPORARY ATTACHMENTS ON RECIRCULATION SYSTEM PIPE SPOOL PIECE.

Report Period FEB 1986

I N S P E C T I O N      S T A T U S - (CONTINUED)

\*\*\*\*\*  
\*            BROWNS FERRY 2            \*  
\*\*\*\*\*

INSPECTION SUMMARY

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

SHUTDOWN ON SEPTEMBER 15, 1984 FOR REFUELING DUTAGE.

LAST IE SITE INSPECTION DATE: JANUARY 13-17, 1986 +

INSPECTION REPORT NO: 50-260/86-03 +

R E P O R T S   F R O M   L I C E N S E E


NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
85-018	11/06/85	12/06/85	CREATION OF A POTENTIAL TO VIOLATE SECONDARY CONTAINMENT. CAUSE - CONDITION RESULTED FROM A FAILURE TO PROVIDE POSITIVE CONTROL OF THE SECONDARY CONTAINMENT.
85-020	12/20/85	01/17/86	UNQUALIFIED REACTOR PROTECTION SYSTEM INSTRUMENT PANELS. PANELS WERE NOT FULLY SEISMICALLY QUALIFIED.

1. Docket: 50-296 OPERATING STATUS  
 2. Reporting Period: 02/01/86 Outage + On-line Hrs: 672.0  
 3. Utility Contact: TED THOM (205) 729-3624  
 4. Licensed Thermal Power (MWh): 3293  
 5. Nameplate Rating (Gross MWe): 1280 X 0.9 = 1152  
 6. Design Electrical Rating (Net MWe): 1065  
 7. Maximum Dependable Capacity (Gross MWe): 1098  
 8. Maximum Dependable Capacity (Net MWe): 1065  
 9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE  
 10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_  
 11. Reasons for Restrictions, If Any:  
NONE  
 12. Report Period Hrs      MONTH      YEAR      CUMULATIVE  
672.0      1,416.0      78,888.0  
 13. Hours Reactor Critical      .0      .0      45,306.8  
 14. Rx Reserve Shtdwn Hrs      .0      .0      5,149.4  
 15. Hrs Generator On-Line      .0      .0      44,195.6  
 16. Unit Reserve Shtdwn Hrs      .0      .0      .0  
 17. Gross Therm Ener (MWH)      0      0      131,846,076  
 18. Gross Elec Ener (MWH)      0      0      43,473,760  
 19. Net Elec Ener (MWH)      -3,051      -6,287      42,128,386  
 20. Unit Service Factor      .0      .0      56.0  
 21. Unit Avail Factor      .0      .0      56.0  
 22. Unit Cap Factor (MDC Net)      .0      .0      50.1  
 23. Unit Cap Factor (DER Net)      .0      .0      50.1  
 24. Unit Forced Outage Rate      .0      .0      22.0  
 25. Forced Outage Hours      .0      .0      12,473.4  
 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE  
 27. If Currently Shutdown Estimated Startup Date: 03/15/86

\*\*\*\*\*  
\* BROWNS FERRY 3 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

BROWNS FERRY 3



Report Period FEB 1986

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* BROWNS FERRY 3 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System Component	Cause & Corrective Action to Prevent Recurrence
157	12/01/85	S	672.0	H	4			ENVIRONMENTAL QUALIFICATION OUTAGE TO COMPLY WITH NRC REQUIREMENTS.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
BROWNS FERRY 3 REMAINS SHUTDOWN FOR ENVIRONMENTAL QUALIFICATION.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	Instructions for Preparation of
	C-Refueling	H-Other	Data Entry Sheet
	D-Regulatory Restriction		Licensee Event Report
	E-Operator Training & License Examination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* BROWNS FERRY 3 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1986

FACILITY DESCRIPTION

LOCATION  
STATE.....ALABAMA  
COUNTY.....LIMESTONE  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...10 MI NW OF  
DECATUR, ALA  
TYPE OF REACTOR.....BWR  
DATE INITIAL CRITICALITY...AUGUST 8, 1976  
DATE ELEC ENER 1ST GENER...SEPTEMBER 12, 1976  
DATE COMMERCIAL OPERATE....MARCH 1, 1977  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER....TENNESSEE RIVER  
ELECTRIC RELIABILITY  
COUNCIL.....SOUTHEASTERN ELECTRIC  
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....TENNESSEE VALLEY AUTHORITY  
CORPORATE ADDRESS.....500A CHESTNUT STREET TOWER II  
CHATTANOOGA, TENNESSEE 37401  
CONTRACTOR  
ARCHITECT/ENGINEER.....TENNESSEE VALLEY AUTHORITY  
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC  
CONSTRUCTOR.....TENNESSEE VALLEY AUTHORITY  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II  
IE RESIDENT INSPECTOR.....J. PAULK  
LICENSING PROJ MANAGER.....R. CLARK  
DOCKET NUMBER.....50-296  
LICENSE & DATE ISSUANCE....DPR-68, AUGUST 18, 1976  
PUBLIC DOCUMENT ROOM.....ATHENS PUBLIC LIBRARY  
SOUTH AND FORREST  
ATHENS, ALABAMA 35611

I N S P E C T I O N     S T A T U S

INSPECTION SUMMARY

+ INSPECTION NOVEMBER 21 - DECEMBER 31 (85-57): THIS ROUTINE INSPECTION INVOLVED 94 RESIDENT INSPECTOR-HOURS IN THE AREAS OF OPERATIONAL SAFETY; MAINTENANCE OBSERVATION; SURVEILLANCE TESTING; REPORTABLE OCCURRENCES; RECEIPT, STORAGE AND HANDLING OF EQUIPMENT PROGRAM; AND EMERGENCY DRILL. FOUR VIOLATIONS WERE IDENTIFIED: 1) 10CFR 50.59 FOR FAILURE TO HAVE PRIOR NRC APPROVAL FOR CHANGING A SECONDARY CONTAINMENT ISOLATION DAMPER TIMING; 2) TECHNICAL SPECIFICATION 6.3.A.6 FOR FAILURE TO CONDUCT SIXTEEN SURVEILLANCE INSTRUCTIONS DURING SHUTDOWN AND REFUELING. 3) 10CFR 50, APPENDIX B, CRITERION V FOR FOUR EXAMPLES: A) FAILURE TO HAVE 4160 VOLT SHUTDOWN BOARD A CONTROL POWER CONNECTED PER PLANT DRAWING; B) FAILURE TO HAVE DIESEL GENERATOR OIL PRESSURE SWITCH FUNCTIONAL AS PER PLANT DRAWING; C) FAILURE TO HAVE AN ADEQUATE PROCEDURE TO CONDUCT LPRM CHANGEDOUT; D) FAILURE TO CONDUCT CHARCOAL BED IODINE REMOVAL ANALYSIS IN ACCORDANCE WITH THE TEST REQUIREMENTS AND 4) 10CFR 50, APPENDIX B, CRITERION II FOR FAILURE TO CARRY OUT THE QUALITY ASSURANCE PROGRAM IN ACCORDANCE WITH WRITTEN PROCEDURES AFTER THE DISCOVERY OF NONCONFORMING FUEL CHANNELS.

INSPECTION JANUARY 6-10 (86-01): THIS ROUTINE, UNANNOUNCED INSPECTION ENTAILED 25 INSPECTOR-HOURS ON SITE DURING NORMAL DUTY HOURS, IN THE AREA OF EMERGENCY PREPAREDNESS. OF THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JANUARY 13-17 (86-03): THIS ROUTINE, UNANNOUNCED INSPECTION ENTAILED 12 INSPECTOR-HOURS ON SITE IN THE AREAS OF OBSERVATION OF LIQUID PENETRANT EXAMINATIONS, REVIEW OF RADIOGRAPHIC FILM, FOLLOWUP ON ITEMS OF NONCOMPLIANCE AND UNRESOLVED ITEMS, FOLLOWUP ON IE BULLETINS, AND FOLLOWUP ON INSPECTOR IDENTIFIED PROBLEMS. TWO VIOLATIONS WERE IDENTIFIED - FAILURE TO FOLLOW PROCEDURES FOR HOUSEKEEPING IN RADIATION AND CONTAMINATED AREAS AND FAILURE TO FOLLOW PROCEDURE FOR REMOVAL OF TEMPORARY ATTACHMENTS ON RECIRCULATION SYSTEM PIPE SPOOL PIECE.

Report Period FEB 1986

I N S P E C T I O N      S T A T U S - (CONTINUED)

\*\*\*\*\*  
\* BROWNS FERRY 3 \*  
\*\*\*\*\*

INSPECTION SUMMARY

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

LICENSEE EVALUATING CAUSE OF REACTOR VESSEL WATER LEVEL INDICATION PROBLEMS.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

SHUTDOWN ON MARCH 9, 1985.

LAST IE SITE INSPECTION DATE: JANUARY 13-17, 1986 +

INSPECTION REPORT NO: 50-296/86-03 +

R E P O R T S   F R O M   L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
--------	------------------	-------------------	---------

=====

NONE.


1. Docket: 50-325 OPERATING STATUS  
 2. Reporting Period: 02/01/86 Outage + On-line Hrs: 672.0  
 3. Utility Contact: FRANCES HARRISON (919) 457-9521  
 4. Licensed Thermal Power (MWt): 2436  
 5. Nameplate Rating (Gross MWe): 963 X 0.9 = 867  
 6. Design Electrical Rating (Net MWe): 821  
 7. Maximum Dependable Capacity (Gross MWe): 815  
 8. Maximum Dependable Capacity (Net MWe): 790  
 9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE  
 10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_  
 11. Reasons for Restrictions, If Any:  
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>672.0</u>	<u>1,416.0</u>	<u>78,481.0</u>
13. Hours Reactor Critical	<u>672.0</u>	<u>1,416.0</u>	<u>48,247.4</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>1,647.1</u>
15. Hrs Generator On-Line	<u>672.0</u>	<u>1,416.0</u>	<u>45,554.5</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,618,301</u>	<u>3,390,572</u>	<u>93,497,227</u>
18. Gross Elec Ener (MWH)	<u>532,323</u>	<u>1,122,697</u>	<u>30,873,967</u>
19. Net Elec Ener (MWH)	<u>518,017</u>	<u>1,092,227</u>	<u>29,650,915</u>
20. Unit Service Factor	<u>100.0</u>	<u>100.0</u>	<u>58.0</u>
21. Unit Avail Factor	<u>100.0</u>	<u>100.0</u>	<u>58.0</u>
22. Unit Cap Factor (MDC Net)	<u>97.6</u>	<u>97.6</u>	<u>47.8</u>
23. Unit Cap Factor (DER Net)	<u>93.9</u>	<u>94.0</u>	<u>46.0</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.0</u>	<u>17.6</u>
25. Forced Outage Hours	<u>.0</u>	<u>.0</u>	<u>9,697.4</u>
26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):	<u>NONE</u>		
27. If Currently Shutdown Estimated Startup Date:	<u>N/A</u>		

\*\*\*\*\*  
\* BRUNSWICK 1 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

BRUNSWICK 1



FEBRUARY 1986

Report Period FEB 1986

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* BRUNSWICK 1 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
85-010	02/15/86	F	0.0	B	5				PERFORMED SCRAM TIME ON ONE ROD THAT HAD MAINTENANCE WORK DONE.
86-009	02/07/86	S	0.0	B	5				REDUCED POWER FOR ROUTINE TURBINE, SV, CIV, AND BYPASS VALVE TESTING.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*

BRUNSWICK 1 OPERATED WITH 2 REDUCTIONS DURING FEBRUARY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	Instructions for Preparation of Data Entry Sheet
	C-Refueling	H-Other	
	D-Regulatory Restriction	3-Auto Scram	
	E-Operator Training & License Examination	4-Continued	
		5-Reduced Load	
		9-Other	Licensee Event Report (LER) File (NUREG-0161)

\*\*\*\*\*  
\* BRUNSWICK 1 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1986

FACILITY DESCRIPTION

LOCATION  
STATE.....NORTH CAROLINA  
COUNTY.....BRUNSWICK  
  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...3 MI N OF  
SOUTHPORT, NC  
  
TYPE OF REACTOR.....BWR  
  
DATE INITIAL CRITICALITY...OCTOBER 8, 1976  
  
DATE ELEC ENER 1ST GENER...DECEMBER 4, 1976  
  
DATE COMMERCIAL OPERATE....MARCH 18, 1977  
  
CONDENSER COOLING METHOD...ONCE THRU  
  
CONDENSER COOLING WATER....CAPE FEAR RIVER  
  
ELECTRIC RELIABILITY  
COUNCIL.....SOUTHEASTERN ELECTRIC  
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....CAROLINA POWER & LIGHT  
  
CORPORATE ADDRESS.....P. O. BOX 1551  
RALEIGH, NORTH CAROLINA 27602  
  
CONTRACTOR  
ARCHITECT/ENGINEER.....UNITED ENG. & CONSTRUCTORS  
  
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC  
  
CONSTRUCTOR.....BROWN & ROOT  
  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II  
  
IE RESIDENT INSPECTOR.....W. RULAND  
  
LICENSING PROJ MANAGER.....E. SYLVESTER  
DOCKET NUMBER.....50-325  
  
LICENSE & DATE ISSUANCE....DPR-71, NOVEMBER 12, 1976  
  
PUBLIC DOCUMENT ROOM.....SOUTHPORT-BRUNSWICK COUNTY LIBRARY  
108 W. MOORE STREET  
SOUTHPORT, NORTH CAROLINA 28461

I N S P E C T I O N     S T A T U S

INSPECTION SUMMARY

+ INSPECTION DECEMBER 1-31 (85-40): THIS ROUTINE, SAFETY INSPECTION INVOLVED 53 INSPECTOR-HOURS ON SITE IN THE AREAS OF MAINTENANCE OBSERVATION, SURVEILLANCE OBSERVATION, OPERATIONAL SAFETY VERIFICATION, ENGINEERED SAFEGUARD FEATURE (ESF) SYSTEM WALKDOWN, ON SITE LICENSEE EVENT REPORTS (LERS) REVIEW, COLD WEATHER PREPARATIONS, PLANT MODIFICATIONS, AND FOLLOWUP ON IEB 80-11 (MASONRY WALL DESIGN). TWO VIOLATIONS WERE IDENTIFIED: TWO EXAMPLES OF FAILURE TO TAKE ADEQUATE CORRECTIVE ACTION; TWO EXAMPLES OF FAILURE TO CONDUCT ACTIVITIES ACCORDING TO APPROVED PROCEDURES AND DRAWINGS.

INSPECTION JANUARY 6-10 (86-02): THIS ROUTINE, UNANNOUNCED INSPECTION INVOLVED 12 INSPECTOR-HOURS ON SITE (ONE HOUR ON BACKSHIFTS) INSPECTING: PHYSICAL SECURITY PLAN AND IMPLEMENTING PROCEDURES; MANAGEMENT EFFECTIVENESS - SECURITY PROGRAM; SECURITY ORGANIZATION; PHYSICAL BARRIERS - PROTECTED AREA; PHYSICAL BARRIERS - VITAL AREAS; COMPENSATORY MEASURES; ACCESS CONTROL - PERSONNEL; ACCESS CONTROL - VEHICLES; AND COMMUNICATIONS. IN ADDITION, FOUR HOURS OF INSPECTION TIME WAS EXPENDED IN CONDUCTING A REVIEW OF THE LICENSEE'S AUDIT PROGRAM FOR BACKGROUND SCREENING OF CONTRACTOR PERSONNEL IN RALEIGH, N.C. THE LICENSEE WAS FOUND TO BE IN COMPLIANCE WITH REGULATORY REQUIREMENTS IN THE 10 AREAS INSPECTED. RESULTS OF THE AUDIT PROGRAM REVIEW ARE DISCUSSED IN REPORT.

ENFORCEMENT SUMMARY

CONTRARY TO 10 CFR 50, APPENDIX B, CRITERION V, PROCEDURES DID NOT CONTAIN PREREQUISITES, PRECAUTIONS, ACCEPTANCE CRITERIA AND

Report Period FEB 1986

INSPECTION STATUS - (CONTINUED)

\*\*\*\*\*  
X BRUNSWICK 1 X  
\*\*\*\*\*

ENFORCEMENT SUMMARY

CHECKLISTS IN THAT A PROCEDURE WITHOUT THESE REQUIREMENTS, AOI-28, COLD WEATHER BILL ACTION ITEMS, WAS USED TO CHECK FREEZE PROTECTION CIRCUITS THAT PROTECTED THE SAFETY-RELATED CONDENSATE STORAGE TANK LEVEL SWITCHES. CONTRARY TO THE ABOVE, ACTIVITIES AFFECTING QUALITY WERE NOT ACCOMPLISHED USING DOCUMENTED DRAWINGS IN THAT ALTHOUGH UNIT 2 DRAWING 9527-L-2260 REQUIRED LONGER BOLTS BE USED TO MOUNT LEVEL SWITCH 2-E41-LSL-N003, LONGER BOLTS WERE NOT USED, LEADING TO INSUFFICIENT THREAD ENGAGEMENT FOR THREE OF FOUR MOUNTING BOLTS. CONTRARY TO 10 CFR 50, APPENDIX B, CRITERION XVI, CORRECTIVE ACTION, AS IMPLEMENTED BY THE LICENSEE'S ACCEPTED QA PROGRAM (FSAR CHAPTER 17.2.16), CONDITIONS ADVERSE TO QUALITY WERE NOT CORRECTED IN THAT: (A) ALTHOUGH ANNUNCIATOR PANEL PROCEDURE UA-23 REQUIRED THE PERFORMANCE OF A GROUND ISOLATION PROCEDURE IN RESPONSE TO A "250 V BATTERY BUS A GROUND" ALARM, THE ALARM WAS RECEIVED AND DISABLED ON OR BEFORE JANUARY 1, 1985 AND, AS OF DECEMBER 13, 1985, NO GROUND ISOLATION PROCEDURE WAS PERFORMED ON BATTERY BUS A. (B) TEMPORARY HEAT TRACING, REQUIRED BY WORK REQUEST AND AUTHORIZATION 1-E-85-607, WAS REMOVED ON OCTOBER 28, 1985, FROM AROUND THE UNIT 1 CONDENSATE STORAGE TANK HPCI SUCTION TRANSFER LEVEL SWITCHES, E41-LSL-N002 AND N003, WITHOUT ANY PERMANENT CORRECTIVE ACTION IN PLACE. THE HEAT TRACING HAD BEEN INSTALLED TO CORRECT A FREEZING PROBLEM FOUND ON JANUARY 23, 1985 AND AS OF DECEMBER 23, 1985, PERMANENT CORRECTIVE ACTION HAD STILL NOT BEEN TAKEN. CONTRARY TO 10 CFR 50, APPENDIX B, CRITERION V, PROCEDURES DID NOT CONTAIN PREREQUISITES, PRECAUTIONS, ACCEPTANCE CRITERIA AND CHECKLISTS IN THAT A PROCEDURE WITHOUT THESE REQUIREMENTS, AOI-28, COLD WEATHER BILL ACTION ITEMS, WAS USED TO CHECK FREEZE PROTECTION CIRCUITS THAT PROTECTED THE SAFETY-RELATED CONDENSATE STORAGE TANK LEVEL SWITCHES. CONTRARY TO THE ABOVE, ACTIVITIES AFFECTING QUALITY WERE NOT ACCOMPLISHED USING DOCUMENTED DRAWINGS IN THAT ALTHOUGH UNIT 2 DRAWING 9527-L-2260 REQUIRED LONGER BOLTS BE USED TO MOUNT LEVEL SWITCH 2-E41-LSL-N003, LONGER BOLTS WERE NOT USED, LEADING TO INSUFFICIENT THREAD ENGAGEMENT FOR THREE OF FOUR MOUNTING BOLTS. (8504 4)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

NORMAL OPERATION.

LAST IE SITE INSPECTION DATE: JANUARY 6-10, 1986 +

INSPECTION REPORT NO: 50-325/86-02 +

Report Period FEB 1986

R E P O R T S   F R O M   L I C E N S E E

\*\*\*\*\*  
X BRUNSWICK 1 X  
\*\*\*\*\*

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
85-058	10/29/85	11/27/85	INOPERABILITY OF REACTOR CORE SPRAY AND RESIDUAL HEAT REMOVAL. A STEP IN THE PROCEDURE PREVENTED THE RHR LPCI INITIATION LOGIC FROM SENSING REACTOR PRESSURE.
85-059	11/02/85	12/02/85	REACTOR SCRAM RESULTING FROM PRIMARY CONTAINMENT GROUP I ISOLATION. A PRESSURE SPIKE OCCURRED ON THE INSTRUMENT'S COMMON REFERENCE LEG DUE TO OPENING THE INSTRUMENT DRAIN VALVE.
85-060	11/05/85	12/05/85	FAILURE TO PERFORM REQUIRED SAMPLING EXPLOSIVE GAS MONITORING SYSTEM. REQUIRED SURVEILLANCE MISSED DUE TO A FAILURE TO ADEQUATELY RECOGNIZE CHANGES IN PLANT CONDITIONS.
85-061	11/06/85	12/06/85	LOW PRESSURE COOLANT INJECTION AND CORE SPRAY DECLARED INOPERABLE. HPCI INOPERABILITY WAS ADMINISTRATIVE IN NATURE.
85-062	11/12/85	12/12/85	AUTOMATIC STARTING OF CONTROL BUILDING EMERGENCY AIR FILTRATION SYSTEM, ATTRIBUTED TO SPURIOUS ACTUATION AND DUST ACCUMULATION.
85-067	12/27/85	01/21/86	LOSS OF EMERGENCY AC BUS E-1 DURING CHANNEL FUNCTIONAL TESTING. THE EVENT WAS INITIATED AS THE RESULT OF A PROCEDURAL WEAKNESS.


THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-324 OPERATING STATUS  
 2. Reporting Period: 02/01/86 Outage + On-line Hrs: 672.0  
 3. Utility Contact: FRANCES HARRISON (919) 457-9521  
 4. Licensed Thermal Power (MWh): 2436  
 5. Nameplate Rating (Gross MWe): 963 X 0.9 = 867  
 6. Design Electrical Rating (Net MWe): 821  
 7. Maximum Dependable Capacity (Gross MWe): 815  
 8. Maximum Dependable Capacity (Net MWe): 790  
 9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE  
 10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_  
 11. Reasons for Restrictions, If Any:  
NONE  
 12. Report Period Hrs      MONTH      YEAR      CUMULATIVE  
                               672.0      1,416.0      90,505.0  
 13. Hours Reactor Critical      .0      .0      54,512.2  
 14. Rx Reserve Shtdwn Hrs      .0      .0      .0  
 15. Hrs Generator On-Line      .0      .0      51,011.1  
 16. Unit Reserve Shtdwn Hrs      .0      .0      .0  
 17. Gross Therm Ener (MWH)      .0      .0      98,828,458  
 18. Gross Elec Ener (MWH)      .0      .0      32,795,388  
 19. Net Elec Ener (MWH)      -2,651      -6,201      31,431,488  
 20. Unit Service Factor      .0      .0      56.4  
 21. Unit Avail Factor      .0      .0      56.4  
 22. Unit Cap Factor (MDC Net)      .0      .0      44.0  
 23. Unit Cap Factor (DER Net)      .0      .0      42.3  
 24. Unit Forced Outage Rate      .0      .0      17.0  
 25. Forced Outage Hours      .0      .0      10,870.3  
 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE  
 27. If Currently Shutdown Estimated Startup Date: 06/04/86

\*\*\*\*\*  
\* BRUNSWICK 2 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

BRUNSWICK 2



FEBRUARY 1986

Report Period FEB 1986

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* BRUNSWICK 2 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
85-078	11/30/85	S	672.0	C	4	NA	RC	FUELXX	REFUELING/MAINTENANCE DUTAGE CONTINUES.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*

BRUNSWICK 2 REMAINS SHUTDOWN FOR MAINTENANCE AND REFUELING.

Type	Reason	Method	System & Component	
F-Forced	A-Equip Failure	F-Admin	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	2-Manual Scram	Instructions for
	C-Refueling	H-Other	3-Auto Scram	Preparation of
	D-Regulatory Restriction		4-Continued	Data Entry Sheet
	E-Operator Training & License Examination		5-Reduced Load	Licensee Event Report
			9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* BRUNSWICK 2 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1986

FACILITY DESCRIPTION

LOCATION  
STATE.....NORTH CAROLINA  
CITY.....BRUNSWICK  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...3 MI N OF  
SOUTHPORT, NC  
TYPE OF REACTOR.....BWR  
DATE INITIAL CRITICALITY...MARCH 20, 1975  
DATE ELEC ENER 1ST GENER...APRIL 29, 1975  
DATE COMMERCIAL OPERATE....NOVEMBER 3, 1975  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER....CAPE FEAR RIVER  
ELECTRIC RELIABILITY  
COUNCIL.....SOUTHEASTERN ELECTRIC  
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....CAROLINA POWER & LIGHT  
CORPORATE ADDRESS.....411 FAYETTEVILLE STREET  
RALEIGH, NORTH CAROLINA 27602  
CONTRACTOR  
ARCHITECT/ENGINEER.....UNITED ENG. & CONSTRUCTORS  
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC  
CONSTRUCTOR.....BROWN & ROOT  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II  
IE RESIDENT INSPECTOR.....W. RULAND  
LICENSING PROJ MANAGER.....E. SYLVESTER  
DOCKET NUMBER.....50-324  
LICENSE & DATE ISSUANCE....DPR-62, DECEMBER 27, 1974  
PUBLIC DOCUMENT ROOM.....SOUTHPORT-BRUNSWICK COUNTY LIBRARY  
108 W. MOORE STREET  
SOUTHPORT, NORTH CAROLINA 28461

I N S P E C T I O N     S T A T U S

INSPECTION SUMMARY

+ INSPECTION DECEMBER 1-31 (85-40): THIS ROUTINE, SAFETY INSPECTION INVOLVED 54 INSPECTOR-HOURS ON SITE IN THE AREAS OF MAINTENANCE OBSERVATION, SURVEILLANCE OBSERVATION, OPERATIONAL SAFETY VERIFICATION, ENGINEERED SAFEGUARD FEATURE (ESF) SYSTEM WALKDOWN, ON SITE LICENSEE EVENT REPORTS (LERS) REVIEW, COLD WEATHER PREPARATIONS, PLANT MODIFICATIONS, AND FOLLOWUP ON IEB 80-11 (MASONRY WALL DESIGN). TWO VIOLATIONS WERE IDENTIFIED: TWO EXAMPLES OF FAILURE TO TAKE ADEQUATE CORRECTIVE ACTION; TWO EXAMPLES OF FAILURE TO CONDUCT ACTIVITIES ACCORDING TO APPROVED PROCEDURES AND DRAWINGS.

INSPECTION JANUARY 6-10 (86-02): THIS ROUTINE, UNANNOUNCED INSPECTION INVOLVED 12 INSPECTOR-HOURS ON SITE (ONE HOUR ON BACKSHIFTS) INSPECTING: PHYSICAL SECURITY PLAN AND IMPLEMENTING PROCEDURES; MANAGEMENT EFFECTIVENESS - SECURITY PROGRAM; SECURITY ORGANIZATION; PHYSICAL BARRIERS - PROTECTED AREA; PHYSICAL BARRIERS - VITAL AREAS; COMPENSATORY MEASURES; ACCESS CONTROL - PERSONNEL; ACCESS CONTROL - VEHICLES; AND COMMUNICATIONS. IN ADDITION, FOUR HOURS OF INSPECTION TIME WAS EXPENDED IN CONDUCTING A REVIEW OF THE LICENSEE'S AUDIT PROGRAM FOR BACKGROUND SCREENING OF CONTRACTOR PERSONNEL IN RALEIGH, N.C. THE LICENSEE WAS FOUND TO BE IN COMPLIANCE WITH REGULATORY REQUIREMENTS IN THE 10 AREAS INSPECTED. RESULTS OF THE AUDIT PROGRAM REVIEW ARE DISCUSSED IN REPORT.

INSPECTION JANUARY 8-10 (86-03): THIS SPECIAL, ANNOUNCED INSPECTION ENTAILED 10 INSPECTOR-HOURS AT THE WYLE LABORATORIES IN HUNTSVILLE, ALABAMA IN THE AREA OF SAFETY RELIEF VALVE (SRV) TESTING. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

Report Period FEB 1986

I N S P E C T I O N      S T A T U S - (CONTINUED)

\*\*\*\*\*  
\* BRUNSWICK 2 \*  
\*\*\*\*\*

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

COLD SHUTDOWN REFUELING AND .. MODIFICATIONS

LAST IE SITE INSPECTION DATE: JANUARY 8-10, 1986 +

INSPECTION REPORT NO: 50-324/86-03 +

R E P O R T S   F R O M   L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
--------	------------------	-------------------	---------

=====

NONE.

=====

1. Docket: 50-454 OPERATING STATUS  
 2. Reporting Period: 02/01/86 Outage + On-line Hrs: 672.0  
 3. Utility Contact: J. E. LANGAN (815) 234-5441 X2825  
 4. Licensed Thermal Power (MWh): 3411  
 5. Nameplate Rating (Gross MWe): 1175  
 6. Design Electrical Rating (Net MWe): 1120  
 7. Maximum Dependable Capacity (Gross MWe): 1175  
 8. Maximum Dependable Capacity (Net MWe): 1129  
 9. If Changes Occur Above Since Last Report, Give Reasons:  
 \_\_\_\_\_  
 10. Power Level To Which Restricted, If Any (Net MWe): 1152  
 11. Reasons for Restrictions, If Any: \_\_\_\_\_

SPLIT FEEDWATER FLOW.

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>672.0</u>	<u>1,416.0</u>	<u>3,985.0</u>
13. Hours Reactor Critical	<u>392.2</u>	<u>1,103.7</u>	<u>2,384.7</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>21.7</u>	<u>37.8</u>
15. Hrs Generator On-Line	<u>392.2</u>	<u>1,063.3</u>	<u>2,255.7</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,211,423</u>	<u>3,241,070</u>	<u>6,580,262</u>
18. Gross Elec Ener (MWH)	<u>409,118</u>	<u>1,076,886</u>	<u>2,165,476</u>
19. Net Elec Ener (MWH)	<u>383,390</u>	<u>1,012,424</u>	<u>2,025,322</u>
20. Unit Service Factor	<u>58.4</u>	<u>75.1</u>	<u>56.6</u>
21. Unit Avail Factor	<u>58.4</u>	<u>75.1</u>	<u>56.6</u>
22. Unit Cap Factor (MDC Net)	<u>50.5</u>	<u>63.3</u>	<u>45.0</u>
23. Unit Cap Factor (DER Net)	<u>50.9</u>	<u>63.8</u>	<u>45.4</u>
24. Unit Forced Outage Rate	<u>7.1</u>	<u>8.8</u>	<u>8.3</u>
25. Forced Outage Hours	<u>29.8</u>	<u>102.7</u>	<u>205.3</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


NONE

27. If Currently Shutdown Estimated Startup Date: 03/04/86

\*\*\*\*\*  
\* BYRON 1 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

BYRON 1



FEBRUARY 1986

Report Period FEB 1986

## UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
 \* BYRON 1 \*  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
5	01/31/86	S	0.0	B	5		KE	COND	CONDENSER WATERBOX CLEANING CONTINUED FROM PREVIOUS MONTH.
6	02/17/86	F	29.8	H	3	86-08	EZ	XPT	GENERATOR/TURBINE/REACTOR TRIP DUE TO MAIN TRANSFORMER PHASE IMBALANCE CAUSED BY TRANSMISSION TOWER ICING.
7	02/18/86	S	250.0	B	9				DECISION MADE TO ENTER THE PLANNED OUTAGE WHICH WAS ORIGINALLY SCHEDULED FOR 5/15/86.

\*\*\*\*\*  
 \* SUMMARY \*  
 \*\*\*\*\*  
 BYRON 1 OPERATED WITH 1 REDUCTION AND 2 OUTAGES, SHUTTING DOWN FOR MAINTENANCE ON FEBRUARY 18TH.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	Instructions for Preparation of Data Entry Sheet
	C-Refueling	H-Other	4-Continued
	D-Regulatory Restriction		5-Reduced Load
	E-Operator Training & License Examination		9-Other
			Licensee Event Report (LER) File (NUREG-0161)

\*\*\*\*\*  
\* BYRON 1 \*  
\*\*\*\*\*

## FACILITY DATA

Report Period FEB 1986

### FACILITY DESCRIPTION

LOCATION  
STATE.....ILLINOIS  
COUNTY.....OGLE  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...17 MI SW OF  
ROCKFORD, ILL  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...FEBRUARY 2, 1985  
DATE ELEC ENER 1ST GENER...MARCH 1, 1985  
DATE COMMERCIAL OPERATE....SEPTEMBER 16, 1985  
CONDENSER COOLING METHOD...CC HNDCT  
CONDENSER COOLING WATER....ROCK RIVER  
ELECTRIC RELIABILITY  
COUNCIL.....MID-AMERICA  
INTERPOOL NETWORK

### UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....COMMONWEALTH EDISON  
CORPORATE ADDRESS.....P.O. BOX 767  
CHICAGO, ILLINOIS 60690  
CONTRACTOR  
ARCHITECT/ENGINEER.....SARGENT & LUNDY  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
CONSTRUCTOR.....COMMONWEALTH EDISON  
TURBINE SUPPLIER.....WESTINGHOUSE

### REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III  
IE RESIDENT INSPECTOR.....J. HINDS  
LICENSING PROJ MANAGER.....L. OLSHAN  
DOCKET NUMBER.....50-454  
LICENSE & DATE ISSUANCE....NPF-37, FEBRUARY 14, 1985  
PUBLIC DOCUMENT ROOM.....LIBRARIAN  
BUSINESS SCIENCE & TECHNOLOGY DEPT.  
ROCKFORD PUBLIC LIBRARY  
215 NORTH WYMAN STREET  
ROCKFORD, ILLINOIS 61101

### INSPECTION STATUS

#### INSPECTION SUMMARY

INSPECTION ON AUGUST 20-21 AND BETWEEN NOVEMBER 4 AND DECEMBER 18 (85037): ROUTINE, UNANNOUNCED INSPECTION OF THE RADIATION PROTECTION PROGRAM INCLUDING: ORGANIZATION AND MANAGEMENT CONTROLS; TRAINING AND QUALIFICATIONS; EXPOSURE CONTROLS; CONTROL OF RADIOACTIVE MATERIAL; SOLID RADWASTE; TRANSPORTATION; AN ALLEGATION CONCERNING HEALTH PHYSICS PRACTICES; LICENSEE ACTION ON PREVIOUS FINDINGS; UNIT 1 OUTAGE PLANNING; A UNIT 2 CONTAMINATION INCIDENT; A CONTAMINATED RESIN TRANSFER TO NON-LICENSED VENDORS; STATUS OF UNIT 2 RADIATION MONITORS; AND SELECTED IE INFORMATION NOTICES. THE INSPECTION INVOLVED 176 INSPECTOR-HOURS ONSITE BY TWO NRC INSPECTORS. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION ON NOVEMBER 18-22, DECEMBER 9-12, 1985, AND JANUARY 10 (85049): ROUTINE UNANNOUNCED SAFETY INSPECTION CONDUCTED TO CLOSEOUT OPEN ITEMS AND VERIFY THE ADEQUACY OF ROUTINE FIRE PROTECTION PROGRAM IMPLEMENTATION. THE INSPECTION INVOLVED 63 INSPECTOR-HOURS INCLUDING EIGHT INSPECTOR-HOURS DURING OFF-SHIFTS AND NINE INSPECTOR-HOURS CONDUCTING IN-OFFICE REVIEW AT THE REGION III OFFICE. THE FOLLOWING INSPECTION PROCEDURES WERE USED DURING THIS INSPECTION: 30703, 64703, AND 92701. NO VIOLATIONS WERE IDENTIFIED IN ANY OF THE AREAS INSPECTED.

INSPECTION ON NOVEMBER 25-27, 1985 (85051): ROUTINE UNANNOUNCED INSPECTION OF GASEOUS AND LIQUID RADIOACTIVE PROGRAMS INCLUDING: EFFLUENT RELEASES, RECORDS AND REPORTS OF EFFLUENTS; PROCEDURES FOR CONTROLLING RELEASES; AND EFFLUENT CONTROL INSTRUMENTATION. THE INSPECTION INVOLVED 27 INSPECTOR-HOURS ONSITE BY ONE NRC INSPECTOR. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

Report Period FEB 1986

I N S P E C T I O N      S T A T U S - (CONTINUED)

\*\*\*\*\*  
\* BYRON 1 \*  
\*\*\*\*\*

INSPECTION SUMMARY

INSPECTION ON DECEMBER 3-31, 1985 (85053): ROUTINE, UNANNOUNCED SAFETY INSPECTION BY THE RESIDENT INSPECTORS OF LICENSEE ACTION ON PREVIOUS INSPECTION FINDINGS; OPERATIONS SUMMARY; LERS; SURVEILLANCE; MAINTENANCE; OPERATIONAL SAFETY AND ESF WALKDOWN; COLD WEATHER PREPARATION; REGION III REQUESTS; REACTOR EVENTS; COMMISSIONER'S TOUR; MANAGEMENT MEETINGS AND OTHER ACTIVITIES. THE INSPECTION CONSISTED OF 137 INSPECTOR-HOURS ONSITE BY THREE NRC INSPECTORS INCLUDING 30 INSPECTOR-HOURS DURING OFF-SHIFTS. OF THE EIGHT AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED IN SEVEN AREAS; IN THE REMAINING AREA ONE VIOLATION WAS IDENTIFIED: (FAILURE TO FOLLOW APPROVED PROCEDURES). THIS VIOLATION IS OF MINOR SIGNIFICANCE AND HAD MINIMAL POTENTIAL TO AFFECT THE PUBLIC HEALTH AND SAFETY.

INSPECTION ON DECEMBER 2-13 (85056): SPECIAL UNANNOUNCED SAFETY INSPECTION BY THE RESIDENT INSPECTORS TO REVIEW SUPPLEMENTAL INFORMATION PRESENTED AT THE ENFORCEMENT CONFERENCE FOR INSPECTION REPORT 454/85042(DRP). THE INSPECTION CONSISTED OF 14 INSPECTOR-HOURS ONSITE BY TWO NRC INSPECTORS INCLUDING FIVE INSPECTOR-HOURS DURING OFF-SHIFTS. THIS REPORT IDENTIFIED ONE VIOLATION OF NRC REQUIREMENTS: (FAILURE TO WRITE AN ADEQUATE SURVEILLANCE/CALIBRATION PROCEDURE). THIS VIOLATION IS CONSIDERED TO BE OF MORE THAN MINOR SAFETY SIGNIFICANCE WHICH HAD THE POTENTIAL TO AFFECT THE PUBLIC'S HEALTH AND SAFETY. AS A RESULT OF THE SUPPLEMENTAL INFORMATION PROVIDED BY THE LICENSEE, THE APPARENT VIOLATION (454/85042-07(DRP)) IDENTIFIED IN INSPECTION REPORT 454/85042(DRP) IS NO LONGER CONSIDERED TO BE A VIOLATION AND IT IS HEREBY RETRACTED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

SHUTDOWN FOR MAINTENANCE.

LAST IE SITE INSPECTION DATE: FEBRUARY 19, 1986

INSPECTION REPORT NO: 86008

Report Period FEB 1986

R E P O R T S   F R O M   L I C E N S E E

\*\*\*\*\*  
\* BYRON 1 \*  
\*\*\*\*\*

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
85-96	12/07/85	01/03/86	INCORRECT PRESSURE LOOPS UTILIZED TO FULFILL POST ACCIDENT MONITORING REQUIREMENTS DUE TO MISINTERPRETATION
85-97	12/08/85	01/03/86	INADVERTENT SAFETY INJECTION DURING SURVEILLANCE TESTING DUE TO MALPOSITIONED SWITCH
85-98	12/09/85	01/06/86	ACTUATION OF THE MAIN CONTROL ROOM VENTILATION SYSTEM DUE TO DE-ENERGIZATION OF THE ASSOCIATED RADIATION MONITORS
85-99	12/11/85	01/06/86	ACTUATION OF THE MAIN CONTROL ROOM VENTILATION SYSTEM DUE TO THE SPIKING OF THE IODINE CHANNEL OF THE OPR31J MONITOR
85-100	12/11/85	01/06/86	CONSTRUCTION EQUIPMENT BLOCKING FIRE DOOR IN OPEN POSITION
85-101	12/27/85	01/16/86	REACTOR TRIP DUE TO HIGH STEAM GENERATOR LEVEL DURING TESTING
85-102	12/31/85	01/16/86	MISSSED ISI SURVEILLANCE DUE TO OUTAGE PROCEDURE DEFICIENCY


THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-483 OPERATING STATUS  
 2. Reporting Period: 02/01/86 Outage + On-line Hrs: 672.0  
 3. Utility Contact: DAN PRATTE (314) 676-8460  
 4. Licensed Thermal Power (MWt): 3411  
 5. Nameplate Rating (Gross MWe): 1373 X .9 = 1236  
 6. Design Electrical Rating (Net MWe): 1171  
 7. Maximum Dependable Capacity (Gross MWe): 1174  
 8. Maximum Dependable Capacity (Net MWe): 1120  
 9. If Changes Occur Above Since Last Report, Give Reasons:  
 \_\_\_\_\_  
 10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_  
 11. Reasons for Restrictions, If Any:  
NONE  
 12. Report Period Hrs      MONTH      YEAR      CUMULATIVE  
672.0      1,416.0      10,478.5  
 13. Hours Reactor Critical      671.8      1,415.8      9,879.3  
 14. Rx Reserve Shtdwn Hrs      .0      .0      .0  
 15. Hrs Generator On-Line      669.5      1,413.5      9,600.9  
 16. Unit Reserve Shtdwn Hrs      .0      .0      .0  
 17. Gross Therm Ener (MWH)      2,161,005      4,606,743      30,534,237  
 18. Gross Elec Ener (MWH)      740,893      1,576,025      10,389,968  
 19. Net Elec Ener (MWH)      704,984      1,500,363      9,869,150  
 20. Unit Service Factor      99.6      99.8      91.6  
 21. Unit Avail Factor      99.6      99.8      91.6  
 22. Unit Cap Factor (MDC Net)      93.7      94.6      84.1  
 23. Unit Cap Factor (DER Net)      89.6      90.5      80.4  
 24. Unit Forced Outage Rate      .0      .0      5.3  
 25. Forced Outage Hours      .0      .0      536.8  
 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE  
 27. If Currently Shutdown Estimated Startup Date: 04/12/86

\*\*\*\*\*  
\* CALLAWAY 1 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

CALLAWAY 1



FEBRUARY 1986

Report Period FEB 1986

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* CALLAWAY 1 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System Component	Cause & Corrective Action to Prevent Recurrence
3	02/23/86	S	0.0	C	5			UNIT IN COASTDOWN PRIOR TO REFUELING.
4	02/28/86	S	2.5	C	1			UNIT OFF LINE FOR REFUELING.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*

CALLAWAY 1 SHUTDOWN ON FEBRUARY 28TH FOR REFUELING.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	Instructions for Preparation of Data Entry Sheet
	C-Refueling	H-Other	Licensor Event Report (LER) File (NUREG-0161)
	D-Regulatory Restriction		
	E-Operator Training & License Examination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	

\*\*\*\*\*  
\* CALLAWAY 1 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1986

FACILITY DESCRIPTION

LOCATION STATE.....MISSOURI  
COUNTY.....CALLAWAY  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...10 MI SE OF  
FULTON, MO  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...OCTOBER 2, 1984  
DATE ELEC ENER 1ST GENER...OCTOBER 24, 1984  
DATE COMMERCIAL OPERATE....DECEMBER 19, 1984  
CONDENSER COOLING METHOD...COOLING TOWER  
CONDENSER COOLING WATER....MISSOURI RIVER  
ELECTRIC RELIABILITY  
COUNCIL.....MID-AMERICA  
INTERPOOL NETWORK

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....UNION ELECTRIC  
CORPORATE ADDRESS.....P.O. BOX 149  
ST LOUIS, MISSOURI 63166

CONTRACTOR  
ARCHITECT/ENGINEER.....BECHTEL  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
CONSTRUCTOR.....DANIEL INTERNATIONAL  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III  
IE RESIDENT INSPECTOR.....B. LITTLE  
LICENSING PROJ MANAGER.....T. ALEXION  
DOCKET NUMBER.....50-483  
LICENSE & DATE ISSUANCE....NPF-30, OCTOBER 18, 1984  
PUBLIC DOCUMENT ROOM.....FULTON CITY LIBRARY  
709 MARKET STREET  
FULTON, MO 65251

I N S P E C T I O N     S T A T U S

INSPECTION SUMMARY

INSPECTION ON OCTOBER 22 THROUGH DECEMBER 16 (85023): ROUTINE UNANNOUNCED SAFETY INSPECTION BY THE RESIDENT INSPECTORS OF LICENSEE EVENT REPORTS, SURVEILLANCE OPERATIONAL SAFETY MAINTENANCE COLD WEATHER PREPARATIONS, RADILOGICAL EMERGENCY DRILL, SECURITY INFORMATION MEETING WITH LOCAL OFFICIALS AND A SITE VISIT. THE INSPECTION INVOLVED A TOTAL OF 269 INSPECTOR-HOURS ONSITE BY TWO NRC INSPECTORS INCLUDING 57 INSPECTOR-HOURS ONSITE DURING OFF-SHIFTS. NO VIOLATIONS, DEVIATIONS OR SAFETY CONCERNs WERE IDENTIFIED IN THE AREAS REVIEWED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

Report Period FEB 1986

I N S P E C T I O N      S T A T U S - (CONTINUED)

\*\*\*\*\*  
\* CALLAWAY 1 \*  
\*\*\*\*\*

OTHER ITEMS

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

SHUTDOWN FOR REFUELING.

LAST IE SITE INSPECTION DATE: MARCH 15, 1986

INSPECTION REPORT NO: 86004

R E P O R T S   F R O M   L I C E N S E E


NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
85-51	12/08/85	01/07/86	REACTOR TRIP ON HIGH NEGATIVE FLUX RATE
85-52	12/09/85	01/08/86	REACTOR TRIP DUE TO CLOSURE OF MFIVS
85-53	12/09/85	01/07/86	FAILURE TO SURVEIL A TECH SPEC CONTAINMENT PENETRATION
85-54	12/26/85	01/24/86	REACTOR TRIP ON SPURIOUS OT DELTA T SIGNAL

1. Docket: 50-317 OPERATING STATUS  
 2. Reporting Period: 02/01/86 Outage + On-line Hrs: 672.0  
 3. Utility Contact: H. PORTER (301) 260-4868  
 4. Licensed Thermal Power (MWe): 2700  
 5. Nameplate Rating (Gross MWe): 1020 X 0.9 = 918  
 6. Design Electrical Rating (Net MWe): 845  
 7. Maximum Dependable Capacity (Gross MWe): 860  
 8. Maximum Dependable Capacity (Net MWe): 825  
 9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE  
 10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_  
 11. Reasons for Restrictions, If Any:  
NONE  
 12. Report Period Hrs      MONTH      YEAR      CUMULATIVE  
672.0      1,416.0      94,789.0  
 13. Hours Reactor Critical      672.0      1,396.6      74,262.1  
 14. Rx Reserve Shtdwn Hrs      .0      .0      2,299.2  
 15. Hrs Generator On-Line      672.0      1,385.5      72,745.0  
 16. Unit Reserve Shtdwn Hrs      .0      .0      .0  
 17. Gross Therm Ener (MWH)      1,808,947      3,681,463      181,005,656  
 18. Gross Elec Ener (MWH)      613,151      1,248,526      59,851,303  
 19. Net Elec Ener (MWH)      588,463      1,196,572      57,112,874  
 20. Unit Service Factor      100.0      97.8      76.7  
 21. Unit Avail Factor      100.0      97.8      76.7  
 22. Unit Cap Factor (MDC Net)      106.1      102.4      73.5\*  
 23. Unit Cap Factor (DER Net)      103.6      100.0      71.3  
 24. Unit Forced Outage Rate      .0      2.2      8.1  
 25. Forced Outage Hours      .0      30.5      6,325.6  
 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE  
 27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\* CALVERT CLIFFS 1 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

CALVERT CLIFFS 1



FEBRUARY 1986

\* Item calculated with a Weighted Average

PAGE 2-050

Report Period FEB 1986

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
X CALVERT CLIFFS 1  
\*\*\*\*\*

No. Date Type Hours Reason Method LER Number System Component Cause & Corrective Action to Prevent Recurrence

NONE

\*\*\*\*\*  
CALVERT CLIFFS 1 OPERATED AT FULL POWER DURING FEBRUARY.  
X SUMMARY X  
\*\*\*\*\*

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	Instructions for
	C-Refueling	H-Other	Preparation of
	D-Regulatory Restriction	3-Auto Scram	Data Entry Sheet
	E-Operator Training	4-Continued	Licensee Event Report
	& License Examination	5-Reduced Load	(LER) File (NUREG-0161)
		9-Other	

\*\*\*\*\*  
\* CALVERT CLIFFS 1 \*  
\*\*\*\*\*

#### FACILITY DATA

Report Period FEB 1986

**FACILITY DESCRIPTION**

LOCATION STATE..... MARYLAND  
COUNTY..... CALVERT  
DIST AND DIRECTION FROM NEAREST POPULATION CTR... 40 MI S OF ANNAPOLIS, MD  
TYPE OF REACTOR..... PWR  
DATE INITIAL CRITICALITY... OCTOBER 7, 1964  
DATE ELEC ENER 1ST GENER... JANUARY 3, 1968  
DATE COMMERCIAL OPERATE... MAY 8, 1975  
CONDENSER COOLING METHOD... ONCE THRU  
CONDENSER COOLING WATER... CHESAPEAKE BAY  
ELECTRIC RELIABILITY COUNCIL..... MID-ATLANTIC AREA COUNCIL

**INSPECTION SUMMARY**

NO INSPECTION INPUT PROVIDED.

## ENFORCEMENT SUMMARY

NONE

**OTHER ITEMS**

#### **SYSTEMS AND COMPONENTS:**

NO INPUT PROVIDED.

#### **FACILITY ITEMS (PLANS AND PROCEDURES):**

NO INPUT PROVIDED.

**UTILITY & CONTRACTOR INFORMATION**

UTILITY  
LICENSEE..... BALTIMORE GAS & ELEC  
CORPORATE ADDRESS..... P.O. BOX 1475  
BALTIMORE, MARYLAND 2120

CONTRACTOR  
    ARCHITECT/ENGINEER.....BECHTEL  
  
NUC STEAM SYS SUPPLIER...COMBUSTION ENGINEERING  
  
CONSTRUCTOR.....BECHTEL  
  
TURBINE SUPPLIER.....GENERAL ELECTRIC

## REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I  
IE RESIDENT INSPECTOR.....T. FOLEY  
LICENSING PROJ MANAGER.....D. JAFFE  
DOCKET NUMBER.....50-317  
LICENSE & DATE ISSUANCE....DPR-53, JULY 31, 1974  
PUBLIC DOCUMENT ROOM.....CALVERT COUNTY LIBRARY  
FOURTH STREET  
PRINCE FREDERICK, MARYLAND 20678

**INSPECTION STATUS**

Report Period FEB 1986

I N S P E C T I O N      S T A T U S - (CONTINUED)

\*\*\*\*\*  
\* CALVERT CLIFFS 1 \*  
\*\*\*\*\*

OTHER ITEMS

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S   F R O M   L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
NO INPUT PROVIDED.			


=====

1. Docket: 50-318 OPERATING STATUS  
 2. Reporting Period: 02/01/86 Outage + On-line Hrs: 672.0  
 3. Utility Contact: H. PORTER (301) 260-4868  
 4. Licensed Thermal Power (MWh): 2700  
 5. Nameplate Rating (Gross MWe): 1012 X 0.9 = 911  
 6. Design Electrical Rating (Net MWe): 845  
 7. Maximum Dependable Capacity (Gross MWe): 860  
 8. Maximum Dependable Capacity (Net MWe): 825  
 9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE  
 10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_  
 11. Reasons for Restrictions, If Any:  
NONE  
 12. Report Period Hrs      MONTH      YEAR      CUMULATIVE  
672.0      1,416.0      78,144.0  
 13. Hours Reactor Critical      654.9      1,398.9      64,841.1  
 14. Rx Reserve Shtdwn Hrs      .0      .0      1,260.9  
 15. Hrs Generator On-Line      652.5      1,396.5      63,806.9  
 16. Unit Reserve Shtdwn Hrs      .0      .0      .0  
 17. Gross Therm Ener (MWH)      1,658,362      3,645,516      160,127,551  
 18. Gross Elec Ener (MWH)      570,184      1,244,781      52,766,340  
 19. Net Elec Ener (MWH)      546,128      1,193,814      50,344,069  
 20. Unit Service Factor      97.1      98.6      81.7  
 21. Unit Avail Factor      97.1      98.6      81.7  
 22. Unit Cap Factor (MDC Net)      98.5      102.2      78.3\*  
 23. Unit Cap Factor (DER Net)      96.2      99.8      76.2  
 24. Unit Forced Outage Rate      2.9      1.4      5.9  
 25. Forced Outage Hours      19.5      19.5      4,021.3  
 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE  
 27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\* CALVERT CLIFFS 2 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

CALVERT CLIFFS 2



FEBRUARY 1986

\* Item calculated with a Weighted Average

Report Period FEB 1986

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* CALVERT CLIFFS 2 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
86-02	02/04/86	F	19.5	A	3	86-02	IB	INSTRU	THE MAIN TURBINE TRIPPED DUE TO A SPURIOUS HIGH LEVEL STEAM GENERATOR TRIP SIGNAL. THE REACTOR TRIPPED ON LOSS OF LOAD.

\*\*\*\*\* CALVERT CLIFFS 2 OPERATED WITH 1 OUTAGE FOR EQUIPMENT FAILURE.

-\* SUMMARY \*

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	Instructions for Preparation of
	C-Refueling	H-Other	Data Entry Sheet
	D-Regulatory Restriction	3-Auto Scram	Licensee Event Report
	E-Operator Training & License Examination	4-Continued	(LER) File (NUREG-0161)
		5-Reduced Load	
		9-Other	

\*\*\*\*\*  
\* CALVERT CLIFFS 2 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1986

FACILITY DESCRIPTION

LOCATION STATE.....MARYLAND  
COUNTY.....CALVERT  
DIST AND DIRECTION FROM NEAREST POPULATION CTR.. 40 MI S OF ANNAPOLIS, MD  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...NOVEMBER 30, 1976  
DATE ELEC ENER 1ST GENER...DECEMBER 7, 1976  
DATE COMMERCIAL OPERATE....APRIL 1, 1977  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER....CHESAPEAKE BAY  
ELECTRIC RELIABILITY COUNCIL.....MID-ATLANTIC AREA COUNCIL

INSPECTION STATUS

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....BALTIMORE GAS & ELEC  
CORPORATE ADDRESS.....P.O. BOX 1475  
BALTIMORE, MARYLAND 21203

CONTRACTOR  
ARCHITECT/ENGINEER.....BECHTEL  
NUC STEAM SYS SUPPLIER...COMBUSTION ENGINEERING  
CONSTRUCTOR.....BECHTEL  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I  
IE RESIDENT INSPECTOR.....T. FOLEY  
LICENSING PROJ MANAGER....D. JAFFE  
DOCKET NUMBER.....50-318  
LICENSE & DATE ISSUANCE....DPR-69, NOVEMBER 30, 1976  
PUBLIC DOCUMENT ROOM.....CALVERT COUNTY LIBRARY  
FOURTH STREET  
PRINCE FREDERICK, MARYLAND 20678

Report Period FEB 1986

I N S P E C T I O N      S T A T U S - (CONTINUED)

\*\*\*\*\*  
\*            CALVERT CLIFFS 2            \*  
\*\*\*\*\*

OTHER ITEMS

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S   F R O M   L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
--------	------------------	-------------------	---------

=====

NO INPUT PROVIDED.


=====

1. Docket: 50-413 OPERATING STATUS  
 2. Reporting Period: 02/01/86 Outage + On-line Hrs: 672.0  
 3. Utility Contact: J. A. REAVIS (704) 373-7567  
 4. Licensed Thermal Power (MWh): 3411  
 5. Nameplate Rating (Gross MWe): 1205  
 6. Design Electrical Rating (Net MWe): 1145  
 7. Maximum Dependable Capacity (Gross MWe): 1145  
 8. Maximum Dependable Capacity (Net MWe): 1145  
 9. If Changes Occur Above Since Last Report, Give Reasons:  
 \_\_\_\_\_  
 10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_  
 11. Reasons for Restrictions, If Any: \_\_\_\_\_  
 NONE  
 12. Report Period Hrs MONTH YEAR CUMULATIVE  
 13. Hours Reactor Critical 672.0 1,416.0 5,881.0  
 14. Rx Reserve Shtdwn Hrs .0 .0 .0  
 15. Hrs Generator On-Line 672.0 1,331.2 4,846.9  
 16. Unit Reserve Shtdwn Hrs .0 .0 .0  
 17. Gross Therm Ener (MWH) 2,193,998 4,246,903 14,937,083  
 18. Gross Elec Ener (MWH) 776,226 1,499,490 5,183,759  
 19. Net Elec Ener (MWH) 734,969 1,414,716 4,855,230  
 20. Unit Service Factor 100.0 94.0 82.4  
 21. Unit Avail Factor 100.0 94.0 82.4  
 22. Unit Cap Factor (MDC Net) 95.5 87.3 72.1  
 23. Unit Cap Factor (DER Net) 95.5 87.3 72.1  
 24. Unit Forced Outage Rate .0 6.0 17.6  
 25. Forced Outage Hours .0 84.8 1,034.1  
 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
 NONE  
 27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*  
 \* CATAWBA 1  
 \*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

CATAWBA 1



FEBRUARY 1986

Report Period FEB 1986

## UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
 \* CATAWBA 1  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
26-P	02/01/86	F	0.0	B	5		CH	HTEXCH	FEEDWATER PUMP 1A CONDENSER CLEANING.
28-P	02/02/86	F	0.0	A	5		CH	INSTRU	MAIN FEEDWATER PUMP (1A) VIBRATION INSTRUMENTATION REPAIR.
30-P	02/06/86	F	0.0	A	5		HC	TRANSF	LOW CONDENSER VACUUM DUE TO LOSS OF POWER TO COOLING TOWER TRANSFORMER.
33-P	02/13/86	F	0.0	H	5		HC	HTEXCH	COOLING TOWER "C" DE-ICING.

\*\*\*\*\*  
 \* SUMMARY \*  
 \*\*\*\*\*

CATAWBA 1 OPERATED WITH SEVERAL REDUCTIONS LISTED IN DETAIL ABOVE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	1-Manual
S-Sched	B-Maint or Test	G-Oper Error	2-Manual Scram
	C-Refueling	H-Other	3-Auto Scram
	D-Regulatory Restriction		4-Continued
	E-Operator Training & License Examination		5-Reduced Load
			9-Other
			Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161)

\*\*\*\*\*  
\* CATAWBA 1 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1986

FACILITY DESCRIPTION

LOCATION  
STATE.....SOUTH CAROLINA  
COUNTY.....YORK  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...6 MI NNW OF  
ROCK HILL, SC  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...JANUARY 7, 1985  
DATE ELEC ENER 1ST GENER...JANUARY 22, 1985  
DATE COMMERCIAL OPERATE....JUNE 29, 1985  
CONDENSER COOLING METHOD...MDCT  
CONDENSER COOLING WATER....LAKE WYLIE  
ELECTRIC RELIABILITY  
COUNCIL.....SOUTHEASTERN ELECTRIC  
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....DUKE POWER  
CORPORATE ADDRESS.....422 SOUTH CHURCH STREET  
CHARLOTTE, NORTH CAROLINA 28242  
CONTRACTOR  
ARCHITECT/ENGINEER.....DUKE POWER  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
CONSTRUCTOR.....DUKE POWER  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II  
IE RESIDENT INSPECTOR.....P. SKINNER  
LICENSING PROJ MANAGER.....K. JABBOUR  
DOCKET NUMBER.....50-413  
LICENSE & DATE ISSUANCE....NPF-35, JANUARY 17, 1985  
PUBLIC DOCUMENT ROOM.....YORK COUNTY LIBRARY  
138 E. BLACK STREET  
ROCK HILL, SOUTH CAROLINA 29730

I N S P E C T I O N     S T A T U S

INSPECTION SUMMARY

+ INSPECTION NOVEMBER 26 - DECEMBER 25 (85-52): THIS ROUTINE, UNANNOUNCED INSPECTION INVOLVED 51 INSPECTOR-HOURS ON SITE IN THE AREAS OF FOLLOWUP OF LICENSEE AND NRC IDENTIFIED ITEMS; PLANT OPERATIONS; SURVEILLANCE OBSERVATION; MAINTENANCE OBSERVATIONS; REVIEW OF ADMINISTRATIVE CONTROL OF OPERATING PROCEDURES; AND REVIEW OF TMI ACTION ITEMS. OF THE SIX AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JANUARY 6-10 (86-03): THIS ROUTINE, ANNOUNCED INSPECTION ENTAILED 23 INSPECTOR-HOURS ON SITE AND AT THE LICENSEE'S DESIGN ENGINEERING OFFICE IN CHARLOTTE, NORTH CAROLINA, IN THE AREAS OF PIPE SUPPORT BASEPLATE DESIGNS USING CONCRETE EXPANSION ANCHORS (IEB 79-02) AND SEISMIC ANALYSIS FOR AS BUILT SAFETY-RELATED PIPING SYSTEMS (IEB 79-14) - UNIT 2. ALSO, INSPECTED AND EVALUATED THE INFORMATION RELATED TO THE FAILED SUPPORTS/RESTRAINTS IN THE AUXILIARY STEAM (SA) SYSTEM - UNIT 1. TWO VIOLATIONS WERE IDENTIFIED - FAILURE TO FOLLOW PROCEDURES IN RESTORING TO SERVICE FAILED SUPPORT/RESTRAINTS AND INADEQUATE ENGINEERING EVALUATION OF AN EVENT THAT DAMAGED SUPPORT/RESTRAINTS.

INSPECTION JANUARY 13-17 AND 23-31 (86-09): THIS ROUTINE, ANNOUNCED INSPECTION INVOLVED 81 INSPECTOR-HOURS ON SITE IN THE AREAS OF PREOPERATIONAL TEST WITNESSING, PREOPERATIONAL TEST RESULTS REVIEW, NRC INFORMATION NOTICE FOLLOWUP, REVIEW OF SAFETY EVALUATION REPORT (SER) OPEN ITEM AND REVIEW OF PREVIOUSLY IDENTIFIED INSPECTOR FOLLOWUP ITEMS. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

Report Period FEB 1986

INSPECTION STATUS - (CONTINUED)

\*\*\*\*\*  
\* CATAWBA 1 \*  
\*\*\*\*\*

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

NONE.

LAST IE SITE INSPECTION DATE: JANUARY 13-17 AND 23-31, 1986 +

INSPECTION REPORT NO: 50-413/86-09 +

Report Period FEB 1986

R E P O R T S   F R O M   L I C E N S E E

\*\*\*\*\*  
\*           CATAWBA 1           \*  
\*\*\*\*\*

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
85-061	10/18/85	11/18/85	UNIT SHUTDOWN DUE TO EXCESS REACTOR COOLANT UNIDENTIFIED LEAKAGE. LEAKAGE OF GREATER THAN 1 GPM WAS ATTRIBUTED TO SEVERAL LEAK SOURCES.
85-062	11/05/85	12/05/85	CONTINUOUS FIRE WATCH NOT PERFORMED DUE TO MISCOMMUNICATION. THIS INCIDENT RESULTED FROM MISCOMMUNICATION BETWEEN SECURITY AND MAINTENANCE PERSONNEL.
85-063	11/07/85	12/06/85	CERTAIN FIRE DETECTION ZONES NOT BEING SCANNED BY COMPUTER FOR UNKNOWN REASONS.
85-064	11/07/85	12/06/85	REQUIRED FIRE WATCHES NOT PERFORMED DUE TO MISCOMMUNICATION. THIS INCIDENT IS CLASSIFIED AS A PERSONNEL ERROR.
85-070	12/17/85	01/16/86	MISSSED FIREWATCH DUE TO MALFUNCTION OF SECURITY COMPUTER. THE INCIDENT IS DUE TO THE EQUIPMENT MALFUNCTION IN THE SECURITY COMPUTER MULTIPLEXER.
85-071	12/20/85	01/17/86	REACTOR TRIP DUE TO MALFUNCTION OF FEEDWATER CONTROL VALVE. FEEDWATER CONTROL VALVE WAS FOUND TO CONTAIN WATER AND CORROSION.


THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-315 OPERATING STATUS  
 2. Reporting Period: 02/01/86 Outage + On-line Hrs: 672.0  
 3. Utility Contact: W. T. GILLETT (616) 465-5901  
 4. Licensed Thermal Power (MWh): 3250  
 5. Nameplate Rating (Gross MWe): 1280 X 0.9 = 1152  
 6. Design Electrical Rating (Net MWe): 1030  
 7. Maximum Dependable Capacity (Gross MWe): 1056  
 8. Maximum Dependable Capacity (Net MWe): 1020  
 9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE  
 10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_  
 11. Reasons for Restrictions, If Any:  
NONE  
 12. Report Period Hrs      MONTH      YEAR      CUMULATIVE  
672.0      1,416.0      97,848.0  
 13. Hours Reactor Critical      672.0      1,416.0      69,715.7  
 14. Rx Reserve Shtdwn Hrs      .0      .0      463.0  
 15. Hrs Generator On-Line      672.0      1,416.0      68,268.6  
 16. Unit Reserve Shtdwn Hrs      .0      .0      321.0  
 17. Gross Therm Ener (MWH)      1,967,273      4,149,374      199,145,027  
 18. Gross Elec Ener (MWH)      636,260      1,343,570      65,321,110  
 19. Net Elec Ener (MWH)      611,783      1,291,943      62,839,100  
 20. Unit Service Factor      100.0      100.0      71.2  
 21. Unit Avail Factor      100.0      100.0      71.2  
 22. Unit Cap Factor (MDC Net)      89.3      89.4      64.2  
 23. Unit Cap Factor (DER Net)      88.4      88.6      61.8  
 24. Unit Forced Outage Rate      .0      .0      7.6  
 25. Forced Outage Hours      .0      .0      4,942.9  
 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE  
 27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\* COOK 1 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

COOK 1



FEBRUARY 1986

Report Period FEB 1986

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* COOK 1 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System Component	Cause & Corrective Action to Prevent Recurrence
-----	------	------	-------	--------	--------	------------	------------------	---

NONE

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
COOK 1 OPERATED ROUTINELY WITH NO OUTAGES OR REDUCTIONS IN FEBRUARY.

Type	Reason	Method	System & Component	
F-Forced	A-Equip Failure	F-Admin	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	2-Manual Scram	Instructions for
	C-Refueling	H-Other	3-Auto Scram	Preparation of
	D-Regulatory Restriction		4-Continued	Data Entry Sheet
	E-Operator Training & License Examination		5-Reduced Load	Licensee Event Report
			9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
X COOK 1 X  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1986

FACILITY DESCRIPTION

LOCATION  
STATE.....MICHIGAN  
COUNTY.....BERRIEN  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...11 MI S OF  
BENTON HARBOR, MI  
TYPE OF REACTOR.....PWR

DATE INITIAL CRITICALITY...JANUARY 18, 1975  
DATE ELEC ENER 1ST GENER...FEBRUARY 10, 1975  
DATE COMMERCIAL OPERATE....AUGUST 27, 1975

CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER....LAKE MICHIGAN  
ELECTRIC RELIABILITY  
COUNCIL.....EAST CENTRAL AREA  
RELIABILITY COORDINATION  
AGREEMENT

I N S P E C T I O N     S T A T U S

INSPECTION SUMMARY

INSPECTION ON DECEMBER 9-12 (85040): ROUTING, ANNOUNCED INSPECTION OF: (1) CHEMISTRY AND RADIOCHEMISTRY, INCLUDING WATER CHEMISTRY CONTROL, QUALITY ASSURANCE/QUALITY CONTROL OF SAMPLING AND ANALYSIS IN THE LABORATORY, OBSERVATIONS OF TECHNICIAN PERFORMANCE, AND OF LABORATORY, COUNTING ROOM, AND SAMPLING ROOMS; (2) TRAINING AND QUALIFICATIONS OF CHEMISTRY STAFF; (3) LICENSEE INTERNAL AUDITS; AND (4) REVIEW OF CORRECTIVE ACTIONS TAKEN REGARDING A LICENSEE EVENT REPORT. THE INSPECTION INVOLVED 66 INSPECTOR-HOURS ONSITE BY TWO NRC INSPECTORS. NO VIOLATIONS WERE IDENTIFIED IN FIVE OF SIX AREAS INSPECTED. ONE APPARENT VIOLATION WAS IDENTIFIED IN THE AREA OF LABORATORY QUALITY ASSURANCE/QUALITY CONTROL FOR FAILURE TO PERFORM QUARTERLY ANALYSES OF UNKNOWNS CONTAINING BORON AND FOR FAILURE TO ROUTINELY TEST THE INDIVIDUAL TECHNICIANS AS REQUIRED BY TECHNICAL SPECIFICATION 6.8.1.A (SEVERITY LEVEL V).

ENFORCEMENT SUMMARY

UNIT 1 AND UNIT 2 TECHNICAL SPECIFICATION 6.8.1.A STATES THAT WRITTEN PROCEDURES SHALL BE ESTABLISHED, IMPLEMENTED AND MAINTAINED COVERING AMONG OTHER THINGS, THE APPLICABLE PROCEDURES RECOMMENDED IN APPENDIX "A" OF REGULATORY GUIDE 1.33, NOVEMBER, 1972. THIS REQUIREMENT IS IMPLEMENTED IN PROCEDURE 12 THP 6020 LAB.044, "LABORATORY QUALITY ASSURANCE," (REVISION 6, SEPTEMBER 12, 1985), THAT STATES IN PART (SECTION 12.1): "A PROGRAM TO ASSURE THE RELIABILITY OF PROCEDURAL ACCURACY AND INDIVIDUAL TECHNICIAN TECHNIQUE WILL BE ROUTINELY CONDUCTED. EACH RELEVANT PROCEDURE WILL BE CHECKED AT LEAST QUARTERLY WITH 'UNKNOWNS'." CONTRARY TO THE ABOVE REQUIREMENTS, THE LICENSEE HAS NOT FULLY IMPLEMENTED THIS PROCEDURE IN THAT: (1) THE LICENSEE FAILED TO PROVIDE

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....INDIANA & MICHIGAN ELECTRIC  
CORPORATE ADDRESS.....1 RIVERSIDE PLAZA  
COLUMBUS, OHIO 43216  
CONTRACTOR  
ARCHITECT/ENGINEER.....AMERICAN ELEC. POWER SERVICE CORP.  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
CONSTRUCTOR.....AMERICAN ELEC. POWER SERVICE CORP.  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III  
IE RESIDENT INSPECTOR.....B. JURGENSEN  
LICENSING PROJ MANAGER.....D. WIGGINTON  
DOCKET NUMBER.....50-315  
LICENSE & DATE ISSUANCE....DPR-58, OCTOBER 25, 1974  
PUBLIC DOCUMENT ROOM.....MAUDE PRESTON PALENSKE MEMORIAL LIBRARY  
500 MARKET STREET  
ST. JOSEPH, MICHIGAN 49085

Report Period FEB 1986

INSPECTION STATUS - (CONTINUED)

\*\*\*\*\*  
\* COOK 1 \*  
\*\*\*\*\*

ENFORCEMENT SUMMARY

"UNKNOWN" SAMPLES TO CHECK THE PROCEDURAL ACCURACY IN THE DETERMINATION OF BORON CONCENTRATIONS IN REACTOR SYSTEMS, AND (2) SOME TECHNICIANS HAVE NOT BEEN CHECKED FOR PERFORMANCE TO ASSURE INDIVIDUAL TECHNICIAN TECHNIQUE. UNIT 1 AND UNIT 2 TECHNICAL SPECIFICATION 6.8.1.A STATES THAT WRITTEN PROCEDURES SHALL BE ESTABLISHED, IMPLEMENTED AND MAINTAINED COVERING AMONG OTHER THINGS, THE APPLICABLE PROCEDURES RECOMMENDED IN APPENDIX "A" OF REGULATORY GUIDE 1.32, NOVEMBER, 1972. THIS REQUIREMENT IS IMPLEMENTED IN PROCEDURE 12 THP 6020 LAB.044, "LABORATORY QUALITY ASSURANCE," (REVISION 6, SEPTEMBER 12, 1985), THAT STATES IN PART (SECTION 12.1): "A PROGRAM TO ASSURE THE RELIABILITY OF PROCEDURAL ACCURACY AND INDIVIDUAL TECHNICIAN TECHNIQUE WILL BE ROUTINELY CONDUCTED. EACH RELEVANT PROCEDURE WILL BE CHECKED AT LEAST QUARTERLY WITH 'UNKNOWN'." CONTRARY TO THE ABOVE REQUIREMENTS, THE LICENSEE HAS NOT FULLY IMPLEMENTED THIS PROCEDURE IN THAT: (1) THE LICENSEE FAILED TO PROVIDE "UNKNOWN" SAMPLES TO CHECK THE PROCEDURAL ACCURACY IN THE DETERMINATION OF BORON CONCENTRATIONS IN REACTOR SYSTEMS, AND (2) SOME TECHNICIANS HAVE NOT BEEN CHECKED FOR PERFORMANCE TO ASSURE INDIVIDUAL TECHNICIAN TECHNIQUE.  
(8504 5)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

UNIT IS OPERATING NORMALLY.

LAST IE SITE INSPECTION DATE: MARCH 3 - 7, 1986

INSPECTION REPORT NO: 86011

Report Period FEB 1986

R E P O R T S   F R O M   L I C E N S E E

\*\*\*\*\*  
\* COOK 1 \*  
\*\*\*\*\*


NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
85-65	11/25/85	12/26/85	ESF ACTUATION - REACTOR TRIP
85-66	12/12/85	12/30/85	ESF ACTUATION
85-67	12/04/85	01/02/86	INOPERABLE ICE CONDENSER LOWER INLET DOORS
85-68	12/13/85	01/02/86	ESF ACTUATION
85-69	11/17/85	01/09/86	OPERATION WITH INOPERABLE INTERMEDIATE RANGE NEUTRON FLUX DETECTOR
85-70	12/10/85	01/09/86	INOPERABLE FIRE BARRIERS
85-71	12/19/85	01/17/86	SUSPENDED FIRE WATCH TOUR

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-316 OPERATING STATUS  
 2. Reporting Period: 02/01/86 Outage + On-line Hrs: 672.0  
 3. Utility Contact: W. T. GILLETT (616) 465-5901  
 4. Licensed Thermal Power (MWt): 3411  
 5. Nameplate Rating (Gross MWe): 1333 X 0.85 = 1133  
 6. Design Electrical Rating (Net MWe): 1100  
 7. Maximum Dependable Capacity (Gross MWe): 1100  
 8. Maximum Dependable Capacity (Net MWe): 1060  
 9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE  
 10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_  
 11. Reasons for Restrictions, If Any:  
NONE  
 12. Report Period Hrs      MONTH      YEAR      CUMULATIVE  
672.0      1,416.0      71,544.0  
 13. Hours Reactor Critical      608.6      1,352.6      50,381.4  
 14. Rx Reserve Shtdwn Hrs      .0      .0      .0  
 15. Hrs Generator On-Line      528.5      1,272.5      49,126.4  
 16. Unit Reserve Shtdwn Hrs      .0      .0      .0  
 17. Gross Therm Ener (MWH)      1,360,957      3,404,597      157,079,049  
 18. Gross Elec Ener (MWH)      436,500      1,097,780      50,784,190  
 19. Net Elec Ener (MWH)      418,027      1,053,472      48,954,822  
 20. Unit Service Factor      78.6      89.9      71.1  
 21. Unit Avail Factor      78.6      89.9      71.1  
 22. Unit Cap Factor (MDC Net)      58.7      70.2      66.9  
 23. Unit Cap Factor (DER Net)      56.6      67.6      65.4  
 24. Unit Forced Outage Rate      20.8      9.9      15.7  
 25. Forced Outage Hours      139.2      139.2      9,104.7  
 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE  
 27. If Currently Shutdown Estimated Startup Date: 07/10/86

\*\*\*\*\*  
\* COOK 2 \*  
\*\*\*\*\*  
AVERAGE DAILY POWER LEVEL (MWe) PLOT

COOK 2



FEBRUARY 1986

Report Period FEB 1986

## UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
 \* COOK 2 \*  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
169	02/01/86	F	139.2	A	3	86-005-0	EB	TRANSF	THE UNIT TRIPPED FROM 80% POWER DUE TO AUXILIARY TRANSFORMER 2 CD UNIT DIFFERENTIAL OPERATING. THE TRANSFORMER UNIT DIFFERENTIAL WAS CAUSED BY A BUSHING EXPLODING WHICH RESULTED IN A FIRE. REPAIRS WERE MADE WHICH PERMITTED STARTUP OF THE UNIT UTILIZING THE OFF-SITE AUXILIARY TRANSFORMERS.
170	02/21/86	F	0.0	B	5		HH	HTEXCH	REACTOR POWER WAS REDUCED TO 55% TO REMOVE THE WEST MAIN FEEDPUMP FROM SERVICE TO CHECK THE FEEDPUMP TURBINE CONDENSER FOR TUBE LEAKS. ONE LEAKING TUBE WAS PLUGGED. REACTOR POWER WAS RETURNED TO 80% THE SAME DAY.
171	02/22/86	F	0.0	B	5		HH	HTEXCH	REACTOR POWER WAS REDUCED TO 55% TO AGAIN REMOVE THE WEST MAIN FEEDPUMP FROM SERVICE TO CHECK THE FEEDPUMP TURBINE CONDENSER FOR TUBE LEAKS. SIX TUBES WERE PLUGGED. THE EAST FEEDPUMP TURBINE CONDENSER WAS ALSO CHECKED WITH ONE TUBE PLUGGED. REACTOR POWER WAS RETURNED TO 80% ON 860223.
172	02/28/86	S	4.3	C	1		ZZ	ZZZZZ	THE UNIT WAS REMOVED FROM SERVICE AT 1943 HOURS FOR CYCLE 5-6 REFUELING OUTAGE. IN ADDITION TO THE REFUELING ACTIVITIES, MAJOR MAINTENANCE WORK INCLUDES STEAM GENERATOR EDDY CURRENT TESTING, CONTROL ROD GUIDE TUBE SPLIT PIN REPLACEMENT, REPLACEMENT OF THE MAIN FEEDPUMP TURBINE CONDENSERS, REPLACEMENT OF PCB OIL COOLED TRANSFORMERS.

\*\*\*\*\* COOK 2 OPERATED WITH 2 OUTAGES AND 2 REDUCTIONS IN FEBRUARY.

\* SUMMARY \*

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	Instructions for Preparation of
	C-Refueling	H-Other	Data Entry Sheet
	D-Regulatory Restriction	3-Auto Scram	
	E-Operator Training & License Examination	4-Continued	
		5-Reduced Load	Licensee Event Report
		9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* COOK 2 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1986

FACILITY DESCRIPTION

LOCATION STATE.....MICHIGAN  
COUNTY.....BERRIEN  
DIST AND DIRECTION FROM NEAREST POPULATION CTR...11 MI S OF BENTON HARBOR, MI

TYPE OF REACTOR.....PWR

DATE INITIAL CRITICALITY...MARCH 10, 1978

DATE ELEC ENER 1ST GENER...MARCH 22, 1978

DATE COMMERCIAL OPERATE....JULY 1, 1978

CONDENSER COOLING METHOD...ONCE THRU

CONDENSER COOLING WATER....LAKE MICHIGAN

ELECTRIC RELIABILITY COUNCIL.....EAST CENTRAL AREA RELIABILITY COORDINATION AGREEMENT

I N S P E C T I O N     S T A T U S

INSPECTION SUMMARY

INSPECTION ON DECEMBER 9-12 (85040): ROUTING, ANNOUNCED INSPECTION OF: (1) CHEMISTRY AND RADIOCHEMISTRY, INCLUDING WATER CHEMISTRY CONTROL, QUALITY ASSURANCE/QUALITY CONTROL OF SAMPLING AND ANALYSIS IN THE LABORATORY, OBSERVATIONS OF TECHNICIAN PERFORMANCE, AND OF LABORATORY, COUNTING ROOM, AND SAMPLING ROOMS; (2) TRAINING AND QUALIFICATIONS OF CHEMISTRY STAFF; (3) LICENSEE INTERNAL AUDITS; AND (4) REVIEW OF CORRECTIVE ACTIONS TAKEN REGARDING A LICENSEE EVENT REPORT. THE INSPECTION INVOLVED 66 INSPECTOR-HOURS ONSITE BY TWO NRC INSPECTORS. NO VIOLATIONS WERE IDENTIFIED IN FIVE OF SIX AREAS INSPECTED. ONE APPARENT VIOLATION WAS IDENTIFIED IN THE AREA OF LABORATORY QUALITY ASSURANCE/QUALITY CONTROL FOR FAILURE TO PERFORM QUARTERLY ANALYSES OF UNKNOWNNS CONTAINING BORON AND FOR FAILURE TO ROUTINELY TEST THE INDIVIDUAL TECHNICIANS AS REQUIRED BY TECHNICAL SPECIFICATION 6.8.1.A (SEVERITY LEVEL V).

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

Report Period FEB 1986

I N S P E C T I O N      S T A T U S - (CONTINUED)

\*\*\*\*\*  
\* COOK 2 \*  
\*\*\*\*\*

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

UNIT IS OPERATING NORMALLY.

LAST IE SITE INSPECTION DATE: MARCH 2 - 7, 1986

INSPECTION REPORT NO: 86011

R E P O R T S   F R O M   L I C E N S E E


NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
85-40	12/05/85	12/30/85	ESF ACTUATION
85-41	12/11/85	01/09/86	ESF ACTUATION
85-42	12/27/85	01/16/86	MISSSED HOURLY INSPECTION OF INOPERABLE FIRE BARRIER
85-43	12/27/85	01/24/86	MISSSED AUXILIARY BUILDING VENT SAMPLE

1. Docket: 50-298 OPERATING STATUS  
 2. Reporting Period: 02/01/86 Outage + On-line Hrs: 672.0  
 3. Utility Contact: K. E. SUTTON (402) 825-3811  
 4. Licensed Thermal Power (MWh): 2381  
 5. Nameplate Rating (Gross MWe): 983 X 0.85 = 836  
 6. Design Electrical Rating (Net MWe): 778  
 7. Maximum Dependable Capacity (Gross MWe): 787  
 8. Maximum Dependable Capacity (Net MWe): 764  
 9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE  
 10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_  
 11. Reasons for Restrictions, If Any:  
NONE  
 12. Report Period Hrs      MONTH      YEAR      CUMULATIVE  
672.0      1,416.0      102,265.0  
 13. Hours Reactor Critical      644.0      1,388.0      76,401.1  
 14. Rx Reserve Shtdn Hrs      .0      .0      .0  
 15. Hrs Generator On-Line      632.0      1,376.0      75,081.8  
 16. Unit Reserve Shtdn Hrs      .0      .0      .0  
 17. Gross Therm Ener (MWH)      1,471,661      3,209,093      148,071,759  
 18. Gross Elec Ener (MWH)      496,004      1,084,497      47,224,470  
 19. Net Elec Ener (MWH)      477,426      1,043,791      45,498,151  
 20. Unit Service Factor      94.0      97.2      73.4  
 21. Unit Avail Factor      94.0      97.2      73.4  
 22. Unit Cap Factor (MDC Net)      93.0      96.5      58.2  
 23. Unit Cap Factor (DER Net)      91.3      94.7      57.2  
 24. Unit Forced Outage Rate      6.0      2.8      5.0  
 25. Forced Outage Hours      40.0      40.0      3,314.7  
 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE  
 27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\* COOPER STATION \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

COOPER STATION



FEBRUARY 1986

Report Period FEB 1986

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* COOPER STATION \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System Component	Cause & Corrective Action to Prevent Recurrence
86-01	02/27/86	F	40.0	G	3			DURING THE PERFORMANCE OF A SPECIAL PROCEDURE TO TRANSFER OPERATION FROM TWO RF PUMPS TO A SINGLE RF PUMP, AN ERROR IN THE PROCEDURE ALLOWED A MISMATCH OF FEED PUMP FLOW AND STEAM FLOW. THIS RESULTED IN A DECREASING REACTOR WATER LEVEL AND CAUSED A LOW WATER LEVEL SCRAM.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	Instructions for Preparation of
	C-Refueling	H-Other	Data Entry Sheet
	D-Regulatory Restriction	3-Auto Scram	Licensee Event Report
	E-Operator Training & License Examination	4-Continued	(LER) File (NUREG-0161)
		5-Reduced Load	
		9-Other	

\*\*\*\*\*  
\* COOPER STATION \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1986

FACILITY DESCRIPTION

LOCATION  
STATE.....NEBRASKA  
COUNTY.....NEMAHIA  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...23 MI S OF  
NEBRASKA CITY, NEB  
TYPE OF REACTOR.....BWR  
DATE INITIAL CRITICALITY...FEBRUARY 21, 1974  
DATE ELEC ENER 1ST GENER...MAY 10, 1974  
DATE COMMERCIAL OPERATE....JULY 1, 1974  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER....MISSOURI RIVER  
ELECTRIC RELIABILITY  
COUNCIL.....MID-CONTINENT AREA  
RELIABILITY COORDINATION  
AGREEMENT

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....NEBRASKA PUBLIC POWER DISTRICT  
CORPORATE ADDRESS.....P.O. BOX 499  
COLUMBUS, NEBRASKA 68601  
CONTRACTOR  
ARCHITECT/ENGINEER.....BURNS & ROE  
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC  
CONSTRUCTOR.....BURNS & ROE  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....IV  
IE RESIDENT INSPECTOR.....D. DUBOIS  
LICENSING PROJ MANAGER.....W. LONG  
DOCKET NUMBER.....50-298  
LICENSE & DATE ISSUANCE....DPR-46, JANUARY 18, 1974  
PUBLIC DOCUMENT ROOM.....AUBURN PUBLIC LIBRARY  
1118 15TH STREET  
AUBURN, NEBRASKA 68305

I N S P E C T I O N     S T A T U S

INSPECTION SUMMARY

INSPECTION CONDUCTED NOV. 18-22, 1985 (85-31) ROUTINE, UNANNOUNCED INSPECTION OF SECONDARY CONTAINMENT INTERGRITY, SURVEILLANCE OF PIPE SUPPORTS AND THE FIRE PROTECTION PROGRAM AND ITS IMPLEMENTATION. THE INSPECTION INVOLVED 46 INSPECTOR-HOURS ONSITE BY NRC INSPECTORS. WITHIN THE AREAS INSPECTED, THREE VIOLATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

Report Period FEB 1986

I N S P E C T I O N     S T A T U S - (CONTINUED)

\*\*\*\*\*  
\* COOPER STATION \*  
\*\*\*\*\*

OTHER ITEMS

NONE

MANAGERIAL ITEMS:

PLANT STATUS:

NORMAL POWER OPERATION

LAST IE SITE INSPECTION DATE: NOVEMBER 18-22, 1985

INSPECTION REPORT NO: 50-298/85-31

R E P O R T S   F R O M   L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
86-001	01/27/86	02/26/86	INADVERTANT RWCU TEMPERATURE SWITCH SETPOINT CHANGE


=====

1. Docket: 50-302 OPERATING STATUS  
 2. Reporting Period: 02/01/86 Outage + On-line Hrs: 672.0  
 3. Utility Contact: D. GRAHAM (904) 795-3802  
 4. Licensed Thermal Power (Mwt): 2544  
 5. Nameplate Rating (Gross MWe): 989 X 0.9 = 890  
 6. Design Electrical Rating (Net MWe): 825  
 7. Maximum Dependable Capacity (Gross MWe): 860  
 8. Maximum Dependable Capacity (Net MWe): 821  
 9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE  
 10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_  
 11. Reasons for Restrictions, If Any:  
NONE  
 12. Report Period Hrs 672.0 MONTH 672.0 YEAR 1,416.0 CUMULATIVE 78,600.0  
 13. Hours Reactor Critical .0 23.6 50,325.4  
 14. Rx Reserve Shtdwn Hrs .0 .0 1,275.5  
 15. Hrs Generator On-Line .0 23.6 49,114.5  
 16. Unit Reserve Shtdwn Hrs .0 .0 .0  
 17. Gross Therm Ener (MWH) 0 55,103 110,523,968  
 18. Gross Elec Ener (MWH) 0 19,541 37,761,185  
 19. Net Elec Ener (MWH) 0 18,580 35,863,252  
 20. Unit Service Factor .0 1.7 62.5  
 21. Unit Avail Factor .0 1.7 62.5  
 22. Unit Cap Factor (MDC Net) .0 1.6 55.6  
 23. Unit Cap Factor (DER Net) .0 1.6 55.3  
 24. Unit Forced Outage Rate 100.0 98.3 21.6  
 25. Forced Outage Hours 672.0 1,392.4 13,553.2  
 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE  
 27. If Currently Shutdown Estimated Startup Date: 04/15/86

\*\*\*\*\*  
\* CRYSTAL RIVER 3 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

CRYSTAL RIVER 3



FEBRUARY 1986

Report Period FEB 1986

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* CRYSTAL RIVER 3 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
86-01	01/01/86	F	672.0	A	4	86-01	CB	PUMPXX	THE "A" REACTOR COOLANT PUMP SHAFT IS BEING REPLACED. NONDESTRUCTIVE TESTING AND EVALUATION OF B, C, AND D PUMP SHAFTS WILL ALSO BE PERFORMED.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*

CRYSTAL RIVER 3 REMAINS SHUTDOWN FOR EQUIPMENT REPAIR.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	1-Manual Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	2-Manual Scram Instructions for
	C-Refueling	H-Other	3-Auto Scram Preparation of
	D-Regulatory Restriction		4-Continued Data Entry Sheet
	E-Operator Training		5-Reduced Load Licensee Event Report
	& License Examination		9-Other (LER) File (NUREG-0161)

\*\*\*\*\*  
\* CRYSTAL RIVER 3 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1986

FACILITY DESCRIPTION

LOCATION STATE.....FLORIDA  
COUNTY.....CITRUS  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...7 MI NW OF  
CRYSTAL RIVER, FLA  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...JANUARY 14, 1977  
DATE ELEC ENER 1ST GENER...JANUARY 30, 1977  
DATE COMMERCIAL OPERATE....MARCH 13, 1977  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER....GULF OF MEXICO  
ELECTRIC RELIABILITY  
COUNCIL.....SOUTHEASTERN ELECTRIC  
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.... FLORIDA POWER CORPORATION  
CORPORATE ADDRESS.....3201 34TH STREET, SOUTH  
ST PETERSBURG, FLORIDA 33733  
CONTRACTOR  
ARCHITECT/ENGINEER.....GILBERT ASSOCIATES  
NUC STEAM SYS SUPPLIER...BABCOCK & WILCOX  
CONSTRUCTOR.....J. A. JONES CONSTRUCTION  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II  
IE RESIDENT INSPECTOR.....T. STETKA  
LICENSING PROJ MANAGER.....H. SILVER  
DOCKET NUMBER.....50-302  
LICENSE & DATE ISSUANCE....DPR-72, JANUARY 28, 1977  
PUBLIC DOCUMENT ROOM.....CRYSTAL RIVER PUBLIC LIBRARY  
668 N.W. FIRST  
CRYSTAL RIVER, FLORIDA 32639

I N S P E C T I O N     S T A T U S

INSPECTION SUMMARY

+ INSPECTION DECEMBER 9-13 (85-43): THIS ROUTINE, UNANNOUNCED INSPECTION INVOLVED 34 INSPECTOR-HOURS ON SITE IN THE AREAS OF LICENSEE ACTION ON PREVIOUS ENFORCEMENT MATTERS, DESIGN CONTROL, AND TESTS AND EXPERIMENTS. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION NOVEMBER 26 - JANUARY 17, 1986 (85-44): THIS ROUTINE INSPECTION INVOLVED 266 INSPECTOR-HOURS ON SITE BY TWO RESIDENT INSPECTORS IN THE AREAS OF PLANT OPERATIONS, SECURITY, RADIOLOGICAL CONTROLS, LICENSEE EVENT REPORTS AND NONCONFORMING OPERATIONS REPORTS, AND LICENSEE ACTION ON PREVIOUS INSPECTION ITEMS. NUMEROUS FACILITY TOURS WERE CONDUCTED AND FACILITY OPERATIONS OBSERVED. SOME OF THESE TOURS AND OBSERVATIONS WERE CONDUCTED ON BACKSHIFTS. TWO VIOLATIONS AND ONE DEVIATION WERE IDENTIFIED: FAILURE TO MAKE A ONE HOUR REPORT TO THE NRC OPERATIONS CENTER AS REQUIRED BY 10CFR 50.72; FAILURE TO ADHERE TO THE REQUIREMENTS OF A RADIATION WORK PERMIT; DEVIATION FROM A COMMITMENT TO AN NRC VIOLATION.

INSPECTION JANUARY 6-10 AND 14-16 (86-03): THIS ROUTINE, ANNOUNCED INSPECTION ENTAILED 67 INSPECTOR-HOURS ON SITE IN THE AREAS OF INSPECTOR ACTION ON PREVIOUS ENFORCEMENT MATTERS; INSPECTOR IDENTIFIED FOLLOW-UP ITEMS; REVIEW AND EVALUATION OF ISI DATA; LICENSEE ACTIONS RELATIVE TO REACTOR COOLANT PUMP "1A" SHAFT FAILURE. JANUARY 7, 1986 WAS DEDICATED TO RESPIRATOR TRAINING AND ISSUING OF APPROPRIATE PICTURE BADGE. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JANUARY 18 - FEBRUARY 7 (86-07): THIS ROUTINE INSPECTION INVOLVED 144 INSPECTOR-HOURS ON SITE BY TWO RESIDENT INSPECTORS IN THE AREAS OF PLANT OPERATIONS, SECURITY, RADIOLOGICAL CONTROLS, LICENSE EVENT REPORTS AND NONCONFORMING OPERATIONS REPORTS, IE INFORMATION NOTICES (IN), COLD WEATHER PREPARATIONS, AND LICENSEE ACTION ON PREVIOUS INSPECTION ITEMS. NUMEROUS

Report Period FEB 1986

INSPECTION STATUS - (CONTINUED)

\*\*\*\*\*  
\* CRYSTAL RIVER 3 \*  
\*\*\*\*\*

INSPECTION SUMMARY

FACILITY TOURS WERE CONDUCTED AND FACILITY OPERATIONS OBSERVED. SOME OF THESE TOURS AND OBSERVATIONS WERE CONDUCTED ON BACKSHIFTS. ONE VIOLATION WAS IDENTIFIED. FAILURE TO PERFORM ADEQUATE INSPECTIONS OF SAFETY-RELATED MAINTENANCE AND VERIFICATION OF REPLACEMENT PARTS AS REQUIRED BY 10CFR 50, APPENDIX B, CRITERION II.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

- + RCP 1A SHAFT SHEARED; REPLACEMENT COMPLETE.
- + RCP 1B SHAFT REPLACEMENT IN PROGRESS.
- + RCPS 1C AND 1D SHOW CRACK INDICATIONS; REPLACEMENT PLANNED.

FACILITY ITEMS (PLANS AND PROCEDURES):

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

- + SHUTDOWN, COOLED DOWN (MODE 5) IN ORDER TO REPAIR RCP 1A/1B/1C/1D.

LAST IE SITE INSPECTION DATE: JANUARY 18 - FEBRUARY 7, 1986 +

INSPECTION REPORT NO: 50-302/86-07 +

R E P O R T S   F R O M   L I C E N S E E


NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
85-023	10/26/85	11/25/85	REACTOR TRIP FOLLOWING AN INVERTER FAILURE. CAUSE - DEFECTIVE OSCILLATOR BOARD CAUSED THE LOW VOLTAGE FAILURE AND IT WAS REPLACED.
85-033	12/26/85	01/24/86	"B" CHANNEL LOW LEVEL BISTABLE FOUND TO HAVE FAILED TO THE TRIPPED CONDITION. FAILED BISTABLE REPLACED.

1. Docket: 50-346 OPERATING STATUS  
 2. Reporting Period: 02/01/86 Outage + On-line Hrs: 672.0  
 3. Utility Contact: MORTEZA KHARZRAI (419) 249-5000 X290  
 4. Licensed Thermal Power (MWh): 2772  
 5. Nameplate Rating (Gross MWe): 1069 X 0.9 = 962  
 6. Design Electrical Rating (Net MWe): 906  
 7. Maximum Dependable Capacity (Gross MWe): 904  
 8. Maximum Dependable Capacity (Net MWe): 860  
 9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE  
 10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_  
 11. Reasons for Restrictions, If Any:  
NONE  
 12. Report Period Hrs      MONTH      YEAR      CUMULATIVE  
                              672.0      1,416.0      66,481.0  
 13. Hours Reactor Critical      .0      .0      35,878.0  
 14. Rx Reserve Shtdn Hrs      .0      .0      4,058.8  
 15. Hrs Generator On-Line      .0      .0      34,371.8  
 16. Unit Reserve Shtdn Hrs      .0      .0      1,732.7  
 17. Gross Therm Ener (MWH)      0      0      81,297,599  
 18. Gross Elec Ener (MWH)      0      0      26,933,622  
 19. Net Elec Ener (MWH)      0      0      25,233,177  
 20. Unit Service Factor      .0      .0      51.7  
 21. Unit Avail Factor      .0      .0      54.3  
 22. Unit Cap Factor (MDC Net)      .0      ,0      44.1  
 23. Unit Cap Factor (DER Net)      .0      .0      41.9  
 24. Unit Forced Outage Rate      100.0      100.0      27.6  
 25. Forced Outage Hours      672.0      1,416.0      13,707.8  
 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE  
 27. If Currently Shutdown Estimated Startup Date: 04/28/86

\*\*\*\*\*  
\*      DAVIS-BESSE 1      \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

DAVIS-BESSE 1



FEBRUARY 1986

Report Period FEB 1986

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* DAVIS-BESSE 1 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
7	06/09/85	F	672.0	A	4	85-013	JK	SC	THE UNIT REMAINED SHUTDOWN FOLLOWING THE REACTOR TRIP ON JUNE 9, 1986. SEE OPERATIONAL SUMMARY FOR FURTHER DETAILS.

\*\*\*\*\*  
\* DAVIS-BESSE 1 REMAINS SHUTDOWN FOR EQUIPMENT REPAIR.  
\* SUMMARY \*  
\*\*\*\*\*

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	1-Manual Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	2-Manual Scram Instructions for
	C-Refueling	H-Other	3-Auto Scram Preparation of
	D-Regulatory Restriction		4-Continued Data Entry Sheet
	E-Operator Training		5-Reduced Load Licensee Event Report
	& License Examination		9-Other (LER) File (NUREG-0161)

\*\*\*\*\*  
\* DAVIS-BESSE 1 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1986

FACILITY DESCRIPTION

LOCATION  
STATE.....OHIO

COUNTY.....OTTAWA

DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...21 MI E OF  
TOLEDO, OH

TYPE OF REACTOR.....PWR

DATE INITIAL CRITICALITY...AUGUST 12, 1977

DATE ELEC ENER 1ST GENER...AUGUST 28, 1977

DATE COMMERCIAL OPERATE....JULY 31, 1978

CONDENSER COOLING METHOD...COOLING TOWER

CONDENSER COOLING WATER....LAKE ERIE

ELECTRIC RELIABILITY

COUNCIL.....EAST CENTRAL AREA  
RELIABILITY COORDINATION  
AGREEMENT

INSPECTION SUMMARY

NONE

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....TOLEDO EDISON

CORPORATE ADDRESS.....300 MADISON AVENUE  
TOLEDO, OHIO 43652

CONTRACTOR  
ARCHITECT/ENGINEER.....BECHTEL

NUC STEAM SYS SUPPLIER...BABCOCK & WILCOX

CONSTRUCTOR.....BECHTEL

TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III

IE RESIDENT INSPECTOR.....W. ROGERS

LICENSING PROJ MANAGER.....A. DEAGAZIO  
DOCKET NUMBER.....50-346

LICENSE & DATE ISSUANCE....NPF-3, APRIL 22, 1977

PUBLIC DOCUMENT ROOM.....UNIVERSITY OF TOLEDO LIBRARY  
GOVERNMENT DOCUMENTS COLLECTION  
2801 WEST BANCROFT AVENUE  
TOLEDO, OHIO 43606

I N S P E C T I O N     S T A T U S

Report Period FEB 1986

I N S P E C T I O N      S T A T U S - (CONTINUED)

\*\*\*\*\*  
\*           DAVIS-BESSE 1           \*  
\*\*\*\*\*

OTHER ITEMS

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

THE UNIT IS IN COLD SHUTDOWN FOLLOWING THE JUNE 9, 1985 TRIP.

LAST IE SITE INSPECTION DATE: FEBRUARY 26 - 28, 1986

INSPECTION REPORT NO: 86011

R E P O R T S   F R O M   L I C E N S E E


NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
85-05	12/30/85	01/29/86	IMPROPER BOOT-SEAL INSTALLATION
86-06	01/02/86	02/01/86	ENVIRONMENTAL QUALIFICATION PROGRAM NOT ADEQUATELY ESTABLISHED
86-07	01/04/86	02/01/86	CONTAINMENT AIR COOLER FAN RUNNING BACKWARD
86-02	12/10/85	01/09/86	EMERGENCY DIESEL GENERATOR AIR START SYSTEM PRESSURE INADEQUATE
86-03	12/13/85	01/16/86	ESSENTIAL 4160V BUS VOLTAGE HIGH
86-04	12/14/85	01/13/86	SAFETY FEATURES ACTUATION SYSTEM TESTING OF HIGH PRESSURE INJECTION

1. Docket: 50-275 OPERATING STATUS  
 2. Reporting Period: 02/01/86 Outage + On-line Hrs: 672.0  
 3. Utility Contact: BOB KANICK (805) 595-7351  
 4. Licensed Thermal Power (MWh): 3338  
 5. Nameplate Rating (Gross MWe): 1137  
 6. Design Electrical Rating (Net MWe): 1086  
 7. Maximum Dependable Capacity (Gross MWe): 1125  
 8. Maximum Dependable Capacity (Net MWe): 1073  
 9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE  
 10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_  
 11. Reasons for Restrictions, If Any:  
NONE  
 12. Report Period Hrs      MONTH      YEAR      CUMULATIVE  
672.0      1,416.0      7,150.3  
 13. Hours Reactor Critical      672.0      1,416.0      6,711.6  
 14. Rx Reserve Shtdwn Hrs      .0      .0      .0  
 15. Hrs Generator On-Line      672.0      1,416.0      6,623.3  
 16. Unit Reserve Shtdwn Hrs      .0      .0      .0  
 17. Gross Therm Ener (MWH)      2,102,251      4,526,520      21,091,973  
 18. Gross Elec Ener (MWH)      695,000      1,494,300      7,008,632  
 19. Net Elec Ener (MWH)      661,125      1,421,314      6,655,548  
 20. Unit Service Factor      100.0      100.0      92.6  
 21. Unit Avail Factor      100.0      100.0      92.6  
 22. Unit Cap Factor (MDC Net)      91.7      93.5      86.7  
 23. Unit Cap Factor (DER Net)      90.6      92.4      85.7  
 24. Unit Forced Outage Rate      .0      .0      3.6  
 25. Forced Outage Hours      .0      .0      247.4  
 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
REFUELING OUTAGE, 08/30/86, 68 DAYS.  
 27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\* DIABLO CANYON 1 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

DIABLO CANYON 1



FEBRUARY 1986

Report Period FEB 1986

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* DIABLO CANYON 1 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System Component	Cause & Corrective Action to Prevent Recurrence
-----	------	------	-------	--------	--------	------------	------------------	---

NONE

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
DIABLO CANYON 1 OPERATED ROUTINELY DURING THE FEBRUARY REPORT MONTH.

Type	Reason	Method	System & Component
F-Forced S-Sched	A-Equip Failure B-Maint or Test C-Refueling D-Regulatory Restriction E-Operator Training & License Examination	F-Admin G-Oper Error H-Other I-Continued J-Reduced Load K-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161)

\*\*\*\*\*  
\* DIABLO CANYON 1 \*  
\*\*\*\*\*

FACILITY DESCRIPTION

LOCATION  
STATE.....CALIFORNIA  
COUNTY.....SAN LUIS OBISPO  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...12 MI WSW OF  
SAN LUIS OBISPO  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY..APRIL 29, 1984  
DATE ELEC ENER 1ST GENER...NOVEMBER 11, 1984  
DATE COMMERCIAL OPERATE....MAY 7, 1985  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER....PACIFIC OCEAN  
ELECTRIC RELIABILITY  
COUNCIL.....WESTERN SYSTEMS  
COORDINATING COUNCIL

FACILITY DATA

Report Period FEB 1986

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....PACIFIC GAS & ELECTRIC  
CORPORATE ADDRESS.....77 BEALE STREET  
SAN FRANCISCO, CALIFORNIA 94106  
CONTRACTOR  
ARCHITECT/ENGINEER.....PACIFIC GAS & ELECTRIC  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
CONSTRUCTOR.....PACIFIC GAS & ELECTRIC  
TURBINE SUPPLIERS.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....V  
IE RESIDENT INSPECTOR.....M. MENDONCA  
LICENSING PROJ MANAGER.....H. SCHIERLING  
DOCKET NUMBER.....50-275  
LICENSE & DATE ISSUANCE....DPR-80, NOVEMBER 2, 1984  
PUBLIC DOCUMENT ROOM.....ROBERT F. KENNEDY LIBRARY  
CALIFORNIA POLYTECHNIC STATE UNIVERSITY  
SAN LUIS OBISPO, CA. 93407

INSPECTION STATUS

INSPECTION SUMMARY

+ INSPECTION ON DECEMBER 30, 1985 - JANUARY 3, 1986 (REPORT NO. 50-275/85-45) AREAS INSPECTED: ROUTINE, UNANNOUNCED INSPECTION OF THE LICENSEE'S EMERGENCY PREPAREDNESS PROGRAM INCLUDING: KNOWLEDGE AND PERFORMANCE OF DUTIES (TRAINING), LICENSEE AUDITS, AND THE PUBLIC INFORMATION PROGRAM. DURING THIS INSPECTION, VARIOUS INSPECTION PROCEDURES WERE UTILIZED. THE INSPECTION INVOLVED 40 INSPECTOR-HOURS ONSITE BY ONE NRC INSPECTOR.

RESULTS: OF THE THREE AREAS INSPECTED, TWO ITEMS OF NONCOMPLIANCE WERE IDENTIFIED IN TWO AREAS (FAILURE TO COMPLETE REQUIRED ANNUAL RETRAINING, AND FAILURE TO MAINTAIN EMERGENCY KITS).

+ INSPECTION ON FEBRUARY 24 - MARCH 7, 1986 (REPORT NO. 50-275/86-02) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

+ INSPECTION ON JANUARY 21 - FEBRUARY 3, 1986 (REPORT NO. 50-275/86-03) AREAS INSPECTED: ROUTINE, UNANNOUNCED INSPECTION OF LOW-LEVEL RADIOACTIVE WASTE (LLRW) STORAGE FACILITIES, AND FACILITY TOURS. THE LICENSEE'S ACTIONS WITH REGARD TO LICENSEE EVENT REPORT 85-34-LO WERE ALSO REVIEWED. DURING THIS INSPECTION, VARIOUS INSPECTION PROCEDURES WERE UTILIZED. THE INSPECTION INVOLVED 22 INSPECTOR-HOURS ONSITE AND 4 INSPECTOR-HOURS IN-OFFICE BY ONE REGIONALLY BASED NRC INSPECTOR.

RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

+ INSPECTION ON JANUARY 26 - MARCH 1, 1986 (REPORT NO. 50-275/86-04) AREAS INSPECTED: THE INSPECTION INCLUDED ROUTINE INSPECTIONS OF PLANT OPERATIONS, MAINTENANCE AND SURVEILLANCE ACTIVITIES, INDEPENDENT INSPECTION, AND FOLLOWUP OF ONSITE EVENTS.

Report Period FEB 1986

I N S P E C T I O N      S T A T U S - (CONTINUED)

\*\*\*\*\*  
\*           DIABLO CANYON 1  
\*\*\*\*\*

INSPECTION SUMMARY

DURING THIS INSPECTION, VARIOUS INSPECTION PROCEDURES WERE IDENTIFIED. THE INSPECTION INVOLVED 127 INSPECTOR-HOURS ONSITE BY THREE RESIDENT NRC INSPECTORS.

RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

+ INSPECTION ON FEBRUARY 10-14, 1986 (REPORT NO. 50-275/86-05) AREAS INSPECTED: UNANNOUNCED INSPECTION BY ONE REGIONALLY BASED INSPECTOR OF INSERVICE INSPECTION PROGRAM, OPEN ITEM CONSISTING OF IE BULLETIN(S)/ NOTICES AND PART 21 REPORT(S), AND INDEPENDENT INSPECTION OF THE PLANT. DURING THIS INSPECTION, VARIOUS INSPECTION PROCEDURES WERE UTILIZED. THE INSPECTION INVOLVED 50 INSPECTOR-HOURS ONSITE BY ONE NRC INSPECTOR.

RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

+ INSPECTION ON FEBRUARY 24-28, 1986 (REPORT NO. 50-275/86-06) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

A \$50,000 CIVIL PENALTY WAS PROPOSED BY THE NRC STAFF ON FEBRUARY 12, 1986 FOR FAILURE OF THE LICENSEE TO PROMPTLY IDENTIFY AND RESOLVE A WIRING ERROR THAT RESULTED IN ONE CHANNEL OF A MAINSTEAM ISOLATION VALVE BEING OUT OF SERVICE FOR AT LEAST FOUR MONTHS.

PLANT STATUS:

ROUTINE OPERATIONS.

LAST IE SITE INSPECTION DATE: 02/24-03/07/86

INSPECTION REPORT NO: 50-275/86-02

Report Period FEB 1986

R E P O R T S   F R O M   L I C E N S E E

\*\*\*\*\*  
\* DIABLO CANYON 1 \*  
\*\*\*\*\*

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
--------	------------------	-------------------	---------

-----  
85-37-L0 10-30-35 01-07-86 MISSED SURVEILLANCE CONTAINMENT SPRAY PUMPS 1-2 & 2-2  
=====

THIS PAGE INTENTIONALLY LEFT BLANK



Report Period FEB 1986

## UNIT SHUT DOWNS / REDUCTIONS

\*\*\*\*\*  
 \* DIABLO CANYON 2 \*  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
1	01/13/86	S	479.6	B	4				STRAINER REMOVAL OUTAGE.
2	02/19/86	F	1.8	H	1				NINE MINUTES AFTER PARALLELING TO THE GRID, THE GENERATOR WAS SEPARATED FROM THE SYSTEM WHEN A CRACKING SOUND WAS HEARD IN THE METERING POTENTIAL TRANSFORMER CABINETS. A FUSE DRAWER WAS FOUND TO BE NOT FULLY LATCHED.
3	02/22/86	F	53.8	A	3	2-86-005	TL	RG	A VOLTAGE TRANSIENT ON THE MAIN GENERATOR VOLTAGE REGULATOR RESULTED IN A TURBINE TRIP AND SUBSEQUENT REACTOR TRIP. THE CAUSE OF THE VOLTAGE TRANSIENT IS BEING INVESTIGATED.
4	02/28/86	F	2.5	A	1		JJ		UNIT 2 WAS REMOVED FROM THE GRID TO CORRECT A TURBINE DIGITAL CONTROL PROBLEM. THE UNIT WAS SWITCHED TO A DIFFERENT ELECTRO-HYDRAULIC CONTROL MODE AND RETURNED TO THE GRID.

\*\*\*\*\*  
 \* SUMMARY \*  
 \* DIABLO CANYON 2 RETURNED ONLINE FEBRUARY 20TH AND OPERATED ROUTINELY THE REMAINDER  
 \* OF THE MONTH.  
 \*\*\*\*\*

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	Instructions for Preparation of Data Entry Sheet
	C-Refueling	H-Other	
	D-Regulatory Restriction	3-Auto Scram	
	E-Operator Training & License Examination	4-Continued 5-Reduced Load 9-Other	Licensee Event Report (LER) File (NUREG-0161)

\*\*\*\*\*  
\* DIABLO CANYON 2 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1986

FACILITY DESCRIPTION

LOCATION  
STATE.....CALIFORNIA  
COUNTY.....SAN LUIS OBISPO  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...12 MI WSW OF  
SAN LUIS OBISPO  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...AUGUST 19, 1985  
DATE ELEC ENER 1ST GENER...OCTOBER 20, 1985  
DATE COMMERCIAL OPERATE....\*\*\*\*\*  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER....PACIFIC OCEAN  
ELECTRIC RELIABILITY  
COUNCIL.....WESTERN SYSTEMS  
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....PACIFIC GAS & ELECTRIC  
CORPORATE ADDRESS.....77 BEALE STREET  
SAN FRANCISCO, CALIFORNIA 94106  
CONTRACTOR  
ARCHITECT/ENGINEER.....PACIFIC GAS & ELECTRIC  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
CONSTRUCTOR.....PACIFIC GAS & ELECTRIC  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....V  
IE RESIDENT INSPECTOR.....M. MENDOCA  
LICENSING PROJ MANAGER.....H. SCHIERLING  
DOCKET NUMBER.....50-323  
LICENSE & DATE ISSUANCE....DPR-81, AUGUST 26, 1985  
PUBLIC DOCUMENT ROOM.....ROBERT F. KENNEDY LIBRARY  
CALIFORNIA POLYTECHNIC STATE UNIVERSITY  
SAN LUIS OBISPO, CA. 93407

I N S P E C T I O N     S T A T U S

INSPECTION SUMMARY

- + INSPECTION ON MARCH 3-7, 1986 (REPORT NO. 50-323/86-08) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.
- + INSPECTION ON MARCH 3-7, 1986 (REPORT NO. 50-323/86-09) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.
- + INSPECTION ON MARCH 2 - APRIL 5, 1986 (REPORT NO. 50-323/86-10) INSPECTION CONTINUING; TO BE REPORTED NEXT MONTH.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

+ NONE

Report Period FEB 1986

INSPECTION STATUS - (CONTINUED)

\*\*\*\*\*  
\* DIABLO CANYON 2 \*  
\*\*\*\*\*

OTHER ITEMS

FACILITY ITEMS (PLANS AND PROCEDURES):

+ NONE

MANAGERIAL ITEMS:

+ NONE

PLANT STATUS:

ROUTINE OPERATION.

LAST IE SITE INSPECTION DATE: 03/02-04/05/86+

INSPECTION REPORT NO: 50-323/86-10+

REPORTS FROM LICENSEE

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
--------	------------------	-------------------	---------


-----  
NONE  
=====

1. Docket: 50-237 OPERATING STATUS  
 2. Reporting Period: 02/01/86 Outage + On-line Hrs: 672.0  
 3. Utility Contact: D. C. MAXWELL (815) 942-2920  
 4. Licensed Thermal Power (MWt): 2527  
 5. Nameplate Rating (Gross MWe): 920 X 0.9 = 828  
 6. Design Electrical Rating (Net MWe): 794  
 7. Maximum Dependable Capacity (Gross MWe): 812  
 8. Maximum Dependable Capacity (Net MWe): 772  
 9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE  
 10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_  
 11. Reasons for Restrictions, If Any:  
NONE  
 12. Report Period Hrs 672.0 MONTH 672.0 YEAR 1,416.0 CUMULATIVE 138,480.0  
 13. Hours Reactor Critical 620.3  
 14. Rx Reserve Shtdwn Hrs .0  
 15. Hrs Generator On-Line 555.2  
 16. Unit Reserve Shtdwn Hrs .0  
 17. Gross Therm Ener (MWH) 1,234,874 2,584,205 204,260,804  
 18. Gross Elec Ener (MWH) 402,699 842,418 65,325,594  
 19. Net Elec Ener (MWH) 383,663 802,260 61,747,552  
 20. Unit Service Factor 82.6  
 21. Unit Avail Factor 82.6  
 22. Unit Cap Factor (MDC Net) 74.0  
 23. Unit Cap Factor (DER Net) 71.9  
 24. Unit Forced Outage Rate 17.1  
 25. Forced Outage Hours 116.8  
 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
MID-MAY FOR A WEEKEND SNUBBER INSPECTION.  
 27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*  
 \* DRESDEN 2 \*  
 \*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

DRESDEN 2



FEBRUARY 1986

Report Period FEB 1986

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* DRESDEN 2 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
3	02/04/86	F	116.8	A	1	86-005-0			STEAM LEAK IN X-AREA DRAIN LINE. DURING SUBSEQUENT START-UP REACTOR SCRAMMED WHILE MOVING MODE SWITCH FROM REFUEL TO START-UP (RX AT 0 MWT).

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*

DRESDEN 2 OPERATED WITH 1 OUTAGE FOR EQUIPMENT FAILURE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	Instructions for Preparation of
	C-Refueling	H-Other	Data Entry Sheet
	D-Regulatory Restriction		Licensee Event Report
	E-Operator Training & License Examination	5-Reduced Load 9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* DRESDEN 2 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1986

FACILITY DESCRIPTION

LOCATION  
STATE.....ILLINOIS

COUNTY.....GRUNDY

DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...9 MI E OF  
MORRIS, ILL

TYPE OF REACTOR.....BWR

DATE INITIAL CRITICALITY...JANUARY 7, 1970

DATE ELEC ENER 1ST GENER...APRIL 13, 1970

DATE COMMERCIAL OPERATE....JUNE 9, 1970

CONDENSER COOLING METHOD...COOLING LAKE

CONDENSER COOLING WATER....KANKAKEE RIVER

ELECTRIC RELIABILITY  
COUNCIL.....MID-AMERICA  
INTERPOOL NETWORK

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....COMMONWEALTH EDISON

CORPORATE ADDRESS.....P.O. BOX 767  
CHICAGO, ILLINOIS 60690

CONTRACTOR  
ARCHITECT/ENGINEER.....SARGENT & LUNDY

NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC

CONSTRUCTOR.....UNITED ENG. & CONSTRUCTORS

TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III

IE RESIDENT INSPECTOR.....L. MCGREGOR

LICENSING PROJ MANAGER.....R. GILBERT  
DOCKET NUMBER.....50-237

LICENSE & DATE ISSUANCE....DPR-19, DECEMBER 22, 1969

PUBLIC DOCUMENT ROOM.....MORRIS PUBLIC LIBRARY  
604 LIBERTY STREET  
MORRIS, ILLINOIS 60450

I N S P E C T I O N     S T A T U S

INSPECTION SUMMARY

INSPECTION DURING THE PERIOD OF NOVEMBER 1 THROUGH JANUARY 7 (85035): ROUTINE UNANNOUNCED RESIDENT INSPECTION OF PREVIOUS FINDINGS, OPERATIONAL SAFETY, MAINTENANCE/MODIFICATIONS, SURVEILLANCES, EVENTS, LICENSEE EVENT REPORTS, REFUELING ACTIVITIES, REFUELING SURVEILLANCE, AND REPORT REVIEW. THE INSPECTION INVOLVED A TOTAL OF 458 INSPECTOR-HOURS ONSITE BY FIVE NRC INSPECTORS INCLUDING 59 INSPECTOR-HOURS ONSITE DURING OFF-SHIFTS. OF THE NINE AREAS INSPECTED, NO VIOLATIONS WERE IDENTIFIED.

INSPECTION ON DECEMBER 16-19 (85037): ROUTINE, UNANNOUNCED INSPECTION OF THE FOLLOWING AREAS OF THE DRESDEN STATION'S EMERGENCY PREPAREDNESS PROGRAM: LICENSEE ACTIONS ON PREVIOUSLY IDENTIFIED ITEMS; EMERGENCY PLAN ACTIVATIONS; CHANGES TO THE EMERGENCY PREPAREDNESS PROGRAM; KNOWLEDGE AND PERFORMANCE OF DUTIES (TRAINING); LICENSEE AUDITS; AND MAINTENANCE OF EMERGENCY PREPAREDNESS. THE INSPECTION INVOLVED 50 INSPECTOR-HOURS ONSITE BY TWO NRC INSPECTORS. NO VIOLATIONS OF NRC REQUIREMENTS AND NO DEVIATIONS FROM COMMITMENTS TO THE NRC WERE IDENTIFIED DURING THIS INSPECTION. HOWEVER, ONE UNRESOLVED ITEM IS IDENTIFIED IN THE TEXT OF THIS REPORT.

INSPECTION ON DECEMBER 2-6 AND 16-19 (85040): THIS SPECIAL, ANNOUNCED ASSESSMENT BY TWO REGIONAL INSPECTORS OF MAINTENANCE ACTIVITIES INVOLVED A TOTAL OF 77 INSPECTOR-HOURS ONSITE. IT WAS CONDUCTED WITHIN THE GUIDELINES ESTABLISHED BY NRC INSPECTION PROCEDURES NO. 30730, NO. 62700, NO. 762702 AND NO. 92706. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

Report Period FEB 1986

I N S P E C T I O N      S T A T U S - (CONTINUED)

\*\*\*\*\*  
X            DRESDEN 2    X  
\*\*\*\*\*

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

UNIT IS OPERATING NORMALLY.


LAST IE SITE INSPECTION DATE: FEBRUARY 14 - APRIL 14, 1986

INSPECTION REPORT NO: 86004

R E P O R T S   F R O M   L I C E N S E E

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
85-43	12/05/85	01/03/86	LOSS OF POWER TO THE 125V DC RESERVE BUS DUE TO PROCEDURAL INADEQUACY
85-44	12/13/85	01/10/86	UNIT 2 AND 2/3 DIESEL GENERATORS (D/G) INOPERABLE DUE TO DAMAGED POWER CABLE OF THE 2/3 D/G COOLING WATER PUMP AND SUBSEQUENT FAILURE OF UNIT 2 D/G TURBO-CHARGER WHILE TESTING

1. Docket:	<u>50-249</u>	OPERATING STATUS		
2. Reporting Period:	<u>02/01/86</u>	Outage + On-line Hrs:	<u>672.0</u>	
3. Utility Contact:	<u>D. C. MAXWELL (815) 942-2920</u>			
4. Licensed Thermal Power (MWt)	<u>2527</u>			
5. Nameplate Rating (Gross MWe):	<u>920 X 0.9 = 828</u>			
6. Design Electrical Rating (Net MWe):	<u>794</u>			
7. Maximum Dependable Capacity (Gross MWe):	<u>812</u>			
8. Maximum Dependable Capacity (Net MWe):	<u>773</u>			
9. If Changes Occur Above Since Last Report, Give Reasons:	<u>NONE</u>			
10. Power Level To Which Restricted, If Any (Net MWe):	<u> </u>			
11. Reasons for Restrictions, If Any:	<u> </u>			
	<u>NONE</u>			
12. Report Period Hrs	<u>MONTH</u>	<u>YEAR</u>	<u>CUMULATIVE</u>	
13. Hours Reactor Critical	<u>672.0</u>	<u>1,416.0</u>	<u>128,065.0</u>	
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>93,442.9</u>	
15. Hrs Generator On-Line	<u>.0</u>	<u>.0</u>	<u>89,794.8</u>	
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>	
17. Gross Therm Ener (MWH)	<u>0</u>	<u>0</u>	<u>181,765,542</u>	
18. Gross Elec Ener (MWH)	<u>0</u>	<u>0</u>	<u>58,821,103</u>	
19. Net Elec Ener (MWH)	<u>-4,205</u>	<u>-9,934</u>	<u>55,716,359</u>	
20. Unit Service Factor	<u>.0</u>	<u>.0</u>	<u>70.1</u>	
21. Unit Avail Factor	<u>.0</u>	<u>.0</u>	<u>70.1</u>	
22. Unit Cap Factor (MDC Net)	<u>.0</u>	<u>.0</u>	<u>56.3</u>	
23. Unit Cap Factor (DER Net)	<u>.0</u>	<u>.0</u>	<u>4.8</u>	
24. Unit Forced Outage Rate	<u>.0</u>	<u>.0</u>	<u>12.0</u>	
25. Forced Outage Hours	<u>.0</u>	<u>.0</u>	<u>7,365.0</u>	
26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):				
	<u>NONE</u>			
27. If Currently Shutdown Estimated Start Date:	<u>06/04/86</u>			



FEBRUARY 1986

Report Period FEB 1986

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* DRESDEN 3 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
6	10/28/85	S	6/2.0	C	4		RC	FUELXX	OFF-LINE MANUALLY TO 9TH REFUELING/RECIRCULATION PIPE REPLACEMENT OUTAGE.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*

DRESDEN 3 REMAINS SHUTDOWN FOR REFUELING.

Type	Reason	Method	System & Component	
F-Forced	A-Equip Failure	F-Admin	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	2-Manual Scram	Instructions for
	C-Refueling	H-Other	3-Auto Scram	Preparation of
	D-Regulatory Restriction		4-Continued	Data Entry Sheet
	E-Operator Training		5-Reduced Load	Licensee Event Report
	& License Examination		9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* DRESDEN 3 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1986

FACILITY DESCRIPTION

LOCATION STATE.....ILLINOIS  
COUNTY.....GRUNDY  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...9 MI E OF  
MORRIS, ILL  
TYPE OF REACTOR.....BWR  
DATE INITIAL CRITICALITY...JANUARY 31, 1971  
DATE ELEC ENER 1ST GENER...JULY 22, 1971  
DATE COMMERCIAL OPERATE....NOVEMBER 16, 1971  
CONDENSER COOLING METHOD...COOLING LAKE  
CONDENSER COOLING WATER....KAMKAKEE RIVER  
ELECTRIC RELIABILITY  
COUNCIL.....MID-AMERICA  
INTERPOOL NETWORK

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....COMMONWEALTH EDISON  
CORPORATE ADDRESS.....P.O. BOX 767  
CHICAGO, ILLINOIS 60690

CONTRACTOR  
ARCHITECT/ENGINEER.....SARGENT & LUNDY  
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC  
CONSTRUCTOR.....UNITED ENG. & CONSTRUCTORS  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III  
IE RESIDENT INSPECTOR.....L. MCGREGOR  
LICENSING PROJ MANAGER.....R. GILBERT  
DOCKET NUMBER.....50-249  
LICENSE & DATE ISSUANCE....DPR-25, MARCH 2, 1971  
PUBLIC DOCUMENT ROOM.....MORRIS PUBLIC LIBRARY  
604 LIBERTY STREET  
MORRIS, ILLINOIS 60450

I N S P E C T I O N     S T A T U S

INSPECTION SUMMARY

INSPECTION DURING THE PERIOD OF NOVEMBER 1 THROUGH JANUARY 7 (85030): ROUTINE UNANNOUNCED RESIDENT INSPECTION OF PREVIOUS FINDINGS, OPERATIONAL SAFETY, MAINTENANCE/MODIFICATIONS, SURVEILLANCES, EVENTS, LICENSEE EVENT REPORTS, REFUELING ACTIVITIES, REFUELING SURVEILLANCE, AND REPORT REVIEW. THE INSPECTION INVOLVED A TOTAL OF 458 INSPECTOR-HOURS ONSITE BY FIVE NRC INSPECTORS INCLUDING 59 INSPECTOR-HOURS ONSITE DURING OFF-SHIFTS. OF THE NINE AREAS INSPECTED, NO VIOLATIONS WERE IDENTIFIED.

INSPECTION ON DECEMBER 16-19 (85033): ROUTINE, UNANNOUNCED INSPECTION OF THE FOLLOWING AREAS OF THE DRESDEN STATION'S EMERGENCY PREPAREDNESS PROGRAM: LICENSEE ACTIONS ON PREVIOUSLY IDENTIFIED ITEMS; EMERGENCY PLAN ACTIVATIONS; CHANGES TO THE EMERGENCY PREPAREDNESS PROGRAM; KNOWLEDGE AND PERFORMANCE OF DUTIES (TRAINING); LICENSEE AUDITS; AND MAINTENANCE OF EMERGENCY PREPAREDNESS. THE INSPECTION INVOLVED 50 INSPECTOR-HOURS ONSITE BY TWO NRC INSPECTORS. NO VIOLATIONS OF NRC REQUIREMENTS AND NO DEVIATIONS FROM COMMITMENTS TO THE NRC WERE IDENTIFIED DURING THIS INSPECTION. HOWEVER, ONE UNRESOLVED ITEM IS IDENTIFIED IN THE TEXT OF THIS REPORT.

INSPECTION ON DECEMBER 2-6 AND 16-19 (85038): THIS SPECIAL, ANNOUNCED ASSESSMENT BY TWO REGIONAL INSPECTORS OF MAINTENANCE ACTIVITIES INVOLVED A TOTAL OF 77 INSPECTOR-HOURS ONSITE. IT WAS CONDUCTED WITHIN THE GUIDELINES ESTABLISHED BY NRC INSPECTION PROCEDURES NO. 30730, NO. 62700, NO. 762702 AND NO. 92706. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

Report Period FEB 1986

I N S P E C T I O N      S T A T U S - (CONTINUED)

\*\*\*\*\*  
\* DRESDEN 3 \*  
\*\*\*\*\*

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

SHUT DOWN FOR MAJOR PIPING REPLACEMENT ON OCTOBER 27, 1985.

LAST IE SITE INSPECTION DATE: JANUARY 28 - FEBRUARY 7, 1986

INSPECTION REPORT NO: 86006


R E P O R T S   F R O M   L I C E N S E E

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
85-25	12/31/85	01/29/86	REACTOR BUILDING VENTILATION SYSTEM ISOLATION AND AUTOMATIC INITIATION OF STANDBY GAS TREATMENT SYSTEM CAUSED BY A VIBRATED LEVEL INDICATOR

1. Docket: 50-331 OPERATING STATUS  
 2. Reporting Period: 02/01/86 Outage + On-line Hrs: 672.0  
 3. Utility Contact: BRADFORD THOMAS (319) 851-7339  
 4. Licensed Thermal Power (MWe): 1658  
 5. Nameplate Rating (Gross MWe): 663 X 0.9 = 597  
 6. Design Electrical Rating (Net MWe): 538  
 7. Maximum Dependable Capacity (Gross MWe): 545  
 8. Maximum Dependable Capacity (Net MWe): 515  
 9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE  
 10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_  
 11. Reasons for Restrictions, If Any:  
NONE  
 12. Report Period Hrs      MONTH      YEAR      CUMULATIVE  
                               672.0    1,416.0    97,104.0  
 13. Hours Reactor Critical      MONTH      YEAR      CUMULATIVE  
                               672.0    1,416.0    68,711.3  
 14. Rx Reserve Shtdwn Hrs      .0      .0      130.3  
 15. Hrs Generator On-Line      MONTH      YEAR      CUMULATIVE  
                               672.0    1,416.0    66,975.5  
 16. Unit Reserve Shtdwn Hrs      .0      .0      .0  
 17. Gross Therm Ener (MWH)      831,031    1,683,221    84,289,424  
 18. Gross Elec Ener (MWH)      284,746    575,958    28,232,019  
 19. Net Elec Ener (MWH)      267,442    540,272    26,434,690  
 20. Unit Service Factor      100.0    100.0    69.0  
 21. Unit Avail Factor      100.0    100.0    69.0  
 22. Unit Cap Factor (MDC Net)      77.3    74.1    52.9  
 23. Unit Cap Factor (DER Net)      74.0    70.9    50.6  
 24. Unit Forced Outage Rate      .0      .0      15.7  
 25. Forced Outage Hours      .0      .0      12,384.8  
 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
SURV TESTING & INSPECTION: 03/14/86, 2 WEEKS.  
 27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\* DUANE ARNOLD \*  
\*\*\*\*\*  
AVERAGE DAILY POWER LEVEL (MWe) PLOT

DUANE ARNOLD



FEBRUARY 1986

Report Period FEB 1986

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* DUANE ARNOLD \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System Component	Cause & Corrective Action to Prevent Recurrence
-----	------	------	-------	--------	--------	------------	------------------	---

NONE

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
DUANE ARNOLD OPERATED ROUTINELY DURING THE FEBRUARY REPORT PERIOD.

Type	Reason	Method	System & Component	
F-Forced S-Sched	A-Equip Failure B-Maint or Test C-Refueling D-Regulatory Restriction E-Operator Training & License Examination	F-Admin G-Oper Error H-Other I-Continued J-Reduced Load K-Other	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 6-Other 7-Other 8-Other 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161)

\*\*\*\*\*  
\* DUANE ARNOLD \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1986

FACILITY DESCRIPTION

LOCATION  
STATE.....IOWA  
COUNTY.....LINN  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...8 MI NW OF  
CEDAR RAPIDS, IA

TYPE OF REACTOR.....BWR  
DATE INITIAL CRITICALITY...MARCH 23, 1974  
DATE ELEC ENER 1ST GENER...MAY 19, 1974

DATE COMMERCIAL OPERATE....FEBRUARY 1, 1975  
CONDENSER COOLING METHOD...COOLING TOWER  
CONDENSER COOLING WATER....CEDAR RAPIDS RIVER

ELECTRIC RELIABILITY  
COUNCIL.....MID-CONTINENT AREA  
RELIABILITY COORDINATION  
AGREEMENT

I N S P E C T I O N     S T A T U S

INSPECTION SUMMARY

NONE

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....IOWA ELECTRIC LIGHT & POWER  
CORPORATE ADDRESS.....I E TOWERS, P.O. BOX 351  
CEDAR RAPIDS, IOWA 52406

CONTRACTOR  
ARCHITECT/ENGINEER.....BECHTEL  
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC  
CONSTRUCTOR.....BECHTEL  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III  
IE RESIDENT INSPECTOR.....J. WEIBE  
LICENSING PROJ MANAGER....M. THADANI  
DOCKET NUMBER.....50-331  
LICENSE & DATE ISSUANCE....DPR-49, FEBRUARY 22, 1974  
PUBLIC DOCUMENT ROOM.....CEDAR RAPIDS PUBLIC LIBRARY  
500 FIRST STREET, S.E.  
CEDAR RAPIDS, IOWA 52401

Report Period FEB 1986

I N S P E C T I O N      S T A T U S - (CONTINUED)

\*\*\*\*\*  
\*           DUANE ARNOLD   \*  
\*\*\*\*\*

OTHER ITEMS

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

OPERATING ROUTINELY

LAST IE SITE INSPECTION DATE: FEBRUARY 24 - 28, 1986

INSPECTION REPORT NO: 86005

R E P O R T S   F R O M   L I C E N S E E


NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
85-47	12/01/85	12/31/85	SPURIOUS ACTUATIONS OF CONTROL ROOM STANDBY FILTER UNIT

1. Docket: 50-348 OPERATING STATUS  
 2. Reporting Period: 02/01/86 Outage + On-line Hrs: 672.0  
 3. Utility Contact: J. D. WOODARD (205) 899-5156  
 4. Licensed Thermal Power (MWh): 2652  
 5. Nameplate Rating (Gross MWe): 1045 X 0.85 = 888  
 6. Design Electrical Rating (Net MWe): 829  
 7. Maximum Dependable Capacity (Gross MWe): 873  
 8. Maximum Dependable Capacity (Net MWe): 827  
 9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE  
 10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_  
 11. Reasons for Restrictions, If Any:  
NONE  
 12. Report Period Hrs      MONTH      YEAR      CUMULATIVE  
    672.0      1,416.0      72,288.0  
 13. Hours Reactor Critical      664.4      1,408.4      51,041.5  
 14. Rx Reserve Shtdn Hrs      .0      .0      3,650.7  
 15. Hrs Generator On-Line      664.4      1,408.4      49,814.0  
 16. Unit Reserve Shtdn Hrs      .0      .0      .0  
 17. Gross Therm Ener (MWH)      1,741,224      3,618,933      126,490,473  
 18. Gross Elec Ener (MWH)      579,440      1,203,928      40,406,112  
 19. Net Elec Ener (MWH)      550,396      1,142,470      38,140,188  
 20. Unit Service Factor      98.9      99.5      68.9  
 21. Unit Avail Factor      98.9      99.5      68.9  
 22. Unit Cap Factor (MDC Net)      99.0      97.6      65.9\*  
 23. Unit Cap Factor (DER Net)      98.8      97.3      63.6  
 24. Unit Forced Outage Rate      1.1      .5      11.4  
 25. Forced Outage Hours      7.6      7.6      6,390.5  
 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE  
 27. If Currently Shutdown Estimated Startup Date: 03/02/86

\*\*\*\*\*  
\* FARLEY 1 \*  
\*\*\*\*\*

#### AVERAGE DAILY POWER LEVEL (MWe) PLOT

FARLEY 1



FEBRUARY 1986

\* Item calculated with a Weighted Average

PAGE 2-108

Report Period FEB 1986

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* FARLEY 1 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
001	02/28/86	F	7.6	A	3	86-004-00	AA	PEN	A REACTOR TRIP OCCURRED AS A RESULT OF A DROPPED CONTROL ROD. A SHORT EXISTED IN THE CONTAINER ELECTRICAL PENETRATION FOR THE CONTROL ROD STATIONARY AND MOVABLE GRIPPERS AND CAUSED THE CONTROL ROD TO DROP.

\*\*\*\*\* FARLEY 1 OPERATED WITH 1 OUTAGE FOR EQUIPMENT FAILURE.  
\* SUMMARY \*  
\*\*\*\*\*

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	Instructions for
	C-Refueling	H-Other	Preparation of
	D-Regulatory Restriction		Data Entry Sheet
	E-Operator Training		Licensee Event Report
	& License Examination	5-Reduced Load 9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* FARLEY 1 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1986

FACILITY DESCRIPTION

LOCATION STATE.....ALABAMA  
COUNTY.....HOUSTON  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...18 MI SE OF  
DOTHAN, ALA  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...AUGUST 9, 1977  
DATE ELEC ENER 1ST GENER...AUGUST 18, 1977  
DATE COMMERCIAL OPERATE....DECEMBER 1, 1977  
CONDENSER COOLING METHOD...COOLING TOWER  
CONDENSER COOLING WATER....CHATAHOOCHEE RIVER  
ELECTRIC RELIABILITY  
COUNCIL.....SOUTHEASTERN ELECTRIC  
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....ALABAMA POWER CO.  
CORPORATE ADDRESS.....600 NORTH 18TH STREET  
BIRMINGHAM, ALABAMA 35203  
CONTRACTOR  
ARCHITECT/ENGINEER.....SOUTHERN SERVICES INCORPORATED  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
CONSTRUCTOR.....DANIEL INTERNATIONAL  
TURBINE SUPPLIER.....WESTINGHOUSE  
REGULATORY INFORMATION  
IE REGION RESPONSIBLE.....II  
IE RESIDENT INSPECTOR.....W. BRADFORD  
LICENSING PROJ MANAGER.....E. REEVES  
DOCKET NUMBER.....50-348  
LICENSE & DATE ISSUANCE....NPF-2, JUNE 25, 1977  
PUBLIC DOCUMENT ROOM.....G.S. HOUSTON MEMORIAL LIBRARY  
212 W. BURDESHAW STREET  
DOOTHAN, ALABAMA 36301

I N S P E C T I O N     S T A T U S

INSPECTION SUMMARY

+ INSPECTION JANUARY 21-24 (86-01): THIS ROUTINE, UNANNOUNCED INSPECTION INVOLVED 15 INSPECTOR-HOURS ON SITE IN THE AREA OF PLANT CHEMISTRY. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JANUARY 13-17 (86-02); THIS ROUTINE, UNANNOUNCED INSPECTION INVOLVED 19 INSPECTOR-HOURS ON SITE DURING REGULAR HOURS IN THE AREA OF RADIATION PROTECTION INCLUDING EXTERNAL EXPOSURE CONTROL; INTERNAL EXPOSURE CONTROL; TRAINING AND QUALIFICATIONS OF PERSONNEL; RADIOACTIVE MATERIALS CONTROL, POSTING AND LABELING; AND PROGRAM FOR MAINTAINING EXPOSURES AS LOW AS REASONABLY ACHIEVABLE (ALARA). NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

Report Period FEB 1986

I N S P E C T I O N      S T A T U S - (CONTINUED)

\*\*\*\*\*  
\* FARLEY 1 \*  
\*\*\*\*\*

OTHER ITEMS

NONE.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

NORMAL OPERATIONS.

LAST IE SITE INSPECTION DATE: JANUARY 21-24, 1986 +

INSPECTION REPORT NO: 50-348/86-01 +

R E P O R T S   F R O M   L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
-----			
NONE.			
-----			


=====

1. Docket: 50-364 OPERATING STATUS  
 2. Reporting Period: 02/01/86 Outage + On-line Hrs: 672.0  
 3. Utility Contact: J. D. WOODARD (205) 899-5156  
 4. Licensed Thermal Power (MWT): 2652  
 5. Nameplate Rating (Gross MWe): 860  
 6. Design Electrical Rating (Net MWe): 829  
 7. Maximum Dependable Capacity (Gross MWe): 872  
 8. Maximum Dependable Capacity (Net MWe): 829  
 9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE  
 10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_  
 11. Reasons for Restrictions, If Any:  
NONE  
 12. Report Period Hrs      MONTH      YEAR      CUMULATIVE  
                               672.0      1,416.0      40,201.0  
 13. Hours Reactor Critical      672.0      1,386.2      35,186.8  
 14. Rx Reserve Shtdwn Hrs      .0      .0      138.4  
 15. Hrs Generator On-Line      672.0      1,378.5      34,770.9  
 16. Unit Reserve Shtdwn Hrs      .0      .0      .0  
 17. Gross Therm Ener (MWH)      1,755,415      3,553,653      89,397,051  
 18. Gross Elec Ener (MWH)      584,936      1,187,366      28,909,976  
 19. Net Elec Ener (MWH)      557,696      1,130,226      27,419,466  
 20. Unit Service Factor      100.0      97.4      86.5  
 21. Unit Avail Factor      100.0      97.4      86.5  
 22. Unit Cap Factor (MDC Net)      100.1      96.3      82.3  
 23. Unit Cap Factor (DER Net)      100.1      96.3      82.3  
 24. Unit Forced Outage Rate      .0      2.6      4.7  
 25. Forced Outage Hours      .0      37.5      1,724.3  
 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
REFUELING/MAINT. OUTAGE, 4/4/86 APPROX. 5 WEEKS.  
 27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\* FARLEY 2 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

FARLEY 2



FEBRUARY 1986

Report Period FEB 1986

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* FARLEY 2 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System Component	Cause & Corrective Action to Prevent Recurrence
-----	------	------	-------	--------	--------	------------	------------------	---

NONE

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
FARLEY 2 OPERATED AT FULL POWER IN FEBRUARY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	Instructions for
	C-Refueling	H-Other	Preparation of
	D-Regulatory Restriction		Data Entry Sheet
	E-Operator Training		Licensee Event Report
	& License Examination	5-Reduced Load 9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* FARLEY 2 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1986

FACILITY DESCRIPTION

LOCATION STATE.....ALABAMA  
COUNTY.....HOUSTON  
DIST AND DIRECTION FROM NEAREST POPULATION CTR...28 MI SE OF  
DOOTHAN, ALA  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...MAY 5, 1981  
DATE ELEC ENER 1ST GENER...MAY 25, 1981  
DATE COMMERCIAL OPERATE....JULY 30, 1981  
CONDENSER COOLING METHOD...COOLING TOWER  
CONDENSER COOLING WATER....CHATAHOOCHEE RIVER  
ELECTRIC RELIABILITY COUNCIL.....SOUTHEASTERN ELECTRIC RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....ALABAMA POWER CO.  
CORPORATE ADDRESS.....600 NORTH 18TH STREET  
BIRMINGHAM, ALABAMA 35203  
CONTRACTOR  
ARCHITECT/ENGINEER.....SOUTHERN SERVICES INCORPORATED  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
CONSTRUCTOR.....BECHTEL  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II  
IE RESIDENT INSPECTOR.....W. BRADFORD  
LICENSING PROJ MANAGER.....E. REEVES  
DOCKET NUMBER.....50-364  
LICENSE & DATE ISSUANCE....NPF-8, MARCH 31, 1981  
PUBLIC DOCUMENT ROOM.....G.S. HOUSTON MEMORIAL LIBRARY  
212 W. BURDESHAW STREET  
DOOTHAN, ALABAMA 36301

I N S P E C T I O N     S T A T U S

INSPECTION SUMMARY

+ INSPECTION JANUARY 21-24 (86-01): THIS ROUTINE, UNANNOUNCED INSPECTION INVOLVED 16 INSPECTOR-HOURS ON SITE IN THE AREA OF PLANT CHEMISTRY. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JANUARY 13-17 (86-02); THIS ROUTINE, UNANNOUNCED INSPECTION INVOLVED 19 INSPECTOR-HOURS ON SITE DURING REGULAR HOURS IN THE AREA OF RADIATION PROTECTION INCLUDING EXTERNAL EXPOSURE CONTROL; INTERNAL EXPOSURE CONTROL; TRAINING AND QUALIFICATIONS OF PERSONNEL; RADIOACTIVE MATERIALS CONTROL, POSTING AND LABELING; AND PROGRAM FOR MAINTAINING EXPOSURES AS LOW AS REASONABLY ACHIEVABLE (ALARA). NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

Report Period FEB 1986

INSPECTION STATUS - (CONTINUED)

\*\*\*\*\*  
\* FARLEY 2 \*  
\*\*\*\*\*

OTHER ITEMS

LICENSEE CONTINUES TENDON FIELD ANCHORS INSPECTION.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

NORMAL OPERATION.

LAST IE SITE INSPECTION DATE: JANUARY 21-24, 1986 +

INSPECTION REPORT NO: 50-364/86-01 +

R E P O R T S   F R O M   L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
--------	------------------	-------------------	---------

=====


NONE.

1. Docket: 50-333 OPERATING STATUS  
 2. Reporting Period: 02/01/86 Outage + On-line Hrs: 672.0  
 3. Utility Contact: J. COOK (315) 342-3840  
 4. Licensed Thermal Power (MWh): 2436  
 5. Nameplate Rating (Gross MWe): 981 X 0.9 = 883  
 6. Design Electrical Rating (Net MWe): 816  
 7. Maximum Dependable Capacity (Gross MWe): 823  
 8. Maximum Dependable Capacity (Net MWe): 796  
 9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE  
 10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_  
 11. Reasons for Restrictions, If Any:  
NONE  
 12. Report Period Hrs      MONTH      YEAR      CUMULATIVE  
672.0      1,416.0      92,857.0  
 13. Hours Reactor Critical      672.0      1,416.0      66,831.6  
 14. Rx Reserve Shtdwn Hrs      .0      .0      .0  
 15. Hrs Generator On-Line      672.0      1,416.0      64,942.4  
 16. Unit Reserve Shtdwn Hrs      .0      .0      .0  
 17. Gross Therm Ener (MWH)      1,632,264      3,427,560      139,140,274  
 18. Gross Elec Ener (MWH)      558,490      1,172,770      47,204,110  
 19. Net Elec Ener (MWH)      539,705      1,132,565      45,697,090  
 20. Unit Service Factor      100.0      100.0      69.9  
 21. Unit Avail Factor      100.0      100.0      69.9  
 22. Unit Cap Factor (MDC Net)      100.9      99.6      63.6\*  
 23. Unit Cap Factor (DER Net)      98.4      97.7      60.3  
 24. Unit Forced Outage Rate      .0      .0      13.0  
 25. Forced Outage Hours      .0      .0      9,846.0  
 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
MAINT. OUTAGE: 03/13, APPROX. 2 WEEKS.  
 27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\* FITZPATRICK \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

FITZPATRICK



FEBRUARY 1986

\* Item calculated with a Weighted Average

Report Period FEB 1986

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* FITZPATRICK \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System Component	Cause & Corrective Action to Prevent Recurrence
-----	------	------	-------	--------	--------	------------	------------------	---

NONE

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
THE FITZPATRICK PLANT OPERATED AT NEAR FULL POWER FOR THIS ENTIRE REPORTING PERIOD.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	Instructions for
	C-Refueling	H-Other	Preparation of
	D-Regulatory Restriction		Data Entry Sheet
	E-Operator Training & License Examination	5-Reduced Load 9-Other	Licensee Event Report (LER) File (NUREG-0161)

\*\*\*\*\*  
\* FITZPATRICK \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1986

FACILITY DESCRIPTION

LOCATION  
STATE.....NEW YORK

COUNTY.....OSWEGO

DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...8 MI NE OF  
OSWEGO, NY

TYPE OF REACTOR.....BWR

DATE INITIAL CRITICALITY...NOVEMBER 17, 1974

DATE ELEC ENER 1ST GENER...FEBRUARY 1, 1975

DATE COMMERCIAL OPERATE....JULY 28, 1975

CONDENSER COOLING METHOD...ONCE THRU

CONDENSER COOLING WATER....LAKE ONTARIO

ELECTRIC RELIABILITY  
COUNCIL.....NORTHEAST POWER  
COORDINATING COUNCIL

I N S P E C T I O N     S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

TECHNICAL SPECIFICATION 6.8(A) REQUIRES THAT WRITTEN PROCEDURES AND ADMINISTRATIVE POLICIES BE ESTABLISHED, IMPLEMENTED, AND MAINTAINED THAT MEET OR EXCEED THE REQUIREMENTS AND RECOMMENDATIONS OF SECTION 5 "FACILITY ADMINISTRATIVE POLICIES AND PROCEDURES" OF ANSI 18.7-1972. WORK ACTIVITY CONTROL PROCEDURE 10.1.1, PROCEDURE FOR CONTROL OF MAINTENANCE, REVISION 9, DATED SEPTEMBER 28, 1984, SECTION 7.2.1 REQUIRES THE USE OF A WORK TRACKING FORM TO TRACK AND CONTROL CORRECTIVE MAINTENANCE FOR CATEGORY I SYSTEMS. WORK ACTIVITY CONTROL PROCEDURE 10.1.2, EQUIPMENT AND PERSONNEL PROTECTIVE TAGGING, REVISION 8, DATED SEPTEMBER 25, 1985, REQUIRES, IN SECTION 6.18, REMOVAL OF REFERENCE TAGS FROM CONTROL SWITCHES WHEN THE TAGOUT IS RELEASED AND, IN SECTION 7.1.3.D, AN INDEPENDENT VERIFICATION OF THE REMOVAL OF THE TAGS AND REPOSITION OF EACH DEVICE. CONTRARY TO THE ABOVE, ON NOVEMBER 6, 1985, THE FILTERS WERE REPLACED FOR THE AIR HANDLING UNITS (AHU) (CATEGORY I) OF THE 125 STATION BATTERY VENTILATION SYSTEM WITHOUT A WORK TRACKING FORM, AND THE REMOVAL OF PROTECTIVE TAGOUT NO. 851701 ON NOVEMBER 7, 1985, WAS NOT PROPERLY CONTROLLED, LEAVING THE CONTROL SWITCHES FOR THE "B" AHU TAGGED IN THE PULL-TO-LOCK POSITION.  
(8502 4)

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....NEW YORK POWER AUTHORITY

CORPORATE ADDRESS.....10 COLUMBUS CIRCLE  
NEW YORK, NEW YORK 10019

CONTRACTOR  
ARCHITECT/ENGINEER.....STONE & WEBSTER  
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC  
CONSTRUCTOR.....STONE & WEBSTER  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I

IE RESIDENT INSPECTOR.....A. LUPTAK

LICENSING PROJ MANAGER.....H. ABELSON  
DOCKET NUMBER.....50-333

LICENSE & DATE ISSUANCE....DPR-59, OCTOBER 17, 1974

PUBLIC DOCUMENT ROOM.....STATE UNIVERSITY COLLEGE OF OSWEGO  
PENFIELD LIBRARY - GOVERNMENT DOCUMENTS COL  
OSWEGO, NY 13126  
(315) 341-2323

Report Period FEB 1986

I N S P E C T I O N      S T A T U S - (CONTINUED)

\*\*\*\*\*  
X      FITZPATRICK      X  
\*\*\*\*\*

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S   F R O M   L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
-----			
NO INPUT PROVIDED.			
-----			


=====

1. Docket: 50-285 OPERATING STATUS  
 2. Reporting Period: 02/01/86 Outage + On-line Hrs: 672.0  
 3. Utility Contact: T. P. MATTHEWS (402) 536-4733  
 4. Licensed Thermal Power (MWt): 1500  
 5. Nameplate Rating (Gross MWe): 591 X 0.85 = 502  
 6. Design Electrical Rating (Net MWe): 478  
 7. Maximum Dependable Capacity (Gross MWe): 502  
 8. Maximum Dependable Capacity (Net MWe): 478  
 9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE  
 10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_  
 11. Reasons for Restrictions, If Any:  
NONE  
 12. Report Period Hrs      MONTH      YEAR      CUMULATIVE  
    672.0      1,416.0      108,961.0  
 13. Hours Reactor Critical      672.0      1,220.5      83,686.8  
 14. Rx Reserve Shtdwn Hrs      .0      .0      1,309.5  
 15. Hrs Generator On-Line      672.0      1,044.7      82,117.7  
 16. Unit Reserve Shtdwn Hrs      .0      .0      .0  
 17. Gross Therm Ener (MWH)      838,106      1,012,615      104,763,660  
 18. Gross Elec Ener (MWH)      279,965      330,933      34,627,357  
 19. Net Elec Ener (MWH)      268,313      313,861      32,791,746  
 20. Unit Service Factor      100.0      73.8      75.4  
 21. Unit Avail Factor      100.0      73.8      75.4  
 22. Unit Cap Factor (MDC Net)      83.5      46.4      65.3\*  
 23. Unit Cap Factor (DER Net)      83.5      46.4      63.0  
 24. Unit Forced Outage Rate      .0      .0      3.5  
 25. Forced Outage Hours      .0      .0      1,750.3  
 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE  
 27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*  
 \* FORT CALHOUN 1 \*  
 \*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

FORT CALHOUN 1



FEBRUARY 1986

\* Item calculated with a Weighted Average

PAGE 2-120

Report Period FEB 1986

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* FORT CALHOUN 1 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System Component	Cause & Corrective Action to Prevent Recurrence
-----	------	------	-------	--------	--------	------------	------------------	---

NONE

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*

FORT CALHOUN OPERATED ROUTINELY DURING FEBRUARY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	Instructions for Preparation of
	C-Refueling	H-Other	Data Entry Sheet
	D-Regulatory Restriction		Licensee Event Report
	E-Operator Training & License Examination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* FORT CALHOUN 1 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1986

FACILITY DESCRIPTION

LOCATION  
STATE.....NEBRASKA

COUNTY.....WASHINGTON

DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...19 MI N OF  
OMAHA, NEB

TYPE OF REACTOR.....PWR

DATE INITIAL CRITICALITY...AUGUST 6, 1973

DATE ELEC ENER 1ST GENER...AUGUST 25, 1973

DATE COMMERCIAL OPERATE....JUNE 20, 1974

CONDENSER COOLING METHOD...ONCE THRU

CONDENSER COOLING WATER....MISSOURI RIVER

ELECTRIC RELIABILITY  
COUNCIL.....MID-CONTINENT AREA  
RELIABILITY COORDINATION  
AGREEMENT

I N S P E C T I O N     S T A T U S

INSPECTION SUMMARY

INSPECTION CONDUCTED SEPTEMBER 1-30, 1985 (85-21) ROUTINE, UNANNOUNCED INSPECTION OF OPERATIONAL SAFETY VERIFICATION, SURVEILLANCE TESTING, AND ALLEGATION FOLLOWUP. WITHIN THE THREE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION CONDUCTED JANUARY 1-31, 1986 (86-02) ROUTINE, UNANNOUNCED INSPECTION INCLUDING OPERATIONAL SAFETY VERIFICATION, MAINTENANCE, SURVEILLANCE, PLANT TOURS, SAFETY-RELATED SYSTEM WALKDOWNS, FOLLOWUP ON IE BULLETIN 79-01B, FOLLOWUP ON A REGIONAL REQUEST FOR REPORT ON LIMITORQUE VALVES, FOLLOWUP ON PREVIOUSLY IDENTIFIED ITEMS, COLD WEATHER PREPARATIONS, AND PLANT STARTUP FROM REFUELING. WITHIN THE 11 AREAS INSPECTED, ONE VIOLATION WAS IDENTIFIED.

ENFORCEMENT SUMMARY

CONTRARY TO THE REQUIREMENTS OF 10 CFR 50.47(B)(15) AND 10 CFR 50.54(G) AND (S)(II), THREE OPERATING SHIFTS OF THE LICENSEE'S STAFF WERE INADEQUATELY TRAINED SUCH THAT THEY COULD DEMONSTRATE THE ABILITY TO PERFORM 15 MINUTE NOTIFICATIONS OF STATE AND LOCAL AUTHORITIES. CONTRARY TO THE REQUIREMENTS OF 10 CFR 50.47(B)(15), THE LICENSEE WAS NOT PROVIDING ADEQUATE RADILOGICAL EMERGENCY TRAINING AS EVIDENCED BY: (1) HP TECHNICIANS WERE UNABLE TO PERFORM EP TASK(2) SHIFT PERSONNEL WERE UNABLE TO DETERMINE POPULATION SECTORS AFFECTED BY THE PLUME (3) NO TRAINING REQUIREMENTS BASTED FOR STA'S AND SRO'S (NOT SHIFT SUPERVISORS) (4) EMERGENCY ASSIGNMENTS WERE MADE TO UNQUALIFIED & UNTRAINED PERSONNEL (5) INADEQUATE TESTS WERE GIVEN TO EP TRAINEES. CONTRARY TO THE REQUIREMENTS OF 10 CFR 50.54(A), THE LICENSEE FAILED TO PERFORM ADEQUATE AUDITS.

Report Period FEB 1986

I N S P E C T I O N      S T A T U S - (CONTINUED)

\*\*\*\*\*  
\* FORT CALHOUN 1 \*  
\*\*\*\*\*

ENFORCEMENT SUMMARY

(8501 4)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

LAST IE SITE INSPECTION DATE: JANUARY 1-31, 1986

INSPECTION REPORT NO: 50-285/86-02

R E P O R T S   F R O M   L I C E N S E E

NUMBER      DATE OF      DATE OF      SUBJECT  
EVENT      REPORT


-----  
NONE

1. Docket: 50-267 OPERATING STATUS  
 2. Reporting Period: 02/01/86 Outage + On-line Hrs: 672.0  
 3. Utility Contact: FRANK NOVACHEK (303) 785-2224  
 4. Licensed Thermal Power (MWh): 842  
 5. Nameplate Rating (Gross MWe): 403 X 0.85 = 343  
 6. Design Electrical Rating (Net MWe): 330  
 7. Maximum Dependable Capacity (Gross MWe): 342  
 8. Maximum Dependable Capacity (Net MWe): 330  
 9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE  
 10. Power Level To Which Restricted, If Any (Net MWe): 115  
 11. Reasons for Restrictions, If Any: \_\_\_\_\_  
**ENVIRONMENTAL QUALIFICATION**  
 12. Report Period Hrs 672.0 MONTH 1,416.0 YEAR 58,441.0 CUMULATIVE  
 13. Hours Reactor Critical 346.5 346.5 28,382.7  
 14. Rx Reserve Shtdn Hrs .0 .0 .0  
 15. Hrs Generator On-Line .0 .0 18,463.5  
 16. Unit Reserve Shtdn Hrs .0 .0 .0  
 17. Gross Therm Ener (MWH) 1,974 1,974 9,745,141  
 18. Gross Elec Ener (MWH) 0 0 3,248,888  
 19. Net Elec Ener (MWH) -2,988 -6,019 2,890,027  
 20. Unit Service Factor .0 .0 31.6  
 21. Unit Avail Factor .0 .0 31.6  
 22. Unit Cap Factor (MDC Net) .0 .0 15.0  
 23. Unit Cap Factor (DER Net) .0 .0 15.0  
 24. Unit Forced Outage Rate 100.0 100.0 58.9  
 25. Forced Outage Hours 672.0 1,416.0 26,505.5  
 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE  
 27. If Currently Shutdown Estimated Startup Date: 10/16/86

\*\*\*\*\*  
\* FORT ST VRAIN \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

FORT ST VRAIN



FEBRUARY 1986

Report Period FEB 1986

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* FORT ST VRAIN \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
85-003	11/08/85	F	672.0	D	4		ZZ	ZZZZZ	ENVIRONMENTAL QUALIFICATION. AN ADDITIONAL, INADVERTENTLY LEFT CLOSED VALVE LINEUP PERFORMED.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*

FORT ST. VRAIN REMAINS SHUTDOWN FOR ENVIRONMENTAL QUALIFICATION.

Type	Reason	Method	System & Component	
F-Forced	A-Equip Failure	F-Admin	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	2-Manual Scram	Instructions for
	C-Refueling	H-Other	3-Auto Scram	Preparation of
	D-Regulatory Restriction		4-Continued	Data Entry Sheet
	E-Operator Training		5-Reduced Load	Licensee Event Report
	& License Examination		9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* FORT ST VRAIN \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1986

FACILITY DESCRIPTION

LOCATION  
STATE.....COLORADO  
COUNTY.....WELD  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...35 MI N OF  
DENVER, COL  
TYPE OF REACTOR.....HTGR  
DATE INITIAL CRITICALITY...JANUARY 31, 1974  
DATE ELEC ENER 1ST GENER...DECEMBER 1, 1976  
DATE COMMERCIAL OPERATE....JULY 1, 1979  
CONDENSER COOLING METHOD...COOLING TOWER  
CONDENSER COOLING WATER....S. PLATTE RIVER  
ELECTRIC RELIABILITY  
COUNCIL.....WESTERN SYSTEMS  
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....PUBLIC SERVICE OF COLORADO  
CORPORATE ADDRESS.....P.O. BOX 840  
DENVER, COLORADO 80201  
CONTRACTOR  
ARCHITECT/ENGINEER.....SARGENT & LUNDY  
NUC STEAM SYS SUPPLIER...GENERAL ATOMIC CORP.  
CONSTRUCTOR.....EBASCO  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....IV  
IE RESIDENT INSPECTOR.....R. FARRELL  
LICENSING PROJ MANAGER....K. HEITNER  
DOCKET NUMBER.....50-267  
LICENSE & DATE ISSUANCE....DPR-34, DECEMBER 21, 1973  
PUBLIC DOCUMENT ROOM.....GREELEY PUBLIC LIBRARY  
CITY COMPLEX BUILDING  
GEELEY, COLORADO 80631

I N S P E C T I O N     S T A T U S

INSPECTION SUMMARY

INSPECTION CONDUCTED APRIL 15-29; JULY 17-19, AND OCT. 22-25, 1985 (85-13) SPECIAL, UNANNOUNCED INSPECTIONS INVOLVING THE REVIEW OF THE CORROSION PHENOMENON OCCURRING IN THE PRESTRESSED CONCRETE REACTOR VESSEL (PCRV), POST-TENSIONING TENDON WIRES; EXTENT OF PCRV TENDON DEGRADATION; PROPOSED MONITORING AND SURVEILLNACE PROGRAM; AND CORRECTIVE MEASURES BEING PROPOSED AND/OR INITIATED. WITHIN THE FOUR AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION CONDUCTED JANUARY 6-10, 1986 (86-01) ROUTINE, UNANNOUNCED INSPECTION OF NONLICENSED OPERATOR TRAINING, FIRE PREVENTION/PROTECTION PROGRAM IMPLEMENTATION, FOLLOWUP TO NRC INSPECTION REPORT 85-26, AND FOLLOWUP TO NRC REVIEW OF REVISION 3 TO FSAR. WITHIN THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION CONDUCTED JANUARY 13-23, 1986 (86-04) SPECIAL, ANNOUNCED INSPECTION OF FT. ST VRAIN GENERATING STATION HIGH-ENERGY PIPING SYSTEMS. WITHIN THE AREA INSPECTED NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

Report Period FEB 1986

I N S P E C T I O N      S T A T U S - (CONTINUED)

\*\*\*\*\*  
\*            FORT ST VRAIN    \*  
\*\*\*\*\*

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

PLANT OPERATING AT 1.2% POWER

LAST IE SITE INSPECTION DATE: JANUARY 12-23, 1986

INSPECTION REPORT NO: 50-267/86-04

R E P O R T S   F R O M   L I C E N S E E


NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
86-01	1/5/86	2/2/86	"C" CIRCULATOR TRIP ON BUFFER-MID-BUFFER
86-02	1/5/86	2/4/86	"C" HELIUM CIRCULATOR TRIP ON BUFFER-MID-BUFFER LOW
86-03	1/13/86	2/12/86	"C" CIRCULATOR TRIP ON BUFFER-MID-BUFFER
86-07	1/23/86	2/22/86	"A" CIRCULATOR TRIP DURING IN-SERVICE LEAK TEST
86-08	1/21/86	2/23/86	INOPERABLE MECHANICAL SNUBBERS
86-09	1/25/86	2/22/86	OPERATION IN VIOLATION OF LCO 4.4.1

1. Docket: 50-244 OPERATING STATUS  
 2. Reporting Period: 02/01/86 Outage + On-line Hrs: 672.0  
 3. Utility Contact: ANDREW MC NAMARA (315) 524-4446  
 4. Licensed Thermal Power (MWt): 1520  
 5. Nameplate Rating (Gross MWe): 608 X 0.85 = 517  
 6. Design Electrical Rating (Net MWe): 470  
 7. Maximum Dependable Capacity (Gross MWe): 490  
 8. Maximum Dependable Capacity (Net MWe): 470  
 9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE  
 10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_  
 11. Reasons for Restrictions, If Any:  
NONE  
 12. Report Period Hrs 672.0 MONTH 1,416.0 YEAR 142,536.0 CUMULATIVE  
 13. Hours Reactor Critical 168.0 912.0 109,198.6  
 14. Rx Reserve Shtdwn Hrs .0 .0 1,687.7  
 15. Hrs Generator On-Line 168.0 912.0 106,905.8  
 16. Unit Reserve Shtdwn Hrs .0 .0 8.5  
 17. Gross Therm Ener (MWH) 198,456 1,255,128 148,977,353  
 18. Gross Elec Ener (MWH) 66,043 420,288 48,731,145  
 19. Net Elec Ener (MWH) 62,064 398,170 46,201,488  
 20. Unit Service Factor 25.0 64.4 75.0  
 21. Unit Avail Factor 25.0 64.4 75.0  
 22. Unit Cap Factor (MDC Net) 19.7 59.8 70.6\*  
 23. Unit Cap Factor (DER Net) 19.7 59.8 70.6\*  
 24. Unit Forced Outage Rate .0 .0 7.1  
 25. Forced Outage Hours .0 .0 4,243.8  
 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE  
 27. If Currently Shutdown Estimated Startup Date: 06/04/86

\*\*\*\*  
 \* GINNA \*  
 \*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

GINNA



FEBRUARY 1986

\* Item calculated with a Weighted Average

PAGE 2-128

Report Period FEB 1986

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* GINNA \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
1	02/07/86	S	504.0	C	1		RC	FUELXX	ANNUAL REFUELING AND MAINTENANCE. SPLIT PIN MODIFICATIONS, CONTAINMENT INTEGRATED LEAK RATE TEST.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*

GINNA SHUTDOWN FOR REFUELING ON FEBRUARY 7TH.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	Instructions for Preparation of
	C-Refueling	H-Other	Data Entry Sheet
	D-Regulatory Restriction		Licensee Event Report
	E-Operator Training & License Examination	5-Reduced Load 9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
X GINNA X  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1986

FACILITY DESCRIPTION

LOCATION  
STATE.....NEW YORK

COUNTY.....WAYNE

DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...15 MI NE OF  
ROCHESTER, NY

TYPE OF REACTOR.....PWR.

DATE INITIAL CRITICALITY...NOVEMBER 8, 1969

DATE ELEC ENER 1ST GENER...DECEMBER 2, 1969

DATE COMMERCIAL OPERATE....JULY 1, 1970

CONDENSER COOLING METHOD...ONCE THRU

CONDENSER COOLING WATER....LAKE ONTARIO

ELECTRIC RELIABILITY  
COUNCIL.....NORTHEAST POWER  
COORDINATING COUNCIL

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....ROCHESTER GAS & ELECTRIC

CORPORATE ADDRESS.....89 EAST AVENUE  
ROCHESTER, NEW YORK 14604

CONTRACTOR  
ARCHITECT/ENGINEER.....GILBERT ASSOCIATES

NUC STEAM SYS SUPPLIER...WESTINGHOUSE

CONSTRUCTOR.....BECHTEL

TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I

IE RESIDENT INSPECTOR.....W. COOK

LICENSING PROJ MANAGER.....M. FAIRTILE  
DOCKET NUMBER.....50-244

LICENSE & DATE ISSUANCE....DPR-18, DECEMBER 10, 1984

PUBLIC DOCUMENT ROOM.....ROCHESTER PUBLIC LIBRARY  
BUSINESS AND SOCIAL SCIENCE DIVISION  
115 SOUTH AVENUE  
ROCHESTER, NEW YORK 14604

I N S P E C T I O N     S T A T U S

Report Period FEB 1986

I N S P E C T I O N      S T A T U S - (CONTINUED)

\*\*\*\*\*  
\* GINNA \*  
\*\*\*\*\*

OTHER ITEMS

NO INPUT PROVIDED.

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S   F R O M   L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
--------	------------------	-------------------	---------

=====


NO INPUT PROVIDED.

1. Docket: 50-416 OPERATING STATUS  
 2. Reporting Period: 02/01/86 Outage + On-line Hrs: 672.0  
 3. Utility Contact: J. G. CESARE (601) 969-2585  
 4. Licensed Thermal Power (MWh): 3833  
 5. Nameplate Rating (Gross MWe): 1373  
 6. Design Electrical Rating (Net MWe): 1250  
 7. Maximum Dependable Capacity (Gross MWe): 1157  
 8. Maximum Dependable Capacity (Net MWe): 1108  
 9. If Changes Occur Above Since Last Report, Give Reasons:  
  
 10. Power Level To Which Restricted, If Any (Net MWe): 700  
 11. Reasons for Restrictions, If Any:  
ECONOMIC & LOAD DISPATCH CONSIDERATIONS.  
 12. Report Period Hrs      MONTH      YEAR      CUMULATIVE  
                               672.0    1,416.0    5,833.0  
 13. Hours Reactor Critical      577.2    1,288.8    4,172.2  
 14. Rx Reserve Shtdwn Hrs      .0    .0    .0  
 15. Hrs Generator On-Line      554.7    1,236.3    3,928.8  
 16. Unit Reserve Shtdwn Hrs      .0    .0    .0  
 17. Gross Therm Ener (MWH)      1,278,605    3,069,245    12,150,076  
 18. Gross Elec Ener (MWH)      386,430    934,850    3,727,740  
 19. Net Elec Ener (MWH)      361,898    881,512    3,535,661  
 20. Unit Service Factor      82.5    87.3    77.4  
 21. Unit Avail Factor      82.5    87.3    67.4  
 22. Unit Cap Factor (MDC Net)      48.6    56.2    54.7  
 23. Unit Cap Factor (DER Net)      43.1    49.8    48.5  
 24. Unit Forced Outage Rate      17.5    12.7    11.1  
 25. Forced Outage Hours      117.3    179.7    489.4  
 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE  
 27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\* GRAND GULF 1 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

GRAND GULF 1



FEBRUARY 1986

Report Period FEB 1986

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* GRAND GULF 1 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
86-04	02/12/86	F	117.3	H	3	86-004	AD	SEAL	A SEAL ON REACTOR RECIRCULATION PUMP "B" FAILED CAUSING THE REACTOR COOLANT LEAKAGE TO EXCEED TECHNICAL SPECIFICATION LIMITS. DURING PLANT SHUTDOWN, THE "B" REACTOR FEEDWATER PUMP TRIPPED DUE TO LOW SUCTION FLOW CAUSING A LOW WATER LEVEL REACTOR SCRAM.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*

GRAND GULF 1 OPERATED WITH 1 OUTAGE DURING THE FEBRUARY REPORT PERIOD.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	Instructions for Preparation of
	C-Refueling	H-Other	Data Entry Sheet
	D-Regulatory Restriction		Licensee Event Report
	E-Operator Training & License Examination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* GRAND GULF 1 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1986

FACILITY DESCRIPTION

LOCATION  
STATE.....MISSISSIPPI  
COUNTY.....CLAIBORNE  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...25 MI S OF  
VICKSBURG, MISS  
TYPE OF REACTOR.....BWR  
DATE INITIAL CRITICALITY...AUGUST 18, 1982  
DATE ELEC ENER 1ST GENER...OCTOBER 20, 1984  
DATE COMMERCIAL OPERATE....JULY 1, 1985  
CONDENSER COOLING METHOD...CCHNDCT  
CONDENSER COOLING WATER....MISSISSIPPI RIVER  
ELECTRIC RELIABILITY  
COUNCIL.....SOUTHWEST POWER POOL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....MISSISSIPPI POWER & LIGHT COMPANY  
CORPORATE ADDRESS.....P.O. BOX 1640  
JACKSON, MISSISSIPPI 39205  
CONTRACTOR  
ARCHITECT/ENGINEER.....BECHTEL  
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC  
CONSTRUCTOR.. .....BECHTEL  
TURBINE SUPPLIER.....ALLIS-CHALMERS

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II  
IE RESIDENT INSPECTOR.....R. BUTCHER  
LICENSING PROJ MANAGER.....L. KINTNER  
DOCKET NUMBER.....50-416  
LICENSE & DATE ISSUANCE....NPF-29, NOVEMBER 1, 1984  
PUBLIC DOCUMENT ROOM.....HINDS JUNIOR COLLEGE  
MC LENDON LIBRARY  
RAYMOND, MISSISSIPPI 39154

I N S P E C T I O N     S T A T U S

INSPECTION SUMMARY

+ INSPECTION DECEMBER 21 - JANUARY 17, 1986 (85-46): THIS ROUTINE INSPECTION ENTAILED 177 RESIDENT INSPECTOR-HOURS AT THE SITE IN THE AREAS OF OPERATIONAL SAFETY VERIFICATION, MAINTENANCE OBSERVATION, SURVEILLANCE OBSERVATION, COLD WEATHER PREPARATIONS, REPORTABLE OCCURRENCES, OPERATING REACTOR EVENTS, AND INSPECTOR FOLLOWUP AND UNRESOLVED ITEMS. VIOLATION - THREE EXAMPLES OF FAILURE TO FOLLOW PROCEDURES FOR PLACING SHUTDOWN COOLING IN EFFECT, TO MAINTAIN REACTOR VESSEL WATER LEVEL AND FEEDWATER PUMP DISCHARGE PRESSURE AS REQUIRED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE.

Report Period FEB 1986

I N S P E C T I O N      S T A T U S - (CONTINUED)

\*\*\*\*\*  
\* GRAND GULF 1 \*  
\*\*\*\*\*

OTHER ITEMS

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

OPERATING ROUTINELY.

LAST IE SITE INSPECTION DATE: DECEMBER 21, 1985 - JANUARY 17, 1986 +

INSPECTION REPORT NO: 50-416/85-46 +

R E P O R T S   F R O M   L I C E N S E E


NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
85-041	10/31/85	12/02/85	PERSONNEL ERROR CAUSES TECHNICAL SPECIFICATION TO BE LATE. INADEQUATE COORDINATION RESULTED IN THE DEMONSTRATION BEING PERFORMED 4 HOURS LATE.
85-042	11/02/85	12/03/85	INCORRECT WIRING CONFIGURATION AND INCREASED LOAD CAUSES ESF BUS TRIP. THE WIRING NONCONFORMANCE HAS BEEN CORRECTED.
85-047	12/16/85	01/14/86	CONTROL ROOM EMERGENCY FILTRATION SYSTEM ACTUATES ON FALSE CHLORINE SIGNAL. CAUSE COULD NOT BE DETERMINED.
85-048	12/18/85	01/15/86	POWER TO DIV. 3 ESF BUS 17AC LOST CAUSING ACTUATION OF DIV. 3 DIESEL GENERATOR. CAUSE - A TREE FELL ON PRIMARY TRANSMISSION LINE.
85-049	12/22/85	01/21/86	INADEQUATE SURVEILLANCE REVIEW CAUSES FAILURE TO ENTER AN LCO, DUE TO THE FAILURE TO IMPLEMENT THE REQUIREMENTS OF THE ACTION STATEMENT OF TECHNICAL SPECIFICATION 3.6.6.2.

1. Docket: 50-213 OPERATING STATUS  
 2. Reporting Period: 02/01/86 Outage + On-line Hrs: 672.0  
 3. Utility Contact: J. P. DRAGO (203) 267-2556 X452  
 4. Licensed Thermal Power (MWe): 1825  
 5. Nameplate Rating (Gross MWe): 667 X 0.9 = 600  
 6. Design Electrical Rating (Net MWe): 582  
 7. Maximum Dependable Capacity (Gross MWe): 596  
 8. Maximum Dependable Capacity (Net MWe): 569  
 9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE  
 10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_  
 11. Reasons for Restrictions, If Any:  
NONE  
 12. Report Period Hrs 672.0    13. Hours Reactor Critical .0    14. Rx Reserve Shtdwn Hrs .0    15. Hrs Generator On-Line .0    16. Unit Reserve Shtdwn Hrs .0    17. Gross Therm Ener (MWH) 3    18. Gross Elec Ener (MWH) 0    19. Net Elec Ener (MWH) -2,571    20. Unit Service Factor .0    21. Unit Avail Factor .0    22. Unit Cap Factor (MDC Net) .0    23. Unit Cap Factor (DER Net) .0    24. Unit Forced Outage Rate .0    25. Forced Outage Hours .0    26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE  
 27. If Currently Shutdown Estimated Startup Date: 04/18/86

\*\*\*\*\*  
\* HADDAM NECK \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

HADDAM NECK



FEBRUARY 1986

\* Item calculated with a Weighted Average

Report Period FEB 1986

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* HADDAM NECK \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
86-01	01/04/86	S	672.0	C	4		RC	FUELXX	CONTINUATION OF CORE 13-14 REFUELING.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*

CONNECTICUT YANKEE HADDAM NECK REMAINS SHUTDOWN FOR REFUELING.

Type	Reason	Method	System & Component	
F-Forced	A-Equip Failure	F-Admin	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	2-Manual Scram	Instructions for
	C-Refueling	H-Other	3-Auto Scram	Preparation of
	D-Regulatory Restriction		4-Continued	Data Entry Sheet
	E-Operator Training & License Examination		5-Reduced Load	Licensee Event Report
			9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* HADDAM NECK \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1986

FACILITY DESCRIPTION

LOCATION STATE.....CONNECTICUT  
COUNTY.....MIDDLESEX  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...13 MI E OF  
MERIDEN, CONN  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...JULY 24, 1967  
DATE ELEC ENER 1ST GENER...AUGUST 7, 1967  
DATE COMMERCIAL OPERATE....JANUARY 1, 1968  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER....CONNECTICUT RIVER  
ELECTRIC RELIABILITY  
COUNCIL.....NORTHEAST POWER  
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....CONNECTICUT YANKEE ATOMIC POWER  
CORPORATE ADDRESS.....P.O. BOX 270  
HARTFORD, CONNECTICUT 06101  
CONTRACTOR  
ARCHITECT/ENGINEER.....STONE & WEBSTER  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
CONSTRUCTOR.....STONE & WEBSTER  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I  
IE RESIDENT INSPECTOR.....P. SWETLAND  
LICENSING PROJ MANAGER.....F. AKSTULEWICZ  
DOCKET NUMBER.....50-213  
LICENSE & DATE ISSUANCE....DPR-61, DECEMBER 27, 1974  
PUBLIC DOCUMENT ROOM.....RUSSELL LIBRARY  
123 BROAD STREET  
MIDDLETON, CONNECTICUT 06457

I N S P E C T I O N     S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

CONTRARY TO 10CFR50 APP B, TECH SPEC 6.8 AND ADMIN CONTROL PROCEDURES: A) ON 12/12/85, AWO 85-06480 WAS NOT CONTROLLED & DOC PER PROC 1.2-5.1 IN THAT (1) SUPP WORK ORDERS WERE NOT IMPL WHEN WORK SCOPE CHANGED FROM #3 SG WIDE RANGE LEVEL INDICATORS TO #3 SG WIDE RANGE & NARROW LEVEL TRANSMITTERS; (2) MIL FOR THIS WORK ACT WAS NOT CORRECTLY PROCESSED BECAUSE CAT 1 CLASS OF REQD REPLACE COMP WAS NOT SPECIFIED. B) ON 10/25/84, AWD 84-08964 WAS NOT CONTROLLED & DOC IN ACCORD WITH PROC 1.2-5.1 BECAUSE APPLICABLE PDGR 622 CORE COOLING USING PORV'S WAS NOT SPEC IN TASK DESCRIPT SECT OF AWD, & BECAUSE APPLICABLE PREOP TEST (SPL 10.7-219) WAS NOT SPEC IN RETEST SECT OF AWD. C) ON 10/15/85, NCR 85-194 FOR INSTALL OF A NON-CAT 1 LEVEL TRANSMITTER IN CAT 1 SG LEVEL INDIC SYSTEM WAS NOT REVIEWED & DISPOSIT IN TIMELY MANNER, IN THAT NCR WAS NOT DISPOSIT UNTIL 10/23/85. HAD THAT REVIEW DETER THAT REPLACE TRANSMITTER WAS NOT ACCEPT, TS 3.9 LCD WOULD HAVE BEEN EXCEEDED FOR 9 DAYS. D) ON 10/4/85, MIL FOR AWD 85-06299 WAS NOT CORR CLASS, & STOREKEEPER DID NOT ASSURE THAT ISSUED MATL CONFORMED TO MIL REQMTS IN THAT ALARM UNIT LISTED ON MIL WAS NOT CLASS AS CAT 1 & A CAT 1 UNIT WAS ISSUED. ALTHOUGH THIS WAS CONSERVATIVE ACTION, THIS IS AN EXAMPLE OF NON-ADHERENCE TO PROC. E) THREE SAFETY-RELATED TPC'S WERE NOT REVIEWED BY PORC OR APPROVED BY STATION SUPER WITHIN 14 DAYS IN THAT TPC'S 85-123 AND 85-124 IMPLLEM ON 9/16/85 AND TPC 84-185 IMPLLEM ON 10/19/84 WERE NOT REVIEWED & APPROVED UNTIL 10/17 & 25/85, RESPECT. F) AS OF 12/2/85, SURVEIL TESTS NECESSITATED BY PDGR 622, WERE NOT INCLUDED IN PLANT PROC WITHIN 1 MON OF COMPLETION OF THAT DESIGN CHG ON 10/29/84 IN THAT

Report Period FEB 1986

I N S P E C T I O N     S T A T U S - (CONTINUED)

\*\*\*\*\*  
\* HADDAM NECK \*  
\*\*\*\*\*

ENFORCEMENT SUMMARY

NO PROC EXISTED FOR PORV AIR SUPPLY CHECK VALVE SEAT LEAK TEST OR PORV EMERG AIR AND CONTROL POWER TEST. CONTRARY TO 10CFR50 APPENDIX B CRITERION XVI, THE LICENSEE'S CORRECTIVE ACTIONS DID NOT ASSURE THAT THE PROCEDURE REVIEW NONCONFORMANCES IDENTIFIED IN AUGUST 1985 WERE PROMPTLY CORRECTED, IN THAT 15 OVERDUE PROCEDURE REVIEWS REMAINED INCOMPLETE AS OF OCTOBER 16, 1985. NEITHER DID THE CORRECTIVE ACTIONS PRECLUDE REPETITION OF THIS NONCONFORMANCE, BECAUSE SEVEN OTHER PROCEDURES BECAME OVERDUE FOR REVIEW DURING THE PERIOD SEPTEMBER 17 - OCTOBER 16, 1985.  
(8502 4)

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S   F R O M   L I C E N S E E


=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
--------	------------------	-------------------	---------

=====

NO INPUT PROVIDED.

1. Docket: 50-321 OPERATING STATUS  
 2. Reporting Period: 02/01/86 Outage + On-line Hrs: 672.0  
 3. Utility Contact: LEE KANIPE (912) 367-7781 X2882  
 4. Licensed Thermal Power (MWt): 2436  
 5. Nameplate Rating (Gross MWe): 1000 X 0.85 = 850  
 6. Design Electrical Rating (Net MWe): 777  
 7. Maximum Dependable Capacity (Gross MWe): 801  
 8. Maximum Dependable Capacity (Net MWe): 768  
 9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE  
 10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_  
 11. Reasons for Restrictions, If Any:  
NONE  
 12. Report Period Hrs      MONTH      YEAR      CUMULATIVE  
                               672.0      1,416.0      89,088.0  
 13. Hours Reactor Critical      .0      .0      62,052.0  
 14. Rx Reserve Shtdwn Hrs      .0      .0      .0  
 15. Hrs Generator On-Line      .0      .0      58,566.3  
 16. Unit Reserve Shtdwn Hrs      .0      .0      .0  
 17. Gross Therm Ener (MWH)      0      0      124,432,255  
 18. Gross Elec Ener (MWH)      0      0      40,232,840  
 19. Net Elec Ener (MWH)      0      0      38,209,178  
 20. Unit Service Factor      .0      .0      65.7  
 21. Unit Avail Factor      .0      .0      65.7  
 22. Unit Cap Factor (MDC Net)      .0      .0      55.8  
 23. Unit Cap Factor (DER Net)      .0      .0      55.2  
 24. Unit Forced Outage Rate      .0      .0      15.5  
 25. Forced Outage Hours      .0      .0      10,520.0  
 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE  
 27. If Currently Shutdown Estimated Startup Date: 04/01/86



Report Period FEB 1986

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* HATCH 1 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
86-002	11/27/85	S	672.0	C	4		RC	FUELXX	REFUELING OUTAGE CONTINUES.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*

HATCH 1 REMAINS SHUTDOWN FOR REFUELING.

Type	Reason	Method	System & Component	
F-Forced	A-Equip Failure	F-Admin	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	2-Manual Scram	Instructions for
	C-Refueling	H-Other	3-Auto Scram	Preparation of
	D-Regulatory Restriction		4-Continued	Data Entry Sheet
	E-Operator Training & License Examination		5-Reduced Load	Licensee Event Report
			9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* HATCH 1 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1986

FACILITY DESCRIPTION

LOCATION  
STATE.....GEORGIA  
COUNTY.....APPLING  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...11 MI N OF  
BAXLEY, GA  
TYPE OF REACTOR.....BWR  
DATE INITIAL CRITICALITY...SEPTEMBER 12, 1974  
DATE ELEC ENER 1ST GENER...NOVEMBER 11, 1974  
DATE COMMERCIAL OPERATE....DECEMBER 31, 1975  
CONDENSER COOLING METHOD...COOLING TOWER  
CONDENSER COOLING WATER....ALTAMAHIA RIVER  
ELECTRIC RELIABILITY  
COUNCIL.....SOUTHEASTERN ELECTRIC  
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....GEORGIA POWER  
CORPORATE ADDRESS.....333 PIEDMONT AVENUE  
ATLANTA, GEORGIA 30308

CONTRACTOR  
ARCHITECT/ENGINEER.....BECHTEL  
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC  
CONSTRUCTOR.....GEORGIA POWER CO.  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II  
IE RESIDENT INSPECTOR.....P. HOLMES RAY  
LICENSING PROJ MANAGER.....G. RIVENBARK  
DOCKET NUMBER.....50-321  
LICENSE & DATE ISSUANCE....DPR-57, OCTOBER 13, 1974  
PUBLIC DOCUMENT ROOM.....APPLING COUNTY PUBLIC LIBRARY  
301 CITY HALL DRIVE  
BAXLEY, GEORGIA 31563

I N S P E C T I O N     S T A T U S

INSPECTION SUMMARY

+ INSPECTION DECEMBER 12 - JANUARY 21, 1986 (85-36): THIS SPECIAL, ANNOUNCED PHYSICAL SECURITY INSPECTION ENTAILED 4 INSPECTOR-HOURS ON SITE REVIEWING THE FACTS AND CIRCUMSTANCES SURROUNDING A PHYSICAL SECURITY EVENT REPORTED BY THE LICENSEE ON DECEMBER 10, 1985. A VIOLATION WAS IDENTIFIED IN THE AREA OF ACCESS CONTROL - PROTECTED AND VITAL AREAS.

INSPECTION DECEMBER 21 - JANUARY 17, 1986 (85-38): THIS INSPECTION INVOLVED 67 INSPECTOR-HOURS ON SITE IN THE AREAS OF TECHNICAL SPECIFICATION COMPLIANCE, OPERATOR PERFORMANCE, OVERALL PLANT OPERATIONS, QUALITY ASSURANCE PRACTICES, STATION AND CORPORATE MANAGEMENT PRACTICES, CORRECTIVE AND PREVENTIVE MAINTENANCE ACTIVITIES, SITE SECURITY PROCEDURES, RADIATION CONTROL ACTIVITIES, AND SURVEILLANCE ACTIVITIES. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION DECEMBER 26-27 (85-39): THIS REACTIVE INSPECTION ENTAILED 20 INSPECTOR-HOURS ON SITE IN RESPONSE TO AN EVENT WHICH OCCURRED ON DECEMBER 21, 1985. INSPECTION METHODS INCLUDED LOG REVIEWS, PERSONNEL INTERVIEWS, PLANT TOURS, AND STAFF BRIEFINGS. AREAS INSPECTED INCLUDED OPERATING PROCEDURES, PERSONNEL AND EQUIPMENT PERFORMANCE. ONE VIOLATION WAS IDENTIFIED IN THAT PROCEDURE 30AC-OPS-001-01 WAS NOT FOLLOWED IN THE RELEASE OF SAFETY CLEARANCE 1-85-1675 FOR MAINTENANCE WORK ORDER 1-85-1720.

INSPECTION JANUARY 6-10 (86-01): THIS ROUTINE, UNANNOUNCED INSPECTION ENTAILED 24 INSPECTOR-HOURS ON SITE IN THE AREAS OF TRAINING AND QUALIFICATIONS OF THE CONTRACT HEALTH PHYSICS STAFF, INSTRUMENT CALIBRATION, PERFORMANCE AND DOCUMENTATION OF RADIATION SURVEYS, RADIOACTIVE WASTE TRANSPORTATION, RADIOACTIVE WASTE CLASSIFICATION AND RESPIRATORY PROTECTION. OF THE SIX AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED IN FOUR AREAS; TWO VIOLATIONS WERE FOUND IN THE AREAS OF INSTRUMENT CALIBRATION AND RADIOACTIVE WASTE TRANSPORTATION.

Report Period FEB 1986

I N S P E C T I O N      S T A T U S - (CONTINUED)

\*\*\*\*\*  
\* HATCH 1 \*  
\*\*\*\*\*

INSPECTION SUMMARY

INSPECTION JANUARY 6-10 (86-02): THIS ROUTINE, UNANNOUNCED INSPECTION ENTITLED 21 INSPECTOR-HOURS ON SITE IN THE AREAS OF INSERVICE INSPECTION, NUCLEAR WELDING (OVERLAY WELDING AND INDUCTION HEAT STRESS IMPROVEMENT), AND INSPECTOR FOLLOWUP ITEMS. ONE VIOLATION WAS IDENTIFIED - FAILURE TO FOLLOW PROCEDURE FOR SIGN OFF OF TRAVELER STEPS FOR IHSI.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

+ A NEW SITE MANAGER OF ENGINEERING WAS SELECTED.

PLANT STATUS:

+ UNIT UNDER GOING 14 WEEKS REFUELING AND MAINTENANCE OUTAGE, WHICH COMMENCED 11-30-85.

LAST IE SITE INSPECTION DATE: JANUARY 6-10, 1986 +

INSPECTION REPORT NO: 50-321/86-02 +


R E P O R T S   F R O M   L I C E N S E E

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
85-046	12/19/85	01/17/86	SPURIOUS STANDBY GAS TREATMENT INITIATION. DETERMINED TO BE A NONRECURRING SPURIOUS ACTUATION.
85-047	12/20/85	01/17/86	INADEQUATE SURVEILLANCE TEST FOR DRYWELL PERSONNEL AIRLOCK DOOR SEALS. THIS EVENT IS THE RESULT OF NONLICENSED PERSONNEL ERROR.
85-052	12/19/85	01/17/86	SAFETY RELIEF VALVES FOUND OUT OF TOLERANCE. A PROPOSED TECHNICAL SPECIFICATION REVISION HAS BEEN RECOMMENDED.

1. Docket: 50-366 OPERATING STATUS  
 2. Reporting Period: 02/01/86 Outage + On-line Hrs: 672.0  
 3. Utility Contact: LEE KANIPE (912) 367-7781 X2882  
 4. Licensed Thermal Power (MWh): 2436  
 5. Nameplate Rating (Gross MWe): 1000 X 0.85 = 850  
 6. Design Electrical Rating (Net MWe): 784  
 7. Maximum Dependable Capacity (Gross MWe): 804  
 8. Maximum Dependable Capacity (Net MWe): 777  
 9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE  
 10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_  
 11. Reasons for Restrictions, If Any:  
NONE  
 12. Report Period Hrs MONTH YEAR CUMULATIVE  
672.0 1,416.0 56,857.0  
 13. Hours Reactor Critical 672.0 1,347.2 39,067.9  
 14. Rx Reserve Shtdwn Hrs .0 .0 .0  
 15. Hrs Generator On-Line 672.0 1,300.8 37,311.5  
 16. Unit Reserve Shtdwn Hrs .0 .0 .0  
 17. Gross Therm Ener (MWH) 1,387,008 2,700,016 81,233,263  
 18. Gross Elec Ener (MWH) 457,030 892,900 26,807,890  
 19. Net Elec Ener (MWH) 436,459 852,389 25,522,582  
 20. Unit Service Factor 100.0 91.9 65.6  
 21. Unit Avail Factor 100.0 91.9 65.6  
 22. Unit Cap Factor (MDC Net) 83.6 77.5 57.8  
 23. Unit Cap Factor (DER Net) 82.8 76.8 57.3  
 24. Unit Forced Outage Rate .0 8.1 9.7  
 25. Forced Outage Hours .0 115.2 4,001.2  
 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
REFUELING OUTAGE: 09/06/86 - 8 WEEKS.  
 27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\* HATCH 2 \*  
\*\*\*\*\*  
AVERAGE DAILY POWER LEVEL (MWe) PLOT

HATCH 2



FEBRUARY 1986

Report Period FEB 1986

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* HATCH 2 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
86-010	02/01/86	S	0.0	H	5		ZZ	ZZZZZ	MANAGEMENT DECISION TO REDUCE POWER TO 85%. HIGH OFFGAS ACTIVITY IN RX. AND TURBINE BUILDING CAUSED BY LEAKING FUEL WAS SLOWING DOWN UNIT ONE OUTAGE WORK.
86-011	02/15/86	S	0.0	B	5		HA	TURBIN	REDUCING POWER FOR TURBINE AND MSIV TESTING.
86-012	02/15/86	S	0.0	H	5		ZZ	ZZZZZ	MANAGEMENT DECISION TO REDUCE POWER TO 85%. HIGH OFFGAS ACTIVITY IN RX. AND TURBINE BUILDING CAUSED BY LEAKING FUEL WAS SLOWING DOWN UNIT ONE OUTAGE WORK.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*

HATCH 2 OPERATED WITH 3 REDUCTIONS IN FEBRUARY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	Instructions for
	C-Refueling	H-Other	Preparation of
	D-Regulatory Restriction		Data Entry Sheet
	E-Operator Training		Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* HATCH 2 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1986

FACILITY DESCRIPTION

LOCATION  
STATE ..... GEORGIA  
COUNTY ..... APPLING  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR... 11 MI N OF  
BAXLEY, GA  
TYPE OF REACTOR..... BWR  
DATE INITIAL CRITICALITY... JULY 4, 1978  
DATE ELEC ENER 1ST GENER... SEPTEMBER 22, 1978  
DATE COMMERCIAL OPERATE.... SEPTEMBER 5, 1979  
CONDENSER COOLING METHOD... COOLING TOWER  
CONDENSER COOLING WATER.... ALATAMAHIA RIVER  
ELECTRIC RELIABILITY  
COUNCIL..... SOUTHEASTERN ELECTRIC  
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE..... GEORGIA POWER  
CORPORATE ADDRESS..... 333 PIEDMONT AVENUE  
ATLANTA, GEORGIA 30308  
CONTRACTOR  
ARCHITECT/ENGINEER..... BECHTEL  
NUC STEAM SYS SUPFLIER... GENERAL ELECTRIC  
CONSTRUCTOR..... GEORGIA POWER CO.  
TURBINE SUPPLIER..... GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE..... II  
IE RESIDENT INSPECTOR..... P. HOLMES RAY  
LICENSING PROJ MANAGER..... G. RIVENBARK  
DOCKET NUMBER..... 50-366  
LICENSE & DATE ISSUANCE.... NPF-5, JUNE 13, 1978  
PUBLIC DOCUMENT ROOM..... APPLING COUNTY PUBLIC LIBRARY  
301 CITY HALL DRIVE  
BAXLEY, GEORGIA 31563

I N S P E C T I O N     S T A T U S

INSPECTION SUMMARY

+ INSPECTION DECEMBER 12 - JANUARY 21, 1986 (85-36): THIS SPECIAL, ANNOUNCED PHYSICAL SECURITY INSPECTION ENTAILED 4 INSPECTOR-HOURS ON SITE REVIEWING THE FACTS AND CIRCUMSTANCES SURROUNDING A PHYSICAL SECURITY EVENT REPORTED BY THE LICENSEE ON DECEMBER 10, 1985. A VIOLATION WAS IDENTIFIED IN THE AREA OF ACCESS CONTROL - PROTECTED AND VITAL AREAS.

INSPECTION DECEMBER 21 - JANUARY 17, 1986 (85-38): THIS INSPECTION INVOLVED 67 INSPECTOR-HOURS ON SITE IN THE AREAS OF TECHNICAL SPECIFICATION COMPLIANCE, OPERATOR PERFORMANCE, OVERALL PLANT OPERATIONS, QUALITY ASSURANCE PRACTICES, STATION AND CORPORATE MANAGEMENT PRACTICES, CORRECTIVE AND PREVENTIVE MAINTENANCE ACTIVITIES, SITE SECURITY PROCEDURES, RADIATION CONTROL ACTIVITIES, AND SURVEILLANCE ACTIVITIES. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JANUARY 6-10 (86-01): THIS ROUTINE, UNANNOUNCED INSPECTION ENTAILED 24 INSPECTOR-HOURS ON SITE IN THE AREAS OF TRAINING AND QUALIFICATIONS OF THE CONTRACT HEALTH PHYSICS STAFF, INSTRUMENT CALIBRATION, PERFORMANCE AND DOCUMENTATION OF RADIATION SURVEYS, RADIOACTIVE WASTE TRANSPORTATION, RADIOACTIVE WASTE CLASSIFICATION AND RESPIRATORY PROTECTION. OF THE SIX AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED IN FOUR AREAS; TWO VIOLATIONS WERE FOUND IN THE AREAS OF INSTRUMENT CALIBRATION AND RADIOACTIVE WASTE TRANSPORTATION.

INSPECTION JANUARY 6-10 (86-02): THIS ROUTINE, UNANNOUNCED INSPECTION ENTAILED 20 INSPECTOR-HOURS ON SITE IN THE AREAS OF INSERVICE INSPECTION, NUCLEAR WELDING (OVERLAY WELDING AND INDUCTION HEAT STRESS IMPROVEMENT), AND INSPECTOR FOLLOWUP ITEMS. ONE VIOLATION WAS IDENTIFIED - FAILURE TO FOLLOW PROCEDURE FOR SIGN OFF OF TRAVELER STEPS FOR IHSI.

Report Period FEB 1986

I N S P E C T I O N      S T A T U S - (CONTINUED)

\*\*\*\*\*  
\*            HATCH 2            \*  
\*\*\*\*\*

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE.

FACILITY ITEMS (PLANS AND PROCEDURES):

MANAGERIAL ITEMS:

+ A NEW SITE MANAGER OF ENGINEERING WAS SELECTED.

PLANT STATUS:

ROUTINE OPERATION.

LAST IE SITE INSPECTION DATE: JANUARY 6-10, 1986 +

INSPECTION REPORT NO: 50-366/86-02 +

R E P O R T S   F R O M   L I C E N S E E


NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
85-030	11/05/85	12/05/85	REACTOR SCRAM CAUSES ESF ACTUATIONS AND HPCI INJECTION. LOW OIL PRESSURE ON "2B" CONDENSATE BOOSTER PUMP WAS EVALUATED AS BEING CAUSED BY A STUCK SUCTION (FOOT) VALVE.
85-036	11/07/85	12/06/85	PERSONNEL ERROR CAUSES REACTOR SCRAM. THIS EVENT IS THE RESULT OF LICENSED PLANT PERSONNEL ERROR.
85-037	12/18/85	01/17/86	UNPLANNED PRIMARY CONTAINMENT VALVE ISOLATION. PERSONNEL INITIATED SURVEILLANCE ON THE RCIC STEAM LINE DIFFERENTIAL PRESSURE ANALOG TRIP UNIT INSTEAD OF THE HPCI.
85-038	12/22/85	01/21/86	BLOWN FUSE CAUSES LOSS OF POWER TO "A" RPS BUS. SUBSLQUENT TO REPLACING THE RELAY FUSE, THE SCRAM WAS RESET.

1. Docket: 50-247 OPERATING STATUS  
 2. Reporting Period: 02/01/86 Outage + On-line Hrs: 672.0  
 3. Utility Contact: K. KRIEGER (914) 526-5155  
 4. Licensed Thermal Power (MWh): 2758  
 5. Nameplate Rating (Gross MWe): 1126 X 0.9 = 1013  
 6. Design Electrical Rating (Net MWe): 873  
 7. Maximum Dependable Capacity (Gross MWe): 900  
 8. Maximum Dependable Capacity (Net MWe): 864  
 9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE  
 10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_  
 11. Reasons for Restrictions, If Any:  
NONE  
 12. Report Period Hrs      MONTH      YEAR      CUMULATIVE  
672.0      1,416.0      102,265.0  
 13. Hours Reactor Critical      .0      300.5      69,470.6  
 14. Rx Reserve Shtdn Hrs      .0      .0      2,497.6  
 15. Hrs Generator On-Line      .0      295.1      67,431.6  
 16. Unit Reserve Shtdn Hrs      .0      .0      .0  
 17. Gross Therm Ener (MWH)      0      799,337      175,633,544  
 18. Gross Elec Ener (MWH)      0      252,760      54,503,236  
 19. Net Elec Ener (MWH)      -1,560      239,535      51,418,393  
 20. Unit Service Factor      .0      20.8      65.9  
 21. Unit Avail Factor      .0      20.8      65.9  
 22. Unit Cap Factor (MDC Net)      .0      19.6      59.2\*
 23. Unit Cap Factor (DER Net)      .0      19.4      57.6  
 24. Unit Forced Outage Rate      .0      4.3      9.1  
 25. Forced Outage Hours      .0      13.3      6,487.1  
 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE  
 27. If Currently Shutdown Estimated Startup Date: 03/29/86

\*\*\*\*  
 \* INDIAN POINT 2 \*  
 \*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

INDIAN POINT 2



FEBRUARY 1986

\* Item calculated with a Weighted Average

Report Period FEB 1986

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* INDIAN POINT 2 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
1	01/13/86	S	672.0	C	4		RC	FUELXX	CYCLE 7/8 REFUELING OUTAGE CONTINUES.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*

INDIAN POINT 2 REMAINS SHUTDOWN FOR REFUELING.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	Instructions for
	C-Refueling	H-Other	Preparation of
	D-Regulatory Restriction		Data Entry Sheet
	E-Operator Training		Licensee Event Report
	& License Examination	5-Reduced Load 9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* INDIAN POINT 2 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1986

FACILITY DESCRIPTION

LOCATION  
STATE.....NEW YORK  
COUNTY.....WESTCHESTER  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...25 MI N OF  
NEW YORK CITY, NY  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...MAY 22, 1973  
DATE ELEC ENER 1ST GENER...JUNE 26, 1973  
DATE COMMERCIAL OPERATE....AUGUST 1, 1974  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER....HUDSON RIVER  
ELECTRIC RELIABILITY  
COUNCIL.....NORTHEAST POWER  
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....CONSOLIDATED EDISON  
CORPORATE ADDRESS.....4 IRVING PLACE  
NEW YORK, NEW YORK 10003  
CONTRACTOR  
ARCHITECT/ENGINEER.....UNITED FNG. & CONSTRUCTORS  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
CONSTRUCTOR.....WESTINGHOUSE DEVELOPMENT CORP  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I  
IE RESIDENT INSPECTOR.....L. ROSSBACH  
LICENSING PROJ MANAGER.....M. SLOSSON  
DOCKET NUMBER.....50-247  
LICENSE & DATE ISSUANCE....DPR-26, SEPTEMBER 28, 1973  
PUBLIC DOCUMENT ROOM.....WHITE PLAINS PUBLIC LIBRARY  
100 MARTINE AVENUE  
WHITE PLAINS, NEW YORK 10601

I N S P E C T I O N     S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

Report Period FEB 1986

INSPECTION STATUS - (CONTINUED)

\*\*\*\*\*  
X INDIAN POINT 2 X  
\*\*\*\*\*

OTHER ITEMS

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

REPORTS FROM LICENSEE

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
NO INPUT PROVIDED.			


=====

1. Docket: 50-286 OPERATING STATUS  
 2. Reporting Period: 02/01/86 Outage + On-line Hrs: 672.0  
 3. Utility Contact: L. KELLY (914) 739-8200  
 4. Licensed Thermal Power (MWt): 3025  
 5. Nameplate Rating (Gross MWe): 1126 X 0.9 = 1013  
 6. Design Electrical Rating (Net MWe): 965  
 7. Maximum Dependable Capacity (Gross MWe): 1000  
 8. Maximum Dependable Capacity (Net MWe): 965  
 9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE  
 10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_  
 11. Reasons for Restrictions, If Any:  
NONE  
 12. Report Period Hrs      MONTH      YEAR      CUMULATIVE  
672.0      1,416.0      83,281.0  
 13. Hours Reactor Critical      657.1      1,401.1      48,668.3  
 14. Rx Reserve Shtdwn Hrs      .0      .0      .0  
 15. Hrs Generator On-Line      656.9      1,400.9      47,034.5  
 16. Unit Reserve Shtdwn Hrs      .0      .0      .0  
 17. Gross Therm Ener (MWH)      1,981,394      4,236,359      122,958,323  
 18. Gross Elec Ener (MWH)      659,960      1,408,120      39,012,506  
 19. Net Elec Ener (MWH)      638,105      1,361,905      37,376,296  
 20. Unit Service Factor      97.8      98.9      56.5  
 21. Unit Avail Factor      97.8      98.9      56.5  
 22. Unit Cap Factor (MDC Net)      98.4      99.7      46.5  
 23. Unit Cap Factor (DER Net)      98.4      99.7      46.5  
 24. Unit Forced Outage Rate      2.2      1.1      19.1  
 25. Forced Outage Hours      15.1      15.1      11,208.1  
 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
STEAM GENERATOR INSPECTION: 04/86.  
 27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\* INDIAN POINT 3 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

INDIAN POINT 3



FEBRUARY 1986

Report Period FEB 1986

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* INDIAN POINT 3 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
01	02/28/86	F	15.1	A	3	86-001-00	IC	RELAYX	WHILE CONDUCTING A TURBINE INDEPENDENT ELECTRICAL OVERSPEED PROTECTION SYSTEM (IEOPS) ANALOG TEST A STUCK BLOCKING RELAY (LTB-1) IN THE IEOPS CIRCUIT CAUSED MAIN TURBINE GENERATOR STEAM STOP AND CONTROL VALVES TO CLOSE. THIS CAUSED STEAM GENERATOR LEVELS TO SHRINK BELOW TRIP SET POINT.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	Instructions for Preparation of
	C-Refueling	H-Other	Data Entry Sheet
	D-Regulatory Restriction	4-Continued	Licensee Event Report
	E-Operator Training & License Examination	5-Reduced Load	(LER) File (NUREG-0161)
		9-Other	

\*\*\*\*\*  
\* INDIAN POINT 3 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1986

FACILITY DESCRIPTION

LOCATION  
STATE.....NEW YORK  
COUNTY.....WESTCHESTER  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...25 MI N OF  
NEW YORK CITY, NY  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...APRIL 6, 1976  
DATE ELEC ENER 1ST GENER...APRIL 27, 1976  
DATE COMMERCIAL OPERATE....AUGUST 30, 1976  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER....HUDSON RIVER  
ELECTRIC RELIABILITY  
COUNCIL.....NORTHEAST POWER  
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....NEW YORK POWER AUTHORITY  
CORPORATE ADDRESS.....10 COLUMBUS CIRCLE  
NEW YORK, NEW YORK 10019  
CONTRACTOR  
ARCHITECT/ENGINEER.....UNITED ENG. & CONSTRUCTORS  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
CONSTRUCTOR.....WESTINGHOUSE DEVELOPMENT CORP  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I  
IE RESIDENT INSPECTOR.....P. KOLTAY  
LICENSING PROJ MANAGER.....D. NEIGHBORS  
DOCKET NUMBER.....50-286  
LICENSE & DATE ISSUANCE....DPR-64, APRIL 5, 1976  
PUBLIC DOCUMENT ROOM.....WHITE PLAINS PUBLIC LIBRARY  
100 MARTINE AVENUE  
WHITE PLAINS, NEW YORK 10601

I N S P E C T I O N     S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

Report Period FEB 1986

I N S P E C T I O N      S T A T U S - (CONTINUED)

\*\*\*\*\*  
\* INDIAN POINT 3 \*  
\*\*\*\*\*

OTHER ITEMS

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S   F R O M   L I C E N S E E

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
--------	------------------	-------------------	---------

---

NO INPUT PROVIDED.


---

1. Docket: 50-305 OPERATING STATUS  
 2. Reporting Period: 02/01/86 Outage + On-line Hrs: 672.0  
 3. Utility Contact: G.RUITER (414) 388-2560 X207  
 4. Licensed Thermal Power (MWh): 1650  
 5. Nameplate Rating (Gross MWe): 622 X 0.9 = 560  
 6. Design Electrical Rating (Net MWe): 535  
 7. Maximum Dependable Capacity (Gross MWe): 529  
 8. Maximum Dependable Capacity (Net MWe): 503  
 9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE  
 10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_  
 11. Reasons for Restrictions, If Any:  
NONE  
 12. Report Period Hrs      MONTH      YEAR      CUMULATIVE  
672.0      1,416.0      102,625.0  
 13. Hours Reactor Critical      671.8      1,415.8      87,432.9  
 14. Rx Reserve Shtdwn Hrs      .0      .0      2,330.5  
 15. Hrs Generator On-Line      671.5      1,415.5      85,971.1  
 16. Unit Reserve Shtdwn Hrs      .0      .0      10.0  
 17. Gross Therm Ener (MWH)      1,067,018      2,284,899      134,992,632  
 18. Gross Elec Ener (MWH)      357,800      765,200      44,503,703  
 19. Net Elec Ener (MWH)      341,664      730,923      42,372,135  
 20. Unit Service Factor      99.9      100.0      83.8  
 21. Unit Avail Factor      99.9      100.0      83.8  
 22. Unit Cap Factor (MDC Net)      101.1      102.6      79.8\*  
 23. Unit Cap Factor (DER Net)      95.0      96.5      77.2  
 24. Unit Forced Outage Rate      .0      .0      3.3  
 25. Forced Outage Hours      .0      .0      2,791.4  
 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE  
 27. If Currently Shutdown Estimated Startup Date: 04/22/86

\*\*\*\*\*  
\* KEWAUNEE \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

KEWAUNEE



FEBRUARY 1986

\* Item calculated with a Weighted Average

Report Period FEB 1986

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* KEWAUNEE \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
1	02/28/86	S	0.0	B	5		RC	FUELXX	UNIT LOAD WAS REDUCED TO 44.5% FOR END OF LIFE PHYSICS TESTING.
2	02/28/86	S	0.5	C	1		RC	FUELXX	COMMENCED CYCLE XI-XII REFUELING OUTAGE.

\*\*\*\*\* KEWAUNEE SHUTDOWN FOR REFUELING ON FEBRUARY 28TH.

\* SUMMARY \*

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	1-Manual
S-Sched	B-Maint or Test	G-Oper Error	2-Manual Scram
	C-Refueling	H-Other	3-Auto Scram
	D-Regulatory Restriction		4-Continued
	E-Operator Training & License Examination		5-Reduced Load
			9-Other
			Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161)

\*\*\*\*\*  
\* KEWAUNEE \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1986

FACILITY DESCRIPTION

LOCATION  
STATE.....WISCONSIN  
COUNTY.....KEWAUNEE  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...27 MI E OF  
GREEN BAY, WI.  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...MARCH 7, 1974  
DATE ELEC ENER 1ST GENER...APRIL 8, 1974  
DATE COMMERCIAL OPERATE....JUNE 16, 1974  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER....LAKE MICHIGAN  
ELECTRIC RELIABILITY  
COUNCIL.....MID-AMERICA  
INTERPOOL NETWORK

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....WISCONSIN PUBLIC SERVICE  
CORPORATE ADDRESS.....P.O. BOX 19002  
GREEN BAY, WISCONSIN 54307  
CONTRACTOR  
ARCHITECT/ENGINEER.....PIONEER SERVICES & ENGINEERING  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
CONSTRUCTOR.....PIONEER SERVICES & ENGINEERING  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III  
IE RESIDENT INSPECTOR.....R. NELSON  
LICENSING PROJ MANAGER.....M. FAIRTILE  
DOCKET NUMBER.....50-305  
LICENSE & DATE ISSUANCE....DPR-43, DECEMBER 21, 1973  
PUBLIC DOCUMENT ROOM.....UNIVERSITY OF WISCONSIN  
LIBRARY LEARNING CENTER  
2420 NICOLET DRIVE  
GREEN BAY, WISCONSIN 54301

I N S P E C T I O N     S T A T U S

INSPECTION SUMMARY

INSPECTION ON OCTOBER 16 THROUGH DECEMBER 31 (85016): ROUTINE UNANNOUNCED INSPECTION BY RESIDENT INSPECTION OF PREVIOUS INSPECTION FINDINGS; OPERATIONAL SAFETY; SURVEILLANCE; MAINTENANCE; LICENSEE EVENT REPORTS; LICENSEE EVENTS; PLANT MODIFICATIONS; AND PART 21 REPORTS. THE INSPECTION INVOLVED A TOTAL OF 198 INSPECTOR-HOURS BY ONE INSPECTOR INCLUDING 44 INSPECTOR-HOURS ONSITE DURING OFF-SHIFTS. TWO OPEN ITEMS WERE CLOSED FROM PRIOR NRC INSPECTIONS. ONE ITEM OF VIOLATION WAS IDENTIFIED DURING THIS INSPECTION.

INSPECTION ON DECEMBER 9-12 (85018): INCLUDED A REVIEW OF MANAGEMENT EFFECTIVENESS; SECURITY PROGRAM AUDIT; TESTING AND MAINTENANCE; PHYSICAL BARRIERS - PROTECTED AND VITAL AREAS; LIGHTING; ASSESSMENT AIDS; ACCESS CONTROL - PERSONNEL AND PACKAGES; DETECTION AIDS - PROTECTED AREA; AND ALARM STATIONS. A REVIEW OF WEAKNESSES AND CONCERNS, WHICH WERE IDENTIFIED AS A RESULT OF REGION III ANALYSIS OF PREVIOUS INSPECTION FINDINGS AND FINDINGS FROM THE REGULATORY EFFECTIVENESS REVIEW CONDUCTED BY HEADQUARTERS, NUCLEAR REGULATORY COMMISSION IN JUNE 1984, WAS PERFORMED. THE INSPECTION INVOLVED 34.5 INSPECTOR-HOURS ONSITE BY ONE NRC INSPECTOR. THE INSPECTION BEGAN DURING THE DAY SHIFT. THE LICENSEE WAS FOUND TO BE IN COMPLIANCE WITH NRC REQUIREMENTS WITHIN 10 OF THE 11 AREAS EXAMINED DURING THIS INSPECTION, EXCEPT AS NOTED BELOW: ALARM STATIONS: SOME ALARM STATION BARRIERS DID NOT OFFER THE REQUIRED PENETRATION RESISTANCE. IN ADDITION THERE WERE THREE OPEN ITEMS IDENTIFIED IN THE AREAS OF COMMUNICATIONS TESTING, PROTECTED AREA BARRIERS AND BACKGROUND SCREENING.

Report Period FEB 1986

INSPECTION STATUS - (CONTINUED)

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

THE PLANT IS OPERATING NORMALLY.

LAST IE SITE INSPECTION DATE: FEBRUARY 16 - APRIL 15, 1986

INSPECTION REPORT NO: 86003

REPORTS FROM LICENSEE


NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
85-23	12/12/85	01/10/86	REACTOR TRIP DUE TO LOSS OF INSTRUMENT BUS

1. Docket: 50-409 OPERATING STATUS  
 2. Reporting Period: 02/01/86 Outage + On-line Hrs: 672.0  
 3. Utility Contact: L. S. GOODMAN (608) 689-2331  
 4. Licensed Thermal Power (MWh): 165  
 5. Nameplate Rating (Gross MWe): 76.8 X 0.85 = 65  
 6. Design Electrical Rating (Net MWe): 50  
 7. Maximum Dependable Capacity (Gross MWe): 50  
 8. Maximum Dependable Capacity (Net MWe): 48  
 9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE  
 10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_  
 11. Reasons for Restrictions, If Any:  
NONE  
 12. Report Period Hrs 672.0 MONTH 672.0 YEAR 1,416.0 CUMULATIVE 143,139.0  
 13. Hours Reactor Critical 672.0 1,175.0 97,113.6  
 14. Rx Reserve Shtdwn Hrs .0 .0 478.0  
 15. Hrs Generator On-Line 672.0 1,124.1 90,625.3  
 16. Unit Reserve Shtdwn Hrs .0 .0 79.0  
 17. Gross Therm Ener (MWH) 95,812 153,881 12,612,828  
 18. Gross Elec Ener (MWH) 29,714 47,909 3,787,118  
 19. Net Elec Ener (MWH) 28,018 44,830 3,513,578  
 20. Unit Service Factor 100.0 79.4 63.3  
 21. Unit Avail Factor 100.0 79.4 63.4  
 22. Unit Cap Factor (FC Net) 86.9 66.0 51.1  
 23. Unit Cap Factor (DER Net) 83.4 63.3 49.1  
 24. Unit Forced Outage Rate .0 20.6 9.8  
 25. Forced Outage Hours .0 291.9 8,887.6  
 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
REFUELING, 03/09/86, APPROX. 6 WEEKS.  
 27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\* LA CROSSE \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

LA CROSSE



FEBRUARY 1986

Report Period FEB 1986

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* LA CROSSE \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System Component	Cause & Corrective Action to Prevent Recurrence
-----	------	------	-------	--------	--------	------------	------------------	---

NONE

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*

LA CROSSE OPERATED ROUTINELY DURING FEBRUARY.

Type	Reason	Method	System & Component	
F-Forced	A-Equip Failure	F-Admin	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	2-Manual Scram	Instructions for Preparation of Data Entry Sheet
	C-Refueling	H-Other	3-Auto Scram	Licensee Event Report (LER) File (NUREG-0161)
	D-Regulatory Restriction		4-Continued	
	E-Operator Training & License Examination		5-Reduced Load	
			9-Other	

\*\*\*\*\*  
\* LA CROSSE \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1986

FACILITY DESCRIPTION

LOCATION  
STATE.....WISCONSIN

COUNTY.....VERNON

DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...19 MI S OF  
LACROSSE, WISC

TYPE OF REACTOR.....BWR

DATE INITIAL CRITICALITY...JULY 11, 1967

DATE ELEC ENER 1ST GENER...APRIL 26, 1968

DATE COMMERCIAL OPERATE....NOVEMBER 1, 1969

CONDENSER COOLING METHOD...ONCE THRU

CONDENSER COOLING WATER....MISSISSIPPI RIVER

ELECTRIC RELIABILITY  
COUNCIL.....MID-CONTINENT AREA  
RELIABILITY COORDINATION  
AGREEMENT

INSPECTION STATUS

INSPECTION SUMMARY

INSPECTION ON DECEMBER 16-19 (85021): ROUTINE UNANNOUNCED INSPECTION OF THE CONFIRMATORY MEASUREMENTS PROGRAM INCLUDING SAMPLING, LABORATORY QUALITY CONTROL, LICENSEE FOLLOWUP OF OPEN ITEMS AND REGULATORY IMPROVEMENT ITEMS IDENTIFIED IN PREVIOUS INSPECTIONS. THE INSPECTION INVOLVED 29 INSPECTOR-HOURS ONSITE BY ONE NRC INSPECTOR. NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEF.....DAIRYLAND POWER

CORPORATE ADDRESS.....2615 EAST AVENUE SOUTH  
LACROSSE, WISCONSIN 54601

CONTRACTOR  
ARCHITECT/ENGINEER.....SARGENT & LUNDY

NUC STEAM SYS SUPPLIER...ALLIS-CHALMERS

CONSTRUCTOR.....MAXON CONSTRUCTION COMPANY

TURBINE SUPPLIER.....ALLIS-CHALMERS

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III

IE RESIDENT INSPECTOR.....I. VILLALVA

LICENSING PROJ MANAGER.....J. STANG  
DOCKET NUMBER.....50-409

LICENSE & DATE ISSUANCE....DPR-45, AUGUST 28, 1973

PUBLIC DOCUMENT ROOM.....LA CROSSE PUBLIC LIBRARY  
800 MAIN STREET  
LA CROSSE, WISCONSIN 54601

Report Period FEB 1986

I N S P E C T I O N      S T A T U S - (CONTINUED)

\*\*\*\*\*  
\* LA CROSSE \*  
\*\*\*\*\*

OTHER ITEMS

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

OPERATING ROUTINELY.

LAST IE SITE INSPECTION DATE: FEBRUARY 18 - APRIL 18, 1986

INSPECTION REPORT NO: 86002


R E P O R T S   F R O M   L I C E N S E E

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
85-20	12/31/85	01/24/86	1A HIGH PRESSURE SERVICE WATER DIESEL FAILURE
86-01	01/06/86	01/27/86	TYPE C LEAKAGE TEST FAILURE - REACTOR BUILDING MAIN STEAM ISOLATION VALVE AND IT BYPASS

1. Docket: 50-373 OPERATING STATUS  
 2. Reporting Period: 02/01/86 Outage + On-line Hrs: 672.0  
 3. Utility Contact: JAMES P. PETERS (815) 357-6761  
 4. Licensed Thermal Power (MWh): 3323  
 5. Nameplate Rating (Gross MWe): 1078  
 6. Design Electrical Rating (Net MWe): 1078  
 7. Maximum Dependable Capacity (Gross MWe): 1078  
 8. Maximum Dependable Capacity (Net MWe): 1036  
 9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE  
 10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_  
 11. Reasons for Restrictions, If Any:  
NONE  
 12. Report Period Hrs      MONTH      YEAR      CUMULATIVE  
                               672.0     1,416.0    18,960.0  
 13. Hours Reactor Critical      .0      .0      12,037.5  
 14. Rx Reserve Shtdwn Hrs      .0      .0      1,640.9  
 15. Hrs Generator On-Line      .0      .0      11,639.9  
 16. Unit Reserve Shtdwn Hrs      .0      .0      1.0  
 17. Gross Therm Ener (MWH)      0      0      38,349,668  
 18. Gross Elec Ener (MWH)      0      0      10,499,394  
 19. Net Elec Ener (MWH)      -8,847      -14,429      10,001,175  
 20. Unit Service Factor      .0      .0      61.4  
 21. Unit Avail Factor      .0      .0      61.4  
 22. Unit Cap Factor (MDC Net)      .0      .0      50.9  
 23. Unit Cap Factor (DER Net)      .0      .0      48.9  
 24. Unit Forced Outage Rate      .0      .0      17.4  
 25. Forced Outage Hours      .0      .0      2,458.4  
 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE  
 27. If Currently Shutdown Estimated Startup Date: 05/03/86

\*\*\*\*\*  
\* LASALLE 1 \*  
\*\*\*\*\*  
AVERAGE DAILY POWER LEVEL (MWe) PLOT

LASALLE 1



FEBRUARY 1986

Report Period FEB 1986

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* LASALLE 1 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
18	10/18/85	S	672.0	C	4		RC	FUELXX	REFUELING AND MAINTENANCE OUTAGE CONTINUES.

\*\*\*\*\*

LASALLE 1 REMAINS SHUTDOWN FOR REFUELING.

\* SUMMARY \*

\*\*\*\*\*

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	Instructions for
	C-Refueling	H-Other	Preparation of
	D-Regulatory Restriction		Data Entry Sheet
	E-Operator Training		Licensee Event Report
	& License Examination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	(LER) File (NUREG-0161)

\*\*\*\*\* LASALLE 1 \*\*\*\*\*

Report Period FEB 1986

## FACILITY DATA

### UTILITY & CONTRACTOR INFORMATION

FACILITY DESCRIPTION	LOCATION STATE.....	UTILITY LICENSEE.....	COMMONWEALTH EDISON
DIST AND DIRECTION FROM NEAREST POPULATION CTR... 11 MI SE OF OTTAWA, ILL	COUNTY..... LA SALLE	CORPORATE ADDRESS..... P.O. BOX 767	CHICAGO, ILLINOIS 60690
TYPE OF REACTOR..... BWR		CONTRACTOR ARCHITECT/ENGINEER..... SARGENT & LUNDY	
DATE INITIAL CRITICALITY... JUNE 21, 1982		NUC STEAM SYS SUPPLIER .. GENERAL ELECTRIC	
DATE ELEC ENER 1ST GENER... SEPTEMBER 4, 1982		CONSTRUCTOR..... COMMONWEALTH EDISON	
DATE COMMERCIAL OPERATE... JANUARY 1, 1984		TURBINE SUPPLIER..... GENERAL ELECTRIC	
CONDENSER COOLING METHOD... POND		REGULATORY INFORMATION	
CONDENSER COOLING WATER... RESERVOIR		IE REGION RESPONSIBLE..... III	
ELECTRIC RELIABILITY COUNCIL..... MID-AMERICA INTERPOOL NETWORK		IE RESIDENT INSPECTOR..... M. JORDAN	
		LICENSING PROJ MANAGER..... A. BOURNIA DOCKET NUMBER..... 50-373	
		LICENSE & DATE ISSUANCE... NPF-11, AUGUST 13, 1982	
		PUBLIC DOCUMENT ROOM..... ILLINOIS VALLEY COMMUNITY COLLEGE RURAL ROUTE NO. 1 OGLESBY, ILLINOIS 16348	

### INSPECTION SUMMARY

INSPECTION ON OCTOBER 1-4, 17-18, 22-24, 29-31, NOVEMBER 1, 18-22 AND DECEMBER 5 AND 19 (85032; 85033): SPECIAL, ANNOUNCED IN-DEPTH ASSESSMENT BY TWO REGIONAL INSPECTORS OF MAINTENANCE ACTIVITIES. THE ASSESSMENT INVOLVED 206 INSPECTOR-HOURS ON SITE. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION ON OCTOBER 1 THROUGH NOVEMBER 12 (85033): ROUTINE, UNANNOUNCED INSPECTION CONDUCTED BY RESIDENT INSPECTORS AND ONE REGIONAL INSPECTOR OF LICENSEE ACTIONS ON PREVIOUS INSPECTION FINDINGS; OPERATIONAL SAFETY; SURVEILLANCE; PREPARATION FOR REFUELING; LICENSEE EVENT REPORTS; EMERGENCY PREPAREDNESS TRAINING; REGION REQUESTS; UNIT TRIPS AND FOLLOWUP ON EVENTS. THE INSPECTION INVOLVED A TOTAL OF 369 INSPECTOR-HOURS ON SITE. BY FOUR NRC INSPECTORS INCLUDING 61 HOURS ON SITE DURING OFF-SHIFTS. OF THE 10 AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED IN 8 AREAS; TWO VIOLATIONS WERE IDENTIFIED IN THE REMAINING TWO AREAS (FAILURE TO FOLLOW TECHNICAL SPECIFICATION LIMITING CONDITION FOR OPERATIONS; AND FAILURE TO REVIEW AND APPROVE PLANT MODIFICATIONS). THE LICENSEE'S EFFORT TO SCHEDULE AND PLAN WORK WAS HAVING SOME EFFECT ON JOBS BEING ACCOMPLISHED IN A REASONABLE TIME.

INSPECTION ON OCTOBER 21-23, 30-31 AND NOVEMBER 1, (85034): ROUTINE ANNOUNCED INSPECTION OF SAFETY-RELATED EQUIPMENT AND CABLES IN THE UNIT 1 AND UNIT 2 DRYWELLS TO IDENTIFY ANY DEGRADATION WHICH MAY HAVE OCCURRED AS A RESULT OF HIGHER THAN ANTICIPATED OPERATING AMBIENT TEMPERATURES. IN ADDITION, MOTOR OPERATED VALVE LIMITORQUE UNITS WERE EXAMINED FOR SETUP, MAINTENANCE, TESTING, AND PHYSICAL CONDITION. THE INSPECTION INVOLVED A TOTAL OF 77 INSPECTION-HOURS ON SITE AND EIGHT INSPECTION-HOURS OFF-SITE BY THREE NRC INSPECTORS. OF THE AREAS INSPECTED, THREE VIOLATIONS WERE IDENTIFIED (FAILURE TO IMPLEMENT MEASURES TO PROMPTLY IDENTIFY AND CORRECT CONDITIONS ADVERSE TO QUALITY; FAILURE TO FOLLOW PROCEDURES WHICH LIMIT THE NUMBER OF TERMINATIONS ON A SINGLE STUD; AND

Report Period FEB 1986

INSPECTION STATUS - (CONTINUED)

\*\*\*\*\*  
\* LASALLE 1 \*  
\*\*\*\*\*

INSPECTION SUMMARY

FAILURE TO PROVIDE PERMANENT IDENTIFICATION FOR THE UNIT 1 SRVS.

INSPECTION ON NOVEMBER 13 THROUGH DECEMBER 30 (85038): ROUTINE, UNANNOUNCED INSPECTION CONDUCTED BY RESIDENT INSPECTORS AND REGIONAL INSPECTORS OF LICENSEE ACTIONS ON PREVIOUS INSPECTION FINDINGS; OPERATIONAL SAFETY; SURVEILLANCE; MAINTENANCE; LICENSEE EVENT REPORTS; HEADQUARTERS REQUESTS; AND REGION REQUESTS. THE INSPECTION INVOLVED A TOTAL OF 462 INSPECTOR-HOURS ONSITE BY SEVEN NRC INSPECTORS INCLUDING 89 HOURS ONSITE DURING OFF-SHIFTS. OF THE SEVEN AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED. ALTHOUGH NO VIOLATIONS WERE ISSUED, THE LICENSEE CONTINUES TO HAVE PROBLEMS WITH THE PLANNING AND COORDINATION OF WORK ACTIVITIES RESULTING IN MISSED SAMPLES, MISSED SURVEILLANCES, AND OVER LOOKING MAINTENANCE ACTIVITIES THAT ULTIMATELY AFFECT OPERATION OF THE FACILITY. AS BRIEFLY ADDRESSED IN THIS REPORT, THESE AND OTHER CONCERNS RESULTED IN A SEPARATE REQUEST FOR THE LICENSEE, PURSUANT TO 10 CFR 50.54(F), TO DEVELOP A CORRECTIVE ACTION PLAN.

INSPECTION ON NOVEMBER 20 THROUGH DECEMBER 20, (85039): ROUTINE UNANNOUNCED INSPECTION OF THE LICENSEE'S INSPECTION PROGRAM MOTOR FOR OPERATOR VALVE LIMIT SWITCH COMPARTMENT WIRING. THE INSPECTION INVOLVED A TOTAL OF 32 INSPECTOR-HOURS BY TWO NRC INSPECTORS. ONE VIOLATION WAS IDENTIFIED (TWO EXAMPLES OF FAILURE TO FOLLOW PROCEDURES).

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

SHUT DOWN FOR ITS FIRST REFUELING ON OCTOBER 18, 1985

LAST IE SITE INSPECTION DATE: FEBRUARY 24 - 29, 1986

INSPECTION REPORT NO: 86008

Report Period FEB 1986


R E P O R T S   F R O M   L I C E N S E E

\*\*\*\*\* LASALLE 1 \*\*\*\*\*  
\*\*\*\*\* LASALLE 1 \*\*\*\*\*  
\*\*\*\*\* LASALLE 1 \*\*\*\*\*

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
-----			
NONE			

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-374 OPERATING STATUS  
 2. Reporting Period: 02/01/86 Outage + On-line Hrs: 674.0  
 3. Utility Contact: JAMES P. PETERS (815) 357-6761
4. Licensed Thermal Power (MWh): 3323
5. Nameplate Rating (Gross MWh): 1078
6. Design Electrical Rating (Net MWh): 1078
7. Maximum Dependable Capacity (Gross MWh): 1078
8. Maximum Dependable Capacity (Net MWh): 1036
9. If Changes Occur Above Since Last Report, Give Reasons:  
 \_\_\_\_\_
10. Power Level To Which Restricted, If Any (Net MWh): \_\_\_\_\_  
 11. Reasons for Restrictions, If Any:  
 NONE
- |  | MONTH            | YEAR             | CUMULATIVE        |
|--|------------------|------------------|-------------------|
| 12. Report Period Hrs  | <u>672.0</u>     | <u>1,416.0</u>   | <u>11,952.0</u>   |
| 13. Hours Reactor Critical                                     | <u>624.5</u>     | <u>1,368.5</u>   | <u>6,757.9</u>    |
| 14. Rx Reserve Shtdwn Hrs                                      | <u>29.8</u>      | <u>29.8</u>      | <u>1,716.7</u>    |
| 15. Hrs Generator On-Line                                      | <u>605.3</u>     | <u>1,349.3</u>   | <u>6,586.6</u>    |
| 16. Unit Reserve Shtdwn Hrs                                    | <u>0</u>         | <u>0</u>         | <u>0</u>          |
| 17. Gross Therm Ener (MWh)                                     | <u>1,798,080</u> | <u>3,964,104</u> | <u>19,472,655</u> |
| 18. Gross Elec Ener (MWh)                                      | <u>601,090</u>   | <u>1,325,871</u> | <u>6,435,640</u>  |
| 19. Net Elec Ener (MWh)  | <u>582,879</u>   | <u>1,289,889</u> | <u>6,112,604</u>  |
| 20. Unit Service Factor  | <u>90.1</u>      | <u>95.3</u>      | <u>55.1</u>       |
| 21. Unit Avail Factor  | <u>90.1</u>      | <u>95.3</u>      | <u>55.1</u>       |
| 22. Unit Cap Factor (DER Net)                                  | <u>83.7</u>      | <u>87.9</u>      | <u>49.9</u>       |
| 23. Unit Cap Factor (MDC Net)                                  | <u>80.5</u>      | <u>84.5</u>      | <u>47.9</u>       |
| 24. Unit Forced Outage Rate                                    | <u>9.9</u>       | <u>4.7</u>       | <u>22.5</u>       |
| 25. Forced Outage Hours  | <u>66.7</u>      | <u>66.7</u>      | <u>1,907.4</u>    |
| 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration): | <u>NONE</u>      |                  |                   |
| 27. If Currently Shutdown Estimated Startup Date:              | <u>N/A</u>       |                  |                   |



FEBRUARY 1986

Report Period FEB 1986

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* LASALLE 2 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System Component	Cause & Corrective Action to Prevent Recurrence
15	02/10/86	F	29.8	A	2			FAILURE OF #1 BYPASS VALVE.
16	02/16/86	F	36.9	A	3			REACTOR SCRAM ON LOAD REJECT DUE TO A PHASE TO PHASE FAULT ON A TRANSMISSION LINE. THE A PHASE OCB 1-9 FAILED TO TRIP (OUT OF TOLERANCE ON TRIP COILS) RESULTING IN THE 2 EAST MAIN TRANSFORMER.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	Instructions for Preparation of
	C-Refueling	H-Other	Data Entry Sheet
	D-Regulatory Restriction	4-Continued	Licensee Event Report
	E-Operator Training & License Examination	5-Reduced Load	(LER) File (NUREG-0161)
		9-Other	

\*\*\*\*\*  
\* LASALLE 2 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1986

FACILITY DESCRIPTION

LOCATION

STATE.....ILLINOIS

COUNTY.....LA SALLE

DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...11 MI SE OF  
OTTAWA, ILL

TYPE OF REACTOR.....BWR

DATE INITIAL CRITICALITY...MARCH 10, 1984

DATE ELEC ENER 1ST GENER...APRIL 20, 1984

DATE COMMERCIAL OPERATE....OCTOBER 19, 1984

CONDENSER COOLING METHOD...POND

CONDENSER COOLING WATER....RESERVOIR

ELECTRIC RELIABILITY  
COUNCIL.....MID-AMERICA  
INTERPOOL NETWORK

UTILITY & CONTRACTOR INFORMATION

UTILITY

LICENSEE.....COMMONWEALTH EDISON

CORPORATE ADDRESS.....P.O. BOX 767  
CHICAGO, ILLINOIS 60690

CONTRACTOR

ARCHITECT/ENGINEER.....SARGENT & LUNDY

NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC

CONSTRUCTOR.....COMMONWEALTH EDISON

TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III

IE RESIDENT INSPECTOR.....M. JORDAN

LICENSING PROJ MANAGER.....A. BOURNIA  
DOCKET NUMBER.....50-374

LICENSE & DATE ISSUANCE....NPF-18, MARCH 23, 1984

PUBLIC DOCUMENT ROOM.....ILLINOIS VALLEY COMMUNITY COLLEGE  
RURAL ROUTE NO. 1  
OGLESBY, ILLINOIS 16348

I N S P E C T I O N     S T A T U S

INSPECTION SUMMARY

INSPECTION ON OCTOBER 1-4, 17-18, 22-24, 29-31, NOVEMBER 1, 18-22 AND DECEMBER 5 AND 19 (85033) SPECIAL, ANNOUNCED IN-DEPTH ASSESSMENT BY TWO REGIONAL INSPECTORS OF MAINTENANCE ACTIVITIES. THE ASSESSMENT INVOLVED 206 INSPECTOR-HOURS ONSITE. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION ON OCTOBER 1 THROUGH NOVEMBER 12 (85034): ROUTINE, UNANNOUNCED INSPECTION CONDUCTED BY RESIDENT INSPECTORS AND ONE REGIONAL INSPECTOR OF LICENSEE ACTIONS ON PREVIOUS INSPECTION FINDINGS; OPERATIONAL SAFETY; SURVEILLANCE; MAINTENANCE; PREPARATION FOR REFUELING; LICENSEE EVENT REPORTS; EMERGENCY PREPAREDNESS TRAINING; REGION REQUESTS; UNIT TRIPS AND FOLLOWUP ON EVENTS. THE INSPECTION INVOLVED A TOTAL OF 369 INSPECTOR-HOURS ONSITE BY FOUR NRC INSPECTORS INCLUDING 61 HOURS ONSITE DURING OFF-SHIFTS. OF THE 10 AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED IN 8 AREAS; TWO VIOLATIONS WERE IDENTIFIED IN THE REMAINING TWO AREAS (FAILURE TO FOLLOW TECHNICAL SPECIFICATION LIMITING CONDITION FOR OPERATIONS; AND FAILURE TO REVIEW AND APPROVE PLANT MODIFICATIONS). THE LICENSEE'S EFFORT TO SCHEDULE AND PLAN WORK WAS HAVING SOME EFFECT ON JOBS BEING ACCOMPLISHED IN A REASONABLE TIME.

INSPECTION ON OCTOBER 21-23, 30-31 AND NOVEMBER 1, (85035): ROUTINE ANNOUNCED INSPECTION OF SAFETY-RELATED EQUIPMENT AND CABLES IN THE UNIT 1 AND UNIT 2 DRYWELLS TO IDENTIFY ANY DEGRADATION WHICH MAY HAVE OCCURRED AS A RESULT OF HIGHER THAN ANTICIPATED OPERATING AMBIENT TEMPERATURES. IN ADDITION, MOTOR OPERATED VALVE LIMITORQUE UNITS WERE EXAMINED FOR SETUP, MAINTENANCE, TESTING, AND PHYSICAL CONDITION. THE INSPECTION INVOLVED A TOTAL OF 77 INSPECTION-HOURS ONSITE AND EIGHT INSPECTION-HOURS OFFSITE BY THREE NRC INSPECTORS. OF THE AREAS INSPECTED, THREE VIOLATIONS WERE IDENTIFIED (FAILURE TO IMPLEMENT MEASURES TO PROMPTLY IDENTIFY AND CORRECT CONDITIONS ADVERSE TO QUALITY; FAILURE TO FOLLOW PROCEDURES WHICH LIMIT THE NUMBER OF TERMINATIONS ON A SINGLE STUD; AND

Report Period FEB 1986

I N S P E C T I O N      S T A T U S - (C O N T I N U E D)

\*\*\*\*\*  
\* LASALLE 2 \*  
\*\*\*\*\*

INSPECTION SUMMARY

FAILURE TO PROVIDE PERMANENT IDENTIFICATION FOR THE UNIT 1 SRVS).

INSPECTION ON NOVEMBER 13 THROUGH DECEMBER 30 (85039): ROUTINE, UNANNOUNCED INSPECTION CONDUCTED BY RESIDENT INSPECTORS AND REGIONAL INSPECTORS OF LICENSEE ACTIONS ON PREVIOUS INSPECTION FINDINGS; OPERATIONAL SAFETY; SURVEILLANCE; MAINTENANCE; LICENSEE EVENT REPORTS; HEADQUARTERS REQUESTS; AND REGION REQUESTS. THE INSPECTION INVOLVED A TOTAL OF 462 INSPECTOR-HOURS ONSITE BY SEVEN NRC INSPECTORS INCLUDING 89 HOURS ONSITE DURING OFF-SHIFTS. OF THE SEVEN AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED. ALTHOUGH NO VIOLATIONS WERE ISSUED, THE LICENSEE CONTINUES TO HAVE PROBLEMS WITH THE PLANNING AND COORDINATION OF WORK ACTIVITIES RESULTING IN MISSED SAMPLES, MISSED SURVEILLANCES, AND OVER LOOKING MAINTENANCE ACTIVITIES THAT ULTIMATELY AFFECT OPERATION OF THE FACILITY. AS BRIEFLY ADDRESSED IN THIS REPORT, THESE AND OTHER CONCERNS RESULTED IN A SEPARATE REQUEST FOR THE LICENSEE, PURSUANT TO 10 CFR 50.54(F), TO DEVELOP A CORRECTIVE ACTION PLAN.

INSPECTION ON NOVEMBER 20 THROUGH DECEMBER 20, (85040): ROUTINE UNANNOUNCED INSPECTION OF THE LICENSEE'S INSPECTION PROGRAM MOTOR FOR OPERATOR VALVE LIMIT SWITCH COMPARTMENT WIRING. THE INSPECTION INVOLVED A TOTAL OF 32 INSPECTOR-HOURS BY TWO NRC INSPECTORS. ONE VIOLATION WAS IDENTIFIED (TWO EXAMPLES OF FAILURE TO FOLLOW PROCEDURES).

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

OPERATING NORMALLY.

LAST IE SITE INSPECTION DATE: FEBRUARY 24 - 28, 1986

INSPECTION REPORT NO: 86009

Report Period FEB 1986


R E P O R T S   F R O M   L I C E N S E E

\*\*\*\*\*  
\* LASALLE 2 \*  
\*\*\*\*\*

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
85-48	12/24/85	01/20/86	RCIC WATER LEG PUMP FAILURE

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-352 OPERATING STATUS  
 2. Reporting Period: 02/01/86 Outage + On-line Hrs: 672.0  
 3. Utility Contact: BILL ALDEN (215) 841-5022  
 4. Licensed Thermal Power (MWh): 3293  
 5. Nameplate Rating (Gross MWe): 1092  
 6. Design Electrical Rating (Net MWe): 1055  
 7. Maximum Dependable Capacity (Gross MWe): 1092  
 8. Maximum Dependable Capacity (Net MWe): 1055  
 9. If Changes Occur Above Since Last Report, Give Reasons:  
 \_\_\_\_\_  
 10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_  
 11. Reasons for Restrictions, If Any: \_\_\_\_\_  
 NONE  
 12. Report Period Hrs MONTH 672.0 YEAR 672.0 CUMULATIVE 672.0  
 13. Hours Reactor Critical 651.1 651.1 651.1  
 14. Rx Reserve Shtdwn Hrs .0 .0 .0  
 15. Hrs Generator On-Line 645.6 645.6 645.6  
 16. Unit Reserve Shtdwn Hrs .0 .0 .0  
 17. Gross Therm Ener (MWH) 2,109,974 2,109,974 2,109,974  
 18. Gross Elec Ener (MWH) 699,970 699,970 699,970  
 19. Net Elec Ener (MWH) 673,943 673,943 673,943  
 20. Unit Service Factor 96.1 96.1 96.1  
 21. Unit Avail Factor 96.1 96.1 96.1  
 22. Unit Cap Factor (MDC Net) 95.1 95.1 95.1  
 23. Unit Cap Factor (DER Net) 95.1 95.1 95.1  
 24. Unit Forced Outage Rate 3.9 3.9 3.9  
 25. Forced Outage Hours 26.4 26.4 26.4  
 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
SURV. TESTING AND MAINT.: 05/01 - 6 TO 8 WEEKS.  
 27. If Currently Shutdown Estimated Startup Date: N/A



FEBRUARY 1986

Report Period FEB 1986

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* LIMERICK 1 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System Component	Cause & Corrective Action to Prevent Recurrence
1	02/10/86	F	26.4	A	3	86-11	HA INSTRU	A FULL REACTOR SCRAM FROM 99.8% POWER, OCCURRED AS A RESULT OF HIGH NEUTRON FLUX (FLOW BIASED THE NEUTRON FLUX SPIKE WAS A RESULT OF AN INCREASE IN REACTOR PRESSURE CAUSED BY THE UNEXPECTED CLOSURE OF THE TURBINE CONTROL VALVES. A GROUND IN THE ELECTROHYDRAULIC CONTROL (EHC) CIRCUIT CAUSED THE TURBINE CONTROL VALVES TO CLOSE.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*

LIMERICK 1 DECLARED COMMERCIAL OPERATION ON FEBRUARY 1, 1986.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	1-Manual
S-Sched	B-Maint or Test	G-Oper Error	2-Manual Scram
	C-Refueling	H-Other	3-Auto Scram
	D-Regulatory Restriction		4-Continued
	E-Operator Training		5-Reduced Load
	& License Examination		9-Other
			Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161)

\*\*\*\*\*  
\* LIMERICK 1 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1986

FACILITY DESCRIPTION

LOCATION  
STATE.....PENNSYLVANIA  
COUNTY.....MONTGOMERY  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...21 MI NW OF  
PHILADELPHIA, PA  
TYPE OF REACTOR.....BWR  
DATE INITIAL CRITICALITY...DECEMBER 22, 1984  
DATE ELEC ENER 1ST GENER...APRIL 13, 1985  
DATE COMMERCIAL OPERATE....FEBRUARY 1, 1986  
CONDENSER COOLING METHOD...CC HNDCT  
CONDENSER COOLING WATER....SCHUYLKILL RIVER  
ELECTRIC RELIABILITY  
COUNCIL.....MID-ATLANTIC  
AREA COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....PHILADELPHIA ELECTRIC  
CORPORATE ADDRESS.....2301 MARKET STREET  
PHILADELPHIA, PENNSYLVANIA 19105  
CONTRACTOR  
ARCHITECT/ENGINEER.....BECHTEL  
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC  
CONSTRUCTOR.....BECHTEL  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I  
IE RESIDENT INSPECTOR.....G. KELLY  
LICENSING PROJ MANAGER.....R. MARTIN  
DOCKET NUMBER.....50-352  
LICENSE & DATE ISSUANCE....NPF-39, AUGUST 8, 1985  
PUBLIC DOCUMENT ROOM.....POTTSTOWN PUBLIC LIBRARY  
500 HIGH STREET  
POTTSTOWN, PENNSYLVANIA 19464

I N S P E C T I O N     S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

Report Period FEB 1986

I N S P E C T I O N     S T A T U S - (CONTINUED)

\*\*\*\*\*  
\* LIMERICK 1 \*  
\*\*\*\*\*

OTHER ITEMS

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S   F R O M   L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
NO INPUT PROVIDED.			


=====

1. Docket: 50-309 OPERATING STATUS  
 2. Reporting Period: 02/01/86 Outage + On-line Hrs: 672.0  
 3. Utility Contact: K. L. EMBRY (207) 623-3521  
 4. Licensed Thermal Power (MWh): 2630  
 5. Nameplate Rating (Gross MWe): 864  
 6. Design Electrical Rating (Net MWe): 825  
 7. Maximum Dependable Capacity (Gross MWe): 850  
 8. Maximum Dependable Capacity (Net MWe): 810  
 9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE  
 10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_  
 11. Reasons for Restrictions, If Any:  
NONE  
 12. Report Period Hrs                    MONTH                    YEAR                    CUMULATIVE  
672.0                    1,416.0                    116,652.6  
 13. Hours Reactor Critical            520.2                    1,249.4                    93,586.8  
 14. Rx Reserve Shtdwn Hrs            .0                    .0                    .0  
 15. Hrs Generator On-Line            503.2                    1,228.7                    90,777.4  
 16. Unit Reserve Shtdwn Hrs        .0                    .0                    .0  
 17. Gross Therm Ener (MWH)        1,238,645            3,037,952            205,038,636  
 18. Gross Elec Ener (MWH)        414,800                    1,020,020            67,259,740  
 19. Net Elec Ener (MWH)        401,295                    986,166                    64,176,458  
 20. Unit Service Factor            74.9                    86.8                    77.8  
 21. Unit Avail Factor            74.9                    86.8                    77.8  
 22. Unit Cap Factor (MDC Net)    73.7                    86.0                    69.7\*  
 23. Unit Cap Factor (DER Net)    72.4                    84.4                    67.9\*  
 24. Unit Forced Outage Rate        25.1                    13.2                    7.0  
 25. Forced Outage Hours        168.8                    187.3                    5,959.8  
 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE  
 27. If Currently Shutdown Estimated Startup Date: 03/06/86

\*\*\*\*\*  
\* MAINE YANKEE \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

MAINE YANKEE



FEBRUARY 1986

\* Item calculated with a Weighted Average

Report Period FEB 1986

## UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
 \* MAINE YANKEE \*  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
1	02/01/86	F	0.0	B	5		HH	PUMPXX	TURBINE VALVE TESTING AND TROUBLE SHOOTING OF THE MAIN FEED PUMP (P2C) OIL SYSTEM.
2	02/14/86	F	0.0	B	5		HA	INSTRU	REDUCED POWER TO REPAIR COMPONENTS IN TURBINE VALVE LIMITS CIRCUITRY.
8-86-9	02/21/86	F	168.8	B	1		HA	GENERA	SHUTDOWN TO REPAIR HYDROGEN LEAKAGE FROM MAIN GENERATOR. STARTUP DELAYED DUE TO CHLORIDE INTRUSION IN CONDENSER.

\*\*\*\*\*  
 \* SUMMARY \*  
 \*\*\*\*\*

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	1-Manual
S-Sched	B-Maint or Test	G-Oper Error	2-Manual Scram
	C-Refueling	H-Other	3-Auto Scram
	D-Regulatory Restriction		4-Continued
	E-Operator Training & License Examination		5-Reduced Load
			9-Other
			Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161)

\*\*\*\*\*  
\* MAINE YANKEE \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1986

FACILITY DESCRIPTION

LOCATION  
STATE.....MAINE  
COUNTY.....LINCOLN  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...10 MI N OF  
BATH, ME  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...OCTOBER 23, 1972  
DATE ELEC ENER 1ST GENER...NOVEMBER 8, 1972  
DATE COMMERCIAL OPERATE....DECEMBER 28, 1972  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER....BACK RIVER  
ELECTRIC RELIABILITY  
(COUNCIL.....NORTHEAST POWER  
COORDINATING COUNCIL

INSPECTION STATUS

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....MAINE YANKEE ATOMIC POWER  
CORPORATE ADDRESS.....83 EDISON DRIVE  
AUGUSTA, MAINE 04366  
CONTRACTOR  
ARCHITECT/ENGINEER.....STONE & WEBSTER  
NUC STEAM SYS SUPPLIER...COMBUSTION ENGINEERING  
CONSTRUCTOR.....STONE & WEBSTER  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I  
IE RESIDENT INSPECTOR.....C. HOLDEN  
LICENSING PROJ MANAGER.....P. SEARS  
DOCKET NUMBER.....50-309  
LICENSE & DATE ISSUANCE....DPR-36, JUNE 29, 1973  
PUBLIC DOCUMENT ROOM.....WISCASSET PUBLIC LIBRARY  
HIGH STREET  
WISCASSET, MAINE 04578

Report Period FEB 1986

INSPECTION STATUS - (CONTINUED)

\*\*\*\*\*  
\* MAINE YANKEE \*  
\*\*\*\*\*

OTHER ITEMS

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

REPORTS FROM LICENSEE

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
--------	------------------	-------------------	---------


NO INPUT PROVIDED.

1. Docket: 50-369 OPERATING STATUS  
 2. Reporting Period: 02/01/86 Outage + On-line Hrs: 672.0  
 3. Utility Contact: J. A. REAVIS (704) 373-7567  
 4. Licensed Thermal Power (MWh): 3411  
 5. Nameplate Rating (Gross MWe): 1305  
 6. Design Electrical Rating (Net MWe): 1150  
 7. Maximum Dependable Capacity (Gross MWe): 1225  
 8. Maximum Dependable Capacity (Net MWe): 1150  
 9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE  
 10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_  
 11. Reasons for Restrictions, If Any:  
NONE  
 12. Report Period Hrs                    MONTH                    YEAR                    CUMULATIVE  
672.0                    1,416.0                    37,224.0  
 13. Hours Reactor Critical            672.0                    1,404.5                    26,866.0  
 14. Rx Reserve Shtdwn Hrs            .0                    .0                    .0  
 15. Hrs Generator On-Line            672.0                    1,402.5                    26,114.3  
 16. Unit Reserve Shtdwn Hrs            .0                    .0                    .0  
 17. Gross Therm Ener (MWH)            2,022,499            4,494,198            71,859,611  
 18. Gross Elec Ener (MWH)            709,263                    1,575,599                    24,886,252  
 19. Net Elec Ener (MWH)              680,955                    1,515,475                    23,667,489  
 20. Unit Service Factor                100.0                    99.0                    70.2  
 21. Unit Avail Factor                 100.0                    99.0                    70.2  
 22. Unit Cap Factor (MDC Net)        88.1                    93.1                    55.3  
 23. Unit Cap Factor (DER Net)        88.1                    93.1                    55.3  
 24. Unit Forced Outage Rate          .0                    1.0                    13.6  
 25. Forced Outage Hours                .0                    13.5                    4,125.0  
 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
REFUELING - MAY 30, 1986 - 11 WEEKS.  
 27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\*                    MCGUTRE 1                    \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

MCQUIRE 1



FEBRUARY 1986

Report Period FEB 1986

## UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
 \* MCGUIRE 1 \*  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
5-P	02/03/86	S	0.0	F	5		RC	FUELXX	CORE CONSERVATION TO EXTEND THE TIME UNTIL REFUELING OUTAGE.
6-P	02/06/86	S	0.0	B	5		CC	VALVEX	TURBINE VALVE MOVEMENT TEST.
7-P	02/06/86	S	0.0	F	5		RC	FUELXX	CORE CONSERVATION TO EXTEND THE TIME UNTIL REFUELING OUTAGE.
8-P	02/10/86	F	0.0	A	5		HH	PUMPXX	REPAIR "B" FEEDWATER PUMP.
9-P	02/10/86	S	0.0	F	5		RC	FUELXX	CORE CONSERVATION TO EXTEND THE TIME UNTIL REFUELING OUTAGE.
10-P	02/13/86	F	0.0	A	5		HH	ACCUMU	REPAIR (1C1) HEATER DRAIN TANK.

\*\*\*\*\*  
 \* MCGUIRE 1 OPERATED WITH 6 REDUCTIONS LISTED IN DETAIL ABOVE.  
 \* SUMMARY \*  
 \*\*\*\*\*

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	1-Manual
S-Sched	B-Maint or Test	G-Oper Error	2-Manual Scram
	C-Refueling	H-Other	3-Auto Scram
	D-Regulatory Restriction		4-Continued
	E-Operator Training & License Examination		5-Reduced Load
			9-Other
			Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161)

\*\*\*\*\*  
\* MCGUIRE 1 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1986

FACILITY DESCRIPTION

LOCATION  
STATE.....NORTH CAROLINA  
COUNTY.....MECKLENBURG  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...17 MI N OF  
CHARLOTTE, NC  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...AUGUST 8, 1981  
DATE ELEC ENER 1ST GENER...SEPTEMBER 12, 1981  
DATE COMMERCIAL OPERATE....DECEMBER 1, 1981  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER....LAKE NORMAN  
ELECTRIC RELIABILITY  
COUNCIL.....SOUTHEASTERN ELECTRIC  
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....DUKE POWER  
CORPORATE ADDRESS.....422 SOUTH CHURCH STREET  
CHARLOTTE, NORTH CAROLINA 28242  
CONTRACTOR  
ARCHITECT/ENGINEER.....DUKE POWER  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
CONSTRUCTOR.....DUKE POWER  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II  
IE RESIDENT INSPECTOR.....W. ORDERS  
LICENSING PROJ MANAGER.....D. HOOD  
DOCKET NUMBER.....50-369  
LICENSE & DATE ISSUANCE....NPF-9, JULY 8, 1981  
PUBLIC DOCUMENT ROOM.....MS. DAWN HUBBS  
ATKINS LIBRARY  
UNIVERSITY OF NORTH CAROLINA - CHARLOTTE  
UNCC STATION,  
CHARLOTTE, NC 28223

I N S P E C T I O N     S T A T U S

INSPECTION SUMMARY

+ INSPECTION NOVEMBER 21 - DECEMBER 20 (85-41): THIS ROUTINE, UNANNOUNCED INSPECTION INVOLVED 120 HOURS ON SITE IN THE AREAS OF OPERATIONS, SURVEILLANCE TESTING AND MAINTENANCE ACTIVITIES. ONE VIOLATION - FAILURE TO FOLLOW PROCEDURE.

INSPECTION JANUARY 21-24 (86-01): THIS ROUTINE, UNANNOUNCED INSPECTION ENTAILED 31 INSPECTOR-HOURS AT THE SITE IN THE AREAS OF GASEOUS AND LIQUID RADWASTE SYSTEMS, RADILOGICAL EFFLUENT ACCOUNTABILITY, REACTOR COOLANT AND SECONDARY WATER TECHNICAL SPECIFICATION REQUIREMENTS, AND REVIEW OF SELECTED INSPECTOR FOLLOWUP ITEMS. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

CONTRARY TO TECHNICAL SPECIFICATION 6.8.1 AND STATION HEALTH PHYSICS MANUAL, SECTION 8.3, RADILOGICAL STATUS AND ROUTINE SURVEYS, AND ITS ATTACHED EXHIBIT 8.3-2, ROUTINES AND THEIR FREQUENCIES, FROM NOVEMBER 1 TO DECEMBER 13, 1985 APPROXIMATELY TEN PERCENT OF DAILY AND FIVE PERCENT OF WEEKLY SURVEYS WERE NOT PERFORMED.  
(8504 4)

Report Period FEB 1986

I N S P E C T I O N      S T A T U S - (CONTINUED)

\*\*\*\*\*  
\*            MCGUIRE 1            \*  
\*\*\*\*\*

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

POWER OPERATION.

LAST IE SITE INSPECTION DATE: JANUARY 21-24, 1986 +

INSPECTION REPORT NO: 50-369/86-01 +

R E P O R T S   F R O M   L I C E N S E E

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
85-034	11/02/85	12/09/85	REACTOR TRIPS ON BOTH UNITS DUE TO LOSS OF INSTRUMENT AIR. A SECTION OF BRAIDED, FLEXIBLE PIPE ON THE DISCHARGE OF INSTRUMENT AIR COMPRESSOR B RUPTURED AT A WELDED SEAM.
85-035	10/30/85	12/02/85	SEVEN BABCOCK & WILCOX SPENT FUEL ASSEMBLIES INCORRECTLY STORED. THIS INCIDENT IS ATTRIBUTED TO PERSONNEL ERROR.
85-038	12/22/85	01/21/86	REACTOR TRIP ON TURBINE TRIP DUE TO GROUND FAULT. THE UNIT WAS STABILIZED FOLLOWING THE TRIP AND THE "MOD" WAS REPAIRED.

1. Docket: 50-370 OPERATING STATUS  
 2. Reporting Period: 02/01/86 Outage + On-line Hrs: 672.0  
 3. Utility Contact: J. A. REAVIS EXT (704) 373-7567  
 4. Licensed Thermal Power (MWh): 3411  
 5. Nameplate Rating (Gross MWe): 1450 X .9 = 1305  
 6. Design Electrical Rating (Net MWe): 1180  
 7. Maximum Dependable Capacity (Gross MWe): 1225  
 8. Maximum Dependable Capacity (Net MWe): 1150  
 9. If Changes Occur Above Since Last Report, Give Reasons:  
 \_\_\_\_\_

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_  
 11. Reasons for Restrictions, If Any: \_\_\_\_\_  
 NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>672.0</u>	<u>1,416.0</u>	<u>17,520.0</u>
13. Hours Reactor Critical	<u>672.0</u>	<u>1,369.5</u>	<u>12,998.3</u>
14. Rx Reserve Shtdn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>672.0</u>	<u>1,365.3</u>	<u>12,631.1</u>
16. Unit Reserve Shtdn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>2,262,594</u>	<u>4,546,842</u>	<u>40,697,872</u>
18. Gross Elec Ener (MWH)	<u>797,678</u>	<u>1,605,528</u>	<u>14,305,520</u>
19. Net Elec Ener (MWH)	<u>769,484</u>	<u>1,546,460</u>	<u>13,700,113</u>
20. Unit Service Factor	<u>100.0</u>	<u>96.4</u>	<u>72.1</u>
21. Unit Avail Factor	<u>100.0</u>	<u>96.4</u>	<u>72.1</u>
22. Unit Cap Factor (MDC Net)	<u>99.6</u>	<u>93.7</u>	<u>68.0</u>
23. Unit Cap Factor (DER Net)	<u>99.6</u>	<u>93.7</u>	<u>68.0</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>3.6</u>	<u>16.6</u>
25. Forced Outage Hours	<u>.0</u>	<u>50.7</u>	<u>2,518.2</u>
26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):			
REFUELING - 03/14/86 - 9 WEEKS.			

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\* MC GUIRE 2 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

MC GUIRE 2



FEBRUARY 1986

Report Period FEB 1986

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* MC GUIRE 2 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
6-P	02/19/86	S	0.0	B	5		CC	VALVEX	TURBINE VALVE MOVEMENT TEST.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*

MC GUIRE 2 OPERATED WITH 1 REDUCTION FOR TESTING.

Type	Reason	Method	System & Component	
F-Forced S-Sched	A-Equip Failure B-Maint or Test C-Refueling D-Regulatory Restriction E-Operator Training & License Examination	F-Admin G-Oper Error H-Other	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161)

\*\*\*\*\*  
\* MC GUIRE 2 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1986

FACILITY DESCRIPTION

LOCATION  
STATE.....NORTH CAROLINA  
COUNTY.....MECKLENBURG  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...17 MI N OF  
CHARLOTTE, NC  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...MAY 8, 1983  
DATE ELEC ENER 1ST GENER...MAY 23, 1983  
DATE COMMERCIAL OPERATE....MARCH 1, 1984  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER....LAKE NORMAN  
ELECTRIC RELIABILITY  
COUNCIL.....SOUTHEASTERN ELECTRIC  
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....DUKE POWER  
CORPORATE ADDRESS.....POWER BLDG., BOX 2178  
CHARLOTTE, NORTH CAROLINA 28201  
CONTRACTOR  
ARCHITECT/ENGINEER.....DUKE POWER  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
CONSTRUCTOR.....DUKE POWER  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II  
IE RESIDENT INSPECTOR.....W. ORDERS  
LICENSING PROJ MANAGER.....D. HOOD  
DOCKET NUMBER.....50-370  
LICENSE & DATE ISSUANCE....NPF-17, MAY 27, 1983  
PUBLIC DOCUMENT ROOM.....MS. DAWN HUBBS  
ATKINS LIBRARY  
UNIVERSITY OF NORTH CAROLINA - CHARLOTTE  
UNCC STATION,  
CHARLOTTE, NC 28223

I N S P E C T I O N     S T A T U S

INSPECTION SUMMARY

+ INSPECTION NOVEMBER 21 - DECEMBER 20 (85-42): THIS ROUTINE, UNANNOUNCED INSPECTION INVOLVED 120 HOURS ON SITE IN THE AREAS OF OPERATIONS, SURVEILLANCE TESTING AND MAINTENANCE ACTIVITIES. ONE VIOLATION - FAILURE TO FOLLOW PROCEDURE.

INSPECTION JANUARY 21-24 (86-01): THIS ROUTINE, UNANNOUNCED INSPECTION ENTAILED 32 INSPECTOR-HOURS AT THE SITE IN THE AREAS OF GASEOUS AND LIQUID RADWASTE SYSTEMS, RADIOLOGICAL EFFLUENT ACCOUNTABILITY, REACTOR COOLANT AND SECONDARY WATER TECHNICAL SPECIFICATION REQUIREMENTS, AND REVIEW OF SELECTED INSPECTOR FOLLOWUP ITEMS. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

Report Period FEB 1986

INSPECTION STATUS - (CONTINUED)

\*\*\*\*\*  
\* MC GUIRE 2 \*  
\*\*\*\*\*

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

POWER OPERATION.

LAST IE SITE INSPECTION DATE: JANUARY 21-24, 1986 +

INSPECTION REPORT NO: 50-370/86-01 +

REPORTS FROM LICENSEE


NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
85-029	11/10/85	12/09/85	INADVERTENT START OF TURBINE DRIVEN AUXILIARY FEEDWATER PUMP. THE FUSE BLEW ON THE AUTO-START CIRCUITRY.
85-030	12/11/85	01/13/86	REACTOR TRIP WHILE SUBCRITICAL, DUE TO SOURCE RANGE SPIKE. IT IS BELIEVED THAT WATER IN THE DETECTOR CANISTER CAUSED THE FAILURE.

1. Docket: 50-245 OPERATING STATUS  
 2. Reporting Period: 02/01/86 Outage + On-line Hrs: 672.0  
 3. Utility Contact: GEORGE HARRAN (203) 447-1791 X4194  
 4. Licensed Thermal Power (MWh): 2011  
 5. Nameplate Rating (Gross MWe): 735 X 0.9 = 662  
 6. Design Electrical Rating (Net MWe): 660  
 7. Maximum Dependable Capacity (Gross MWe): 684  
 8. Maximum Dependable Capacity (Net MWe): 654  
 9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE  
 10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_  
 11. Reasons for Restrictions, If Any:  
NONE  
 12. Report Period Hrs MONTH YEAR CUMULATIVE  
672.0 1,416.0 133,704.0  
 13. Hours Reactor Critical 637.3 1,381.3 102,460.4  
 14. Rx Reserve Shtdwn Hrs .0 .0 2,834.5  
 15. Hrs Generator On-Line 630.7 1,374.7 99,563.9  
 16. Unit Reserve Shtdwn Hrs .0 .0 93.7  
 17. Gross Therm Ener (MWH) 1,239,702 2,730,997 183,345,195  
 18. Gross Elec Ener (MWH) 425,200 936,600 61,637,896  
 19. Net Elec Ener (MWH) 406,452 895,886 58,788,399  
 20. Unit Service Factor 93.9 97.1 74.5  
 21. Unit Avail Factor 93.9 97.1 74.5  
 22. Unit Cap Factor (MDC Net) 92.5 96.7 67.2  
 23. Unit Cap Factor (DER Net) 91.6 95.9 66.6  
 24. Unit Forced Outage Rate 6.1 2.9 12.2  
 25. Forced Outage Hours 41.3 41.3 5,855.6  
 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE  
 27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\* MILLSTONE 1 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

MILLSTONE 1



FEBRUARY 1986

Report Period FEB 1986

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* MILLSTONE 1 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System Component	Cause & Corrective Action to Prevent Recurrence
1	02/05/86	F	41.3	H	3	86-005		A PRESSURE OSCILLATION IN THE MECHANICAL PRESSURE REGULATOR (MPR) SYSTEM CAUSED THE REACTOR TO SCRAM ON APRM HI-HI FLUX. A COMPLETE OVERHAUL OF THE MPR SYSTEM IS PLANNED TO PREVENT RECURRENCE.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	Instructions for Preparation of Data Entry Sheet
	C-Refueling	H-Other	4-Continued
	D-Regulatory Restriction		5-Reduced Load
	E-Operator Training & License Examination		9-Other
			Licensee Event Report (LER) File (NUREG-0161)

\*\*\*\*\*  
\* MILLSTONE 1 \*  
\*\*\*\*\*

FACILITY DESCRIPTION

LOCATION STATE.....CONNECTICUT  
COUNTY.....NEW LONDON  
DIST AND DIRECTION FROM NEAREST POPULATION CTR...5 MI SW OF NEW LONDON, CONN  
TYPE OF REACTOR.....BWR  
DATE INITIAL CRITICALITY...OCTOBER 26, 1970  
DATE ELEC ENER 1ST GENER...NOVEMBER 29, 1970  
DATE COMMERCIAL OPERATE....MARCH 1, 1971  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER....LONG ISLAND SOUND  
ELECTRIC RELIABILITY COUNCIL.....NORTHEAST POWER COORDINATING COUNCIL

FACILITY DATA

Report Period FEB 1986

UTILITY & CONTRACTOR INFORMATION

UTILITY LICENSEE.....NORTHEAST NUCLEAR ENERGY  
CORPORATE ADDRESS.....P.O. BOX 270 HARTFORD, CONNECTICUT 06101  
CONTRACTOR ARCHITECT/ENGINEER.....EBASCO  
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC  
CONSTRUCTOR.....EBASCO  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I  
IE RESIDENT INSPECTOR.....J. SHEDLOSKY  
LICENSING PROJ MANAGER.....J. SHEA  
DOCKET NUMBER.....50-245  
LICENSE & DATE ISSUANCE....DPR-21, OCTOBER 26, 1970  
PUBLIC DOCUMENT ROOM.....WATERFORD PUBLIC LIBRARY  
45 ROPE FERRY ROAD  
ROUTE 156  
WATERFORD, CONNECTICUT 06385

I N S P E C T I O N     S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

Report Period FEB 1986

I N S P E C T I O N      S T A T U S - (CONTINUED)

\*\*\*\*\*  
\*            MILLSTONE 1            \*  
\*\*\*\*\*

OTHER ITEMS

NO INPUT PROVIDED.

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S   F R O M   L I C E N S E E

NUMBER      DATE OF      DATE OF      SUBJECT  
EVENT          REPORT

---

NO INPUT PROVIDED.


---

1. Docket: 50-336      O P R A T I N G   S T A T U S  
 2. Reporting Period: 02/01/86 Outage On-line Hrs: 672.0  
 3. Utility Contact: R. BORCHERT (203) 447-1791 X4418  
 4. Licensed Thermal Power (MWh): 2700  
 5. Nameplate Rating (Gross MWe): 1011 X 0.9 = 910  
 6. Design Electrical Rating (Net MWe): 870  
 7. Maximum Dependable Capacity (Gross MWe): 889  
 8. Maximum Dependable Capacity (Net MWe): 857  
 9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE  
 10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_  
 11. Reasons for Restrictions, If Any:  
NONE  
 12. Report Period Hrs      MONTH      YEAR      CUMULATIVE  
672.0      1,416.0      89,232.0  
 13. Hours Reactor Critical      672.0      1,416.0      62,838.4  
 14. Rx Reserve Shtdwn Hrs      .0      .0      2,166.9  
 15. Hrs Generator On-Line      672.0      1,416.0      60,133.4  
 16. Unit Reserve Shtdwn Hrs      .0      .0      468.2  
 17. Gross Therm Ener (MWH)      1,813,645      3,797,744      152,706,253  
 18. Gross Elec Ener (MWH)      587,600      1,231,200      49,563,673  
 19. Net Elec Ener (MWH)      566,888      1,187,490      47,510,271  
 20. Unit Service Factor      100.0      100.0      67.4  
 21. Unit Avail Factor      100.0      100.0      67.9  
 22. Unit Cap Factor (MDC Net)      98.4      97.9      63.2\*  
 23. Unit Cap Factor (DER Net)      97.0      96.4      62.2\*  
 24. Unit Forced Outage Rate      .0      .0      17.0  
 25. Forced Outage Hours      .0      .0      11,062.8  
 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE  
 27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\* MILLSTONE 2 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

MILLSTONE 2



FEBRUARY 1986

\* Item calculated with a Weighted Average

Report Period FEB 1986

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* MILLSTONE 2 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System Component	Cause & Corrective Action to Prevent Recurrence
-----	------	------	-------	--------	--------	------------	------------------	---

NONE

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*

MILLSTONE 2 OPERATED AT NEAR FULL POWER DURING FEBRUARY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Manual	Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	Instructions for
	C-Refueling	H-Other	Preparation of
	D-Regulatory Restriction	I-Auto Scram	Data Entry Sheet
	E-Operator Training & License Examination	J-Continued	Licensee Event Report
		K-Reduced Load	(LER) File (NUREG-0161)
		L-Other	

\*\*\*\*\*  
\* MILLSTONE 2 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1986

FACILITY DESCRIPTION

LOCATION STATE.....CONNECTICUT  
COUNTY.....NEW LONDON  
DIST AND DIRECTION FROM NEAREST POPULATION CTR...5 MI SW OF NEW LONDON, CONN  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...OCTOBER 17, 1975  
DATE ELIC ENER 1ST GENER...NOVEMBER 9, 1975  
DATE COMMERCIAL OPERATE....DECEMBER 26, 1975  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER....LONG ISLAND SOUND  
ELECTRIC RELIABILITY COUNCIL.....NORTHEAST POWER COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....NORTHEAST NUCLEAR ENERGY  
CORPORATE ADDRESS.....P.O. BOX 270  
HARTFORD, CONNECTICUT 06101

CONTRACTOR  
ARCHITECT/ENGINEER.....BECHTEL  
NUC STEAM SYS SUPPLIER...COMBUSTION ENGINEERING  
CONSTRUCTOR.....BECHTEL  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I  
IE RESIDENT INSPECTOR.....J. SHEDLOSKY  
LICENSING PROJ MANAGER.....D. OSBORNE  
DOCKET NUMBER.....50-336  
LICENSE & DATE ISSUANCE....DPR-65, SEPTEMBER 30, 1975  
PUBLIC DOCUMENT ROOM.....WATERFORD PUBLIC LIBRARY  
45 ROPE FERRY ROAD  
ROUTE 156  
WATERFORD, CONNECTICUT 06385

I N S P E C T I O N     S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

Report Period FEB 1986

I N S P E C T I O N      S T A T U S - (CONTINUED)

\*\*\*\*\*  
\*            MILLSTONE 2            \*  
\*\*\*\*\*

OTHER ITEMS

NO INPUT PROVIDED.

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S   F R O M   L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
--------	------------------	-------------------	---------

=====

NO INPUT PROVIDED.

1. Docket: 50-423 OPERATING STATUS  
 2. Reporting Period: 02/01/86 Outage + On-line Hrs: 672.0  
 3. Utility Contact: A. ELMS (203) 444-5388  
 4. Licensed Thermal Power (MWT): 3411  
 5. Nameplate Rating (Gross MWe): 1253  
 6. Design Electrical Rating (Net MWe): 1156  
 7. Maximum Dependable Capacity (Gross MWe): 1156  
 8. Maximum Dependable Capacity (Net MWe): 1156  
 9. If Changes Occur Above Since Last Report, Give Reasons:  
 \_\_\_\_\_

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_  
 11. Reasons for Restrictions, If Any: \_\_\_\_\_  
 NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>399.6</u>	<u>399.6</u>	<u>399.6</u>
13. Hours Reactor Critical	<u>174.1</u>	<u>174.1</u>	<u>174.1</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>143.5</u>	<u>143.5</u>	<u>143.5</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>179,659</u>	<u>179,659</u>	<u>179,659</u>
18. Gross Elec Ener (MWH)	<u>40,425</u>	<u>40,425</u>	<u>40,425</u>
19. Net Elec Ener (MWH)	<u>28,470</u>	<u>28,470</u>	<u>28,470</u>
20. Unit Service Factor			
21. Unit Avail Factor		NOT IN	
22. Unit Cap Factor (MDC Net)		COMMERCIAL	
23. Unit Cap Factor (DER Net)		OPERATION	
24. Unit Forced Outage Rate			
25. Forced Outage Hours	<u>233.6</u>	<u>233.6</u>	<u>233.6</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
 NONE  
 27. If Currently Shutdown Estimated Startup Date: 03/05/86

\*\*\*\*\*  
\* MILLSTONE 3 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

MILLSTONE 3



\* Item calculated with a Weighted Average

Report Period FEB 1986

## UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
 \* MILLSTONE 3 \*  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
86-01	02/12/86	F	20.7	G	3	86-014-00	JB		LOW S/G LEVEL-GENERATOR PROGRAM WATER LEVEL SHORTED TO 0% - PERSONNEL ERROR.
86-02	02/13/86	F	35.5	H	3	86-016-00	JC		GENERAL WARNING CAUSE UNKNOWN.
86-03	02/15/86	S	1.3	B	9		TA	TRB	INITIAL PLANT STARTUP TESTING-TURBINE TRIP ONLY.
86-04	02/18/86	S	21.2	B	1		AC	RCT	INITIAL PLANT STARTUP TESTING.
86-05	02/21/86	F	177.4	B	1		SJ	SG	CLEAN S/G.

\*\*\*\*\*  
 \* SUMMARY \*  
 \*\*\*\*\*

MILLSTONE 3 GENERATED INITIAL ELECTRICITY ON FEBRUARY 12, 1986.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	1-Manual
S-Sched	B-Maint or Test	G-Oper Error	2-Manual Scram
	C-Refueling	H-Other	3-Auto Scram
	D-Regulatory Restriction		4-Continued
	E-Operator Training & License Examination		5-Reduced Load
			9-Other
			Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161)

\*\*\*\*\*  
\* MILLSTONE 3 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1986

FACILITY DESCRIPTION

LOCATION STATE..... CONNECTICUT  
COUNTY..... NEW LONDON  
DIST AND DIRECTION FROM NEAREST POPULATION CTR... 3.2 MI WSW OF NEW LONDON CT.  
TYPE OF REACTOR..... PWR  
DATE INITIAL CRITICALITY... JANUARY 23, 1984  
DATE ELEC ENER 1ST GENER... FEBRUARY 12, 1986  
DATE COMMERCIAL OPERATE.... \*\*\*\*\*  
CONDENSER COOLING METHOD... ONCE THRU  
CONDENSER COOLING WATER... NIANTIC BAY  
ELECTRIC RELIABILITY COUNCIL..... NORTHEAST POWER COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE..... NORTHEAST NUCLEAR ENERGY  
CORPORATE ADDRESS..... P.O. BOX 270  
HARTFORD, CONNECTICUT 06101  
CONTRACTOR  
ARCHITECT/ENGINEER..... STONE & WEBSTER  
NUC STEAM SYS SUPPLIER... WESTINGHOUSE  
CONSTRUCTOR..... STONE & WEBSTER  
TURBINE SUPPLIER..... GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE..... I  
IE RESIDENT INSPECTOR..... T. REBELOWSKI  
LICENSING PROJ MANAGER..... E. DOOLITTLE  
DOCKET NUMBER..... 50-423  
LICENSE & DATE ISSUANCE.... NPF-49, JANUARY 31, 1986  
PUBLIC DOCUMENT ROOM.....

ROUTE 156  
WATERFORD, CONNECTICUT 06385

I N S P E C T I O N     S T A T U S

INSPECTION SUMMARY

INFO. NOT SUPPLIED BY REGION

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

INFO. NOT SUPPLIED BY REGION

FACILITY ITEMS (PLANS AND PROCEDURES):

INFO. NOT SUPPLIED BY REGION

MANAGERIAL ITEMS:

INFO. NOT SUPPLIED BY REGION

Report Period FEB 1986

I N S P E C T I O N      S T A T U S - (CONTINUED)

\*\*\*\*\*  
\* MILLSTONE 3 \*  
\*\*\*\*\*

PLANT STATUS:

INFO. NOT SUPPLIED BY REGION

LAST IE SITE INSPECTION DATE: INFO. NOT SUPPLIED BY REGION

INSPECTION REPORT NO: INFO. NOT SUPPLIED BY REGION

R E P O R T S   F R O M   L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
--------	------------------	-------------------	---------

=====


INFO. NOT SUPPLIED BY REGION

1. Docket: 50-263 OPERATING STATUS  
 2. Reporting Period: 02/01/86 Outage + On-line Hrs: 672.0  
 3. Utility Contact: A. L. Myrabo (612) 295-5151  
 4. Licensed Thermal Power (MWh): 1670  
 5. Nameplate Rating (Gross MWe): 632 X 0.9 = 569  
 6. Design Electrical Rating (Net MWe): 545  
 7. Maximum Dependable Capacity (Gross MWe): 564  
 8. Maximum Dependable Capacity (Net MWe): 536  
 9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE  
 10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_  
 11. Reasons for Restrictions, If Any:  
NONE  
 12. Report Period Hrs      MONTH      YEAR      CUMULATIVE  
672.0      1,416.0      128,569.0  
 13. Hours Reactor Critical      672.0      1,416.0      99,494.5  
 14. Rx Reserve Shtdn Hrs      .0      .0      940.7  
 15. Hrs Generator On-Line      672.0      1,416.0      97,449.6  
 16. Unit Reserve Shtdn Hrs      .0      .0      .0  
 17. Gross Therm Ener (MWH)      961,234      2,138,417      156,431,927  
 18. Gross Elec Ener (MWH)      327,671      730,644      50,381,921  
 19. Net Elec Ener (MWH)      314,279      701,988      48,164,399  
 20. Unit Service Factor      100.0      100.0      75.8  
 21. Unit Avail Factor      100.0      100.0      75.8  
 22. Unit Cap Factor (MDC Net)      87.3      92.5      69.9  
 23. Unit Cap Factor (DER Net)      85.8      91.0      68.7  
 24. Unit Forced Outage Rate      .0      .0      4.8  
 25. Forced Outage Hours      .0      .0      1,335.0  
 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
5/1/86 - 1986 REFUELING OUTAGE - 54 DAYS.  
 27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\* MONTICELLO \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

MONTICELLO



FEBRUARY 1986

Report Period FEB 1986

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* MONTICELLO \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System Component	Cause & Corrective Action to Prevent Recurrence
-----	------	------	-------	--------	--------	------------	------------------	---

NONE

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
MONTICELLO OPERATED ROUTINELY IN FEBRUARY WITH NO OUTAGES OR POWER REDUCTIONS REPORTED.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	Instructions for
	C-Refueling	H-Other	Preparation of
	D-Regulatory Restriction		Data Entry Sheet
	E-Operator Training & License Examination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Licensee Event Report (LER) File (NUREG-0161)

\*\*\*\*\*  
\* MONTICELLO \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1986

FACILITY DESCRIPTION

LOCATION  
STATE.....MINNESOTA  
COUNTY.....WRIGHT  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...30 MI NW OF  
MINNEAPOLIS, MINN

TYPE OF REACTOR.....BWR  
DATE INITIAL CRITICALITY...DECEMBER 10, 1970

DATE ELEC ENER 1ST GENER...MARCH 5, 1971

DATE COMMERCIAL OPERATE....JUNE 30, 1971

CONDENSER COOLING METHOD...COOLING TOWER

CONDENSER COOLING WATER....MISSISSIPPI RIVER

ELECTRIC RELIABILITY  
COUNCIL.....MID-CONTINENT AREA  
RELIABILITY COORDINATION  
AGREEMENT

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....NORTHERN STATES POWER  
CORPORATE ADDRESS.....414 NICOLLET MALL  
MINNEAPOLIS, MINNESOTA 55401

CONTRACTOR  
ARCHITECT/ENGINEER.....BECHTEL  
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC  
CONSTRUCTOR.....BECHTEL  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III  
IE RESIDENT INSPECTOR.....P. HARTMAN  
LICENSING PROJ MANAGER.....R. AULUCK  
DOCKET NUMBER.....50-263  
LICENSE & DATE ISSUANCE....DPR-22, JANUARY 9, 1981  
PUBLIC DOCUMENT ROOM.....ENVIRONMENTAL CONSERVATION LIBRARY  
MINNEAPOLIS PUBLIC LIBRARY  
300 NICOLLET MALL  
MINNEAPOLIS, MINNESOTA 55401

INSPECTION STATUS

INSPECTION SUMMARY

NONE

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

Report Period FEB 1986

INSPECTION STATUS - (CONTINUED)

\*\*\*\*\*  
\* MONTICELLO \*  
\*\*\*\*\*

OTHER ITEMS

NONE

MANAGERIAL ITEMS:

"NONE

PLANT STATUS:

OPERATING ROUTINELY

LAST IE SITE INSPECTION DATE: JANUARY 21 - MARCH 3, 1986

INSPECTION REPORT NO: 86002

REPORTS FROM LICENSEE

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
--------	---------------	----------------	---------


85-21	12/18/85	01/16/86	EFT ACTUATION DUE TO AMMONIA DETECTOR SPIKE
-------	----------	----------	---

1. Docket: 50-220 OPERATING STATUS  
 2. Reporting Period: 02/01/86 Outage + On-line Hrs: 672.0  
 3. Utility Contact: THOMAS W. ROMAN (315) 349-2422  
 4. Licensed Thermal Power (Mw): 1850  
 5. Nameplate Rating (Gross MWe): 755 X 0.85 = 642  
 6. Design Electrical Rating (Net MWe): 620  
 7. Maximum Dependable Capacity (Gross MWe): 630  
 8. Maximum Dependable Capacity (Net MWe): 610  
 9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE  
 10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_  
 11. Reasons for Restrictions, If Any:  
NONE  
 12. Report Period Hrs      MONTH      YEAR      CUMULATIVE  
672.0      1,416.0      143,136.0  
 13. Hours Reactor Critical      672.0      1,262.0      102,502.5  
 14. Rx Reserve Shtdwn Hrs      .0      .0      1,204.2  
 15. Hrs Generator On-Line      672.0      1,252.8      99,500.8  
 16. Unit Reserve Shtdwn Hrs      .0      .0      20.2  
 17. Gross Therm Ener (MWH)      950,712      1,844,275      166,339,950  
 18. Gross Elec Ener (MWH)      314,009      611,057      55,080,513  
 19. Net Elec Ener (MWH)      301,797      587,934      53,350,261  
 20. Unit Service Factor      100.0      88.5      69.5  
 21. Unit Avail Factor      100.0      88.5      69.5  
 22. Unit Cap Factor (MDC Net)      73.6      68.1      61.1  
 23. Unit Cap Factor (DER Net)      72.4      67.0      60.1  
 24. Unit Forced Outage Rate      .0      11.5      15.4  
 25. Forced Outage Hours      .0      163.2      13,539.7  
 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
REFUEL OUTAGE: MARCH 1986 - DURATION: 14 WEEKS.  
 27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\*     NINE MILE POINT 1     \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

NINE MILE POINT 1



FEBRUARY 1986

Report Period FEB 1986

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* NINE MILE POINT 1 \*  
\*\*\*\*\*

No. Date Type Hours Reason Method LER Number System Component Cause & Corrective Action to Prevent Recurrence

NONE

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*

NINE MILE POINT 1 OPERATED ROUTINELY IN FEBRUARY WITH NO SHUTDOWNS OR POWER REDUCTIONS REPORTED.

Type	Reason	Method	System & Component	
F-Forced	A-Equip Failure	F-Admin	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	2-Manual Scram	Instructions for
	C-Refueling	H-Other	3-Auto Scram	Preparation of
	D-Regulatory Restriction		4-Continued	Data Entry Sheet
	E-Operator Training & License Examination		5-Reduced Load	Licensee Event Report
			9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* NINE MILE POINT 1 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1986

FACILITY DESCRIPTION

LOCATION  
STATE.....NEW YORK

COUNTY.....OSWEGO

DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...8 MI NE OF  
OSWEGO, NY

TYPE OF REACTOR.....BWR

DATE INITIAL CRITICALITY...SEPTEMBER 5, 1969

DATE ELEC ENER 1ST GENER...NOVEMBER 9, 1969

DATE COMMERCIAL OPERATE....DECEMBER 1, 1969

CONDENSER COOLING METHOD...ONCE THRU

CONDENSER COOLING WATER....LAKE ONTARIO

ELECTRIC RELIABILITY  
COUNCIL.....NORTHEAST POWER  
COORDINATING COUNCIL

I N S P E C T I O N     S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....NIAGARA MOHAWK POWER CORP.

CORPORATE ADDRESS.....300 ERIE BOULEVARD WEST  
SYRACUSE, NEW YORK 13202

CONTRACTOR  
ARCHITECT/ENGINEER.....NIAGARA MOHAWK POWER CORP.

NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC

CONSTRUCTOR.....STONE & WEBSTER

TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I

IE RESIDENT INSPECTOR.....S. HUDSON

LICENSING PROJ MANAGER.....R. HERMANN  
DOCKET NUMBER.....50-220

LICENSE & DATE ISSUANCE....DPR-63, DECEMBER 26, 1974

PUBLIC DOCUMENT ROOM.....STATE UNIVERSITY COLLEGE OF OSWEGO  
PENFIELD LIBRARY - DOCUMENTS  
OSWEGO, NY 13126  
(315) 341-2323

Report Period FEB 1986

I N S P E C T I O N     S T A T U S - (CONTINUED)

\*\*\*\*\*  
\* NINE MILE POINT 1 \*  
\*\*\*\*\*

OTHER ITEMS

NO INPUT PROVIDED.

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S   F R O M   L I C E N S E E

=====


NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
NO INPUT PROVIDED.			

=====

1. Docket: 50-338 OPERATING STATUS  
 2. Reporting Period: 02/01/86 Outage + On-line Hrs: 672.0  
 3. Utility Contact: B. GARNER (703) 894-5151 X2527  
 4. Licensed Thermal Power (MWh): 2775  
 5. Nameplate Rating (Gross MWe): 947  
 6. Design Electrical Rating (Net MWe): 907  
 7. Maximum Dependable Capacity (Gross MWe): 941  
 8. Maximum Dependable Capacity (Net MWe): 893  
 9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE  
 10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_  
 11. Reasons for Restrictions, If Any:  
NONE  
 12. Report Period Hrs      MONTH      YEAR      CUMULATIVE  
672.0      1,416.0      67,801.0  
 13. Hours Reactor Critical      642.0      995.1      46,280.9  
 14. Rx Reserve Shtdwn Hrs      30.0      420.9      4,427.5  
 15. Hrs Generator On-Line      616.5      962.6      44,874.7  
 16. Unit Reserve Shtdwn Hrs      .0      .0      .0  
 17. Gross Therm Ener (MWH)      1,703,397      2,514,123      117,490,675  
 18. Gross Elec Ener (MWH)      573,749      844,175      38,321,801  
 19. Net Elec Ener (MWH)      545,461      800,916      36,215,864  
 20. Unit Service Factor      91.7      68.0      66.2  
 21. Unit Avail Factor      91.7      68.0      66.2  
 22. Unit Cap Factor (MDC Net)      90.9      63.3      59.8  
 23. Unit Cap Factor (DER Net)      89.5      62.4      58.9  
 24. Unit Forced Outage Rate      8.3      31.8      12.7  
 25. Forced Outage Hours      55.5      449.4      6,433.9  
 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE  
 27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\*            NORTH ANNA 1            \*  
\*\*\*\*\*  
AVERAGE DAILY POWER LEVEL (MWe) PLOT

NORTH ANNA 1



FEBRUARY 1986

Report Period FEB 1986

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* NORTH ANNA 1 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
86-02	02/23/86	F	55.5	A	3	N1-86-02			ON FEBRUARY 23, 1986 AT 1540, REACTOR TRIP FROM 100% POWER, DUE TO "B" STEAM GENERATOR LO/LO LEVEL NARROW RANGE WHICH WAS CAUSED BY TURBINE GOVERNOR VALVES FAILING SHUT. THE EHC SYSTEM WAS REPAIRED AND UNIT RETURNED TO 100% POWER.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*

NORTH ANNA 1 OPERATED WITH 1 SHUTDOWN IN FEBRUARY AS DISCUSSED ABOVE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	1-Manual
S-Sched	B-Maint or Test	G-Oper Error	2-Manual Scram
	C-Refueling	H-Other	3-Auto Scram
	D-Regulatory Restriction		4-Continued
	E-Operator Training		5-Reduced Load
	& License Examination		9-Other
			Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161)

\*\*\*\*\*  
\* ANNA 1 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1986

FACILITY DESCRIPTION

LOCATION  
STATE.....VIRGINIA

COUNTY.....LOUISA

DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...40 MI NW OF  
RICHMOND, VA

TYPE OF REACTOR.....PWR

DATE INITIAL CRITICALITY...APRIL 5, 1978

DATE ELEC ENER 1ST GENER...APRIL 17, 1978

DATE COMMERCIAL OPERATE....JUNE 6, 1978

CONDENSER COOLING METHOD...ONCE THRU

CONDENSER COOLING WATER....LAKE ANNA

ELECTRIC RELIABILITY  
COUNCIL.....SOUTHEASTERN ELECTRIC  
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....VIRGINIA POWER

CORPORATE ADDRESS.....P.O. BOX 26666  
RICHMOND, VIRGINIA 23261

CONTRACTOR  
ARCHITECT/ENGINEER.....STONE & WEBSTER

NUC STEAM SYS SUPPLIER...WESTINGHOUSE

CONSTRUCTOR.....STONE & WEBSTER

TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II

IE RESIDENT INSPECTOR.....M. BRANCH

LICENSING PROJ MANAGER.....L. ENGLE  
DOCKET NUMBER.....50-338

LICENSE & DATE ISSUANCE....NPF-4, APRIL 1, 1978

PUBLIC DOCUMENT ROOM.....ALDERMAN LIBRARY/MANUSCRIPTS DEPT.  
UNIV. OF VIRGINIA/CHARLOTTESVILLE VA 22901  
& LOUISA COUNTY COURTHOUSE,  
LOUISA, VA 23093

I N S P E C T I O N     S T A T U S

INSPECTION SUMMARY

+ INSPECTION OCTOBER 28 - NOVEMBER 1 (85-28): THIS ROUTINE, UNANNOUNCED INSPECTION ENTAILED 17 INSPECTOR-HOURS ON SITE IN THE AREAS OF MODIFICATION TO THE SERVICE WATER INTAKE STRUCTURE. FOUR EXAMPLES OF A VIOLATION OF LICENSEE REQUIREMENTS WERE IDENTIFIED - FAILURE TO CONTROL TEMPERATURE OF CONCRETE TEST CYLINDERS, FAILURE TO CONTROL MOISTURE CONTENT OF SELECT FILL, FAILURE TO MEET SPECIFIED TEST REQUIREMENTS FOR SLUMP, AIR, CONCRETE TEMPERATURE AND AGGREGATES, AND DOCUMENT CORRECT QUANTITIES OF CONCRETE MIX INGREDIENTS ON BATCH TICKETS, AND FAILURE TO HAVE A PROCEDURE WHICH IMPLEMENTS CURRENT SPECIFICATIONS.

INSPECTION JANUARY 6-10 (86-01): THIS ROUTINE, UNANNOUNCED INSPECTION ENTAILED 16 INSPECTOR-HOURS ON SITE IN THE AREAS OF POST-REFUELING STARTUP TESTS AND MODERATOR COEFFICIENT MEASUREMENTS AT POWER. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JANUARY 6-10 (86-02): THIS ROUTINE, UNANNOUNCED INSPECTION ENTAILED 20 INSPECTOR-HOURS AT THE SITE DURING NORMAL DUTY HOURS, IN THE AREAS OF RADIATION PROTECTION INCLUDING TRAINING AND QUALIFICATIONS; EXTERNAL EXPOSURE CONTROL AND PERSONAL DOSIMETRY; CONTROL OF RADIOACTIVE MATERIALS, POSTING AND LABELING; INTERNAL EXPOSURE CONTROL AND ASSESSMENT; AND THE PROGRAM FOR MAINTAINING RADIATION EXPOSURE AS LOW AS REASONABLY ACHIEVABLE (ALARA). NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

Report Period FEB 1986

INSPECTION STATUS - (CONTINUED)

\*\*\*\*\*  
X NORTH ANNA 1 X  
\*\*\*\*\*

ENFORCEMENT SUMMARY

CONTRARY TO 10 CFR 50, APPENDIX B, CRITERION V, AND DESIGN CHANGE 83-32 PROCEDURE USED THROUGH FIELD CHANGE NO. 36, DESIGN CHANGE 83-32 PROCEDURE WAS NOT APPROPRIATE FOR USE THROUGH FIELD CHANGE NO. 36, DATED OCTOBER 12, 1985, IN THAT IT CONTAINED CONFLICTING REQUIREMENTS, RESULTING IN IMPROPER INSTALLATION OF AN ASCO SOLENOID OPERATED VALVE, SOV-BD-100H. THE SOLENOID WAS MOUNTED AT AN APPROXIMATE 45 DEGREES ANGLE TO THE VERTICAL INSTEAD OF IN THE REQUIRED VERTICAL POSITION.  
(8503 4)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

NORMAL OPERATION.

LAST IE SITE INSPECTION DATE: JANUARY 6-10, 1986 +

INSPECTION REPORT NO: 50-338/86-02 +

REPORTS FROM LICENSEE


NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
85-023	12/16/85	01/15/86	INADVERTENT ECCS ACCUMULATOR INJECTION DURING COLD SHUTDOWN. ACCUMULATOR DISCHARGE VALVES WERE REENERGIZED AND THE VALVES AUTOMATICALLY OPENED DUE TO A FALSE SIGNAL.
85-025	12/19/85	01/14/86	PRESSURIZER PORV OPENS IN MODE 5 DURING RCS HEAT UP. THE OPERATOR CAUSED THE RCS PRESSURE TO EXCEED THE LIFT SETTING OF THE PRESSURIZER PORV.
85-027	12/24/85	01/16/86	REACTOR PROTECTION SYSTEM INSTRUMENTATION CHANNELS INOPERABLE. INOPERABILITY WAS DETERMINED TO BE CAUSED BY A CHANGE IN THE RESISTANCE TEMPERATURE DETECTOR.

1. Docket 50-339 OPERATING STATUS  
 2. Reporting Period: 02/01/86 Outage + On-line Hrs: 672.0  
 3. Utility Contact: B. GARNER (703) 894-5151 X2527  
 4. Licensed Thermal Power (MWh): 2775  
 5. Nameplate Rating (Gross MWe): 947  
 6. Design Electrical Rating (Net MWe): 907  
 7. Maximum Dependable Capacity (Gross MWe): 941  
 8. Maximum Dependable Capacity (Net MWe): 893  
 9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE  
 10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_  
 11. Reasons for Restrictions, If Any:  
NONE  
 12. Report Period Hrs      MONTH      YEAR      CUMULATIVE  
672.0      1,416.0      45,672.0  
 13. Hours Reactor Critical      470.6      1,214.6      35,531.9  
 14. Rx Reserve Shtdwn Hrs      201.4      201.4      2,773.5  
 15. Hrs Generator On-Line      470.3      1,214.3      34,646.4  
 16. Unit Reserve Shtdwn Hrs      .0      .0      .0  
 17. Gross Therm Ener (MWH)      1,148,578      3,196,529      90,345,918  
 18. Gross Elec Ener (MWH)      387,374      1,069,667      29,971,849  
 19. Net Elec Ener (MWH)      366,627      1,015,479      28,398,339  
 20. Unit Service Factor      70.0      85.8      75.9  
 21. Unit Avail Factor      70.0      85.8      75.9  
 22. Unit Cap Factor (MDC Net)      61.1      80.3      69.6  
 23. Unit Cap Factor (DER Net)      60.2      79.1      68.6  
 24. Unit Forced Outage Rate      .0      0      11.0  
 25. Forced Outage Hours      .0      .0      4,279.8  
 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE  
 27. If Currently Shutdown Estimated Startup Date: 04/08/86

\*\*\*\*  
 \* NORTH ANNA C \*  
 \*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

NORTH ANNA 2



FEBRUARY 1986

Report Period FEB 1986

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* NORTH ANNA 2 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
86-02	02/20/86	S	201.7	C	4	N2-86-02			COMMENCED RAMPDOWN TO 0% POWER FOR REFUELING OUTAGE. APPROXIMATELY TWENTY MINUTES AFTER UNIT WAS OFF LINE IN MODE 3 THE REACTOR TRIPPED DUE TO A SPIKE ON ONE OF THE SOURCE RANGE NEUTRON DETECTORS. BOTH SOURCE RANGE DETECTORS HAVE BEEN REPLACED.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*

NORTH AN BEGAN A REFUELING OUTAGE FEBRUARY 20.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	Instructions for Preparation of
	C-Refueling	H-Other	Data Entry Sheet
	D-Regulatory Restriction	4-Continued	Licensee Event Report
	E-Operator Training & License Examination	5-Reduced Load	(LER) File (NUREG-0161)
		9-Other	

\*\*\*\*\*  
\* NORTH ANNA 2 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1986

FACILITY DESCRIPTION

LOCATION  
STATE.....VIRGINIA

COUNTY.....LOUISA

DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...40 MI NW OF  
RICHMOND, VA

TYPE OF REACTOR.....PWR

DATE INITIAL CRITICALITY...JUNE 12, 1980

DATE ELEC ENER 1ST GENER...AUGUST 25, 1980

DATE COMMERCIAL OPERATE....DECEMBER 14, 1980

CONDENSER COOLING METHOD...ONCE THRU

CONDENSER COOLING WATER....LAKE ANNA

ELECTRIC RELIABILITY  
COUNCIL.....SOUTHEASTERN ELECTRIC  
RELIABILITY COUNCIL

INSPECTION STATUS

INSPECTION SUMMARY

+ INSPECTION OCTOBER 28 - NOVEMBER 1 (85-28): THIS ROUTINE, UNANNOUNCED INSPECTION ENTAILED 18 INSPECTOR-HOURS ON SITE IN THE AREAS OF MODIFICATION TO THE SERVICE WATER INTAKE STRUCTURE. FOUR EXAMPLES OF A VIOLATION OF LICENSEE REQUIREMENTS WERE IDENTIFIED - FAILURE TO CONTROL TEMPERATURE OF CONCRETE TEST CYLINDERS, FAILURE TO CONTROL MOISTURE CONTENT OF SELECT FILL, FAILURE TO MEET SPECIFIED TEST REQUIREMENTS FOR SLUMP, AIR, CONCRETE TEMPERATURE AND AGGREGATES, AND DOCUMENT CORRECT QUANTITIES OF CONCRETE MIX INGREDIENTS ON BATCH TICKETS, AND FAILURE TO HAVE A PROCEDURE WHICH IMPLEMENTS CURRENT SPECIFICATIONS.

INSPECTION JANUARY 6-10 (86-01): THIS ROUTINE, UNANNOUNCED INSPECTION ENTAILED 16 INSPECTOR-HOURS ON SITE IN THE AREAS OF POST-REFUELING STARTUP TESTS AND MODERATOR COEFFICIENT MEASUREMENTS AT POWER. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JANUARY 6-10 (86-02): THIS ROUTINE, UNANNOUNCED INSPECTION ENTAILED 21 INSPECTOR-HOURS AT THE SITE DURING NORMAL DUTY HOURS, IN THE AREAS OF RADIATION PROTECTION INCLUDING TRAINING AND QUALIFICATIONS; EXTERNAL EXPOSURE CONTROL AND PERSONAL DOSIMETRY; CONTROL OF RADIOACTIVE MATERIALS, POSTING AND LABELING; INTERNAL EXPOSURE CONTROL AND ASSESSMENT; AND THE PROGRAM FOR MAINTAINING RADIATION EXPOSURE AS LOW AS REASONABLY ACHIEVABLE (ALARA). NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

Report Period FEB 1986

I N S P E C T I O N      S T A T U S - (CONTINUED)

\*\*\*\*\*  
X            NORTH ANNA 2  
\*\*\*\*\*

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

- + DIESEL GENERATOR RELIABILITY PROBLEM - LICENSEE IS INVESTIGATING.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

- + REFUELING OUTAGE COMMENCED 2-20-86. ALSO, INSPECTION OF STEAM GENERATORS IS PLANNED.

' AST TE SITE INSPECTION DATE: JANUARY 6-10, 1986 +

INSPECTION REPORT NO: 50-339/86-02 +

R E P O R T S   F R O M   L I C E N S E E


NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
=====			
85-011	09/12/85	11/25/85	NOBLE GAS HIGH RANGE EFFLUENT MONITORS INOPERABLE. THE MICROPROCESSOR KEYBOARD WOULD NOT FUNCTION.
=====			

1. Docket: 50-269 OPERATING STATUS  
 2. Reporting Period: 02/01/86 Outage + On-line Hrs: 672.0  
 3. Utility Contact: J. A. REAVIS (704) 373-7567  
 4. Licensed Thermal Power (MWt): 2568  
 5. Nameplate Rating (Gross MWe): 1038 X 0.9 = 934  
 6. Design Electrical Rating (Net MWe): 887  
 7. Maximum Dependable Capacity (Gross MWe): 899  
 8. Maximum Dependable Capacity (Net MWe): 860  
 9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE  
 10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_  
 11. Reasons for Restrictions, If Any:  
NONE  
 12. Report Period Hrs      MONTH      YEAR      CUMULATIVE  
672.0      1,416.0      110,665.0  
 13. Hours Reactor Critical      300.8      1,040.7      81,487.4  
 14. Rx Reserve Shtdn Hrs      .0      .0      .0  
 15. Hrs Generator On-Line      293.7      1,029.5      78,159.6  
 16. Unit Reserve Shtdn Hrs      .0      .0      .0  
 17. Gross Therm Ener (MWH)      734,654      2,624,291      188,924,491  
 18. Gross Elec Ener (MWH)      255,490      914,950      65,661,790  
 19. Net Elec Ener (MWH)      241,515      872,234      62,270,483  
 20. Unit Service Factor      43.7      72.7      70.6  
 21. Unit Avail Factor      43.7      72.7      70.6  
 22. Unit Cap Factor (MDC Net)      41.8      71.6      65.3\*  
 23. Unit Cap Factor (DER Net)      40.5      69.4      63.5\*  
 24. Unit Forced Outage Rate      1.1      1.1      14.7  
 25. Forced Outage Hours      3.4      11.6      12,551.1  
 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE  
 27. If Currently Shutdown Estimated Startup Date: 04/28/86

\*\*\*\*  
 \* OCONEE 1 \*  
 \*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

OCONEE 1



FEBRUARY 1986

\* Item calculated with a Weighted Average

PAGE 2-220

Report Period FEB 1986

## UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
 \* OCONEE 1 \*  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
1	02/01/86	F	3.4	A	3		EA	CKTBRK	REACTOR TRIP DUE TO MALFUNCTION OF SWITCHYARD BREAKER.
4-P	02/01/86	F	0.0	F	5		RC	FUELXX	QUADRANT POWER TILT EXCEEDED STEADY STATE LIMIT.
5-P	02/01/86	F	0.0	B	5		HH	PUMPXX	HOLDING POWER TO PUT ON (D) HEATER DRAIN PUMPS.
6-P	02/01/86	F	0.0	B	5		HH	PUMPXX	PUT (D) HEATER DRAIN PUMPS IN SERVICE.
7-P	02/01/86	F	0.0	A	5		CH	PUMPXX	HAD DIFFICULTY PLACING (1A) FEEDWATER PUMP IN AUTO.
8-P	02/01/86	F	0.0	F	5		RB	ZZZZZ	APPROACHING ROD WITHDRAWAL CURVES LIMITS.
9-P	02/01/86	F	0.0	H	5		RC	FUELXX	HIGH AXIAL IMBALANCE PROBLEM.
10-P	02/12/86	S	0.0	B	5		RB	ZZZZZ	PERFORM MODERATOR TEMPERATURE PERFORMANCE TEST.
2	02/13/86	S	374.9	C	1		RC	FUELXX	END OF CYCLE 9 REFUELING OUTAGE.

\*\*\*\*\*  
 \* SUMMARY \*  
 \*\*\*\*\*

OCONEE 1 EXPERIENCED 2 OUTAGES AND SEVERAL POWER REDUCTIONS IN FEBRUARY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	Instructions for Preparation of Data Entry Sheet
	C-Refueling	H-Other	4-Continued
	D-Regulatory Restriction		5-Reduced Load
	E-Operator Training		Licensee Event Report
	& License Examination		(LER) File (NUREG-0161)
		9-Other	

\*\*\*\*\*  
\* OCONEE 1 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1986

FACILITY DESCRIPTION

LOCATION  
STATE... SOUTHERN CAROLINA

COUNTY... OCONEE

DIST AND DIRECTION FROM  
NEAREST POPULATION CTR... 30 MI W OF  
GREENVILLE, SC

TYPE OF REACTOR... PWR

DATE INITIAL CRITICALITY... APRIL 19, 1973

DATE ELEC ENER 1ST GENER... MAY 6, 1973

DATE COMMERCIAL OPERATE... JULY 15, 1973

CONDENSER COOLING METHOD... ONCE THRU

CONDENSER COOLING WATER... LAKE KEOWEE

ELECTRIC RELIABILITY  
COUNCIL... SOUTHEASTERN ELECTRIC  
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE... DUKE POWER

CORPORATE ADDRESS... 422 SOUTH CHURCH STREET  
CHARLOTTE, NORTH CAROLINA 28242

CONTRACTOR  
ARCHITECT/ENGINEER... DUKE & BECHTEL

NUC STEAM SYS SUPPLIER... BABCOCK & WILCOX

CONSTRUCTOR... DUKE POWER

TURBINE SUPPLIER... GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE... II

IE RESIDENT INSPECTOR... J. BRYANT

LICENSING PROJ MANAGER... H. NICOLARAS  
DOCKET NUMBER... 50-269

LICENSE & DATE ISSUANCE... DPR-38, FEBRUARY 6, 1973

PUBLIC DOCUMENT ROOM... OCONEE COUNTY LIBRARY  
501 W. SOUTH BROAD ST.  
WALHALLA, SOUTH CAROLINA 29691

I N S P E C T I O N     S T A T U S

INSPECTION SUMMARY

< INSPECTION DECEMBER 10 - JANUARY 13, 1986 (85-41): THIS ROUTINE, ANNOUNCED INSPECTION ENTAILED 74 INSPECTOR-HOURS ON SITE IN THE AREAS OF OPERATIONS, SURVEILLANCE, MAINTENANCE, FACILITY MODIFICATIONS, LER REVIEW, AND RESPONSE TO THE RANCHO SECO EVENT. OF THE SIX AREAS INSPECTED, NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED IN FOUR AREAS; TWO ITEMS OF NONCOMPLIANCE WERE FOUND IN TWO AREAS; FAILURE TO FOLLOW EXEMPT CHANGE PROCEDURE AND FAILURE TO SHUT DOWN REACTOR WITHIN 24 HOURS OF DISCOVERY OF EXCESS LEAKAGE.

INSPECTION DECEMBER 16-20 (85-42): THIS ROUTINE, UNANNOUNCED INSPECTION ENTAILED 12 INSPECTOR-HOURS ON SITE DURING REGULAR HOURS INSPECTING THE RADIATION PROTECTION PROGRAM INCLUDING TRAINING AND QUALIFICATION OF PERSONNEL, INTERNAL AND EXTERNAL EXPOSURE CONTROL, RADIOACTIVE MATERIAL CONTROL, POSTING AND LABELING, AND THE PROGRAM FOR MAINTAINING EXPOSURES AS LOW AS REASONABLY ACHIEVABLE (ALARA). ONE VIOLATION FOR FAILURE TO PROVIDE POSITIVE ACCESS CONTROL FOR TWO HIGH RADIATION AREAS.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

Report Period FEB 1986

I N S P E C T I O N      S T A T U S - (CONTINUED)

\*\*\*\*\*  
\*            OCONEE 1            \*  
\*\*\*\*\*

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

POWER OPERATION.

LAST IE SITE INSPECTION DATE: DECEMBER 10, 1985 - JANUARY 13, 1986 +

INSPECTION REPORT NO: 50-269/85-41 +

R E P O R T S   F R O M   L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
--------	------------------	-------------------	---------

=====

NONE.


=====

1. Docket: 50-270 OPERATING STATUS  
 2. Reporting Period: 02/01/86 Outage + On-line Hrs: 672.0  
 3. Utility Contact: J. A. REAVIS (704) 373-7567  
 4. Licensed Thermal Power (MWh): 2568  
 5. Nameplate Rating (Gross MWe): 1038 X 0.9 = 934  
 6. Design Electrical Rating (Net MWe): 887  
 7. Maximum Dependable Capacity (Gross MWe): 899  
 8. Maximum Dependable Capacity (Net MWe): 860  
 9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE  
 10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_  
 11. Reasons for Restrictions, If Any:  
NONE  
 12. Report Period Hrs 672.0 MONTH 672.0 YEAR 1,416.0 CUMULATIVE 100,585.0  
 13. Hours Reactor Critical 667.2  
 14. Rx Reserve Shtdwn Hrs .0  
 15. Hrs Generator On-Line 663.4  
 16. Unit Reserve Shtdwn Hrs .0  
 17. Gross Therm Ener (MWH) 1,675,774  
 18. Gross Elec Ener (MWH) 574,360  
 19. Net Elec Ener (MWH) 549,664  
 20. Unit Service Factor 98.7  
 21. Unit Avail Factor 98.7  
 22. Unit Cap Factor (MDC Net) 95.1  
 23. Unit Cap Factor (DER Net) 92.2  
 24. Unit Forced Outage Rate 1.3  
 25. Forced Outage Hours 8.6  
 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE  
 27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\* OCONEE 2 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

OCONEE 2



FEBRUARY 1986

\* Item calculated with a Weighted Average

PAGE 2-224

Report Period FEB 1986

## UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
 \* OCONEE 2  
 \*  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
1	02/01/86	F	0.1	A	3		EA	CKTBRK	GENERATOR BREAKER MALFUNCTION DURING TRANSMISSIONS TEST.
2-P	02/01/86	F	0.0	B	5		HG	ZZZZZZ	HIGH CONDENSATE FLOW WITH ONLY 3 POWDEX CELLS AVAILABLE.
3-P	02/01/86	F	0.0	B	5		HG	ZZZZZZ	LIMITED BY CONDENSATE FLOW WITH 3 POWDEX CELLS.
4-P	02/01/86	F	0.0	B	5		HG	ZZZZZZ	LIMITED BY CONDENSATE FLOW THROUGH 4 POWDEX CELLS.
2	02/04/86	F	8.5	A	3		IA	INSTRU	REACTOR TRIP DURING REACTOR PROTECTION SYSTEM TESTING.
5-P	02/05/86	F	0.0	H	5		HH	ZZZZZZ	STOPPED REACTOR POWER INCREASE DUE TO FEEDWATER SWINGS.
6-P	02/05/86	F	0.0	H	5		RB	FUELXX	STOPPED REACTOR POWER INCREASE DUE TO IMBALANCE.
7-P	02/18/86	F	0.0	A	5		RB	INSTRU	ASSYMETRIC ROD RUNBACK CIRCUITRY PROBLEM.
8-P	02/18/86	F	0.0	A	5		RB	INSTRU	ASSYMETRIC ROD RUNBACK CIRCUITRY PROBLEM.
9-P	02/18/86	F	0.0	A	5		RB	INSTRU	ASSYMETRIC ROD RUNBACK CIRCUITRY PROBLEM.

\*\*\*\*\*  
 \* OCONEE 2 OPERATED IN FEBRUARY WITH 2 SHUTDOWNS AND SEVERAL POWER REDUCTIONS.  
 \* SUMMARY \*  
 \*\*\*\*\*

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	Instructions for Preparation of Data Entry Sheet
	C-Refueling	H-Other	
	D-Regulatory Restriction	3-Manual Scram	
	E-Operator Training & License Examination	4-Continued	
		5-Reduced Load	
		9-Other	Licensor Event Report (LER) File (NUREG-0161)

\*\*\*\*\*  
\* OCONEE 2 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1986

FACILITY DESCRIPTION

LOCATION STATE.....SOUTH CAROLINA  
COUNTY.....OCONEE  
DIST AND DIRECTION FROM NEAREST POPULATION CTR...30 MI W OF GREENVILLE, SC  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...NOVEMBER 11, 1973  
DATE ELEC ENER 1ST GENER...DECEMBER 5, 1973  
DATE COMMERCIAL OPERATE....SEPTEMBER 9, 1974  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER....LAKE KEOWEE  
ELECTRIC RELIABILITY COUNCIL.....SOUTHEASTERN ELECTRIC RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY LICENSEE.....DUKE POWER  
CORPORATE ADDRESS.....422 SOUTH CHURCH STREET CHARLOTTE, NORTH CAROLINA 28242  
CONTRACTOR ARCHITECT/ENGINEER.....DUKE & BECHTEL  
NUC STEAM SYS SUPPLIER...BABCOCK & WILCOX  
CONSTRUCTOR.....DUKE POWER  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II  
IE RESIDENT INSPECTOR.....J. BRYANT  
LICENSING PROJ MANAGER.....H. NICOLARAS  
DOCKET NUMBER.....50-270  
LICENSE & DATE ISSUANCE....DPR-47, OCTOBER 6, 1973  
PUBLIC DOCUMENT ROOM.....OCONEE COUNTY LIBRARY  
501 W. SOUTH BROAD ST.  
WALHALLA, SOUTH CAROLINA 29691

I N S P E C T I O N     S T A T U S

INSPECTION SUMMARY

+ INSPECTION DECEMBER 10 - JANUARY 13, 1986 (85-41): THIS ROUTINE, ANNOUNCED INSPECTION ENTAILED 75 INSPECTOR-HOURS ON SITE IN THE AREAS OF OPERATIONS, SURVEILLANCE, MAINTENANCE, FACILITY MODIFICATIONS, LER REVIEW, AND RESPONSE TO THE RANCHO SECO EVENT. OF THE SIX AREAS INSPECTED, NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED IN FOUR AREAS; TWO ITEMS OF NON COMPLIANCE WERE FOUND IN TWO AREAS; FAILURE TO FOLLOW EXEMPT CHANGE PROCEDURE AND FAILURE TO SHUT DOWN REACTOR WITHIN 24 HOURS OF DISCOVERY OF EXCESS LEAKAGE.

INSPECTION DECEMBER 16-20 (85-42): THIS ROUTINE, UNANNOUNCED INSPECTION ENTAILED 13 INSPECTOR-HOURS ON SITE DURING REGULAR HOURS INSPECTING THE RADIATION PROTECTION PROGRAM INCLUDING TRAINING AND QUALIFICATION OF PERSONNEL, INTERNAL AND EXTERNAL EXPOSURE CONTROL, RADIOACTIVE MATERIAL CONTROL, POSTING AND LABELING, AND THE PROGRAM FOR MAINTAINING EXPOSURES AS LOW AS REASONABLY ACHIEVABLE (ALARA). ONE VIOLATION FOR FAILURE TO PROVIDE POSITIVE ACCESS CONTROL FOR TWO HIGH RADIATION AREAS.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

Report Period FEB 1986

I N S P E C T I O N     S T A T U S - (CONTINUED)

\*\*\*\*\*  
\*            OCONEE 2            \*  
\*\*\*\*\*

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

POWER OPERATION.

LAST IE SITE INSPECTION DATE: DECEMBER 10, 1985 - JANUARY 13, 1986 +

INSPECTION REPORT NO: 50-270/85-41 +


R E P O R T S   F R O M   L I C E N S E E

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
85-007	11/05/85	12/04/85	FIRE WATCH PATROL NOT ESTABLISHED WHILE FIRE DETECTOR STRING WAS INOPERABLE. CAUSE - INADEQUATE OPERATOR TRAINING.
85-008	12/14/85	01/10/86	REACTOR SHUTDOWN BECAUSE OF REACTOR COOLANT SYSTEM LEAKAGE GREATER THAN 1 GPM. CAUSE - INSTRUMENT ROOT VALVE PACKING GLAND FAILURE.
85-009	12/19/85	01/15/86	UNIT VENT RADIATION MONITOR INOPERABLE WITHOUT ESTABLISHING MANUAL SAMPLING. CAUSE - PERSONNEL ERROR.

1. Docket: 50-287 OPERATING STATUS  
 2. Reporting Period: 02/01/86 Outage + On-line Hrs: 672.0  
 3. Utility Contact: J. A. REAVIS (704) 373-7567  
 4. Licensed Thermal Power (MWh): 2568  
 5. Nameplate Rating (Gross MWe): 1038 X 0.9 = 934  
 6. Design Electrical Rating (Net MWe): 887  
 7. Maximum Dependable Capacity (Gross MWe): 899  
 8. Maximum Dependable Capacity (Net MWe): 860  
 9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE  
 10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_  
 11. Reasons for Restrictions, If Any:  
NONE  
 12. Report Period Hrs 672.0 MONTH 672.0 YEAR 1,416.0 CUMULATIVE 98,232.0  
 13. Hours Reactor Critical 672.0 1,412.8 70,784.3  
 14. Rx Reserve Shtdwn Hrs .0 .0 .0  
 15. Hrs Generator On-Line 672.0 1,392.3 69,525.5  
 16. Unit Reserve Shtdwn Hrs .0 .0 .0  
 17. Gross Therm Ener (MWH) 1,725,080 3,540,142 170,208,587  
 18. Gross Elec Ener (MWH) 596,900 1,229,830 58,757,884  
 19. Net Elec Ener (MWH) 572,832 1,179,189 55,958,546  
 20. Unit Service Factor 100.0 98.3 70.8  
 21. Unit Avail Factor 100.0 98.3 70.8  
 22. Unit Cap Factor (MDC Net) 99.1 96.8 66.1\*  
 23. Unit Cap Factor (DER Net) 96.1 93.9 64.3\*  
 24. Unit Forced Outage Rate .0 1.7 14.3  
 25. Forced Outage Hours .0 23.7 11,789.1  
 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE  
 27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\* OCONEE 3 \*\*\*\*  
 \*\*\*\* OCONEE 3 \*\*\*\*  
 AVERAGE DAILY POWER LEVEL (MWe) PIPT

### OCONEE 3



FEBRUARY 1986

\* Item calculated with a Weighted Average

Report Period FEB 1986

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* OCONEE 3 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
3-P	02/01/86	S	0.0	F	5		ZZ	ZZZZZ	DISPATCHER HOLD.
4-P	02/28/86	S	0.0	B	5		CC	VALVEX	TURBINE VALVE MOVEMENT PT'S.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*

OCONEE 3 OPERATED ROUTINELY IN FEBRUARY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	1-Manual
S-Sched	B-Maint or Test	G-Oper Error	2-Manual Scram
	C-Refueling	H-Other	3-Auto Scram
	D-Regulatory Restriction		4-Continued
	E-Operator Training & License Examination		5-Reduced Load
			9-Other
			Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161)

\*\*\*\*\*  
\* OCONEE 3 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1986

FACILITY DESCRIPTION

LOCATION  
STATE.....SOUTH CAROLINA

COUNTY.....OCONEE

DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...30 MI W OF  
GREENVILLE, SC

TYPE OF REACTOR.....PWR

DATE INITIAL CRITICALITY...SEPTEMBER 5, 1974

DATE ELEC ENER 1ST GENER...SEPTEMBER 18, 1974

DATE COMMERCIAL OPERATE...DECEMBER 16, 1974

CONDENSER COOLING METHOD...ONCE THRU

CONDENSER COOLING WATER....LAKE KEOWEE

ELECTRIC RELIABILITY  
COUNCIL.....SOUTHEASTERN ELECTRIC  
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....DUKE POWER

CORPORATE ADDRESS.....422 SOUTH CHURCH STREET  
CHARLOTTE, NORTH CAROLINA 28242

CONTRACTOR  
ARCHITECT/ENGINEER.....DUKE & BECHTEL

NUC STEAM SYS SUPPLIER...BABCOCK & WILCOX

CONSTRUCTOR.....DUKE POWER

TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II

IE RESIDENT INSPECTOR.....J. BRYANT

LICENSING PROJ MANAGER.....H. NICOLARAS  
DOCKET NUMBER.....50-287

LICENSE & DATE ISSUANCE....DPR-55, JULY 19, 1974

PUBLIC DOCUMENT ROOM.....OCONEE COUNTY LIBRARY  
501 W. SOUTH BROAD ST.  
HALHALLA, SOUTH CAROLINA 29691

I N S P E C T I O N     S T A T U S

INSPECTION SUMMARY

+ INSPECTION DECEMBER 10 - JANUARY 13, 1986 (85-41): THIS ROUTINE, ANNOUNCED INSPECTION ENTAILED 75 INSPECTOR-HOURS ON SITE IN THE AREAS OF OPERATIONS, SURVEILLANCE, MAINTENANCE, FACILITY MODIFICATIONS, LER REVIEW, AND RESPONSE TO THE RANCHO SECO EVENT. OF THE SIX AREAS INSPECTED, NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED IN FOUR AREAS; TWO ITEMS OF NONCOMPLIANCE WERE FOUND IN TWO AREAS; FAILURE TO FOLLOW EXEMPT CHANGE PROCEDURE AND FAILURE TO SHUT DOWN REACTOR WITHIN 24 HOURS OF DISCOVERY OF EXCESS LEAKAGE.

INSPECTION DECEMBER 16-20 (85-42): THIS ROUTINE, UNANNOUNCED INSPECTION ENTAILED 13 INSPECTOR-HOURS ON SITE DURING REGULAR HOURS INSPECTING THE RADIATION PROTECTION PROGRAM INCLUDING TRAINING AND QUALIFICATION OF PERSONNEL, INTERNAL AND EXTERNAL EXPOSURE CONTROL, RADIOACTIVE MATERIAL CONTROL, POSTING AND LABELING, AND THE PROGRAM FOR MAINTAINING EXPOSURES AS LOW AS REASONABLY ACHIEVABLE (ALARA). ONE VIOLATION FOR FAILURE TO PROVIDE POSITIVE ACCESS CONTROL FOR TWO HIGH RADIATION AREAS.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

Report Period FEB 1986

I N S P E C T I O N      S T A T U S - (CONTINUED)

\*\*\*\*\*  
\*           OCONEE 3           \*  
\*\*\*\*\*

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

POWER OPERATION.

LAST IE SITE INSPECTION DATE: DECEMBER 10, 1985 - JANUARY 13, 1986 +

INSPECTION REPORT NO: 50-287/85-41 +


R E P O R T S   F R O M   L I C E N S E E

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
85-004	10/17/85	11/15/85	MISSSED HYDROGEN CONCENTRATION SAMPLING OF ISOLATED GWD TANK. DUE TO PERSONNEL ERROR.
85-005	10/24/85	11/22/85	ANTICIPATORY REACTOR TRIP ON LOSS OF MAIN FEEDWATER. CAUSE - FAILURE OF THE REGULATOR VALVE TO FUNCTION PROPERLY.

1. Docket: 50-219 OPERATING STATUS  
 2. Reporting Period: 02/01/86 Outage + On-line Hrs: 672.0  
 3. Utility Contact: JOSEPH R. MOLNAR (609) 971-4699  
 4. Licensed Thermal Power (MWh): 1930  
 5. Nameplate Rating (Gross MWe): 722 X .9 = 650  
 6. Design Electrical Rating (Net MWe): 650  
 7. Maximum Dependable Capacity (Gross MWe): 650  
 8. Maximum Dependable Capacity (Net MWe): 620  
 9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE  
 10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_  
 11. Reasons for Restrictions, If Any:  
NONE  
 12. Report Period Hrs      MONTH      YEAR      CUMULATIVE  
672.0      1,416.0      141,888.0  
 13. Hours Reactor Critical      672.0      1,416.0      94,558.4  
 14. Rx Reserve Shtdwn Hrs      .0      .0      759.5  
 15. Hrs Generator On-Line      672.0      1,416.0      91,474.1  
 16. Unit Reserve Shtdwn Hrs      .0      .0      1,308.6  
 17. Gross Therm Ener (MWH)      1,242,000      2,648,000      151,602,000  
 18. Gross Elec Ener (MWH)      420,780      899,170      51,189,855  
 19. Net Elec Ener (MWH)      405,019      865,876      49,176,369  
 20. Unit Service Factor      100.0      100.0      64.5  
 21. Unit Avail Factor      100.0      100.0      65.4  
 22. Unit Cap Factor (MDC Net)      97.2      98.6      55.9\*  
 23. Unit Cap Factor (DER Net)      92.7      94.1      53.3  
 24. Unit Forced Outage Rate      .0      .0      12.3  
 25. Forced Outage Hours      .0      .0      10,905.2  
 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
REFUELING, APRIL 12, 1986, 6 MONTHS.  
 27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\* OYSTER CREEK 1 \*  
\*\*\*\*\*  
AVERAGE DAILY POWER LEVEL (MWe) PLOT

OYSTER CREEK 1



FEBRUARY 1986

\* Item calculated with a Weighted Average

Report Period FEB 1986

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* OYSTER CREEK 1 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
	02/21/86	F	0.0	A	5				FEB. 12: REDUCED PLANT LOAD FROM 620 MWE TO 473 MWE (23.7% LOAD REDUCTION) TO REPAIR A TUBE LEAK IN "A" NORTH CONDENSER.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	Instructions for
	C-Refueling	H-Other	Preparation of
	D-Regulatory Restriction		Data Entry Sheet
	E-Operator Training	4-Continued	Licensor Event Report
	& License Examination	5-Reduced Load	(LER) File (NUREG-0161)
		9-Other	

\*\*\*\*\*  
\* OYSTER CREEK 1 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1986

FACILITY DESCRIPTION

LOCATION  
STATE.....NEW JERSEY  
COUNTY.....OCEAN  
  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...9 MI S OF  
TOMS RIVER, NJ  
  
TYPE OF REACTOR.....BWR  
  
DATE INITIAL CRITICALITY...MAY 3, 1969  
  
DATE ELEC ENER 1ST GENER...SEPTEMBER 23, 1969  
  
DATE COMMERCIAL OPERATE....DECEMBER 1, 1969  
  
CONDENSER COOLING METHOD...ONCE THRU  
  
CONDENSER COOLING WATER....BARNEGAT BAY  
  
ELECTRIC RELIABILITY  
COUNCIL.....MID-ATLANTIC  
AREA COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....GPU NUCLEAR CORPORATION  
  
CORPORATE ADDRESS.....100 INTERPACE PARKWAY  
PARSIPPANY, NEW JERSEY 07054  
  
CONTRACTOR  
ARCHITECT/ENGINEER.....BURNS & ROE  
  
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC  
  
CONSTRUCTOR.....BURNS & ROE  
  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I  
  
IE RESIDENT INSPECTOR.....W. BATEMAN  
  
LICENSING PROJ MANAGER.....J. DONOHEW  
DOCKET NUMBER.....50-219  
  
LICENSE & DATE ISSUANCE....DPR-16, AUGUST 1, 1969  
  
PUBLIC DOCUMENT ROOM.....OCEAN COUNTY LIBRARY  
101 WASHINGTON STREET  
TOMS RIVER, NEW JERSEY 08753

I N S P E C T I O N     S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

Report Period FEB 1986

I N S P E C T I O N      S T A T U S - (CONTINUED)

\*\*\*\*\*  
\*            OYSTER CREEK 1        \*  
\*\*\*\*\*

OTHER ITEMS

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S   F R O M   L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
NO INPUT PROVIDED.			


=====

1. Docket: 50-255 OPERATING STATUS  
 2. Reporting Period: 02/01/86 Outage + On-line Hrs: 672.0  
 3. Utility Contact: P. A. SMITH (616) 764-8913  
 4. Licensed Thermal Power (MWe): 2530  
 5. Nameplate Rating (Gross MWe): 955 X 0.85 = 812  
 6. Design Electrical Rating (Net MWe): 805  
 7. Maximum Dependable Capacity (Gross MWe): 770  
 8. Maximum Dependable Capacity (Net MWe): 730  
 9. If Changes Occur Above Since Last Report, Give Reasons:  
ITEM 6 & 7 ARE REVISED  
 10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_  
 11. Reasons for Restrictions, If Any: \_\_\_\_\_  
NONE  
 12. Report Period Hrs      MONTH      YEAR      CUMULATIVE  
                              672.0      1,416.0      124,455.0  
 13. Hours Reactor Critical      .9      .9      68,309.3  
 14. Rx Reserve Shtdwn Hrs      .0      .0      .0  
 15. Hrs Generator On-Line      .0      .0      64,959.2  
 16. Unit Reserve Shtdwn Hrs      .0      .0      .0  
 17. Gross Therm Ener (MWH)      0      0      135,602,040  
 18. Gross Elec Ener (MWH)      0      0      42,217,400  
 19. Net Elec Ener (MWH)      0      0      39,741,360  
 20. Unit Service Factor      .0      .0      52.2  
 21. Unit Avail Factor      .0      .0      52.2  
 22. Unit Cap Factor (MDC Net)      .0      .0      43.7  
 23. Unit Cap Factor (DER Net)      .0      .0      39.7  
 24. Unit Forced Outage Rate      .0      .0      31.3  
 25. Forced Outage Hours      .0      .0      15,556.1  
 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE  
 27. If Currently Shutdown Estimated Startup Date: 03/03/86

\*\*\*\*\*  
\* PALISADES \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

PALISADES



FEBRUARY 1986

Report Period FEB 1986

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* PALISADES \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System Component	Cause & Corrective Action to Prevent Recurrence
1	11/30/85	S	672.0	C	4		RC FUELXX	REFUELING AND MAINTENANCE OUTAGE CONTINUES.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*

PALISADES REMAINS SHUT DOWN FOR REFUELING.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	Instructions for
	C-Refueling	H-Other	Preparation of
	D-Regulatory Restriction		Data Entry Sheet
	E-Operator Training & License Examination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Licensee Event Report (LER) File (NUREG-0161)

\*\*\*\*\*  
\* PALISADES \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1986

FACILITY DESCRIPTION

LOCATION STATE..... MICHIGAN

COUNTY..... VANBUREN

DIST AND DIRECTION FROM  
NEAREST POPULATION CTR... 5 MI S OF  
SOUTH HAVEN, MI

TYPE OF REACTOR..... PWR

DATE INITIAL CRITICALITY... MAY 24, 1971

DATE ELEC ENER 1ST GENER... DECEMBER 31, 1971

DATE COMMERCIAL OPERATE.... DECEMBER 31, 1971

CONDENSER COOLING METHOD... COOLING TOWERS

CONDENSER COOLING WATER.... LAKE MICHIGAN

ELECTRIC RELIABILITY  
COUNCIL..... EAST CENTRAL AREA  
RELIABILITY COORDINATION  
AGREEMENT

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE..... CONSUMERS POWER

CORPORATE ADDRESS..... 212 WEST MICHIGAN AVENUE  
JACKSON, MICHIGAN 49201

CONTRACTOR  
ARCHITECT/ENGINEER..... BECHTEL

NUC STEAM SYS SUPPLIER... COMBUSTION ENGINEERING

CONSTRUCTOR..... BECHTEL

TURBINE SUPPLIER..... WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE..... III

IE RESIDENT INSPECTOR..... E. SWANSON

LICENSING PROJ MANAGER..... T. WAMBACH  
DOCKET NUMBER..... 50-255

LICENSE & DATE ISSUANCE.... DPR-20, OCTOBER 16, 1972

PUBLIC DOCUMENT ROOM..... VAN ZOEREN LIBRARY  
HOPE COLLEGE  
HOLLAND, MICHIGAN

49423 49007

I N S P E C T I O N     S T A T U S

INSPECTION SUMMARY

INSPECTION ON NOVEMBER 19 THROUGH DECEMBER 23 (85030): ROUTINE, UNANNOUNCED INSPECTION BY RESIDENT INSPECTORS OF OPERATIONAL SAFETY; MAINTENANCE; SURVEILLANCE; ENGINEERED SAFETY FEATURES WALKDOWN; REPORTABLE EVENTS; HEADQUARTERS REQUESTS AND REGIONAL REQUESTS. THE INSPECTION INVOLVED A TOTAL OF 186 INSPECTOR-HOURS ONSITE BY TWO NRC INSPECTORS INCLUDING 35 INSPECTOR-HOURS ON SITE DURING OFF-SHIFTS. OF THE AREAS INSPECTED ONE VIOLATION WAS IDENTIFIED FOR LATE REPORTING OF THE IDENTIFICATION OF DEGRADATION OF CONTAINMENT INTEGRITY DURING LOCAL LEAKRATE TESTING.

INSPECTION ON DECEMBER 3-5 AND 16-20 (85031): ROUTINE ANNOUNCED INSPECTION OF LICENSEE ACTIONS ON PREVIOUS INSPECTION FINDINGS, REACTOR COOLANT SYSTEM LEAK RATE TESTING, REFUELING PREPARATIONS, REFUELING ACTIVITIES, SPENT FUEL POOL ACTIVITIES, AND LICENSEE ACTIONS REGARDING IE BULLETIN 84-03. THE INSPECTION INVOLVED A TOTAL OF 57 INSPECTOR-HOURS ONSITE BY ONE NRC INSPECTOR. THE INSPECTION WAS CONDUCTED IN ACCORDANCE WITH INSPECTION PROCEDURES 61728, 92701, 60705, 60710, 86700, 92703, AND 30703. IN THE FIVE AREAS INSPECTED, ONE VIOLATION WAS IDENTIFIED (FAILURE TO FOLLOW PROCEDURES).

INSPECTION ON DECEMBER 16-19 (85033): SPECIAL, UNANNOUNCED INSPECTION OF THE FOLLOWING AREAS OF THE EMERGENCY PREPAREDNESS PROGRAM: EMERGENCY DETECTION AND CLASSIFICATION; NOTIFICATIONS AND COMMUNICATIONS; AND TRAINING RELATED TO THE LICENSEE'S COMMITMENTS TO IMPROVE THEIR EMERGENCY PREPAREDNESS PROGRAM, PARTICULARLY THOSE AREAS DEFINED AS A RESULT OF THE AUGUST 20, 1985 ANNUAL EMERGENCY EXERCISE. THE INSPECTION INVOLVED 73 INSPECTOR-HOURS ONSITE BY TWO NRC INSPECTORS. NO VIOLATIONS, DEFICIENCIES OR DEVIATIONS WERE IDENTIFIED AS A RESULT OF THIS INSPECTION.

Report Period FEB 1986

INSPECTION STATUS - (CONTINUED)

\*\*\*\*\*  
\* PALISADES \*  
\*\*\*\*\*

ENFORCEMENT SUMMARY

10 CFR 50.72 (B)(2)(I) REQUIRES REPORTING WITHIN FOUR HOURS, AN EVENT DISCOVERED DURING PLANT SHUTDOWN CONDITIONS, WHICH HAD IT BEEN FOUND DURING REACTOR OPERATION, WOULD HAVE CONSTITUTED SERIOUS DEGRADATION OF PRINCIPAL SAFETY BARRIERS. TECHNICAL SPECIFICATION 4.5.2 REQUIRES CONTAINMENT LOCAL LEAKRATES TO BE LESS THAN 0.6LA (65,200 SCCM). CONTRARY TO THE ABOVE, TESTING PERFORMED ON DECEMBER 4, 1985, DETERMINED THAT THE LOCAL LEAKRATE FOR A CONTAINMENT PENETRATION (78,913 SCCM) EXCEEDED 0.60LA, THE ALLOWABLE LEAKAGE VALUE, AND THIS WAS NOT REPORTED TO THE NRC UNTIL DECEMBER 16, 1985. (8503 5)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

ENTERED A REFUELING OUTAGE ON 11/30/85.

LAST IE SITE INSPECTION DATE: JANUARY 26 - 28, 1986

INSPECTION REPORT NO: 86009

Report Period FEB 1986

R E P O R T S   F R O M   L I C E N S E E

\*\*\*\*\*  
\*           PALISADES   \*  
\*\*\*\*\*

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
85-27	12/05/85	01/03/86	TERMINAL BLOCK IN RPS CIRCUIT
85-28	12/10/85	01/09/86	SAFETY INJECTION SYSTEM ACTUATION
85-29	12/16/85	01/15/86	FAILED LOCAL LEAK RATE TEST ON CONTAINMENT PENETRATION
85-30	12/23/85	01/22/86	INADVERTENT CONTAINMENT ISOLATION ACTUATION
85-31	12/28/85	01/27/86	AUTO START OF 1-2 DIESEL GENERATOR
86-01	01/06/86	01/27/86	RADIOACTIVE WASTE SHIPMENT
86-02	01/02/86	02/03/86	MISSILE SHIELD LIFT DEVICE OUTSIDE SAFE WORKING LOAD REQUIREMENT


THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-528 OPERATING STATUS  
 2. Reporting Period: 02/01/86 Outage + On-line Hrs: 384.0  
 3. Utility Contact: MARY P. RICHARDSON (602) 932-5300  
 4. Licensed Thermal Power (MWT): 3800  
 5. Nameplate Rating (Gross MWe): 1403  
 6. Design Electrical Rating (Net MWe): 1270  
 7. Maximum Dependable Capacity (Gross MWe): 1282  
 8. Maximum Dependable Capacity (Net MWe): 1200  
 9. If Changes Occur Above Since Last Report, Give Reasons:  
 \_\_\_\_\_  
 10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_  
 11. Reasons for Restrictions, If Any: \_\_\_\_\_  
 NONE  
 12. Report Period Hrs MONTH 384.0 YEAR 384.0 CUMULATIVE 384.0  
 13. Hours Reactor Critical 384.0 384.0 384.0  
 14. Rx Reserve Shtdwn Hrs .0 .0 .0  
 15. Hrs Generator On-Line 384.0 384.0 384.0  
 16. Unit Reserve Shtdwn Hrs .0 .0 .0  
 17. Gross Therm Ener (MWH) 1,446,400 1,446,400 1,446,400  
 18. Gross Elec Ener (MWH) 499,700 499,700 499,700  
 19. Net Elec Ener (MWH) 470,464 470,464 470,464  
 20. Unit Service Factor 100.0 100.0 100.0  
 21. Unit Avail Factor 100.0 100.0 100.0  
 22. Unit Cap Factor (MDC Net) 102.1 102.1 102.1  
 23. Unit Cap Factor (DER Net) 96.5 96.5 96.5  
 24. Unit Forced Outage Rate .0 .0 .0  
 25. Forced Outage Hours .0 .0 .0  
 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
 SURV. TEST OUTAGE - 3/86, 49 DAYS.  
 27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*  
 \* PALO VERDE 1 \*  
 \*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

PALO VERDE 1



FEBRUARY 1986

Report Period FEB 1986

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* PALO VERDE 1 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System Component	Cause & Corrective Action to Prevent Recurrence
-----	------	------	-------	--------	--------	------------	------------------	---

NONE

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
PALO VERDE DECLARED COMMERCIAL OPERATION ON FEBRUARY 13, 1986.

Type	Reason	Method	System & Component	
F-Forced	A-Equip Failure	F-Admin	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	2-Manual Scram	Instructions for
	C-Refueling	H-Other	3-Auto Scram	Preparation of
	D-Regulatory Restriction		4-Continued	Data Entry Sheet
	E-Operator Training		5-Reduced Load	Licensee Event Report
	& License Examination		9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* PALO VERDE 1 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1986

FACILITY DESCRIPTION

LOCATION  
STATE.....ARIZONA  
COUNTY.....MARICOPA  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...36 MI W OF  
PHOENIX, AZ  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...MAY 25, 1985  
DATE ELEC ENER 1ST GENER...JUNE 10, 1985  
DATE COMMERCIAL OPERATE....FEBRUARY 13, 1986  
CONDENSER COOLING METHOD...TREATED SEWAGE  
CONDENSER COOLING WATER....SEWAGE TREATMENT  
ELECTRIC RELIABILITY  
COUNCIL.....WESTERN SYSTEMS  
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....ARIZONA PUBLIC SERVICE  
CORPORATE ADDRESS.....P.O. BOX 21666  
PHOENIX, ARIZONA 85036

CONTRACTOR  
ARCHITECT/ENGINEER.....BECHTEL  
NUC STEAM SYS SUPPLIER...COMBUSTION ENGINEERING  
CONSTRUCTOR.....BECHTEL  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....V  
IE RESIDENT INSPECTOR.....R. ZIMMERMAN  
LICENSING PROJ MANAGER.....E. LICITRA  
DOCKET NUMBER.....50-528  
LICENSE & DATE ISSUANCE....NPF-41, JUNE 1, 1985  
PUBLIC DOCUMENT ROOM.....MS STEFANIE MORITZ  
DOCUMENTS LIBRARIAN  
PHOENIX PUBLIC LIBRARY  
12 EAST McDOWELL ROAD  
PHOENIX, ARIZONA 85004

I N S P E C T I O N     S T A T U S

INSPECTION SUMMARY

+ INSPECTION ON SEPTEMBER 16 , 1985 - FEBRUARY 1, 1986 (REPORT NO. 50-528/85/36) YEARLY SYSTEMATIC ASSESSMENT OF LICENSEE PERFORMANCE. REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

+ INSPECTION ON DECEMBER 27, 1985 - FEBRUARY 2, 1986 (REPORT NO. 50-528/86-02) AREAS INSPECTED: ROUTINE, ONSITE INSPECTION BY THE THREE RESIDENT INSPECTORS. AREAS INSPECTED INCLUDED: FOLLOWUP OF PREVIOUSLY IDENTIFIED ITEM; REVIEW OF PLANT ACTIVITIES; ENGINEERED SAFETY SYSTEM WALKDOWNS; SURVEILLANCE TESTING; MAINTENANCE; PWR ASCENSION TEST WITNESSING; PERSONNEL ERRORS; LICENSEE EVENT REPORT FOLLOWUP; PERIODIC AND SPECIAL REPORT REVIEW; AND PLANT TOURS. DURING THIS INSPECTION, VARIOUS INSPECTION PROCEDURES WERE UTILIZED. THE INSPECTION INVOLVED 200 INSPECTOR-HOURS ONSITE BY THREE RESIDENT NRC INSPECTORS.

RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

+ INSPECTION ON FEBRUARY 3 - MARCH 9, 1986 (REPORT NO. 50-528/86-05) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

+ INSPECTION ON JANUARY 26 - FEBRUARY 25, 1986 (REPORT NO. 50-528/86-06) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

+ INSPECTION ON FEBRUARY 11 - MARCH 4, 1986 (REPORT NO. 50-528/86-07) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

Report Period FEB 1986

INSPECTION STATUS - (CONTINUED)

\*\*\*\*\*  
X PALO VERDE 1  
\*\*\*\*\*

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

MICROBIOLOGICAL INDUCED CORROSION ISSUE IN SPRAY POND IS BEING RESOLVED BY NRR. AUXILIARY SPRAY SYSTEM SAFETY GRADE ISSUE IS BEING RESOLVED BY NRR.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

ANNUAL SALP BOARD MEETING HELD ON NOVEMBER 14, 1985; SALP REPORT TRANSMITTED TO THE LICENSEE ON DECEMBER 19, 1985.

PLANT STATUS:

THE PLANT ACHIEVED INITIAL CRITICALITY ON MAY 25, 1985. THE PLANT ACHIEVED 100% POWER ON DECEMBER 9, 1985. POWER ASCENSION TEST IS COMPLETED. COMMERCIAL OPERATION WAS DECLARED ON FEBRUARY 13, 1986.

LAST IE SITE INSPECTION DATE: 02/03-03/09/86+

INSPECTION REPORT NO: 50-528/86-05+


R E P O R T S   F R O M   L I C E N S E E

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
--------	---------------	----------------	---------

-----  
NONE

1. Docket: 50-277 OPERATING STATUS  
 2. Reporting Period: 02/01/86 Outage + On-line Hrs: 672.0  
 3. Utility Contact: W. M. Alden (215) 841-5022  
 4. Licensed Thermal Power (MWh): 3293  
 5. Nameplate Rating (Gross MWe): 1280 X 0.9 = 1152  
 6. Design Electrical Rating (Net MWe): 1065  
 7. Maximum Dependable Capacity (Gross MWe): 1098  
 8. Maximum Dependable Capacity (Net MWe): 1051  
 9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE  
 10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_  
 11. Reasons for Restrictions, If Any:  
NONE  
 12. Report Period Hrs 672.0 MONTH 1,416.0 YEAR 102,168.0 CUMULATIVE  
 13. Hours Reactor Critical 547.2 985.7 66,179.3  
 14. Rx Reserve Shtdwn Hrs .0 .0 .0  
 15. Hrs Generator On-Line 533.7 944.8 64,073.6  
 16. Unit Reserve Shtdwn Hrs .0 .0 .0  
 17. Gross Therm Ener (MWH) 1,628,671 2,670,312 188,936,827  
 18. Gross Elec Ener (MWH) 534,180 869,150 62,082,110  
 19. Net Elec Ener (MWH) 516,156 837,067 59,429,362  
 20. Unit Service Factor 79.4 66.7 62.7  
 21. Unit Avail Factor 79.4 66.7 62.7  
 22. Unit Cap Factor (MDC Net) 73.1 56.2 55.3  
 23. Unit Cap Factor (DER Net) 72.1 55.5 54.6  
 24. Unit Forced Outage Rate 20.6 27.0 13.2  
 25. Forced Outage Hours 138.3 349.6 9,762.1  
 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE  
 27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*  
 \* PEACH BOTTOM 2 \*  
 \*\*\*\*  
 AVERAGE DAILY POWER LEVEL (MWe) PLOT  
 PEACH BOTTOM 2



FEBRUARY 1986

Report Period FEB 1986

## UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
 \* PEACH BOTTOM 2  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
9	02/01/86	F	138.3	A	3	2-86-3	EE	ENGINE	DIESEL INOPERABLE. SCRAM FROM 96% POWER DUE TO THE CLOSURE OF TWO MSIVS, CONINCIDENT WITH THE FAILURE OF THE E-2 DIESEL GENERATOR.
10	02/15/86	S	0.0	B	5		RC	ZZZZZ	LOAD REDUCTION TO 760 MWE FOR CONTROL ROD PATTERN ADJUSTMENT.

\*\*\*\*\*  
 \* PEACH BOTTOM 2 OPERATED WITH 1 OUTAGE IN FEBRUARY AS DESCRIBED ABOVE.  
 \* SUMMARY \*  
 \*\*\*\*\*

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	Instructions for Preparation of
	C-Refueling	H-Other	Data Entry Sheet
	D-Regulatory Restriction	3-Auto Scram	Licensee Event Report
	E-Operator Training & License Examination	4-Continued	(LER) File (NUREG-0161)
		5-Reduced Load	
		9-Other	

\*\*\*\*\*  
\* PEACH BOTTOM 2 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1986

FACILITY DESCRIPTION

LOCATION STATE..... PENNSYLVANIA  
COUNTY..... YORK  
DIST AND DIRECTION FROM NEAREST POPULATION CTR... 19 MI S OF  
LANCASTER, PA  
TYPE OF REACTOR..... BWR  
DATE INITIAL CRITICALITY... SEPTEMBER 16, 1973  
DATE ELEC ENER 1ST GENER... FEBRUARY 18, 1974  
DATE COMMERCIAL OPERATE.... JULY 5, 1974  
CONDENSER COOLING METHOD... ONCE THRU  
CONDENSER COOLING WATER.... SUSQUEHANNA RIVER  
ELECTRIC RELIABILITY COUNCIL..... MID-ATLANTIC AREA COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY LICENSEE..... PHILADELPHIA ELECTRIC  
CORPORATE ADDRESS..... 2301 MARKET STREET  
PHILADELPHIA, PENNSYLVANIA 19105  
CONTRACTOR ARCHITECT/ENGINEER..... BECHTEL  
NUC STEAM SYS SUPPLIER... GENERAL ELECTRIC  
CONSTRUCTOR..... BECHTEL  
TURBINE SUPPLIER..... GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE..... I  
IE RESIDENT INSPECTOR..... T. JOHNSON  
LICENSING PROJ MANAGER..... G. GEARS  
DOCKET NUMBER..... 50-277  
LICENSE & DATE ISSUANCE.... DPR-44, DECEMBER 14, 1973  
PUBLIC DOCUMENT ROOM..... GOVERNMENT PUBLICATIONS SECTION  
STATE LIBRARY OF PENNSYLVANIA  
FORUM BUILDING  
COMMONWEALTH AND WALNUT STREET  
HARRISBURG, PENNSYLVANIA 17105

INSPECTION STATUS

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

Report Period FEB 1986

INSPECTION STATUS - (CONTINUED)

\*\*\*\*\* PEACH BOTTOM 2 \*\*\*\*\*  
\*\*\*\*\* X \*\*\*\*\*

OTHER ITEMS

NO INPUT PROVIDED.

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

REPORTS FROM LICENSEE


NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
NO INPUT PROVIDED.			

1. Docket: 50-278 OPERATING STATUS  
 2. Reporting Period: 02/01/86 Outage + On-line Hrs: 672.0  
 3. Utility Contact: H. M. Alden (215) 841-5022  
 4. Licensed Thermal Power (MWe): 3293  
 5. Nameplate Rating (Gross MWe): 1280 X 0.9 = 1152  
 6. Design Electrical Rating (Net MWe): 1065  
 7. Maximum Dependable Capacity (Gross MWe): 1098  
 8. Maximum Dependable Capacity (Net MWe): 1035  
 9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE  
 10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_  
 11. Reasons for Restrictions, If Any:  
NONE  
 12. Report Period Hrs 672.0 YEAR 1,416.0 CUMULATIVE 98,064.0  
 13. Hours Reactor Critical .0 .0 68,613.5  
 14. Rx Reserve Shtdn Hrs .0 .0 .0  
 15. Hrs Generator On-Line .0 .0 66,854.4  
 16. Unit Reserve Shtdn Hrs .0 .0 .0  
 17. Gross Therm Ener (MWH) 0 0 194,996,664  
 18. Gross Elec Ener (MWH) 0 0 63,993,670  
 19. Net Elec Ener (MWH) -4,141 -9,484 61,383,257  
 20. Unit Service Factor .0 .0 68.2  
 21. Unit Avail Factor .0 .0 68.2  
 22. Unit Cap Factor (MDC Net) .0 .0 60.5  
 23. Unit Cap Factor (DER Net) .0 .0 58.8  
 24. Unit Forced Outage Rate .0 .0 7.1  
 25. Forced Outage Hours .0 .0 5,126.6  
 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE  
 27. If Currently Shutdown Estimated Startup Date: 03/02/86

\*\*\*\*\*  
\* PEACH BOTTOM 3 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

PEACH BOTTOM 3



FEBRUARY 1986

Report Period FEB 1986

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* PEACH BOTTOM 3 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
1	07/14/85	S	672.0	C	4		RC	FUELXX	SHUTDOWN FOR SIXTH REFUELING AND MAINTENANCE OUTAGE CONTINUES.

\*\*\*\*\*  
\* PEACH BOTTOM 3 WAS SHUTDOWN FOR REFUELING DURING ALL OF FEBRUARY.  
\* SUMMARY \*  
\*\*\*\*\*

Type	Reason	Method	System & Component	
F-Forced	A-Equip Failure	F-Admin	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	2-Manual Scram	Instructions for Preparation of
	C-Refueling	H-Other	3-Auto Scram	Data Entry Sheet
	D-Regulatory Restriction		4-Continued	Licensee Event Report
	E-Operator Training		5-Reduced Load	(LER) File (NUREG-0161)
	& License Examination		9-Other	

\*\*\*\*\*  
\* PEACH BOTTOM 3 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1986

FACILITY DESCRIPTION

LOCATION  
STATE.....PENNSYLVANIA  
COUNTY.....YORK  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...19 MI S OF  
LANCASTER, PA  
TYPE OF REACTOR.....BWR  
DATE INITIAL CRITICALITY...AUGUST 7, 1974  
DATE ELEC ENER 1ST GENER...SEPTEMBER 1, 1974  
DATE COMMERCIAL OPERATE....DECEMBER 23, 1974  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER....SUSQUEHANNA RIVER  
ELECTRIC RELIABILITY  
COUNCIL.....MID-ATLANTIC  
AREA COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....PHILADELPHIA ELECTRIC  
CORPORATE ADDRESS.....2301 MARKET STREET  
PHILADELPHIA, PENNSYLVANIA 19105  
CONTRACTOR  
ARCHITECT/ENGINEER.....BECHTEL  
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC  
CONSTRUCTOR.....BECHTEL  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I  
IE RESIDENT INSPECTOR.....T. JOHNSON  
LICENSING PROJ MANAGER.....G. GEARS  
DOCKET NUMBER.....50-278  
LICENSE & DATE ISSUANCE....DPR-56, JULY 2, 1974  
PUBLIC DOCUMENT ROOM.....GOVERNMENT PUBLICATIONS SECTION  
STATE LIBRARY OF PENNSYLVANIA  
FORUM BUILDING  
COMMONWEALTH AND WALNUT STREET  
HARRISBURG, PENNSYLVANIA 17105

INSPECTION SUMMARY

I N S P E C T I O N      S T A T U S

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

Report Period FEB 1986

INSPECTION STATUS - (CONTINUED)

\*\*\*\*\*  
\* PEACH BOTTOM 3 \*  
\*\*\*\*\*

OTHER ITEMS

NO INPUT PROVIDED.

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

REPORTS FROM LICENSEE

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
--------	------------------	-------------------	---------


NO INPUT PROVIDED.

1. Docket: 50-293 OPERATING STATUS  
 2. Reporting Period: 02/01/86 Outage + On-line Hrs: 672.0  
 3. Utility Contact: P. HAMILTON (617) 746-7900  
 4. Licensed Thermal Power (MWh): 1998  
 5. Nameplate Rating (Gross MWe): 780 X 0.87 = 678  
 6. Design Electrical Rating (Net MWe): 655  
 7. Maximum Dependable Capacity (Gross MWe): 690  
 8. Maximum Dependable Capacity (Net MWe): 670  
 9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE  
 10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_  
 11. Reasons for Restrictions, If Any:  
NONE  
 12. Report Period Hrs MONTH YEAR CUMULATIVE  
672.0 1,416.0 115,920.0  
 13. Hours Reactor Critical 672.0 1,327.5 79,390.7  
 14. Rx Reserve Shtdwn Hrs .0 .0 .0  
 15. Hrs Generator On-Line 672.0 1,301.0 76,871.9  
 16. Unit Reserve Shtdwn Hrs .0 .0 .0  
 17. Gross Therm Ener (MWh) 1,317,696 2,509,104 134,894,736  
 18. Gross Elec Ener (MWh) 456,850 863,810 45,245,414  
 19. Net Elec Ener (MWh) 439,790 836,230 43,484,128  
 20. Unit Service Factor 100.0 91.9 66.3  
 21. Unit Avail Factor 100.0 91.9 66.3  
 22. Unit Cap Factor (MDC Net) 97.7 88.1 56.0  
 23. Unit Cap Factor (DER Net) 99.9 90.2 57.3  
 24. Unit Forced Outage Rate .0 3.9 9.0  
 25. Forced Outage Hours .0 52.5 7,596.7  
 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE  
 27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\* PILGRIM 1 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

PILGRIM 1



FEBRUARY 1986

Report Period FEB 1986

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* PILGRIM 1 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System Component	Cause & Corrective Action to Prevent Recurrence
09	02/16/86	S	0.0	B	5			REDUCED POWER FOR CONDENSER BACKWASH AND CONTROL ROD PATTERN CHANGE.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*

Type	Reason	Method	System & Component	
F-Forced	A-Equip Failure	F-Admin	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	2-Manual Scram	Instructions for
	C-Refueling	H-Other	3-Auto Scram	Preparation of
	D-Regulatory Restriction		4-Continued	Data Entry Sheet
	E-Operator Training		5-Reduced Load	Licensee Event Report
	& License Examination		9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* PILGRIM 1 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1986

FACILITY DESCRIPTION

LOCATION STATE..... MASSACHUSETTS  
COUNTY..... PLYMOUTH  
DIST AND DIRECTION FROM NEAREST POPULATION CTR...4 MI SE OF PLYMOUTH, MASS  
TYPE OF REACTOR..... BWR  
DATE INITIAL CRITICALITY...JUNE 16, 1972  
DATE ELEC ENER 1ST GENER...JULY 19, 1972  
DATE COMMERCIAL OPERATE....DECEMBER 1, 1972  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER....CAPE COD BAY  
ELECTRIC RELIABILITY COUNCIL..... NORTHEAST POWER COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY LICENSEE..... BOSTON EDISON  
CORPORATE ADDRESS..... 800 BOYLSTON STREET  
BOSTON, MASSACHUSETTS 02199  
CONTRACTOR ARCHITECT/ENGINEER..... BECHTEL  
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC  
CONSTRUCTOR..... BECHTEL  
TURBINE SUPPLIER..... GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE..... I  
IE RESIDENT INSPECTOR..... M. MCBRIDE  
LICENSING PROJ MANAGER.... P. LEECH  
DOCKET NUMBER..... 50-293  
LICENSE & DATE ISSUANCE.... DPR-35, SEPTEMBER 15, 1972  
PUBLIC DOCUMENT ROOM..... PLYMOUTH PUBLIC LIBRARY  
11 NORTH STREET  
PLYMOUTH, MASSACHUSETTS 02360

I N S P E C T I O N     S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

Report Period FEB 1986

I N S P E C T I O N      S T A T U S - (CONTINUED)

\*\*\*\*\*  
\*            PILGRIM 1            \*  
\*\*\*\*\*

OTHER ITEMS

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S   F R O M   L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
--------	------------------	-------------------	---------

=====

NO INPUT PROVIDED.

1. Docket: 50-266 OPERATING STATUS  
 2. Reporting Period: 02/01/86 Outage + On-line Hrs: 672.0  
 3. Utility Contact: C. W. KRAUSE (414) 277-2001  
 4. Licensed Thermal Power (MWt): 1518  
 5. Nameplate Rating (Gross MWe): 582 X 0.9 = 524  
 6. Design Electrical Rating (Net MWe): 497  
 7. Maximum Dependable Capacity (Gross MWe): 509  
 8. Maximum Dependable Capacity (Net MWe): 485  
 9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE


10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_  
 11. Reasons for Restrictions, If Any:  
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>672.0</u>	<u>1,416.0</u>	<u>134,256.0</u>
13. Hours Reactor Critical	<u>672.0</u>	<u>1,416.0</u>	<u>108,889.0</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>634.4</u>
15. Hrs Generator On-Line	<u>672.0</u>	<u>1,416.0</u>	<u>106,322.8</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>,0</u>	<u>804.0</u>
17. Gross Therm Ener (MWH)	<u>1,003,299</u>	<u>2,128,131</u>	<u>145,296,075</u>
18. Gross Elec Ener (MWH)	<u>343,080</u>	<u>727,390</u>	<u>48,879,070</u>
19. Net Elec Ener (MWH)	<u>329,186</u>	<u>698,074</u>	<u>46,529,340</u>
20. Unit Service Factor	<u>100.0</u>	<u>100.0</u>	<u>79.2</u>
21. Unit Avail Factor	<u>100.0</u>	<u>100.0</u>	<u>79.8</u>
22. Unit Cap Factor (MDC Net)	<u>101.0</u>	<u>101.6</u>	<u>70.9*</u>
23. Unit Cap Factor (DER Net)	<u>98.6</u>	<u>99.2</u>	<u>69.7</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.0</u>	<u>2.4</u>
25. Forced Outage Hours	<u>.0</u>	<u>.0</u>	<u>2,413.4</u>
26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):			
REFUELING & MAINT.: APRIL 11, 1986.			
27. If Currently Shutdown Estimated Startup Date:	<u>N/A</u>		

\*\*\*\*\*  
\* POINT BEACH 1 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

POINT BEACH 1



FEBRUARY 1986

\* Item calculated with a Weighted Average

PAGE 2-258

Report Period FEB 1986

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* POINT BEACH 1 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
1	02/15/86	S	0.0	B	5	XX	XXXXXX		TURBINE STOP VALVE TESTING AND REPAIR OF A STEAM LEAK FROM A ONE-INCH PIPE ON THE HP TURBINE EXHAUST.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*

POINT BEACH 1 OPERATED ROUTINELY IN FEBRUARY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	Instructions for Preparation of
	C-Refueling	H-Other	Data Entry Sheet
	D-Regulatory Restriction	3-Auto Scram	Licensee Event Report
	E-Operator Training & License Examination	4-Continued	(LER) File (NUREG-0161)
		5-Reduced Load	
		9-Other	

\*\*\*\*\*  
X POINT BEACH 1 X  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1986

FACILITY DESCRIPTION

LOCATION  
STATE.....WISCONSIN  
COUNTY.....MANITOWOC  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...15 MI N OF  
MANITOWOC, WISC  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...NOVEMBER 2, 1970  
DATE ELEC ENER 1ST GENER...NOVEMBER 6, 1970  
DATE COMMERCIAL OPERATE....DECEMBER 21, 1970  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER....LAKE MICHIGAN  
ELECTRIC RELIABILITY  
COUNCIL.....MID-AMERICA  
INTERPOOL NETWORK

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....WISCONSIN ELECTRIC POWER COMPANY  
CORPORATE ADDRESS.....231 WEST MICHIGAN STREET  
MILWAUKEE, WISCONSIN 53201  
CONTRACTOR  
ARCHITECT/ENGINEER.....BECHTEL  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
CONSTRUCTOR.....BECHTEL  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III  
IE RESIDENT INSPECTOR.....R. HAGUE  
LICENSING PROJ MANAGER.....T. COLBURN  
DOCKET NUMBER.....50-266  
LICENSE & DATE ISSUANCE....DPR-24, OCTOBER 5, 1970  
PUBLIC DOCUMENT ROOM.....JOSEPH MANN PUBLIC LIBRARY  
1516 16TH ST.  
TWO RIVERS, WISCONSIN 54241

I N S P E C T I O N     S T A T U S

INSPECTION SUMMARY

INSPECTION ON DECEMBER 9-12 (85023): ROUTINE, UNANNOUNCED INSPECTION OF GASEOUS AND LIQUID RADIOACTIVE PROGRAM INCLUDING: EFFLUENT RELEASE RECORDS AND REPORTS OF EFFLUENTS; EFFLUENT CONTROL INSTRUMENTATION; PROCEDURES FOR CONTROLLING RELEASES; PRIMARY AND SECONDARY COOLANT CHEMISTRY AND ACTIVITY, GASEOUS EFFLUENT FILTRATION, AUDITS AND REVIEW OF STATUS OF PREVIOUSLY IDENTIFIED VIOLATIONS, UNRESOLVED ITEM AND OPEN ITEMS. THE INSPECTION INVOLVED 35 INSPECTOR-HOURS ONSITE BY ONE NRC INSPECTOR. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

Report Period FE- 1-86

INSPECTION STATUS - (CONTINUED)

\*\*\*\*\*  
X POINT BEACH 1 X  
\*\*\*\*\*

OTHER ITEMS

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

THE UNIT IS OPERATING NORMALLY.

LAST IE SITE INSPECTION DATE: FEBRUARY 18 - 21, 1986

INSPECTION REPORT NO: 86004


REPORTS FROM LICENSEE

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
85-10	12/20/85	01/20/86	NUCLEAR INSTRUMENTATION TURBINE RUNBACK
86-01	01/02/86	01/20/86	NUCLEAR INSTRUMENTATION TURBINE RUNBACK

1. Docket: 50-301 OPERATING STATUS  
 2. Reporting Period: 02/01/86 Outage + On-line Hrs: 672.0  
 3. Utility Contact: C. W. KRAUSE (414) 277-2001  
 4. Licensed Thermal Power (MWh): 1518  
 5. Nameplate Rating (Gross MWe): 582 X 0.9 = 524  
 6. Design Electrical Rating (Net MWe): 497  
 7. Maximum Dependable Capacity (Gross MWe): 509  
 8. Maximum Dependable Capacity (Net MWe): 485  
 9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE  
 10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_  
 11. Reasons for Restrictions, If Any:  
NONE  
 12. Report Period Hrs 672.0 MONTH 672.0 YEAR 1,416.0 CUMULATIVE 119,041.0  
 13. Hours Reactor Critical 672.0 1,416.0 104,964.6  
 14. Rx Reserve Shtdwn Hrs .0 .0 207.4  
 15. Hrs Generator On-Line 672.0 1,405.9 103,206.6  
 16. Unit Reserve Shtdwn Hrs .0 .0 234.3  
 17. Gross Therm Ener (MWH) 1,001,623 2,097,997 144,977,867  
 18. Gross Elec Ener (MWH) 340,650 713,190 49,129,040  
 19. Net Elec Ener (MWH) 326,200 682,802 46,803,521  
 20. Unit Service Factor 100.0 99.3 86.7  
 21. Unit Avail Factor 100.0 99.3 86.9  
 22. Unit Cap Factor (MDC Net) 100.1 99.4 80.1\*  
 23. Unit Cap Factor (DER Net) 97.7 97.0 79.1  
 24. Unit Forced Outage Rate .0 .7 1.3  
 25. Forced Outage Hours .0 10.1 755.0  
 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE  
 27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\* POINT BEACH 2 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT  
 POINT BEACH 2



FEBRUARY 1986

\* Item calculated with a Weighted Average

Report Period FEB 1986

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* POINT BEACH 2 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System Component	Cause & Corrective Action to Prevent Recurrence
1	02/01/86	S	0.0	B	5	XX	XXXXXX	SPECIAL PERFORMANCE TESTING OF MOISTURE SEPARATOR REHEATERS.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
POINT BEACH 2 OPERATED ROUTINELY IN FEBRUARY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	Instructions for
	C-Refueling	H-Other	Preparation of
	D-Regulatory Restriction		Data Entry Sheet
	E-Operator Training & License Examination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Licensor Event Report (LER) File (NUREG-0161)

\*\*\*\*\*  
\* POINT BEACH 2 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1986

FACILITY DESCRIPTION

LOCATION STATE.....WISCONSIN  
COUNTY.....MANITOWOC  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...15 MI N OF  
MANITOWOC, WISC  
TYPE OF REACTOR.....PHR  
DATE INITIAL CRITICALITY...MAY 30, 1972  
DATE ELEC ENER 1ST GENER...AUGUST 2, 1972  
DATE COMMERCIAL OPERATE....OCTOBER 1, 1972  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER....LAKE MICHIGAN  
ELECTRIC RELIABILITY  
COUNCIL.....MID-AMERICA  
INTERPOOL NETWORK

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....WISCONSIN ELECTRIC POWER COMPANY  
CORPORATE ADDRESS.....231 WEST MICHIGAN STREET  
MILWAUKEE, WISCONSIN 53201  
CONTRACTOR  
ARCHITECT/ENGINEER.....BECHTEL  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
CONSTRUCTOR.....BECHTEL  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III  
IE RESIDENT INSPECTOR.....R. HAGUE  
LICENSING PROJ MANAGER.....T. COLBURN  
DOCKET NUMBER.....50-301  
LICENSE & DATE ISSUANCE....DPR-27, MARCH 8, 1973  
PUBLIC DOCUMENT ROOM.....JOSEPH MANN PUBLIC LIBRARY  
1516 16TH ST.  
TWO RIVERS, WISCONSIN 54241

I N S P E C T I O N     S T A T U S

INSPECTION SUMMARY

INSPECTION ON DECEMBER 9-12 (85022): ROUTINE, UNANNOUNCED INSPECTION OF GASEOUS AND LIQUID RADIOACTIVE PROGRAM INCLUDING:  
EFFLUENT RELEASE RECORDS AND REPORTS OF EFFLUENTS; EFFLUENT CONTROL INSTRUMENTATION; PROCEDURES FOR CONTROLLING RELEASES; PRIMARY  
AND SECONDARY COOLANT CHEMISTRY AND ACTIVITY, GASEOUS EFFLUENT FILTRATION, AUDITS AND REVIEW OF STATUS OF PREVIOUSLY IDENTIFIED  
VIOLATIONS, UNRESOLVED ITEM AND OPEN ITEMS. THE INSPECTION INVOLVED 35 INSPECTOR-HOURS ONSITE BY ONE NRC INSPECTOR. NO  
VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

Report Period FEB 1986

I N S P E C T I O N      S T A T U S - (CONTINUED)

\*\*\*\*\*  
\*        POINT BEACH 2        \*  
\*\*\*\*\*

OTHER ITEMS

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

THE UNIT IS IS OPERATING NORMALLY.

LAST IE SITE INSPECTION DATE: FEBRUARY 18 - 21, 1986

INSPECTION REPORT NO: 85022

R E P O R T S   F R O M   L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
--------	------------------	-------------------	---------

=====

85-05	12/31/85	01/28/86	REACTOR TRIP DUE TO LOSS OF LOAD
-------	----------	----------	----------------------------------


=====

1. Docket: 50-282 OPERATING STATUS  
 2. Reporting Period: 02/01/86 Outage + On-line Hrs: 672.0  
 3. Utility Contact: DALE DUGSTAD (612) 388-1121  
 4. Licensed Thermal Power (MWh): 1650  
 5. Nameplate Rating (Gross MWe): 659 X 0.9 = 593  
 6. Design Electrical Rating (Net MWe): 530  
 7. Maximum Dependable Capacity (Gross MWe): 534  
 8. Maximum Dependable Capacity (Net MWe): 503  
 9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE  
 10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_  
 11. Reasons for Restrictions, If Any:  
NONE  
 12. Report Period Hrs      MONTH      YEAR      CUMULATIVE  
672.0      1,416.0      106,992.0  
 13. Hours Reactor Critical      672.0      1,416.0      88,773.5  
 14. Rx Reserve Shtdwn Hrs      .0      .0      5,571.1  
 15. Hrs Generator On-Line      672.0      1,416.0      87,418.5  
 16. Unit Reserve Shtdwn Hrs      .0      .0      .0  
 17. Gross Therm Ener (MWH)      710,736      1,794,874      137,163,487  
 18. Gross Elec Ener (MWH)      236,140      603,790      44,805,060  
 19. Net Elec Ener (MWH)      219,940      567,943      41,995,777  
 20. Unit Service Factor      100.0      100.0      81.7  
 21. Unit Avail Factor      100.0      100.0      81.7  
 22. Unit Cap Factor (MDC Net)      65.1      79.7      78.0  
 23. Unit Cap Factor (DER Net)      61.8      75.7      74.1  
 24. Unit Forced Outage Rate      .0      .0      7.5  
 25. Forced Outage Hours      .0      .0      3,390.7  
 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
REFUELING OUTAGE: MARCH 5, 1986.  
 27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\* PRAIRIE ISLAND 1 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

PRAIRIE ISLAND 1



FEBRUARY 1986

Report Period FEB 1986

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* PRAIRIE ISLAND 1 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System Component	Cause & Corrective Action to Prevent Recurrence
	02/09/86	S	0.0	B	5			TURBINE VALVES TEST.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*

PRAIRIE ISLAND 1 OPERATED ROUTINELY IN FEBRUARY.

Type	Reason	Method	System & Component	
F-Forced	A-Equip Failure	F-Admin	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	2-Manual Scram	Instructions for Preparation of
	C-Refueling	H-Other	3-Auto Scram	Data Entry Sheet
	D-Regulatory Restriction		4-Continued	Licensee Event Report
	E-Operator Training & License Examination		5-Reduced Load	(LER) File (NUREG-01/1)
			9-Other	

\*\*\*\*\*  
\* PRAIRIE ISLAND 1 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1986

FACILITY DESCRIPTION

LOCATION STATE.....MINNESOTA  
COUNTY.....GOODHUE  
DIST AND DIRECTION FROM NEAREST POPULATION CTR...28 MI SE OF MINNEAPOLIS, MINN

TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...DECEMBER 1, 1973  
DATE ELEC ENER 1ST GENER...DECEMBER 4, 1973  
DATE COMMERCIAL OPERATE....DECEMBER 16, 1973  
CONDENSER COOLING METHOD...COOLING TOWERS  
CONDENSER COOLING WATER....MISSISSIPPI RIVER  
ELECTRIC RELIABILITY COUNCIL.....MID-CONTINENT AREA RELIABILITY COORDINATION AGREEMENT

I N S P E C T I O N     S T A T U S

INSPECTION SUMMARY

INSPECTION ON OCTOBER 28 - NOVEMBER 1 AND 12-15 (85021): SPECIAL ANNOUNCED INSPECTION BY TWO REGIONAL INSPECTORS OF THE LICENSEE'S PLANT MODIFICATION PROGRAM AND RELATED ACTIVITIES. THE INSPECTION INVOLVED A TOTAL OF 125 INSPECTOR-HOURS ONSITE AND 57 INSPECTOR-HOURS IN THE REGIONAL OFFICE BY TWO REGION BASED INSPECTORS. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION ON OCTOBER 13 THROUGH DECEMBER 7 (85022): ROUTINE UNANNOUNCED INSPECTION BY RESIDENT INSPECTORS OF PREVIOUS INSPECTION FINDINGS, PLANT OPERATIONAL SAFETY, MAINTENANCE, SURVEILLANCE, FACILITY MODIFICATIONS, MEETING WITH CORPORATE MANAGEMENT, AND FOLLOWUP OF LICENSEE EVENT REPORTS. THE INSPECTION INVOLVED A TOTAL OF 408 INSPECTOR-HOURS BY TWO NRC INSPECTORS INCLUDING 34 INSPECTOR-HOURS ONSITE DURING OFF-SHIFTS. NO VIOLATIONS WERE IDENTIFIED IN THE SEVEN AREAS INSPECTED.

INSPECTION ON JANUARY 7-10, (86002) ROUTINE UNANNOUNCED INSPECTION OF THE FOLLOWING AREAS OF THE EMERGENCY PREPAREDNESS PROGRAM: KNOWLEDGE AND PERFORMANCE OF DUTIES (TRAINING); CHANGES TO THE EMERGENCY PREPAREDNESS PROGRAM; LICENSEE AUDITS; MAINTENANCE OF EMERGENCY PREPAREDNESS; LICENSEE ACTIONS ON PREVIOUSLY-IDENTIFIED ITEMS; AND ACTIVATION OF THE EMERGENCY PLAN. THE INSPECTION INVOLVED 62 INSPECTOR-HOURS ON SITE BY TWO NRC INSPECTORS. NO VIOLATIONS, DEFICIENCIES, OR DEVIATIONS WERE IDENTIFIED IN FIVE AREAS; HOWEVER, ONE VIOLATION WAS IDENTIFIED IN ONE AREA (KNOWLEDGE AND PERFORMANCE OF DUTIES).

Report Period FEB 1986

I N S P E C T I O N      S T A T U S - (CONTINUED)

\*\*\*\*\*  
\* PRAIRIE ISLAND 1 \*  
\*\*\*\*\*

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

THE UNIT IS OPERATING NORMALLY.

LAST IE SITE INSPECTION DATE: FEBRUARY 9 - APRIL 12, 1986

INSPECTION REPORT NO: 86005

R E P O R T S   F R O M   L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
-----			
NONE			
-----			


=====

1. Docket: 50-306 OPERATING STATUS  
 2. Reporting Period: 02/01/86 Outage + On-line Hrs: 672.0  
 3. Utility Contact: DALE DUGSTAD (612) 388-1121  
 4. Licensed Thermal Power (MWh): 1650  
 5. Nameplate Rating (Gross MWe): 659 X 0.9 = 593  
 6. Design Electrical Rating (Net MWe): 530  
 7. Maximum Dependable Capacity (Gross MWe): 531  
 8. Maximum Dependable Capacity (Net MWe): 500  
 9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE  
 10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_  
 11. Reasons for Restrictions, If Any:  
NONE  
 12. Report Period Hrs      MONTH      YEAR      CUMULATIVE  
672.0      1,416.0      98,110.0  
 13. Hours Reactor Critical      672.0      1,416.0      84,918.9  
 14. Rx Reserve Shtdwn Hrs      .0      .0      1,516.1  
 15. Hrs Generator On-Line      672.0      1,416.0      83,918.5  
 16. Unit Reserve Shtdwn Hrs      .0      .0      .0  
 17. Gross Therm Ener (MWH)      1,104,138      2,320,290      131,992,681  
 18. Gross Elec Ener (MWH)      373,910      785,390      42,844,830  
 19. Net Elec Ener (MWH)      356,626      748,788      40,238,105  
 20. Unit Service Factor      100.0      100.0      85.5  
 21. Unit Avail Factor      100.0      100.0      85.5  
 22. Unit Cap Factor (MDC Net)      106.1      105.8      82.0  
 23. Unit Cap Factor (DER Net)      100.1      99.8      77.4  
 24. Unit Forced Outage Rate      .0      .0      3.6  
 25. Forced Outage Hours      .0      .0      3,315.5  
 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE  
 27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\* PRAIRIE ISLAND 2 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

PRAIRIE ISLAND 2



FEBRUARY 1986

Report Period FEB 1986

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* PRAIRIE ISLAND 2 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
1	02/18/86	S	0.0	B	5				AXIAL OFFSET TEST.
2	02/23/86	S	0.0	B	5				TURBINE VALVES TEST.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*

PRAIRIE ISLAND 2 OPERATED ROUTINELY IN FEBRUARY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	Instructions for
	C-Refueling	H-Other	Preparation of
	D-Regulatory Restriction	3-Auto Scram	Data Entry Sheet
	E-Operator Training & License Examination	4-Continued	Licensee Event Report
		5-Reduced Load	(LER) File (NUREG-0161)
		9-Other	

\*\*\*\*\*  
\* PRAIRIE ISLAND 2 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1986

FACILITY DESCRIPTION

LOCATION  
STATE.....MINNESOTA  
COUNTY.....GOODHUE  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...28 MI SE OF  
MINNEAPOLIS, MINN  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...DECEMBER 17, 1974  
DATE ELEC ENER 1ST GENER...DECEMBER 21, 1974  
DATE COMMERCIAL OPERATE....DECEMBER 21, 1974  
CONDENSER COOLING METHOD...COOLING TOWERS  
CONDENSER COOLING WATER....MISSISSIPPI RIVER  
ELECTRIC RELIABILITY  
COUNCIL.....MID-CONTINENT AREA  
RELIABILITY COORDINATION  
AGREEMENT

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....NORTHERN STATES POWER  
CORPORATE ADDRESS.....414 NICOLLET MALL  
MINNEAPOLIS, MINNESOTA 55401

CONTRACTOR  
ARCHITECT/ENGINEER.....FLUOR PIONEER, INC.

NUC STEAM SYS SUPPLIER...WESTINGHOUSE

CONSTRUCTOR.....NORTHERN STATES POWER COMPANY  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III

IE RESIDENT INSPECTOR.....J. HARD

LICENSING PROJ MANAGER.....D. DIANNI  
DOCKET NUMBER.....50-306

LICENSE & DATE ISSUANCE....DPR-60, OCTOBER 29, 1974

PUBLIC DOCUMENT ROOM.....ENVIRONMENTAL CONSERVATION LIBRARY  
MINNEAPOLIS PUBLIC LIBRARY  
300 NICOLLET MALL  
MINNEAPOLIS, MINNESOTA 55401

I N S P E C T I O N     S T A T U S

INSPECTION SUMMARY

INSPECTION ON OCTOBER 28 - NOVEMBER 1 AND 12-15 (85019): SPECIAL ANNOUNCED INSPECTION BY TWO REGIONAL INSPECTORS OF THE LICENSEE'S PLANT MODIFICATION PROGRAM AND RELATED ACTIVITIES. THE INSPECTION INVOLVED A TOTAL OF 125 INSPECTOR-HOURS ONSITE AND 57 INSPECTOR-HOURS IN THE REGIONAL OFFICE BY TWO REGION BASED INSPECTORS. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION ON OCTOBER 13 THROUGH DECEMBER 7 (85020): ROUTINE UNANNOUNCED INSPECTION BY RESIDENT INSPECTORS OF PREVIOUS INSPECTION FINDINGS, PLANT OPERATIONAL SAFETY, MAINTENANCE, SURVEILLANCE, FACILITY MODIFICATIONS, MEETING WITH CORPORATE MANAGEMENT, AND FOLLOWUP OF LICENSEE EVENT REPORTS. THE INSPECTION INVOLVED A TOTAL OF 408 INSPECTOR-HOURS BY TWO NRC INSPECTORS INCLUDING 34 INSPECTOR-HOURS ONSITE DURING OFF-SHIFTS. NO VIOLATIONS WERE IDENTIFIED IN THE SEVEN AREAS INSPECTED.

INSPECTION ON JANUARY 7-10, (86002) ROUTINE UNANNOUNCED INSPECTION OF THE FOLLOWING AREAS OF THE EMERGENCY PREPAREDNESS PROGRAM: KNOWLEDGE AND PERFORMANCE OF DUTIES (TRAINING); CHANGES TO THE EMERGENCY PREPAREDNESS PROGRAM; LICENSEE AUDITS; MAINTENANCE OF EMERGENCY PREPAREDNESS; LICENSEE ACTIONS ON PREVIOUSLY-IDENTIFIED ITEMS; AND ACTIVATION OF THE EMERGENCY PLAN. THE INSPECTION INVOLVED 62 INSPECTOR-HOURS ON SITE BY TWO NRC INSPECTORS. NO VIOLATIONS, DEFICIENCIES, OR DEVIATIONS WERE IDENTIFIED IN FIVE AREAS; HOWEVER, ONE VIOLATION WAS IDENTIFIED IN ONE AREA (KNOWLEDGE AND PERFORMANCE OF DUTIES).

Report Period FEB 1986

I N S P E C T I O N      S T A T U S - (CONTINUED)

\*\*\*\*\*  
\* PRAIRIE ISLAND 2 \*  
\*\*\*\*\*

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

THE UNIT IS OPERATING NORMALLY.

LAST IE SITE INSPECTION DATE: FEBRUARY 9 - APRIL 12, 1986

INSPECTION REPORT NO: 86005

R E P O R T S   F R O M   L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
--------	------------------	-------------------	---------

=====

NONE

1. Docket: 50-254 OPERATING STATUS  
 2. Reporting Period: 02/01/86 Outage + On-line Hrs: 672.0  
 3. Utility Contact: CAROL KRONICH (309) 654-2241 X193  
 4. Licensed Thermal Power (MWh): 2511  
 5. Nameplate Rating (Gross MWe): 920 X 0.9 = 828  
 6. Design Electrical Rating (Net MWe): 789  
 7. Maximum Dependable Capacity (Gross MWe): 813  
 8. Maximum Dependable Capacity (Net MWe): 769  
 9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

11. Reasons for Restrictions, If Any: \_\_\_\_\_

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>672.0</u>	<u>1,416.0</u>	<u>120,984.0</u>
13. Hours Reactor Critical	<u>.0</u>	<u>120.0</u>	<u>96,781.5</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>3,421.9</u>
15. Hrs Generator On-Line	<u>.0</u>	<u>120.0</u>	<u>93,398.7</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>909.2</u>
17. Gross Therm Ener (MWH)	<u>0</u>	<u>240,485</u>	<u>195,205,642</u>
18. Gross Elec Ener (MWH)	<u>0</u>	<u>80,622</u>	<u>63,202,109</u>
19. Net Elec Ener (MWH)	<u>-2,530</u>	<u>72,210</u>	<u>59,099,524</u>
20. Unit Service Factor	<u>.0</u>	<u>8.5</u>	<u>77.2</u>
21. Unit Avail Factor	<u>.0</u>	<u>8.5</u>	<u>78.0</u>
22. Unit Cap Factor (MDC Net)	<u>.0</u>	<u>6.6</u>	<u>63.5</u>
23. Unit Cap Factor (DER Net)	<u>.0</u>	<u>6.5</u>	<u>61.9</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.0</u>	<u>5.6</u>
25. Forced Outage Hours	<u>.0</u>	<u>.0</u>	<u>3,181.6</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


NONE

27. If Currently Shutdown Estimated Startup Date: 03/25/86

\*\*\*\*\*  
\* QUAD CITIES 1 \*  
\*\*\*\*\*

#### AVERAGE DAILY POWER LEVEL (MWe) PLOT

QUAD CITIES 1



FEBRUARY 1986

Report Period FEB 1986

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* QUAD CITIES 1 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
86-2	01/05/86	S	672.0	C	4		RC	FUELXX	UNIT SHUTDOWN FOR END OF CYCLE EIGHT REFUELING AND MAINTENANCE OUTAGE.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*

QUAD CITIES 1 REMAINS SHUT DOWN FOR REFUELING.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	Instructions for Preparation of Data Entry Sheet
	C-Refueling	H-Other	
	D-Regulatory Restriction	3-Auto Scram	
	E-Operator Training & License Examination	4-Continued	
		5-Reduced Load	Licensee Event Report
		9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* QUAD CITIES 1 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1986

FACILITY DESCRIPTION

LOCATION  
STATE.....ILLINOIS

COUNTY.....ROCK ISLAND

DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...20 MI NE OF  
MOLINE, ILL

TYPE OF REACTOR.....BWR

DATE INITIAL CRITICALITY...OCTOBER 18, 1971

DATE ELEC ENER 1ST GENER...APRIL 12, 1972

DATE COMMERCIAL OPERATE....FEBRUARY 18, 1973

CONDENSER COOLING METHOD...ONCE THRU

CONDENSER COOLING WATER....MISSISSIPPI RIVER

ELECTRIC RELIABILITY  
COUNCIL.....MID-AMERICA  
INTERPOOL NETWORK

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....COMMONWEALTH EDISON

CORPORATE ADDRESS.....P.O. BOX 767  
CHICAGO, ILLINOIS 60690

CONTRACTOR  
ARCHITECT/ENGINEER.....SARGENT & LUNDY

NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC

CONSTRUCTOR.....UNITED ENG. & CONSTRUCTORS

TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III

IE RESIDENT INSPECTOR.....A. MADISON

LICENSING PROJ MANAGER.....R. BEVAN  
DOCKET NUMBER.....50-254

LICENSE & DATE ISSUANCE....DPR-29, DECEMBER 14, 1972

PUBLIC DOCUMENT ROOM.....MOLINE PUBLIC LIBRARY  
504 17TH STREET  
MOLINE, ILLINOIS 61265

I N S P E C T I O N     S T A T U S

INSPECTION SUMMARY

INSPECTION ON OCTOBER 1 THROUGH DECEMBER 7 (85027): ROUTINE, UNANNOUNCED INSPECTION BY THE RESIDENT INSPECTORS OF ACTIONS ON PREVIOUS INSPECTIONS FINDINGS; OPERATIONS; RADIOLOGICAL CONTROLS; MAINTENANCE/ MODIFICATIONS; SURVEILLANCE; HOUSEKEEPING PROCEDURES; FIRE PROTECTION; EMERGENCY PREPAREDNESS; SECURITY; QUALITY ASSURANCE; QUALITY CONTROL; ADMINISTRATION; ROUTINE REPORTS, LLR REVIEW; BULLETIN FOLLOWUP; REGIONAL REQUESTS; TRAINING; AND INDEPENDENT INSPECTION. THE INSPECTION INVOLVED A TOTAL OF 399 INSPECTOR-HOURS ONSITE BY THREE NRC INSPECTORS, INCLUDING 79 INSPECTOR-HOURS ONSITE DURING OFF-SHIFTS. TWO VIOLATIONS WERE IDENTIFIED. THE FIRST INVOLVED FAILURE TO COMPLY WITH TECHNICAL SPECIFICATION REQUIREMENTS CONCERNING FIRE DETECTION EQUIPMENT ON THE REFUEL FLOOR. THE SECOND INVOLVED INADEQUATE REVIEW AND CORRECTIVE ACTIONS CONCERNING A 10 CFR PART 21 REPORT ON RUSKIN FIRE DAMPERS. OVERALL, THE LICENSEE'S PERFORMANCE HAS IMPROVED IN OPERATIONS AND REMAINED STEADY IN ALL OTHER AREAS.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

Report Period FEB 1986

I N S P E C T I O N      S T A T U S - (CONTINUED)

\*\*\*\*\*  
\* QUAD CITIES 1 \*  
\*\*\*\*\*

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

SHUT DOWN 1/6/86 FOR 12-WEEK REFUELING OUTAGE.

LAST IE SITE INSPECTION DATE: FEBRUARY 10 - 14, 1986

INSPECTION REPORT NO: 86004


R E P O R T S   F R O M   L I C E N S E E

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
85-20	12/10/85	01/06/86	AUTO-START SIGNAL SENT TO STANDBY GAS TREATMENT SYSTEM DUE TO BYPASS OF 'A' AND DOWNSCALE SPIKE OF 'B' FUEL POOL RADIATION MONITORS
85-22	12/28/85	01/20/86	STANDBY GAS TRAIN A LOSES FLOW DUE TO OBSTRUCTED INTAKE AND TRAIN B DOESN'T START DUE TO BLOWN FUSE
86-01	01/06/86	01/31/86	LEAK RATE FROM ALL VALVES AND PENETRATIONS IN EXCESS OF TECHNICAL SPECIFICATION LIMIT
86-02	01/07/86	01/30/86	LEAK RATE FOR MSIV (MAIN STEAM ISOLATION VALVE) IN EXCESS OF TECHNICAL SPECIFICATION LIMIT
86-03	01/02/86	01/22/86	1/2 DIESEL GENERATOR COOLING WATER PUMP INOPERABLE DUE TO LOSS OF CONTROL POWER

1. Docket: 50-265 OPERATING STATUS  
 2. Reporting Period: 02/01/86 Outage + On-line Hrs: 672.0  
 3. Utility Contact: CAROL KRONICH (309) 654-2241 X193  
 4. Licensed Thermal Power (MWt): 2511  
 5. Nameplate Rating (Gross MWe): 920 X 0.9 = 828  
 6. Design Electrical Rating (Net MWe): 789  
 7. Maximum Dependable Capacity (Gross MWe): 813  
 8. Maximum Dependable Capacity (Net MWe): 769  
 9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE  
 10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_  
 11. Reasons for Restrictions, If Any:  
NONE  
 12. Report Period Hrs 672.0 MONTH 672.0 YEAR 1,416.0 CUMULATIVE 120,094.0  
 13. Hours Reactor Critical 506.8 1,242.6 92,510.6  
 14. Rx Reserve Shtdwn Hrs .0 .0 2,985.8  
 15. Hrs Generator On-Line 506.8 1,239.2 89,536.9  
 16. Unit Reserve Shtdwn Hrs .0 .0 702.9  
 17. Gross Therm Ener (MWH) 1,205,019 2,942,256 189,051,279  
 18. Gross Elec Ener (MWH) 395,832 969,059 60,385,831  
 19. Net Elec Ener (MWH) 377,921 926,094 56,801,759  
 20. Unit Service Factor 75.4 87.5 74.6  
 21. Unit Avail Factor 75.4 87.5 75.1  
 22. Unit Cap Factor (MDC Net) 73.1 85.0 61.5  
 23. Unit Cap Factor (DER Net) 71.3 82.9 59.9  
 24. Unit Forced Outage Rate .0 .9 7.9  
 25. Forced Outage Hours .0 11.6 3,829.8  
 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE  
 27. If Currently Shutdown Estimated Startup Date: 03/04/86

\*\*\*\*\*  
\* QUAD CITIES 2 \*  
\*\*\*\*\*  
AVERAGE DAILY POWER LEVEL (MWe) PLOT

QUAD CITIES 2



FEBRUARY 1986

Report Period FEB 1986

## UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
 \* QUAD CITIES 2 \*  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
86-5	02/06/86	F	0.0	H	5		AA	HTEXCH	DROPPED LOAD DUE TO GSEP UNUSUAL EVENT - HPCI AND RCIC ROOM COOLERS OUT OF SERVICE (LOAD DROP TERMINATED 4 HOURS AT 590 MWE).
86-6	02/08/86	S	0.0	H	5		RC	CONROD	LOAD REDUCED TO 698 MWE TO RETURN CONTROL ROD D-3 TO SERVICE.
86-7	02/21/86	S	165.2	B	2		ZZ	ZZZZZ	UNIT SHUTDOWN FOR SHORT SCHEDULED MAINTENANCE OUTAGE.

\*\*\*\*\*  
 \* SUMMARY \*  
 \*\*\*\*\*

QUAD CITIES 2 EXPERIENCED 1 SHUTDOWN FOR MAINTENANCE IN FEBRUARY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	1-Manual
S-Sched	B-Maint or Test	G-Oper Error	2-Manual Scram
	C-Refueling	H-Other	3-Auto Scram
	D-Regulatory Restriction		4-Continued
	E-Operator Training & License Examination		5-Reduced Load
			9-Other
			Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161)

\*\*\*\*\*  
\* QUAD CITIES 2 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1986

FACILITY DESCRIPTION

LOCATION  
STATE.....ILLINOIS

COUNTY.....ROCK ISLAND

DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...20 MI NE OF  
MOLINE, ILL

TYPE OF REACTOR.....BWR

DATE INITIAL CRITICALITY...APRIL 26, 1972

DATE ELEC ENER 1ST GENER...MAY 23, 1972

DATE COMMERCIAL OPERATE....MARCH 10, 1973

CONDENSER COOLING METHOD...ONCE THRU

CONDENSER COOLING WATER....MISSISSIPPI RIVER

ELECTRIC RELIABILITY  
COUNCIL.....MID-AMERICA  
INTERPOOL NETWORK

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....COMMONWEALTH EDISON

CORPORATE ADDRESS.....P.O. BOX 767  
CHICAGO, ILLINOIS 60690

CONTRACTOR  
ARCHITECT/ENGINEER.....SARGENT & LUNDY

NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC

CONSTRUCTOR.....UNITED ENG. & CONSTRUCTORS

TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III

IE RESIDENT INSPECTOR.....A. MADISON

LICENSING PROJ MANAGER.....R. BEVAN  
DOCKET NUMBER.....50-265

LICENSE & DATE ISSUANCE....DPR-30, DECEMBER 14, 1972

PUBLIC DOCUMENT ROOM.....MOLINE PUBLIC LIBRARY  
504 17TH STREET  
MOLINE, ILLINOIS 61265

I N S P E C T I O N     S T A T U S

INSPECTION SUMMARY

INSPECTION ON OCTOBER 1 THROUGH DECEMBER 7 (85030): ROUTINE, UNANNOUNCED INSPECTION BY THE RESIDENT INSPECTORS OF ACTIONS ON PREVIOUS INSPECTIONS FINDINGS; OPERATIONS; RADIOLOGICAL CONTROLS; MAINTENANCE/ MODIFICATIONS; SURVEILLANCE; HOUSEKEEPING PROCEDURES; FIRE PROTECTION; EMERGENCY PREPAREDNESS; SECURITY; QUALITY ASSURANCE; QUALITY CONTROL; ADMINISTRATION; ROUTINE REPORTS, LER REVIEW; BULLETIN FOLLOWUP; REGIONAL REQUESTS; TRAINING; AND INDEPENDENT INSPECTION. THE INSPECTION INVOLVED A TOTAL OF 399 INSPECTOR-HOURS ONSITE BY THREE NRC INSPECTORS, INCLUDING 79 INSPECTOR-HOURS ONSITE DURING OFF-SHIFTS. TWO VIOLATIONS WERE IDENTIFIED. THE FIRST INVOLVED FAILURE TO COMPLY WITH TECHNICAL SPECIFICATION REQUIREMENTS CONCERNING FIRE DETECTION EQUIPMENT ON THE REFUEL FLOOR. THE SECOND INVOLVED INADEQUATE REVIEW AND CORRECTIVE ACTIONS CONCERNING A 10 CFR PART 21 REPORT ON RUSKIN FIRE DAMPERS. OVERALL, THE LICENSEE'S PERFORMANCE HAS IMPROVED IN OPERATIONS AND REMAINED STEADY IN ALL OTHER AREAS.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

Report Period FEB 1986

I N S P E C T I O N      S T A T U S - (CONTINUED)

\*\*\*\*\*  
\* QUAD CITIES 2 \*  
\*\*\*\*\*

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

UNIT IS OPERATING NORMALLY.

LAST IE SITE INSPECTION DATE: FEBRUARY 10 - 14, 1986

INSPECTION REPORT NO: 86004

R E P O R T S   F R O M   L I C E N S E E


NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
85-23	12/26/85	01/16/85	HIGH PRESSURE COOLANT INJECTION INOPERABLE DUE TO MO-2-2301-4 VALVE UNABLE TO OPEN

1. Docket: 50-312 OPERATING STATUS  
 2. Reporting Period: 02/01/86 Outage + On-line Hrs: 672.0  
 3. Utility Contact: RON COLOMBO (916) 452-3211  
 4. Licensed Thermal Power (MWt): 2772  
 5. Nameplate Rating (Gross MWe): 1070 X 0.9 = 963  
 6. Design Electrical Rating (Net MWe): 918  
 7. Maximum Dependable Capacity (Gross MWe): 917  
 8. Maximum Dependable Capacity (Net MWe): 873  
 9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE  
 10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_  
 11. Reasons for Restrictions, If Any:  
NONE  
 12. Report Period Hrs      MONTH      YEAR      CUMULATIVE  
672.0      1,416.0      95,281.0  
 13. Hours Reactor Critical      .0      .0      52,565.0  
 14. Rx Reserve Shtdwn Hrs      .0      .0      10,647.7  
 15. Hrs Generator On-Line      .0      .0      50,363.8  
 16. Unit Reserve Shtdwn Hrs      .0      .0      1,210.2  
 17. Gross Therm Ener (MWH)      0      0      124,228,535  
 18. Gross Elec Ener (MWH)      0      0      41,528,149  
 19. Net Elec Ener (MWH)      0      0      39,078,111  
 20. Unit Service Factor      .0      .0      52.9  
 21. Unit Avail Factor      .0      .0      54.1  
 22. Unit Cap Factor (MDC Net)      .0      .0      47.0  
 23. Unit Cap Factor (DER Net)      .0      .0      44.7  
 24. Unit Forced Outage Rate      100.0      100.0      31.2  
 25. Forced Outage Hours      672.0      1,416.0      22,801.5  
 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE  
 27. If Currently Shutdown Estimated Startup Date: 04/18/86

\*\*\*\*\*  
\* RANCHO SECO 1 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

RANCHO SECO 1



FEBRUARY 1986

Report Period FEB 1986

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
X RANCHO SECO 1  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
1	12/26/86	F	672.0	A	4	85-25	CB	INSTRU	REACTOR TRIP ON HIGH PRESSURE. TOTAL LOSS OF ALL ICS POWER. CORRECTIVE ACTIONS BEING IMPLEMENTED.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*

Type	Reason	Method	System & Component	
F-Forced	A-Equip Failure	F-Admin	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	2-Manual Scram	Instructions for Preparation of
	C-Refueling	H-Other	3-Auto Scram	Data Entry Sheet
	D-Regulatory Restriction		4-Continued	Licensee Event Report
	E-Operator Training & License Examination		5-Reduced Load	(LER) File (NUREG-0161)
			9-Other	

\*\*\*\*\*  
\* RANCHO SECO 1 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1986

FACILITY DESCRIPTION

LOCATION  
STATE.....CALIFORNIA  
COUNTY.....SACRAMENTO  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...25 MI SE OF  
SACRAMENTO, CA  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...SEPTEMBER 16, 1974  
DATE ELEC ENER 1ST GENER...OCTOBER 13, 1974  
DATE COMMERCIAL OPERATE....APRIL 17, 1975  
CONDENSER COOLING METHOD...COOLING TOWERS  
CONDENSER COOLING WATER....FOLSOM CANAL  
ELECTRIC RELIABILITY  
COUNCIL.....WESTERN SYSTEMS  
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....SACRAMENTO MUN. UTIL. DISTRICT  
CORPORATE ADDRESS.....6201 S STREET P.O. BOX 15830  
SACRAMENTO, CALIFORNIA 95813  
CONTRACTOR  
ARCHITECT/ENGINEER.....BECHTEL  
NUC STEAM SYS SUPPLIER...BABCOCK & WILCOX  
CONSTRUCTOR.....BECHTEL  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....V  
IE RESIDENT INSPECTOR.....J. ECKHARD  
LICENSING PROJ MANAGER....S. MINER  
DOCKET NUMBER.....50-312  
LICENSE & DATE ISSUANCE....DPR-54, AUGUST 16, 1974  
PUBLIC DOCUMENT ROOM.....BUSINESS AND MUNICIPAL DEPARTMENT  
SACRAMENTO CITY - COUNTY LIBRARY  
828 I STREET  
SACRAMENTO, CALIFORNIA 95814

I N S P E C T I O N     S T A T U S

INSPECTION SUMMARY

- + INSPECTION ON NOVEMBER 4 - DECEMBER 22, 1985 (REPORT NO. 50-312/85-34) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.
- + INSPECTION ON JANUARY 6-10, 1986 (REPORT NO. 50-312/86-01) AREAS INSPECTED: THIS ROUTINE, UNANNOUNCED INSPECTION CONSISTED OF A REVIEW OF OPEN ITEMS, AND THE PROGRAM PLAN, PROCEDURES, RECORDS PERTAINING TO THE RANCHO SECO INSERVICE TESTING PROGRAM FOR PUMPS AND VALVES. DURING THIS INSPECTION, VARIOUS INSPECTION PROCEDURES WERE UTILIZED. THE INSPECTION INVOLVED 44 INSPECTOR-HOURS ONSITE BY ONE NRC INSPECTOR.
- RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.
- + INSPECTION ON APRIL 14-25, 1986 (REPORT NO. 50-312/86-02) INSPECTION TO BE COMPLETED IN APRIL 1986.
- + INSPECTION ON FEBRUARY 3-7, 1986 (REPORT NO. 50-312/86-04) AREAS INSPECTED: SECURITY PLAN AND PROCEDURES; MANAGEMENT EFFECTIVENESS; SECURITY ORGANIZATION; RECORDS AND REPORTS; TESTING AND MAINTENANCE; LOCKS, KEYS AND COMBINATIONS; PHYSICAL BARRIERS - PA; PHYSICAL BARRIERS - VA; LIGHTING; COMPENSATORY MEASURE; ASSESSMENT AIDS; ACCESS CONTROL - PERSONNEL; ACCESS CONTROL - PACKAGES; ACCESS CONTROL - VEHICLES; DETECTION AIDS - PA; DETECTION AIDS - VA; ALARM STATIONS; COMMUNICATIONS; CONTINGENCY PLAN IMPLEMENTING PROCEDURES, AND FOLLOWUP ON LICENSEE AND INSPECTOR IDENTIFIED ITEMS. DURING THIS INSPECTION, VARIOUS INSPECTION PROCEDURES WERE UTILIZED. THE INSPECTION WAS IN TWO PARTS, BOTH CONDUCTED SIMULTANEOUSLY AND INDEPENDENT OF EACH OTHER. PART ONE FOLLOWED UP ON ITEMS IDENTIFIED FOR ADDITIONAL REVIEW AS A RESULT OF A TEAM INSPECTION CONDUCTED IN NOVEMBER AND DECEMBER, 1985.

Report Period FEB 1986

I N S P E C T I O N      S T A T U S - (C O N T I N U E D)

\*\*\*\*\*  
X RANCHO SECO 1  
\*\*\*\*\*

#### INSPECTION SUMMARY

PART TWO REVIEWED CONCERNS RELATED TO PERCEIVED SAFETY SECURITY INTERFACE PROBLEMS AT RANCHO SECO. THE INSPECTION INVOLVED 323 INSPECTOR-HOURS ONSITE BY SEVEN NRC INSPECTORS.

RESULTS: THE LICENSEE WAS FOUND TO BE IN VIOLATION OF NRC REQUIREMENTS WITHIN THE FOLLOWING AREAS INSPECTED: RECORDS AND REPORTS (ONE INSTANCE OF VIOLATION); PHYSICAL BARRIERS - VA (NINE INSTANCES OF VIOLATION); ACCESS CONTROL - PERSONNEL (FOURTEEN INSTANCES OF VIOLATION); ACCESS CONTROL - VEHICLES (ONE INSTANCE OF VIOLATION); DETECTION AIDS - VA (THREE INSTANCES OF VIOLATION); DETECTION AIDS ALARM ASSESSMENT (THREE INSTANCES OF VIOLATION); COMPENSATORY MEASURES (THREE INSTANCES OF VIOLATION).

- + INSPECTION ON JANUARY 16 - FEBRUARY 19, 1986 (REPORT NO. 50-312/86-05) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.
- + INSPECTION ON JANUARY 16 - FEBRUARY 3, 1986 (REPORT NO. 50-312/86-06) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.
- + INSPECTION ON JANUARY 27 - MARCH 31, 1986 (REPORT NO. 50-312/86-07) INSPECTION CONTINUING TO BE REPORTED NEXT MONTH.
- + INSPECTION ON FEBRUARY 3 - MARCH 7, 1986 (REPORT NO. 50-312/86-08) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.
- + MEETING ON FEBRUARY 10, 1986 (REPORT NO. 50-312/86-09) AREAS INSPECTED: MANAGEMENT MEETING TO DISCUSS PROPOSED ACTIONS BY LICENSEE TO BE RESOLVED PRIOR TO RESTART OF RANCHO SECO FROM THE DECEMBER 26, 1985 OUTAGE WHICH RESULTED IN AN EXCESSIVE COOLDOWN TRANSIENT. THE MEETING INVOLVED 80 HOURS BY VARIOUS REGION V NRC PERSONNEL.

RESULTS: THIS MEETING DID NOT INVOLVE DIRECT INSPECTION OF LICENSEE ACTIVITIES.

- + INSPECTION ON MARCH 3-7, 1986 (REPORT NO. 50-312/86-10) INSPECTION TO BE COMPLETED NEXT MONTH.
- + INSPECTION ON FEBRUARY 24 - MARCH 6, 1986 (REPORT NO. 50-312/86-11) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.
- + EXAMINATIONS ON FEBRUARY 4-6, 1986 (REPORT NO. 50-312/OL-86-01) WRITTEN EXAMINATIONS WERE ADMINISTERED TO TWO REACTOR OPERATOR CANDIDATES AND SIX SENIOR OPERATOR CANDIDATES. TWO REACTOR OPERATOR CANDIDATES PASSED THE WRITTEN EXAMINATIONS. ONE REACTOR OPERATOR CANDIDATE RECEIVED A WAIVER OF THE OPERATING EXAMINATION AND ONE REACTOR OPERATOR CANDIDATE PASSED THE OPERATING EXAMINATION. SIX SENIOR REACTOR OPERATOR CANDIDATES PASSED THE WRITTEN EXAMINATION. FIVE SENIOR REACTOR OPERATOR CANDIDATES PASSED THE OPERATING EXAMINATION, WHILE ONE SENIOR REACTOR OPERATOR CANDIDATE FAILED THE OPERATING EXAMINATION.

#### ENFORCEMENT SUMMARY

FAILURE TO SEARCH AND BADGE TWO PERSONS BEFORE GRANTING ACCESS TO THE PROTECTED AREA.  
(8503 4)

#### OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

INTEGRATED CONTROL SYSTEM UNDER REVIEW FOLLOWING EXCESSIVE COOLDOWN RATE PRODUCED WHEN SYSTEM LOST DC POWER AT 100% REACTOR POWER.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

Report Period FEB 1986

INSPECTION STATUS - (CONTINUED)

RANCHO SECO 1

OTHER ITEMS

MANAGERIAL ITEMS:

REGION V AND SPECIAL IIT CONDUCTED POST-DECEMBER 26, 1985 EVENT INVESTIGATIONS DURING THE ENTIRE MONTH.

+ RESTART ACTION PLAN IMPLEMENTATION IS BEING REVIEWED BY REGION V PRIOR TO RETURN TO OPERATION.

PLANT STATUS:

PLANT REMAINS IN COLD SHUTDOWN FOLLOWING PLANT TRIP FROM 100% DUE TO LOSS OF ICS DC POWER ON DECEMBER 26, 1985.

LAST IE SITE INSPECTION DATE: 04/14-25/86

INSPECTION REPORT NO: 56-312/86-02

REPORTS FROM LICENSEE

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
85-23-L0	12-05-85	01-02-86	HIGH PRESSURE REACTOR TRIP RESULTING FROM STEAM GENERATOR UNDERFEED (ICS ELECTRICAL TRANSIENT, STUCK RECORDER PEN, OPERATOR ERROR)
85-25-L0	12-26-85	01-20-86	REACTOR TRIP FOLLOWING LOSS OF ICS POWER

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-458 OPERATING STATUS  
 2. Reporting Period: 02/01/86 Outage + On-line Hrs: 672.0  
 3. Utility Contact: J. H. SIMMONS (504) 635-6094  
 4. Licensed Thermal Power (MWh): 2894  
 5. Nameplate Rating (Gross MWe): 2894  
 6. Design Electrical Rating (Net MWe): 936  
 7. Maximum Dependable Capacity (Gross MWe): 936  
 8. Maximum Dependable Capacity (Net MWe): 936  
 9. If Changes Occur Above Since Last Report, Give Reasons:  
 \_\_\_\_\_

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

11. Reasons for Restrictions, If Any: \_\_\_\_\_

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>672.0</u>	<u>672.0</u>	<u>672.0</u>
13. Hours Reactor Critical	<u>379.9</u>	<u>379.9</u>	<u>379.9</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>248.7</u>	<u>248.7</u>	<u>248.7</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>213,169</u>	<u>213,169</u>	<u>213,169</u>
18. Gross Elec Ener (MWH)	<u>47,246</u>	<u>47,246</u>	<u>47,246</u>
19. Net Elec Ener (MWH)	<u>39,442</u>	<u>39,442</u>	<u>39,442</u>

20. Unit Service Factor

21. Unit Avail Factor NOT IN

22. Unit Cap Factor (MDC Net) COMMERCIAL

23. Unit Cap Factor (DER Net) OPERATION

24. Unit Forced Outage Rate

25. Forced Outage Hours 124.8 124.8 124.8

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


NONE

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
X RIVER BEND 1 X  
\*\*\*\*\*

#### AVERAGE DAILY POWER LEVEL (MWh) PLOT

RIVER BEND 1



FEBRUARY 1986

Report Period FEB 1986

## UNIT SHUTDOWN / REDUCTIONS

\*\*\*\*\*  
 \* RIVER BEND 1 \*  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
1	02/01/86	F	79.5	A	2				CONTINUED FROM JAN. CNTMT PURGE VLV FAILED STP. SHUTDOWN REQUIRED BY TECHNICAL SPECIFICATIONS.
2	02/04/86	F	0.0	A	5				LOSS OF "A" FEEDPUMP STARTED "B" FEEDPUMP AND RETURNED AND RETURNED UNIT ON LINE.
3	02/12/86	F	45.3	H	2				TURBINE/RX TRIP DUE TO MSR HIGH LEVEL.
4	02/14/86	S	298.5	B	2				SCRAM INITIATED AS PART OF ST-28. SHUTDOWN FROM OUTSIDE CONTROL ROOM. REMOTE SHUTDOWN PANEL TEST.

\*\*\*\*\*  
 \* RIVER BEND 1 INCURRED 3 SHUTDOWNS IN FEBRUARY AS DESCRIBED ABOVE.  
 \* SUMMARY \*  
 \*\*\*\*\*

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	Instructions for Preparation of Data Entry Sheet
	C-Refueling	H-Other	Licensee Event Report (LER) File (NUREG-0161)
	D-Regulatory Restriction		
	E-Operator Training & License Examination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	

\*\*\*\*\*  
\* RIVER BEND 1 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1986

FACILITY DESCRIPTION

LOCATION  
STATE.....LOUISIANA  
COUNTY.....WEST FELICIANA  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...24 MI NNW OF  
BATON ROUGE, LA  
TYPE OF REACTOR.....BWR  
DATE INITIAL CRITICALITY...OCTOBER 31, 1985  
DATE ELEC ENER 1ST GENER...DECEMBER 3, 1985  
DATE COMMERCIAL OPERATE....\*\*\*\*\*  
CONDENSER COOLING METHOD...MDCT  
CONDENSER COOLING WATER....MISSISSIPPI RIVER  
ELECTRIC RELIABILITY  
COUNCIL.....SOUTHWEST POWER POOL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....GULF STATES UTILITIES  
CORPORATE ADDRESS.....P.O. BOX 2951  
BEAUMONT, LOUISIANA 77704  
CONTRACTOR  
ARCHITECT/ENGINEER.....STONE & WEBSTER  
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC  
CONSTRUCTOR.....STONE & WEBSTER  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....IV  
IE RESIDENT INSPECTOR.....D. CHAMBERLAIN  
LICENSING PROJ MANAGER.....S. STERN  
DOCKET NUMBER.....50-458  
LICENSE & DATE ISSUANCE....NPF-47, NOVEMBER 20, 1985  
PUBLIC DOCUMENT ROOM.....

828 I STREET  
SACRAMENTO, CALIFORNIA 95814

I N S P E C T I O N     S T A T U S

INSPECTION SUMMARY

INFO. NOT SUPPLIED BY REGION

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

INFO. NOT SUPPLIED BY REGION

FACILITY ITEMS (PLANS AND PROCEDURES):

INFO. NOT SUPPLIED BY REGION

MANAGERIAL ITEMS:

INFO. NOT SUPPLIED BY REGION

Report Period FEB 1986

I N S P E C T I O N      S T A T U S - (CONTINUED)

\*\*\*\*\*  
\* RIVER BEND 1 \*  
\*\*\*\*\*

PLANT STATUS:

INFO. NOT SUPPLIED BY REGION

LAST IE SITE INSPECTION DATE: INFO. NOT SUPPLIED BY REGION

INSPECTION REPORT NO: INFO. NOT SUPPLIED BY REGION

R E P O R T S   F R O M   L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
--------	------------------	-------------------	---------

=====


INFO. NOT SUPPLIED BY REGION

=====

1. Docket: 50-261 OPERATING STATUS  
 2. Reporting Period: 02/01/86 Outage + On-line Hrs: 672.0  
 3. Utility Contact: ANITA E. SCOTT (803) 383-4524  
 4. Licensed Thermal Power (MWt): 2300  
 5. Nameplate Rating (Gross MWe): 854 X 0.9 = 769  
 6. Design Electrical Rating (Net MWe): 700  
 7. Maximum Dependable Capacity (Gross MWe): 700  
 8. Maximum Dependable Capacity (Net MWe): 665  
 9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE  
 10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_  
 11. Reasons for Restrictions, If Any:  
NONE  
 12. Report Period Hrs      MONTH      YEAR      CUMULATIVE  
672.0      1,416.0      131,406.0  
 13. Hours Reactor Critical      .0      567.4      92,624.0  
 14. Rx Reserve Shtdwn Hrs      .0      154.5      2,810.1  
 15. Hrs Generator On-Line      .0      563.1      90,331.0  
 16. Unit Reserve Shtdwn Hrs      .0      .0      23.2  
 17. Gross Therm Ener (MWH)      0      952,597      180,444,510  
 18. Gross Elec Ener (MWH)      0      318,422      58,177,913  
 19. Net Elec Ener (MWH)      -1,569      296,205      54,945,779  
 20. Unit Service Factor      .0      39.8      68.7  
 21. Unit Avail Factor      .0      39.8      68.8  
 22. Unit Cap Factor (MDC Net)      .0      31.5      62.9  
 23. Unit Cap Factor (DER Net)      .0      29.9      59.7  
 24. Unit Forced Outage Rate      .0      24.3      14.2  
 25. Forced Outage Hours      .0      180.9      9,225.9  
 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE  
 27. If Currently Shutdown Estimated Startup Date: 03/17/86

\*\*\*\*  
 \* ROBINSON 2 \*  
 \*\*\*\*  
 AVERAGE DAILY POWER LEVEL (MWe) PLOT

ROBINSON 2



FEBRUARY 1986

Report Period FEB 1986

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* ROBINSON 2 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
0201	01/28/86	S	672.0	C	4		RC	FUELXX	A REACTOR TRIP OCCURRED ON 01/28/86, DUE TO A BLOWN UNDER VOLTAGE FUSE ON EMERGENCY BUS NO. 2. THE FUSE WAS REPLACED. THE UNIT REMAINED IN THE SHUTDOWN MODE AND BEGAN THE PLANNED REFUELING OUTAGE ON 02/01/86.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*

ROBINSON 2 IS PRESENTLY SHUT DOWN FOR REFUELING.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	1-Manual
S-Sched	B-Maint or Test	G-Oper Error	2-Manual Scram
	C-Refueling	H-Other	3-Auto Scram
	D-Regulatory Restriction		4-Continued
	E-Operator Training & License Examination		5-Reduced Load
			9-Other
			Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161)

\*\*\*\*\*  
\* ROBINSON 2 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1986

FACILITY DESCRIPTION

LOCATION STATE.....SOUTH CAROLINA  
COUNTY.....DARLINGTON  
DIST AND DIRECTION FROM NEAREST POPULATION CTR...5 MI NW OF HARTSVILLE, SC  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...SEPTEMBER 20, 1970  
DATE ELEC ENER 1ST GENER...SEPTEMBER 26, 1970  
DATE COMMERCIAL OPERATE....MARCH 7, 1971  
CONDENSER COOLING METHOD...RECIRCULATION  
CONDENSER COOLING WATER....ROBINSON IMPOUNDMENT  
ELECTRIC RELIABILITY COUNCIL.....SOUTHEASTERN ELECTRIC RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY LICENSEE.....CAROLINA POWER & LIGHT  
CORPORATE ADDRESS.....411 FAYETTEVILLE STREET RALEIGH, NORTH CAROLINA 27601

CONTRACTOR ARCHITECT/ENGINEER.....EBASCO

NUC STEAM SYS SUPPLIER...WESTINGHOUSE

CONSTRUCTOR ..... EBASCO

TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II

IE RESIDENT INSPECTOR.....P. KRUG

LICENSING PROJ MANAGER.....G. REQUA  
DOCKET NUMBER.....50-261

LICENSE & DATE ISSUANCE....DPR-23, SEPTEMBER 23, 1970

PUBLIC DOCUMENT ROOM.....HARTSVILLE MEMORIAL LIBRARY  
220 N. FIFTH ST.  
HARTSVILLE, SOUTH CAROLINA 29550

I N S P E C T I O N     S T A T U S

INSPECTION SUMMARY

+ INSPECTION DECEMBER 11 - JANUARY 10, 1986 (85-36): THIS ROUTINE, ANNOUNCED INSPECTION INVOLVED 111 RESIDENT INSPECTOR-HOURS ON SITE IN THE AREAS OF TECHNICAL SPECIFICATION (TS) COMPLIANCE, PLANT TOUR, OPERATIONS PERFORMANCE, REPORTABLE OCCURRENCES, HOUSEKEEPING, SITE SECURITY, SURVEILLANCE ACTIVITIES, MAINTENANCE ACTIVITIES, QUALITY ASSURANCE PRACTICES, RADIATION CONTROL ACTIVITIES, OUTSTANDING ITEMS REVIEW, IE NOTICE FOLLOWUP, ORGANIZATION AND ADMINISTRATION, INDEPENDENT INSPECTION, AND SYSTEMATIC ASSESSMENT OF LICENSEE PERFORMANCE (SALP). NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED IN THE AREAS INSPECTED.

INSPECTION JANUARY 21-24 (86-02): THIS ROUTINE, UNANNOUNCED INSPECTION ENTAILED 32 INSPECTOR-HOURS ON SITE IN THE AREAS OF QUALITY ASSURANCE (QA)/QUALITY CONTROL (QC) ADMINISTRATION; QA PROGRAM ANNUAL REVIEW; AND LICENSEE ACTION ON PREVIOUS ENFORCEMENT MATTERS. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

Report Period FEB 1986

INSPECTION STATUS - (CONTINUED)

\*\*\*\*\*  
\* ROBINSON 2 \*  
\*\*\*\*\*

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

NORMAL OPERATION.

LAST IE SITE INSPECTION DATE: JANUARY 21-24, 1986 +

INSPECTION REPORT NO: 50-261/86-02 +


REPORTS FROM LICENSEE

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
-----			
NONE.			
-----			

=====

1. Docket: 50-272 OPERATING STATUS  
 2. Reporting Period: 02/01/86 Outage + On-line Hrs: 672.0  
 3. Utility Contact: PELL WHITE (609) 935-6000 X4451  
 4. Licensed Thermal Power (MWh): 3338  
 5. Nameplate Rating (Gross MWe): 1300 X 0.9 = 1170  
 6. Design Electrical Rating (Net MWe): 1090  
 7. Maximum Dependable Capacity (Gross MWe): 1124  
 8. Maximum Dependable Capacity (Net MWe): 1079  
 9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE  
 10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_  
 11. Reasons for Restrictions, If Any:  
NONE  
 12. Report Period Hrs MONTH YEAR CUMULATIVE  
     672.0 1,416.0 75,985.0  
 13. Hours Reactor Critical 620.6 1,331.8 45,517.2  
 14. Rx Reserve Shtdn Hrs .0 .0 3,088.4  
 15. Hrs Generator On-Line 574.4 1,261.2 43,765.8  
 16. Unit Reserve Shtdn Hrs .0 .0 .0  
 17. Gross Therm Ener (MWH) 1,816,716 4,279,162 134,765,397  
 18. Gross Elec Ener (MWH) 601,380 1,354,500 44,648,308  
 19. Net Elec Ener (MWH) 573,578 1,295,684 42,401,676  
 20. Unit Service Factor 85.5 89.1 57.6  
 21. Unit Avail Factor 85.5 89.1 57.6  
 22. Unit Cap Factor (MDC Net) 79.1 84.8 51.7  
 23. Unit Cap Factor (DER Net) 78.3 83.9 51.2  
 24. Unit Forced Outage Rate 14.5 10.9 29.6  
 25. Forced Outage Hours 97.6 154.8 18,643.6  
 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
REFUELING: MARCH 22, 1986 - 60 DAYS.  
 27. If Currently Shutdown Estimated Startup Date: N/A



Report Period FEB 1986

## UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* SALEM 1 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
144	01/31/86	F	45.1	A	4		CH	VALVEX	FEEDWATER REGULATING BOILER LEVEL CONTROL VALVES.
150	02/04/86	F	13.0	A	1		HA	VALVEX	LUBE OIL SYSTEMS VALVES AND TYPING TURBINE.
202	02/20/86	F	39.5	A	3				STEAM GENERATOR CONTROL.
232	02/24/86	F	0.0	B	5		HC	HTEXCH	CONDENSER TUBE AND WATER BOX CLEANING.
240	02/25/86	F	0.0	A	5		HC	HTEXCH	CONDENSER TUBE FOULING TUBE SIDE DIRTY CONDENSER.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
SALEM 1 INCURRED 3 SHUTDOWNS AND 2 REDUCTIONS IN FEBRUARY AS DISCUSSED ABOVE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	
S-Sched	B-Maint or Test	G-Oper Error	1-Manual
	C-Refueling	H-Other	2-Manual Scram
	D-Regulatory Restriction		3-Auto Scram
	E-Operator Training & License Examination		4-Continued
			5-Reduced Load
			9-Other
			Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161)

\*\*\*\*\*  
\* SALEM 1 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1986

FACILITY DESCRIPTION

LOCATION STATE.....NEW JERSEY  
COUNTY.....SALEM  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...20 MI S OF  
WILMINGTON, DEL  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...DECEMBER 11, 1976  
DATE ELEC ENER 1ST GENER...DECEMBER 25, 1976  
DATE COMMERCIAL OPERATE....JUNE 30, 1977  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER....DELAWARE RIVER  
ELECTRIC RELIABILITY  
COUNCIL.....MID-ATLANTIC  
AREA COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....PUBLIC SERVICE ELECTRIC & GAS  
CORPORATE ADDRESS.....80 PARK PLACE  
NEWARK, NEW JERSEY 07101  
CONTRACTOR  
ARCHITECT/ENGINEER.....PUBLIC SERVICES & GAS CO.  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
CONSTRUCTOR.....UNITED ENG. & CONSTRUCTORS  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I  
IE RESIDENT INSPECTOR.....T. LINVILLE  
LICENSING PROJ MANAGER.....D. FISCHER  
DOCKET NUMBER.....50-272  
LICENSE & DATE ISSUANCE....DPR-70, DECEMBER 1, 1976  
PUBLIC DOCUMENT ROOM.....SALEM FREE PUBLIC LIBRARY  
112 WEST BROADWAY  
SALEM, NEW JERSEY 08079

I N S P E C T I O N     S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

Report Period FEB 1986

INSPECTION STATUS - (CONTINUED)

\*\*\*\*\*  
\* SALEM 1 \*  
\*\*\*\*\*

OTHER ITEMS

#### **MANAGERIAL ITEMS:**

NO INPUT PROVIDED.

**PLANT STATUS:**

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

REPORTS FROM LICENSEE


NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
--------	------------------	-------------------	---------

NO INPUT PROVIDED.

1. Docket: 50-311 OPERATING STATUS  
 2. Reporting Period: 02/01/86 Outage + On-line Hrs: 672.0  
 3. Utility Contact: PELL WHITE (609) 935-6000 X4451  
 4. Licensed Thermal Power (MWt): 3411  
 5. Nameplate Rating (Gross MWe): 1162  
 6. Design Electrical Rating (Net MWe): 1115  
 7. Maximum Dependable Capacity (Gross MWe): 1149  
 8. Maximum Dependable Capacity (Net MWe): 1106  
 9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE  
 10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_  
 11. Reasons for Restrictions, If Any:  
NONE  
 12. Report Period Hrs      MONTH      YEAR      CUMULATIVE  
672.0      1,416.0      38,401.0  
 13. Hours Reactor Critical      629.7      986.7      21,312.4  
 14. Rx Reserve Shtdwn Hrs      .0      .0      3,533.6  
 15. Hrs Generator On-Line      618.9      968.7      20,505.5  
 16. Unit Reserve Shtdwn Hrs      .0      .0      .0  
 17. Gross Therm Ener (MWH)      2,066,002      3,174,315      62,920,013  
 18. Gross Elec Ener (MWH)      686,220      1,054,650      20,631,130  
 19. Net Elec Ener (MWH)      657,468      1,006,067      19,540,922  
 20. Unit Service Factor      92.1      68.4      53.4  
 21. Unit Avail Factor      92.1      68.4      53.4  
 22. Unit Cap Factor (MDC Net)      88.5      64.2      46.0  
 23. Unit Cap Factor (DER Net)      87.7      63.7      45.6  
 24. Unit Forced Outage Rate      7.9      31.6      40.1  
 25. Forced Outage Hours      53.1      447.3      13,742.9  
 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE  
 27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
 \* SALEM 2 \*  
 \*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT  
 SALEM 2



FEBRUARY 1986

Report Period FEB 1986

## UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
 \* SALEM 2  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
040	01/19/86	F	53.1	A	4				REACTOR COOLANT PUMP SEALS.
042	02/03/86	F	0.0	A	5		CH	INSTRU	FEEDWATER PUMP LOCAL CONTROLS.
068	02/22/86	F	0.0	A	5		HF	PUMPXX	INTAKE SYSTEMS PROBLEMS OTHER VAN TRAVELINGS SCREENS.
086	02/27/86	F	0.0	A	5		HF	FILTER	TRAVELING SCREEN/TRASH RACK/CANAL SCREEN.

\*\*\*\*\*  
 \* SUMMARY \*  
 \*\*\*\*\*

SALEM 2 OPERATED IN FEBRUARY WITH 1 OUTAGE AND 3 REDUCTIONS AS DISCUSSED ABOVE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	Instructions for Preparation of
	C-Refueling	H-Other	Data Entry Sheet
	D-Regulatory Restriction		Licensee Event Report
	E-Operator Training		(LER) File (NUREG-0161)
	& License Examination		

\*\*\*\*\*  
\* SALEM 2 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1986

FACILITY DESCRIPTION

LOCATION  
STATE.....NEW JERSEY  
COUNTY.....SALEM  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...20 MI S OF  
WILMINGTON, DEL  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...AUGUST 8, 1980  
DATE ELEC ENER 1ST GENER...JUNE 3, 1981  
DATE COMMERCIAL OPERATE...OCTOBER 13, 1981  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER....DELAWARE RIVER  
ELECTRIC RELIABILITY  
COUNCIL.....MID-ATLANTIC  
AREA COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....PUBLIC SERVICE ELECTRIC & GAS  
CORPORATE ADDRESS.....80 PARK PLACE  
NEWARK, NEW JERSEY 07101  
CONTRACTOR  
ARCHITECT/ENGINEER.....PUBLIC SERVICES & GAS CO.  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
CONSTRUCTOR.....UNITED ENG. & CONSTRUCTORS  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I  
IE RESIDENT INSPECTOR.....T. LINVILLE  
LICENSING PROJ MANAGER.....D. FISCHER  
DOCKET NUMBER.....50-311  
LICENSE & DATE ISSUANCE....DPR-75, MAY 20, 1981  
PUBLIC DOCUMENT ROOM.....SALEM FREE PUBLIC LIBRARY  
112 WEST BROADWAY  
SALEM, NEW JERSEY 08079

I N S P E C T I O N     S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

Report Period FEB 1986

I N S P E C T I O N      S T A T U S - (CONTINUED)

\*\*\*\*\*  
\*            SALEM 2        \*  
\*\*\*\*\*

OTHER ITEMS

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S   F R O M   L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
--------	------------------	-------------------	---------

=====

NO INPUT PROVIDED.


=====

1. Docket: 50-206 OPERATING STATUS  
 2. Reporting Period: 02/01/86 Outage + On-line Hrs: 672.0  
 3. Utility Contact: E. R. SIACOR (714) 368-6223  
 4. Licensed Thermal Power (MWh): 1347  
 5. Nameplate Rating (Gross MWh): 500 X 0.9 = 450  
 6. Design Electrical Rating (Net MWh): 436  
 7. Maximum Dependable Capacity (Gross MWh): 456  
 8. Maximum Dependable Capacity (Net MWh): 436  
 9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE  
 10. Power Level To Which Restricted, If Any (Net MWh): 390  
 11. Reasons for Restrictions, If Any: \_\_\_\_\_  
STEAM GENERATOR TUBE CORROSION.  
 12. Report Period Hrs 672.0 MONTH 672.0 YEAR 1,416.0 CUMULATIVE 164,000.0  
 13. Hours Reactor Critical .0 .0 96,113.2  
 14. Rx Reserve Shtdwn Hrs .0 .0 .0  
 15. Hrs Generator On-Line .0 .0 92,375.5  
 16. Unit Reserve Shtdwn Hrs .0 .0 .0  
 17. Gross Therm Ener (MWH) 0 0 117,311,124  
 18. Gross Elec Ener (MWH) 0 0 39,829,634  
 19. Net Elec Ener (MWH) -852 -2,092 37,658,985  
 20. Unit Service Factor .0 .0 56.3  
 21. Unit Avail Factor .0 .0 56.3  
 22. Unit Cap Factor (MDC Net) .0 .0 52.6  
 23. Unit Cap Factor (DER Net) .0 .0 52.6  
 24. Unit Forced Outage Rate .0 .0 21.1  
 25. Forced Outage Hours .0 .0 12,129.7  
 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE  
 27. If Currently Shutdown Estimated Startup Date: 05/15/86

\*\*\*\*\*  
\* SAN ONOFRE 1 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWh) PLOT

SAN ONOFRE 1



FEBRUARY 1986

Report Period FEB 1986

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* SAN ONOFRE 1 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System Component	Cause & Corrective Action to Prevent Recurrence
93	11/21/85	S	672.0	C	4			REFUELING/BACKFIT WORK.

\*\*\*\*\* SAN ONOFRE 1 REMAINS SHUT DOWN FOR REFUELING AND BACKFIT.

\* SUMMARY \*

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	Instructions for Preparation of
	C-Refueling	H-Other	Data Entry Sheet
	D-Regulatory Restriction	4-Continued	Licensee Event Report
	E-Operator Training & License Examination	5-Reduced Load	(LER) File (NUREG-0161)
		9-Other	

\*\*\*\*\* SAN ONOFRE 1 \*\*\*\*\*

FACILITY DATA

Report Period FEB 1986

FACILITY DESCRIPTION

LOCATION STATE..... CALIFORNIA  
COUNTY..... SAN DIEGO  
DIST AND DIRECTION FROM NEAREST POPULATION CTR... 5 MI S OF SAN CLEMENTE, CA  
TYPE OF REACTOR..... PWR  
DATE INITIAL CRITICALITY... JUNE 14, 1967  
DATE ELEC ENER 1ST GENER... JULY 16, 1967  
DATE COMMERCIAL OPERATE.... JANUARY 1, 1968  
CONDENSER COOLING METHOD... ONCE THRU  
CONDENSER COOLING WATER.... PACIFIC OCEAN  
ELECTRIC RELIABILITY COUNCIL..... WESTERN SYSTEMS COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY LICENSEE..... SOUTHERN CALIFORNIA EDISON  
CORPORATE ADDRESS..... 2244 WALNUT GROVE AVENUE ROSEMEAD, CALIFORNIA 91770  
CONTRACTOR ARCHITECT/ENGINEER..... BECHTEL  
NUC STEAM SYS SUPPLIER... WESTINGHOUSE  
CONSTRUCTOR..... BECHTEL  
TURBINE SUPPLIER..... WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE..... V  
IE RESIDENT INSPECTOR..... A. DANGELO  
LICENSING PROJ. MANAGER..... H. PAULSON  
DOCKET NUMBER..... 50-206  
LICENSE & DATE ISSUANCE.... DPR-13, MARCH 27, 1967  
PUBLIC DOCUMENT ROOM..... SAN CLEMENTE BRANCH LIBRARY  
242 AVENIDA DEL MAR  
SAN CLEMENTE, CALIFORNIA 92672

I N S P E C T I O N     S T A T U S

INSPECTION SUMMARY

- + INSPECTION ON JANUARY 6 - FEBRUARY 7, 1986 (REPORT NO. 50-206/86-01) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.
- + INSPECTION ON JANUARY 13 - FEBRUARY 7, 1986 (REPORT NO. 50-206/86-02) AREAS INSPECTED: ROUTINE, UNANNOUNCED INSPECTION OF LICENSEE ACTION ON PREVIOUS INSPECTION FINDINGS, REVIEW OF LICENSEE REPORTS, GASEOUS WASTE SYSTEMS, RADIOLOGICAL ENVIRONMENTAL MONITORING, OCCUPATIONAL EXPOSURE DURING EXTENDED OUTAGES, FACILITY TOURS AND FOLLOWUP ON INFORMATION NOTICES. DURING THIS INSPECTION, VARIOUS INSPECTION PROCEDURES WERE IDENTIFIED.
- RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.
- + INSPECTION ON JANUARY 11 - FEBRUARY 14, 1986 (REPORT NO. 50-206/86-04) AREAS INSPECTED: ROUTINE RESIDENT INSPECTION OF OPERATIONS PROGRAM INCLUDING THE FOLLOWING AREAS: OPERATIONAL SAFETY VERIFICATION, EVALUATION OF PLANT TRIPS AND EVENTS, MONTHLY SURVEILLANCE ACTIVITIES, MONTHLY MAINTENANCE ACTIVITIES, ENGINEERED SAFETY FEATURE WALKDOWN, REFUELING ACTIVITIES, LICENSEE EVENT REPORTS REVIEW, AND FOLLOWUP OF PREVIOUSLY IDENTIFIED ITEMS. DURING THIS INSPECTION, VARIOUS INSPECTION PROCEDURES WERE UTILIZED. THE INSPECTION INVOLVED 315 INSPECTOR-HOURS ONSITE BY FIVE NRC INSPECTORS.

RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

- + INSPECTION ON FEBRUARY 10-14, 1986 (REPORT NO. 50-206/86-05) AREAS INSPECTED: ROUTINE, UNANNOUNCED INSPECTION BY REGIONALLY BASED INSPECTORS OF ACTIVITIES ASSOCIATED WITH AUDITS, RECORDS, FIRE PROTECTION, AND LICENSEE ACTION ON INSPECTOR-IDENTIFIED

Report Period FEB 1986

INSPECTION STATUS - (CONTINUED)

\*\*\*\*\*  
\* SAN ONOFRE 1 \*  
\*\*\*\*\*

INSPECTION SUMMARY

ITEMS. DURING THIS INSPECTION, VARIOUS INSPECTION PROCEDURES WERE UTILIZED. THE INSPECTION INVOLVED 70 INSPECTOR-HOURS ONSITE BY TWO NRC INSPECTORS.

RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

+ MEETING ON FEBRUARY 6, 1986 (REPORT NO. 50-206/86-06) AREAS INSPECTED: SPECIAL, ANNOUNCED MEETING WITH LICENSEE REPRESENTATIVES CONCERNING THEIR PLANS TO REDUCE THE QUANTITY OF RADIOACTIVE MATERIAL IN LIQUIDS DISCHARGED FROM THE SITE. DURING THIS MEETING, ONE INSPECTION PROCEDURE WAS ADDRESSED. THE MEETING INVOLVED THREE HOURS ONSITE BY TWO NRC INSPECTORS AND ONE REGION V MANAGEMENT REPRESENTATIVE.

RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

+ INSPECTION ON FEBRUARY 12 - MARCH 8, 1986 (REPORT NO. 50-206/86-07) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

+ MANAGEMENT MEETING ON FEBRUARY 19, 1986 (REPORT NO. 50-206/86-08) THE LICENSEE'S PLAN AND SCHEDULE TO ADDRESS CONCERNS FROM A NOVEMBER 21, 1985, EVENT FOR A MAY 1986 RESTART WERE DISCUSSED. THE MEETING INVOLVED 49 HOURS BY 14 NRC REPRESENTATIVES. + INSPECTION ON FEBRUARY 15 - MARCH 17, 1986 (REPORT NO. 50-206/86-09) INSPECTION CONTINUING; TO BE REPORTED NEXT MONTH.

ENFORCEMENT SUMMARY

CONTRARY TO 10 CFR 50, APPENDIX B, CRITERION XI, ON NOVEMBER 14, 1984, DURING SETPOINT TESTING OF THE TEN UNIT 1 MAIN STEAM SAFETY VALVES, THE AS-FOUND SETPOINT PRESSURE WAS NOT DOCUMENTED FOR SIX OF THE TEN VALVES.  
(8503 5)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

INVESTIGATION FOLLOWING THE NOVEMBER 21, 1985, TRIP AND FEEDWATER HAMMER EVENT DISCLOSED FAILURES OF FIVE MAIN FLOW CHECK VALVES IN THE FEEDWATER SYSTEM (BOTH FEEDMASTER PUMP DISCHARGE CHECK VALVES AND ALL THREE STEAM GENERATOR FEED LINE CHECK VALVES).

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

THE UNIT BEGAN A REFUELING AND MODIFICATION OUTAGE IN LATE NOVEMBER 1985. MODIFICATIONS WILL INCLUDE TMI, FIRE PROTECTION, SEISMIC UPGRADE, AND EQUIPMENT QUALIFICATION ITEMS. RETURN TO OPERATION IS SCHEDULED FOR JUNE 1986.

LAST IE SITE INSPECTION DATE: 02/15-03/17/86+

INSPECTION REPORT NO: 50-206/86-09+

Report Period FEB 1986

I N S P E C T I O N      S T A T U S - (CONTINUED)

\*\*\*\*\*  
\* SAN ONOFRE 1 \*  
\*\*\*\*\*

R E P O R T S   F R O M   L I C E N S E E

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
--------	------------------	-------------------	---------

---

NONE

---

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-361 OPERATING STATUS  
 2. Reporting Period: 02/01/86 Outage + On-line Hrs: 672.0  
 3. Utility Contact: E. R. SIACOR (714) 368-6223  
 4. Licensed Thermal Power (MWh): 3410  
 5. Nameplate Rating (Gross MWe): 1127  
 6. Design Electrical Rating (Net MWe): 1070  
 7. Maximum Dependable Capacity (Gross MWe): 1127  
 8. Maximum Dependable Capacity (Net MWe): 1070  
 9. If Changes Occur Above Since Last Report, Give Reasons:  
 \_\_\_\_\_

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

11. Reasons for Restrictions, If Any: \_\_\_\_\_  
 NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>672.0</u>	<u>1,416.0</u>	<u>22,465.0</u>
13. Hours Reactor Critical	<u>672.0</u>	<u>1,367.5</u>	<u>14,488.4</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>672.0</u>	<u>1,362.0</u>	<u>14,211.7</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>2,044,658</u>	<u>4,308,834</u>	<u>45,844,796</u>
18. Gross Elec Ener (MWH)	<u>681,382</u>	<u>1,446,123</u>	<u>15,416,323</u>
19. Net Elec Ener (MWH)	<u>647,371</u>	<u>1,374,817</u>	<u>14,571,456</u>
20. Unit Service Factor	<u>100.0</u>	<u>96.2</u>	<u>63.3</u>
21. Unit Avail Factor	<u>100.0</u>	<u>96.2</u>	<u>63.3</u>
22. Unit Cap Factor (MDC Net)	<u>90.0</u>	<u>90.7</u>	<u>60.6</u>
23. Unit Cap Factor (DER Net)	<u>90.0</u>	<u>90.7</u>	<u>60.6</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>3.8</u>	<u>5.1</u>
25. Forced Outage Hours	<u>.0</u>	<u>54.0</u>	<u>767.9</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
 NONE

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
 \* SAN ONOFRE 2 \*  
 \*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

SAN ONOFRE 2



FEBRUARY 1986

Report Period FEB 1986

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* SAN ONOFRE 2 \*  
\*\*\*\*\*

No. Date Type Hours Reason Method LER Number System Component Cause & Corrective Action to Prevent Recurrence

NONE

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
SAN ONOFRE 2 OPERATED ROUTINELY IN FEBRUARY WITH NO SHUTDOWNS OR POWER  
REDUCTIONS REPORTED.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	Instructions for
	C-Refueling	H-Other	Preparation of
	D-Regulatory Restriction		Data Entry Sheet
	E-Operator Training & License Examination	5-Continued 6-Reduced Load 9-Other	Licensee Event Report (LER) File (NUREG-0161)

\*\*\*\*\*  
\* SAN ONOFRE 2 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1986

FACILITY DESCRIPTION

LOCATION STATE..... CALIFORNIA  
COUNTY..... SAN DIEGO  
DIST AND DIRECTION FROM NEAREST POPULATION CTR... 5 MI S OF SAN CLEMENTE, CA  
TYPE OF REACTOR..... PWR  
DATE INITIAL CRITICALITY... JULY 26, 1982  
DATE ELEC ENER 1ST GENER... SEPTEMBER 20, 1982  
DATE COMMERCIAL OPERATE.... AUGUST 8, 1983  
CONDENSER COOLING METHOD... ONCE THRU  
CONDENSER COOLING WATER.... PACIFIC OCEAN  
ELECTRIC RELIABILITY COUNCIL..... WESTERN SYSTEMS COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE..... SOUTHERN CALIFORNIA EDISON  
CORPORATE ADDRESS..... P.O. BOX 800 ROSEMEAD, CALIFORNIA 91770  
CONTRACTOR  
ARCHITECT/ENGINEER..... BECHTEL  
NUC STEAM SYS SUPPLIER... COMBUSTION ENGINEERING  
CONSTRUCTOR..... BECHTEL  
TURBINE SUPPLIER..... GENERAL ELECTRIC COM (ENG VERSION)

REGULATORY INFORMATION

IE REGION RESPONSIBLE..... V  
IE RESIDENT INSPECTOR..... R. HUEY  
LICENSING PROJ MANAGER..... H. ROOD  
DOCKET NUMBER..... 50-361  
LICENSE & DATE ISSUANCE.... NPF-10, SEPTEMBER 7, 1982  
PUBLIC DOCUMENT ROOM..... SAN CLEMENTE LIBRARY  
242 AVENIDA DEL MAR  
SAN CLEMENTE, CALIFORNIA

I N S P E C T I O N     S T A T U S

INSPECTION SUMMARY

+ INSPECTION ON JANUARY 6 - FEBRUARY 7, 1986 (REPORT NO. 50-361/86-01) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.  
+ INSPECTION ON JANUARY 13 - FEBRUARY 7, 1986 (REPORT NO. 50-361/86-02) AREAS INSPECTED: ROUTINE, UNANNOUNCED INSPECTION OF LICENSEE ACTION ON PREVIOUS INSPECTION FINDINGS, REVIEW OF LICENSEE REPORTS, GASEOUS WASTE SYSTEMS, RADIOLOGICAL ENVIRONMENTAL MONITORING, OCCUPATIONAL EXPOSURE DURING EXTENDED OUTAGES, FACILITY TOURS AND FOLLOWUP ON INFORMATION NOTICES. DURING THIS INSPECTION, VARIOUS INSPECTION PROCEDURES WERE UTILIZED.

RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

+ INSPECTION ON JANUARY 11 - FEBRUARY 14, 1986 (REPORT NO. 50-361/86-05) AREAS INSPECTED: ROUTINE, RESIDENT INSPECTION OF OPERATIONS PROGRAM INCLUDING THE FOLLOWING AREAS: OPERATION SAFETY VERIFICATION, EVALUATION OF PLANT TRIPS AND EVENTS, MONTHLY SURVEILLANCE ACTIVITIES, MONTHLY MAINTENANCE ACTIVITIES, ENGINEERED SAFETY FEATURE WALKDOWN, REFUELING ACTIVITIES, LICENSEE EVENT REPORTS REVIEW, AND FOLLOWUP OF PREVIOUSLY IDENTIFIED ITEMS. DURING THIS INSPECTION, VARIOUS INSPECTION PROCEDURES WERE UTILIZED. THE INSPECTION INVOLVED 122 INSPECTOR-HOURS ONSITE BY FIVE NRC INSPECTORS.

RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

+ INSPECTION ON FEBRUARY 10-14, 1986 (REPORT NO. 50-361/86-06) AREAS INSPECTED: ROUTINE, UNANNOUNCED INSPECTION BY REGIONALLY BASED INSPECTORS OF ACTIVITIES ASSOCIATED WITH AUDITS, RECORDS, FIRE PROTECTION, AND LICENSEE ACTION ON INSPECTOR-IDENTIFIED

Report Period FEB 1986

I N S P E C T I O N      S T A T U S - (CONTINUED)

\*\*\*\*\*  
\* SAN ONOFRE 2 \*  
\*\*\*\*\*

INSPECTION SUMMARY

ITEMS. DURING THIS INSPECTION, VARIOUS INSPECTION PROCEDURES WERE UTILIZED. THE INSPECTION INVOLVED 70 INSPECTOR-HOURS BY TWO NRC INSPECTORS.

RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

+ MEETING ON FEBRUARY 6, 1986 (REPORT NO. 50-361/86-07) AREAS INSPECTED: SPECIAL, ANNOUNCED MEETING WITH LICENSEE REPRESENTATIVES CONCERNING THEIR PLANS TO REDUCE THE QUANTITY OF RADIOACTIVE MATERIAL IN LIQUIDS DISCHARGED FROM THE SITE. DURING THIS MEETING, ONE INSPECTION PROCEDURE WAS ADDRESSED. THE MEETING INVOLVED THREE HOURS ONSITE BY TWO NRC INSPECTORS AND ONE REGION V MANAGEMENT REPRESENTATIVE.

RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

+ INSPECTION ON FEBRUARY 15 - MARCH 17, 1986 (REPORT NO. 50-361/86-08) INSPECTION CONTINUING; TO BE REPORTED NEXT MONTH.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

+ THE UNIT CONTINUED FULL POWER OPERATION IN FEBRUARY. ON FEBRUARY 14, 1986, POWER WAS REDUCED TO 80% DUE TO LOW BORON CONCENTRATIONS IN APPROACHING THE SCHEDULED MARCH 1986 REFUELING OUTAGE.

LAST IE SITE INSPECTION DATE: 02/15-03/17/86+

INSPECTION REPORT NO: 50-361/86-08+

Report Period FEB 1986

R E P O R T S   F R O M   L I C E N S E E


\*\*\*\*\*  
\* SAN ONOFRE 2 \*  
\*\*\*\*\*

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
85-57-L0	12-16-85	01-14-86	SPURIOUS TGIS DUE TO ELECTRICAL SHORT
85-58-L0	12-10-85	01-09-86	TRIP ON LOW STEAM GENERATOR LEVEL / DUE TO I&C ISOLATING NITROGEN TO MSIV / AND MSIV CLOSURE
85-59-L0	12-11-85	01-10-86	SPURIOUS TGIS DUE TO TROUBLESHOOTING FAILED AMMONIA ANALYZER

=====

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-362 OPERATING STATUS  
 2. Reporting Period: 02/01/86 Outage + On-line Hrs: 672.0  
 3. Utility Contact: E. R. SIACOR (714) 368-6223  
 4. Licensed Thermal Power (MWh): 3390  
 5. Nameplate Rating (Gross MWe): 1127  
 6. Design Electrical Rating (Net MWe): 1080  
 7. Maximum Dependable Capacity (Gross MWe): 1127  
 8. Maximum Dependable Capacity (Net MWe): 1080  
 9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE  
 10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_  
 11. Reasons for Restrictions, If Any:  
NONE  
 12. Report Period Hrs      MONTH      YEAR      CUMULATIVE  
672.0      1,416.0      16,776.0  
 13. Hours Reactor Critical      .946.9      1,030.9      10,216.0  
 14. Rx Reserve Shtdwn Hrs      .0      .0      .0  
 15. Hrs Generator On-line      310.4      774.9      9,590.2  
 16. Unit Reserve Shtdwn Hrs      .0      .0      .0  
 17. Gross Therm Ener (MWH)      951,789      2,088,968      27,088,532  
 18. Gross Elec Ener (MWH)      312,365      678,660      9,050,062  
 19. Net Elec Ener (MWH)      282,164      615,384      8,422,731  
 20. Unit Service Factor      46.2      54.7      57.2  
 21. Unit Avail Factor      46.2      54.7      57.2  
 22. Unit Cap Factor (MDC Net)      38.9      40.2      46.5  
 23. Unit Cap Factor (DER Net)      38.9      40.2      46.5  
 24. Unit Forced Outage Rate      48.9      28.9      15.5  
 25. Forced Outage Hours      297.5      315.4      1,764.3  
 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE  
 27. If Currently Shutdown Estimated Startup Date: 03/17/86



FEBRUARY 1986

Report Period FEB 1986

## UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* SAN ONOFRE 3 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
24	02/12/86	S	64.1	A	2		CC	CCL	REACTOR WAS MANUALLY TRIPPED AT 15% POWER FOR REPAIRS TO THE LEAKING COMPONENT COOLING WATER LINE FOR THE COOLING COIL OF REACTOR COOLANT PUMP 3P004 LOWER MOTOR BEARING. THE LEAK WAS CAUSED BY A BROKEN THREADED CONNECTION IN THE LINE.
25	02/16/86	F	53.6	A	4		KE	P	THE TURBINE WAS TRIPPED OFFLINE (REACTOR REMAINED CRITICAL) DUE TO BOTH SCREEN WASH PUMPS FAILURE AS A RESULT OF SUCTION STRAINERS PLUGGED WITH DEBRIS FROM STORM. DEBRIS HAD BEEN REMOVED FROM THE STRAINERS, RAKES AND SCREENS HAD BEEN REPAIRED, AND THE SCREEN WASH EQUIPMENT RETURNED TO SERVICE.
	02/17/86	F	69.1	H	4		TA	TRB	TURBINE RUPTURE DISCS FAILED DUE TO OVERPRESSURIZATION OF THE TURBINE EXHAUST HOOD. THE EXACT CAUSE OF THE OVERPRESSURIZATION COULD NOT BE DETERMINED, HOWEVER, A POSSIBLE CAUSE HAS BEEN ATTRIBUTED TO EXCESS ENERGY FROM GLAND STEAM WITH CONDENSER VACUUM BROKEN. APPROPRIATE PROCEDURES HAVE BEEN REVISED TO PREVENT RECURRENCE. THE FAILED RUPTURE DISCS HAVE BEEN REPLACED AND THE TURBINE RETURNED TO SERVICE.
26	02/21/86	F	174.8	A	2		EL	XFMR	MANUALLY TRIPPED THE TURBINE AND REACTOR FOR INVESTIGATION OF INCREASING COMBUSTIBLE GASES IN THE MAIN TRANSFORMER 3XM. REPLACEMENT OF THE MAIN TRANSFORMER WITH A SPARE IS IN PROGRESS. INVESTIGATION OF THE CAUSE OF THE INCREASE IN COMBUSTIBLE GASES IS CONTINUING.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*

SAN ONOFRE 3 INCURRED 3 OUTAGES IN FEBRUARY AS DISCUSSED ABOVE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	Instructions for Preparation of
	C-Refueling	H-Other	Data Entry Sheet
	D-Regulatory Restriction	3-Auto Scram	Licensee Event Report
	E-Operator Training & License Examination	4-Continued	(LER) File (NUREG-0161)
		5-Reduced Load	
		9-Other	

\*\*\*\*\*  
\* SAN ONOFRE 3 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1986

FACILITY DESCRIPTION

LOCATION  
STATE.....CALIFORNIA  
  
COUNTY.....SAN DIEGO  
  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...5 MI S OF  
SAN CLEMENTE, CA  
  
TYPE OF REACTOR.....PWR  
  
DATE INITIAL CRITICALITY...AUGUST 29, 1983  
  
DATE ELEC ENER 1ST GENER...SEPTEMBER 25, 1983  
  
DATE COMMERCIAL OPERATE....APRIL 1, 1984  
  
CONDENSER COOLING METHOD...ONCE THRU  
  
CONDENSER COOLING WATER....PACIFIC OCEAN  
  
ELECTRIC RELIABILITY  
COUNCIL.....WESTERN SYSTEMS  
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....SOUTHERN CALIFORNIA EDISON  
  
CORPORATE ADDRESS.....P.O. BOX 800  
ROSEMEAD, CALIFORNIA 91770  
  
CONTRACTOR  
ARCHITECT/ENGINEER.....BECHTEL  
  
NUC STEAM SYS SUPPLIER...COMBUSTION ENGINEERING  
  
CONSTRCTOR.....BECHTEL  
  
TURBINE SUPPLIER.....GENERAL ELECTRIC COM (ENG VERSION)

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....V  
  
IE RESIDENT INSPECTOR.....R. HUEY  
  
LICENSING PROJ MANAGER....H. ROOD  
DOCKET NUMBER.....50-362  
  
LICENSE & DATE ISSUANCE....NPF-15, NOVEMBER 15, 1982  
  
PUBLIC DOCUMENT ROOM.....SAN CLEMENTE LIBRARY  
242 AVENIDA DEL MAR  
SAN CLEMENTE, CALIFORNIA

I N S P E C T I O N     S T A T U S

INSPECTION SUMMARY

+ INSPECTION ON JANUARY 6 - FEBRUARY 7, 1986 (REPORT NO. 50-362/86-01) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.  
  
+ INSPECTION ON JANUARY 13 - FEBRUARY 7, 1986 (REPORT NO. 50-362/86-02) AREAS INSPECTED: ROUTINE, UNANNOUNCED INSPECTION OF LICENSEE ACTION ON PREVIOUS INSPECTION FINDINGS, REVIEW OF LICENSEE REPORTS, GASEOUS WASTE SYSTEMS, RADIOLOGICAL ENVIRONMENTAL MONITORING, OCCUPATIONAL EXPOSURE DURING EXTENDED OUTAGES, FUEL FRAGMENT CONTAMINATION, FACILITY TOURS AND FOLLOWUP ON INFORMATION NOTICES. DURING THIS INSPECTION, VARIOUS INSPECTION PROCEDURES WERE UTILIZED.

RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

+ INSPECTION ON JANUARY 11 - FEBRUARY 14, 1986 (REPORT NO. 50-362/86-05) AREAS INSPECTED: ROUTINE, RESIDENT INSPECTION OF OPERATIONS PROGRAM INCLUDING THE FOLLOWING AREAS: OPERATIONAL SAFETY VERIFICATION, EVALUATION OF PLANT TRIPS AND EVENTS, MONTHLY SURVEILLANCE ACTIVITIES, MONTHLY MAINTENANCE ACTIVITIES, ENGINEERED SAFETY FEATURE WALKDOWN, REFUELING ACTIVITIES, LICENSEE EVENT REPORTS REVIEW AND FOLLOWUP OF PREVIOUSLY IDENTIFIED ITEMS. DURING THIS INSPECTION, VARIOUS INSPECTION PROCEDURES WERE IDENTIFIED. THE INSPECTION INVOLVED 152 INSPECTOR-HOURS ONSITE BY FIVE NRC INSPECTORS.

RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

+ INSPECTION ON FEBRUARY 10-14, 1986 (REPORT NO. 50-362/86-06) AREAS INSPECTED: ROUTINE, UNANNOUNCED INSPECTION BY REGIONALLY BASED INSPECTORS OF ACTIVITIES ASSOCIATED WITH AUDITS, RECORDS, FIRE PROTECTION, AND LICENSE ACTION ON INSPECTOR-IDENTIFIED ITEMS.

Report Period FEB 1986

I N S P E C T I O N      S T A T U S - (CONTINUED)

\*\*\*\*\*  
\* SAN ONOFRE 3 \*  
\*\*\*\*\*

INSPECTION SUMMARY

DURING THIS INSPECTION, VARIOUS INSPECTION PROCEDURES WERE UTILIZED. THE INSPECTION INVOLVED 70 INSPECTOR-HOURS ONSITE BY TWO NRC INSPECTORS.

RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

+ MEETING ON FEBRUARY 6, 1986 (REPORT NO. 50-362/86-07) AREAS INSPECTED: SPECIAL, ANNOUNCED MEETING WITH LICENSEE REPRESENTATIVES CONCERNING THEIR PLANS TO REDUCE THE QUANTITY OF RADIOACTIVE MATERIAL IN LIQUIDS DISCHARGED FROM THE SITE. DURING THIS MEETING, ONE INSPECTION PROCEDURE WAS ADDRESSED. THE MEETING INVOLVED THREE HOURS ONSITE BY TWO NRC INSPECTORS AND ONE REGION V MANAGEMENT REPRESENTATIVE.

RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

+ INSPECTION ON FEBRUARY 15 - MARCH 17, 1986 (REPORT NO. 50-362/86-08) INSPECTION CONTINUING; TO BE REPORTED NEXT MONTH.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

+ THE UNIT ENTERED THE MONTH AT FULL POWER. ON FEBRUARY 12, 1986, THE UNIT WAS SHUT DOWN BY MANUAL REACTOR TRIP DUE TO REACTOR COOLANT PUMP LOWER BEARING COOLING COIL PROBLEMS. AFTER REPAIR THE UNIT ENTERED MODE 1 ON FEBRUARY 15, 1986, AND WAS MANUALLY ENTERED MODE 1 AND WAS MANUALLY TRIPPED DUE TO A MAIN TRANSFORMER FAILURE. ON FEBRUARY 21, 1986, THE UNIT REMAINED SHUTDOWN FOR THE REMAINDER OF THE MONTH. ALSO ON FEBRUARY 27, 1986, DURING COOLDOWN TO MODE 5, A LEAK IN A PRESSURIZER INSTRUMENT LINE AT THE PRESSURIZER HEAD WAS DISCOVERED.

LAST IE SITE INSPECTION DATE: 02/15-03/17/86+

INSPECTION REPORT NO: 50-362/86-08+

Report Period FEB 1986

R E P O R T S   F R O M   L I C E N S E E

\*\*\*\*\*  
\* SAN ONOFRE 3 \*  
\*\*\*\*\*

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
--------	------------------	-------------------	---------

---

NONE

---


THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-327 OPERATING STATUS  
 2. Reporting Period: 02/01/86 Outage + On-line Hrs: 672.0  
 3. Utility Contact: DAVID DUPREE (615) 870-6544  
 4. Licensed Thermal Power (MWt): 3411  
 5. Nameplate Rating (Gross MWe): 1220  
 6. Design Electrical Rating (Net MWe): 1148  
 7. Maximum Dependable Capacity (Gross MWe): 1183  
 8. Maximum Dependable Capacity (Net MWe): 1148  
 9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE  
 10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_  
 11. Reasons for Restrictions, If Any:  
NONE  
 12. Report Period Hrs 672.0 MONTH 1,416.0 YEAR 40,897.0 CUMULATIVE  
 13. Hours Reactor Critical .0 .0 24,444.7  
 14. Rx Reserve Shtdwn Hrs .0 .0 .0  
 15. Hrs Generator On-Line .0 .0 23,871.0  
 16. Unit Reserve Shtdwn Hrs .0 .0 .0  
 17. Gross Therm Ener (MWH) 0 0 77,060,921  
 18. Gross Elec Ener (MWH) 0 0 25,978,386  
 19. Net Elec Ener (MWH) -2,959 -6,152 24,936,585  
 20. Unit Service Factor .0 .0 58.4  
 21. Unit Avail Factor .0 .0 58.4  
 22. Unit Cap Factor (MDC Net) .0 .0 53.1  
 23. Unit Cap Factor (DER Net) .0 .0 53.1  
 24. Unit Forced Outage Rate 100.0 100.0 22.8  
 25. Forced Outage Hours 672.0 1,416.0 7,043.1  
 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE  
 27. If Currently Shutdown Estimated Startup Date: 06/15/86

\*\*\*\*\*  
\* SEQUOYAH 1 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

SEQUOYAH 1



FEBRUARY 1986

Report Period FEB 1986

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* SEQUOYAH 1 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System Component	Cause & Corrective Action to Prevent Recurrence
7	12/20/85	F	672.0	F	4			10CFR50.49, ENVIRONMENTAL QUALIFICATION OF ELECTRICAL EQUIPMENT IMPORTANT TO PLANT SAFETY.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
SEQUOYAH 1 REMAINS IN AN EXTENDED ADMINISTRATIVE SHUTDOWN.

Type	Reason	Method	System & Component	
F-Forced	A-Equip Failure	F-Admin	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	2-Manual Scram	Instructions for Preparation of
	C-Refueling	H-Other	3-Auto Scram	Data Entry Sheet
	D-Regulatory Restriction		4-Continued	Licensee Event Report
	E-Operator Training & License Examination		5-Reduced Load	(LER) File (NUREG-0161)
			9-Other	

\*\*\*\*\*  
\* SEQUOYAH 1 \*  
\*\*\*\*\*

FACILITY DESCRIPTION

LOCATION STATE..... TENNESSEE  
COUNTY..... HAMILTON  
DIST AND DIRECTION FROM NEAREST POPULATION CTR... 9.5 MI NE OF CHATTANOOGA, TN  
TYPE OF REACTOR..... PWR  
DATE INITIAL CRITICALITY... JULY 5, 1980  
DATE ELEC ENER 1ST GENER... JULY 22, 1980  
DATE COMMERCIAL OPERATE.... JULY 1, 1981  
CONDENSER COOLING METHOD... ONCE THRU  
CONDENSER COOLING WATER.... CHICKAMAUGA LAKE  
ELECTRIC RELIABILITY COUNCIL..... SOUTHEASTERN ELECTRIC RELIABILITY COUNCIL

FACILITY DATA

Report Period FEB 1986

UTILITY & CONTRACTOR INFORMATION

UTILITY LICENSEE..... TENNESSEE VALLEY AUTHORITY  
CORPORATE ADDRESS..... 6 NORTH 38A LOOKOUT PLACE CHATTANOOGA, TENNESSEE 37401  
CONTRACTOR ARCHITECT/ENGINEER..... TENNESSEE VALLEY AUTHORITY  
NUC STEAM SYS SUPPLIER... WESTINGHOUSE  
CONSTRUCTOR..... TENNESSEE VALLEY AUTHORITY  
TURBINE SUPPLIER..... WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE..... II  
IE RESIDENT INSPECTOR..... E. FORD  
LICENSING PROJ MANAGER.... C. STAHL  
DOCKET NUMBER..... 50-327  
LICENSE & DATE ISSUANCE.... DPR-77, SEPTEMBER 17, 1980  
PUBLIC DOCUMENT ROOM..... CHATTANOOGA - HAMILTON BICENTENNIAL LIBRARY  
1001 BROAD STREET  
CHATTANOOGA, TENNESSEE 37402

INSPECTION STATUS

INSPECTION SUMMARY

+ INSPECTION DECEMBER 2-6 (85-45): THIS ROUTINE, ANNOUNCED INSPECTION INVOLVED 247 INSPECTOR-HOURS ON SITE IN THE AREA OF MAINTENANCE ACTIVITIES. TWO VIOLATIONS WERE IDENTIFIED: TWO EXAMPLES OF FAILURE TO TAKE PROMPT CORRECTIVE ACTIONS IN RESOLVING PROBLEMS WITH UPPER HEAD INJECTION (UHI) LEVEL SWITCHES AND IN RESOLVING PROBLEMS ASSOCIATED WITH REVIEW OF COMPLETED MAINTENANCE REQUESTS (MRS); AND THREE EXAMPLES OF FAILURE TO FOLLOW PROCEDURES IN THE AREAS OF MOTOR OPERATED VALVE MODIFICATION, DEFINITION OF PREVENTATIVE MAINTENANCE FOR AUXILIARY AIR COMPRESSOR DRYERS, AND HOUSEKEEPING OF CONTAMINATED WORK AREAS.

INSPECTION DECEMBER 6 - JANUARY 5, 1986 (85-47): THIS ROUTINE, ANNOUNCED INSPECTION INVOLVED 138 RESIDENT INSPECTOR-HOURS ON SITE IN THE AREAS OF OPERATIONAL SAFETY VERIFICATION INCLUDING OPERATIONS PERFORMANCE, SYSTEM LINEUPS, RADIATION PROTECTION, SECURITY AND HOUSEKEEPING INSPECTIONS; SURVEILLANCE AND MAINTENANCE OBSERVATIONS; REVIEW OF PREVIOUS INSPECTION FINDINGS; FOLLOWUP OF EVENTS; REVIEW OF LICENSEE IDENTIFIED ITEMS; AND REVIEW OF INSPECTOR FOLLOWUP ITEMS. ONE VIOLATION FOR FAILURE TO FOLLOW PROCEDURE WAS IDENTIFIED WITH THREE EXAMPLES.

INSPECTION DECEMBER 16-20 (85-48): THIS SPECIAL, ANNOUNCED INSPECTION INVOLVED 33 INSPECTOR-HOURS ON SITE IN THE AREA OF PREVIOUS DESIGN CONTROL ADEQUACY. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION DECEMBER 16-20 (85-49): THIS ROUTINE, UNANNOUNCED INSPECTION INVOLVED 18 INSPECTOR-HOURS ON SITE IN THE AREAS OF LICENSEE ACTIONS ON PREVIOUS ENFORCEMENT MATTERS PERTAINING TO SAFETY-RELATED CABLE TRAY SUPPORT SYSTEMS, AND SAFETY-RELATED PIPE SUPPORT AND RESTRAINT SYSTEMS. ONE VIOLATION WAS IDENTIFIED - INSPECTION AND INSTALLATION PROBLEMS FOR SEISMICALLY DESIGNED PIPE SUPPORTS.

Report Period FEB 1986

INSPECTION STATUS - (CONTINUED)

\*\*\*\*\*  
\* SEQUOYAH 1 \*  
\*\*\*\*\*

INSPECTION SUMMARY

INSPECTION JANUARY 6-10 (86-02): THIS ROUTINE, UNANNOUNCED INSPECTION ENTAILED 22 INSPECTOR-HOURS ON SITE IN THE AREAS OF GASEOUS AND LIQUID RADWASTE SYSTEMS; RADIOLOGICAL EFFLUENT ACCOUNTABILITY; REACTOR COOLANT AND SECONDARY WATER TECHNICAL SPECIFICATION CHEMISTRY REQUIREMENTS; AND REVIEW OF SELECTED INSPECTOR FOLLOWUP ITEMS. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JANUARY 6-8 (86-03): THIS SPECIAL, UNANNOUNCED INSPECTION ENTAILED 12 INSPECTOR-HOURS ON SITE IN THE AREAS OF RADIOLOGICAL EMERGENCY PREPAREDNESS AS REFLECTED IN SECTION V OF THE SEQUOYAH NUCLEAR PERFORMANCE PLAN. OF THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JANUARY 21-24 (86-08): THIS SPECIAL, ANNOUNCED INSPECTION ENTAILED 80 INSPECTOR-HOURS AT THE SEQUOYAH SITE, AT THE WATTS BAR SITE, AND AT THE CORPORATE OFFICES IN KNOXVILLE TO CONDUCT A PROGRAMMATIC REVIEW OF THE TVA EMPLOYEE CONCERNS PROGRAM FACETS APPLICABLE EITHER SPECIFICALLY OR GENERICALLY TO THE SEQUOYAH SITE. AREAS INSPECTED INCLUDED EVALUATION OF CRITERIA AND PROCEDURES USED BY TVA TO SCREEN EMPLOYEE CONCERNS FOR APPLICABILITY TO SEQUOYAH AND FOR SAFETY SIGNIFICANCE, REVIEW OF PROGRAM IMPLEMENTATION, REVIEW OF TVA OVERSIGHT OF THE SEQUOYAH EMPLOYEE CONCERN RESOLUTION EFFORT, AND VERIFICATION OF EMPLOYEE CONCERN PROGRAM TRAINING AND SAFETY NOTICES. OF THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED. THE INSPECTORS HAD OBSERVATIONS RELATIVE TO THE PROCEDURES AND CRITERIA USED TO CATEGORIZE AND PRIORITIZE EMPLOYEE CONCERNS AND THE CONSISTENCY OF PROGRAM IMPLEMENTATION.

ENFORCEMENT SUMMARY

CONTRARY TO TS 6.8.1 REQUIREMENT, IN THE INSTANCES CITED BELOW, THE LICENSEE INADEQUATELY ESTABLISHED OR MAINTAINED SURVEILLANCE INSTRUCTIONS AND SYSTEM OPERATING INSTRUCTIONS. (A) SI-256, PERIODIC CALIBRATION OF OVERCURRENT RELAYS AND DISTANCE RELAYS ON 6.9 KV REACTOR COOLANT PUMPS ON 6.9 KV UNIT BOARDS, CONTAINS THE FOLLOWING INADEQUATE ACCEPTANCE CRITERIA: (1) FOR PRIMARY OVERCURRENT PROTECTIVE DEVICES, THE PROCEDURE ESTABLISHES A TRIP SETPOINT AMPERAGE TOLERANCE VALUE OF PLUS OR MINUS 5 PERCENT. TS TABLE 3.8-1 FOR BOTH UNITS REQUIRES A PLUS OR MINUS PERCENTAGE TOLERANCE. (2) FOR PRIMARY OVERCURRENT PROTECTIVE DEVICES, THE PROCEDURE ESTABLISHES A 75 DEGREE IMPEDANCE ANGLE OF MAXIMUM TORQUE. THE PROPER VALUE IS 105 DEGREES. (3) FOR PRIMARY OVERCURRENT PROTECTIVE DEVICES, THE PROCEDURE REQUIRES DISTANCE RELAY TARGETS TO OPERATE BETWEEN 1.0 AND 2.0 AMPERES WITH DC VOLTAGE APPLIED. THE VENDOR MANUAL FOR THESE TYPE IAC 66K RELAYS REQUIRES PROPER OPERATION BETWEEN 0.1 AND 2.0 AMPERES. (B) PROCEDURE SOI 30.6, AUXILIARY BUILDING GAS TREATMENT SYSTEM, LISTED USE OF FUSES WITH INCORRECT AMPERAGE RATINGS AND PRESCRIBED POSITIONING OF A BLOCK SWITCH WHICH HAD BEEN PREVIOUSLY DISCONNECTED FROM THE CIRCUIT. (C) INSTRUMENT MAINTENANCE PROCEDURE IMI-99, REACTOR PROTECTION SYSTEM CALIBRATION AND FUNCTIONAL TESTING, PRESCRIBED USE OF INADEQUATE MEASURING AND TEST EQUIPMENT. THE MEASURING AND TEST EQUIPMENT PRESCRIBED WAS ONLY 2 TO 2.5 TIMES MORE ACCURATE THAN THE MEASURED PARAMETER WHEN THE SETPOINT METHODOLOGY USED TO DETERMINE REACTOR PROTECTION SETPOINTS ASSUMED THE EQUIPMENT WAS TEN TIMES MORE ACCURATE THAN THE MEASURED PARAMETER.

CONTRARY TO TS 6.5.1.6.D, THE PORC FAILED TO CONDUCT A FORMAL REVIEW OF THE POTENTIAL NUCLEAR SAFETY HAZARDS ASSOCIATED WITH ACCURACY OF MEASURING AND TEST EQUIPMENT (M&TE) USED FOR CALIBRATION OF REACTOR PROTECTION SYSTEM (RPS) INSTRUMENTATION. THE M&TE ACCURACY FOR SUCH TEST EQUIPMENT AS FLUKE 8600 AND ASHCROFT DIGIGAGE USED FOR CALIBRATING RPS INSTRUMENTATION DID NOT MEET THE ACCURACY ASSUMPTIONS USED IN THE SETPOINT METHODOLOGY FOR RPS TRIP SETPOINTS. CONTRARY TO 10 CFR 50, APPENDIX B, CRITERION V, AND SEQUOYAH INSPECTION INSTRUCTION NO. 66, INSPECTION SUPPORTS, BETWEEN DECEMBER 16-20, 1985, ACTIVITIES AFFECTING QUALITY HAD NOT BEEN ACCOMPLISHED IN ACCORDANCE WITH DOCUMENTED INSTRUCTIONS AND DRAWINGS IN THAT A FIELD INSPECTION OF EIGHT SUPPORTS REVEALED (8504 4)

CONTRARY TO TS 6.8.1 REQUIREMENTS FOR PROCEDURE IMPLEMENTATION SI-256 AND AI-4 PROCEDURES WERE NOT IMPLEMENTED IN THAT: (A) INITIAL AND INDEPENDENT VERIFICATION SIGNOFFS FOR CONFORMANCE TO SI-256 RELAY TEST RECORD SHEET ACCEPTANCE CRITERIA WERE MADE WHEN THE RECORDED VALUE WAS OUTSIDE THE PROCEDURE ACCEPTANCE CRITERIA. IN ADDITION, SUPERVISORY REVIEW OF THE SURVEILLANCE PACKAGE DID NOT IDENTIFY THESE DEFICIENCIES. (B) PROPER PROCEDURE CHANGE CONTROL REQUIREMENTS OF AI-4 WERE NOT IMPLEMENTED FOR PEN AND INK CHANGES MADE IN THE UNITS OF MEASURE FOR RELAY TEST RECORD PARAMETERS OF SI-256. SUPERVISORY REVIEW OF THE SURVEILLANCE PACKAGE

Report Period FEB 1986

I N S P E C T I O N     S T A T U S - (CONTINUED)

\*\*\*\*\*  
\* SEQUOYAH 1 \*  
\*\*\*\*\*

ENFORCEMENT SUMMARY

DID NOT IDENTIFY THESE DEFICIENCIES.  
(8504 5)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

MODE 5.

LAST IE SITE INSPECTION DATE: JANUARY 21-24, 1986 +

INSPECTION REPORT NO: 50-327/86-08 +

R E P O R T S   F R O M   L I C E N S E E

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
85-065	10/31/85	11/27/85	DIESEL GENERATOR START AND AN AUXILIARY BUILDING ISOLATION. THE "1B" START BUS ALTERNATE FEEDER BREAKER RACKING MECHANISM WAS FOUND TO HAVE A BENT RACKING LEVER.


THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-328 OPERATING STATUS  
 2. Reporting Period: 02/01/86 Outage + On-line Hrs: 672.0  
 3. Utility Contact: DAVID DUPREE (615) 870-6544  
 4. Licensed Thermal Power (MWh): 3411  
 5. Nameplate Rating (Gross MWe): 1220  
 6. Design Electrical Rating (Net MWe): 1148  
 7. Maximum Dependable Capacity (Gross MWe): 1183  
 8. Maximum Dependable Capacity (Net MWe): 1148  
 9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE  
 10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_  
 11. Reasons for Restrictions, If Any:  
NONE  
 12. Report Period Hrs MONTH YEAR CUMULATIVE  
672.0 1,416.0 32,857.0  
 13. Hours Reactor Critical .0 .0 21,984.5  
 14. Rx Reserve Shtdwn Hrs .0 .0 .0  
 15. Hrs Generator On-Line .0 .0 21,494.4  
 16. Unit Reserve Shtdwn Hrs .0 .0 .0  
 17. Gross Therm Ener (MWH) 0 0 69,127,974  
 18. Gross Elec Ener (MWH) 0 0 23,536,780  
 19. Net Elec Ener (MWH) -3,691 -6,907 22,625,051  
 20. Unit Service Factor .0 .0 65.4  
 21. Unit Avail Factor .0 .0 65.4  
 22. Unit Cap Factor (MDC Net) .0 .0 60.0  
 23. Unit Cap Factor (DER Net) .0 .0 60.0  
 24. Unit Forced Outage Rate 100.0 100.0 23.3  
 25. Forced Outage Hours 672.0 1,416.0 6,539.3  
 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE  
 27. If Currently Shutdown Estimated Startup Date: 06/15/86

\*\*\*\*  
 \* SEQUOYAH 2  
 \*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

SEQUOYAH 2



FEBRUARY 1986

Report Period FEB 1986

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* SEQUOYAH 2 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
9	08/21/85	F	672.0	F	4				10CFR50.49, ENVIRONMENTAL QUALIFICATION OF ELECTRICAL EQUIPMENT IMPORTANT TO PLANT SAFETY.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
SEQUOYAH 2 REMAINS IN AN EXTENDED ADMINISTRATIVE SHUTDOWN.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	
S-Sched	B-Maint or Test	G-Oper Error	1-Manual
	C-Refueling	H-Other	2-Manual Scram
	D-Regulatory Restriction		3-Auto Scram
	E-Operator Training & License Examination		4-Continued
			5-Reduced Load
			9-Other
			Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161)

\*\*\*\*\*  
\* SEQUOYAH 2 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1986

FACILITY DESCRIPTION

LOCATION STATE..... TENNESSEE  
COUNTY..... HAMILTON  
DIST AND DIRECTION FROM NEAREST POPULATION CTR... 9.5 MI NE OF CHATTANOOGA, TN  
TYPE OF REACTOR..... PWR  
DATE INITIAL CRITICALITY... NOVEMBER 5, 1981  
DATE ELEC ENER 1ST GENER... DECEMBER 23, 1981  
DATE COMMERCIAL OPERATE.... JUNE 1, 1982  
CONDENSER COOLING METHOD... ONCE THRU  
CONDENSER COOLING WATER.... CHICKAMAUGA LAKE  
ELECTRIC RELIABILITY COUNCIL..... SOUTHEASTERN ELECTRIC RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY LICENSEE..... TENNESSEE VALLEY AUTHORITY  
CORPORATE ADDRESS..... 6 NORTH 38A LOOKOUT PLACE, CHATTANOOGA, TENNESSEE 37401  
CONTRACTOR ARCHITECT/ENGINEER..... TENNESSEE VALLEY AUTHORITY  
NUC STEAM SYS SUPPLIER... WESTINGHOUSE  
CONSTRUCTOR..... TENNESSEE VALLEY AUTHORITY  
TURBINE SUPPLIER..... WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE..... II  
IE RESIDENT INSPECTOR..... E. FORD  
LICENSING PROJ MANAGER..... C. STAHL  
DOCKET NUMBER..... 50-328  
LICENSE & DATE ISSUANCE.... DPR-79, SEPTEMBER 15, 1981  
PUBLIC DOCUMENT ROOM..... CHATTANOOGA - HAMILTON BICENTENNIAL LIBRARY  
1001 BROAD STREET  
CHATTANOOGA, TENNESSEE 37402

I N S P E C T I O N     S T A T U S

INSPECTION SUMMARY

+ INSPECTION DECEMBER 2-6 (85-45): THIS ROUTINE, ANNOUNCED INSPECTION INVOLVED 247 INSPECTOR-HOURS ON SITE IN THE AREA OF MAINTENANCE ACTIVITIES. TWO VIOLATIONS WERE IDENTIFIED: TWO EXAMPLES OF FAILURE TO TAKE PROMPT CORRECTIVE ACTIONS IN RESOLVING PROBLEMS WITH UPPER HEAD INJECTION (UHI) LEVEL SWITCHES AND IN RESOLVING PROBLEMS ASSOCIATED WITH REVIEW OF COMPLETED MAINTENANCE REQUESTS (MRS); AND THREE EXAMPLES OF FAILURE TO FOLLOW PROCEDURES IN THE AREAS OF MOTOR OPERATED VALVE MODIFICATION, DEFINITION OF PREVENTATIVE MAINTENANCE FOR AUXILIARY AIR COMPRESSOR DRYERS, AND HOUSEKEEPING OF CONTAMINATED WORK AREAS.

INSPECTION DECEMBER 6 - JANUARY 5, 1986 (85-47): THIS ROUTINE, ANNOUNCED INSPECTION INVOLVED 138 RESIDENT INSPECTOR-HOURS ON SITE IN THE AREAS OF OPERATIONAL SAFETY VERIFICATION INCLUDING OPERATIONS PERFORMANCE, SYSTEM LINEUPS, RADIATION PROTECTION, SECURITY AND HOUSEKEEPING INSPECTIONS; SURVEILLANCE AND MAINTENANCE OBSERVATIONS; REVIEW OF PREVIOUS INSPECTION FINDINGS; FOLLOWUP OF EVENTS; REVIEW OF LICENSEE IDENTIFIED ITEMS; AND REVIEW OF INSPECTOR FOLLOWUP ITEMS. ONE VIOLATION FOR FAILURE TO FOLLOW PROCEDURE WAS IDENTIFIED WITH THREE EXAMPLES.

INSPECTION DECEMBER 16-20 (85-48): THIS SPECIAL, ANNOUNCED INSPECTION INVOLVED 33 INSPECTOR-HOURS ON SITE IN THE AREA OF PREVIOUS DESIGN CONTROL ADEQUACY. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION DECEMBER 16-20 (85-49): THIS ROUTINE, UNANNOUNCED INSPECTION INVOLVED 18 INSPECTOR-HOURS ON SITE IN THE AREAS OF LICENSEE ACTIONS ON PREVIOUS ENFORCEMENT MATTERS PERTAINING TO SAFETY-RELATED CABLE TRAY SUPPORT SYSTEMS, AND SAFETY-RELATED PIPE SUPPORT AND RESTRAINT SYSTEMS. ONE VIOLATION WAS IDENTIFIED - INSPECTION AND INSTALLATION PROBLEMS FOR SEISMICALLY DESIGNED PIPE SUPPORTS.

Report Period FEB 1986

INSPECTION STATUS - (CONTINUED)

\*\*\*\*\*  
\* SEQUOYAH 2 \*  
\*\*\*\*\*

INSPECTION SUMMARY

INSPECTION JANUARY 6-10 (86-02): THIS ROUTINE, UNANNOUNCED INSPECTION ENTAILED 23 INSPECTOR-HOURS ON SITE IN THE AREAS OF GASEOUS AND LIQUID RADWASTE SYSTEMS; RADIOLOGICAL EFFLUENT ACCOUNTABILITY; REACTOR COOLANT AND SECONDARY WATER TECHNICAL SPECIFICATION CHEMISTRY REQUIREMENTS; AND REVIEW OF SELECTED INSPECTOR FOLLOWUP ITEMS. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JANUARY 6-8 (86-03): THIS SPECIAL, UNANNOUNCED INSPECTION ENTAILED 12 INSPECTOR-HOURS ON SITE IN THE AREAS OF RADIOLOGICAL EMERGENCY PREPAREDNESS AS REFLECTED IN SECTION V OF THE SEQUOYAH NUCLEAR PERFORMANCE PLAN. OF THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JANUARY 21-24 (86-08): THIS SPECIAL, ANNOUNCED INSPECTION ENTAILED 80 INSPECTOR-HOURS AT THE SEQUOYAH SITE AT THE WATTS BAR SITE, AND AT THE CORPORATE OFFICES IN KNOXVILLE TO CONDUCT A PROGRAMMATIC REVIEW OF THE TVA EMPLOYEE CONCERN PROGRAM PROCEDURES USED BY TVA TO SCREEN EMPLOYEE CONCERN FOR APPLICABILITY TO SEQUOYAH AND FOR SAFETY SIGNIFICANCE, REVIEW OF PROGRAM IMPLEMENTATION, REVIEW OF TVA OVERSIGHT OF THE SEQUOYAH EMPLOYEE CONCERN RESOLUTION EFFORT, AND VERIFICATION OF EMPLOYEE CONCERN PROGRAM TRAINING AND SAFETY NOTICES. OF THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED. THE INSPECTORS HAD OBSERVATIONS RELATIVE TO THE PROCEDURES AND CRITERIA USED TO CATEGORIZE AND PRIORITIZE EMPLOYEE CONCERN AND THE CONSISTENCY OF PROGRAM IMPLEMENTATION.

ENFORCEMENT SUMMARY

CONTRARY TO TS 6.8.1 REQUIREMENT, IN THE INSTANCES CITED BELOW, THE LICENSEE INADEQUATELY ESTABLISHED OR MAINTAINED SURVEILLANCE INSTRUCTIONS AND SYSTEM OPERATING INSTRUCTIONS. (A) SI-256, PERIODIC CALIBRATION OF OVERCURRENT RELAYS AND DISTANCE RELAYS ON 6.9 KV REACTOR COOLANT PUMPS ON 6.9 KV UNIT BOARDS, CONTAINS THE FOLLOWING INADEQUATE ACCEPTANCE CRITERIA: (1) FOR PRIMARY OVERCURRENT PROTECTIVE DEVICES, THE PROCEDURE ESTABLISHES A TRIP SETPOINT AMPERAGE TOLERANCE VALUE OF PLUS OR MINUS 5 PERCENT. TS TABLE 3.8-1 FOR BOTH UNITS REQUIRES A PLUS OR MINUS PERCENT TOLERANCE. (2) FOR PRIMARY OVERCURRENT PROTECTIVE DEVICES, THE PROCEDURE ESTABLISHES A 75 DEGREE IMPEDANCE ANGLE OF MAXIMUM TORQUE. THE PROPER VALUE IS 105 DEGREES. (3) FOR PRIMARY OVERCURRENT PROTECTIVE DEVICES, THE PROCEDURE REQUIRES DISTANCE RELAY TARGETS TO OPERATE BETWEEN 1.0 AND 2.0 AMPERES WITH DC VOLTAGE APPLIED. THE VENDOR MANUAL FOR THESE TYPE IAC 66K RELAYS REQUIRES PROPER OPERATION BETWEEN 0.1 AND 2.0 AMPERES. (B) PROCEDURE SOI 30.6, AUXILIARY BUILDING GAS TREATMENT SYSTEM, LISTED USE OF FUSES WITH INCORRECT AMPERAGE RATINGS AND PRESCRIBED POSITIONING OF A BLOCK SWITCH WHICH HAD BEEN PREVIOUSLY DISCONNECTED FROM THE CIRCUIT. (C) INSTRUMENT MAINTENANCE PROCEDURE IMI-99, REACTOR PROTECTION SYSTEM CALIBRATION AND FUNCTIONAL TESTING, PRESCRIBED USE OF INADEQUATE MEASURING AND TEST EQUIPMENT. THE MEASURING AND TEST EQUIPMENT PRESCRIBED WAS ONLY 2 TO 2.5 TIMES MORE ACCURATE THAN THE MEASURED PARAMETER WHEN THE SETPOINT METHODOLOGY USED TO DETERMINE REACTOR PROTECTION SETPOINTS ASSUMED THE EQUIPMENT WAS TEN TIMES MORE ACCURATE THAN THE MEASURED PARAMETER.

CONTRARY TO TS 6.5.1.6.D, THE PORC FAILED TO CONDUCT A FORMAL REVIEW OF THE POTENTIAL NUCLEAR SAFETY HAZARDS ASSOCIATED WITH ACCURACY OF MEASURING AND TEST EQUIPMENT (M&TE) USED FOR CALIBRATION OF REACTOR PROTECTION SYSTEM (RPS) INSTRUMENTATION. THE M&TE ACCURACY ASSUMPTIONS USED IN THE SETPOINT METHODOLOGY FOR RPS TRIP SETPOINTS. CONTRARY TO 10 CFR 50, APPENDIX B, CRITERION V, AND SEQUOYAH INSPECTION INSTRUCTION NO. 66, INSPECTION SUPPORTS, BETWEEN DECEMBER 16-20, 1985, ACTIVITIES AFFECTING QUALITY HAD NOT BEEN ACCOMPLISHED IN ACCORDANCE WITH DOCUMENTED INSTRUCTIONS AND DRAWINGS IN THAT A FIELD INSPECTION OF EIGHT SUPPORTS REVEALED FOUR SEISMICALLY DESIGNED SUPPORTS WITH DEVIATIONS FROM THE DOCUMENTED REQUIREMENTS. (8504 4)

CONTRARY TO TS 6.8.1 REQUIREMENTS FOR PROCEDURE IMPLEMENTATION SI-256 AND AI-4 PROCEDURES WERE NOT IMPLEMENTED IN THAT: (A) INITIAL AND INDEPENDENT VERIFICATION SIGNOFFS FOR CONFORMANCE TO SI-256 RELAY TEST RECORD SHEET ACCEPTANCE CRITERIA WERE MADE WHEN THE RECORDED VALUE WAS OUTSIDE THE PROCEDURE ACCEPTANCE CRITERIA. IN ADDITION, SUPERVISORY REVIEW OF THE SURVEILLANCE PACKAGE DID NOT IDENTIFY THESE DEFICIENCIES. (B) PROPER PROCEDURE CHANGE CONTROL REQUIREMENTS OF AI-4 WERE NOT IMPLEMENTED FOR PEN AND INK CHANGES MADE IN THE UNITS OF MEASURE FOR RELAY TEST RECORD PARAMETERS OF SI-256. SUPERVISORY REVIEW OF THE SURVEILLANCE PACKAGE

Report Period FEB 1986

I N S P E C T I O N      S T A T U S - (CONTINUED)

\*\*\*\*\*  
\* SEQUOYAH 2 \*  
\*\*\*\*\*

ENFORCEMENT SUMMARY

DID NOT IDENTIFY THESE DEFICIENCIES.  
(8504 5)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

+ MODE 5.

LAST IE SITE INSPECTION DATE: JANUARY 21-24, 1986 +

INSPECTION REPORT NO: 50-328/76-08 +

R E P O R T S   F R O M   L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
--------	------------------	-------------------	---------

=====

NONE.

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-335

O P E R A T I N G S T A T U S

2. Reporting Period: 02/01/86 Outage + On-line Hrs: 672.0

3. Utility Contact: N. W. GRANT (305) 552-3675

4. Licensed Thermal Power (MWh): 2700

5. Nameplate Rating (Gross MWe): 1000 X 0.89 = 890

6. Design Electrical Rating (Net MWe): 830

7. Maximum Dependable Capacity (Gross MWe): 867

8. Maximum Dependable Capacity (Net MWe): 827

9. If Changes Occur Above Since Last Report, Give Reasons:

NONE

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

11. Reasons for Restrictions, If Any: \_\_\_\_\_

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>672.0</u>	<u>1,416.0</u>	<u>80,568.0</u>
13. Hours Reactor Critical	<u>663.6</u>	<u>1,407.6</u>	<u>58,563.8</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>205.3</u>
15. Hrs Generator On-Line	<u>661.1</u>	<u>1,403.6</u>	<u>57,206.4</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>39.3</u>
17. Gross Therm Ener (MWH)	<u>1,773,239</u>	<u>3,736,950</u>	<u>144,627,185</u>
18. Gross Elec Ener (MWH)	<u>596,690</u>	<u>1,260,400</u>	<u>47,316,905</u>
19. Net Elec Ener (MWH)	<u>567,109</u>	<u>1,197,903</u>	<u>44,622,117</u>
20. Unit Service Factor	<u>98.4</u>	<u>99.1</u>	<u>71.0</u>
21. Unit Avail Factor	<u>98.4</u>	<u>99.1</u>	<u>71.1</u>
22. Unit Cap Factor (MDC Net)	<u>102.0</u>	<u>102.3</u>	<u>67.0</u>
23. Unit Cap Factor (DER Net)	<u>101.7</u>	<u>101.9</u>	<u>66.7</u>
24. Unit Forced Outage Rate	<u>1.6</u>	<u>.9</u>	<u>4.3</u>
25. Forced Outage Hours	<u>10.9</u>	<u>12.4</u>	<u>2,567.2</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


NONE

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\* ST LUCIE 1 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

ST LUCIE 1



FEBRUARY 1986

Report Period FEB 1986

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* ST LUCIE 1 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
01	02/06/86	F	10.9	A	3	335-86-02	1A	CKTBRK	WHILE AT FULL POWER, AN AUTOMATIC REACTOR TRIP OCCURRED DURING THE MONTHLY REACTOR PROTECTION SYSTEM (RPS), LOGIC MATRIX TEST. A FAILED RPS RELAY TRIP SELECT SWITCH ALLOWED A LOGIC MATRIX RELAY TO DEENERGIZE OUT OF SEQUENCE CAUSING THE TRIP. THE SWITCH WAS REPLACED AND THE UNIT RETURNED TO POWER.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*

ST. LUCIE 1 OPERATED WITH 1 SHUTDOWN IN FEBRUARY.

Type	Reason	Method	System & Component	
F-Forced	A-Equip Failure	F-Admin	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	2-Manual Scram	Instructions for Preparation of
	C-Refueling	H-Other	3-Auto Scram	Data Entry Sheet
	D-Regulatory Restriction		4-Continued	Licensor Event Report
	E-Operator Training & License Examination		5-Reduced Load	(LER) File (NUREG-0161)
			9-Other	

\*\*\*\*\*  
\* ST LUCIE 1 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1986

FACILITY DESCRIPTION

LOCATION STATE.....FLORIDA  
COUNTY.....ST LUCIE  
DIST AND DIRECTION FROM NEAREST POPULATION CTR...12 MI SE OF FT. PIERCE, FLA  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...APRIL 22, 1976  
DATE ELEC ENER 1ST GENER...MAY 7, 1976  
DATE COMMERCIAL OPERATE....DECEMBER 21, 1976  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER....ATLANTIC OCEAN  
ELECTRIC RELIABILITY COUNCIL.....SOUTHEASTERN ELECTRIC RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....FLORIDA POWER & LIGHT  
CORPORATE ADDRESS.....9250 WEST FLAGLER STREET P.O. BOX 529100 MIAMI, FLORIDA 33152

CONTRACTOR  
ARCHITECT/ENGINEER.....EBASCO  
NUC STEAM SYS SUPPLIER...COMBUSTION ENGINEERING  
CONSTRUCTOR.....EBASCO  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II  
IE RESIDENT INSPECTOR.....R. CRENJAK  
LICENSING PROJ MANAGER.....E. TOURIGNY  
DOCKET NUMBER.....50-335  
LICENSE & DATE ISSUANCE....DPR-67, MARCH 1, 1976  
PUBLIC DOCUMENT ROOM.....INDIAN RIVER COMMUNITY COLLEGE LIBRARY  
3209 VIRGINIA AVENUE  
FT. PIERCE, FLORIDA 33450

I N S P E C T I O N     S T A T U S

INSPECTION SUMMARY

+ INSPECTION DECEMBER 16-20 (85-33): THIS ROUTINE, UNANNOUNCED INSPECTION INVOLVED 18 INSPECTOR-HOURS ON SITE IN THE AREAS OF FIRE PROTECTION/PREVENTION AND FOLLOWUP ON PREVIOUSLY IDENTIFIED INSPECTION ITEMS. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION DECEMBER 10 - JANUARY 13, 1986 (85-36): THIS INSPECTION INVOLVED 112 INSPECTOR-HOURS ON SITE IN THE AREAS OF TECHNICAL SPECIFICATION (TS) COMPLIANCE, OPERATOR PERFORMANCE, OVERALL PLANT OPERATIONS, QUALITY ASSURANCE PRACTICES, STATION AND CORPORATE MANAGEMENT PRACTICES, CORRECTIVE AND PREVENTIVE MAINTENANCE ACTIVITIES, SITE SECURITY PROCEDURES, RADIATION CONTROL ACTIVITIES, SURVEILLANCE ACTIVITIES, AND INSPECTION AND ENFORCEMENT INFORMATION NOTICE REVIEW. IN THE AREAS INSPECTED, ONE VIOLATION WAS IDENTIFIED.

INSPECTION JANUARY 21-22 (86-03): THIS SPECIAL ANNOUNCED INSPECTION ENTAILED 3.5 INSPECTOR-HOURS ON SITE AND 2.5 HOURS IN THE CORPORATE OFFICE AT JUNO BEACH IN THE AREA OF FIRE PROTECTION AND FOLLOWUP ON PREVIOUSLY NRC IDENTIFIED FINDINGS. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

Report Period FEB 1986

I N S P E C T I O N      S T A T U S - (CONTINUED)

\*\*\*\*\*  
\* ST LUCIE 1 \*  
\*\*\*\*\*

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

NORMAL OPERATIONS.

LAST IE SITE INSPECTION DATE: JANUARY 21-22, 1986 +

INSPECTION REPORT NO: 50-335/86-03 +


R E P O R T S   F R O M   L I C E N S E E

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
85-009	11/06/85	12/06/85	DEFECTIVE PROCEDURE LEADS TO LIFT RIG FAILURE. ROOT CAUSE OF THE INSUFFICIENT LIFTING BOLT THREAD ENGAGEMENT WAS DUE TO A DEFICIENCY IN THE MAINTENANCE PROCEDURE.
85-012	12/19/85	01/20/86	ISI SNUBBER INSPECTION FAILURES. THE CAUSES OF THE VARIOUS SNUBBER FAILURES INCLUDED DESIGN AND PERSONNEL ERRORS.

1. Docket: 50-389 OPERATING STATUS  
 2. Reporting Period: 02/01/86 Outage + On-line Hrs: 672.0  
 3. Utility Contact: N. W. GRANT (305) 552-3675  
 4. Licensed Thermal Power (MWh): 2700  
 5. Nameplate Rating (Gross MWe): 0850  
 6. Design Electrical Rating (Net MWe): 830  
 7. Maximum Dependable Capacity (Gross MWe): 882  
 8. Maximum Dependable Capacity (Net MWe): 837  
 9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE  
 10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_  
 11. Reasons for Restrictions, If Any:  
NONE  
 12. Report Period Hrs      MONTH      YEAR      CUMULATIVE  
672.0      1,416.0      22,465.0  
 13. Hours Reactor Critical      672.0      1,400.2      19,449.1  
 14. Rx Reserve Shtdwn Hrs      .0      .0      .0  
 15. Hrs Generator On-Line      672.0      1,383.5      18,955.7  
 16. Unit Reserve Shtdwn Hrs      .0      .0      .0  
 17. Gross Therm Ener (MWH)      1,806,646      3,698,090      48,344,624  
 18. Gross Elec Ener (MWH)      605,310      1,240,990      16,157,670  
 19. Net Elec Ener (MWH)      574,584      1,176,689      15,247,732  
 20. Unit Service Factor      100.0      97.7      84.4  
 21. Unit Avail Factor      100.0      97.7      84.4  
 22. Unit Cap Factor (MDC Net)      102.2      99.3      81.1  
 23. Unit Cap Factor (DER Net)      103.0      100.1      81.8  
 24. Unit Forced Outage Rate      .0      2.3      10.2  
 25. Forced Outage Hours      .0      32.5      2,159.1  
 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE  
 27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\* ST LUCIE 2 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT  
ST LUCIE 2



FEBRUARY 1986

Report Period FEB 1986

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* ST LUCIE 2 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System Component	Cause & Corrective Action to Prevent Recurrence
-----	------	------	-------	--------	--------	------------	------------------	---

NONE

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
ST. LUCIE 2 OPERATED ROUTINELY IN FEBRUARY WITH NO DUTAGES OR POWER REDUCTIONS REPORTED.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	Instructions for Preparation of
	C-Refueling	H-Other	Data Entry Sheet
	D-Regulatory Restriction	4-Continued	Licensee Event Report
	E-Operator Training & License Examination	5-Reduced Load	(LER) File (NUREG-0161)
		9-Other	

\*\*\*\*\*  
\* ST LUCIE 2 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1986

FACILITY DESCRIPTION

LOCATION  
STATE.....FLORIDA  
COUNTY.....ST LUCIE  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...12 MI SE OF  
FT. PIERCE, FLA  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...JUNE 2, 1983  
DATE ELEC ENER 1ST GENER...JUNE 13, 1983  
DATE COMMERCIAL OPERATE....AUGUST 8, 1983  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER....ATLANTIC OCEAN  
ELECTRIC RELIABILITY  
COUNCIL.....SOUTHEASTERN ELECTRIC  
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....FLORIDA POWER & LIGHT  
CORPORATE ADDRESS.....9250 WEST FLAGLER ST., P.O. BOX 529100  
MIAMI, FLORIDA 33152

CONTRACTOR  
ARCHITECT/ENGINEER.....EBASCO  
NUC STEAM SYS SUPPLIER...COMBUSTION ENGINEERING  
CONSTRUCTOR.....EBASCO  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II  
IE RESIDENT INSPECTOR.....R. CRENJAK  
LICENSING PROJ MANAGER.....E. TOURIGNY  
DOCKET NUMBER.....50-389  
LICENSE & DATE ISSUANCE....NPF-16, JUNE 10, 1983  
PUBLIC DOCUMENT ROOM.....INDIAN RIVER COMMUNITY COLLEGE LIBRARY  
3209 VIRGINIA AVENUE  
FT. PIERCE, FLORIDA 33450

I N S P E C T I O N     S T A T U S

INSPECTION SUMMARY

+ INSPECTION DECEMBER 16-20 (85-33): THIS ROUTINE, UNANNOUNCED INSPECTION INVOLVED 18 INSPECTOR-HOURS ON SITE IN THE AREAS OF FIRE PROTECTION/PREVENTION AND FOLLOWUP ON PREVIOUSLY IDENTIFIED INSPECTION ITEMS. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION DECEMBER 10 - JANUARY 13, 1986 (85-36): THIS INSPECTION INVOLVED 112 INSPECTOR-HOURS ON SITE IN THE AREAS OF TECHNICAL SPECIFICATION (TS) COMPLIANCE, OPERATOR PERFORMANCE, OVERALL PLANT OPERATIONS, QUALITY ASSURANCE PRACTICES, STATION AND CORPORATE MANAGEMENT PRACTICES, CORRECTIVE AND PREVENTIVE MAINTENANCE ACTIVITIES, SITE SECURITY PROCEDURES, RADIATION CONTROL ACTIVITIES, SURVEILLANCE ACTIVITIES, AND INSPECTION AND ENFORCEMENT INFORMATION NOTICE REVIEW. IN THE AREAS INSPECTED, ONE VIOLATION WAS IDENTIFIED.

INSPECTION JANUARY 21-22 (86-02): THIS SPECIAL ANNOUNCED INSPECTION ENTAILED 3.5 INSPECTOR-HOURS ON SITE AND 2.5 HOURS IN THE CORPORATE OFFICE AT JUNO BEACH IN THE AREA OF FIRE PROTECTION AND FOLLOWUP ON PREVIOUSLY NRC IDENTIFIED FINDINGS. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

Report Period FEB 1986

INSPECTION STATUS - (CONTINUED)

\*\*\*\*\*  
\* ST LUCIE 2 \*  
\*\*\*\*\*

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

+ NORMAL OPERATIONS. REFUELING OUTAGE SCHEDULED FOR 3/30/86.

LAST IE SITE INSPECTION DATE: JANUARY 21-22, 1986 +

INSPECTION REPORT NO: 50-389/86-02 +

REPORTS FROM LICENSEE

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
--------	------------------	-------------------	---------

=====

NONE.

1. Docket: 50-395 OPERATING STATUS  
 2. Reporting Period: 02/01/86 Outage + On-line Hrs: 672.0  
 3. Utility Contact: G. A. LOIGNON (803) 345-5209  
 4. Licensed Thermal Power (MWh): 2775  
 5. Nameplate Rating (Gross MWe): 0900  
 6. Design Electrical Rating (Net MWe): 900  
 7. Maximum Dependable Capacity (Gross MWe): 900  
 8. Maximum Dependable Capacity (Net MWe): 885  
 9. If Changes Occur Above Since Last Report, Give Reasons:  
 \_\_\_\_\_

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

11. Reasons for Restrictions, If Any: \_\_\_\_\_  
 NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>672.0</u>	<u>1,416.0</u>	<u>18,960.0</u>
13. Hours Reactor Critical	<u>628.7</u>	<u>1,372.7</u>	<u>13,366.0</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>614.9</u>	<u>1,358.9</u>	<u>12,999.2</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,638,382</u>	<u>3,677,538</u>	<u>33,515,104</u>
18. Gross Elec Ener (MWH)	<u>548,290</u>	<u>1,229,760</u>	<u>11,160,383</u>
19. Net Elec Ener (MWH)	<u>523,973</u>	<u>1,178,127</u>	<u>10,605,174</u>
20. Unit Service Factor	<u>91.5</u>	<u>96.0</u>	<u>68.6</u>
21. Unit Avail Factor	<u>91.5</u>	<u>96.0</u>	<u>68.6</u>
22. Unit Cap Factor (MDC Net)	<u>88.1</u>	<u>94.0</u>	<u>63.2</u>
23. Unit Cap Factor (DER Net)	<u>86.6</u>	<u>92.4</u>	<u>62.1</u>
24. Unit Forced Outage Rate	<u>8.5</u>	<u>4.0</u>	<u>7.9</u>
25. Forced Outage Hours	<u>57.1</u>	<u>57.1</u>	<u>1,117.8</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
 \_\_\_\_\_


NONE

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
 \* SUMMER 1 \*  
 \*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

SUMMER 1



FEBRUARY 1986

Report Period FEB 1986

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* SUMMER 1 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
1	02/02/86	F	57.1	B	3				TAGOUT CAUSED LOSS OF CONDENSATE FLOW. SI OCCURRED DURING RESTART.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*

SUMMER 1 OPERATED IN FEBRUARY WITH 1 SHUTDOWN AS DESCRIBED ABOVE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for Preparation of
	C-Refueling	3-Auto Scram	Data Entry Sheet
	D-Regulatory Restriction	4-Continued	Licensee Event Report
	E-Operator Training & License Examination	5-Reduced Load	(LER File (NUREG-0161)
		9-Other	

\*\*\*\*\*  
X SUMMER 1 X  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1986

FACILITY DESCRIPTION

LOCATION STATE.....SOUTH CAROLINA  
COUNTY.....FAIRFIELD  
DIST AND DIRECTION FROM NEAREST POPULATION CTR...26 MI NW OF COLUMBIA, SC  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...OCTOBER 22, 1982  
DATE ELEC ENER 1ST GENER...NOVEMBER 16, 1982  
DATE COMMERCIAL OPERATE....JANUARY 1, 1984  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER....MONTICELLO RESERVOIR  
ELECTRIC RELIABILITY COUNCIL.....SOUTHEASTERN ELECTRIC RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY LICENSEE.....SOUTH CAROLINA ELECTRIC & GAS CO.  
CORPORATE ADDRESS.....P.O. BOX 754 COLUMBIA, SOUTH CAROLINA 29202  
CONTRACTOR ARCHITECT/ENGINEER.....GILBERT ASSOCIATES  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
CONSTRUCTOR.....DANIEL INTERNATIONAL  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II  
IE RESIDENT INSPECTOR.....R. PREVATTE  
LICENSING PROJ MANAGER.....J. HOPKINS  
DOCKET NUMBER.....50-395  
LICENSE & DATE ISSUANCE....NPF-12, NOVEMBER 12, 1982  
PUBLIC DOCUMENT ROOM.....FAIRFIELD COUNTY LIBRARY  
GARDEN & WASHINGTON STREETS  
WINNSBORO, SOUTH CAROLINA 29180

I N S P E C T I O N     S T A T U S

INSPECTION SUMMARY

+ INSPECTION DECEMBER 1-31 (85-46): THIS ROUTINE, ANNOUNCED INSPECTION INVOLVED 360 RESIDENT INSPECTOR-HOURS ON SITE IN THE AREAS OF FOLLOWUP ON NONROUTINE EVENTS AND REPORTS, SURVEILLANCE OBSERVATIONS OF SAFETY RELATED SYSTEMS, OBSERVATION OF MAINTENANCE ACTIVITIES, FOLLOWUP OF OPERATIONAL EVENTS, OPERATIONAL SAFETY VERIFICATIONS, PLANT STARTUP FROM REFUELING, ENGINEERED SAFETY SYSTEMS, ORGANIZATIONAL AND ADMINISTRATIVE ACTIVITIES. OF THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JANUARY 6-10 (86-01): THIS ROUTINE, UNANNOUNCED INSPECTION ENTAILED 37 INSPECTOR-HOURS AT THE SITE DURING NORMAL DUTY HOURS, IN THE AREAS OF PLANT CHEMISTRY. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JANUARY 1-31 (86-02): THIS ROUTINE, ANNOUNCED INSPECTION INVOLVED 263 RESIDENT INSPECTOR-HOURS ON SITE IN THE AREAS OF FOLLOWUP ON NONROUTINE EVENTS AND REPORTS, SURVEILLANCE OBSERVATIONS OF SAFETY RELATED SYSTEMS, OBSERVATION OF MAINTENANCE ACTIVITIES, FOLLOWUP OF OPERATIONAL EVENTS, ESF SYSTEM WALKDOWN, OPERATIONAL SAFETY VERIFICATIONS, PLANT PHYSICAL PROTECTION AND INFORMATION MEETING WITH LOCAL OFFICIALS. OF THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

Report Period FEB 1986

I N S P E C T I O N      S T A T U S - (CONTINUED)

\*\*\*\*\*  
\* SUMMER 1 \*  
\*\*\*\*\*

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

NORMAL OPERATION.

LAST IE SITE INSPECTION DATE: JANUARY 1-31, 1986 +

INSPECTION REPORT NO: 50-395/86-02 +

R E P O R T S   F R O M   L I C E N S E E

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
85-031	10/14/85	11/13/85	STEAM GENERATOR TUBE EDDY CURRENT EXAMINATION. TUBE DEGRADATION APPEARS TO BE RELATED TO STRESSES FROM IMPROPER ROLLING OF THE TUBES.
85-033	12/11/85	01/10/86	REACTOR VESSEL LEVEL INDICATION SYSTEM ERROR. CORRECTIVE ACTION WILL BE TO RE-SCALE RVLIS FOR THE STEAM DENSITY COMPENSATION.
85-034	12/25/85	01/24/86	REACTOR TRIP WITH SAFETY INJECTION. THE CAUSE OF THIS EVENT WAS IMPROPER ASSEMBLY OF THE POSITIONER PILOT VALVE.

1. Docket: 50-280 OPERATING STATUS  
 2. Reporting Period: 02/01/86 Outage + On-line Hrs: 672.0  
 3. Utility Contact: VIVIAN H. JONES (804) 357-3184  
 4. Licensed Thermal Power (MWh): 2441  
 5. Nameplate Rating (Gross MWe): 942 X 0.9 = 848  
 6. Design Electrical Rating (Net MWe): 788  
 7. Maximum Dependable Capacity (Gross MWe): 820  
 8. Maximum Dependable Capacity (Net MWe): 781  
 9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_  
 11. Reasons for Restrictions, If Any: \_\_\_\_\_  
NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>672.0</u>	<u>1,416.0</u>	<u>115,608.0</u>
13. Hours Reactor Critical	<u>504.8</u>	<u>1,047.9</u>	<u>73,376.0</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>3,774.5</u>
15. Hrs Generator On-Line	<u>494.0</u>	<u>1,014.7</u>	<u>71,852.8</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>3,736.2</u>
17. Gross Therm Ener (MWH)	<u>1,145,190</u>	<u>2,319,634</u>	<u>165,676,560</u>
18. Gross Elec Ener (MWH)	<u>383,835</u>	<u>766,915</u>	<u>53,538,848</u>
19. Net Elec Ener (MWH)	<u>364,466</u>	<u>727,070</u>	<u>50,757,199</u>
20. Unit Service Factor	<u>73.5</u>	<u>71.7</u>	<u>62.2</u>
21. Unit Avail Factor	<u>73.5</u>	<u>71.7</u>	<u>65.4</u>
22. Unit Cap Factor (MDC Net)	<u>69.4</u>	<u>65.7</u>	<u>56.2</u>
23. Unit Cap Factor (DER Net)	<u>68.8</u>	<u>65.2</u>	<u>55.7</u>
24. Unit Forced Outage Rate	<u>2.1</u>	<u>5.2</u>	<u>18.9</u>
25. Forced Outage Hours	<u>10.5</u>	<u>56.0</u>	<u>13,037.3</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
REFUELING: 05/09/86 - 48 DAYS.  
 27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\* SURRY 1 \*\*\*\*  
 \*\*\*\* SURRY 1 \*\*\*\*

#### AVERAGE DAILY POWER LEVEL (MWe) PLOT

SURRY 1



FEBRUARY 1986

Report Period FEB 1986

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* SURRY 1 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System Component	Cause & Corrective Action to Prevent Recurrence
86-03	01/24/86	S	167.5	A	4			CONTINUATION OF SNUBBER OUTAGE.
86-04	02/07/86	F	10.5	A	3			REACTOR TRIP BY TURBINE TRIP, CAUSED BY "C" STEAM GENERATOR HIGH LEVEL DURING STARTUP. HIGH LEVEL CAUSED BY THE "C" BYPASS VALVE FAILING OPEN. CORRECTIVE ACTION - TECHNICAL BLEW MOISTURE OUT OF SENSING LINES TO THE BYPASS VALVE.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*

SURRY 1 INCURRED 2 SHUTDOWNS IN FEBRUARY AS DISCUSSED ABOVE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	Instructions for Preparation of Data Entry Sheet
	C-Refueling	H-Other	Licensor Event Report
	D-Regulatory Restriction		(LER) File (NUREG-0161)
	E-Operator Training & License Examination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	

\*\*\*\*\*  
X SURRY 1 X  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1986

FACILITY DESCRIPTION

LOCATION STATE.....VIRGINIA  
COUNTY.....SURRY  
DIST AND DIRECTION FROM NEAREST POPULATION CTR...17 MI NW OF NEWPORT NEWS, VA  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...JULY 1, 1972  
DATE ELEC ENER 1ST GENER...JULY 4, 1972  
DATE COMMERCIAL OPERATE....DECEMBER 22, 1972  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER....JAMES RIVER  
ELECTRIC RELIABILITY COUNCIL.....SOUTHEASTERN ELECTRIC RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY LICENSEE.....VIRGINIA POWER  
CORPORATE ADDRESS.....P.O. BOX 26666 RICHMOND, VIRGINIA 23261  
CONTRACTOR ARCHITECT/ENGINEER.....STONE & WEBSTER  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
CONSTRUCTOR.....STONE & WEBSTER  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II  
IE RESIDENT INSPECTOR.....D. BURKE  
LICENSING PROJ MANAGER.....C. PATEL  
DOCKET NUMBER.....50-280  
LICENSE & DATE ISSUANCE....DPR-32, MAY 25, 1972  
PUBLIC DOCUMENT ROOM.....SWEM LIBRARY  
COLLEGE OF WILLIAM AND MARY  
WILLIAMSBURG, VIRGINIA 23185

I N S P E C T I O N     S T A T U S

INSPECTION SUMMARY

+ INSPECTION DECEMBER 30 - JANUARY 3, 1986 (85-39): THIS ROUTINE, UNANNOUNCED INSPECTION ENTAILED 13 INSPECTOR-HOURS ON SITE IN THE AREAS OF MAINTENANCE AND SURVEILLANCE TESTING OF THE PRESSURIZER CODE SAFETY VALVES AND THE MAIN STEAM CODE SAFETY VALVES. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JANUARY 6-10 (86-01): THIS ROUTINE, UNANNOUNCED INSPECTION INVOLVED 17 INSPECTOR-HOURS ON SITE IN THE AREAS OF LIQUID AND GASEOUS RADWASTE SYSTEMS, LIQUID AND GASEOUS EFFLUENT SAMPLING, ANALYSIS, MONITORING AND REPORTING, AND PREVIOUSLY IDENTIFIED INSPECTOR FOLLOWUP ITEMS. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

Report Period FEB 1986

I N S P E C T I O N      S T A T U S - (CONTINUED)

\*\*\*\*\*  
\* SURRY 1 \*  
\*\*\*\*\*

OTHER ITEMS

NONE.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

REFUELING OUTAGE

LAST IE SITE INSPECTION DATE: JANUARY 6-10, 1986 +

INSPECTION REPORT NO: 50-280/86-01 +

R E P O R T S   F R O M   L I C E N S E E


NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
--------	------------------	-------------------	---------

85-021	11/14/85	12/11/86	INADVERTENT ESF ACTUATION. AUXILIARY FEED PUMP STARTED BECAUSE OF AN OPEN COIL IN BFD RELAY.
--------	----------	----------	--

1. Docket: 50-281 OPERATING STATUS  
 2. Reporting Period: 02/01/86 Outage + On-line Hrs: 672.0  
 3. Utility Contact: VIVIAN H. JONES (804) 357-3184  
 4. Licensed Thermal Power (MWt): 2441  
 5. Nameplate Rating (Gross MWe): 942 X 0.9 = 848  
 6. Design Electrical Rating (Net MWe): 788  
 7. Maximum Dependable Capacity (Gross MWe): 811  
 8. Maximum Dependable Capacity (Net MWe): 781  
 9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE  
 10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_  
 11. Reasons for Restrictions, If Any:  
NONE  
 12. Report Period Hrs      MONTH      YEAR      CUMULATIVE  
672.0      1,416.0      112,488.0  
 13. Hours Reactor Critical      481.9      1,225.9      73,168.3  
 14. Rx Reserve Shtdwn Hrs      .0      .0      23.8  
 15. Hrs Generator On-Line      465.9      1,209.9      71,975.3  
 16. Unit Reserve Shtdwn Hrs      .0      .0      .0  
 17. Gross Therm Ener (MWH)      1,093,580      2,907,919      168,214,946  
 18. Gross Elec Ener (MWH)      362,090      959,350      54,542,654  
 19. Net Elec Ener (MWH)      343,909      911,789      51,700,676  
 20. Unit Service Factor      69.3      85.4      64.0  
 21. Unit Avail Factor      69.3      85.4      64.0  
 22. Unit Cap Factor (MDC Net)      65.5      82.8      58.8  
 23. Unit Cap Factor (DER Net)      64.9      81.7      58.3  
 24. Unit Forced Outage Rate      .0      .0      12.8  
 25. Forced Outage Hours      .0      .0      7,931.8  
 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE  
 27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\* SURRY 2 \*  
\*\*\*\*\*  
AVERAGE DAILY POWER LEVEL (MWe) PLOT

SURRY 2



FEBRUARY 1986

Report Period FEB 1986

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* SURRY 2 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
86-02	02/16/86	S	206.1	H	3				UNIT SHUTDOWN FOR SNUBBER OUTAGE. REACTOR TRIPPED ON "B" S/G HIGH LEVEL AFTER THE GENERATOR WAS OFF THE LINE. CAUSE OF S/G HIGH LEVEL WAS EXCESSIVE LEAKAGE THRU THE FEED REGULATING AND BYPASS VALVES. CORRFCTIVE ACTION - MAINTENANCE PERFORMED ON VALVE DURING OUTAGE.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
SURRY 2 INCURRED 1 SHUTDOWN IN FEBRUARY FOR SNUBBER AND OTHER MAINTENANCE. SEE DETAILS ABOVE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	Instructions for Preparation of Data Entry Sheet
	C-Refueling	H-Other	Licensee Event Report (LER) File (NUREG-0161)
	D-Regulatory Restriction		
	E-Operator Training & License Examination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	

\*\*\*\*\*  
\* SURRY 2 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1986

FACILITY DESCRIPTION

LOCATION  
STATE.....VIRGINIA

COUNTY.....SURRY

DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...17 MI NW OF  
NEWPORT NEWS, VA

TYPE OF REACTOR.....PWR

DATE INITIAL CRITICALITY...MARCH 7, 1973

DATE ELEC ENER 1ST GENER...MARCH 10, 1973

DATE COMMERCIAL OPERATE...MAY 1, 1973

CONDENSER COOLING METHOD...ONCE THRU

CONDENSER COOLING WATER....JAMES RIVER

ELECTRIC RELIABILITY  
COUNCIL.....SOUTHEASTERN ELECTRIC  
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....VIRGINIA POWER

CORPORATE ADDRESS.....P.O. BOX 26666  
RICHMOND, VIRGINIA 23261

CONTRACTOR  
ARCHITECT/ENGINEER.....STONE & WEBSTER

NUC STEAM SYS SUPPLIER...WESTINGHOUSE

CONSTRUCTOR.....STONE & WEBSTER

TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II

IE RESIDENT INSPECTOR.....D. BURKE

LICENSING PROJ MANAGER.....C. PATEL  
DOCKET NUMBER.....50-281

LICENSE & DATE ISSUANCE....DPR-37, JANUARY 29, 1973

PUBLIC DOCUMENT ROOM.....SWEM LIBRARY  
COLLEGE OF WILLIAM AND MARY  
WILLIAMSBURG, VIRGINIA 23185

I N S P E C T I O N     S T A T U S

INSPECTION SUMMARY

+ INSPECTION DECEMBER 30 - JANUARY 3, 1986 (85-39): THIS ROUTINE, UNANNOUNCED INSPECTION ENTAILED 14 INSPECTOR-HOURS ON SITE IN THE AREAS OF MAINTENANCE AND SURVEILLANCE TESTING OF THE PRESSURIZER CODE SAFETY VALVES AND THE MAIN STEAM CODE SAFETY VALVES. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JANUARY 6-10 (86-01): THIS ROUTINE, UNANNOUNCED INSPECTION INVOLVED 18 INSPECTOR-HOURS ON SITE IN THE AREAS OF LIQUID AND GASEOUS RADWASTE SYSTEMS, LIQUID AND GASEOUS EFFLUENT SAMPLING, ANALYSIS, MONITORING AND REPORTING, AND PREVIOUSLY IDENTIFIED INSPECTOR FOLLOWUP ITEMS. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

Report Period FEB 1986

I N S P E C T I O N      S T A T U S - (CONTINUED)

\*\*\*\*\*  
\* SURRY 2 \*  
\*\*\*\*\*

OTHER ITEMS

NONE.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

REFUELING OUTAGE

LAST IE SITE INSPECTION DATE: JANUARY 6-10, 1986 +


INSPECTION REPORT NO: 50-281/86-01 +

R E P O R T S   F R O M   L I C E N S E E

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
85-012	10/26/85	11/25/85	INADVERTENT DILUTION. THE FLOW TRANSMITTER TO THE BORIC ACID INTEGRATOR WAS OUT OF CALIBRATION.
85-013	11/07/85	12/06/85	TURBINE TRIP/RX TRIP-HI S.G. LEVEL. CAUSE - OPERATOR'S LACK OF EXPERIENCE.
85-014	12/26/85	01/22/86	ROD CONTROL URGENT FAILURE. THE PROBLEM WAS FOUND TO BE IN THE LOGIC CABINET PULSER CARD.

1. Docket: 50-387 OPERATING STATUS  
 2. Reporting Period: 02/01/86 Outage + On-line Hrs: 672.0  
 3. Utility Contact: J. A. HIRT (717) 542-3917  
 4. Licensed Thermal Power (MWh): 3293  
 5. Nameplate Rating (Gross MWe): 1280 X 0.9 = 1152  
 6. Design Electrical Rating (Net MWe): 1065  
 7. Maximum Dependable Capacity (Gross MWe): 1068  
 8. Maximum Dependable Capacity (Net MWe): 1032  
 9. If Changes Occur Above Since Last Report, Give Reasons:  
 \_\_\_\_\_  
 10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_  
 11. Reasons for Restrictions, If Any: \_\_\_\_\_  
 NONE  
 12. Report Period Hrs MONTH 672.0 YEAR 1,416.0 CUMULATIVE 23,929.0  
 13. Hours Reactor Critical 337.8 1,081.8 17,074.9  
 14. Rx Reserve Shtdwn Hrs .0 .0 671.1  
 15. Hrs Generator On-Line 337.0 1,081.0 16,701.6  
 16. Unit Reserve Shtdwn Hrs .0 .0 .0  
 17. Gross Therm Ener (MWH) 1,069,170 3,420,677 51,000,950  
 18. Gross Elec Ener (MWH) 349,286 1,118,896 16,617,888  
 19. Net Elec Ener (MWH) 331,508 1,072,624 15,961,850  
 20. Unit Service Factor 50.1 76.3 69.8  
 21. Unit Avail Factor 50.1 76.3 69.8  
 22. Unit Cap Factor (MDC Net) 47.8 73.4 64.6  
 23. Unit Cap Factor (DER Net) 46.3 71.1 62.6  
 24. Unit Forced Outage Rate .0 .0 19.6  
 25. Forced Outage Hours .0 .0 1,980.1  
 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
 NONE  
 27. If Currently Shutdown Estimated Startup Date: 05/18/86

\*\*\*\* SUSQUEHANNA 1 \*\*\*\*  
 AVERAGE DAILY POWER LEVEL (MWe) PLOT  
 SUSQUEHANNA 1



FEBRUARY 1986

Report Period FEB 1986

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* SUSQUEHANNA 1 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System Component	Cause & Corrective Action to Prevent Recurrence
3	02/15/86	S	335.0	C	2		RC FUELXX	MANUAL SCRAM TO COMMENCE SECOND REFUELING OUTAGE.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
SUSQUEHANNA 1 BEGAN ON REFUELING OUTAGE ON FEBRUARY 15.

Type	Reason	Method	System & Component	
F-Forced	A-Equip Failure	F-Admin	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	2-Manual Scram	Instructions for
	C-Refueling	H-Other	3-Auto Scram	Preparation of
	D-Regulatory Restriction		4-Continued	Data Entry Sheet
	E-Operator Training & License Examination		5-Reduced Load	Licensee Event Report
			6-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* SUSQUEHANNA 1 \*  
\*\*\*\*\*

FACILITY DESCRIPTION

LOCATION  
STATE.....PENNSYLVANIA  
COUNTY.....LUZERNE  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...7 MI NE OF  
BERWICK, PA  
TYPE OF REACTOR.....BWR  
DATE INITIAL CRITICALITY...SEPTEMBER 10, 1982  
DATE ELEC ENER 1ST GENER...NOVEMBER 16, 1982  
DATE COMMERCIAL OPERATE....JUNE 8, 1983  
CONDENSER COOLING METHOD...CC,HNDCT  
CONDENSER COOLING WATER....SUSQUEHANNA RIVER  
ELECTRIC RELIABILITY  
COUNCIL.....MID-ATLANTIC  
AREA COUNCIL

FACILITY DATA

Report Period FEB 1986

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....PENNSYLVANIA POWER & LIGHT  
CORPORATE ADDRESS.....2 NORTH NINTH STREET  
ALLENTOWN, PENNSYLVANIA 18101  
CONTRACTOR  
ARCHITECT/ENGINEER.....BECHTEL  
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC  
CONSTRUCTOR.....BECHTEL  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I  
IE RESIDENT INSPECTOR.....R. JACOBS  
LICENSING PROJ MANAGER.....M. CAMPAGNONE  
DOCKET NUMBER.....50-387  
LICENSE & DATE ISSUANCE....NPF-14, NOVEMBER 12, 1982  
PUBLIC DOCUMENT ROOM.....OSTERHOUT FREE LIBRARY  
71 SOUTH FRANKLIN STREET  
WILKES-BARRE, PENNSYLVANIA 18701

I N S P E C T I O N     S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

Report Period FEB 1986

I N S P E C T I O N      S T A T U S - (CONTINUED)

\*\*\*\*\*  
\* SUSQUEHANNA 1 \*  
\*\*\*\*\*

OTHER ITEMS

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S   F R O M   L I C E N S E E

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
NO INPUT PROVIDED.			

1. Docket: 50-388 OPERATING STATUS  
2. Reporting Period: 02/01/86 Outage + On-line Hrs: 672.0  
3. Utility Contact: J. A. HIRT (717) 542-3917


4. Licensed Thermal Power (MWh): 3293  
5. Nameplate Rating (Gross MWe): 1152  
6. Design Electrical Rating (Net MWe): 1065  
7. Maximum Dependable Capacity (Gross MWe): 1068  
8. Maximum Dependable Capacity (Net MWe): 1032  
9. If Changes Occur Above Since Last Report, Give Reasons:  
  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_  
11. Reasons for Restrictions, If Any: \_\_\_\_\_  
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>672.0</u>	<u>1,416.0</u>	<u>9,168.0</u>
13. Hours Reactor Critical	<u>672.0</u>	<u>1,282.4</u>	<u>8,403.6</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>133.6</u>	<u>693.9</u>
15. Hrs Generator On-Line	<u>672.0</u>	<u>1,257.6</u>	<u>8,252.7</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>2,161,190</u>	<u>3,951,679</u>	<u>25,982,477</u>
18. Gross Elec Ener (MWH)	<u>715,402</u>	<u>1,305,762</u>	<u>8,518,562</u>
19. Net Elec Ener (MWH)	<u>690,779</u>	<u>1,257,746</u>	<u>8,212,056</u>
20. Unit Service Factor	<u>100.0</u>	<u>88.8</u>	<u>90.0</u>
21. Unit Avail Factor	<u>100.0</u>	<u>88.8</u>	<u>90.0</u>
22. Unit Cap Factor (MDC Net)	<u>99.6</u>	<u>86.1</u>	<u>86.8</u>
23. Unit Cap Factor (DER Net)	<u>96.5</u>	<u>83.4</u>	<u>84.1</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>11.2</u>	<u>10.0</u>
25. Forced Outage Hours	<u>.0</u>	<u>158.4</u>	<u>915.3</u>
26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):			
REFUELING OUTAGE: 08/02/86 - 84 DAYS.			
27. If Currently Shutdown Estimated Startup Date:	<u>N/A</u>		

\*\*\*\*\*  
\* SUSQUEHANNA 2 \*  
\*\*\*\*\*  
AVERAGE DAILY POWER LEVEL (MWe) PLOT

SUSQUEHANNA 2



FEBRUARY 1986

Report Period FEB 1986

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* SUSQUEHANNA 2 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System Component	Cause & Corrective Action to Prevent Recurrence
NONE								

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*

SUSQUEHANNA 2 OPERATED ROUTINELY IN FEBRUARY WITH NO OUTAGES OR POWER REDUCTIONS REPORTED.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	1-Manual
S-Sched	B-Maint or Test	G-Oper Error	2-Manual Scram
	C-Refueling	H-Other	3-Auto Scram
	D-Regulatory Restriction		4-Continued
	E-Operator Training & License Examination		5-Reduced Load
			9-Other
			Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161)

\*\*\*\*\*  
X SUSQUEHANNA 2 X  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1986

FACILITY DESCRIPTION

LOCATION  
STATE.....PENNSYLVANIA

COUNTY.....LUZERNE

DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...7 MI NE OF  
BERWICK, PA

TYPE OF REACTOR.....BWR

DATE INITIAL CRITICALITY...MAY 8, 1984

DATE ELEC ENER 1ST GENER...JULY 3, 1984

DATE COMMERCIAL OPERATE....FEBRUARY 12, 1985

CONDENSER COOLING METHOD...CC,HNDCT

CONDENSER COOLING WATER....SUSQUEHANNA RIVER

ELECTRIC RELIABILITY  
COUNCIL.....MID-ATLANTIC  
AREA COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....PENNSYLVANIA POWER & LIGHT  
CORPORATE ADDRESS.....2 NORTH NINTH STREET  
ALLENTOWN, PENNSYLVANIA 18101

CONTRACTOR  
ARCHITECT/ENGINEER.....BECHTEL

NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC

CONSTRUCTOR.....BECHTEL

TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I

IE RESIDENT INSPECTOR.....L. PLISCO

LICENSING PROJ MANAGER.....M. CAMPAGNONE  
DOCKET NUMBER.....50-388

LICENSE & DATE ISSUANCE....NPF-22, JUNE 27, 1984

PUBLIC DOCUMENT ROOM.....

WILKES-BARRE, PENNSYLVANIA 18701

I N S P E C T I O N     S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

Report Period FEB 1986

I N S P E C T I O N      S T A T U S - (CONTINUED)

\*\*\*\*\*  
\* SUSQUEHANNA 2 \*  
\*\*\*\*\*

OTHER ITEMS

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S   F R O M   L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
NO INPUT PROVIDED.			


=====

1. Docket: 50-289 OPERATING STATUS  
 2. Reporting Period: 02/01/86 Outage + On-line Hrs: 672.0  
 3. Utility Contact: C. W. SMYTH (717) 948-8551  
 4. Licensed Thermal Power (MWe): 2535  
 5. Nameplate Rating (Gross MWe): 968 X 0.9 = 871  
 6. Design Electrical Rating (Net MWe): 819  
 7. Maximum Dependable Capacity (Gross MWe): 840  
 8. Maximum Dependable Capacity (Net MWe): 776  
 9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE  
 10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_  
 11. Reasons for Restrictions, If Any:  
NONE  
 12. Report Period Hrs      MONTH      YEAR      CUMULATIVE  
672.0      1,416.0      100,753.0  
 13. Hours Reactor Critical      586.0      1,190.3      35,006.9  
 14. Rx Reserve Shtdwn Hrs      86.0      191.3      1,075.5  
 15. Hrs Generator On-Line      582.8      1,178.7      34,212.6  
 16. Unit Reserve Shtdwn Hrs      .0      .0      .0  
 17. Gross Therm Ener (MWH)      1,452,251      2,925,796      82,276,192  
 18. Gross Elec Ener (MWH)      491,292      976,657      27,368,810  
 19. Net Elec Ener (MWH)      461,761      915,531      25,567,244  
 20. Unit Service Factor      86.7      83.2      34.0  
 21. Unit Avail Factor      86.7      83.2      34.0  
 22. Unit Cap Factor (MDC Net)      88.5      83.3      32.5\*  
 23. Unit Cap Factor (DER Net)      83.9      78.9      31.0  
 24. Unit Forced Outage Rate      13.3      7.8      63.3  
 25. Forced Outage Hours      89.2      99.7      58,868.2  
 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
EDDY CURRENT: 03/22/86 - 35 DAYS.  
 27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\* THREE MILE ISLAND 1 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

THREE MILE ISLAND 1



FEBRUARY 1986

\* Item calculated with a Weighted Average

Report Period FEB 1986

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* THREE MILE ISLAND 1 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
1	01/27/86	F	89.2	A	4		HJ	HTEXCH	SHUTDOWN TO REPAIR BELLOWS ON EXTRACTION STEAM LINE CONCLUDES.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
THREE MILE ISLAND 1 EXPERIENCED 1 SHUTDOWN IN FEBRUARY  
FOR AN EXTRACTION STEAM LINE BELLOWS REPAIR.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	1-Manual Exhibit F & H
S-Sched	B-Maint or Test	G-Upper Error	2-Manual Scram Instructions for
	C-Refueling	H-Other	3-Auto Scram Preparation of
	D-Regulatory Restriction		4-Continued Data Entry Sheet
	E-Operator Training & License Examination		5-Reduced Load Licensee Event Report
			9-Other (LER) File (NUREG-0161)

\*\*\*\*\*  
\* THREE MILE ISLAND 1 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1986

FACILITY DESCRIPTION

LOCATION  
STATE..... PENNSYLVANIA  
COUNTY..... DAUPHIN  
  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR... 10 MI SE OF  
HARRISBURG, PA  
  
TYPE OF REACTOR..... PWR  
  
DATE INITIAL CRITICALITY... JUNE 5, 1974  
  
DATE ELEC ENER 1ST GENER... JUNE 19, 1974  
  
DATE COMMERCIAL OPERATE... SEPTEMBER 2, 1974  
  
CONDENSER COOLING METHOD... COOLING TOWERS  
  
CONDENSER COOLING WATER... SUSQUEHANNA RIVER  
  
ELECTRIC RELIABILITY  
COUNCIL..... MID-ATLANTIC  
AREA COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE..... GPU NUCLEAR CORP.  
  
CORPORATE ADDRESS..... P.O. BOX 480  
MIDDLETOWN, PENNSYLVANIA 17057  
  
CONTRACTOR  
ARCHITECT/ENGINEER..... GILBERT ASSOCIATES  
  
NUC STEAM SYS SUPPLIER... BABCOCK & WILCOX  
  
CONSTRUCTOR..... UNITED ENG. & CONSTRUCTORS  
  
TURBINE SUPPLIER..... GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE..... I  
  
IE RESIDENT INSPECTOR..... R. CONTE  
  
LICENSING PROJ MANAGER..... J. THOMA  
DOCKET NUMBER..... 50-289  
  
LICENSE & DATE ISSUANCE.... DPR-50, APRIL 19, 1974  
  
PUBLIC DOCUMENT ROOM..... GOVERNMENT PUBLICATIONS SECTION  
STATE LIBRARY OF PENNSYLVANIA  
FORUM BUILDING  
COMMONWEALTH AND WALNUT STREET  
HARRISBURG, PENNSYLVANIA 17105

I N S P E C T I O N     S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

CONTRARY TO TECH SPEC 6.8.1 REQUIREMENTS TO ESTABLISH AND IMPLEMENT WRITTEN PROCEDURES RECOMMENDED IN APPENDIX A OF REG GUIDE 1.33: A) ON OCTOBER 23, 1985, AN OPERATION INVOLVING THE OVERRIDING OF THE SAFETY RODS OUT INTERLOCK FOR THE CONTROL ROD DRIVE SYSTEM WAS CONDUCTED WITHOUT THE USE OF A WRITTEN PROCEDURE; B) ON NOVEMBER 1, 1985, AN OXYGEN SAMPLE WAS TAKEN FROM THE REACTOR COOLANT DRAIN TANK WITHOUT THE USE OF A WRITTEN PROCEDURE, RESULTING IN THE INADVERTENT DRAINING OF ONE LEG OF DIFFERENTIAL FLOW TRANSMITTER 922 WHICH MADE THIS REACTOR COOLANT SAFETY VALVE FLOW INSTRUMENT INOPERABLE UNTIL THE LEG WAS REFILLED LATER THE SAME DAY; C) ON NOVEMBER 1 AND 6, 1985, DURING THE LINEUP FOR A LIQUID RELEASE FROM THE WASTE EVAPORATOR CONDENSATE STORAGE TANK PER OPERATING PROCEDURE 1104-29B, PROCEDURE STEPS 1.3.A, B, C COULD NOT BE IMPLEMENTED AS WRITTEN AND THE SUPERVISOR WAS NOT CONTACTED TO RESOLVE THE DISCREPANCY; AND D) ON NOVEMBER 12, 1985, THE PREINSPECTION LINEUP FOR EMERGENCY DIESEL GENERATOR 1B COULD NOT BE IMPLEMENTED AS WRITTEN AND THE SUPERVISOR WAS NOT CONTACTED TO RESOLVE THE DISCREPANCY. CONTRARY TO TECH SPEC 6.5.1.1 AND 6.8.2 REQUIREMENTS THAT CHANGES TO SAFETY-RELATED ADMINISTRATIVE CONTROL PROCEDURES BE REVIEWED FOR ADEQUACY BETWEEN SEPTEMBER 5, 1984 AND NOVEMBER 27, 1985, CHANGES (REVISIONS) WERE MADE TO SEVERAL SAFETY-RELATED ADMINISTRATIVE CONTROL PROCEDURES (AP) DEALING WITH

Report Period FEB 1986

INSPECTION STATUS - (CONTINUED)

\*\*\*\*\*  
\* THREE MILE ISLAND 1 \*  
\*\*\*\*\*

ENFORCEMENT SUMMARY

INDEPENDENT VERIFICATION OF SAFETY-RELATED ACTIVITIES, AND THESE CHANGES WERE NOT COMPLETELY REVIEWED FOR ADEQUACY. CONTRARY TO TECH SPEC 6.54 AND 6.81 AND FACILITY PROCEDURE 6310-ADM-1010.01 REQUIREMENTS FOR THE INDEPENDENT ONSITE SAFETY REVIEW GROUP (IOSRG): A) AS OF NOVEMBER 15, 1985, NO SCHEDULE FOR EVALUATIONS AND ASSESSMENTS TO IMPLEMENT THE PERIODIC REVIEW REQUIREMENTS HAD BEEN PREPARED BY THE MANAGER, SAFETY REVIEW, AND AS A RESULT, NO PERIODIC REVIEW OF THE REQUIRED FUNCTIONAL AREAS HAD BEEN PERFORMED; B) DURING THE PERIOD OF JANUARY 1984 TO NOVEMBER 1985, REPORTS WERE GENERATED BY IOSRG IN THE FORM OF MEMORANDA, BUT THERE WAS NO INDICATION OF REPORT APPROVAL AND DISTRIBUTION OF THESE REPORTS WAS NOT IN ACCORDANCE WITH THE TECHNICAL SPECIFICATION DISTRIBUTION REQUIREMENTS; C) IOSRG RECORDS FOR THE PERIOD JANUARY 1984 TO NOVEMBER 1985 SHOWED NO METHOD OF APPROVAL OF RECOMMENDATIONS EXISTS, RECOMMENDATIONS ARE NOT ALWAYS CLEARLY IDENTIFIED, RECOMMENDATIONS ARE NOT ALWAYS TRANSMITTED AS SPECIFIED AND RESULTS OF RECOMMENDATIONS ARE NOT MAINTAINED; AND D) BETWEEN JULY 20, 1984 AND OCTOBER 31, 1985, SEVEN TECHNICAL SPECIFICATION CHANGES WERE SUBMITTED TO THE NRC, BUT ONLY TWO OF THOSE CHANGES, TECHNICAL SPECIFICATION CHANGE REQUESTS 141 AND 146, HAD SAFETY REVIEW SHEETS COMPLETED.  
(8502 4)

CONTRARY TO SECURITY PLAN, TECH SPEC 6.8.1.D AND SECURITY PROCEDURE 1005.11 REQUIREMENTS THAT PERSONNEL IN PROTECTED AND VITAL AREAS DISPLAY THEIR PHOTO IDENTIFICATION BADGES, ON NOVEMBER 15 AND 18, 1985, PHOTO IDENTIFICATION BADGES AND KEYCARDS WERE FOUND ATTACHED TO GARMENTS ON A RACK AT AN UNATTENDED CHANGING STATION, AND THEREFORE WERE NOT ON THE INDIVIDUALS; FURTHER, BETWEEN NOVEMBER 20 AND 27, 1985, CERTAIN EMPLOYEES WERE IN THE INSTRUMENT AND CONTROL SHOP AND THE CONTROL ROOM AND THEIR PHOTO IDENTIFICATION BADGES WERE NOT DISPLAYED OR SECURED IN THEIR POCKETS.  
(8502 5)

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

Report Period FEB 1986

REPORTS FROM LICENSEE

\*\*\*\*\*  
X THREE MILE ISLAND 1  
\*\*\*\*\*


NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
NO INPUT PROVIDED.			

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-344 OPERATING STATUS  
 2. Reporting Period: 02/01/86 Outage + On-line Hrs: 672.0  
 3. Utility Contact: F. J. UHMER (503) 556-3713 X495  
 4. Licensed Thermal Power (MWh): 3411  
 5. Nameplate Rating (Gross MWe): 1280 X 0.95 = 1216  
 6. Design Electrical Rating (Net MWe): 1130  
 7. Maximum Dependable Capacity (Gross MWe): 1122  
 8. Maximum Dependable Capacity (Net MWe): 1050  
 9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE  
 10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_  
 11. Reasons for Restrictions, If Any:  
NONE  
 12. Report Period Hrs      MONTH      YEAR      CUMULATIVE  
672.0      1,416.0      83,232.0  
 13. Hours Reactor Critical      658.4      1,402.4      51,952.8  
 14. Rx Reserve Shtdwn Hrs      .0      .0      3,875.4  
 15. Hrs Generator On-Line      656.6      1,400.6      50,454.9  
 16. Unit Reserve Shtdwn Hrs      .0      .0      3,237.0  
 17. Gross Therm Ener (MWH)      2,178,213      4,712,197      161,242,780  
 18. Gross Elec Ener (MWH)      698,938      1,513,228      52,331,544  
 19. Net Elec Ener (MWH)      665,609      1,442,316      49,503,590  
 20. Unit Service Factor      97.7      98.9      60.6  
 21. Unit Avail Factor      97.7      98.9      64.5  
 22. Unit Cap Factor (MDC Net)      94.3      97.0      56.6  
 23. Unit Cap Factor (DER Net)      87.7      90.1      52.6  
 24. Unit Forced Outage Rate      2.3      1.1      15.2  
 25. Forced Outage Hours      15.4      15.4      9,025.8  
 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
REFUELING OUTAGE IS SCHEDULED FOR 04/24/86.  
 27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\* TROJAN \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT  
TROJAN



FEBRUARY 1986

Report Period FEB 1986

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* TROJAN \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
86-01	02/08/86	F	15.4	G	3	86-001	BA		REACTOR TRIP CAUSED BY HIGH NEGATIVE RATE TRIP BEING SET SO CONSERVATIVE THAT THE MANUAL TURBINE RUNBACK DUE TO LOSS OF A CIRCULATING WATER PUMP ON LOW OIL FLOW CAUSED THE SETPOINT TO BE EXCEEDED. THE TRIP WAS INVESTIGATED, CAUSE DETERMINED, AND NEGATIVE RATE SETPOINTS ADJUSTED PER WESTINGHOUSE/TROJAN EVALUATION. THE CIRCULATING PUMP LUBE OIL SYSTEM WAS REVIEWED, EVALUATED, AND PROCEDURES WERE CHANGED TO INSURE PROPER SYSTEM OPERATION DURING COLD WEATHER CONDITIONS.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*

TROJAN INCURRED 1 SHUTDOWN IN FEBRUARY AS DISCUSSED ABOVE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	Instructions for Preparation of Data Entry Sheet
	C-Refueling	H-Other	Licensor Event Report
	D-Regulatory Restriction		(LER) File (NUREG-0161)
	E-Operator Training & License Examination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	

\*\*\*\*\*  
\* TROJAN \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1986

FACILITY DESCRIPTION

LOCATION  
STATE.....OREGON  
COUNTY.....COLUMBIA  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...32 MI N OF  
PORTLAND, ORE  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...DECEMBER 15, 1975  
DATE ELEC ENER 1ST GENER...DECEMBER 23, 1975  
DATE COMMERCIAL OPERATE....MAY 20, 1976  
CONDENSER COOLING METHOD...COOLING TOWERS  
CONDENSER COOLING WATER....COOLING TOWER  
ELECTRIC RELIABILITY  
COUNCIL.....WESTERN SYSTEMS  
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....PORTLAND GENERAL ELECTRIC  
CORPORATE ADDRESS.....121 S.W. SALMON STREET  
PORTLAND, OREGON 97204  
CONTRACTOR  
ARCHITECT/ENGINEER.....BECHTEL  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
CONSTRUCTOR.....BECHTEL  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....V  
IE RESIDENT INSPECTOR.....S. RICHARDS  
LICENSING PROJ MANAGER.....K. JOHNSTON  
DOCKET NUMBER.....50-344  
LICENSE & DATE ISSUANCE....NPF-1, NOVEMBER 21, 1975  
PUBLIC DOCUMENT ROOM.....MULTNOMAH COUNTY LIBRARY  
SOCIAL SCIENCES & SCIENCE DEPARTMENT  
801 SW 10TH AVENUE  
PORTLAND, OREGON 97205

I N S P E C T I O N     S T A T U S

INSPECTION SUMMARY

+ INSPECTION ON JANUARY 4 - FEBRUARY 10, 1986 (REPORT NO. 50-344/86-02) AREAS INSPECTED: ROUTINE INSPECTION OF OPERATIONAL SAFETY VERIFICATION, CORRECTIVE ACTION, MAINTENANCE, SURVEILLANCE, FACILITY ORGANIZATION AND ADMINISTRATION, REVIEW OF REACTOR COOLANT LEAK RATE DETERMINATION METHODS, FOLLOWUP ON PREVIOUSLY IDENTIFIED ITEMS, AND INSPECTION OF VARIOUS ASPECTS OF PLANT OPERATION. DURING THIS INSPECTION, VARIOUS INSPECTION PROCEDURES WERE UTILIZED. THE INSPECTION INVOLVED 199 INSPECTOR-HOURS BY THE RESIDENT NRC INSPECTORS.

RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

+ INSPECTION ON JANUARY 13 - FEBRUARY 12, 1986 (REPORT NO. 50-344/86-03) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

+ INSPECTION ON FEBRUARY 3-7, 1986 (REPORT NO. 50-344/86-05) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

+ INSPECTION ON JANUARY 28 - FEBRUARY 28, 1986 (REPORT NO. 50-344/86-06) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

+ INSPECTION ON FEBRUARY 11 - MARCH 17, 1986 (REPORT NO. 50-344/86-07) INSPECTION CONTINUING; TO BE REPORTED NEXT MONTH.

+ EXAMINATIONS ON FEBRUARY 11-12, 1986 (REPORT NO. 50-344/OL-86-01) WRITTEN AND ORAL EXAMINATIONS WERE ADMINISTERED TO TWO SENIOR REACTOR OPERATOR CANDIDATES. BOTH CANDIDATES PASSED ALL THEIR EXAMS.

Report Period FEB 1986

INSPECTION STATUS - (CONTINUED)

\*\*\*\*\*  
\* TROJAN \*  
\*\*\*\*\*

INSPECTION SUMMARY

ENFORCEMENT SUMMARY

10 CFR PART 50, APPENDIX B, CRITERION X READS, "A PROGRAM FOR INSPECTION OF ACTIVITIES AFFECTING QUALITY SHALL BE ESTABLISHED AND EXECUTED BY OR FOR THE ORGANIZATION PERFORMING THE ACTIVITY TO VERIFY CONFORMANCE WITH THE DOCUMENTED INSTRUCTIONS, PROCEDURES, AND DRAWINGS FOR ACCOMPLISHING THE ACTIVITY. SUCH INSPECTION SHALL BE PERFORMED BY INDIVIDUALS OTHER THAN THOSE WHO PERFORMED THE ACTIVITY BEING INSPECTED..." THE TROJAN QUALITY ASSURANCE PROGRAM, SECTION 2.2 REFERENCES SECTION 3.2 OF THE TROJAN NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT (FSAR) FOR GUIDELINES TO BE USED FOR DETERMINING THAT SYSTEMS ARE SAFETY-RELATED AND GOVERNED BY 10 CFR PART 50, APPENDIX B. SECTION 3.2 OF THE FSAR LISTS THE AUXILIARY FEEDWATER SYSTEM AND THE DIESEL GENERATORS AS BEING SAFETY-RELATED. ADMINISTRATIVE ORDER 3-9 STATES THAT WHEN THE TROJAN MAINTENANCE ORGANIZATION AUTHORIZES WORK, THE ASSIGNED WORK GROUP SUPERVISOR IS RESPONSIBLE FOR DETERMINING THE NEED FOR QA/QC REVIEW OF WORK INSTRUCTIONS AND FOR PROVIDING FOR APPROPRIATE INSTALLATION CHECKS TO ENSURE THAT THE EQUIPMENT FUNCTIONS PROPERLY WHEN RETURNED TO SERVICE. TROJAN QA PROCEDURE 10-2 REQUIRES A SIGN-OFF BY SIGNATURE OR A CONTROLLED STAMP SHOWING EVIDENCE OF SATISFACTORY COMPLETION AND VERIFICATION OF THE INSPECTION BY A QUALIFIED INSPECTOR IN ACCORDANCE WITH ANSI N45.2.6 OR SNT-TC-1A-1968 AS APPROPRIATE. CONTRARY TO THE REQUIREMENT, THE INSPECTION OF THE WEST EMERGENCY DIESEL GENERATOR, WHICH WAS COMPLETED ON AUGUST 2, 1984 UNDER MR-84-0564, WAS VERIFIED BY THE SAME INDIVIDUAL WHO PERFORMED THE ACTIVITY. IN ADDITION, THE SATISFACTORY COMPLETION AND VERIFICATION INSPECTION IN SEPTEMBER 1985 UNDER MR-85-4389 OF FOUR TIME DELAY RELAYS IN THE CONTROL CIRCUITRY FOR THE DIESEL DRIVEN AUXILIARY FEEDWATER PUMPS WAS NOT PERFORMED BY AN INSPECTOR WHO HAD BEEN QUALIFIED IN ACCORDANCE WITH QA PROCEDURE 10-2.  
(8503 3)

10 CFR, PART 50, APPENDIX B, CRITERION V, INSTRUCTIONS, PROCEDURES AND DRAWINGS STATES IN PART THAT ACTIVITIES AFFECTING QUALITY SHALL BE PRESCRIBED BY DOCUMENTED INSTRUCTIONS, PROCEDURES, OR DRAWINGS OF A TYPE APPROPRIATE TO THE CIRCUMSTANCES AND SHALL BE ACCOMPLISHED IN ACCORDANCE WITH THESE INSTRUCTIONS, PROCEDURES, OR DRAWINGS. CONTRARY TO THE REQUIREMENT, ON DECEMBER 10, 1985, IDENTIFICATION NUMBERS PLACED ON THE SWITCHES DID NOT MATCH THOSE SHOWN ON PIPING AND INSTRUMENTATION DRAWING M-213, SHEET 2, REVISION 6.  
(8503 4)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

+ APPROXIMATE PRIMARY TO SECONDARY LEAK OF 60 GALLONS PER DAY.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

100% POWER

LAST IE SITE INSPECTION DATE: 02/11-03/17/86+

Report Period FEB 1986

INSPECTION STATUS - (CONTINUED)

OTHER ITEMS

INSPECTION REPORT NO: 50-344/86-07+

REPORTS FROM LICENSEE

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
85-14-10	12-18-85	01-16-86	AUTOMATIC ACTUATION OF "B" EMERGENCY DIESEL GENERATOR

XXXXXXXXXXXXXXXXXXXX  
X TROJAN X  
XXXXXXXXXXXXXXXXXXXX


THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-250 OPERATING STATUS  
 2. Reporting Period: 02/01/86 Outage + On-line Hrs: 672.0  
 3. Utility Contact: N. W. GRANT (305) 552-3675  
 4. Licensed Thermal Power (MWt): 2200  
 5. Nameplate Rating (Gross MWe): 894 X 0.85 = 760  
 6. Design Electrical Rating (Net MWe): 693  
 7. Maximum Dependable Capacity (Gross MWe): 700  
 8. Maximum Dependable Capacity (Net MWe): 666  
 9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE  
 10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_  
 11. Reasons for Restrictions, If Any:  
NONE  
 12. Report Period Hrs      MONTH      YEAR      CUMULATIVE  
672.0      1,416.0      116,025.6  
 13. Hours Reactor Critical      644.6      1,154.4      81,951.3  
 14. Rx Reserve Shtdwn Hrs      .0      .0      844.3  
 15. Hrs Generator On-Line      642.1      1,134.7      79,541.7  
 16. Unit Reserve Shtdwn Hrs      .0      .0      121.8  
 17. Gross Therm Ener (MWH)      1,349,846      2,416,426      164,621,947  
 18. Gross Elec Ener (MWH)      443,190      793,070      52,664,615  
 19. Net Elec Ener (MWH)      421,114      750,235      49,859,816  
 20. Unit Service Factor      95.6      80.1      68.6  
 21. Unit Avail Factor      95.6      80.1      68.7  
 22. Unit Cap Factor (MDC Net)      94.1      79.6      66.1\*  
 23. Unit Cap Factor (DER Net)      90.4      76.5      62.0  
 24. Unit Forced Outage Rate      4.4      19.9      6.9  
 25. Forced Outage Hours      29.9      281.3      5,316.1  
 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE  
 27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\* TURKEY POINT 3 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

TURKEY POINT 3



FEBRUARY 1986

\* Item calculated with a Weighted Average

Report Period FEB 1986

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
X TURKEY POINT 3  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System Component	Cause & Corrective Action to Prevent Recurrence
03	02/11/86	F	29.9	G	3	250-86-0 6	1A INSTRU	AS A RESULT OF A PROCEDURE WITH INADEQUATE GUIDANCE A REACTOR TRIP OCCURRED WHILE CLEARING A CONSTRUCTION ACTIVITY RELATED INADVERTENT CONTAINMENT INSULATION AND HIGH PRESSURE SIGNAL.

\*\*\*\*\*  
X SUMMARY X  
\*\*\*\*\*

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	1-Manual Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	2-Manual Scram Instructions for
	C-Refueling	H-Other	3-Auto Scram Preparation of
	D-Regulatory Restriction		4-Continued Data Entry Sheet
	E-Operator Training & License Examination		5-Reduced Load Licensee Event Report
			9-Other (LER) File (NUREG-0161)

\*\*\*\*\*  
\* TURKEY POINT 3 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1986

FACILITY DESCRIPTION

LOCATION  
STATE.....FLORIDA

COUNTY.....DADE

DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...25 MI S OF  
MIAMI, FLA

TYPE OF REACTOR.....PWR

DATE INITIAL CRITICALITY...OCTOBER 20, 1972

DATE ELEC ENER 1ST GENER...NOVEMBER 2, 1972

DATE COMMERCIAL OPERATE....DECEMBER 14, 1972

CONDENSER COOLING METHOD...CLOSED CANAL

CONDENSER COOLING WATER....CLOSED CYCLE CANAL

ELECTRIC RELIABILITY  
COUNCIL.....SOUTHEASTERN ELECTRIC  
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....FLORIDA POWER & LIGHT

CORPORATE ADDRESS.....9250 WEST FLAGLER STREET P.O. BOX 013100  
MIAMI, FLORIDA 33174

CONTRACTOR  
ARCHITECT/ENGINEER.....BECHTEL

NUC STEAM SYS SUPPLIER...WESTINGHOUSE

CONSTRUCTOR.....BECHTEL

TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II

IE RESIDENT INSPECTOR.....T. PEEBLES

LICENSING PROJ MANAGER.....D. McDONALD  
DOCKET NUMBER.....50-250

LICENSE & DATE ISSUANCE....DPR-31, JULY 19, 1972

PUBLIC DOCUMENT ROOM.....ENVIRONMENTAL AND URBAN AFFAIRS LIBRARY  
FLORIDA INTERNATIONAL UNIVERSITY  
MIAMI, FLORIDA 33199

I N S P E C T I O N     S T A T U S

INSPECTION SUMMARY

+ INSPECTION DECEMBER 9 - JANUARY 13, 1986 (85-44): THIS ROUTINE, UNANNOUNCED INSPECTION ENTAILED 87 DIRECT INSPECTION HOURS AT THE SITE, INCLUDING 11 HOURS OF BACKSHIFT INSPECTION, IN THE AREAS OF LICENSEE ACTION ON PREVIOUS INSPECTION FINDINGS, ANNUAL AND MONTHLY SURVEILLANCE, MAINTENANCE OBSERVATIONS AND REVIEWS, OPERATIONAL SAFETY, ENGINEERED SAFETY FEATURES WALKDOWN, INDEPENDENT INSPECTION, AND PLANT EVENTS. VIOLATION - FAILURE TO MEET THE REQUIREMENTS OF TECHNICAL SPECIFICATION 6.8.1.

INSPECTION JANUARY 21-24 (86-01): THIS ROUTINE, UNANNOUNCED INSPECTION ENTAILED 132 INSPECTOR-HOURS ON SITE DURING NORMAL DUTY HOURS, IN THE AREA OF THE ANNUAL EMERGENCY PREPAREDNESS EXERCISE. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

Report Period FEB 1986

I N S P E C T I O N      S T A T U S - (CONTINUED)

\*\*\*\*\*  
\*            TURKEY POINT 3            \*  
\*\*\*\*\*

OTHER ITEMS

NONE.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

PEP IN PROGRESS.

PLANT STATUS:

NORMAL OPERATION.

LAST IE SITE INSPECTION DATE: JANUARY 21-24, 1986 +

INSPECTION REPORT NO: 50-250/86-01 +


R E P O R T S   F R O M   L I C E N S E E

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
85-035	10/24/85	11/25/85	TECHNICAL SPECIFICATION - CONTAINMENT SUMP LEVEL INDICATION. THE RECEIVER IN THE CONTAINMENT SUMP LEVEL INDICATION WAS RELOCATED.
85-036	10/25/85	11/25/85	RESIDUAL HEAT REMOVAL CAPABILITY. A FAILED RELAY CAUSED TWO BLOWN FUSES IN THE COMPARATOR, WHICH RESULTED IN AN ERRONEOUS HIGH PRESSURE SIGNAL MOV-3-750.
85-039	11/29/85	12/30/85	ACCUMULATOR FILL LINE SEISMIC QUALIFICATION. ENGINEERING DEPARTMENT PROVIDED A SAFETY EVALUATION TO ALLOW THROTTLING OF 883R ON AN INTERIM BASIS.
85-043	12/17/85	01/16/86	TECHNICAL SPECIFICATION - EMERGENCY DIESEL GENERATORS. CAUSE OF THE ABNORMALLY HIGH TEMPERATURE READING WAS HUMAN ERROR IN RECORDING AN ERRONEOUS TEMPERATURE.

1. Docket: 50-251 OPERATING STATUS  
 2. Reporting Period: 02/01/86 Outage + On-line Hrs: 672.0  
 3. Utility Contact: N. W. GRANT (305) 552-3675  
 4. Licensed Thermal Power (MWh): 2200  
 5. Nameplate Rating (Gross MWe): 894 X 0.85 = 760  
 6. Design Electrical Rating (Net MWe): 693  
 7. Maximum Dependable Capacity (Gross MWe): 700  
 8. Maximum Dependable Capacity (Net MWe): 666  
 9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE  
 10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_  
 11. Reasons for Restrictions, If Any:  
NONE  
 12. Report Period Hrs      MONTH      YEAR      CUMULATIVE  
672.0      1,416.0      109,753.0  
 13. Hours Reactor Critical      .0      225.4      77,860.8  
 14. Rx Reserve Shtdn Hrs      .0      .0      166.6  
 15. Hrs Generator On-Line      .0      225.1      75,327.5  
 16. Unit Reserve Shtdn Hrs      .0      .0      31.2  
 17. Gross Therm Ener (MWH)      .0      440,167      159,486,896  
 18. Gross Elec Ener (MWH)      .0      139,235      50,781,867  
 19. Net Elec Ener (MWH)      -984      129,483      48,093,740  
 20. Unit Service Factor      .0      15.9      68.6  
 21. Unit Avail Factor      .0      15.9      68.7  
 22. Unit Cap Factor (MDC Net)      .0      13.7      67.4\*  
 23. Unit Cap Factor (DER Net)      .0      13.2      63.2  
 24. Unit Forced Outage Rate      .0      .0      6.5  
 25. Forced Outage Hours      .0      .0      4,824.7  
 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE  
 27. If Currently Shutdown Estimated Startup Date: 05/07/86

\*\*\*\*\*  
\* TURKEY POINT 4  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT  
 TURKEY POINT 4



FEBRUARY 1986

\* Item calculated with a Weighted Average

Report Period FEB 1986

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* TURKEY POINT 4 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
02	01/10/86	S	672.0	C	4		RC	FUELXX	UNIT #4 REMAINED SHUTDOWN FOR REFUELING AND SCHEDULED MAINTENANCE.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*

TURKEY POINT 4 REMAINS SHUTDOWN FOR REFUELING.

Type	Reason	Method	System & Component
F-Forced S-Sched	A-Equip Failure B-Maint or Test C-Refueling D-Regulatory Restriction E-Operator Training & License Examination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161)

\*\*\*\*\*  
\* TURKEY POINT 4 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1986

FACILITY DESCRIPTION

LOCATION  
STATE.....FLORIDA  
COUNTY.....DADE  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...25 MI S OF  
MIAMI, FLA  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...JUNE 11, 1973  
DATE ELEC ENER 1ST GENER...JUNE 21, 1973  
DATE COMMERCIAL OPERATE....SEPTEMBER 7, 1973  
CONDENSER COOLING METHOD...CLOSED CANAL  
CONDENSER COOLING WATER....CLOSED CYCLE CANAL  
ELECTRIC RELIABILITY  
COUNCIL.....SOUTHEASTERN ELECTRIC  
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....FLORIDA POWER & LIGHT  
CORPORATE ADDRESS.....9250 WEST FLAGLER STREET P.O. BOX 013100  
MIAMI, FLORIDA 33174  
CONTRACTOR  
ARCHITECT/ENGINEER.....BECHTEL  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
CONSTRUCTOR.....BECHTEL  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II  
IE RESIDENT INSPECTOR.....T. PEEBLES  
LICENSING PROJ MANAGER.....D. MCDONALD  
DOCKET NUMBER.....50-251  
LICENSE & DATE ISSUANCE....DPR-41, APRIL 10, 1973  
PUBLIC DOCUMENT ROOM.....ENVIRONMENTAL AND URBAN AFFAIRS LIBRARY  
FLORIDA INTERNATIONAL UNIVERSITY  
MIAMI, FLORIDA 33199

I N S P E C T I O N     S T A T U S

INSPECTION SUMMARY

+ INSPECTION DECEMBER 9 - JANUARY 13, 1986 (85-44): THIS ROUTINE, UNANNOUNCED INSPECTION ENTAILED 87 DIRECT INSPECTION HOURS AT THE SITE, INCLUDING 11 HOURS OF BACKSHIFT INSPECTION, IN THE AREAS OF LICENSEE ACTION ON PREVIOUS INSPECTION FINDINGS, ANNUAL AND MONTHLY SURVEILLANCE, MAINTENANCE OBSERVATIONS AND REVIEWS, OPERATIONAL SAFETY, ENGINEERED SAFETY FEATURES WALKDOWN, INDEPENDENT INSPECTION, AND PLANT EVENTS. VIOLATION - FAILURE TO MEET THE REQUIREMENTS OF TECHNICAL SPECIFICATION 6.3.1.

INSPECTION JANUARY 21-24 (86-01): THIS ROUTINE, UNANNOUNCED INSPECTION ENTAILED 132 INSPECTOR-HOURS ON SITE DURING NORMAL DUTY HOURS, IN THE AREA OF THE ANNUAL EMERGENCY PREPAREDNESS EXERCISE. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

Report Period FEB 1986

I N S P E C T I O N      S T A T U S - (CONTINUED)

\*\*\*\*\*  
\* TURKEY POINT 4 \*  
\*\*\*\*\*

OTHER ITEMS

NONE.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

PEP IN PROGRESS.

PLANT STATUS:

REFUELING OUTAGE.

LAST IE SITE INSPECTION DATE: JANUARY 21-24, 1986 +

INSPECTION REPORT NO: 50-251/86-01 +

R E P O R T S   F R O M   L I C E N S E E


NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
85-023	08/24/85	11/20/85	TECHNICAL SPECIFICATION - CONTAINMENT ISOLATION VALVE, WHEN THE CLEARANCE WAS RELEASED, IT WAS NOT REALIZED THAT VALVE REQUIRED TESTING.
85-024	11/02/85	12/02/85	ESF ACTUATION - COMPONENT COOLING WATER AUTO START. THE AUTOMATIC START WAS THE RESULT OF MAINTENANCE AND POST-MAINTENANCE TESTING.
85-026	12/24/85	01/23/86	EMERGENCY DIESEL GENERATOR. DISCUSSIONS WITH THE VENDOR INDICATE THE "BACKING OFF" ACTION BY THE ARCING CONTACTS IS AN ABNORMAL CONDITION.

1. Docket: 50-271 OPERATING STATUS  
 2. Reporting Period: 02/01/86 Outage + On-line Hrs: 672.0  
 3. Utility Contact: F. J. BURGER (802) 257-7711 X136  
 4. Licensed Thermal Power (MWh): 1593  
 5. Nameplate Rating (Gross MWe): 626 X 0.9 = 563  
 6. Design Electrical Rating (Net MWe): 514  
 7. Maximum Dependable Capacity (Gross MWe): 535  
 8. Maximum Dependable Capacity (Net MWe): 504  
 9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE  
 10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_  
 11. Reasons for Restrictions, If Any:  
NONE  
 12. Report Period Hrs MONTH YEAR CUMULATIVE  
672.0 1,416.0 117,818.8  
 13. Hours Reactor Critical .0 .0 93,110.9  
 14. Rx Reserve Shtdn Hrs .0 .0 .0  
 15. Hrs Generator On-Line .0 .0 90,718.2  
 16. Unit Reserve Shtdn Hrs .0 .0 .0  
 17. Gross Therm Ener (MWH) 0 0 132,109,618  
 18. Gross Elec Ener (MWH) 0 0 43,955,902  
 19. Net Elec Ener (MWH) 0 0 41,700,250  
 20. Unit Service Factor .0 .0 77.0  
 21. Unit Avail Factor .0 .0 77.0  
 22. Unit Cap Factor (MDC Net) .0 .0 70.2  
 23. Unit Cap Factor (DER Net) .0 .0 68.9  
 24. Unit Forced Outage Rate .0 .0 6.9  
 25. Forced Outage Hours .0 .0 5,466.6  
 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE  
 27. If Currently Shutdown Estimated Startup Date: 06/26/86

\*\*\*\*\*  
\* VERMONT YANKEE 1 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

VERMONT YANKEE 1



FEBRUARY 1986

Report Period FEB 1986

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* VERMONT YANKEE 1 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
85-14	09/21/85	S	672.0	C	4		RC	FUELXX	1985 REFUELING/MAINTENANCE/RECIRC PIPE REPLACEMENT OUTAGE IN PROGRESS.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*

Type	Reason	Method	System & Component	
F-Forced	A-Equip Failure	F-Admin	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	2-Manual Scram	Instructions for
	C-Refueling	H-Other	3-Auto Scram	Preparation of
	D-Regulatory Restriction		4-Continued	Data Entry Sheet
	E-Operator Training & License Examination		5-Reduced Load	Licensee Event Report
			9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* VERMONT YANKEE 1 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1986

FACILITY DESCRIPTION

LOCATION STATE.....VERMONT  
COUNTY.....WINDHAM  
DIST AND DIRECTION FROM NEAREST POPULATION CTR...5 MI S OF BRATTLEBORO, VT  
TYPE OF REACTOR.....BWR  
DATE INITIAL CRITICALITY...MARCH 24, 1972  
DATE ELEC ENER 1ST GENER...SEPTEMBER 20, 1972  
DATE COMMERCIAL OPERATE....NOVEMBER 30, 1972  
CONDENSER COOLING METHOD...COOLING TOWER  
CONDENSER COOLING WATER....CONNECTICUT RIVER  
ELECTRIC RELIABILITY COUNCIL.....NORTHEAST POWER COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY LICENSEE.....VERMONT YANKEE NUCLEAR POWER  
CORPORATE ADDRESS.....1671 WORCESTER ROAD FRAMINGHAM, MASSACHUSETTS 01701  
CONTRACTOR ARCHITECT/ENGINEER.....EBASCO  
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC  
CONSTRUCTOR.....EBASCO  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I  
IE RESIDENT INSPECTOR.....W. RAYMOND  
LICENSING PROJ MANAGER.....V. ROONEY  
DOCKET NUMBER.....50-271  
LICENSE & DATE ISSUANCE....DPR-28, FEBRUARY 28, 1973  
PUBLIC DOCUMENT ROOM.....BROOKS MEMORIAL LIBRARY  
224 MAIN STREET  
BRATTLEBORO, VERMONT 05301

I N S P E C T I O N     S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

TECHNICAL SPECIFICATION 6.5.A REQUIRES THAT DETAILED WRITTEN SURVEILLANCE PROCEDURES BE PREPARED, APPROVED AND ADHERED TO. PROCEDURE OP 4511 WAS WRITTEN PURSUANT TO THE ABOVE AND REQUIRES TEST PERSONNEL TO EXPOSE THE REFUEL FLOOR AREA RADIATION MONITORS (ARM'S) TO A HIGH FIELD NOTING AND RECORDING THE TRIP SETTINGS DURING THE QUARTERLY CALIBRATIONS. CONTRARY TO THE ABOVE, DURING QUARTERLY CALIBRATIONS ON JULY 26 AND OCTOBER 28, 1985, THE EAST AND WEST REFUEL FLOOR ARM'S WERE NOT EXPOSED TO A RADIATION FIELD OF SUFFICIENT INTENSITY TO ACTIVATE THE CHANNEL THE TRIP SETPOINTS. FURTHER, SUPERVISORY PERSONNEL WHO APPROVED THE COMPLETED TESTS FAILED TO DETECT THE DISCREPANT TEST RESULTS AND INITIATE CORRECTIVE ACTIONS.  
(8503 5)

OTHER ITEMS

SYSTEMS AND COMPONENTS:

Report Period FEB 1986

I N S P E C T I O N      S T A T U S - (CONTINUED)

\*\*\*\*\*  
\* VERMONT YANKEE 1 \*  
\*\*\*\*\*

OTHER ITEMS

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S   F R O M   L I C E N S E E


NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
--------	------------------	-------------------	---------

-----  
NO INPUT PROVIDED.  
-----

1. Docket: 50-397 OPERATING STATUS  
 2. Reporting Period: 02/01/86 Outage + On-line Hrs: 672.0  
 3. Utility Contact: LEONARD HUTCHISON (509) 377-2501 X2486  
 4. Licensed Thermal Power (MWh): 3323  
 5. Nameplate Rating (Gross MWe): 1201  
 6. Design Electrical Rating (Net MWe): 1100  
 7. Maximum Dependable Capacity (Gross MWe): 1140  
 8. Maximum Dependable Capacity (Net MWe): 1095  
 9. If Changes Occur Above Since Last Report, Give Reasons:  
 10. Power Level To Which Restricted, If Any (Net MWe): 775  
 11. Reasons for Restrictions, If Any:  
 "B" RRC PUMP INOPERABLE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>672.0</u>	<u>1,416.0</u>	<u>10,616.2</u>
13. Hours Reactor Critical	<u>672.0</u>	<u>1,416.0</u>	<u>8,732.2</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>672.0</u>	<u>1,416.0</u>	<u>8,442.5</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,565,040</u>	<u>3,325,290</u>	<u>20,889,570</u>
18. Gross Elec Ener (MWH)	<u>517,930</u>	<u>1,100,250</u>	<u>6,923,500</u>
19. Net Elec Ener (MWH)	<u>497,874</u>	<u>1,057,695</u>	<u>6,644,468</u>
20. Unit Service Factor	<u>100.0</u>	<u>100.0</u>	<u>79.5</u>
21. Unit Avail Factor	<u>100.0</u>	<u>100.0</u>	<u>79.5</u>
22. Unit Cap Factor (MDC Net)	<u>67.7</u>	<u>68.2</u>	<u>57.2</u>
23. Unit Cap Factor (DER Net)	<u>67.4</u>	<u>67.9</u>	<u>56.9</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.0</u>	<u>8.5</u>
25. Forced Outage Hours	<u>.0</u>	<u>.0</u>	<u>785.0</u>
26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):			
REFUELING & MAINT. OUTAGE: <u>4/14/86 FOR 60 DAYS.</u>			
27. If Currently Shutdown Estimated Startup Date:	<u>N/A</u>		

\*\*\*\*  
 \* WASHINGTON NUCLEAR 2 \*  
 \*\*\*\*  
 AVERAGE DAILY POWER LEVEL (MWe) PLOT  
 WASHINGTON NUCLEAR 2



FEBRUARY 1986

Report Period FEB 1986

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* WASHINGTON NUCLEAR 2 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
85-02P	07/01/85	F	0.0	A	5		CB	PUMPXX	POWER OUTPUT LIMITED TO 72% DUE TO THE INOPERABILITY OF "B" RRC PUMP.
86-01P	02/20/86	F	0.0	A	5		HF	PUMPXX	FAULTY THERMOCOUPLE ON CIRCULATING WATER PUMP INDICATED HIGH TEMPERATURE ON THRUST BEARING. THERMOCOUPLE WAS REPLACED AND PUMP RETURNED TO SERVICE.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*

WNP-2 OPERATED ROUTINELY IN FEBRUARY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	1-Manual
S-Sched	B-Maint or Test	G-Oper Error	2-Manual Scram
	C-Refueling	H-Other	3-Auto Scram
	D-Regulatory Restriction		4-Continued
	E-Operator Training & License Examination		5-Reduced Load
			9-Other
			Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161)

\*\*\*\*\*  
\* WASHINGTON NUCLEAR 2 \*  
\*\*\*\*\*

FACILITY DESCRIPTION

LOCATION STATE.....WASHINGTON  
COUNTY.....BENTON  
DIST AND DIRECTION FROM NEAREST POPULATION CTR...12 MI. NW OF RICHLAND, WASH.  
TYPE OF REACTOR.....BWR  
DATE INITIAL CRITICALITY...JANUARY 19, 1984  
DATE ELEC ENER 1ST GENER...MAY 27, 1984  
DATE COMMERCIAL OPERATE....DECEMBER 13, 1984  
CONDENSER COOLING METHOD...COOLING TOWERS  
CONDENSER COOLING WATER....MECHANICAL TOWERS  
ELECTRIC RELIABILITY COUNCIL.....WESTERN SYSTEMS COORDINATING COUNCIL

FACILITY DATA

Report Period FEB 1986

UTILITY & CONTRACTOR INFORMATION

UTILITY LICENSEE.....WASHINGTON PUBLIC POWER SUPPLY SYSTEM  
CORPORATE ADDRESS.....P.O. BOX 968 RICHLAND, WASHINGTON 99352  
CONTRACTOR ARCHITECT/ENGINEER.....BURNS & ROE  
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC  
CONSTRUCTOR.....BECHTEL  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....V  
IE RESIDENT INSPECTOR.....R. BARR  
LICENSING PROJ MANAGER.... J. BRADFUTE  
DOCKET NUMBER.....50-397  
LICENSE & DATE ISSUANCE....NPF-21, APRIL 13, 1984  
PUBLIC DOCUMENT ROOM.....RICHLAND PUBLIC LIBRARY  
SWIFT AND NORTHGATE STREETS  
RICHLAND, WA 99352

I N S P E C T I O N     S T A T U S

INSPECTION SUMMARY

+ INSPECTION ON JANUARY 6 - FEBRUARY 7, 1986 (REPORT NO. 50-397/86-01) AREAS INSPECTED: UNANNOUNCED INSPECTION BY REGIONALLY BASED INSPECTORS. DURING THIS INSPECTION, VARIOUS INSPECTION PROCEDURES WERE UTILIZED. THE INSPECTION INVOLVED 94 INSPECTOR-HOURS ONSITE AND 10 INSPECTOR-HOURS IN-OFFICE BY TWO NRC INSPECTORS.

RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

+ INSPECTION ON MARCH 12-26, 1986 (REPORT NO. 50-397/86-03) INSPECTION TO BE COMPLETED IN MARCH 1986.

+ INSPECTION ON MARCH 3-7, 1986 (REPORT NO. 50-397/86-05) INSPECTION TO BE COMPLETED IN MARCH 1986.

+ INSPECTION ON FEBRUARY 3 - MARCH 14, 1986 (REPORT NO. 50-397/86-06) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

+ INSPECTION ON FEBRUARY 3-7, 1986 (REPORT NO. 50-397/86-07) AREAS INSPECTED: A ROUTINE, UNANNOUNCED INSPECTION BY A REGIONALLY BASED NRC INSPECTOR FOR THE FOLLOWUP OF TMI ACTION ITEMS AND GENERIC LETTER 85-06. DURING THIS INSPECTION, VARIOUS INSPECTION PROCEDURES WERE UTILIZED. THE INSPECTION INVOLVED 30 INSPECTOR-HOURS ONSITE BY ONE NRC INSPECTOR.

RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

Report Period FEB 1986

I N S P E C T I O N      S T A T U S - (CONTINUED)

ENFORCEMENT SUMMARY

\*\*\*\*\*  
\* WASHINGTON NUCLEAR 2 \*  
\*\*\*\*\*

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

"B" RECIRCULATION PUMP OUT OF SERVICE BECAUSE OF VIBRATION.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

THE PLANT OPERATED AT 72% WITH ONE RECIRCULATION LOOP IN SERVICE DURING THE MONTH OF DECEMBER, 1985. THE OTHER RECIRCULATION PUMP IS STOPPED BECAUSE OF VIBRATION EXPERIENCED EARLIER. BASED UPON A TEST RUN OF THE PUMP IN EARLY DECEMBER, SINGLE-LOOP OPERATION IS EXPECTED TO CONTINUE UNTIL THE APRIL 1986 REFUELING OUTAGE.

LAST IE SITE INSPECTION DATE: 02/03-03/14/86+

INSPECTION REPORT NO: 50-397/86-06+

R E P O R T S   F R O M   L I C E N S E E


NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
--------	------------------	-------------------	---------

NONE

=====

1. Docket: 50-382 OPERATING STATUS  
 2. Reporting Period: 02/01/86 Outage + On-line Hrs: 672.0  
 3. Utility Contact: GEORGE MILLER (504) 467-8211  
 4. Licensed Thermal Power (Mwt): 3390  
 5. Nameplate Rating (Gross MWe): 1153  
 6. Design Electrical Rating (Net MWe): 1104  
 7. Maximum Dependable Capacity (Gross MWe): 1104  
 8. Maximum Dependable Capacity (Net MWe): 1104  
 9. If Changes Occur Above Since Last Report, Give Reasons:  
 \_\_\_\_\_  
 10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_  
 11. Reasons for Restrictions, If Any:  
 \_\_\_\_\_  
 NONE  
 12. Report Period Hrs 672.0 MONTH 672.0 YEAR 1,416.0 CUMULATIVE 3,793.0  
 13. Hours Reactor Critical 672.0 1,377.4 3,246.1  
 14. Rx Reserve Shtdn Hrs .0 .0 .0  
 15. Hrs Generator On-Line 672.0 1,365.9 3,167.7  
 16. Unit Reserve Shtdn Hrs .0 .0 .0  
 17. Gross Therm Ener (MWH) 2,236,098 4,549,244 10,191,683  
 18. Gross Elec Ener (MWH) 754,780 1,535,370 3,433,220  
 19. Net Elec Ener (MWH) 721,047 1,465,343 3,270,496  
 20. Unit Service Factor 100.0 96.5 83.5  
 21. Unit Avail Factor 100.0 96.5 83.5  
 22. Unit Cap Factor (MDC Net) 97.2 93.7 78.1  
 23. Unit Cap Factor (DER Net) 97.2 93.7 78.1  
 24. Unit Forced Outage Rate .0 3.5 16.3  
 25. Forced Outage Hours .0 50.1 614.9  
 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
 SURVEILLANCE OUTAGE: 03/86 - 3 WEEKS.  
 27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*  
 \* WATERFORD 3 \*  
 \*\*\*\*  
 AVERAGE DAILY POWER LEVEL (MWe) PLOT  
 WATERFORD 3



FEBRUARY 1986

Report Period FEB 1986

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* WATERFORD 3 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
86-03	02/28/86	S	0.0	B	5		TA	ZZZZZ	UNIT POWER REDUCTION WAS INITIATED TO PERFORM CONTROL ELEMENT ASSEMBLY EXERCISING AND TURBINE VALVE TESTING REQUIRED BY TECHNICAL SPECIFICATIONS.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*

WATERFORD 3 OPERATED ROUTINELY IN FEBRUARY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	Instructions for
	C-Refueling	H-Other	Preparation of
	D-Regulatory Restriction		Data Entry Sheet
	E-Operator Training	4-Continued	Licensor Event Report
	& License Examination	5-Reduced Load	(LER) File (NUREG-0161)
		9-Other	

\*\*\*\*\*  
X WATERFORD 3 X  
\*\*\*\*\*

#### FACILITY DATA

Report Period FEB 1986

##### FACILITY DESCRIPTION

LOCATION  
STATE.....LOUISIANA  
COUNTY.....ST CHARLES  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...20 MI W OF  
NEW ORLEANS, LA  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...MARCH 4, 1985  
DATE ELEC ENER 1ST GENER...MARCH 18, 1985  
DATE COMMERCIAL OPERATE....SEPTEMBER 24, 1985  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER....MISSISSIPPI RIVER  
ELECTRIC RELIABILITY  
COUNCIL....SOUTHWEST POWER POOL

##### UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....LOUISIANA POWER & LIGHT  
CORPORATE ADDRESS.....142 DELARONDE STREET  
NEW ORLEANS, LOUISIANA 70174  
CONTRACTOR  
ARCHITECT/ENGINEER.....EBASCO  
NUC STEAM SYS SUPPLIER...COMBUSTION ENGINEERING  
CONSTRUCTOR.....EBASCO  
TURBINE SUPPLIER.....WESTINGHOUSE

##### REGULATORY INFORMATION

IE REGION RESPONSIBLE.....IV  
IE RESIDENT INSPECTOR.....J. LUEHMAN  
LICENSING PROJ MANAGER.....J. WILSON  
DOCKET NUMBER.....50-382  
LICENSE & DATE ISSUANCE....NPF-38, MARCH 16, 1985  
PUBLIC DOCUMENT ROOM.....HEAD LIBRARIAN  
LOUISIANA COLLECTION  
EARL K. LONG LIBRARY  
UNIVERSITY OF NEW ORLEANS  
LAKEFRONT DRIVE  
NEW ORLEANS, LOUISIANA 70148

#### I N S P E C T I O N     S T A T U S

##### INSPECTION SUMMARY

INSPECTION CONDUCTED OCTOBER 15-18, 1985 (85-29) ROUTINE, UNANNOUNCED INSPECTION OF THE LICENSEE'S PERSONNEL TRAINING AND QUALIFICATIONS, SAFEGUARD CONTINGENCY ACTIVITIES, TESTING AND MAINTENANCE, SECURITY SYSTEMS POWER SUPPLY, MANAGEMENT EFFECTIVENESS, ALLEGATION FOLLOWUP, ACCESS CONTROL-VEHICLE AND PERSONNEL, SECURITY ORGANIZATION, LOCK AND KEY CONTROL, PHYSICAL BARRIERS-PROTECTED AND VITAL AREAS, DETECTION AIDS-PROTECTED AND VITAL AREAS, ASSESSMENT AIDS, AND ALARM STATIONS. THE INSPECTION INVOLVED 74 INSPECTOR-HOURS OF DIRECT INSPECTION TIME BY 2 NRC INSPECTORS. WITHIN THE AREAS INSPECTED NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSEPTION CONDUCTED DECEMBER 2-6, 1985 (85-31) REACTIVE, ANNOUNCED INSPECTION OF THE LICENSEE PREVENTIVE MAINTENANCE PROGRAM AND NONLICENSED STAFF TRAINING. THE INSPECTION INVOLVED 36 INSPECTOR-HOURS ONSITE BY ONE NRC INSPECTOR. WITHIN THE AREA INSPECTED ONE VIOLATION WAS IDENTIFIED.

INSPECTION CONDUCTED JANUARY 27-31, 1986 (86-01) ROUTINE, UNANNOUNCED INSPECTION OF LOCKS, KEYS, AND COMBINATIONS, PHYSICAL BARRIERS-PROTECTED AREA, PHYSICAL BARRIERS-VITAL AREA, LIGHTING, ASSESSMENT AIDS, ACCESS CONTROL-PERSONNEL, ACCESS CONTROL-PACKAGES, ACCESS CONTROL-VEHICLES, DETECTINS AIDS-PROTECTED AREA, DETECTION AIDS-VITAL AREA, AND COMMUNICATIONS. THE INSPECTION INVOLVED 114 INSPECTOR-HOURS BY TWO NRC INSPECTORS. WITHIN THE AREAS INSPECTED 6 VIOLATIONS WERE IDENTIFIED.

Report Period FEB 1986

INSPECTION STATUS - (CONTINUED)

\*\*\*\*\*  
\* WATERFORD 3 \*  
\*\*\*\*\*

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

LAST IE SITE INSPECTION DATE: JAN. 27-31, 1986

INSPECTION REPORT NO: 50-382/86-01

R E P O R T S   F R O M   L I C E N S E E


NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
86-01	1/7/86	2/6/86	REACTOR TRIP ON DROPPED CONTROL ELEMENT ASSEMBLY
86-02	1/22/86	2/21/86	REACTOR TRIP DUE TO DROPPED CEA NUMBER 88 AND FAILURE OF LOWDOWN ISOLATION VALVES TO CLOSE
86-03	1/24/86	2/21/86	INADVERTENT CONTROL ROOM ISOLATIONS DUE TO INSTRUMENT ANOMALIES

1. Docket: 50-482 OPERATING STATUS  
 2. Reporting Period: 02/01/86 Outage + On-line Hrs: 672.0  
 3. Utility Contact: M. WILLIAMS (316) 364-8831  
 4. Licensed Thermal Power (MWt): 3411  
 5. Nameplate Rating (Gross MWe): 1250  
 6. Design Electrical Rating (Net MWe): 1170  
 7. Maximum Dependable Capacity (Gross MWe): 1170  
 8. Maximum Dependable Capacity (Net MWe): 1128  
 9. If Changes Occur Above Since Last Report, Give Reasons:  
 \_\_\_\_\_  
 10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_  
 11. Reasons for Restrictions, If Any: \_\_\_\_\_  
 NONE  
 12. Report Period Hrs      MONTH      YEAR      CUMULATIVE  
 \_\_\_\_\_ 672.0      1,416.0      4,295.7  
 13. Hours Reactor Critical      618.8      1,362.8      4,153.1  
 14. Rx Reserve Shtdn Hrs      41.4      41.4      120.1  
 15. Hrs Generator On-Line      614.7      1,358.7      4,130.3  
 16. Unit Reserve Shtdn Hrs      .0      .0      19.0  
 17. Gross Therm Ener (MWH)      2,005,668      4,486,147      13,361,080  
 18. Gross Elec Ener (MWH)      709,461      1,584,477      4,655,567  
 19. Net Elec Ener (MWH)      679,535      1,521,491      4,463,591  
 20. Unit Service Factor      91.5      96.0      96.1  
 21. Unit Avail Factor      91.5      96.0      96.6  
 22. Unit Cap Factor (MDC Net)      89.9      95.3      55.9\*  
 23. Unit Cap Factor (DER Net)      86.6      91.8      88.8  
 24. Unit Forced Outage Rate      8.5      4.0      3.9  
 25. Forced Outage Hours      57.3      57.3      165.4  
 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
 NONE  
 27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\* WOLF CREEK 1 \*\*\*\*  
 \*\*\*\* WOLF CREEK 1 \*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

WOLF CREEK 1



FEBRUARY 1986

\* Item calculated with a Weighted Average

Report Period FEB 1986

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* WOLF CREEK 1 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System Component	Cause & Corrective Action to Prevent Recurrence
1	02/22/86	F	57.3	A	3	86-007-00		UNIT TRIP CAUSED BY A BAD CARD IN SPEED CONTROL CIRCUIT.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*

WOLF CREEK INCURRED 1 SHUTDOWN IN FEBRUARY AS DESCRIBED ABOVE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	1-Manual
S-Sched	B-Maint or Test	G-Oper Error	Exhibit F & H Instructions for
	C-Refueling	H-Other	2-Manual Scram 3-Auto Scram Preparation of
	D-Regulatory Restriction		4-Continued Data Entry Sheet
	E-Operator Training & License Examination	5-Reduced Load 9-Other	Licensee Event Report (LER) File (NUREG-0161)

\*\*\*\*\*  
\* WOLF CREEK 1 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1986

FACILITY DESCRIPTION

LOCATION  
STATE.....KANSAS  
COUNTY.....COFFEY  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...3.5 MI NE OF  
BURLINGTON, KAN  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...MAY 22, 1985  
DATE ELEC ENER 1ST GENER...JUNE 12, 1985  
DATE COMMERCIAL OPERATE....SEPTEMBER 3, 1985  
CONDENSER COOLING METHOD...COOLING LAKE  
CONDENSER COOLING WATER....COOLING LAKE  
ELECTRIC RELIABILITY  
COUNCIL.....SOUTHWEST POWER POOL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....KANSAS GAS & ELECTRIC  
CORPORATE ADDRESS.....P.O. BOX 208  
WICHITA, KANSAS 67201

CONTRACTOR  
ARCHITECT/ENGINEER.....BECHTEL  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
CONSTRUCTOR.....DANIEL INTERNATIONAL  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....IV  
IE RESIDENT INSPECTOR.....J. CUMMINS  
LICENSING PROJ MANAGER.....P. OCONNOR  
DOCKET NUMBER.....50-482  
LICENSE & DATE ISSUANCE....NPF-42, JUNE 4, 1985  
PUBLIC DOCUMENT ROOM.....WILLIAM ALLAN WHITE LIBRARY  
GOVERNMENT DOCUMENTS DIVISION  
EMPORIA STATE UNIVERSITY  
1200 COMMERCIAL STREET  
EMPORIA, KANSAS 66801

I N S P E C T I O N     S T A T U S

INSPECTION SUMMARY

INFO. NOT SUPPLIED BY REGION

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

INFO. NOT SUPPLIED BY REGION

FACILITY ITEMS (PLANS AND PROCEDURES):

INFO. NOT SUPPLIED BY REGION

MANAGERIAL ITEMS:

Report Period FEB 1986

I N S P E C T I O N     S T A T U S - (CONTINUED)

\*\*\*\*\*  
X            WOLF CREEK 1  
\*\*\*\*\*

INFO. NOT SUPPLIED BY REGION

PLANT STATUS:

INFO. NOT SUPPLIED BY REGION

LAST IE SITE INSPECTION DATE: INFO. NOT SUPPLIED BY REGION

INSPECTION REPORT NO: INFO. NOT SUPPLIED BY REGION

R E P O R T S   F R O M   L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
--------	---------------	----------------	---------

=====


INFO. NOT SUPPLIED BY REGION

1. Docket: 50-029 OPERATING STATUS  
 2. Reporting Period: 02/01/86 Outage + On-line Hrs: 672.0  
 3. Utility Contact: S. WHIPPLE (617) 872-8100  
 4. Licensed Thermal Power (MWh): 600  
 5. Nameplate Rating (Gross MWe): 185 X 1.0 = 185  
 6. Design Electrical Rating (Net MWe): 175  
 7. Maximum Dependable Capacity (Gross MWe): 180  
 8. Maximum Dependable Capacity (Net MWe): 167  
 9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE  
 10. Power Level To Which Restricted, if Any (Net MWe): \_\_\_\_\_  
 11. Reasons for Restrictions, If Any:  
NONE  
 12. Report Period Hrs      MONTH      YEAR      CUMULATIVE  
672.0      1,416.0      221,661.0  
 13. Hours Reactor Critical      672.0      1,416.0      176,937.2  
 14. Rx Reserve Shtdwn Hrs      ,0      ,0      ,0  
 15. Hrs Generator On-Line      672.0      1,416.0      172,074.4  
 16. Unit Reserve Shtdwn Hrs      ,0      ,0      ,0  
 17. Gross Therm Ener (MWH)      401,544      830,679      93,511,296  
 18. Gross Elec Ener (MWH)      123,563      255,685      28,338,358  
 19. Net Elec Ener (MWH)      115,861      239,534      26,515,751  
 20. Unit Service Factor      100.0      100.0      77.6  
 21. Unit Avail Factor      100.0      100.0      77.6  
 22. Unit Cap Factor (MDC Net)      103.2      101.3      73.5\*  
 23. Unit Cap Factor (DER Net)      98.5      96.7      70.0\*  
 24. Unit Forced Outage Rate      ,0      ,0      5.2  
 25. Forced Outage Hours      ,0      ,0      8,326.1  
 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE  
 27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\* YANKEE-ROWE 1 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

YANKEE-ROWE 1



FEBRUARY 1986

\* Item calculated with a Weighted Average

Report Period FEB 1986

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* YANKEE-ROWE 1 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System Component	Cause & Corrective Action to Prevent Recurrence
NONE								

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
YANKEE ROWE OPERATED ROUTINELY IN FEBRUARY WITH NO OUTAGES OR POWER REDUCTIONS REPORTED.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	Instructions for Preparation of
	C-Refueling	H-Other	Data Entry Sheet
	D-Regulatory Restriction	4-Continued	Licensee Event Report
	E-Operator Training & License Examination	5-Reduced Load 9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* YANKEE-ROWE 1 \*  
\*\*\*\*\*

FACILITY DESCRIPTION

LOCATION  
STATE.....MASSACHUSETTS  
COUNTY.....FRANKLIN  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...25 MI NE OF  
PITTSFIELD, MASS  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...AUGUST 19, 1960  
DATE ELEC ENER 1ST GENER...NOVEMBER 10, 1960  
DATE COMMERCIAL OPERATE....JULY 1, 1961  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER....DEERFIELD RIVER  
ELECTRIC RELIABILITY  
COUNCIL.....NORTHEAST POWER  
COORDINATING COUNCIL

FACILITY DATA

Report Period FEB 1986

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....YANKEE ATOMIC ELECTRIC  
CORPORATE ADDRESS.....1671 WORCESTER RD.  
FRAMINGHAM, MASSACHUSETTS 01701  
CONTRACTOR  
ARCHITECT/ENGINEER.....STONE & WEBSTER  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
CONSTRUCTOR.....STONE & WEBSTER  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I  
IE RESIDENT INSPECTOR.....H. EICHENHOLZ  
LICENSING PROJ MANAGER.....J. CLIFFORD  
DOCKET NUMBER.....50-029  
LICENSE & DATE ISSUANCE....DPR-3, DECEMBER 24, 1963  
PUBLIC DOCUMENT ROOM.....GREENFIELD COMMUNITY COLLEGE  
1 COLLEGE DRIVE  
GREENFIELD, MASSACHUSETTS 01301

INSPECTION SUMMARY

INSPECTION STATUS

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

Report Period FEB 1986

I N S P E C T I O N      S T A T U S - (CONTINUED)

\*\*\*\*\*  
\*            YANKEE-ROWE 1            \*  
\*\*\*\*\*

OTHER ITEMS

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S   F R O M   L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
-----			
NO INPUT PROVIDED.			
-----			


=====

1. Docket: 50-295 OPERATING STATUS  
 2. Reporting Period: 02/01/86 Outage + On-line Hrs: 672.0  
 3. Utility Contact: GERRI AUSTIN (312) 746-2084  
 4. Licensed Thermal Power (MWT): 3250  
 5. Nameplate Rating (Gross MWe): 1220 X 0.9 = 1098  
 6. Design Electrical Rating (Net MWe): 1040  
 7. Maximum Dependable Capacity (Gross MWe): 1085  
 8. Maximum Dependable Capacity (Net MWe): 1040  
 9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE  
 10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_  
 11. Reasons for Restrictions, If Any:  
NONE  
 12. Report Period Hrs      MONTH      YEAR      CUMULATIVE  
672.0      1,416.0      106,632.0  
 13. Hours Reactor Critical      672.0      1,416.0      75,133.1  
 14. Rx Reserve Shtdwn Hrs      .0      .0      2,621.8  
 15. Hrs Generator On-Line      672.0      1,416.0      73,022.1  
 16. Unit Reserve Shtdwn Hrs      .0      .0      .0  
 17. Gross Therm Ener (MWH)      2,160,415      4,555,304      211,189,607  
 18. Gross Elec Ener (MWH)      711,534      1,500,164      67,218,962  
 19. Net Elec Ener (MWH)      683,163      1,437,094      63,846,438  
 20. Unit Service Factor      100.0      100.0      68.5  
 21. Unit Avail Factor      100.0      100.0      68.5  
 22. Unit Cap Factor (MDC Net)      97.8      97.6      57.6  
 23. Unit Cap Factor (DER Net)      97.8      97.6      57.6  
 24. Unit Forced Outage Rate      .0      .0      14.0  
 25. Forced Outage Hours      .0      .0      11,216.3  
 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
REFUELING: 06/26/86 - 4 MOS.  
 27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\* ZION 1 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

ZION 1



FEBRUARY 1986

Report Period FEB 1986

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* ZION 1 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System Component	Cause & Corrective Action to Prevent Recurrence
-----	------	------	-------	--------	--------	------------	------------------	---

NONE

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
ZION 1 OPERATED ROUTINELY IN FEBRUARY WITH NO SHUTDOWNS OR POWER REDUCTIONS REPORTED.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	Instructions for Preparation of
	C-Refueling	H-Other	Data Entry Sheet
	D-Regulatory Restriction		Licensee Event Report
	E-Operator Training & License Examination	5-Reduced Load 9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* ZION 1 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1986

FACILITY DESCRIPTION

LOCATION  
STATE.....ILLINOIS  
  
COUNTY.....LAKE  
  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...40 MI N OF  
CHICAGO, ILL  
  
TYPE OF REACTOR.....PWR  
  
DATE INITIAL CRITICALITY...JUNE 19, 1973  
  
DATE ELEC ENER 1ST GENER...JUNE 28, 1973  
  
DATE COMMERCIAL OPERATE....DECEMBER 31, 1973  
  
CONDENSER COOLING METHOD...ONCE THRU  
  
CONDENSER COOLING WATER....LAKE MICHIGAN  
  
ELECTRIC RELIABILITY  
COUNCIL.....MID-AMERICA  
INTERPOOL NETWORK

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....COMMONWEALTH EDISON  
  
CORPORATE ADDRESS.....P.O. BOX 767  
CHICAGO, ILLINOIS 60690  
  
CONTRACTOR  
ARCHITECT/ENGINEER.....SARGENT & LUNDY  
  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
  
CONSTRUCTOR.....COMMONWEALTH EDISON  
  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III  
  
IE RESIDENT INSPECTOR.....M. HOLZMER  
  
LICENSING PROJ MANAGER.....J. NORRIS  
DOCKET NUMBER.....50-295  
  
LICENSE & DATE ISSUANCE....DPR-39, OCTOBER 19, 1973  
  
PUBLIC DOCUMENT ROOM.....ZION - BENTON PUBLIC LIBRARY  
2400 GABRIEL AVENUE  
ZION, ILLINOIS 60099

I N S P E C T I O N     S T A T U S

INSPECTION SUMMARY

INSPECTION ON DECEMBER 9-13 (85040): ROUTINE, UNANNOUNCED INSPECTION OF THE RADIATION PROTECTION PROGRAM DURING A MAINTENANCE OUTAGE INCLUDING: CHANGES IN ORGANIZATION, PERSONNEL, FACILITIES, EQUIPMENT, PROGRAMS, AND PROCEDURES; AUDITS AND APPRAISALS; PLANNING AND PREPARATION; TRAINING AND QUALIFICATIONS OF NEW MATERIALS AND CONTAMINATION, SURVEYS AND MONITORING; AND THE ALARA PROGRAM. ALSO OPEN ITEMS AND LICENSEE RESPONSES TO IE INFORMATION NOTICE NOS. 85-42, 85-43, AND 85-81 WERE REVIEWED. THE INSPECTION INVOLVED 40 INSPECTOR-HOURS ONSITE BY ONE NRC INSPECTOR.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

Report Period FEB 1986

I N S P E C T I O N      S T A T U S - (CONTINUED)

\*\*\*\*\*  
\* ZION 1 \*  
\*\*\*\*\*

OTHER ITEMS

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

UNIT IS OPERATING NORMALLY.

LAST IE SITE INSPECTION DATE: APRIL 21 - 25, 1986

INSPECTION REPORT NO: 86006

R E P O R T S   F R O M   L I C E N S E E


NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
85-40	12/19/85	01/17/86	AUTO START OF PENETRATION PRESSURIZATION AIR COMPRESSORS
85-44	12/06/85	01/06/86	INADVERTENT REACTOR TRIP DUE TO STEAM FLOW TRANSMITTER 1FT-512
85-46	12/05/85	01/06/86	FAILURE OF BOTH SOURCE RANGE CHANNELS FOLLOWING REACTOR TRIP
85-47	12/08/85	01/07/86	MISSSED SURVEILLANCE FOR REACTOR COOLANT IODINE FOLLOWING 15% POWER CHANGE

1. Docket: 50-304 OPERATING STATUS  
 2. Reporting Period: 02/01/86 Outage + On-line Hrs: 672.0  
 3. Utility Contact: GERRI AUSTIN (312) 746-2084  
 4. Licensed Thermal Power (MWT): 3250  
 5. Nameplate Rating (Gross MWe): 1220 X 0.9 = 1098  
 6. Design Electrical Rating (Net MWe): 1040  
 7. Maximum Dependable Capacity (Gross MWe): 1085  
 8. Maximum Dependable Capacity (Net MWe): 1040  
 9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE  
 10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_  
 11. Reasons for Restrictions, If Any:  
NONE  
 12. Report Period Hrs      MONTH      YEAR      CUMULATIVE  
       672.0      1,416.0      100,345.0  
 13. Hours Reactor Critical      672.0      794.1      72,213.5  
 14. Rx Reserve Shtdwn Hrs      .0      .0      226.1  
 15. Hrs Generator On-Line      594.5      594.5      70,202.3  
 16. Unit Reserve Shtdwn Hrs      .0      .0      .0  
 17. Gross Therm Ener (MWH)      1,457,563      1,457,563      207,127,068  
 18. Gross Elec Ener (MWH)      480,166      480,166      64,799,761  
 19. Net Elec Ener (MWH)      457,383      444,720      61,622,162  
 20. Unit Service Factor      88.5      42.0      70.0  
 21. Unit Avail Factor      88.5      42.0      70.0  
 22. Unit Cap Factor (MDC Net)      65.4      30.2      59.0  
 23. Unit Cap Factor (DER Net)      65.4      30.2      59.0  
 24. Unit Forced Outage Rate      .0      .0      15.7  
 25. Forced Outage Hours      .0      .0      13,138.1  
 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE  
 27. If Currently Shutdown Estimated Startup Date: 03/04/86

\*\*\*\*\*  
\* ZION 2 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

ZION 2



FEBRUARY 1986

Report Period FEB 1986

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* ZION 2 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
6	09/05/85	S	77.5	C	4				END OF CYCLE VIII-IX REFUELING OUTAGE CONCLUDES.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
ZION 2 RETURNED TO POWER ON FEBRUARY 4 FOLLOWING A REFUELING OUTAGE.

Type	Reason	Method	System & Component	
F-Forced	A-Equip Failure	F-Admin	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	2-Manual Scram	Instructions for
	C-Refueling	H-Other	3-Auto Scram	Preparation of
	D-Regulatory Restriction		4-Continued	Data Entry Sheet
	E-Operator Training		5-Reduced Load	Licensee Event Report
	& License Examination		9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* ZION 2 \*  
\*\*\*\*\*

#### FACILITY DATA

Report Period FEB 1986

##### FACILITY DESCRIPTION

LOCATION  
STATE.....ILLINOIS  
CITY.....LAKE  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...40 MI N OF  
CHICAGO, ILL  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...DECEMBER 24, 1973  
DATE ELEC ENER 1ST GENER...DECEMBER 26, 1973  
DATE COMMERCIAL OPERATE....SEPTEMBER 17, 1974  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER....LAKE MICHIGAN  
ELECTRIC RELIABILITY  
COUNCIL.....MID-AMERICA  
INTERPOOL NETWORK

##### UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....COMMONWEALTH EDISON  
CORPORATE ADDRESS.....P.O. BOX 767  
CHICAGO, ILLINOIS 60690  
CONTRACTOR  
ARCHITECT/ENGINEER.....SARGENT & LUNDY  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
CONSTRUCTOR.....COMMONWEALTH EDISON  
TURBINE SUPPLIER.....WESTINGHOUSE

##### REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III  
IE RESIDENT INSPECTOR.....M. HOLZMER  
LICENSING PROJ MANAGER.....J. NORRIS  
DOCKET NUMBER.....50-304  
LICENSE & DATE ISSUANCE....DPR-48, NOVEMBER 14, 1973  
PUBLIC DOCUMENT ROOM.....ZION - BENTON PUBLIC LIBRARY  
2400 GABRIEL AVENUE  
ZION, ILLINOIS 60099

##### INSPECTION STATUS

##### INSPECTION SUMMARY

INSPECTION ON DECEMBER 9-13 (85041): ROUTINE, UNANNOUNCED INSPECTION OF THE RADIATION PROTECTION PROGRAM DURING A MAINTENANCE OUTAGE INCLUDING: CHANGES IN ORGANIZATION, PERSONNEL, FACILITIES, EQUIPMENT, PROGRAMS, AND PROCEDURES; AUDITS AND APPRAISALS; PROGRAM. ALSO OPEN ITEMS AND LICENSEE RESPONSES TO IE INFORMATION NOTICE NOS. 85-42, 85-43, AND 85-81 WERE REVIEWED. THE INSPECTION INVOLVED 40 INSPECTOR-HOURS ONSITE BY ONE NRC INSPECTOR.

##### ENFORCEMENT SUMMARY

NONE

##### OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

Report Period FEB 1986

I N S P E C T I O N      S T A T U S - (CONTINUED)

\*\*\*\*\*  
\*            ZION 2            \*  
\*\*\*\*\*

OTHER ITEMS

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

THE UNIT IS IN A REFUELING OUTAGE UNTIL JANUARY 1986.

LAST IE SITE INSPECTION DATE: APRIL 21 - 25, 1986

INSPECTION REPORT NO: 86006

R E P O R T S   F R O M   L I C E N S E E

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
85-28	12/14/85	01/13/86	LOSS OF DECAY HEAT REMOVAL DUE TO RHR PUMP CAVITATION
86-01	01/03/86	01/31/86	OPERATION OF THE PRESSURIZER POWER OPERATED RELIEF VALVES

THIS PAGE INTENTIONALLY LEFT BLANK

**SECTION 3**

**APPENDIX**

\*\*\*\*\*  
 \* PRESSURIZED\* STATUS OF SPENT FUEL STORAGE CAPABILITY  
 \* WATER \*  
 \* REACTORS \* (a)  
 \*\*\*\*\* CORE SIZE PRESENT AUTH. NO. OF REMAINING CAPACITY  
     (NO. OF STORAGE POOL CAP. ASSEMBLIES) (FUEL ASSEMBLIES) STORED (NO. OF ASSEMBLIES)  
 FACILITY ASSEMBLIES \*\*\*\* \* \*\*\*\* APPROVED PENDING REQUEST NEXT REFUEL WILL FILL PRESENT  
 \*\*\*\*\* \*\*\*\* \* \*\*\*\* \* SCHED. DATE AUTH. CAPACITY (b)  
 \*\*\*\*\*

FACILITY	CORE SIZE (NO. OF ASSEMBLIES)	PRESNT AUTH. (FUEL ASSEMBLIES)	NO. OF ASSEMBLIES STORED	REMAINING CAPACITY (NO. OF ASSEMBLIES)	APPROVED SCHED. DATE	PENDING REQUEST AUTH. CAPACITY
ARKANSAS 1	177	988	456	532	08-86	1998
ARKANSAS 2	177	988	168	820	06-86	2003
BEAVER VALLEY 1	157	833	232	601	05-86	1995
BYRON 1	193	1050	0	1050	10-86	1995
CALLAWAY 1	193	1340	0	1340	02-86	1993
CALVERT CLIFFS 1	217	1830(c)	1000(c)	830(c)(m)	1098	10-86
CALVERT CLIFFS 2	217					03-87
CATAWBA 1	193	1418	0	1418		08-86
COOK 1	193	2050(c)	802(c)	1248(c)		N/S
COOK 2	193					03-86
CRYSTAL RIVER 3	177	1163	328	829		N/S
DAVIS-BESSE 1	177	735	204	531		N/S
DIABLO CANYON 1	193	1400	0	1400		08-86
DIABLO CANYON 2						1993
FARLEY 1	157	1407	273	1134		N/S
FARLEY 2	157	1407	188	1219		04-86
FORT CALHOUN 1	133	729	348	381		03-87
GINNA	121	1016	380	636		02-86
HADDAM NECK	157	1168	597	571		07-87
INDIAN POINT 1	0	288	160	128		N/S
INDIAN POINT 2	193	980	396	584		01-86
INDIAN POINT 3	193	840	292	548		N/S
KEWAUNEE	121	990	376	614(m)		02-86
MAINE YANKEE	217	1476	721	755		N/S
MCGUIRE 1	193	1463	152	1311(n)		03-86
MCGUIRE 2	193	1463	78	1385		06-86
MILLSTONE 2	217	667	449	218		10-86
MILLSTONE 3	0	0	0	0		1987
NORTH ANNA 1	157	1737(c)	468(c)	1269		N/S
NORTH ANNA 2	157					1993
OCONEE 1	177	1312(1)	982	330(1)(n)		03-86
OCONEE 2	177					1991
OCONEE 3	177	875	390	485		03-87
PALISADES	204	798	477	321		N/S
PALO VERDE 1	241	1329	0	1329		N/S
POINT BEACH 1	121	1502(c)	835(c)	667(c)		04-86
POINT BEACH 2	121					N/S
PRAIRIE ISLAND 1	121	1586(c)	741(c)	845(c)(m)		03-86
PRAIRIE ISLAND 2	121					N/S
RANCHO SECO 1	177	1080	316	764		01-87
ROBINSON 2	157	541	274	266(e)	379	N/S
SALEM 1	193	1170	296	874		03-86
SALEM 2	193	1170	140	1030		10-86
SAN ONOFRE 1	157	216	94	122		N/S
SAN ONOFRE 2	217	800	72	728		04-86
SAN ONOFRE 3	217	800	72	728		11-86
SEQUOYAH 1	193	1386	348	1033		N/S

\*\*\*\*\*  
\* PRESSURIZED\* S T A T U S   O F   S P E N T   F U E L   S T O R A G E   C A P A B I L I T Y  
\*   W A T E R \*  
\*   R E A C T O R S \*

FACILITY	CORE SIZE (NO. OF ASSEMBLIES)	PRESENT AUTH. (FUEL ASSEMBLIES)	NO. OF STORAGE POOL CAP. ASSEMBLIES	REMAINING CAPACITY STORED (NO. OF ASSEMBLIES)	REMAINING CAPACITY IF PENDING REQUEST		(b) APPROVED SCHED. DATE	NEXT REFUEL WILL FILL PRESENT AUTH. CAPACITY
					NO. OF ASSEMBLIES	APPROVED SCHED. DATE		
SEQUOYAH 2(d)	193						N/S	1994
ST LUCIE 1	217	728	372	356			N/S	1993
ST LUCIE 2	217	1076	80	996		02-86		1993
SUMMER 1	157	1276	96	1180			N/S	2008
SURRY 1	157	1044(c)	849(c)	195(c)		05-86		1985
SURRY 2	157						N/S	1985
THREE MILE ISLAND 1	177	752	208	544			N/S	
THREE MILE ISLAND 2	177	442	0	442			N/S	1991
TROJAN	193	1408	361	1047		04-86		1993
TURKEY POINT 3	157	1404	445	959(m)			N/S	1993
TURKEY POINT 4	157	1404	482	922			N/S	1993
WATERFORD 3	217	1088	0	1088			N/S	
WOLF CREEK 1	193	1340	0	1340			N/S	1993
YANKEE-ROWE 1	76	721	325	396			N/S	
ZION 1	193	2112(c)	1008(c)	1104(c)		06-86		1995
ZION 2	193						N/S	1995

INDEPENDENT SPENT FUEL STORAGE INSTALLATIONS(h)

MORRIS OPERATIONS	750 MTU(j)	315	385 MTU(j)	1490 MTU(j)
NFS(i)	250 MTU	170 MTU	80 MTU	

(a) At each refueling outage approximately 1/3 of a PWR core and 1/4 of a BWR core is off-loaded.

(b) Some of these dates have been adjusted by staff assumptions.

(c) This is the total for both units.

(d) Plant not in commercial operation.

(e) Some spent fuel stored at Brunswick.

(f) Authorized a total 2772 BWR and 1232 PWR assemblies for both pools.

(g) Robinson 2 assemblies being shipped to Brunswick for storage.

(h) Capacity is in metric tons of uranium; 1 MTU = 2 PWR assemblies or 5 BWR assemblies.

(i) No longer accepting spent fuel.

(j) Racked for 700 MTU.

(k) Reserved.

(l) This is the station total.

(m) Installed capacity is less than that authorized.

(n) McGuire 1 authorized to accept Oconee fuel assemblies.

-----  
N/S = Not Scheduled  
-----

\*\*\*\*\*  
 \* BOILING \* STATUS OF SPENT FUEL STORAGE CAPABILITY  
 \* WATER \*  
 \* REACTORS \* (a)  
 \*\*\*\*\* CORE SIZE PRESENT AUTH. NO. OF REMAINING CAPACITY  
 (NO. OF FACILITY ASSEMBLIES) STORAGE POOL CAP. ASSEMBLIES REMAINING CAPACITY IF PENDING REQUEST APPROVED (b)  
 \*\*\*\*\* (FUEL ASSEMBLIES) STORED (NO. OF ASSEMBLIES) (NO. OF ASSEMBLIES) NEXT REFUEL SCHED. DATE WILL FILL PRESENT  
 \*\*\*\*\* ASSEMBLIES \*\*\*\*\* \*\*\*\*\* \*\*\*\*\* \*\*\*\*\* \*\*\*\*\* AUTH. CAPACITY

BIG ROCK POINT 1	84	441	192	249		N/S	1993
BROWNS FERRY 1	764	3471	1288	2183		N/S	1993
BROWNS FERRY 2	764	3471	1161	2310(m)	1819	N/S	1993
BROWNS FERRY 3	764	3471	1004	2467(m)		N/S	1993
BRUNSWICK 1	560	(f)	160PWR+656BWR	123		N/S	1992
BRUNSWICK 2	560		144PWR+564BWR	107		N/S	1993
COOPER STATION	548	2366	790	1576		N/S	1996
DRESDEN 1	464	672	221	451		N/S	1990
DRESDEN 2	724	3537(c)	1413 (c)	2124(c)	(c)	N/S	1993
DRESDEN 3	724	3537	1271	2266		N/S	1993
DUANE ARNOLD	368	2050	696	1354		02-87	1998
FITZPATRICK	560	2244	1012	768		N/S	1992
GRAND GULF 1	800	1440	0	1440		N/S	1993
HATCH 1	560	6026	1580	4446		N/S	1999
HATCH 2	560			1325		N/S	1999
HUMBOLDT BAY	172	487	251	236		N/S	
LA CROSSE	72	440	237	203		03-86	1992
LASALLE 1	764	2162	191	1971		N/S	1988
LASALLE 2	764					N/S	1988
LIMERICK 1	764	2040	0	2040		N/S	1993
MILLSTONE 1	580	2184	1546	638		05-86	1991
MONTICELLO	484	2237	701	1536		05-86	1999
NINE MILE POINT 1	532	2776	1244	1532	1788	03-86	1996
OYSTER CREEK 1	560	2600	1204	1396		04-86	1990

\*\*\*\*\*  
 \* BOILING \* STATUS OF SPENT FUEL STORAGE CAPABILITY  
 \* WATER \*  
 \* REACTORS \* (a)

FACILITY	CORE SIZE (NO. OF ASSEMBLIES)	PRESENT AUTH. (FUEL ASSEMBLIES)	NO. OF STORAGE POOL CAP. (FUEL ASSEMBLIES)	REMAINING CAPACITY IF PENDING REQUEST		APPROVED	NEXT REFUEL SCHED. DATE	WILL FILL PRESENT AUTH. CAPACITY	(b)
				ASSEMBLIES REMAINING	CAPACITY STORED (NO. OF ASSEMBLIES)				
PEACH BOTTOM 2	764	2816	1462	1354		2357	01-87	1989	
PEACH BOTTOM 3	764	2816	1490	1326		2329	N/S	1989	
PILGRIM 1	580	2320	1128	642(m)			09-86	1990	
QUAD CITIES 1	724	3657	2358	1299			N/S	2003	
QUAD CITIES 2	724	3897	842	3055			10-86	2003	
RIVER BEND 1									
SUSQUEHANNA 1	764	2840	191	2649			02-86	1997	
SUSQUEHANNA 2	764	2840	0	2840			08-86	1997	
VERMONT YANKEE 1	368	2000	1296	704			N/S	1992	
WASHINGTON NUCLEAR*	764	2658	0	2658			04-86	1993	

INDEPENDENT SPENT FUEL STORAGE INSTALLATIONS(h)

MORRIS OPERATIONS	750 MTU(j)	315	385 MTU(j)	1490 MTU(j)
NFS(i)	250 MTU	170 MTU	80 MTU	

- (a) At each refueling outage approximately 1/3 of a PWR core and 1/4 of a BWR core is off-loaded.
- (b) Some of these dates have been adjusted by staff assumptions.
- (c) This is the total for both units.
- (d) Plant not in commercial operation.
- (e) Some spent fuel stored at Brunswick.
- (f) Authorized a total 2772 BWR and 1232 PWR assemblies for both pools.
- (g) Robinson 2 assemblies being shipped to Brunswick for storage.
- (h) Capacity is in metric tons of uranium; 1 MTU = 2 PWR assemblies or 5 BWR assemblies.
- (i) No longer accepting spent fuel.
- (j) Racked for 700 MTU.
- (k) Reserved.
- (l) This is the station total.
- (m) Installed capacity is less than that authorized.
- (n) McGuire 1 authorized to accept Oconee fuel assemblies.

-----  
 N/S = Not Scheduled  
 -----

(INCLUDES BOTH LICENSED  
AND NON-LICENSED UNITS)

R E A C T O R Y E A R S O F E X P E R I E N C E

	1ST ELEC	YEARS GENERATE	UNIT	1ST ELEC	YEARS GENERATE	UNIT	1ST ELEC	YEARS GENERATE	UNIT
*****									
* LICENSED *	11.58	08/01/74	ARKANSAS 1	7.18	12/26/78	ARKANSAS 2	9.71	06/14/76	BEAVER VALLEY 1
* OPERATING *	23.23	12/08/62	BIG ROCK POINT 1	12.38	10/15/73	BROWNS FERRY 1	11.51	08/28/74	BROWNS FERRY 2
* ELECTRICAL *	9.46	09/12/76	BROWNS FERRY 3	9.24	12/04/76	BRUNSWICK 1	10.84	04/29/75	BRUNSWICK 2
* PRODUCING *	1.00	03/01/85	BYRON 1	1.35	10/24/84	CALLAWAY 1	11.16	01/03/75	CALVERT CLIFFS 1
* UNITS *	9.23	12/07/76	CALVERT CLIFFS 2	1.10	01/22/85	CATAWBA 1	11.05	02/10/75	COOK 1
*****	7.94	03/22/78	COOK 2	11.81	05/10/74	COOPER STATION	9.08	01/30/77	CRYSTAL RIVER 3
	8.51	08/28/77	DAVIS-BESSE 1	1.30	11/11/84	DIABLO CANYON 1	.36	10/20/85	DIABLO CANYON 2
	15.88	04/13/70	DRESDEN 2	14.61	07/22/71	DRESDEN 3	11.78	05/19/74	DUANE ARNOLD
	8.53	08/ 8/77	FARLEY 1	4.77	05/25/81	FARLEY 2	11.08	02/01/75	FITZPATRICK
	12.51	08/25/73	FORT CALHOUN 1	9.22	12/11/76	FORT ST VRAIN	16.24	12/02/69	GINNA
	1.36	10/20/84	GRAND GULF 1	18.57	08/07/67	HADDAM NECK	11.30	11/11/74	HATCH 1
	7.44	09/22/78	HATCH 2	12.68	06/26/73	INDIAN POINT 2	9.84	04/27/76	INDIAN POINT 3
	11.90	04/08/74	KEWAUNEE	17.85	04/26/68	LA CROSSE	3.49	09/04/82	LASALLE 1
	1.86	04/20/84	LASALLE 2	.88	04/13/85	LIMERICK 1	13.31	11/08/72	MAINE YANKEE
	4.67	06/30/81	MCGUIRE 1	2.77	05/23/83	MCGUIRE 2	15.25	11/29/70	MILLSTONE 1
	10.31	11/09/75	MILLSTONE 2	.05	02/12/86	MILLSTONE 3	14.99	03/05/71	MONTICELLO
	16.31	11/09/69	NINE MILE POINT 1	7.87	04/17/78	NORTH ANNA 1	5.51	08/25/80	NORTH ANNA 2
	12.82	05/06/73	OCONEE 1	12.24	12/05/73	OCONEE 2	11.50	09/01/74	OCONEE 3
	16.44	09/23/69	OYSTER CREEK 1	14.17	12/31/71	PALISADES	.72	06/10/85	PALO VERDE 1
	12.03	02/18/74	PEACH BOTTOM 2	11.50	09/01/74	PEACH BOTTOM 3	13.62	07/19/72	PILGRIM 1
	15.32	11/06/70	POINT BEACH 1	13.58	08/02/72	POINT BEACH 2	12.24	12/04/73	PRAIRIE ISLAND 1
	11.19	12/21/74	PRAIRIE ISLAND 2	13.88	04/12/72	QUAD CITIES 1	13.77	05/23/72	QUAD CITIES 2
	11.38	10/13/74	RANCHO SECO 1	.24	12/03/85	RIVER BEND 1	15.43	09/26/70	ROBINSON 2
	9.18	12/25/76	SALEM 1	4.74	06/03/81	SALEM 2	18.63	07/16/67	SAN ONOFRE 1
	3.44	09/20/82	SAN ONOFRE 2	2.43	09/25/83	SAN ONOFRE 3	5.61	07/22/80	SEQUOYAH 1
	4.19	12/23/81	SEQUOYAH 2	9.82	05/07/76	ST LUCIE 1	2.72	06/13/83	ST LUCIE 2
	3.29	11/16/82	SUMMER 1	13.66	07/04/72	SURRY 1	12.97	03/10/73	SURRY 2
	3.29	11/16/82	SUSQUEHANNA 1	1.66	07/03/84	SUSQUEHANNA 2	11.70	06/19/74	THREE MILE ISLAND 1
	10.19	12/23/75	TROJAN	13.33	11/02/72	TURKEY POINT 3	12.69	06/21/73	TURKEY POINT 4
	13.44	09/20/72	VERMONT YANKEE 1	1.76	05/27/84	WASHINGTON NUCLEAR 2	.95	03/18/85	WATERFORD 3
	.72	06/12/85	WOLF CREEK 1	25.30	11/10/60	YANKEE-ROWE 1	12.67	06/28/73	ZION 1
	12.18	12/26/73	ZION 2						

TOTAL 894.43 YRS

	1ST ELEC SHUTDOWN	YEARS GENERATE	DATE	UNIT	1ST ELEC SHUTDOWN	YEARS GENERATE	DATE	UNIT
*****								
* PERMANENTLY *	3.80	08/14/64	06/01/68	BONUS	3.04	12/18/63	01/01/67	CVTR
* OR *	18.54	04/15/60	10/31/78	DRESDEN 1	4.44	08/24/63	02/01/68	ELK RIVER
* INDEFINITELY*	6.32	08/05/66	11/29/72	FERMI 1	1.26	05/29/63	09/01/64	HALLAM
* SHUTDOWN *	13.21	04/18/63	07/02/76	HUMBOLDT BAY	12.12	09/16/62	10/31/74	INDIAN POINT 1
* UNITS *	1.19	07/25/66	10/01/67	PATHFINDER	7.76	01/21/67	11/01/74	PEACH BOTTOM 1
*****	2.16	11/04/63	01/01/66	PIQUA	.93	04/21/78	03/28/79	THREE MILE ISLAND 2
TOTAL	74.77	YRS						

\*\*\*\*\*  
\* RESEARCH \*  
\* REACTORS \*  
\*\*\*\*\*

NON-POWER REACTORS IN THE U.S.

STATE	CITY	LICENSEE	REACTOR TYPE	LICENSE NUMBER	DATE OF ISSUED	AUTHORIZED POWER LEVEL (KW)	
ALABAMA	TUSKEGEE	TUSKEGEE INSTITUTE	AGN-201 #102	50-406	R-122	08-30-74 0.0001	
ARIZONA	TUCSON	UNIVERSITY OF ARIZONA	TRIGA MARK I	50-113	R-52	12-05-58 100.0	
CALIFORNIA	BERKELEY CANOGA PARK HAWTHORNE IRVINE LOS ANGELES SAN DIEGO SAN DIEGO SAN JOSE SAN LUIS OBISPO SAN RAMON SANTA BARBARA	UNIVERSITY OF CALIFORNIA, BERKELEY COLLEGE ROCKWELL INTERNATIONAL CORP. NORTHROP CORP. LABORATORIES UNIVERSITY OF CALIFORNIA, IRVINE UNIVERSITY OF CALIFORNIA, L.A. GENERAL ATOMIC COMPANY GENERAL ATOMIC COMPANY GENERAL ELECTRIC COMPANY CALIFORNIA STATE POLYTECHNIC COLLEGE AEROTEST OPERATIONS, INC. UNIVERSITY OF CALIFORNIA, SANTA BARBARA	TRIGA MK. III L-85 TRIGA MARK F TRIGA MARK I ARGONAUT TRIGA MARK F TRIGA MARK I NTR AGN-201 #100 TRIGA (INDUS) L-77	50-224 50-375 50-187 50-326 50-142 50-163 50-089 50-073 50-394 50-228 50-433	R-101 R-188 R-90 R-116 R-71 R-67 R-38 R-33 R-121 R-98 R-124	08-10-66 01-05-72 03-04-63 11-24-69 10-03-60 07-01-60 05-03-58 10-31-57 05-16-73 07-02-65 12-03-74	1000.0 0.003 1000.0 250.0 100.0 1500.0 250.0 100.0 0.0001 250.0 0.01
COLORADO	DENVER	U.S. GEOLOGICAL SURVEY DEPARTMENT	TRIGA MARK I	50-274	R-113	02-24-69 1000.0	
DELAWARE	NEWARK	UNIVERSITY OF DELAWARE	AGN-201 #113	50-098	R-43	07-03-58 0.0001	
DIST OF COLUMBIA	WASHINGTON	THE CATHOLIC UNIVERSITY OF AMERICA	AGN-201 #101	50-077	R-31	11-15-67 0.0001	
FLORIDA	GAINESVILLE	UNIVERSITY OF FLORIDA	ARGONAUT	50-083	R-56	05-21-59 100.0	
GEORGIA	ATLANTA ATLANTA	GEORGIA INSTITUTE OF TECHNOLOGY GEORGIA INSTITUTE OF TECHNOLOGY	AGN-201 #104 HEAVY WATER	50-276 50-160	R-111 R-97	04-19-68 12-29-64	0.0001 5000.0
IDAHO	POCATELLO	IDAHO STATE UNIVERSITY	AGN-201 #103	50-284	R-110	10-11-67 0.0001	
ILLINOIS	URBANA URBANA ZION	UNIVERSITY OF ILLINOIS UNIVERSITY OF ILLINOIS WESTINGHOUSE ELECTRIC CORP.	LOPRA TRIGA NTR	50-356 50-151 50-087	R-117 R-115 R-119	12-27-71 07-22-69 01-28-72	10.0 1500.0 10.0
INDIANA	LAFAYETTE	PURDUE UNIVERSITY	LOCKHEED	50-182	R-87	08-16-62 10.0	
IOWA	AMES	IOWA STATE UNIVERSITY	UTR-10	50-116	R-59	10-16-59 10.0	
KANSAS	LAWRENCE MANHATTAN	UNIVERSITY OF KANSAS KANSAS STATE UNIVERSITY	LOCKHEED TRIGA	50-148 50-188	R-78 R-88	06-23-61 10-16-62	250.0 250.0
MARYLAND	BETHESDA COLLEGE PARK	ARMED FORCES RADIobiology RESEARCH INSTITUTE UNIVERSITY OF MARYLAND	TRIGA TRIGA	50-170 50-166	R-84 R-70	06-26-62 10-14-60	1000.0 250.0

\*\*\*\*\*  
\* RESEARCH \*  
\* REACTORS \*  
\*\*\*\*\*

N O N - P O W E R R E A C T O R S I N T H E U. S.

STATE	CITY	LICENSEE	REACTOR TYPE	DOCKET	LICENSE NUMBER	DATE OF ISSUED	AUTHORIZED POWER LEVEL (KW)
MASSACHUSETTS	CAMBRIDGE	MASSACHUSETTS INSTITUTE OF TECHNOLOGY	HWR REFLECTED	50-020	R-37	06-09-58	5000.0
	LOWELL	UNIVERSITY OF LOWELL	GE	50-223	R-125	12-24-74	1000.0
	WORCESTER	WORCESTER POLYTECHNIC INSTITUTE	GE	50-134	R-61	12-16-59	10.0
MICHIGAN	ANN ARBOR	UNIVERSITY OF MICHIGAN	POOL	50-002	R-28	09-13-57	2000.0
	EAST LANSING	MICHIGAN STATE UNIVERSITY	TRIGA MARK I	50-294	R-114	03-21-69	250.0
	MIDLAND	DOW CHEMICAL COMPANY	TRIGA	50-264	R-108	07-03-67	100.0
MISSOURI	COLUMBIA	UNIVERSITY OF MISSOURI, COLUMBIA	TANK	50-186	R-103	10-11-66	10000.0
	ROLLA	UNIVERSITY OF MISSOURI	POOL	50-123	R-79	11-21-61	200.0
NEBRASKA	OMAHA	THE VETERANS ADMINISTRATION HOSPITAL	TRIGA	50-131	R-57	06-26-59	18.0
NEW MEXICO	ALBUQUERQUE	UNIVERSITY OF NEW MEXICO	AGN-201M #112	50-252	R-102	09-17-66	0.005
NEW YORK	BRONX	MANHATTAN COLLEGE - PHYSICS DEPT.	TANK	50-199	R-94	03-24-64	0.0001
	BUFFALO	STATE UNIVERSITY OF NEW YORK	PULSTAR	50-057	R-77	03-24-61	2000.0
	ITHACA	CORNELL UNIVERSITY	TRIGA MARK II	50-157	R-80	01-11-62	500.0
	ITHACA	CORNELL UNIVERSITY	ZPR	50-097	R-89	12-11-62	0.1
	NEW YORK	COLUMBIA UNIVERSITY IN THE CITY OF NEW YORK	TRIGA MARK II	50-208	R-128	04-14-77	250.0
	UXEDO	UNION CARBIDE CORP	POOL	50-054	R-81	09-07-61	5000.0
NORTH CAROLINA	RALEIGH	NORTH CAROLINA STATE UNIVERSITY AT RALEIGH	PULSTAR	50-297	R-120	08-25-74	1000.0
OHIO	COLUMBUS	OHIO STATE UNIVERSITY	POOL	50-150	R-75	02-24-61	10.0
OKLAHOMA	NORMAN	THE UNIVERSITY OF OKLAHOMA	AGN-211 #102	50-112	R-53	12-29-58	0.100
OREGON	CORVALLIS	OREGON STATE UNIVERSITY	TRIGA MARK II	50-243	R-106	03-07-67	1000.0
	PORTLAND	REED COLLEGE	TRIGA MARK I	50-288	R-112	07-02-68	250.0
PENNSYLVANIA	UNIVERSITY PARK	PENNSYLVANIA STATE UNIVERSITY	TRIGA MK. III	50-005	R-2	07-08-55	1000.0
RHODE ISLAND	NARRAGANSETT	RHODE ISLAND NUCLEAR SCIENCE CENTER	GE POOL	50-193	R-95	07-21-64	2000.0
TENNESSEE	MEMPHIS	MEMPHIS STATE UNIVERSITY	AGN-201 #108	50-538	R-127	12-10-76	0.0001
TEXAS	AUSTIN	UNIVERSITY OF TEXAS	TRIGA MARK I	50-192	R-92	08-02-63	250.0
	COLLEGE STATION	TEXAS A&M UNIVERSITY	AGN-201M #106	50-059	R-23	08-26-57	0.005
	COLLEGE STATION	TEXAS A&M UNIVERSITY	TRIGA	50-128	R-83	12-07-61	1000.0
UTAH	PROVO	BRIGHAM YOUNG UNIVERSITY	L-77	50-262	R-109	09-07-67	0.01

\*\*\*\*\*  
\* RESEARCH \*  
\* REACTORS \*  
\*\*\*\*\*

NON-POWER REACTORS IN THE U.S.

STATE	CITY	LICENSEE	REACTOR TYPE	DOCKET	LICENSE NUMBER	DATE OF ISSUED	AUTHORIZED POWER LEVEL (KW)
UTAH	SALT LAKE CITY SALT LAKE CITY	THE UNIVERSITY OF UTAH UNIVERSITY OF UTAH	TRIGA MARK I AGN-201M #107	50-407 50-072	R-126 R-25	09-30-75 09-12-57	100.0 0.005
VIRGINIA	BLACKSBURG CHARLOTTESVILLE CHARLOTTESVILLE LYNCHBURG	VIRGINIA POLYTECHNIC INSTITUTE UNIVERSITY OF VIRGINIA UNIVERSITY OF VIRGINIA BABCOCK & WILCOX COMPANY	UTR-10 CAVALIER POOL LPR	50-124 50-396 50-062 50-099	R-62 R-123 R-66 R-47	12-18-59 09-24-74 06-27-60 09-05-58	100.0 0.1 2000.0 1000.0
WASHINGTON	PULLMAN SEATTLE	WASHINGTON STATE UNIVERSITY UNIVERSITY OF WASHINGTON	TRIGA ARGONAUT	50-027 50-139	R-76 R-73	03-06-61 03-31-61	1000.0 100.0
WISCONSIN	MADISON	UNIVERSITY OF WISCONSIN	TRIGA	50-156	R-74	11-23-60	1000.0

\*\*\*\*\*  
\* EXPERIMENTAL AND TEST REACTORS \*  
\*\*\*\*\*

CALIFORNIA	SAN JOSE	GENERAL ELECTRIC COMPANY	GETR	50-070	TR-1	01-07-59	50,000.0
DIST OF COLUMBIA	WASHINGTON	NATIONAL BUREAU OF STANDARDS	TEST	50-184	TR-5	06-30-70	10,000.0

\*\*\*\*\*  
\* CRITICAL EXPERIMENT FACILITIES \*  
\*\*\*\*\*

NEW YORK	TROY	RENSSELAER POLYTECHNIC INSTITUTE		50-225	CX-22	07-03-64	0.0
VIRGINIA	LYNCHBURG	BABCOCK & WILCOX COMPANY		50-013	CX-10	10-22-58	0.0
WASHINGTON	RICHLAND	BATTELLE MEMORIAL INSTITUTE		50-360	CX-26	11-29-71	0.0

## BIBLIOGRAPHIC DATA SHEET

NUREG-0020 Volume 10 Number 3

4 RECIPIENT'S ACCESSION NUMBER

5 DATE REPORT COMPLETED

MONTH YEAR

APRIL 1986

7 DATE REPORT ISSUED

MONTH YEAR

APRIL 1986

9 PROJECT/TASK/WORK UNIT NUMBER

10 FIN NUMBER

12a TYPE OF REPORT

12b PERIOD COVERED (inclusive dates)

FEBRUARY 1986

## 3 TITLE AND SUBTITLE

Licensed Operating Reactors  
Status Summary Report

## 6 AUTHORISI

P. A. Ross, M. R. Beebe

## 8 PERFORMING ORGANIZATION NAME AND MAILING ADDRESS (Include Zip Code)

Division of Budget and Analysis  
Office of Resource Management  
U. S. Nuclear Regulatory Commission  
Washington, DC 20555

## 11 SPONSORING ORGANIZATION NAME AND MAILING ADDRESS (Include Zip Code)

Division of Budget and Analysis  
Office of Resource Management  
U. S. Nuclear Regulatory Commission  
Washington, DC 20555

## 13 SUPPLEMENTARY NOTES

Status Summary Report

## 14 ABSTRACT (200 words or less)

The OPERATING UNITS STATUS REPORT - LICENSED OPERATING REACTORS provides data on the operation of nuclear units as timely and accurately as possible. This information is collected by the Office of Resource Management from the Headquarters staff of NRC's Office of Inspection and Enforcement, from NRC's Regional Offices, and from utilities. The three sections of the report are: monthly highlights and statistics for commercial operating units, and errata from previously reported data; a compilation of detailed information on each unit, provided by NRC's Regional Offices, IE Headquarters and the utilities; and an appendix for miscellaneous information such as spent fuel storage capability, reactor-years of experience and non-power reactors in the U.S. It is hoped the report is helpful to all agencies and individuals interested in maintaining an awareness of the U.S. energy situation as a whole.

## 15a KEY WORDS AND DOCUMENT ANALYSIS

## 15b DESCRIPTORS

## 16 AVAILABILITY STATEMENT

Unlimited

## 17 SECURITY CLASSIFICATION

*This report*  
Unclassified

## 18 NUMBER OF PAGES

5

## 19 SECURITY CLASSIFICATION

*This paper*  
Unclassified

## 20 PRICE

DISTRIBUTION LIST - NRC

INTERNAL DISTRIBUTION

Office of the Commissioners	5
Atomic Safety and Licensing Appeal Panel	3
Advisory Committee on Reactor Safeguards	6
Office of Inspector and Auditor	1
Office of Policy Evaluation	1
Office of the General Counsel	1
Office of Public Affairs	21
Office of Congressional Affairs	3
Office of the Executive Director for Operations	7
Office of Administration	2
Office of the Executive Legal Director	2
Office of Analysis and Evaluation of Operational Data	2
Office of International Programs	3
Office of State Programs	1
Office of Resource Management	19
Office of Nuclear Material Safety and Safeguards	2
- Division of Fuel Cycle and Material Safety	3
- Division of Safeguards	2
Office of Nuclear Reactor Regulation	138
- Division of Engineering	
- Division of Safety Technology	
- Division of Licensing	
- Division of Systems Integration	
- Division of Human Factors Safety	
Office of Nuclear Regulatory Research	4
Office of Inspection and Enforcement	7
- Region I	11
- Region II	10
- Region III	10
- Region IV	10
- Region V	7
	281

EXTERNAL DISTRIBUTION

<u>SPECIAL REQUESTS</u>	
Air Force	1
Congress	10
Department of Energy	32
Government Accounting Office	1
Environmental Protection Agency	1
Electric Power Research Institute	1
Argonne National Laboratory	3
Bureau of Mines	1
Department of Agriculture	1
Department of the Commerce	1
Department of the Interior	1
	53
<u>OTHER</u>	
GPO Depository	440
GPO Stores	75
National Technical Information Service	25
Subscriptions (NTIS)	250
Colleges and Libraries (including Public Document Rooms)	128
Utilities and Other Requests	227
	1145

UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555

FIRST CLASS MAIL  
POSTAGE & FEES PAID  
USNRC  
WASH D.C.  
PERMIT NO. 687

OFFICIAL BUSINESS  
PENALTY FOR PRIVATE USE, \$300

120555078877 1 1AN1NU  
US NRC  
ADM-DIV OF TIDC  
POLICY & PUB MGT RR-PDR NUREG  
W-501  
WASHINGTON DC 20555