
Evaluation of Nuclear Facility Decommissioning Projects

Summary Status Report
Three Mile Island Unit 2
Reactor Coolant System and Systems Decontamination

Prepared by D. H. Doerge, R. L. Miller, K. S. Scotti

UNC Nuclear Industries

Prepared for
U.S. Nuclear Regulatory
Commission

8606240547 860531
PDR ADOCK 05000320
P PDR

NOTICE

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, or any of their employees, makes any warranty, expressed or implied, or assumes any legal liability of responsibility for any third party's use, or the results of such use, of any information, apparatus, product or process disclosed in this report, or represents that its use by such third party would not infringe privately owned rights.

NOTICE

Availability of Reference Materials Cited in NRC Publications

Most documents cited in NRC publications will be available from one of the following sources:

1. The NRC Public Document Room, 1717 H Street, N.W.
Washington, DC 20555
2. The Superintendent of Documents, U.S. Government Printing Office, Post Office Box 37082,
Washington, DC 20013-7082
3. The National Technical Information Service, Springfield, VA 22161

Although the listing that follows represents the majority of documents cited in NRC publications, it is not intended to be exhaustive.

Referenced documents available for inspection and copying for a fee from the NRC Public Document Room include NRC correspondence and internal NRC memoranda; NRC Office of Inspection and Enforcement bulletins, circulars, information notices, inspection and investigation notices; Licensee Event Reports; vendor reports and correspondence; Commission papers; and applicant and licensee documents and correspondence.

The following documents in the NUREG series are available for purchase from the GPO Sales Program: formal NRC staff and contractor reports, NRC-sponsored conference proceedings, and NRC booklets and brochures. Also available are Regulatory Guides, NRC regulations in the *Code of Federal Regulations*, and *Nuclear Regulatory Commission Issuances*.

Documents available from the National Technical Information Service include NUREG series reports and technical reports prepared by other federal agencies and reports prepared by the Atomic Energy Commission, forerunner agency to the Nuclear Regulatory Commission.

Documents available from public and special technical libraries include all open literature items, such as books, journal and periodical articles, and transactions. *Federal Register* notices, federal and state legislation, and congressional reports can usually be obtained from these libraries.

Documents such as theses, dissertations, foreign reports and translations, and non-NRC conference proceedings are available for purchase from the organization sponsoring the publication cited.

Single copies of NRC draft reports are available free, to the extent of supply, upon written request to the Division of Technical Information and Document Control, U.S. Nuclear Regulatory Commission, Washington, DC 20555.

Copies of industry codes and standards used in a substantive manner in the NRC regulatory process are maintained at the NRC Library, 7920 Norfolk Avenue, Bethesda, Maryland, and are available there for reference use by the public. Codes and standards are usually copyrighted and may be purchased from the originating organization or, if they are American National Standards, from the American National Standards Institute, 1430 Broadway, New York, NY 10018.

Evaluation of Nuclear Facility Decommissioning Projects

Summary Status Report
Three Mile Island Unit 2
Reactor Coolant System and Systems Decontamination

Manuscript Completed: February 1986
Date Published: May 1986

Prepared by
D. H. Doerge, R. L. Miller, K. S. Scotti

UNC Nuclear Industries
Richland, WA 99352

Prepared for
Division of Engineering Technology
Office of Nuclear Regulatory Research
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555
NRC FIN B7568

ABSTRACT

This document summarizes information relating to the decontamination and restoration of the Three Mile Island Unit 2 reactor coolant system and other plant systems.

Data have been collected from activity reports, reactor containment entry records, and other sources and entered in a computerized data system which permits extraction/manipulation of specific data which can be used in planning for recovery from a loss of coolant event similar to that experienced by the Three Mile Island Unit 2 on March 28, 1979.

This report contains a summary of radiation exposures, manpower, and time spent in radiation areas during the referenced period. Support activities conducted outside of radiation areas are not included.

Computer reports included are:

- A chronological listing of all activities related to decontamination and restoration of the reactor coolant system and other plant systems for the period of April 5, 1979, through December 19, 1984.
- A summary of labor and exposures by department for the same time period.
- Summary reports for each major task undertaken in connection with this specific work scope during the referenced time period.

TABLE OF CONTENTS

	<u>PAGE</u>
1.0 INTRODUCTION	1
2.0 SUMMARY OF LABOR AND EXPOSURES BY DEPARTMENT	3
3.0 DESCRIPTION OF COMPUTER REPORTS	4
3.1 TMI-2 Acronyms and Abbreviations	4
3.2 TMI-2 Notes and Descriptions	4
3.3 Activity Report - TMI-2 Reactor Coolant Systems (RCS) and Systems Decontamination (chronological summary)	6
3.4 Activity Report - TMI-2 RCS and Systems Decontamination - Summaries of Individual Tasks	6
4.0 COMPUTER REPORTS	8
4.1 TMI-2 Acronyms and Abbreviations	8
4.2 TMI-2 Notes and Descriptions	14
4.3 Activity Report - TMI-2 RCS and Systems Decontamination (chronological summary)	17
4.4 Activity Report - TMI-2 RCS and Systems Decontamination - Summaries of Individual Tasks	26

EVALUATION OF NUCLEAR FACILITY DECOMMISSIONING PROJECTS PROGRAM

THREE MILE ISLAND UNIT 2

Reactor Coolant System and Systems Decontamination

1.0 INTRODUCTION

The Three Mile Island Unit 2 (TMI-2) nuclear power station is located near Middletown, Pennsylvania. TMI-2 is a pressurized water reactor rated at 959 MWe. The reactor began commercial operation on December 30, 1978.

On March 28, 1979, TMI-2 experienced a partial loss of coolant water which exposed the upper portion of the reactor. Resulting temperatures in the core region were in excess of 2500F causing considerable damage to the core and possibly to other reactor components.

Contaminated reactor coolant water was released to the reactor building basement and to the auxiliary and fuel handling buildings (Figures 1 and 2). This release resulted in gross contamination requiring extensive decontamination and waste handling operations to restore these buildings. Decontamination and repair activities have required many labor man-hours and man-rems of exposure.

Because of the vast quantity of data generated during decontamination, equipment recovery and waste handling activities, the U. S. Nuclear Regulatory Commission (NRC) requested that the data be assembled, analyzed, and entered into a computer data base for historical purposes. The information also serves as a comprehensive base line for future planning, estimates, and actions required should a nuclear facility be confronted with problems similar to those experienced at TMI-2.

Work within the scope of this report is being conducted under the Evaluation of Nuclear Facility Decommissioning Projects (ENFDP) program. The ENFDP program was originated in 1981 under the auspices of the NRC Office of Nuclear Regulatory Research and is currently administered through the Division of Engineering Technology.

UNC Nuclear Industries (UNC) is responsible for technical direction of the program and for preparation of documentation and summary comparisons of evaluated projects. See NUREG/CR-2522, "Evaluation of Nuclear Facility Decommissioning Projects," for a complete description of the Program Plan.

Under the ENFDP program, data is assembled in a form that permits input into a computerized decommissioning data system (DDS). A proprietary computer software package, MAPPER, provides a method for accumulation and manipulation of decommissioning performance information. MAPPER stands for Maintain, Prepare, and Produce Executive Reports.

THREE MILE ISLAND UNIT 2




Figure 1. Reactor & Auxillary Buildings.




Figure 2. Auxillary & Fuel-Handling Building.

Because of the volume and variety of information being collected at TMI-2, nine categories of ENFDP reports have been established and are as follows:

- Volume 1 - Reactor Coolant System and Systems Decontamination
- Volume 2 - Reactor Building Decontamination
- Volume 3 - Reactor Defueling and Disassembly
- Volume 4 - Auxiliary and Fuel Handling Building Decontamination
- Volume 5 - Common Support Facilities and Systems Operations
- Volume 6 - Plant Stability and Safety Activities
- Volume 7 - Liquid Waste Handling
- Volume 8 - Solid Waste Handling
- Volume 9 - Radioactive Waste and Laundry Shipments

Periodic activity status and summary reports for these nine categories will be published as NUREG/CR-4315 Three Mile Island Unit 2 documents.

This report covers activities relating to decontamination and repair of the Reactor Coolant System (RCS), see Figure 3, and other reactor systems for the period of April 5, 1979 through December 19, 1984.

Data have been collected from activity reports, reactor containment entry records, and other sources. This report contains a summary of radiation exposures, manpower, and time spent in radiation areas, during the period referenced, in chronological order.

Additionally, summary reports for each major task related to decontamination and repair of the RCS and other reactor systems, and a summary of labor and exposures by department (manually assembled) are included.

2.0 SUMMARY OF LABOR AND EXPOSURES BY DEPARTMENT

The following (Table 1) is a manually-assembled summary of labor and exposures by department for the period April 5, 1979 through December 19, 1984.

TABLE 1

	<u>Personnel Entries</u>	<u>Labor Man-Hours</u>	<u>Exposure Man-Rem</u>
AD Unit 2 Administration	2	2.75	0.015
CH Chemistry - Unit 1	6	12.16	0.027
CM Unit 2 - Maintenance (General)	57	111.24	0.021
CN Contractor (all crafts)	342	686.57	6.262
CR Corporate	110	206.36	1.584
DM Unit 2 Decon Maintenance	8	20.66	0.010
EG Engineering Staff - Unit 1	2	5.89	0.011
EL Unit 2 Engineering Staff	12	10.42	0.220
ES Unit 2 Engineering Staff	9	26.67	0.113
HP Health Physics (Rad Engineering)	109	246.52	2.155
IC Unit 2 Instrument and Control	30	72.18	0.046
ME Mechanical Maintenance - Unit 1	2	1.40	0.060
MM Unit 2 Mechanical Maintenance	110	256.99	1.200
OP Unit 2 Site Operations	175	678.07	1.607
OS Operations - Unit 1	1	1.08	0.020
QA Quality Assurance	10	13.13	0.068
RP Unit 2 Recovery Programs	8	38.80	0.078
RW Rad Waste - Unit 1	1	3.67	0.008
UM Unit 2 Utilities Maintenance	80	157.97	1.210
VI Visitor	1	DNA*	0.025
TOTAL RCS AND SYSTEMS DECON	<u>1,075</u>	<u>2,552.53</u>	<u>14.740</u>

* Data Not Available - RWP hours were not recorded in 1979.

3.0 DESCRIPTION OF COMPUTER REPORTS

The computer reports included in this document are:

3.1 Activity Report TMI-2 Acronyms and Abbreviations

This is a general report master listing of acronyms and abbreviations used in TMI-2 reports. All acronyms and abbreviations shown in this general report may not necessarily appear in this document but may be contained in the other volumes of NUREG/CR-4315, THREE MILE ISLAND UNIT 2.

3.2 Activity Report - TMI-2 Notes and Descriptions

This report describes the data for each column listing in these activity reports. It also includes a separate department code abbreviation listing which does not appear in the master TMI-2 acronyms and abbreviations report.

TMI-2 Reactor Coolant System




Figure 3.

3.0 DESCRIPTION OF COMPUTER REPORTS

3.3 Activity Report - TMI-2 Reactor Coolant System and Systems Decontamination

This report is a chronological summary of data on manpower, radiation exposure, and labor man-hours spent in radiation areas during decontamination of the reactor coolant system and other systems. Each line of this report represents a task performed, man-hours spent, and radiation exposure received by various department personnel during performance of that task.

3.4 Activity Reports - TMI-2 Reactor Coolant System and Systems Decontamination - Summaries of Individual Tasks

Eight separate areas of activity are summarized for the period of April 5, 1979 through December 19, 1984. Those activities were:

- | | |
|------------------------|--|
| o RCS DECONTAMINATION | Reactor Coolant System Decontamination |
| o AFHB SYS & TKS DECON | Auxiliary and Fuel Handling Building Systems and Tanks Decontamination |
| o RCBT B&C DECON | Reactor Coolant Bleed Tank B&C Decontamination |
| o RCBT A DECON | Reactor Coolant Bleed Tank A Decontamination |
| o MAKEUP FILTERS DECON | Makeup Filters Decontamination |
| o PWST DECON | Process Water Storage Tank Decontamination |
| o OTSG B DECON | Once Through Steam Generator B Decontamination |
| o SYS & TKS RX DECON | Reactor System and Tanks Decontamination |

Table 2 compiles these eight individual summary reports and, again, presents the total exposure and man-hours expended on tasks during the period covered by this report.

TABLE 2

SUMMARY OF LABOR AND EXPOSURES BY TASK
 April 5, 1979 through December 19, 1984

<u>Task Description</u>	<u>Labor (Man-Hours)</u>	<u>Exposure (Man-Rem)</u>
RCS Decon	353.93	1.960
AFHB SYS & TKS Decon	295.69	3.518
RCBT B&C Decon	129.19	.806
RCBT A Decon	302.84	2.452
Makeup Filters Decon	378.16	3.539
PWST Decon	147.35	.076
OTSG B Decon	865.91	2.046
SYS & TKS RX Decon	<u>59.46</u>	<u>.343</u>
TOTALS	<u>2,552.53</u>	<u>14.740</u>

4.0 COMPUTER REPORTS

4.1 TMI-2 Acronyms and Abbreviations

PNO 1
 TMI-2 UNC: DDS - ACRONYMS AND ABBREVIATIONS FOR TMI-2 REPORTS M H3036

* T.FLD.
 * ACRONYM MOD. P. NUM. DESCRIPTION
 *-----

*THIS REPORT IS A WORKING DOCUMENT AND WILL BE UPDATED PERIODICALLY.
 *(SOME ABBREVIATIONS FOUND IN DATA HAVE NOT BEEN IDENTIFIED TO DATE. THESE
 *ABBREVIATIONS OR ACRONYMS WILL BE IDENTIFIED AND INCLUDED IN SUBSEQUENT
 *REPORTS)

ACC	ACCESS
ACOUS	ACOUSTIC OR ACOUSTICAL
ACQ	ACQUISITION
ACQUI	ACQUISITION
ADPTR	ADAPTER
AFHB	AUXILIARY AND FUEL HANDLING BUILDING
AH	AIR HANDLING
AHE	AIR HANDLING EQUIPMENT
AHVG	AIR HANDLING VALVE 'G'
AH-C	AIR HANDLING VALVE 'C'
ALC	AUXILIARY LIQUID CLEANUP (EPICOR 2)
ANN	ANNULUS
APSR	AXIAL POWER SHAPING ROD
ARLK	AIRLOCK
AUX	AUXILIARY (BUILDING)
BLK	BLOCK
BTL(S)	BOTTLE(S)
BWST	BORATED WATER STORAGE TANK
B&W	BABCOCK & WILCOX
CAT	CHEMICAL ADDITION TANK
CCB	CHEMICAL CLEANING BUILDING
CCTB	CHEMICAL CLEANING TANK 'B'
CCTV	CLOSED CIRCUIT TELEVISION
CDT	CONDENSATE DRAIN TANK
CFT	CORE FLOOD TANK
CHEM ADD	CHEMICAL ADDITION
CHK	CHECK
CLR(S)	COOLER(S)
CNTRL	CONTROL
COL	COLUMN
CONC	CONCENTRATED
COND	CONDENSER OR CONDENSATE
CONN	CONNECT OR CONNECTOR
CONST	CONSTRUCT OR CONSTRUCTION
CONT	CONTAMINATED
CONTR	CONTRACTOR
CORR	CORRIDOR
CGUP	COUPLE OR COUPLING
COV	COVERAGE
CRD	CONTROL ROD DRIVE
CRDM	CONTROL ROD DRIVE MECHANISM
CTMT	CONTAINMENT
CU	CLEAN UP

PNO 2
 TMI-2 UNC: DDS - ACRONYMS AND ABBREVIATIONS FOR TMI-2 REPORTS M H3036

* ACRONYM	MOD. P. NUM.	T. FLD.	DESCRIPTION
CWST			CONTAMINATED WASTE STORAGE TANK
CWT			CONTAMINATED WASTE TANK
DEBOR			DEBORATED OR DEBORATING
DECCN			DECONTAMINATION
DEMIN			DEMINERALIZER
DH			DECAY HEAT
DHV			DECAY HEAT VAULT
DISCON			DISCONNECT
DP			DIFFERENTIAL PRESSURE
DSMNTL			DISMANTLE
DWCS			DEFUELING WATER CLEANUP SYSTEM
EFF			EFFLUENT
EL			ELECTRICAL OR ELEVATION
ELEC			ELECTRIC OR ELECTRICAL
ELEVTR			ELEVATOR
ELEV(S)			ELEVATION(S)
EQUIP			EQUIPMENT
EVAP			EVAPORATOR
EXP			EXPERIMENT
FAC			FACILITY
FHB			FUEL HANDLING BUILDING
FILT			FILTER
FLNGE			FLANGE
FLT			FILTER
FSV			FIRE SERVICE VALVE
FTC			FUEL TRANSFER CANAL
FTS			FUEL TRANSFER SYSTEM
FUNCT			FUNCTION OR FUNCTIONAL
GEN			GENERAL
GLVBX			GLOVEBOX
HDR			HEADER
HEPA			HIGH EFFICIENCY PARTICULATE AIR
HI LEV			HIGH LEVEL (WASTE)
HP			HEALTH PHYSICS (RADIOLOGICAL ENGINEERING)
HPR			HEALTH PHYSICS IN-LINE MONITOR
HRF-6B			HIGH RAD FILTER GLOVEBOX
HSEKPG			HOUSEKEEPING
HVAC			HEAT VENTILATION, AIR CONDITIONING
H-2			HYDROGEN
ICC			INTERMEDIATE CLOSED COOLING WATER SYSTEM
IIF			INTERNALS INDEXING FIXTURE
INF			INFLUENT
INJ			INJECTION
INSP			INSPECT OR INSPECTION
INST			INSTRUMENT OR INSTRUMENTATION
INSTL			INSTALL OR INSTALLATION
INTERMED			INTERMEDIATE
LAB			LABORATORY
LD			LEAD
LL			LOW LEVEL (WASTE)

PNO 3
 TMI-2 UNC: DDS - ACRONYMS AND ABBREVIATIONS FOR TMI-2 REPORTS M H3036

* ACRONYM	MOD. P. NUM.	T. FLD.	DESCRIPTION
LN(S)			LINE(S)
LOCA			LOSS OF COOLANT ACCIDENT
LP			LOW PRESSURE
MAG			MAGNETIC
MAINT			MAINTAIN OR MAINTENANCE
MATL			MATERIAL
MB			
MC			MOTOR CONTROL
MC CTR			MOTOR CONTROL CENTER
MDH			MINI-DECAY HEAT
MDHR			MINI DECAY HEAT REMOVAL SYSTEM
MEAS			MEASURE OR MEASUREMENT
MISC			MISCELLANEOUS
MONIT(S)			MONITOR(S)
MOV			MOTOR OPERATED VALVE
MT			EMPTY
MU			MAKE UP
MUF			MAKE UP FILTER
MUP			MAKE UP PUMP
MUV			MAKE UP VALVE
MW			MISCELLANEOUS WASTE
MWHT			MISCELLANEOUS WASTE HOLDUP TANK
MWT			MISCELLANEOUS WASTE TANK
NEUT			NEUTRON
NI			NUCLEAR INSTRUMENT OR INSTRUMENTATION
NLB			MANUFACTURER'S NAME FOR HYDROLASER PUMP
NM			NITROGEN MANIFOLD
NOZZ			NOZZLE
NRC			U. S. NUCLEAR REGULATORY COMMISSION
NS			NUCLEAR SERVICE
NUC			NUCLEAR
NUC INST			NUCLEAR INSTRUMENTATION
N-2			NITROGEN
OPER			OPERATION
OPS			OPERATIONS
OTSG			ONCE THROUGH STEAM GENERATOR
PACK			PACKAGE
PC OR P.C.			POLAR CRANE
PENET			PENETRATION
PERS			PERSON(S) OR PERSONNEL
PHOTO			PHOTOGRAPH OR PHOTOGRAPHIC
PKG			PACKAGE
PM OR P.M.			PREVENTATIVE MAINTENANCE
PMP			PUMP
PORV			PRESSURE OPERATED RELIEF VALVE
PREP			PREPARATION
PROT			PROTECTION
PWST			PROCESS WATER STORAGE TANK
PZR			PRESSURIZER
RAD			RADIATION, RADIOACTIVE, RADIOLOGICAL

PNO 4
 TMI-2 UNC: DDS - ACRONYMS AND ABBREVIATIONS FOR TMI-2 REPORTS M H3036

* ACRONYM	MOD. P. NUM.	T. FLD.	DESCRIPTION
RAP			REACTOR BUILDING
RB			RECLAIMED BORIC ACID PUMP ROOM
RBA			RECLAIMED BORIC ACID TANK
RC			REACTOR COOLANT
RCBT			REACTOR COOLANT BLEED TANK
RCDT			REACTOR COOLANT DRAIN TANK
RCF			REACTOR COOLANT SYSTEM
RCS			RECIRCULATE OR RECIRCULATION
RECIRC			RECOMBINER
RECOMB			RELOCATE
RELOC			RESIN
RES			RETURN
RET			REMOVE
RMVE			ROOM(S)
RM(S)			RADIATION DETECTION INSTRUMENT
RO-2A			REACTOR VESSEL
RV			REACTOR VESSEL HEAD SERVICE STRUCTURE
RVHSS			RADIATION WORK PERMIT
RWP			COMMUNICATIONS SYSTEM
SAM			SAMPLE
SAMP			SCAFFOLD
SCAF			SUBMERGED DEMINERALIZER SYSTEM
SDS			SECTION
SECT			SERVICE
SERV			SPENT FUEL
SF			SPENT FUEL COOLER
SFC			SPENT FUEL FILTER
SFF			SPENT FUEL POOL
SFP			
SFV			
SHLD(G)			SHIELD OR SHIELDING
SPC			STANDBY PRESSURE CONTROL
SPEC			SPECIAL OR SPECIFICATION
SPEC(T)			SPECTRA, SPECTRUM, OR SPECTROMETER
SSTR			
STAB			STABILIZE OR STABILITY
SUPP			SUPPORT
SURV			SURVEY
SWS-P			PUMP IN SPENT FUEL POOL (REMOVED)
SYS			SYSTEM
TEMP			TEMPORARY
TER			TERMINATE OR TERMINAL
THRU			THROUGH
TK(S)			TANK(S)
TLD			THERMOLUMINESCENT DOSIMETER
TRO			
TURB			TURBINE (BUILDING)
TV			TELEVISION
UCI			MICROCURIE

```
PN0      5
TMI-2    UNC: DDS - ACRONYMS AND ABBREVIATIONS FOR TMI-2 REPORTS M H3036
*        T FLD
* ACRONYM MOD P NUM      DESCRIPTION
*-----*-----*-----*-----*
V        VALVE (USED IN CONJUNCTION WITH A NUMBER OR LETTER)
VAC      VACUUM
VLV      VALVE
WDG      WASTE DISPOSAL-GASEOUS
WDL      WASTE DISPOSAL-LIQUID
WDS      WASTE DISPOSAL-SOLID
XFR      TRANSFER
XPORT    TRANSPORT
        ..... END REPORT .....
```

4.0 COMPUTER REPORTS

4.2 TMI-2 Notes and Descriptions

PNO 1
 TMI-2 UNC: DDS - ACTIVITY REPORT - TMI-2 NOTES AND DESCRIPTIONS M 286 D
 * RWP RWP EXP TRCK PERS DEPT EXPOS RWP
 * DATE NUMBER NUMBER ACTIVITY ENTRNG CODE REM HOURS TASK DESCRIPTION
 *-----

*DATA IN THIS REPORT ARE COMPLETE THROUGH MARCH 31, 1985. SUBSEQUENT DATA
 *WILL BE ANALYZED AND ADDED PERIODICALLY.

*NOTES:

*1. DESCRIPTION OF DATA IN EACH COLUMN:

* RWP DATE - THE DATE OF ISSUE OF THE RADIATION WORK PERMIT. THE
 * PERMIT MAY COVER A SINGLE ENTRY OR MAY COVER ENTRIES
 * OVER A PERIOD OF TIME OF UP TO ONE WEEKS DURATION.
 * RWP NUMBER - RADIATION WORK PERMIT IDENTIFICATION NUMBER.
 * EXP TRCK NUMBER-EXPOSURE TRACKING NUMBER - AN IDENTIFICATION NUMBER
 * ASSIGNED TO A SPECIFIC ACTIVITY.
 * ACTIVITY - DESCRIPTION OF AN ACTIVITY OR THE LOCATION OF A
 * TASK WITHIN AN ACTIVITY.
 * PERS ENTRG - NUMBER OF PERSONNEL ENTERING A RADIATION AREA OR
 * PERFORMING WORK WHICH IS COVERED BY AN RWP
 * DEPT CODE - A PERSONNEL ACCOUNTING CODE FOR FUNCTIONAL
 * DEPARTMENT IDENTIFICATION. (SEE NOTE 2)
 * EXPOS REM - ACTUAL RADIATION EXPOSURE. IN REM, RECORDED ON TLDS
 * WORN BY EMPLOYEES DURING PERFORMANCE OF A TASK WHICH
 * IS COVERED BY AN RWP. AN EMPLOYEE MAY WORK ON AN RWP
 * COVERED TASK FOR SEVERAL HOURS AND RECEIVE NG MEASUR-
 * ABLE RADIATION EXPOSURE.
 * RWP HOURS - TIME SPENT ON A TASK INCLUDING JOB PREPARATION, DRESS-
 * UNDRESS, ETC. RECORD WAS INITIATED IN NOVEMBER, 1979.

* TASK DESCRIPTION - SELF EXPLANATORY

*2. DEPARTMENT CODE ABBREVIATIONS:

* D - UNIT-2 ADMINISTRATION
 * AM - ADMINISTRATION - UNIT 1
 * BS - UNIT-2 BUILDING SERVICES
 * CH - CHEMISTRY-UNIT 1
 * CM - UNIT-2 PLANT OPERATIONS MAINTENANCE - GENERAL
 * CN - CONTRACTOR (ALL CRAFTS)
 * CR - CORPORATE
 * DM - UNIT-2 DECON MAINTENANCE (REPLACED BY RECOVERY PROGRAM-RP)
 * EC - ELECTRICAL MAINTENANCE - UNIT 1
 * EG - ENGINEERING STAFF-UNIT 1

4.0 COMPUTER REPORTS

4.3 TMI-2 RCS and Systems Decontamination -
Chronological Summary of Activities From
April 5, 1979 through December 19, 1984

PNO 1		TMT-2		UNC DDS - ACTIVITY REPORT - RCS & SYSTEMS DECONTAMINATION M 2860							
* RWP	RWP	EXP	TRCK	PERS	DEPT	EXPOS	RWP	TASK DESCRIPTION			
* DATE	NUMBER	NUMBER	ACTIVITY	ENTRG	CODE	REM	HOURS				
*790405	022221	E30C001	AFHB SYS & TKS DECON	4	CN	0.055	0.00	RECOMBINER COVERAGE			
*790405	022221	E30C001	AFHB SYS & TKS DECON	1	VI	0.025	0.00	RECOMBINER COVERAGE			
790409	022156	E30C001	AFHB SYS & TKS DECON	2	EL	0.016	0.00	MOVE CABLE TO RECOMBINER			
790409	022143	E30J001	SYS & TKS RX DECON	8	CN	0.060	0.00	TRANSFER RACKS FROM A TO B POOL			
*790409	022143	E30J001	SYS & TKS RX DECON	1	MM	0.000	0.00	TRANSFER RACKS FROM A TO B POOL			
790410	022128	E30J001	SYS & TKS RX DECON	10	CN	0.167	0.00	TRANSFER RACKS FROM A TO B POOL			
*790410	022128	E30J001	SYS & TKS RX DECON	1	OP	0.030	0.00	TRANSFER RACKS FROM A TO B POOL			
*790410	022128	E30J001	SYS & TKS RX DECON	3	MM	0.020	0.00	TRANSFER RACKS FROM A TO B POOL			
790413	021263	E30C001	AFHB SYS & TKS DECON	3	EL	0.180	0.00	CHECK POWER CABLE FOR RECOMBINER			
790615	026748	E30D056	RCBT B&C DECON	4	CN	0.030	0.00	MOVE RECOMB-FUEL POOL TO INTERMED BLDG			
800123	080487	E30C001	AFHB SYS & TKS DECON	1	CN	0.020	1.58	INSTALL TENT AROUND RECOMBINER			
*800123	080487	E30C001	AFHB SYS & TKS DECON	2	CR	0.040	2.00	INSTALL TENT AROUND RECOMBINER			
800124	080502	E30C001	AFHB SYS & TKS DECON	1	CR	0.070	2.08	INSTALL TENT AROUND RECOMBINER			
800124	080517	E30C001	AFHB SYS & TKS DECON	1	CN	0.005	1.75	DECON H-2 RECOMBINER PAD			
*800124	080517	E30C001	AFHB SYS & TKS DECON	1	CR	0.005	1.33	DECON H-2 RECOMBINER PAD			
800125	080546	E30C001	AFHB SYS & TKS DECON	1	CN	0.000	1.00	DECON H-2 RECOMBINER PAD			
*800125	080546	E30C001	AFHB SYS & TKS DECON	1	CR	0.005	1.80	DECON H-2 RECOMBINER PAD			
800125	080547	E30C001	AFHB SYS & TKS DECON	1	CR	0.000	1.00	INSTALL TENT AROUND RECOMBINER			
800128	080621	E30C001	AFHB SYS & TKS DECON	2	CN	0.180	1.75	DECON SPILL INSIDE RECOMBINER TENT			
*800128	080621	E30C001	AFHB SYS & TKS DECON	1	CR	0.105	0.08	DECON SPILL INSIDE RECOMBINER TENT			
800324	081801	E30C001	AFHB SYS & TKS DECON	1	CN	0.020	1.10	DECON H-2 RECOMBINER			
*800324	081801	E30C001	AFHB SYS & TKS DECON	1	CR	0.018	1.05	DECON H-2 RECOMBINER			
*800324	081801	E30C001	AFHB SYS & TKS DECON	1	UM	0.028	0.76	DECON H-2 RECOMBINER			
800325	081829	E30C001	AFHB SYS & TKS DECON	1	CN	0.020	1.33	DECON H-2 RECOMBINER			
*800325	081829	E30C001	AFHB SYS & TKS DECON	2	CR	0.048	1.92	DECON H-2 RECOMBINER			
800327	081881	E30C001	AFHB SYS & TKS DECON	3	CN	0.038	1.95	XFER RECOMB BLOWER FROM TENT/DECON TENT			
*800327	081881	E30C001	AFHB SYS & TKS DECON	1	CR	0.020	0.93	XFER RECOMB BLOWER FROM TENT/DECON TENT			
*800327	081881	E30C001	AFHB SYS & TKS DECON	1	UM	0.020	0.93	XFER RECOMB BLOWER FROM TENT/DECON TENT			
800414	082291	E30D40A	MAKEUP FILTERS DECON	1	CN	0.010	1.33	STAGE AREA TO PULL FILTERS 2A, 2B, 5A, 5B			
*800414	082291	E30D40A	MAKEUP FILTERS DECON	4	CR	0.040	4.33	STAGE AREA TO PULL FILTERS 2A, 2B, 5A, 5B			
800415	082301	E30D40A	MAKEUP FILTERS DECON	3	CN	0.055	3.67	REMOVE MAKEUP FILTERS 2A & 5A			
*800415	082301	E30D40A	MAKEUP FILTERS DECON	2	CR	0.025	1.50	REMOVE MAKEUP FILTERS 2A & 5A			
800415	082302	E30D40A	MAKEUP FILTERS DECON	4	CN	0.075	5.13	MOVE FLTR TRANSPORT SHIELD TO SHLD CASK			
*800415	082302	E30D40A	MAKEUP FILTERS DECON	2	CR	0.010	1.67	MOVE FLTR TRANSPORT SHIELD TO SHLD CASK			
*800415	082302	E30D40A	MAKEUP FILTERS DECON	1	UM	0.000	1.00	MOVE FLTR TRANSPORT SHIELD TO SHLD CASK			
800501	082716	E30D40A	MAKEUP FILTERS DECON	5	CN	0.040	4.92	ASSESS SOLIDS ON MUF-5A FILTER HOUSING			
*800501	082716	E30D40A	MAKEUP FILTERS DECON	2	CR	0.020	2.00	ASSESS SOLIDS ON MUF-5A FILTER HOUSING			
800514	083020	E30C001	AFHB SYS & TKS DECON	1	CN	0.005	0.57	STAGE FOR FLUSH OF RECOMBINER FILL SYS			
800516	083083	E30C001	AFHB SYS & TKS DECON	4	CN	0.015	10.00	FLUSH RECOMBINER/CHANGE FILTERS			
*800516	083083	E30C001	AFHB SYS & TKS DECON	3	CR	0.010	9.00	FLUSH RECOMBINER/CHANGE FILTERS			
800520	083137	E30C001	AFHB SYS & TKS DECON	2	CN	0.040	0.00	DRAIN & REFILL RECOMBINER			
800522	083206	E30C001	AFHB SYS & TKS DECON	2	CN	0.020	5.67	FLUSH RECOMBINER TO DRAIN			
800528	083282	E30C001	AFHB SYS & TKS DECON	1	CN	0.000	3.25	DECON RECOMBINER INTERNALS & FLUSH			
800530	083358	E30C001	AFHB SYS & TKS DECON	2	CN	0.005	2.00	FLUSH RECOMBINER/CHANGE FILTER			
800626	083903	E30C001	AFHB SYS & TKS DECON	1	CN	0.005	1.33	DECON RECOMBINER TENT			
*800626	083903	E30C001	AFHB SYS & TKS DECON	1	CR	0.000	1.33	DECON RECOMBINER TENT			
800703	084022	E30C001	AFHB SYS & TKS DECON	1	CN	0.005	5.75	DECON RECOMBINER TENT			
*800703	084022	E30C001	AFHB SYS & TKS DECON	2	CR	0.010	5.67	DECON RECOMBINER TENT			
800726	084321	E30C001	AFHB SYS & TKS DECON	1	CN	0.000	0.42	CHG FLTRS/DECON HOT SPOTS IN RECOMB TENT			
*800726	084321	E30C001	AFHB SYS & TKS DECON	1	CR	0.000	0.42	CHG FLTRS/DECON HOT SPOTS IN RECOMB TENT			

PNO 2		UNC: DDS - ACTIVITY REPORT - RCS & SYSTEMS DECONTAMINATION M 286D									
* RWP	RWP	EXP	TRCK	PERS		DEPT	EXPOS	RWP			
* DATE	NUMBER	NUMBER	NUMBER	ENTRG	CODE	REM	HOURS	TASK DESCRIPTION			
*800728	084326	E30C001	AFHB SYS & TKS DECON	3	CR	0.002	4.68	FLUSH RECOMBINER COILS			
*800728	084326	E30C001	AFHB SYS & TKS DECON	1	EL	0.005	3.17	FLUSH RECOMBINER COILS			
800728	084350	E30C001	AFHB SYS & TKS DECON	3	CN	0.000	4.33	DECON RECOMBINER TENT/BAG JOINTS			
800828	089308	E30C001	AFHB SYS & TKS DECON	3	CN	0.000	16.25	FLUSH RECOMBINER			
*800828	089308	E30C001	AFHB SYS & TKS DECON	6	CR	0.015	23.17	FLUSH RECOMBINER			
800904	089335	E30C001	AFHB SYS & TKS DECON	1	CN	0.000	2.50	FLUSH RECOMBINER			
*800904	089335	E30C001	AFHB SYS & TKS DECON	1	CR	0.000	2.50	FLUSH RECOMBINER			
800909	084933	E30D40A	MAKEUP FILTERS DECON	3	CN	0.015	1.83	DRY RUN TRAINING FOR FILTER CHANGE			
800910	084951	E30C001	AFHB SYS & TKS DECON	4	CN	0.015	11.66	ADD WATER TO RECOMBINER & FLUSH			
*800910	084951	E30C001	AFHB SYS & TKS DECON	6	CR	0.002	14.17	ADD WATER TO RECOMBINER & FLUSH			
800910	084944	E30D40A	MAKEUP FILTERS DECON	9	CN	0.093	10.26	TRAINING FOR MUF CHANGE/STAGE FOR CHANGE			
*800910	084944	E30D40A	MAKEUP FILTERS DECON	1	EL	0.005	1.33	TRAINING FOR MUF CHANGE/STAGE FOR CHANGE			
*800910	084944	E30D40A	MAKEUP FILTERS DECON	1	HP	0.008	1.08	TRAINING FOR MUF CHANGE/STAGE FOR CHANGE			
*800910	084944	E30D40A	MAKEUP FILTERS DECON	3	CR	0.030	3.50	TRAINING FOR MUF CHANGE/STAGE FOR CHANGE			
800911	084954	E30D40A	MAKEUP FILTERS DECON	3	CN	0.085	3.17	REMOVE MU FILTERS 2A, 2B, 5B			
*800911	084954	E30D40A	MAKEUP FILTERS DECON	3	CR	0.080	3.17	REMOVE MU FILTERS 2A, 2B, 5B			
800912	084971	E30D40A	MAKEUP FILTERS DECON	1	HP	0.010	1.08	REMOVE MU FILTERS 2A, 2B, 5B			
*800912	084971	E30D40A	MAKEUP FILTERS DECON	3	CN	0.025	2.58	REMOVE MU FILTERS 2A, 2B, 5B			
*800912	084971	E30D40A	MAKEUP FILTERS DECON	3	CR	0.030	2.17	REMOVE MU FILTERS 2A, 2B, 5B			
*800912	084971	E30D40A	MAKEUP FILTERS DECON	1	HP	0.020	0.92	REMOVE MU FILTERS 2A, 2B, 5B			
801010	085263	E30D40A	MAKEUP FILTERS DECON	5	CN	0.083	7.50	HYDROTEST MDH FLTR/INSTL TUBING VALVES			
*801010	085263	E30D40A	MAKEUP FILTERS DECON	1	CR	0.010	1.17	HYDROTEST MDH FLTR/INSTL TUBING VALVES			
801021	085366	E30D40A	MAKEUP FILTERS DECON	2	CN	0.020	1.67	HYDRO TEST FILTER CASK SECT. OF MDH SYS.			
801030	085467	E30C001	AFHB SYS & TKS DECON	3	CN	0.000	6.70	STAND RECOMBINER UPRIGHT			
801031	085479	E30C001	AFHB SYS & TKS DECON	2	CR	0.000	2.00	DRAIN RECOMBINER			
801106	085519	E30C001	AFHB SYS & TKS DECON	2	CR	0.020	4.00	DECON RECOMBINER & GENERAL AREA			
801129	085715	E30C001	AFHB SYS & TKS DECON	1	CN	0.003	1.58	REPLACE FILTER WDG-F-1			
*801129	085715	E30C001	AFHB SYS & TKS DECON	1	OP	0.000	0.67	REPLACE FILTER WDG-F-1			
*801129	085715	E30C001	AFHB SYS & TKS DECON	1	MM	0.005	1.33	REPLACE FILTER WDG-F-1			
*801129	085715	E30C001	AFHB SYS & TKS DECON	2	UM	0.015	2.67	REPLACE FILTER WDG-F-1			
801204	085768	E30J001	SYS & TKS RX DECON	7	CN	0.113	34.00	MOVE RECOMBINER TO RECEIVING DOCK			
801205	085776	E30J001	SYS & TKS RX DECON	4	CN	0.013	24.08	MOVE RECOMBINER TO RECEIVING DOCK			
801217	085939	E30A001	RCS DECONTAMINATION	2	CN	0.010	2.33	RCS SAMPLE/RESIN COL TEST WITH ZEOLITE			
*801217	085939	E30A001	RCS DECONTAMINATION	1	CR	0.005	1.17	RCS SAMPLE/RESIN COL TEST WITH ZEOLITE			
801218	085948	E30A001	RCS DECONTAMINATION	1	CN	0.005	0.50	RESIN COLUMN TEST WITH RCS & ZEOLITE			
*801218	085948	E30A001	RCS DECONTAMINATION	1	CR	0.000	0.50	RESIN COLUMN TEST WITH RCS & ZEOLITE			
801219	085960	E30A001	RCS DECONTAMINATION	1	CN	0.005	0.58	RESIN COLUMN TEST WITH RCS & ZEOLITE			
*801219	085960	E30A001	RCS DECONTAMINATION	1	CR	0.000	0.58	RESIN COLUMN TEST WITH RCS & ZEOLITE			
810113	000093	E30D40A	MAKEUP FILTERS DECON	2	CN	0.007	2.08	DECON FTS/MOVE FTS TO MODEL ROOM			
*810113	000093	E30D40A	MAKEUP FILTERS DECON	1	CR	0.010	2.00	DECON FTS/MOVE FTS TO MODEL ROOM			
*810113	000093	E30D40A	MAKEUP FILTERS DECON	1	EL	0.010	2.00	DECON FTS/MOVE FTS TO MODEL ROOM			
810223	000526	E30D056	RCBT B&C DECON	2	OP	0.175	1.00	VALVE LINEUP ON 'B' BLEED TANK			
*810223	000526	E30D056	RCBT B&C DECON	1	HP	0.060	0.50	VALVE LINEUP ON 'B' BLEED TANK			
810225	000558	E30D40A	MAKEUP FILTERS DECON	2	CN	0.015	3.17	MOCK RUN-REMOVAL OF MU FILTERS 2A, 2B, 5B			
*810225	000558	E30D40A	MAKEUP FILTERS DECON	2	CR	0.008	2.33	MOCK RUN-REMOVAL OF MU FILTERS 2A, 2B, 5B			
*810225	000558	E30D40A	MAKEUP FILTERS DECON	12	MM	0.120	17.67	MOCK RUN-REMOVAL OF MU FILTERS 2A, 2B, 5B			
810228	000577	E30D40A	MAKEUP FILTERS DECON	1	CN	0.025	4.32	REMOVE & PKG MU FILTERS 2A, 2B, & 5B			
*810228	000577	E30D40A	MAKEUP FILTERS DECON	1	CR	0.020	4.02	REMOVE & PKG MU FILTERS 2A, 2B, & 5B			
*810228	000577	E30D40A	MAKEUP FILTERS DECON	1	HP	0.015	4.27	REMOVE & PKG MU FILTERS 2A, 2B, & 5B			
*810228	000577	E30D40A	MAKEUP FILTERS DECON	6	MM	0.152	23.29	REMOVE & PKG MU FILTERS 2A, 2B, & 5B			

PNO		3		UNC: DDS - ACTIVITY REPORT - RCS & SYSTEMS DECONTAMINATION M 286D									
* RWP	RWP	EXP	TRCK	PERS		DEPT	EXPOS	RWP				TASK DESCRIPTION	
* DATE	NUMBER	NUMBER	NUMBER	ACTIVITY	ENTRG	CODE	REM	HOURS					
810304	000621	E30D40A		MAKEUP FILTERS DECON	2	CN	0.020	4.00				OBTAIN SAMPLES/GEN CLEANUP/PHOTOGRAPHS	
*810304	000621	E30D40A		MAKEUP FILTERS DECON	1	CR	0.017	2.00				OBTAIN SAMPLES/GEN CLEANUP/PHOTOGRAPHS	
810309	000646	E30D40A		MAKEUP FILTERS DECON	2	CN	0.015	3.00				WET VAC AND GENERAL DECON	
810320	000726	E30D40A		MAKEUP FILTERS DECON	1	CN	0.000	0.33				PREJOB SITING & PHOTOGRAPHS OF MU-F-AA/B	
*810320	000726	E30D40A		MAKEUP FILTERS DECON	1	CR	0.002	0.33				PREJOB SITING & PHOTOGRAPHS OF MU-F-AA/B	
810601	001171	E30D40A		MAKEUP FILTERS DECON	2	CN	0.017	3.92				STAGE AREA FOR FILTER REMOVAL	
*810601	001171	E30D40A		MAKEUP FILTERS DECON	2	CR	0.010	3.75				STAGE AREA FOR FILTER REMOVAL	
*810601	001171	E30D40A		MAKEUP FILTERS DECON	1	AD	0.010	1.75				STAGE AREA FOR FILTER REMOVAL	
*810601	001171	E30D40A		MAKEUP FILTERS DECON	2	UM	0.005	3.75				STAGE AREA FOR FILTER REMOVAL	
810814	001705	E30D056		RCBT B&C DECON	6	MM	0.105	7.42				INSTALL ADAPTERS-WDL V-153A, 153B, 18A	
*810814	001705	E30D056		RCBT B&C DECON	1	CN	0.010	1.25				INSTALL ADAPTERS-WDL V-153A, 153B, 18A	
810817	001728	E30D057		RCBT A DECON	3	CN	0.025	4.17				CONNECT HOSES/PUMP & FLUSH RCBT 'A'	
*810817	001728	E30D057		RCBT A DECON	12	OP	0.134	29.75				CONNECT HOSES/PUMP & FLUSH RCBT 'A'	
810818	001732	E30D056		RCBT B&C DECON	10	CN	0.190	19.90				GAMMA SPEC SURVEY OF TANK SLUDGE	
*810818	001732	E30D056		RCBT B&C DECON	1	CR	0.025	2.75				GAMMA SPEC SURVEY OF TANK SLUDGE	
*810818	001732	E30D056		RCBT B&C DECON	1	QA	0.000	0.33				GAMMA SPEC SURVEY OF TANK SLUDGE	
810818	001734	E30D056		RCBT B&C DECON	1	CN	0.045	1.42				DRAIN SIGHT GLASS TO REDUCE HOT SPOT	
*810818	001734	E30D056		RCBT B&C DECON	1	OP	0.045	2.67				DRAIN SIGHT GLASS TO REDUCE HOT SPOT	
810821	001766	E30D056		RCBT B&C DECON	2	CN	0.025	2.83				DRAIN LOWER LEVEL SIGHT GLASS	
*810821	001766	E30D056		RCBT B&C DECON	1	OP	0.010	2.00				DRAIN LOWER LEVEL SIGHT GLASS	
810822	001772	E30D056		RCBT B&C DECON	1	CN	0.005	1.00				RMVE ADPTR FLNGE/CONN LNS-WDL-V-18A,B,C	
*810822	001772	E30D056		RCBT B&C DECON	1	OP	0.005	1.08				RMVE ADPTR FLNGE/CONN LNS-WDL-V-18A,B,C	
*810822	001772	E30D056		RCBT B&C DECON	2	MM	0.040	2.00				RMVE ADPTR FLNGE/CONN LNS-WDL-V-18A,B,C	
810924	002086	E30D057		RCBT A DECON	1	ME	0.000	0.40				DISCON TEMP SAMP SYS AT WDL-18A,B,C	
*810924	002086	E30D057		RCBT A DECON	3	MM	0.015	3.73				DISCON TEMP SAMP SYS AT WDL-18A,B,C	
810930	002093	E30D057		RCBT A DECON	2	CN	0.013	3.67				FLUSH RCBT 'A'	
*810930	002093	E30D057		RCBT A DECON	5	OP	0.042	22.58				FLUSH RCBT 'A'	
810930	002096	E30D057		RCBT A DECON	1	CN	0.035	1.90				REMOVE TK MANWAY COVER/GASKET & REPLACE	
*810930	002096	E30D057		RCBT A DECON	1	OP	0.020	2.00				REMOVE TK MANWAY COVER/GASKET & REPLACE	
*810930	002096	E30D057		RCBT A DECON	1	HP	0.030	3.00				REMOVE TK MANWAY COVER/GASKET & REPLACE	
*810930	002096	E30D057		RCBT A DECON	1	ME	0.060	1.00				REMOVE TK MANWAY COVER/GASKET & REPLACE	
*810930	002096	E30D057		RCBT A DECON	3	MM	0.100	6.00				REMOVE TK MANWAY COVER/GASKET & REPLACE	
811001	002102	E30D057		RCBT A DECON	2	CN	0.070	2.07				SAMPLE & SURVEY TANK INTERNALS	
*811001	002102	E30D057		RCBT A DECON	1	CR	0.020	0.87				SAMPLE & SURVEY TANK INTERNALS	
*811001	002102	E30D057		RCBT A DECON	1	MM	0.040	1.12				SAMPLE & SURVEY TANK INTERNALS	
811002	002106	E30D057		RCBT A DECON	3	CN	0.090	7.78				VACUUM & FLUSH RCBT 'A'	
*811002	002106	E30D057		RCBT A DECON	4	CR	0.095	11.37				VACUUM & FLUSH RCBT 'A'	
*811002	002106	E30D057		RCBT A DECON	1	ES	0.060	3.35				VACUUM & FLUSH RCBT 'A'	
*811002	002106	E30D057		RCBT A DECON	2	MM	0.070	5.68				VACUUM & FLUSH RCBT 'A'	
*811002	002106	E30D057		RCBT A DECON	2	UM	0.055	5.68				VACUUM & FLUSH RCBT 'A'	
*811002	002106	E30D057		RCBT A DECON	1	OP	0.010	2.33				VACUUM & FLUSH RCBT 'A'	
*811002	002106	E30D057		RCBT A DECON	1	HP	0.040	2.33				VACUUM & FLUSH RCBT 'A'	
811007	002137	E30D057		RCBT A DECON	6	CN	0.105	12.67				SPARGE & FLUSH RCBT 'A'	
*811007	002137	E30D057		RCBT A DECON	11	CR	0.261	24.67				SPARGE & FLUSH RCBT 'A'	
*811007	002137	E30D057		RCBT A DECON	6	MM	0.192	15.83				SPARGE & FLUSH RCBT 'A'	
*811007	002137	E30D057		RCBT A DECON	6	UM	0.037	15.00				SPARGE & FLUSH RCBT 'A'	
*811007	002137	E30D057		RCBT A DECON	4	OP	0.028	8.08				SPARGE & FLUSH RCBT 'A'	
*811007	002137	E30D057		RCBT A DECON	4	HP	0.080	8.58				SPARGE & FLUSH RCBT 'A'	
811010	002153	E30D057		RCBT A DECON	1	CN	0.020	1.50				REPLACE MANWAY COVER & GASKET	
*811010	002153	E30D057		RCBT A DECON	1	OP	0.020	2.50				REPLACE MANWAY COVER & GASKET	

PNO 4		UNC: DDS - ACTIVITY REPORT - RCS & SYSTEMS DECONTAMINATION M 286D									
* RWP	RWP	EXP	TRCK	ACTIVITY	PERS	DEPT	EXPOS	RWP			TASK DESCRIPTION
* DATE	NUMBER	NUMBER			ENTRG	CODE	REM	HOURS			
*811010	002153	E30D057		RCBT A DECON	3	MM	0.075	5.25			REPLACE MANWAY COVER & GASKET
811019	002200	E30D057		RCBT A DECON	1	CN	0.010	2.50			GROSS FLUSH INSIDE OF TK/DECON & DESTAGE
*811019	002200	E30D057		RCBT A DECON	2	CR	0.010	4.75			GROSS FLUSH INSIDE OF TK/DECON & DESTAGE
*811019	002200	E30D057		RCBT A DECON	1	HP	0.010	2.50			GROSS FLUSH INSIDE OF TK/DECON & DESTAGE
*811019	002200	E30D057		RCBT A DECON	2	UM	0.005	4.75			GROSS FLUSH INSIDE OF TK/DECON & DESTAGE
811019	002210	E30D057		RCBT A DECON	2	CN	0.005	1.33			SAMPLE RCBT 'A' AT SANDPIPER PUMP
*811019	002210	E30D057		RCBT A DECON	2	OP	0.000	2.08			SAMPLE RCBT 'A' AT SANDPIPER PUMP
820127	002923	E30E33A		PWST DECON	6	UM	0.010	20.16			REMOVE PLASTIC & SCAFFOLD TENT AT PWST
*820127	002923	E30E33A		PWST DECON	2	HP	0.010	10.00			REMOVE PLASTIC & SCAFFOLD TENT AT PWST
*820127	002923	E30E33A		PWST DECON	1	RW	0.008	3.67			REMOVE PLASTIC & SCAFFOLD TENT AT PWST
*820210	003007	E30D40A		MAKEUP FILTERS DECON	1	MM	0.010	0.75			WEIGH DRUM CONTAINING MU FILTER 2B
*820210	003007	E30D40A		MAKEUP FILTERS DECON	2	UM	0.005	1.50			WEIGH DRUM CONTAINING MU FILTER 2B
*820210	003007	E30D40A		MAKEUP FILTERS DECON	1	HP	0.008	0.83			WEIGH DRUM CONTAINING MU FILTER 2B
820222	003096	E30D40A		MAKEUP FILTERS DECON	1	DM	0.005	1.08			CHK FOR HYDROGEN/SECURE LEAD LINER LID
*820222	003096	E30D40A		MAKEUP FILTERS DECON	1	AD	0.005	1.00			CHK FOR HYDROGEN/SECURE LEAD LINER LID
*820222	003096	E30D40A		MAKEUP FILTERS DECON	1	CR	0.010	1.33			CHK FOR HYDROGEN/SECURE LEAD LINER LID
*820222	003096	E30D40A		MAKEUP FILTERS DECON	1	UM	0.010	1.08			CHK FOR HYDROGEN/SECURE LEAD LINER LID
*820222	003096	E30D40A		MAKEUP FILTERS DECON	1	HP	0.005	1.00			CHK FOR HYDROGEN/SECURE LEAD LINER LID
820226	003399	E30D056		RCBT B&C DECON	1	CM	0.005	1.67			SAMPLE RC BLEED TANK 'C'
*820226	003399	E30D056		RCBT B&C DECON	1	CH	0.000	1.83			SAMPLE RC BLEED TANK 'C'
820317	003313	E30D40A		MAKEUP FILTERS DECON	3	HP	0.015	4.50			RMVE 2B,5A&5B PLUGS/STAGE FOR FLTR PULL
*820317	003313	E30D40A		MAKEUP FILTERS DECON	7	UM	0.020	8.75			RMVE 2B,5A&5B PLUGS/STAGE FOR FLTR PULL
*820317	003313	E30D40A		MAKEUP FILTERS DECON	1	OP	0.000	1.00			RMVE 2B,5A&5B PLUGS/STAGE FOR FLTR PULL
*820317	003313	E30D40A		MAKEUP FILTERS DECON	2	CR	0.000	2.83			RMVE 2B,5A&5B PLUGS/STAGE FOR FLTR PULL
*820317	003313	E30D40A		MAKEUP FILTERS DECON	1	CN	0.000	1.00			RMVE 2B,5A&5B PLUGS/STAGE FOR FLTR PULL
820320	003331	E30D40A		MAKEUP FILTERS DECON	3	CN	0.023	9.00			OBTAIN SPEC MEASUREMENTS FROM MU FILTERS
*820320	003331	E30D40A		MAKEUP FILTERS DECON	1	CR	0.008	3.17			OBTAIN SPEC MEASUREMENTS FROM MU FILTERS
*820320	003331	E30D40A		MAKEUP FILTERS DECON	1	CH	0.007	1.00			OBTAIN SPEC MEASUREMENTS FROM MU FILTERS
820322	003332	E30D40A		MAKEUP FILTERS DECON	1	EG	0.003	0.42			PULL 4A & 4B FILTERS/VACUUM HOUSINGS
*830322	003332	E30D40A		MAKEUP FILTERS DECON	5	HP	0.185	15.50			PULL 4A & 4B FILTERS/VACUUM HOUSINGS
*830322	003332	E30D40A		MAKEUP FILTERS DECON	12	UM	0.372	32.66			PULL 4A & 4B FILTERS/VACUUM HOUSINGS
*830322	003332	E30D40A		MAKEUP FILTERS DECON	2	CR	0.095	6.00			PULL 4A & 4B FILTERS/VACUUM HOUSINGS
*830322	003332	E30D40A		MAKEUP FILTERS DECON	4	CN	0.090	12.17			PULL 4A & 4B FILTERS/VACUUM HOUSINGS
820322	003352	E30D40A		MAKEUP FILTERS DECON	2	OP	0.229	2.25			ISOLATE MU FILTER 4A
*820322	003352	E30D40A		MAKEUP FILTERS DECON	1	HP	0.000	1.08			ISOLATE MU FILTER 4A
*830322	003352	E30D40A		MAKEUP FILTERS DECON	2	CN	0.220	1.92			ISOLATE MU FILTER 4A
820323	003362	E30D057		RCBT A DECON	2	CN	0.020	5.25			FLUSH & SAMPLE RCBT 'A'
*820323	003362	E30D057		RCBT A DECON	1	CH	0.005	2.33			FLUSH & SAMPLE RCBT 'A'
*820323	003362	E30D057		RCBT A DECON	3	OP	0.043	9.33			FLUSH & SAMPLE RCBT 'A'
*820323	003362	E30D057		RCBT A DECON	1	HP	0.010	2.75			FLUSH & SAMPLE RCBT 'A'
820324	003364	E30D40A		MAKEUP FILTERS DECON	5	UM	0.065	8.34			PULL MU FILTERS 2A & 5B
*820324	003364	E30D40A		MAKEUP FILTERS DECON	1	CN	0.010	2.00			PULL MU FILTERS 2A & 5B
*820324	003364	E30D40A		MAKEUP FILTERS DECON	1	CR	0.020	1.58			PULL MU FILTERS 2A & 5B
*820324	003364	E30D40A		MAKEUP FILTERS DECON	1	HP	0.010	2.00			PULL MU FILTERS 2A & 5B
820324	003384	E30D40A		MAKEUP FILTERS DECON	8	UM	0.455	17.91			VAC 2A,2B,5A,5B MUF HOUSINGS AND FLOOR
*820324	003384	E30D40A		MAKEUP FILTERS DECON	4	CR	0.155	9.67			VAC 2A,2B,5A,5B MUF HOUSINGS AND FLOOR
*820324	003384	E30D40A		MAKEUP FILTERS DECON	1	CN	0.050	3.00			VAC 2A,2B,5A,5B MUF HOUSINGS AND FLOOR
*820324	003384	E30D40A		MAKEUP FILTERS DECON	2	HP	0.100	5.17			VAC 2A,2B,5A,5B MUF HOUSINGS AND FLOOR
820328	003405	E30D057		RCBT A DECON	1	CN	0.030	3.67			RECIRC RCBT 'A'/SAMP & DISCONNECT HOSES
*820328	003405	E30D057		RCBT A DECON	1	OP	0.022	4.08			RECIRC RCBT 'A'/SAMP & DISCONNECT HOSES

PN0	5					UNC: DDS - ACTIVITY REPORT - RCS & SYSTEMS DECONTAMINATION M 286D				
* RWP	RWP	UNC	DDS	ACTIVITY	PERS	DEPT	EXPOS	RWP		
* DATE	NUMBER	NUMBER	EXP TRCK	ACTIVITY	ENTRG	CODE	REM	HOURS	TASK DESCRIPTION	
820329	003409	E30D056		RCBT B&C DECON	1	CN	0.010	3.33	SAMPLE & ANALYZE RCS & RCBT 'C'	
*820329	003409	E30D056		RCBT B&C DECON	1	CH	0.005	3.33	SAMPLE & ANALYZE RCS & RCBT 'C'	
820331	003453	E30D056		RCBT B&C DECON	1	CN	0.005	1.33	SAMPLE RCBT 'C'	
*820331	003453	E30D056		RCBT B&C DECON	1	CH	0.000	1.17	SAMPLE RCBT 'C'	
*820331	003453	E30D056		RCBT B&C DECON	1	HP	0.005	1.33	SAMPLE RCBT 'C'	
820331	003434	E30D057		RCBT A DECON	1	CN	0.965	3.42	REMOVE DRUMS FROM RCBT 'A' / PUMP TO CWT	
*820331	003434	E30D057		RCBT A DECON	4	CR	0.110	10.00	REMOVE DRUMS FROM RCBT 'A' / PUMP TO CWT	
*820331	003434	E30D057		RCBT A DECON	1	MM	0.020	1.00	REMOVE DRUMS FROM RCBT 'A' / PUMP TO CWT	
*820331	003434	E30D057		RCBT A DECON	2	UM	0.055	5.50	REMOVE DRUMS FROM RCBT 'A' / PUMP TO CWT	
*820331	003434	E30D057		RCBT A DECON	1	HP	0.025	2.67	REMOVE DRUMS FROM RCBT 'A' / PUMP TO CWT	
820408	003514	E30A001		RCS DECONTAMINATION	2	CN	0.000	2.00	REMOVE RCS CNTRL PANEL SUPPORTS & MODIFY	
820412	003530	E30A001		RCS DECONTAMINATION	7	CN	0.036	11.00	PULL CABLE/RUN CONDUIT-RCF V-4 & V-9	
820412	003531	E30A001		RCS DECONTAMINATION			0.008	17.75	PULL CABLE/RUN CONDUIT-301 A PANEL	
820413	003548	E30A001		RCS DECONTAMINATION	11	CN	0.264	44.22	INSTL FLANGE&SPECTACLE BLIND IN 2'WDL	
*820413	003548	E30A001		RCS DECONTAMINATION	2	HP	0.037	8.08	INSTL FLANGE&SPECTACLE BLIND IN 2'WDL	
820415	003586	E30A001		RCS DECONTAMINATION	2	IC	0.003	1.67	RUN COAXIAL CABLE FOR SAM HOOKUP	
*820415	003586	E30A001		RCS DECONTAMINATION	1	CN	0.005	2.67	RUN COAXIAL CABLE FOR SAM HOOKUP	
820419	003603	E30A001		RCS DECONTAMINATION	1	CH	0.010	2.50	PULL CABLE/RUN CONDUIT-RCF V-4 & V-9	
*820419	003603	E30A001		RCS DECONTAMINATION	6	CN	0.053	13.95	PULL CABLE/RUN CONDUIT-RCF V-4 & V-9	
820427	003687	E30A001		RCS DECONTAMINATION	11	CN	0.063	21.75	INSTL T VLVES/RUN TUBES TO A62-AN A64-AR	
*820427	003687	E30A001		RCS DECONTAMINATION	3	HP	0.005	4.42	INSTL T VLVES/RUN TUBES TO A62-AN A64-AN	
820427	003688	E30A001		RCS DECONTAMINATION	11	CN	0.060	17.15	INSTALL AIR LINES/HOOK UP SANDPIPER PUMP	
*820427	003688	E30A001		RCS DECONTAMINATION	2	OP	0.005	3.08	INSTALL AIR LINES/HOOK UP SANDPIPER PUMP	
*820427	003688	E30A001		RCS DECONTAMINATION	1	HP	0.010	3.00	INSTALL AIR LINES/HOOK UP SANDPIPER PUMP	
820428	003706	E30A001		RCS DECONTAMINATION	2	CN	0.020	6.75	INSTALL TEMP N-2 SYSTEM IN TEST TK AREA	
*820428	003706	E30A001		RCS DECONTAMINATION	2	CR	0.005	2.67	INSTALL TEMP N-2 SYSTEM IN TEST TK AREA	
*820428	003706	E30A001		RCS DECONTAMINATION	11	MM	0.115	21.33	INSTALL TEMP N-2 SYSTEM IN TEST TK AREA	
*820428	003706	E30A001		RCS DECONTAMINATION	1	OP	0.000	0.42	INSTALL TEMP N-2 SYSTEM IN TEST TK AREA	
820428	003709	E30A001		RCS DECONTAMINATION	7	CN	0.148	14.75	INSTALL TEE IN SAMPLE LINE SN18	
*820428	003709	E30A001		RCS DECONTAMINATION	3	HP	0.042	4.73	INSTALL TEE IN SAMPLE LINE SN18	
820428	003708	E30C001		AFHB SYS & TKS DECON	1	CN	0.015	2.67	GAMMA SPEC ANALYSIS OF MU TANK & PIPING	
*820428	003708	E30C001		AFHB SYS & TKS DECON	1	CR	0.020	2.67	GAMMA SPEC ANALYSIS OF MU TANK & PIPING	
820504	003762	E30A001		RCS DECONTAMINATION	20	CN	0.349	55.71	HYDROTEST RCS PIPE/REPAIR LEAKS	
*820504	003762	E30A001		RCS DECONTAMINATION	2	CM	0.000	1.50	HYDROTEST RCS PIPE/REPAIR LEAKS	
*820504	003762	E30A001		RCS DECONTAMINATION	3	ES	0.035	6.92	HYDROTEST RCS PIPE/REPAIR LEAKS	
*820504	003762	E30A001		RCS DECONTAMINATION	1	HP	0.010	1.33	HYDROTEST RCS PIPE/REPAIR LEAKS	
*820504	003762	E30A001		RCS DECONTAMINATION	5	QA	0.058	10.00	HYDROTEST RCS PIPE/REPAIR LEAKS	
*820504	003762	E30A001		RCS DECONTAMINATION	1	CR	0.005	1.67	HYDROTEST RCS PIPE/REPAIR LEAKS	
820506	003786	E30A001		RCS DECONTAMINATION	3	CN	0.035	3.67	ADJUST LIMIT SWITCHES-EVAP COND TK RM	
*820506	003786	E30A001		RCS DECONTAMINATION	1	QA	0.010	0.75	ADJUST LIMIT SWITCHES-EVAP COND TK RM	
820512	003831	E30A001		RCS DECONTAMINATION	14	CN	0.300	28.42	INSTALL HANGERS/ANCHOR	
*820512	003831	E30A001		RCS DECONTAMINATION	1	HP	0.035	2.17	INSTALL HANGERS/ANCHOR	
*820512	003831	E30A001		RCS DECONTAMINATION	1	OS	0.020	1.08	INSTALL HANGERS/ANCHOR	
820512	003832	E30A001		RCS DECONTAMINATION	1	CN	0.075	1.33	REMOVE HYDRO PUMP & HOSES/GEN CLEANUP	
820513	003838	E30A001		RCS DECONTAMINATION	1	OP	0.010	1.50	VALVE LINEUP FOR RCS PROCESSING	
*820513	003838	E30A001		RCS DECONTAMINATION	1	HP	0.010	1.50	VALVE LINEUP FOR RCS PROCESSING	
820513	003852	E30A001		RCS DECONTAMINATION	1	CN	0.005	1.83	VERIFY RCS PROCESSING FLOW	
*820513	003852	E30A001		RCS DECONTAMINATION	2	OP	0.020	3.42	VERIFY RCS PROCESSING FLOW	
*820513	003852	E30A001		RCS DECONTAMINATION	1	ES	0.010	1.67	VERIFY RCS PROCESSING FLOW	
820519	003898	E30C001		AFHB SYS & TKS DECON	2	CN	0.075	4.50	GAMMA SCAN OF SEAL RETURN COOLER & MUF-3	

PNO. 6		UNC: DDS - ACTIVITY REPORT - RCS & SYSTEMS DECONTAMINATION M 286D									
* RWP	RWP	EXP	TRCK	ACTIVITY		PERS	DEPT	EXPOS	RWP	TASK DESCRIPTION	
* DATE	NUMBER	NUMBER	NUMBER	ENTRG	CODE	REMA	REMA	REMA	HOURS		
*820519	003898	E30C001	AFHB	SYS & TKS	DECON	1	CR	0.040	2.17	GAMMA SCAN OF SEAL RETURN COOLER & MUF-3	
820706	004220	E30C001	AFHB	SYS & TKS	DECON	1	UM	0.000	1.67	DECON FLOOR & WALL	
*820706	004220	E30C001	AFHB	SYS & TKS	DECON	1	HP	0.000	1.33	DECON FLOOR & WALL	
820707	004224	E30E33A	PWST	DECON		7	DM	0.005	19.58	REMOVE CONTAMINATED SOIL	
*820707	004224	E30E33A	PWST	DECON		3	HP	0.005	11.00	REMOVE CONTAMINATED SOIL	
820909	004687	E30C001	AFHB	SYS & TKS	DECON	1	CN	0.030	2.17	GAMMA SCAN OF BLOCK ORIFICE IN MUV ROOM	
*820909	004687	E30C001	AFHB	SYS & TKS	DECON	1	HP	0.015	2.17	GAMMA SCAN OF BLOCK ORIFICE IN MUV ROOM	
*820909	004687	E30C001	AFHB	SYS & TKS	DECON	1	CR	0.018	2.25	GAMMA SCAN OF BLOCK ORIFICE IN MUV ROOM	
820913	004693	E30C001	AFHB	SYS & TKS	DECON	5	UM	0.020	3.75	INSTALL RAMP IN CORRIDOR TO MUV ROOM	
*820913	004693	E30C001	AFHB	SYS & TKS	DECON	1	HP	0.000	2.33	INSTALL RAMP IN CORRIDOR TO MUV ROOM	
821202	005221	E30H001	OTSG	B	DECON	3	CN	0.001	17.08	FLUSH OTSG LINES-M-20 AREA	
821202	005222	E30H001	OTSG	B	DECON	7	CN	0.080	44.77	TIE-IN OTSG NEW PIPE TO OLD PIPE	
821217	005355	E30D057	RCBT	A	DECON	5	CN	0.045	8.37	REMOVE EQUIP FROM RCBT 'A' ROOM	
*821217	005355	E30D057	RCBT	A	DECON	1	HP	0.010	1.10	REMOVE EQUIP FROM RCBT 'A' ROOM	
830105	005486	E30H001	OTSG	B	DECON	2	OP	0.000	2.33	MOVE CONTAM MATL-SDS AREA TO TURB BLDG	
830105	005487	E30H001	OTSG	B	DECON	2	OP	0.000	0.97	MOVE SANDPIPER TO TURBINE BLDG	
830107	005504	E30H001	OTSG	B	DECON	1	CM	0.000	1.20	PUMP OTSG A MAIN STEAM LINES TO CDT SUMP	
*830107	005504	E30H001	OTSG	B	DECON	3	OP	0.010	14.47	PUMP OTSG A MAIN STEAM LINES TO CDT SUMP	
830110	005530	E30H001	OTSG	B	DECON	1	MM	0.000	0.85	PUMP OTSG A MAIN STEAM LINES TO CDT SUMP	
830110	005530	E30H001	OTSG	B	DECON	4	OP	0.000	17.81	PUMP OTSG 'A' STEAM & FEED LINES TO CDT	
*830110	005530	E30H001	OTSG	B	DECON	1	RP	0.000	8.12	PUMP OTSG 'A' STEAM & FEED LINES TO CDT	
830112	005548	E30H001	OTSG	B	DECON	13	OP	0.004	67.03	SET UP & OPERATE OTSG CLEANUP SYSTEM	
*830112	005548	E30H001	OTSG	B	DECON	3	MM	0.002	11.45	SET UP & OPERATE OTSG CLEANUP SYSTEM	
*830112	005548	E30H001	OTSG	B	DECON	2	HP	0.000	7.65	SET UP & OPERATE OTSG CLEANUP SYSTEM	
*830112	005548	E30H001	OTSG	B	DECON	2	CM	0.000	4.57	SET UP & OPERATE OTSG CLEANUP SYSTEM	
*830112	005548	E30H001	OTSG	B	DECON	1	RP	0.000	2.00	SET UP & OPERATE OTSG CLEANUP SYSTEM	
830119	005619	E30H001	OTSG	B	DECON	3	OP	0.000	22.85	SET UP/OPERATE/TEAR DOWN OTSG B CU SYS	
*830119	005619	E30H001	OTSG	B	DECON	1	MM	0.000	5.13	SET UP/OPERATE/TEAR DOWN OTSG B CU SYS	
*830119	005619	E30H001	OTSG	B	DECON	1	HP	0.005	6.57	SET UP/OPERATE/TEAR DOWN OTSG B CU SYS	
*830119	005619	E30H001	OTSG	B	DECON	2	CM	0.000	1.22	SET UP/OPERATE/TEAR DOWN OTSG B CU SYS	
830120	005621	E30H001	OTSG	B	DECON	2	CN	0.215	1.87	OPERATIONAL CHECK OF OTSG 'B' DRAIN VLVS	
830121	005632	E30H001	OTSG	B	DECON	27	OP	0.005	157.02	SET UP/OPERATE/TEAR DOWN OTSG B CU SYS	
*830121	005632	E30H001	OTSG	B	DECON	12	HP	0.002	26.05	SET UP/OPERATE/TEAR DOWN OTSG B CU SYS	
*830121	005632	E30H001	OTSG	B	DECON	7	MM	0.002	32.30	SET UP/OPERATE/TEAR DOWN OTSG B CU SYS	
*830121	005632	E30H001	OTSG	B	DECON	2	RP	0.000	10.52	SET UP/OPERATE/TEAR DOWN OTSG B CU SYS	
*830121	005632	E30H001	OTSG	B	DECON	14	CM	0.005	12.95	SET UP/OPERATE/TEAR DOWN OTSG B CU SYS	
*830121	005632	E30H001	OTSG	B	DECON	1	ES	0.000	6.48	SET UP/OPERATE/TEAR DOWN OTSG B CU SYS	
830128	005682	E30H001	OTSG	B	DECON	2	OP	0.005	9.75	SET UP/OPERATE/TEAR DOWN OTSG B CU SYS	
*830128	005682	E30H001	OTSG	B	DECON	1	CM	0.000	0.82	SET UP/OPERATE/TEAR DOWN OTSG B CU SYS	
830128	005689	E30H001	OTSG	B	DECON	8	MM	0.000	30.87	SET UP/OPERATE/TEAR DOWN OTSG B CU SYS	
*830128	005689	E30H001	OTSG	B	DECON	11	OP	0.000	60.05	SET UP/OPERATE/TEAR DOWN OTSG B CU SYS	
*830128	005689	E30H001	OTSG	B	DECON	5	HP	0.003	11.38	SET UP/OPERATE/TEAR DOWN OTSG B CU SYS	
*830128	005689	E30H001	OTSG	B	DECON	2	CM	0.000	1.30	SET UP/OPERATE/TEAR DOWN OTSG B CU SYS	
830202	005722	E30H001	OTSG	B	DECON	3	CN	0.749	5.75	DRAIN OTSG 'B' SECONDARY SIDE	
830204	005742	E30H001	OTSG	B	DECON	2	CN	0.311	2.65	DRAIN OTSG 'B' SECONDARY SIDE	
830209	005786	E30H001	OTSG	B	DECON	1	OP	0.000	1.00	INSTALL HOSE-ALC-P-1 INF TO ALC-P-4 EFF	
*830209	005786	E30H001	OTSG	B	DECON	1	HP	0.005	1.00	INSTALL HOSE-ALC-P-1 INF TO ALC-P-4 EFF	
830209	005787	E30H001	OTSG	B	DECON	22	OP	0.005	98.09	DRAIN DOWN OTSG B TO 327 ELEV VIA CU SYS	
*830209	005787	E30H001	OTSG	B	DECON	13	CM	0.000	11.53	DRAIN DOWN OTSG B TO 327 ELEV VIA CU SYS	
*830209	005787	E30H001	OTSG	B	DECON	3	MM	0.002	12.02	DRAIN DOWN OTSG B TO 327 ELEV VIA CU SYS	

PNO 7											
TMI-2 UNC DDS - ACTIVITY REPORT - RCS & SYSTEMS DECONTAMINATION M 286D											
* RWP	RWP	UNC	DDS	EXP	TRCK	ACTIVITY	PERS	DEPT	EXPOS	RWP	TASK DESCRIPTION
* DATE	NUMBER	NUMBER					ENTRG	CODE	REM	HOURS	
*830209	005787	E30H001				OTSG B DECON	1 RP		0.000	5.63	DRAIN DOWN OTSG B TO 327 ELEV VIA CU SYS
*830209	005787	E30H001				OTSG B DECON	5 HP		0.000	5.70	DRAIN DOWN OTSG B TO 327 ELEV VIA CU SYS
830214	005814	E30H001				OTSG B DECON	4 CN		0.618	5.53	DRAIN OTSG 'B' TO SUMP
830216	005850	E30H001				OTSG B DECON	10 OP		0.005	27.11	DRAIN OTSG 'A' & 'B' VIA 4X4 CLEANUP SYS
*830216	005850	E30H001				OTSG B DECON	3 CM		0.000	2.12	DRAIN OTSG 'A' & 'B' VIA 4X4 CLEANUP SYS
*830216	005850	E30H001				OTSG B DECON	1 RP		0.000	3.97	DRAIN OTSG 'A' & 'B' VIA 4X4 CLEANUP SYS
*830216	005850	E30H001				OTSG B DECON	3 HP		0.000	2.08	DRAIN OTSG 'A' & 'B' VIA 4X4 CLEANUP SYS
830223	005908	E30H001				OTSG B DECON	5 OP		0.000	10.45	DRAIN OTSG 'A' & 'B' VIA 4X4 CLEANUP SYS
*830223	005908	E30H001				OTSG B DECON	2 MM		0.000	2.28	DRAIN OTSG 'A' & 'B' VIA 4X4 CLEANUP SYS
*830223	005908	E30H001				OTSG B DECON	1 HP		0.000	1.30	DRAIN OTSG 'A' & 'B' VIA 4X4 CLEANUP SYS
830307	006002	E30H001				OTSG B DECON	9 OP		0.000	43.17	MOVE OTSG CU SYS TO XPORTER/DISMNTL EQUIP
*830307	006002	E30H001				OTSG B DECON	1 RP		0.000	6.28	MOVE OTSG CU SYS TO XPORTER/DISMNTL EQUIP
*830307	006002	E30H001				OTSG B DECON	1 CR		0.000	1.42	MOVE OTSG CU SYS TO XPORTER/DISMNTL EQUIP
*830307	006002	E30H001				OTSG B DECON	1 HP		0.000	1.50	MOVE OTSG CU SYS TO XPORTER/DISMNTL EQUIP
830322	006119	E30C001				AFHB SYS & TKS DECON	1 OP		0.007	3.00	RBAT-FLUSH WDS-T-3/VALVE LINEUP FOR FLSH
*830322	006119	E30C001				AFHB SYS & TKS DECON	1 MM		0.008	2.97	RBAT-FLUSH WDS-T-3/VALVE LINEUP FOR FLSH
*830322	006119	E30C001				AFHB SYS & TKS DECON	1 IC		0.008	2.97	RBAT-FLUSH WDS-T-3/VALVE LINEUP FOR FLSH
*830322	006119	E30C001				AFHB SYS & TKS DECON	1 CN		0.005	3.98	RBAT-FLUSH WDS-T-3/VALVE LINEUP FOR FLSH
830329	006168	E30C001				AFHB SYS & TKS DECON	1 OP		0.005	0.00	FLUSH RBAT & ASSOCIATED PIPING
*830329	006168	E30C001				AFHB SYS & TKS DECON	1 MM		0.003	3.05	FLUSH RBAT & ASSOCIATED PIPING
830405	006208	E30C001				AFHB SYS & TKS DECON	1 OP		0.000	1.02	REMOVE HOSES FROM DOOR OPENING
*830405	006208	E30C001				AFHB SYS & TKS DECON	1 HP		0.009	1.22	REMOVE HOSES FROM DOOR OPENING
*830405	006208	E30C001				AFHB SYS & TKS DECON	1 CM		0.000	1.18	REMOVE HOSES FROM DOOR OPENING
830421	006320	E30E33A				PWST DECON	4 IC		0.003	18.27	DECON PROCESSED WATER STORAGE TANK
*830421	006320	E30E33A				PWST DECON	2 MM		0.005	9.25	DECON PROCESSED WATER STORAGE TANK
*830421	006320	E30E33A				PWST DECON	1 OP		0.000	6.35	DECON PROCESSED WATER STORAGE TANK
830502	006411	E30D057				RCBT A DECON	1 CN		0.010	1.07	REMOVE & INSTALL MANWAY/SCRAPE SAMPLES
*830502	006411	E30D057				RCBT A DECON	4 MM		0.080	8.00	REMOVE & INSTALL MANWAY/SCRAPE SAMPLES
*830502	006411	E30D057				RCBT A DECON	1 HP		0.020	2.43	REMOVE & INSTALL MANWAY/SCRAPE SAMPLES
830508	006455	E30C001				AFHB SYS & TKS DECON	1 MM		0.000	1.22	INSTALL TEMP BALL VALVE 100GIA
830713	006947	E30J001				SYS & TKS RX DECON	2 CN		0.000	1.38	MODIFY HANDRAIL & LEG ON PLATFORM
830725	007047	E30H001				OTSG B DECON	2 CN		0.000	1.98	RMVE WAX INSIDE GLVBX/DECON CASK&FLOOR
830818	007255	E30C001				AFHB SYS & TKS DECON	1 ES		0.003	0.67	PHOTOGRAPH 3 INCH RESIN FILL LINES
831018	007794	E30D056				RCBT B&C DECON	10 CM		0.006	46.38	RCBT RESIN TESTING
831018	007793	E30E33A				PWST DECON	1 MM		0.000	1.48	DECON FLANGE IN PWST PUMP HOUSE
*831018	007793	E30E33A				PWST DECON	1 OP		0.003	1.50	DECON FLANGE IN PWST PUMP HOUSE
831021	007803	E30D056				RCBT B&C DECON	4 CM		0.000	22.67	RCBT RESIN TESTING
831026	007831	E30E33A				PWST DECON	3 IC		0.000	1.57	DECON INSTRUMENT EQUIPMENT
831027	007835	E30D40A				MAKEUP FILTERS DECON	5 UM		0.000	4.13	GAMMA SPEC MEASUREMENTS-MUF 2B,5A &5B
*831027	007835	E30D40A				MAKEUP FILTERS DECON	2 CN		0.002	7.85	GAMMA SPEC MEASUREMENTS-MUF 2B,5A &5B
*831027	007835	E30D40A				MAKEUP FILTERS DECON	1 HP		0.002	4.22	GAMMA SPEC MEASUREMENTS-MUF 2B,5A &5B
831028	007839	E30E33A				PWST DECON	16 IC		0.027	39.70	PREPARE TV CAMERAS/TEST EQUIPMENT
*831028	007839	E30E33A				PWST DECON	3 HP		0.000	1.22	PREPARE TV CAMERAS/TEST EQUIPMENT
831103	007876	E30E33A				PWST DECON	2 IC		0.000	3.60	EQUIPMENT DECON
840324	008700	E30H001				OTSG B DECON	2 MM		0.000	10.00	REMOVE MS-V-3A & 3B FROM SYSTEM
840404	008766	E30C001				AFHB SYS & TKS DECON	6 HP		0.420	15.32	FLUSH DECAY HEAT REMOVAL SYSTEM
*840404	008766	E30C001				AFHB SYS & TKS DECON	8 HP		0.572	20.20	FLUSH DECAY HEAT REMOVAL SYSTEM
840410	008802	E30C001				AFHB SYS & TKS DECON	2 HP		0.250	8.57	DRAIN & REFILL PUMP & COOLER
*840410	008802	E30C001				AFHB SYS & TKS DECON	3 OP		0.493	12.97	DRAIN & REFILL PUMP & COOLER
840412	008814	E30A001				RCS DECONTAMINATION	3 HP		0.029	1.88	CHANGE SAM II AT 'C' BLEED TANK

PNO. 8									
. TMI-2 UNC: DDS - ACTIVITY REPORT - RCS & SYSTEMS DECONTAMINATION M 286D									
* RWP	RWP	EXP TRCK.	ACTIVITY		PERS	DEPT	EXPOS	RWP	TASK DESCRIPTION
* DATE	NUMBER	NUMBER	ENTRG	CODE	REM	HOURS			
840412	008812	E30D40A	8	UM	0.031	11.63			INSTL SCAF & LD BRICK-CEMENT BLK SHLDG
840421	008868	E30C001	2	OP	0.067	2.80			FLUSH 'B' DECAY HEAT LOOP
*840421	008868	E30C001	1	CN	0.042	1.50			FLUSH 'B' DECAY HEAT LOOP
840828	009801	E30D40A	5	CN	0.009	8.95			PRE-OPER TEST OF MU-P-8 ELUTION SYSTEM
*840828	009801	E30D40A	2	ES	0.005	7.58			PRE-OPER TEST OF MU-P-8 ELUTION SYSTEM
*840828	009801	E30D40A	3	QA	0.000	2.05			PRE-OPER TEST OF MU-P-8 ELUTION SYSTEM
*840828	009801	E30D40A	3	EL	0.004	2.97			PRE-OPER TEST OF MU-P-8 ELUTION SYSTEM
*840828	009801	E30D40A	11	MM	0.019	13.72			PRE-OPER TEST OF MU-P-8 ELUTION SYSTEM
*840828	009801	E30D40A	2	HP	0.005	9.18			PRE-OPER TEST OF MU-P-8 ELUTION SYSTEM
*840828	009801	E30D40A	2	IC	0.005	4.40			PRE-OPER TEST OF MU-P-8 ELUTION SYSTEM
*840828	009801	E30D40A	1	OP	0.000	5.03			PRE-OPER TEST OF MU-P-8 ELUTION SYSTEM
840828	008691	E30H001	1	OP	0.003	1.37			REMOVE INSULATION & DECON PIPING
*840323	008691	E30H001	2	CN	0.007	2.25			REMOVE INSULATION & DECON PIPING
*840323	008691	E30H001	1	EL	0.000	0.95			REMOVE INSULATION & DECON PIPING
*840323	008691	E30H001	1	UM	0.002	1.35			REMOVE INSULATION & DECON PIPING
841215	010481	E30C001	2	OP	0.140	4.48			FLUSH FLOORS, WALLS AND EQUIP-FHB 281'
*841215	010481	E30C001	1	RP	0.078	2.28			FLUSH FLOORS, WALLS AND EQUIP-FHB 281'
*841215	010481	E30C001	1	CN	0.060	3.28			FLUSH FLOORS, WALLS AND EQUIP-FHB 281'
841219	010518	E30A001	1	HP	0.008	4.80			LET DOWN 100 GAL OF RCS THRU BORONOMETER
841219	010518	E30A001	1	CM	0.005	2.13			LET DOWN 100 GAL OF RCS THRU BORONOMETER
841219	010518	E30A001	1	EG	0.008	5.47			LET DOWN 100 GAL OF RCS THRU BORONOMETER
841219	010518	E30A001	1	OP	0.007	5.63			LET DOWN 100 GAL OF RCS THRU BORONOMETER
. GRAND-TOTAL -									
. PERS	ENTRG	"	"	"	1075				
. EXPOS	REM	"	"	"	14.740000				
. RWP	HOURS	"	"	"	2552.5300				
..... END REPORT									

4.0 COMPUTER REPORTS

4.4 TMI-2 RCS and Systems Decontamination
Individual Activity Summaries

PN0	1	UNC: DDS - ACTIVITY REPORT - RCS & SYSTEMS DECONTAMINATION M 286D									
* TMI-2	RWP	EXP TRCK	ACTIVITY	PERS	DEPT	EXPOS	RWP				
* DATE	NUMBER	NUMBER		ENTRG	CODE	REM	HOURS	TASK DESCRIPTION			
* 801217	085939	E30A001	RCS DECONTAMINATION	2	CN	0.010	2.33	RCS SAMPLE/RESIN COL TEST WITH ZEOLITE			
* 801217	085939	E30A001	RCS DECONTAMINATION	1	CR	0.005	1.17	RCS SAMPLE/RESIN COL TEST WITH ZEOLITE			
801218	085948	E30A001	RCS DECONTAMINATION	1	CN	0.005	0.50	RESIN COLUMN TEST WITH RCS & ZEOLITE			
* 801218	085948	E30A001	RCS DECONTAMINATION	1	CR	0.000	0.50	RESIN COLUMN TEST WITH RCS & ZEOLITE			
801219	085960	E30A001	RCS DECONTAMINATION	1	CN	0.005	0.58	RESIN COLUMN TEST WITH RCS & ZEOLITE			
* 801219	085960	E30A001	RCS DECONTAMINATION	1	CR	0.000	0.58	RESIN COLUMN TEST WITH RCS & ZEOLITE			
820408	003514	E30A001	RCS DECONTAMINATION	2	CN	0.000	2.00	REMOVE RCS CNTRL PANEL SUPPORTS & MODIFY			
820412	003530	E30A001	RCS DECONTAMINATION	7	CN	0.038	11.00	PULL CABLE/RUN CONDUIT-RCF V-4 & V-9			
820412	003531	E30A001	RCS DECONTAMINATION	11	CN	0.008	17.75	PULL CABLE/RUN CONDUIT-301 A PANEL			
820413	003548	E30A001	RCS DECONTAMINATION	13	CN	0.264	44.22	INSTL FLANGE&SPECTACLE BLIND IN 2'WDL			
* 820413	003548	E30A001	RCS DECONTAMINATION	2	HP	0.037	8.08	INSTL FLANGE&SPECTACLE BLIND IN 2'WDL			
820415	003586	E30A001	RCS DECONTAMINATION	2	IC	0.003	1.67	RUN COAXIAL CABLE FOR SAM HOOKUP			
* 820415	003586	E30A001	RCS DECONTAMINATION	1	CN	0.005	2.67	RUN COAXIAL CABLE FOR SAM HOOKUP			
820419	003603	E30A001	RCS DECONTAMINATION	1	CH	0.010	2.50	PULL CABLE/RUN CONDUIT-RCF V-4 & V-9			
* 820419	003603	E30A001	RCS DECONTAMINATION	6	CN	0.053	13.95	PULL CABLE/RUN CONDUIT-RCF V-4 & V-9			
820427	003687	E30A001	RCS DECONTAMINATION	11	CN	0.063	21.75	INSTL T VLVES/RUN TUBES TO A62-AN, A64-AR			
* 820427	003687	E30A001	RCS DECONTAMINATION	3	HP	0.005	4.42	INSTL T VLVES/RUN TUBES TO A62-AN, A64-AN			
820427	003688	E30A001	RCS DECONTAMINATION	11	CN	0.060	17.15	INSTALL AIR LINES/HOOK UP SANDPIPER PUMP			
* 820427	003688	E30A001	RCS DECONTAMINATION	2	OP	0.005	3.08	INSTALL AIR LINES/HOOK UP SANDPIPER PUMP			
* 820427	003688	E30A001	RCS DECONTAMINATION	1	HP	0.010	3.00	INSTALL AIR LINES/HOOK UP SANDPIPER PUMP			
820428	003706	E30A001	RCS DECONTAMINATION	2	CN	0.020	6.75	INSTALL TEMP N-2 SYSTEM IN TEST TK AREA			
* 820428	003706	E30A001	RCS DECONTAMINATION	2	CR	0.005	2.67	INSTALL TEMP N-2 SYSTEM IN TEST TK AREA			
* 820428	003706	E30A001	RCS DECONTAMINATION	11	MM	0.115	21.33	INSTALL TEMP N-2 SYSTEM IN TEST TK AREA			
* 820428	003706	E30A001	RCS DECONTAMINATION	1	OP	0.000	0.42	INSTALL TEMP N-2 SYSTEM IN TEST TK AREA			
820428	003709	E30A001	RCS DECONTAMINATION	7	CN	0.148	14.75	INSTALL TEE IN SAMPLE LINE SN18			
* 820428	003709	E30A001	RCS DECONTAMINATION	3	HP	0.042	4.73	INSTALL TEE IN SAMPLE LINE SN18			
820504	003762	E30A001	RCS DECONTAMINATION	20	CN	0.349	55.71	HYDROTEST RCS PIPE/REPAIR LEAKS			
* 820504	003762	E30A001	RCS DECONTAMINATION	2	CM	0.000	1.50	HYDROTEST RCS PIPE/REPAIR LEAKS			
* 820504	003762	E30A001	RCS DECONTAMINATION	3	ES	0.035	6.92	HYDROTEST RCS PIPE/REPAIR LEAKS			
* 820504	003762	E30A001	RCS DECONTAMINATION	1	HP	0.010	1.33	HYDROTEST RCS PIPE/REPAIR LEAKS			
* 820504	003762	E30A001	RCS DECONTAMINATION	5	QA	0.058	10.00	HYDROTEST RCS PIPE/REPAIR LEAKS			
* 820504	003762	E30A001	RCS DECONTAMINATION	1	CR	0.005	1.67	HYDROTEST RCS PIPE/REPAIR LEAKS			
820506	003786	E30A001	RCS DECONTAMINATION	3	CN	0.035	3.67	ADJUST LIMIT SWITCHES-EVAP COND TK RM			
* 820506	003786	E30A001	RCS DECONTAMINATION	1	QA	0.010	0.75	ADJUST LIMIT SWITCHES-EVAP COND TK RM			
820512	003831	E30A001	RCS DECONTAMINATION	14	CN	0.300	28.42	INSTALL HANGERS/ANCHOR			
* 820512	003831	E30A001	RCS DECONTAMINATION	1	HP	0.035	2.17	INSTALL HANGERS/ANCHOR			
* 820512	003831	E30A001	RCS DECONTAMINATION	1	OS	0.020	1.08	INSTALL HANGERS/ANCHOR			
820512	003832	E30A001	RCS DECONTAMINATION	1	CN	0.075	1.33	REMOVE HYDRO PUMP & HOSES/GEN CLEANUP			
820513	003838	E30A001	RCS DECONTAMINATION	1	OP	0.010	1.50	VALVE LINEUP FOR RCS PROCESSING			
* 820513	003838	E30A001	RCS DECONTAMINATION	1	HP	0.010	1.50	VALVE LINEUP FOR RCS PROCESSING			
820513	003852	E30A001	RCS DECONTAMINATION	1	CN	0.005	1.83	VERIFY RCS PROCESSING FLOW			
* 820513	003852	E30A001	RCS DECONTAMINATION	2	OP	0.020	3.42	VERIFY RCS PROCESSING FLOW			
* 820513	003852	E30A001	RCS DECONTAMINATION	1	ES	0.010	1.67	VERIFY RCS PROCESSING FLOW			
840412	008814	E30A001	RCS DECONTAMINATION	3	HP	0.029	1.88	CHANGE SAM II AT 'C' BLEED TANK			
841219	010518	E30A001	RCS DECONTAMINATION	1	HP	0.008	4.80	LET DOWN 100 GAL OF RCS THRU BORONOMETER			
841219	010518	E30A001	RCS DECONTAMINATION	1	CM	0.005	2.13	LET DOWN 100 GAL OF RCS THRU BORONOMETER			
84121	010518	E30A001	RCS DECONTAMINATION	1	EG	0.008	5.47	LET DOWN 100 GAL OF RCS THRU BORONOMETER			
84121	010518	E30A001	RCS DECONTAMINATION	1	OP	0.007	5.63	LET DOWN 100 GAL OF RCS THRU BORONOMETER			
SUBTO AL	-	EXP TRCK	NUMBER = E30A001								
PERS	ENTRG	=	172								

PNO 2
 TMI-2 UNC: DDS - ACTIVITY REPORT - RCS & SYSTEMS DECONTAMINATION M 286D
 * RWP RWP EXP TRCK PERS DEPT EXPOS RWP
 * DATE NUMBER NUMBER ACTIVITY ENTRG CODE REM HOURS TASK DESCRIPTION

EXPOS REM = 1.960000
 RWP HOURS = 353.93000

EXPOS	REM	ACTIVITY	ENTRG	CODE	REM	HOURS	TASK DESCRIPTION
790405	022221	E30C001 AFHB SYS & TKS DECON	4	CN	0.055	0.00	RECOMBINER COVERAGE
*790405	022221	E30C001 AFHB SYS & TKS DECON	1	VI	0.025	0.00	RECOMBINER COVERAGE
790409	022156	E30C001 AFHB SYS & TKS DECON	2	EL	0.016	0.00	MOVE CABLE TO RECOMBINER
790413	021363	E30C001 AFHB SYS & TKS DECON	3	EL	0.180	0.00	CHECK POWER CABLE FOR RECOMBINER
800123	0B0487	E30C001 AFHB SYS & TKS DECON	1	CN	0.020	1.58	INSTALL TENT AROUND RECOMBINER
*800123	0B0487	E30C001 AFHB SYS & TKS DECON	2	CR	0.040	2.00	INSTALL TENT AROUND RECOMBINER
800124	0B0502	E30C001 AFHB SYS & TKS DECON	1	CR	0.070	2.08	INSTALL TENT AROUND RECOMBINER
800124	0B0517	E30C001 AFHB SYS & TKS DECON	1	CN	0.005	1.75	DECON H-2 RECOMBINER PAD
*800124	0B0517	E30C001 AFHB SYS & TKS DECON	1	CR	0.005	1.33	DECON H-2 RECOMBINER PAD
800125	0B0546	E30C001 AFHB SYS & TKS DECON	1	CN	0.000	1.00	DECON H-2 RECOMBINER PAD
*800125	0B0546	E30C001 AFHB SYS & TKS DECON	1	CR	0.005	1.00	DECON H-2 RECOMBINER PAD
800125	0B0547	E30C001 AFHB SYS & TKS DECON	1	CR	0.000	1.00	INSTALL TENT AROUND RECOMBINER
800128	0B0621	E30C001 AFHB SYS & TKS DECON	2	CN	0.180	1.75	DECON SPILL INSIDE RECOMBINER TENT
*800128	0B0621	E30C001 AFHB SYS & TKS DECON	1	CR	0.105	0.08	DECON SPILL INSIDE RECOMBINER TENT
800324	0B1801	E30C001 AFHB SYS & TKS DECON	1	CN	0.020	1.10	DECON H-2 RECOMBINER
*800324	0B1801	E30C001 AFHB SYS & TKS DECON	1	CR	0.018	1.05	DECON H-2 RECOMBINER
*800324	0B1801	E30C001 AFHB SYS & TKS DECON	1	UM	0.028	0.76	DECON H-2 RECOMBINER
800325	0B1829	E30C001 AFHB SYS & TKS DECON	1	CN	0.020	1.33	DECON H-2 RECOMBINER
*800325	0B1829	E30C001 AFHB SYS & TKS DECON	2	CR	0.048	1.92	DECON H-2 RECOMBINER
800327	0B1881	E30C001 AFHB SYS & TKS DECON	3	CN	0.038	1.95	XFER RECOMB BLOWER FROM TENT/DECON TENT
*800327	0B1881	E30C001 AFHB SYS & TKS DECON	1	CR	0.020	0.93	XFER RECOMB BLOWER FROM TENT/DECON TENT
*800327	0B1881	E30C001 AFHB SYS & TKS DECON	1	UM	0.020	0.93	XFER RECOMB BLOWER FROM TENT/DECON TENT
800514	0B3020	E30C001 AFHB SYS & TKS DECON	1	CN	0.005	0.57	STAGE FOR FLUSH OF RECOMBINER FILL SYS
800516	0B3083	E30C001 AFHB SYS & TKS DECON	4	CN	0.015	10.00	FLUSH RECOMBINER/CHANGE FILTERS
*800516	0B3083	E30C001 AFHB SYS & TKS DECON	3	CR	0.010	9.00	FLUSH RECOMBINER/CHANGE FILTERS
800520	0B3137	E30C001 AFHB SYS & TKS DECON	2	CN	0.040	0.00	DRAIN & REFILL RECOMBINER
800522	0B3206	E30C001 AFHB SYS & TKS DECON	2	CN	0.020	5.67	FLUSH RECOMBINER TO DRAIN
800528	0B3282	E30C001 AFHB SYS & TKS DECON	1	CN	0.000	3.25	DECON RECOMBINER INTERNALS & FLUSH
800530	0B3358	E30C001 AFHB SYS & TKS DECON	2	CN	0.005	2.00	FLUSH RECOMBINER/CHANGE FILTER
800626	0B3903	E30C001 AFHB SYS & TKS DECON	1	CN	0.005	1.33	DECON RECOMBINER TENT
*800626	0B3903	E30C001 AFHB SYS & TKS DECON	1	CR	0.000	1.33	DECON RECOMBINER TENT
800703	0B4022	E30C001 AFHB SYS & TKS DECON	1	CN	0.005	5.75	DECON RECOMBINER TENT
*800703	0B4022	E30C001 AFHB SYS & TKS DECON	2	CR	0.010	5.67	DECON RECOMBINER TENT
800726	0B4321	E30C001 AFHB SYS & TKS DECON	1	CN	0.000	0.42	CHG FLTRS/DECON HOT SPOTS IN RECOMB TENT
*800726	0B4321	E30C001 AFHB SYS & TKS DECON	1	CR	0.000	0.42	CHG FLTRS/DECON HOT SPOTS IN RECOMB TENT
800728	0B4326	E30C001 AFHB SYS & TKS DECON	3	CR	0.002	4.68	FLUSH RECOMBINER COILS
*800728	0B4326	E30C001 AFHB SYS & TKS DECON	1	EL	0.005	3.17	FLUSH RECOMBINER COILS
800728	0B4350	E30C001 AFHB SYS & TKS DECON	3	CN	0.000	4.33	DECON RECOMBINER TENT/BAG JOINTS
800828	0B9308	E30C001 AFHB SYS & TKS DECON	3	CN	0.000	16.25	FLUSH RECOMBINER
*800828	0B9308	E30C001 AFHB SYS & TKS DECON	6	CR	0.015	23.17	FLUSH RECOMBINER
800904	0B9335	E30C001 AFHB SYS & TKS DECON	1	CN	0.000	2.50	FLUSH RECOMBINER
*800904	0B9335	E30C001 AFHB SYS & TKS DECON	1	CR	0.000	2.50	FLUSH RECOMBINER
800910	0B4951	E30C001 AFHB SYS & TKS DECON	4	CN	0.015	11.66	ADD WATER TO RECOMBINER & FLUSH
*800910	0B4951	E30C001 AFHB SYS & TKS DECON	6	CR	0.002	14.17	ADD WATER TO RECOMBINER & FLUSH
801030	0B5467	E30C001 AFHB SYS & TKS DECON	3	CN	0.000	6.70	STAND RECOMBINER UPRIGHT
801031	0B5479	E30C001 AFHB SYS & TKS DECON	2	CR	0.000	2.00	DRAIN RECOMBINER
801106	0B5519	E30C001 AFHB SYS & TKS DECON	2	CR	0.020	4.00	DECON RECOMBINER & GENERAL AREA
801129	0B5715	E30C001 AFHB SYS & TKS DECON	1	CN	0.003	1.58	REPLACE FILTER WDG-F-1

-28-

PNO. 3

TMI-2 UNC: DDS - ACTIVITY REPORT - RCS & SYSTEMS DECONTAMINATION M 286D

* RWP	RWP	EXP	TRCK	ACTIVITY	PERS	DEPT	EXPOS	RWP	TASK DESCRIPTION
* DATE	NUMBER	NUMBER			ENTRG	CODE	REM	HOURS	
*801129	0B5715	E30C001		AFHB SYS & TKS DECON	1	OP	0.000	0.67	REPLACE FILTER WDG-F-1
*801129	0B5715	E30C001		AFHB SYS & TKS DECON	1	MM	0.005	1.33	REPLACE FILTER WDG-F-1
*801129	0B5715	E30C001		AFHB SYS & TKS DECON	2	UM	0.015	2.67	REPLACE FILTER WDG-F-1
820428	003708	E30C001		AFHB SYS & TKS DECON	1	CN	0.015	2.67	GAMMA SPEC ANALYSIS OF MU TANK & PIPING
*820428	003708	E30C001		AFHB SYS & TKS DECON	1	CR	0.020	2.67	GAMMA SPEC ANALYSIS OF MU TANK & PIPING
820519	003898	E30C001		AFHB SYS & TKS DECON	2	CN	0.075	4.50	GAMMA SCAN OF SEAL RETURN COOLER & MUF-3
*820519	003898	E30C001		AFHB SYS & TKS DECON	1	CR	0.040	2.17	GAMMA SCAN OF SEAL RETURN COOLER & MUF-3
820706	004220	E30C001		AFHB SYS & TKS DECON	1	UM	0.000	1.67	DECON FLOOR & WALL
*820706	004220	E30C001		AFHB SYS & TKS DECON	1	HP	0.000	1.33	DECON FLOOR & WALL
820909	004687	E30C001		AFHB SYS & TKS DECON	1	CN	0.030	2.17	GAMMA SCAN OF BLOCK ORIFICE IN MUV ROOM
*820909	004687	E30C001		AFHB SYS & TKS DECON	1	HP	0.015	2.17	GAMMA SCAN OF BLOCK ORIFICE IN MUV ROOM
*820909	004687	E30C001		AFHB SYS & TKS DECON	1	CR	0.018	2.25	GAMMA SCAN OF BLOCK ORIFICE IN MUV ROOM
820913	004693	E30C001		AFHB SYS & TKS DECON	5	UM	0.020	8.75	INSTALL RAMP IN CORRIDOR TO MUV ROOM
*820913	004693	E30C001		AFHB SYS & TKS DECON	1	HP	0.000	2.33	INSTALL RAMP IN CORRIDOR TO MUV ROOM
830322	006119	E30C001		AFHB SYS & TKS DECON	1	OP	0.007	3.00	RBAT-FLUSH WDS-T-3/VALVE LINEUP FOR FLSH
*830322	006119	E30C001		AFHB SYS & TKS DECON	1	MM	0.008	2.97	RBAT-FLUSH WDS-T-3/VALVE LINEUP FOR FLSH
*830322	006119	E30C001		AFHB SYS & TKS DECON	1	IC	0.008	2.97	RBAT-FLUSH WDS-T-3/VALVE LINEUP FOR FLSH
*830322	006119	E30C001		AFHB SYS & TKS DECON	1	CN	0.005	3.98	RBAT-FLUSH WDS-T-3/VALVE LINEUP FOR FLSH
830329	006168	E30C001		AFHB SYS & TKS DECON	1	OP	0.005	0.00	FLUSH RBAT & ASSOCIATED PIPING
*830329	006168	E30C001		AFHB SYS & TKS DECON	1	MM	0.003	3.05	FLUSH RBAT & ASSOCIATED PIPING
830405	006208	E30C001		AFHB SYS & TKS DECON	1	OP	0.000	1.02	REMOVE HOSES FROM DOOR OPENING
*830405	006208	E30C001		AFHB SYS & TKS DECON	1	HP	0.009	1.22	REMOVE HOSES FROM DOOR OPENING
*830405	006208	E30C001		AFHB SYS & TKS DECON	1	CM	0.000	1.18	REMOVE HOSES FROM DOOR OPENING
830508	006455	E30C001		AFHB SYS & TKS DECON	1	MM	0.000	1.22	INSTALL TEMP BALL VALVE 10DGIA
830818	007255	E30C001		AFHB SYS & TKS DECON	1	ES	0.003	0.67	PHOTOGRAPH 3 INCH RESIN FILL LINES
840404	008766	E30C001		AFHB SYS & TKS DECON	6	HP	0.420	15.32	FLUSH DECAY HEAT REMOVAL SYSTEM
*840404	008766	E30C001		AFHB SYS & TKS DECON	8	HP	0.572	20.20	FLUSH DECAY HEAT REMOVAL SYSTEM
840410	008802	E30C001		AFHB SYS & TKS DECON	2	HP	0.250	8.57	DRAIN & REFILL PUMP & COOLER
*840410	008802	E30C001		AFHB SYS & TKS DECON	3	OP	0.493	12.97	DRAIN & REFILL PUMP & COOLER
840421	008868	E30C001		AFHB SYS & TKS DECON	2	OP	0.067	2.80	FLUSH 'B' DECAY HEAT LOOP
*840421	008868	E30C001		AFHB SYS & TKS DECON	1	CN	0.042	1.50	FLUSH 'B' DECAY HEAT LOOP
841215	010481	E30C001		AFHB SYS & TKS DECON	2	OP	0.140	4.48	FLUSH FLOORS, WALLS AND EQUIP-FHB 281'
*841215	010481	E30C001		AFHB SYS & TKS DECON	1	RP	0.078	2.28	FLUSH FLOORS, WALLS AND EQUIP-FHB 281'
*841215	010481	E30C001		AFHB SYS & TKS DECON	1	CN	0.060	3.28	FLUSH FLOORS, WALLS AND EQUIP-FHB 281'
SUBTOTAL - EXP TRCK NUMBER = E30C001									
PERS ENTRG = 148									
EXPOS REM = 3.518000									
RWP HOURS = 295.69000									
790615	026748	E30D056		RCBT B&C DECON	4	CN	0.030	0.00	MOVE RECOMB-FUEL POOL TO INTERMED BLDG
810223	000526	E30D056		RCBT B&C DECON	2	OP	0.175	1.00	VALVE LINEUP ON 'B' BLEED TANK
*810223	000526	E30D056		RCBT B&C DECON	1	HP	0.060	0.50	VALVE LINEUP ON 'B' BLEED TANK
810814	001705	E30D056		RCBT B&C DECON	6	MM	0.105	7.42	INSTALL ADAPTERS-WDL V-153A, 153B, 18A
*810814	001705	E30D056		RCBT B&C DECON	1	CN	0.010	1.25	INSTALL ADAPTERS-WDL V-153A, 153B, 18A
810818	001732	E30D056		RCBT B&C DECON	10	CN	0.190	19.90	GAMMA SPEC SURVEY OF TANK SLUDGE
*810818	001732	E30D056		RCBT B&C DECON	1	CR	0.025	2.75	GAMMA SPEC SURVEY OF TANK SLUDGE
*810818	001732	E30D056		RCBT B&C DECON	1	QA	0.000	0.33	GAMMA SPEC SURVEY OF TANK SLUDGE
810818	001734	E30D056		RCBT B&C DECON	1	CN	0.045	1.42	DRAIN SIGHT GLASS TO REDUCE HOT SPOT
*810818	001734	E30D056		RCBT B&C DECON	1	OP	0.045	2.67	DRAIN SIGHT GLASS TO REDUCE HOT SPOT
810821	001766	E30D056		RCBT B&C DECON	2	CN	0.025	2.83	DRAIN LOWER LEVEL SIGHT GLASS
*810821	001766	E30D056		RCBT B&C DECON	1	OP	0.010	2.00	DRAIN LOWER LEVEL SIGHT GLASS

PNO. 4
 TMI-2 UNC: DDS - ACTIVITY REPORT - RCS & SYSTEMS DECONTAMINATION M 286D

* RWP	RWP	EXP TRCK	ACTIVITY	PERS	DEPT	EXPOS	RWP	TASK DESCRIPTION	
* DATE	NUMBER	NUMBER		ENTRG	CODE	REM	HOURS		
*810822	001772	E30D056	RCBT B&C DECON	1	CN	0.005	1.00	RMVE ADPTR FLNGE/CONN LNS-WDL-V-18A,B,C	
*810822	001772	E30D056	RCBT B&C DECON	1	OP	0.005	1.08	RMVE ADPTR FLNGE/CONN LNS-WDL-V-18A,B,C	
*810822	001772	E30D056	RCBT B&C DECON	2	MM	0.040	2.00	RMVE ADPTR FLNGE/CONN LNS-WDL-V-18A,B,C	
820226	003399	E30D056	RCBT B&C DECON	1	CM	0.005	1.67	SAMPLE RC BLEED TANK 'C'	
*820226	003399	E30D056	RCBT B&C DECON	1	CH	0.000	1.83	SAMPLE RC BLEED TANK 'C'	
820329	003409	E30D056	RCBT B&C DECON	1	CN	0.010	3.33	SAMPLE & ANALYZE RCS & RCBT 'C'	
*820329	003409	E30D056	RCBT B&C DECON	1	CH	0.005	3.33	SAMPLE & ANALYZE RCS & RCBT 'C'	
820331	003453	E30D056	RCBT B&C DECON	1	CN	0.005	1.33	SAMPLE RCBT 'C'	
*820331	003453	E30D056	RCBT B&C DECON	1	CH	0.000	1.17	SAMPLE RCBT 'C'	
*820331	003453	E30D056	RCBT B&C DECON	1	HP	0.005	1.33	SAMPLE RCBT 'C'	
831018	007794	E30D056	RCBT B&C DECON	10	CM	0.006	46.38	RCBT RESIN TESTING	
831021	007803	E30D056	RCBT B&C DECON	4	CM	0.000	22.67	RCBT RESIN TESTING	
SUBTOTAL		EXP TRCK NUMBER	= E30D056						
PERS		ENTRG	= 56						
EXPOS		REM	= 0.8060000						
RWP		HOURS	= 129.19000						
810817	001728	E30D057	RCBT A DECON	3	CN	0.025	4.17	CONNECT HOSES/PUMP & FLUSH RCBT 'A'	
*810817	001728	E30D057	RCBT A DECON	12	OP	0.134	29.75	CONNECT HOSES/PUMP & FLUSH RCBT 'A'	
810924	002086	E30D057	RCBT A DECON	1	ME	0.000	0.40	DISCON TEMP SAMP SYS AT WDL-18A,B,C	
*810924	002086	E30D057	RCBT A DECON	3	MM	0.015	3.73	DISCON TEMP SAMP SYS AT WDL-18A,B,C	
810930	002093	E30D057	RCBT A DECON	2	CN	0.013	3.67	FLUSH RCBT 'A'	
*810930	002093	E30D057	RCBT A DECON	5	OP	0.042	22.58	FLUSH RCBT 'A'	
810930	002096	E30D057	RCBT A DECON	1	CN	0.035	1.00	REMOVE TK MANWAY COVER/GASKET & REPLACE	
*810930	002096	E30D057	RCBT A DECON	1	OP	0.020	2.00	REMOVE TK MANWAY COVER/GASKET & REPLACE	
*810930	002096	E30D057	RCBT A DECON	1	HP	0.030	3.00	REMOVE TK MANWAY COVER/GASKET & REPLACE	
*810930	002096	E30D057	RCBT A DECON	1	ME	0.060	1.00	REMOVE TK MANWAY COVER/GASKET & REPLACE	
*810930	002096	E30D057	RCBT A DECON	3	MM	0.100	6.00	REMOVE TK MANWAY COVER/GASKET & REPLACE	
811001	002102	E30D057	RCBT A DECON	2	CN	0.070	2.07	SAMPLE & SURVEY TANK INTERNALS	
*811001	002102	E30D057	RCBT A DECON	1	CR	0.020	0.87	SAMPLE & SURVEY TANK INTERNALS	
*811001	002102	E30D057	RCBT A DECON	1	MM	0.040	1.12	SAMPLE & SURVEY TANK INTERNALS	
811002	002106	E30D057	RCBT A DECON	3	CN	0.090	7.78	VACUUM & FLUSH RCBT 'A'	
*811002	002106	E30D057	RCBT A DECON	4	CR	0.095	11.37	VACUUM & FLUSH RCBT 'A'	
*811002	002106	E30D057	RCBT A DECON	1	ES	0.060	3.35	VACUUM & FLUSH RCBT 'A'	
*811002	002106	E30D057	RCBT A DECON	2	MM	0.070	5.68	VACUUM & FLUSH RCBT 'A'	
*811002	002106	E30D057	RCBT A DECON	2	UM	0.055	5.68	VACUUM & FLUSH RCBT 'A'	
*811002	002106	E30D057	RCBT A DECON	1	OP	0.010	2.33	VACUUM & FLUSH RCBT 'A'	
*811002	002106	E30D057	RCBT A DECON	1	HP	0.040	2.33	VACUUM & FLUSH RCBT 'A'	
811007	002137	E30D057	RCBT A DECON	6	CN	0.105	12.67	SPARGE & FLUSH RCBT 'A'	
*811007	002137	E30D057	RCBT A DECON	11	CR	0.261	24.67	SPARGE & FLUSH RCBT 'A'	
*811007	002137	E30D057	RCBT A DECON	6	MM	0.192	15.83	SPARGE & FLUSH RCBT 'A'	
*811007	002137	E30D057	RCBT A DECON	6	UM	0.037	15.00	SPARGE & FLUSH RCBT 'A'	
*811007	002137	E30D057	RCBT A DECON	4	OP	0.028	8.08	SPARGE & FLUSH RCBT 'A'	
*811007	002137	E30D057	RCBT A DECON	4	HP	0.080	8.58	SPARGE & FLUSH RCBT 'A'	
811010	002153	E30D057	RCBT A DECON	1	CN	0.020	1.50	REPLACE MANWAY COVER & GASKET	
*811010	002153	E30D057	RCBT A DECON	1	OP	0.020	2.50	REPLACE MANWAY COVER & GASKET	
811019	002200	E30D057	RCBT A DECON	3	MM	0.075	5.25	REPLACE MANWAY COVER & GASKET	
*811019	002200	E30D057	RCBT A DECON	1	CN	0.010	2.50	GROSS FLUSH INSIDE OF TK/DECON & DESTAGE	
*811019	002200	E30D057	RCBT A DECON	2	CR	0.010	4.75	GROSS FLUSH INSIDE OF TK/DECON & DESTAGE	
*811019	002200	E30D057	RCBT A DECON	1	HP	0.010	2.50	GROSS FLUSH INSIDE OF TK/DECON & DESTAGE	
*811019	002200	E30D057	RCBT A DECON	2	UM	0.005	4.75	GROSS FLUSH INSIDE OF TK/DECON & DESTAGE	

-30-

UNC: DDS - ACTIVITY REPORT - RCS & SYSTEMS DECONTAMINATION M 286D										
PNO.	TMI-2	RWP	EXP	TRCK.	ACTIVITY	PERS	DEPT	EXPOS	RWP	TASK DESCRIPTION
* DATE	NUMBER	NUMBER	NUMBER	NUMBER	ENTRG	CODE	REM	HOURS		
811019	002210	E30D057	RCBT	A DECON	2	CN	0.005	1.33		SAMPLE RCBT 'A' AT SANDPIPER PUMP
*811019	002210	E30D057	RCBT	A DECON	2	OP	0.000	2.08		SAMPLE RCBT 'A' AT SANDPIPER PUMP
820323	003362	E30D057	RCBT	A DECON	2	CN	0.020	5.25		FLUSH & SAMPLE RCBT 'A'
*820323	003362	E30D057	RCBT	A DECON	1	CH	0.005	2.33		FLUSH & SAMPLE RCBT 'A'
*820323	003362	E30D057	RCBT	A DECON	3	OP	0.043	9.33		FLUSH & SAMPLE RCBT 'A'
*820323	003362	E30D057	RCBT	A DECON	1	HP	0.010	2.75		FLUSH & SAMPLE RCBT 'A'
820328	003405	E30D057	RCBT	A DECON	1	CN	0.030	3.67		RECIRC RCBT 'A'/SAMP & DISCONNECT HOSES
*820328	003405	E30D057	RCBT	A DECON	1	OP	0.022	4.08		RECIRC RCBT 'A'/SAMP & DISCONNECT HOSES
820331	003434	E30D057	RCBT	A DECON	1	CN	0.065	3.42		REMOVE DRUMS FROM RCBT 'A'/ PUMP TO CWT
*820331	003434	E30D057	RCBT	A DECON	4	CR	0.110	10.00		REMOVE DRUMS FROM RCBT 'A'/ PUMP TO CWT
*820331	003434	E30D057	RCBT	A DECON	1	MM	0.020	1.00		REMOVE DRUMS FROM RCBT 'A'/ PUMP TO CWT
*820331	003434	E30D057	RCBT	A DECON	2	UM	0.055	5.50		REMOVE DRUMS FROM RCBT 'A'/ PUMP TO CWT
*820331	003434	E30D057	RCBT	A DECON	1	HP	0.025	2.67		REMOVE DRUMS FROM RCBT 'A'/ PUMP TO CWT
821217	005355	E30D057	RCBT	A DECON	5	CN	0.045	8.37		REMOVE EQUIP FROM RCBT 'A' ROOM
*821217	005355	E30D057	RCBT	A DECON	1	HP	0.010	1.10		REMOVE EQUIP FROM RCBT 'A' ROOM
830502	006411	E30D057	RCBT	A DECON	1	CN	0.010	1.07		REMOVE & INSTALL MANWAY/SCRAPE SAMPLES
*830502	006411	E30D057	RCBT	A DECON	4	MM	0.080	8.00		REMOVE & INSTALL MANWAY/SCRAPE SAMPLES
*830502	006411	E30D057	RCBT	A DECON	1	HP	0.020	2.43		REMOVE & INSTALL MANWAY/SCRAPE SAMPLES
SUBTOTAL EXP TRCK NUMBER = E30D057										
PERS ENTRG = 133										
EXPOS REM = 2.4520000										
RWP HOURS = 302.84000										
800414	0B2291	E30D40A	MAKEUP	FILTERS DECON	1	CN	0.010	1.33		STAGE AREA TO PULL FILTERS 2A,2B,5A,5B
*800414	0B2291	E30D40A	MAKEUP	FILTERS DECON	4	CR	0.040	4.33		STAGE AREA TO PULL FILTERS 2A,2B,5A,5B
800415	0B2301	E30D40A	MAKEUP	FILTERS DECON	3	CN	0.055	3.67		REMOVE MAKEUP FILTERS 2A & 5A
*800415	0B2301	E30D40A	MAKEUP	FILTERS DECON	2	CR	0.025	1.50		REMOVE MAKEUP FILTERS 2A & 5A
800415	0B2302	E30D40A	MAKEUP	FILTERS DECON	4	CN	0.075	5.13		MOVE FLTR TRANSPORT SHIELD TO SHLD CASK
*800415	0B2302	E30D40A	MAKEUP	FILTERS DECON	2	CR	0.010	1.67		MOVE FLTR TRANSPORT SHIELD TO SHLD CASK
*800415	0B2302	E30D40A	MAKEUP	FILTERS DECON	1	UM	0.000	1.00		MOVE FLTR TRANSPORT SHIELD TO SHLD CASK
800501	0B2716	E30D40A	MAKEUP	FILTERS DECON	5	CN	0.040	4.92		ASSESS SOLIDS ON MUF-5A FILTER HOUSING
*800501	0B2716	E30D40A	MAKEUP	FILTERS DECON	2	CR	0.020	2.00		ASSESS SOLIDS ON MUF-5A FILTER HOUSING
800909	0B4933	E30D40A	MAKEUP	FILTERS DECON	3	CN	0.015	1.83		DRY RUN TRAINING FOR FILTER CHANGE
800910	0B4944	E30D40A	MAKEUP	FILTERS DECON	9	CN	0.093	10.26		TRAINING FOR MUF CHANGE/STAGE FOR CHANGE
*800910	0B4944	E30D40A	MAKEUP	FILTERS DECON	1	EL	0.005	1.33		TRAINING FOR MUF CHANGE/STAGE FOR CHANGE
*800910	0B4944	E30D40A	MAKEUP	FILTERS DECON	1	HP	0.008	1.08		TRAINING FOR MUF CHANGE/STAGE FOR CHANGE
*800910	0B4944	E30D40A	MAKEUP	FILTERS DECON	3	CR	0.030	3.50		TRAINING FOR MUF CHANGE/STAGE FOR CHANGE
800911	0B4954	E30D40A	MAKEUP	FILTERS DECON	3	CN	0.085	3.17		REMOVE MU FILTERS 2A, 2B, 5B
*800911	0B4954	E30D40A	MAKEUP	FILTERS DECON	3	CR	0.080	3.17		REMOVE MU FILTERS 2A, 2B, 5B
*800911	0B4954	E30D40A	MAKEUP	FILTERS DECON	1	HP	0.010	1.08		REMOVE MU FILTERS 2A, 2B, 5B
800912	0B4971	E30D40A	MAKEUP	FILTERS DECON	3	CN	0.025	2.58		REMOVE MU FILTERS 2A, 2B, 5B
*800912	0B4971	E30D40A	MAKEUP	FILTERS DECON	3	CR	0.030	2.17		REMOVE MU FILTERS 2A, 2B, 5B
*800912	0B4971	E30D40A	MAKEUP	FILTERS DECON	1	HP	0.020	0.92		REMOVE MU FILTERS 2A, 2B, 5B
801010	0B5263	E30D40A	MAKEUP	FILTERS DECON	5	CN	0.083	7.50		HYDROTEST MDH FLTR/INSTL TUBING VALVES
*801010	0B5263	E30D40A	MAKEUP	FILTERS DECON	1	CR	0.010	1.17		HYDROTEST MDH FLTR/INSTL TUBING VALVES
801021	0B5366	E30D40A	MAKEUP	FILTERS DECON	2	CN	0.020	1.67		HYDRO TEST FILTER CASK SECT. OF MDH SYS.
810113	000093	E30D40A	MAKEUP	FILTERS DECON	2	CN	0.007	2.08		DECON FTS/MOVE FTS TO MODEL ROOM
*810113	000093	E30D40A	MAKEUP	FILTERS DECON	1	CR	0.010	2.00		DECON FTS/MOVE FTS TO MODEL ROOM
*810113	000093	E30D40A	MAKEUP	FILTERS DECON	1	EL	0.010	2.00		DECON FTS/MOVE FTS TO MODEL ROOM
810225	000558	E30D40A	MAKEUP	FILTERS DECON	2	CN	0.015	3.17		MOCK RUN-REMOVAL OF MU FILTERS 2A,2B,5B
*810225	000558	E30D40A	MAKEUP	FILTERS DECON	2	CR	0.008	2.33		MOCK RUN-REMOVAL OF MU FILTERS 2A,2B,5B

PNO. 6		UNC: DDS - ACTIVITY REPORT - RCS & SYSTEMS DECONTAMINATION M 286D										
* RWP	RWP	EXP TRCK		PERS	DEPT	EXPOS	RWP					
* DATE	NUMBER	NUMBER	ACTIVITY	ENTRG	CODE	REM	HOURS	TASK DESCRIPTION				
*810225	000558	E30D40A	MAKEUP FILTERS DECON	12	MM	0.120	17.67	MOCK RUN-REMOVAL OF MU FILTERS 2A, 2B, 5B				
810228	000577	E30D40A	MAKEUP FILTERS DECON	1	CN	0.025	4.32	REMOVE & PKG MU FILTERS 2A, 2B & 5B				
*810228	000577	E30D40A	MAKEUP FILTERS DECON	1	CR	0.020	4.02	REMOVE & PKG MU FILTERS 2A, 2B, & 5B				
*810228	000577	E30D40A	MAKEUP FILTERS DECON	1	HP	0.015	4.27	REMOVE & PKG MU FILTERS 2A, 2B, & 5B				
*810228	000577	E30D40A	MAKEUP FILTERS DECON	6	MM	0.152	23.29	REMOVE & PKG MU FILTERS 2A, 2B, & 5B				
810304	000621	E30D40A	MAKEUP FILTERS DECON	2	CN	0.020	4.00	OBTAIN SAMPLES/GEN CLEANUP/PHOTOGRAPHS				
*810304	000621	E30D40A	MAKEUP FILTERS DECON	1	CR	0.017	2.00	OBTAIN SAMPLES/GEN CLEANUP/PHOTOGRAPHS				
810309	000646	E30D40A	MAKEUP FILTERS DECON	2	CN	0.015	3.00	WET VAC AND GENERAL DECON				
810320	000726	E30D40A	MAKEUP FILTERS DECON	1	CN	0.000	0.33	PREJOB SITING & PHOTOGRAPHS OF MU-F-AA/B				
*810320	000726	E30D40A	MAKEUP FILTERS DECON	1	CR	0.002	0.33	PREJOB SITING & PHOTOGRAPHS OF MU-F-AA/B				
810601	001171	E30D40A	MAKEUP FILTERS DECON	2	CN	0.017	3.92	STAGE AREA FOR FILTER REMOVAL				
*810601	001171	E30D40A	MAKEUP FILTERS DECON	2	CR	0.010	3.75	STAGE AREA FOR FILTER REMOVAL				
*810601	001171	E30D40A	MAKEUP FILTERS DECON	1	AD	0.010	1.75	STAGE AREA FOR FILTER REMOVAL				
*810601	001171	E30D40A	MAKEUP FILTERS DECON	2	UM	0.005	3.75	STAGE AREA FOR FILTER REMOVAL				
820210	003007	E30D40A	MAKEUP FILTERS DECON	1	MM	0.010	0.75	WEIGH DRUM CONTAINING MU FILTER 2B				
*820210	003007	E30D40A	MAKEUP FILTERS DECON	2	UM	0.005	1.50	WEIGH DRUM CONTAINING MU FILTER 2B				
*820210	003007	E30D40A	MAKEUP FILTERS DECON	1	HP	0.008	0.83	WEIGH DRUM CONTAINING MU FILTER 2B				
820222	003096	E30D40A	MAKEUP FILTERS DECON	1	DM	0.005	1.08	CHK FOR HYDROGEN/SECURE LEAD LINER LID				
*820222	003096	E30D40A	MAKEUP FILTERS DECON	1	AD	0.005	1.00	CHK FOR HYDROGEN/SECURE LEAD LINER LID				
*820222	003096	E30D40A	MAKEUP FILTERS DECON	1	CR	0.010	1.33	CHK FOR HYDROGEN/SECURE LEAD LINER LID				
*820222	003096	E30D40A	MAKEUP FILTERS DECON	1	UM	0.010	1.08	CHK FOR HYDROGEN/SECURE LEAD LINER LID				
*820222	003096	E30D40A	MAKEUP FILTERS DECON	1	HP	0.005	1.00	CHK FOR HYDROGEN/SECURE LEAD LINER LID				
820317	003313	E30D40A	MAKEUP FILTERS DECON	3	HP	0.015	4.50	RMVE 2B, 5A&5B PLUGS/STAGE FOR FLTR PULL				
*820317	003313	E30D40A	MAKEUP FILTERS DECON	7	UM	0.020	8.75	RMVE 2B, 5A&5B PLUGS/STAGE FOR FLTR PULL				
*820317	003313	E30D40A	MAKEUP FILTERS DECON	1	DP	0.000	1.00	RMVE 2B, 5A&5B PLUGS/STAGE FOR FLTR PULL				
*820317	003313	E30D40A	MAKEUP FILTERS DECON	2	CR	0.000	2.83	RMVE 2B, 5A&5B PLUGS/STAGE FOR FLTR PULL				
*820317	003313	E30D40A	MAKEUP FILTERS DECON	1	CN	0.000	1.00	RMVE 2B, 5A&5B PLUGS/STAGE FOR FLTR PULL				
820320	003331	E30D40A	MAKEUP FILTERS DECON	3	CN	0.023	9.00	OBTAIN SPEC MEASUREMENTS FROM MU FILTERS				
*820320	003331	E30D40A	MAKEUP FILTERS DECON	1	CR	0.008	3.17	OBTAIN SPEC MEASUREMENTS FROM MU FILTERS				
*820320	003331	E30D40A	MAKEUP FILTERS DECON	1	CH	0.007	1.00	OBTAIN SPEC MEASUREMENTS FROM MU FILTERS				
820322	003332	E30D40A	MAKEUP FILTERS DECON	1	EG	0.003	0.42	PULL 4A & 4B FILTERS/VACUUM HOUSINGS				
*830322	003332	E30D40A	MAKEUP FILTERS DECON	5	HP	0.185	15.50	PULL 4A & 4B FILTERS/VACUUM HOUSINGS				
*830322	003332	E30D40A	MAKEUP FILTERS DECON	12	UM	0.372	32.66	PULL 4A & 4B FILTERS/VACUUM HOUSINGS				
*830322	003332	E30D40A	MAKEUP FILTERS DECON	2	CR	0.095	6.00	PULL 4A & 4B FILTERS/VACUUM HOUSINGS				
*830322	003332	E30D40A	MAKEUP FILTERS DECON	4	CN	0.090	12.17	PULL 4A & 4B FILTERS/VACUUM HOUSINGS				
820322	003352	E30D40A	MAKEUP FILTERS DECON	2	OP	0.229	2.25	ISOLATE MU FILTER 4A				
*820322	003352	E30D40A	MAKEUP FILTERS DECON	1	HP	0.060	1.08	ISOLATE MU FILTER 4A				
*830322	003352	E30D40A	MAKEUP FILTERS DECON	2	CN	0.220	1.92	ISOLATE MU FILTER 4A				
820324	003364	E30D40A	MAKEUP FILTERS DECON	5	UM	0.065	8.34	PULL MU FILTERS 2A & 5B				
*820324	003364	E30D40A	MAKEUP FILTERS DECON	1	CN	0.010	2.00	PULL MU FILTERS 2A & 5B				
*820324	003364	E30D40A	MAKEUP FILTERS DECON	1	CR	0.020	1.58	PULL MU FILTERS 2A & 5B				
*820324	003364	E30D40A	MAKEUP FILTERS DECON	1	HP	0.010	2.00	PULL MU FILTERS 2A & 5B				
820324	003384	E30D40A	MAKEUP FILTERS DECON	8	UM	0.455	17.91	VAC 2A, 2B, 5A, 5B MUF HOUSINGS AND FLOOR				
*820324	003384	E30D40A	MAKEUP FILTERS DECON	4	CR	0.155	9.67	VAC 2A, 2B, 5A, 5B MUF HOUSINGS AND FLOOR				
*820324	003384	E30D40A	MAKEUP FILTERS DECON	1	CN	0.050	3.00	VAC 2A, 2B, 5A, 5B MUF HOUSINGS AND FLOOR				
*820324	003384	E30D40A	MAKEUP FILTERS DECON	2	HP	0.100	5.17	VAC 2A, 2B, 5A, 5B MUF HOUSINGS AND FLOOR				
831027	007835	E30D40A	MAKEUP FILTERS DECON	5	UM	0.000	4.13	GAMMA SPEC MEASUREMENTS-MUF 2B, 5A & 5B				
*831027	007835	E30D40A	MAKEUP FILTERS DECON	2	CN	0.002	7.85	GAMMA SPEC MEASUREMENTS-MUF 2B, 5A & 5B				
*831027	007835	E30D40A	MAKEUP FILTERS DECON	1	HP	0.002	4.22	GAMMA SPEC MEASUREMENTS-MUF 2B, 5A & 5B				
840412	008812	E30D40A	MAKEUP FILTERS DECON	8	UM	0.031	11.63	INSTL SCAF & LD BRICK-CEMENT BLK SHLDG				

PNO. 7									
.TMI-2 UNC: DDS - ACTIVITY REPORT - RCS & SYSTEMS DECONTAMINATION M 286D									
* RWP	.RWP	.EXP TRCK.	.ACTIVITY		.PERS	.DEPT	.EXPOS	.RWP	
* DATE	.NUMBER	.NUMBER			.ENTRG	.CODE	.REM	.HOURS	TASK DESCRIPTION
*-----									
*840828	009801	E30D40A	MAKEUP	FILTERS DECON	5	CN	0.009	8.95	PRE-OPER TEST OF MU-P-8 ELUTION SYSTEM
*840828	009801	E30D40A	MAKEUP	FILTERS DECON	2	ES	0.005	7.58	PRE-OPER TEST OF MU-P-8 ELUTION SYSTEM
*840828	009801	E30D40A	MAKEUP	FILTERS DECON	3	QA	0.000	2.05	PRE-OPER TEST OF MU-P-8 ELUTION SYSTEM
*840828	009801	E30D40A	MAKEUP	FILTERS DECON	3	EL	0.004	2.97	PRE-OPER TEST OF MU-P-8 ELUTION SYSTEM
*840828	009801	E30D40A	MAKEUP	FILTERS DECON	11	MM	0.019	13.72	PRE-OPER TEST OF MU-P-8 ELUTION SYSTEM
*840828	009801	E30D40A	MAKEUP	FILTERS DECON	2	HP	0.005	9.18	PRE-OPER TEST OF MU-P-8 ELUTION SYSTEM
*840828	009801	E30D40A	MAKEUP	FILTERS DECON	2	IC	0.005	4.40	PRE-OPER TEST OF MU-P-8 ELUTION SYSTEM
*840828	009801	E30D40A	MAKEUP	FILTERS DECON	1	OP	0.000	5.03	PRE-OPER TEST OF MU-P-8 ELUTION SYSTEM
.SUBTOTAL		.EXP TRCK NUMBER		= E30D40A					
.PERS		.ENTRG		= 231					
.EXPOS		.REM		= 3.5390000					
.RWP		.HOURS		= 398.16000					
820127	002923	E30E33A	PWST	DECON	6	UM	0.010	20.16	REMOVE PLASTIC & SCAFFOLD TENT AT PWST
*820127	002923	E30E33A	PWST	DECON	2	HP	0.010	10.00	REMOVE PLASTIC & SCAFFOLD TENT AT PWST
*820127	002923	E30E33A	PWST	DECON	1	RW	0.008	3.67	REMOVE PLASTIC & SCAFFOLD TENT AT PWST
820707	004224	E30E33A	PWST	DECON	7	DM	0.005	19.58	REMOVE CONTAMINATED SOIL
*820707	004224	E30E33A	PWST	DECON	3	HP	0.005	11.00	REMOVE CONTAMINATED SOIL
830421	006320	E30E33A	PWST	DECON	4	IC	0.003	18.27	DECON PROCESSED WATER STORAGE TANK
*830421	006320	E30E33A	PWST	DECON	2	MM	0.005	9.25	DECON PROCESSED WATER STORAGE TANK
*830421	006320	E30E33A	PWST	DECON	1	OP	0.000	6.35	DECON PROCESSED WATER STORAGE TANK
831018	007793	E30E33A	PWST	DECON	1	MM	0.000	1.48	DECON FLANGE IN PWST PUMP HOUSE
*831018	007793	E30E33A	PWST	DECON	1	OP	0.003	1.50	DECON FLANGE IN PWST PUMP HOUSE
831026	007831	E30E33A	PWST	DECON	3	IC	0.000	1.57	DECON INSTRUMENT EQUIPMENT
831028	007839	E30E33A	PWST	DECON	16	IC	0.027	39.70	PREPARE TV CAMERAS/TEST EQUIPMENT
*831028	007839	E30E33A	PWST	DECON	3	HP	0.000	1.22	PREPARE TV CAMERAS/TEST EQUIPMENT
831103	007876	E30E33A	PWST	DECON	2	IC	0.000	3.60	EQUIPMENT DECON
.SUBTOTAL		.EXP TRCK NUMBER		= E30E33A					
.PERS		.ENTRG		= 52					
.EXPOS		.REM		= 0.0760000					
.RWP		.HOURS		= 147.35000					
821202	005221	E30H001	OTSG	B DECON	3	CN	0.001	17.08	FLUSH OTSG LINES-M-20 AREA
821202	005222	E30H001	OTSG	B DECON	7	CN	0.080	44.77	TIE-IN OTSG NEW PIPE TO OLD PIPE
830105	005486	E30H001	OTSG	B DECON	2	OP	0.000	2.33	MOVE CONTAM MATL-SDS AREA TO TURB BLDG
830105	005487	E30H001	OTSG	B DECON	2	OP	0.000	0.97	MOVE SANDPIPER TO TURBINE BLDG
830107	005504	E30H001	OTSG	B DECON	1	CM	0.000	1.20	PUMP OTSG A MAIN STEAM LINES TO CDT SUMP
*830107	005504	E30H001	OTSG	B DECON	3	OP	0.010	14.47	PUMP OTSG A MAIN STEAM LINES TO CDT SUMP
*830107	005504	E30H001	OTSG	B DECON	1	MM	0.000	0.85	PUMP OTSG A MAIN STEAM LINES TO CDT SUMP
830110	005530	E30H001	OTSG	B DECON	4	OP	0.000	17.81	PUMP OTSG 'A' STEAM & FEED LINES TO CDT
*830110	005530	E30H001	OTSG	B DECON	1	RP	0.000	8.12	PUMP OTSG 'A' STEAM & FEED LINES TO CDT
830112	005548	E30H001	OTSG	B DECON	13	OP	0.004	67.03	SET UP & OPERATE OTSG CLEANUP SYSTEM
*830112	005548	E30H001	OTSG	B DECON	3	MM	0.002	11.45	SET UP & OPERATE OTSG CLEANUP SYSTEM
*830112	005548	E30H001	OTSG	B DECON	2	HP	0.000	7.65	SET UP & OPERATE OTSG CLEANUP SYSTEM
*830112	005548	E30H001	OTSG	B DECON	2	CM	0.000	4.57	SET UP & OPERATE OTSG CLEANUP SYSTEM
*830112	005548	E30H001	OTSG	B DECON	1	RP	0.000	2.00	SET UP & OPERATE OTSG CLEANUP SYSTEM
830119	005619	E30H001	OTSG	B DECON	3	OP	0.000	22.85	SET UP/OPERATE/TEAR DOWN OTSG B CU SYS
*830119	005619	E30H001	OTSG	B DECON	1	MM	0.000	5.13	SET UP/OPERATE/TEAR DOWN OTSG B CU SYS
*830119	005619	E30H001	OTSG	B DECON	1	HP	0.005	6.57	SET UP/OPERATE/TEAR DOWN OTSG B CU SYS
*830119	005619	E30H001	OTSG	B DECON	2	CM	0.000	1.22	SET UP/OPERATE/TEAR DOWN OTSG B CU SYS
830120	005621	E30H001	OTSG	B DECON	2	CN	0.215	1.87	OPERATIONAL CHECK OF OTSG 'B' DRAIN VLVS
830121	005632	E30H001	OTSG	B DECON	27	OP	0.005	157.02	SET UP/OPERATE/TEAR DOWN OTSG B CU SYS

PNO		8									
TMI-2		UNC: DDS - ACTIVITY REPORT - RCS & SYSTEMS DECONTAMINATION M 286D									
* RWP	RWP	EXP TRCK	PERS		DEPT	EXPOS	RWP	TASK DESCRIPTION			
* DATE	NUMBER	NUMBER	ACTIVITY	ENTRG	CODE	REM	HOURS				
*830121	005632	E30H001	OTSG B DECON	12	HP	0.002	26.05	SET UP/OPERATE/TEAR DOWN OTSG B CU SYS			
*830121	005632	E30H001	OTSG B DECON	7	MM	0.002	32.30	SET UP/OPERATE/TEAR DOWN OTSG B CU SYS			
*830121	005632	E30H001	OTSG B DECON	2	RP	0.000	10.52	SET UP/OPERATE/TEAR DOWN OTSG B CU SYS			
*830121	005632	E30H001	OTSG B DECON	14	CM	0.005	12.95	SET UP/OPERATE/TEAR DOWN OTSG B CU SYS			
*830121	005632	E30H001	OTSG B DECON	1	ES	0.000	6.48	SET UP/OPERATE/TEAR DOWN OTSG B CU SYS			
830128	005682	E30H001	OTSG B DECON	2	OP	0.005	9.75	SET UP/OPERATE/TEAR DOWN OTSG B CU SYS			
*830128	005682	E30H001	OTSG B DECON	1	CM	0.000	0.82	SET UP/OPERATE/TEAR DOWN OTSG B CU SYS			
830128	005689	E30H001	OTSG B DECON	8	MM	0.000	30.87	SET UP/OPERATE/TEAR DOWN OTSG B CU SYS			
*830128	005689	E30H001	OTSG B DECON	11	OP	0.000	60.05	SET UP/OPERATE/TEAR DOWN OTSG B CU SYS			
*830128	005689	E30H001	OTSG B DECON	5	HP	0.003	11.38	SET UP/OPERATE/TEAR DOWN OTSG B CU SYS			
*830128	005689	E30H001	OTSG B DECON	2	CM	0.000	1.30	SET UP/OPERATE/TEAR DOWN OTSG B CU SYS			
830202	005722	E30H001	OTSG B DECON	3	CN	0.749	5.75	DRAIN OTSG 'B' SECONDARY SIDE			
830204	005742	E30H001	OTSG B DECON	2	CN	0.311	2.65	DRAIN OTSG 'B' SECONDARY SIDE			
830209	005786	E30H001	OTSG B DECON	1	OP	0.000	1.00	INSTALL HOSE-ALC-P-1 INF TO ALC-P-4 EFF			
*830209	005786	E30H001	OTSG B DECON	1	HP	0.005	1.00	INSTALL HOSE-ALC-P-1 INF TO ALC-P-4 EFF			
830209	005787	E30H001	OTSG B DECON	22	OP	0.005	98.09	DRAIN DOWN OTSG B TO 327 ELEV VIA CU SYS			
*830209	005787	E30H001	OTSG B DECON	13	CM	0.000	11.53	DRAIN DOWN OTSG B TO 327 ELEV VIA CU SYS			
*830209	005787	E30H001	OTSG B DECON	3	MM	0.002	12.02	DRAIN DOWN OTSG B TO 327 ELEV VIA CU SYS			
*830209	005787	E30H001	OTSG B DECON	1	RP	0.000	5.63	DRAIN DOWN OTSG B TO 327 ELEV VIA CU SYS			
*830209	005787	E30H001	OTSG B DECON	5	HP	0.000	5.70	DRAIN DOWN OTSG B TO 327 ELEV VIA CU SYS			
830214	005814	E30H001	OTSG B DECON	4	CN	0.618	5.53	DRAIN OTSG 'B' TO SUMP			
830216	005850	E30H001	OTSG B DECON	10	OP	0.005	27.11	DRAIN OTSG 'A' & 'B' VIA 4X4 CLEANUP SYS			
*830216	005850	E30H001	OTSG B DECON	3	CM	0.000	2.12	DRAIN OTSG 'A' & 'B' VIA 4X4 CLEANUP SYS			
*830216	005850	E30H001	OTSG B DECON	1	RP	0.000	3.97	DRAIN OTSG 'A' & 'B' VIA 4X4 CLEANUP SYS			
*830216	005850	E30H001	OTSG B DECON	3	HP	0.000	2.08	DRAIN OTSG 'A' & 'B' VIA 4X4 CLEANUP SYS			
830223	005908	E30H001	OTSG B DECON	5	OP	0.000	10.45	DRAIN OTSG 'A' & 'B' VIA 4X4 CLEANUP SYS			
*830223	005908	E30H001	OTSG B DECON	2	MM	0.000	2.28	DRAIN OTSG 'A' & 'B' VIA 4X4 CLEANUP SYS			
*830223	005908	E30H001	OTSG B DECON	1	HP	0.000	1.30	DRAIN OTSG 'A' & 'B' VIA 4X4 CLEANUP SYS			
830307	006002	E30H001	OTSG B DECON	9	OP	0.000	43.17	MOVE OTSG CU SYS TO XPORTER/DISMNTL EQUIP			
*830307	006002	E30H001	OTSG B DECON	1	RP	0.000	6.28	MOVE OTSG CU SYS TO XPORTER/DISMNTL EQUIP			
*830307	006002	E30H001	OTSG B DECON	1	CR	0.000	1.42	MOVE OTSG CU SYS TO XPORTER/DISMNTL EQUIP			
*830307	006002	E30H001	OTSG B DECON	1	HP	0.000	1.50	MOVE OTSG CU SYS TO XPORTER/DISMNTL EQUIP			
830725	007047	E30H001	OTSG B DECON	2	CN	0.000	1.98	REMOVE WAX INSIDE GLVBX/DECON CASK&FLOOR			
840324	008700	E30H001	OTSG B DECON	2	MM	0.000	10.00	REMOVE MS-V-3A & B FROM SYSTEM			
840828	008691	E30H001	OTSG B DECON	1	OP	0.003	1.37	REMOVE INSULATION & DECON PIPING			
*840323	008691	E30H001	OTSG B DECON	2	CN	0.007	2.25	REMOVE INSULATION & DECON PIPING			
*840323	008691	E30H001	OTSG B DECON	1	EL	0.000	0.95	REMOVE INSULATION & DECON PIPING			
*840323	008691	E30H001	OTSG B DECON	1	UM	0.002	1.35	REMOVE INSULATION & DECON PIPING			
.SUBTOTAL - EXP TRCK NUMBER = E30H001											
. PERS ENTRG = 247											
. EXPOS REM = 2.0460000											
. RWP HOURS = 865.91000											
790409	022143	E30J001	SYS & TKS RX DECON	8	CN	0.000	0.00	TRANSFER RACKS FROM A TO B POOL			
*790409	022143	E30J001	SYS & TKS RX DECON	1	MM	0.000	0.00	TRANSFER RACKS FROM A TO B POOL			
790410	022128	E30J001	SYS & TKS RX DECON	10	CN	0.167	0.00	TRANSFER RACKS FROM A TO B POOL			
*790410	022128	E30J001	SYS & TKS RX DECON	1	OP	0.030	0.00	TRANSFER RACKS FROM A TO B POOL			
*790410	022128	E30J001	SYS & TKS RX DECON	3	MM	0.020	0.00	TRANSFER RACKS FROM A TO B POOL			
801204	085768	E30J001	SYS & TKS RX DECON	7	CN	0.113	34.00	MOVE RECOMBINER TO RECEIVING DOCK			
801205	085776	E30J001	SYS & TKS RX DECON	4	CN	0.013	24.08	MOVE RECOMBINER TO RECEIVING DOCK			
830713	006947	E30J001	SYS & TKS RX DECON	2	CN	0.000	1.38	MODIFY HANDRAIL & LEG ON PLATFORM			

-34-

```

PNO. 9
.TMI-2   UNC: DDS - ACTIVITY REPORT - RCS & SYSTEMS DECONTAMINATION M 286D
* RWP   RWP   .EXP TRCK.
* DATE  NUMBER NUMBER   ACTIVITY   .PERS .DEPT .EXPOS .RWP
*=====|=====|=====|=====|=====|=====|=====|=====|
.SUBTOTAL - EXP TRCK NUMBER = E30J001
. PERS  ENTRG  = 36
. EXPOS REM    = 0.3430000
. RWP   HOURS  = 59.460000

.GRAND-TOTAL -
. PERS  ENTRG  = 1075
. EXPOS REM    = 14.740000
. RWP   HOURS  = 2552.5300
..... END REPORT .....

```


BIBLIOGRAPHIC DATA SHEET

NUREG/CR-4315, Vol. 1

3 TITLE AND SUBTITLE

Evaluation of Nuclear Facility Decommissioning Projects
Summary Status Report
Three Mile Island Unit 2
Reactor Coolant System and Systems Decontamination

2 Lead Blank

4 RECIPIENT'S ACCESSION NUMBER

5 DATE REPORT COMPLETED

MONTH | YEAR
February | 1986

6 AUTHOR(S)

D. H. Doerge, R. L. Miller, R. S. Scotti

7 DATE REPORT ISSUED

MONTH | YEAR
May | 1986

8 PERFORMING ORGANIZATION NAME AND MAILING ADDRESS (Include Zip Code)

UNC Nuclear Industries
Decommissioning Programs Department
Fed/300-A/F27, 700 Area
P. O. Box 490
Richland, WA 99352

9 PROJECT TASK/WORK UNIT NUMBER

10 FIN NUMBER

FIN B7568

11 SPONSORING ORGANIZATION NAME AND MAILING ADDRESS (Include Zip Code)

Division of Engineering Technology
Office of Nuclear Regulatory Research
U. S. Nuclear Regulatory Commission
Washington, DC 20555

12a TYPE OF REPORT

Technical

12b PERIOD COVERED (Inclusive dates)

April 5, 1979 to
December 19, 1984

13 SUPPLEMENTARY NOTES

14 ABSTRACT (200 words or less)

This document summarizes information concerning the decontamination and restoration of the Three Mile Island Unit 2 reactor coolant sytem and other plant systems which incurred damage during the loss of coolant accident experienced on March 28, 1979.

The data collected from activity reports, reactor containment entry records, and other sources were placed in a computerized information retrieval/manipulation system which permits extraction/manipulation of specific data which can be utilized in planning for recovery activities should a similar accident occur in a nuclear generating plant. The information is presented in both computer output form and in a manually assembled summary.

This report contains only the man-hours spent and radiation exposure actually incurred during performance of tasks in radiation areas and does not include support activities outside of radiation areas.

15a KEY WORDS AND DOCUMENT ANALYSIS

decontamination
radiation exposure
data acquisition

15b DESCRIPTORS

16 AVAILABILITY STATEMENT

unlimited

17 SECURITY CLASSIFICATION (This report)

unclassified

19 SECURITY CLASSIFICATION (This page)

unclassified

18 NUMBER OF PAGES

20 PRICE

\$

UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555

OFFICIAL BUSINESS
PENALTY FOR PRIVATE USE, \$300

SPECIAL FOURTH-CLASS RATE
POSTAGE & FEES PAID
USNRC
WASH D.C.
PE IMIT No. G-67