

APR 10 1987

Mr. D.F. Schnell
Vice President - Nuclear
Union Electric Company
Post Office Box 149
St. Louis, Missouri 63166

Dear Mr. Schnell:

SUBJECT: Generic Letter 83-28, Item 2.2 (Parts 1 and 2), Equipment Classification and Vendor Interface Program for all Safety Related Components

Item 2.2 (Part 1) of Generic Letter 83-28 requires licensees to describe their program for classifying safety-related components and controlling safety-related activities. Item 2.2 (Part 2) of Generic Letter 83-28 requires licensees to establish, implement and maintain a continuing program to ensure that vendor information for safety-related components is complete, current and controlled throughout the life of the plant, and appropriately referenced or incorporated in plant instructions and procedures. Union Electric Company responded to these items by submittals dated November 18, 1983; March 12, 1984; May 21, 1984; December 27, 1984; May 17, 1985; and January 27, 1987.

The staff has completed its review of your responses and finds them to be acceptable. The safety evaluation for Item 2.2 (Part 1) is in Enclosure 1, and the safety evaluation for Item 2.2 (Part 2) is in Enclosure 2. Regarding Enclosure 2, the staff has the understanding that your commitment to implement the NUTAC/VEITP program includes the objective for "Internal Handling of Vendor Services," described on page 23 of the March 1984 NUTAC report, and includes the enhancements described in Section 3.2 of the report to the extent that you can control or influence such enhancements. In addition, you should establish a program to periodically contact the vendors of key components for the exchange of technical information. For the diesel generator and safety-related switchgear vendors, a formal interface such as that with the NSSS vendor should be established if practicable.

Sincerely,

151

8704160361 870410
PDR ADCK 05000483
P PDR

B.J. Youngblood, Director
PWR Project Directorate #4
Division of PWR Licensing-A

Enclosures: As stated

cc: See next page

DISTRIBUTION:

Docket File
BJYoungblood Rdg
EJordan

Local PDR
MDuncan
JPartlow

NRC PDR
TAllexion
BGrimes

PWR#4 Reading
NThompson
ACRS(10)

PWR#4/DPWR-A
TAllexion/rad
04/10/87

PWR#4/DPWR-A
MDuncan
04/10/87

PWR#4/DPWR-A
BJYoungblood
04/10/87

Mr. D. F. Schnell
Union Electric Company

Callaway Plant
Unit No. 1

cc:

Mr. Nicholas A. Petrick
Executive Director - SNUPPS
5 Choke Cherry Road
Rockville, Maryland 20850

Lewis C. Green, Esq.
Green, Hennings & Henry
Attorney for Joint Intervenors
314 N. Broadway, Suite 1830
St. Louis, Missouri 65251

Gerald Charnoff, Esq.
Thomas A. Baxter, Esq.
Shaw, Pittman, Potts & Trowbridge
1800 M Street, N. W.
Washington, D. C. 20037

Ms. Marjorie Reilly
Energy Chairman of the League of
Women Voters of Univ. City, MO
7065 Pershing Avenue
University City, Missouri 63130

Mr. J. E. Birk
Assistant to the General Counsel
Union Electric Company
Post Office Box 149
St. Louis, Missouri 63166

Mr. Donald Bollinger, Member
Missourians for Safe Energy
6267 Delmar Boulevard
University City, Missouri 63130

U. S. Nuclear Regulatory Commission
Resident Inspectors Office
RR#1
Steedman, Missouri 65077

Mr. Dan I. Bolef, President
Kay Drey, Representative
Board of Directors Coalition
for the Environment
St. Louis Region
6267 Delmar Boulevard
University City, Missouri 63130

Mr. Donald W. Capone, Manager
Nuclear Engineering
Union Electric Company
Post Office Box 149
St. Louis, Missouri 63166

Chris R. Rogers, P.E.
Manager - Electric Department
301 W. High
Post Office Box 360
Jefferson City, Missouri 65102

Regional Administrator
U. S. NRC, Region III
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Mr. Ronald A. Kucera, Deputy Director
Department of Natural Resources
P. O. Box 176
Jefferson City, Missouri 65102

Mr. Bart D. Withers
President and Chief Executive Officer
Wolf Creek Nuclear Operating Corporation
P. O. Box 411
Burlington, Kansas 66839

ENCLOSURE 1