



Point Beach Nuclear Plant
6610 Nuclear Rd., Two Rivers, WI 54241

(920) 755-2321

NPL 98-1022

December 11, 1998

10 CFR 50.73

Document Control Desk
U.S. NUCLEAR REGULATORY COMMISSION
Mail Station P1-137
Washington, D.C. 20555

Ladies/Gentlemen:

DOCKET 50-266

LICENSEE EVENT REPORT 1998-028-00

MISSSED SURVEILLANCES REQUIRED BY THE SECTION XI PRESSURE TEST PROGRAM
CONSTITUTED AN OPERATION PROHIBITED BY TECHNICAL SPECIFICATIONS
POINT BEACH NUCLEAR PLANT, UNIT 1

Enclosed is Licensee Event Report 98-028-00 for Point Beach Nuclear Plant, Unit 1. This report is provided in accordance with 10 CFR 50.73(a)(2)(i)(B), an "operation prohibited by the plant's Technical Specifications." This report describes the discovery that five 40-month Section XI pressure tests were not performed within the required time frame.

New commitments within this report are indicated in italics.

Please contact me if you require additional information.

Sincerely,

A handwritten signature in cursive script, appearing to read 'Vito A. Kaminskas'.

Vito A. Kaminskas
Manager,
Regulatory Services & Licensing

Enclosure

CWK/tat

9812160186 981211
PDR ADOCK 05000266
S PDR

cc: NRC Resident Inspector
NRC Regional Administrator
NRC Project Manager
PSCW
INPO Support Services

11
IE 22