

ILLINOIS POWER COMPANY



CLINTON POWER STATION, P.O. BOX 678, CLINTON, ILLINOIS 61727

U-600628
L30-86(07-02)-L
1A.120

July 2, 1986

Docket No. 50-461

Director of Nuclear Reactor Regulation
Attention: Dr. W. R. Butler, Director
BWR Project Directorate No. 4
Division of BWR Licensing
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Subject: Clinton Power Station
Review of Draft Operating License

Dear Dr. Butler:

The review of the Clinton Power Station (CPS) Draft Low Power Operating License (NPF-55) that was transmitted in NRC letter dated June 18, 1986, has been completed by Illinois Power (IP). The following are IP's comments on the draft operating license:

Item (11)D., Page 6: In Illinois Power letter to the NRC (U-600552), IP requested a deferral of the Traversing Incore Probe System preoperational testing until "prior to exceeding 5% of rated reactor power" and not "prior to reactor heatup" as stated in item (b).

This change was agreed to in a June 23, 1986 discussion with Mr. B. L. Siegel and Mr. R. Becker of NRR.

If you have any questions regarding these comments or require additional information, please call me.

Sincerely yours,

F. A. Spangenberg
Manager - Licensing and Safety

8607070124 860702
PDR ADOCK 05000461
A PDR

TLR/pjr

cc: B. L. Siegel, NRC Clinton Licensing Project Manager
NRC Resident Office
Regional Administrator, Region III, USNRC
Illinois Department of Nuclear Safety

8001
1/0