

JUL 03 1986

Docket Nos. 50-361 and 50-362

Southern California Edison Company
Post Office Box 800
2244 Walnut Grove Avenue
Rosemead, CA 91770

ATTN: Mr. Kenneth P. Baskin, Vice President
Nuclear Engineering Preparedness Inspection

Gentlemen:

This refers to the special inspection conducted by Mr. G. A. Brown of this office on May 13-16, 1986 of activities authorized by NRC license Nos. NPF-10 and NPF-15 and to the discussion of our findings held by Mr. Brown with Mr. H. E. Morgan and other members of your staff at the conclusion of the inspection.

Areas examined during this inspection are described in the enclosed inspection report. Within these areas, the inspection consisted of selective examinations of procedures and representative records, interviews with personnel, and observations by the inspector.

Based on the results of this inspection, it appears that one of your activities was not conducted in full compliance with NRC regulations, as set forth in the enclosed Notice of Violation. Since you have taken corrective action, as described in the enclosure, no reply to the Notice of Violation is required.

We appreciate receiving the additional information provided in your May 16, 1986 letter. Concerning your reference to our statement of a previous violation that was similar in nature, we would like to note that our January 25, 1985 letter to you identified a similar failure to provide timely updated emergency guidance or instruction to workers necessitated by changes to the emergency facilities and equipment as required by 10 CFR 19.12. We again call your attention to the need to assure that facility changes that affect emergency response are promptly transmitted to the working level.

In accordance with 10 CFR 2790(a), a copy of this letter and the enclosure will be placed in the NRC Public Document Room.

B607080093 B60703
PDR ADDCK 05000361
Q PDR

1601
A 0455

JUL 03 1986

-2-

Should you have any questions concerning this inspection, we will be glad to discuss them with you.

Sincerely,

Original signed by
F. A. Wenslawski
F. A. Wenslawski, Chief
Emergency Preparedness and
Radiological Protection Branch

Enclosures:

- A. Notice of Violation
- B. Inspection Report
Nos. 50-361/86-15
50-362/86-15

cc w/enclosures:

- D. J. Fcgarty, SCE
- H. B. Ray, SCE
- H. E. Morgan, SCE (San Clemente)
State of CA (Tong)
- D. Matthews, EPB:IE
- F. C. Jackley, NA&EP, SCE
- D. Peacor, SCE
- S. Elkins, FEMA, Region IX

bcc w/enclosures:

- RSB/Document Control Desk (RIDS)
- Project Inspector
- Resident Inspector
- G. Cook
- B. Faulkenberry
- J. Martin

bcc w/o enclosure B:
LFMB

Region V

GBrown/dot

6/30/86

RFish

6/30/86

FWenslawski

6/30/86

AJohnson

7/1/86

~~BFaulkenberry~~

~~6/1/86~~