



Point Beach Nuclear Plant  
6610 Nuclear Rd., Two Rivers, WI 54241

(920) 755-2321

NPL 99-0300

May 20, 1999

Document Control Desk  
U.S. NUCLEAR REGULATORY COMMISSION  
Mail Station F1-137  
Washington, D.C. 20555

10 CFR 50.73


Ladies/Gentlemen:

DOCKET NOS 50-266 AND 50-301  
LICENSEE EVENT REPORT 1999-004-00  
FUEL OIL TRANSFER PUMP CABLE IN AFW PUMP ROOM  
OUTSIDE APPENDIX R DESIGN BASIS  
POINT BEACH NUCLEAR PLANT, UNITS 1 AND 2

Enclosed is Licensee Event Report 266/1999-004-00 for the Point Beach Nuclear Plant, Unit 1 and 2. This report is provided in accordance with 10 CFR 50.73(a)(2)(ii)(B) as "any event or condition that resulted in the ... nuclear power plant being: (B) in a condition that was outside the design basis of the plant." This report describes the discovery that a postulated fire in the north half of the auxiliary feed water pump room could potentially result in the disruption of the electrical power supply to the fuel oil transfer pump which provides a continuous fuel oil supply to the G-01 Emergency Diesel Generator. This condition is outside the design basis for Appendix R safe shutdown considerations.

New commitments within this report are indicated in italics.

Please contact me if you require additional information.

Sincerely,  
  
Vito A. Kaminskas  
Manager,  
Regulatory Services & Licensing

Enclosure

CWK/tat

9905260230 990520  
PDR ADOCK 05000266  
S PDR

cc: NRC Resident Inspector  
NRC Regional Administrator  
NRC Project Manager  
PSCW  
INPO Support Services

11  
IE22