

TENNESSEE VALLEY AUTHORITY

5N 157B Lookout Place

JUL 27 1988

TVA-SQN-TS-88-13

10 CFR 50.90

U.S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, D.C. 20555

Gentlemen:

In the Matter of  
Tennessee Valley Authority

)  
)

Docket Nos. 50-327  
50-328

SEQUOYAH NUCLEAR PLANT (SQN) - TECHNICAL SPECIFICATION CHANGE 88-13

In accordance with 10 CFR 50.90, we are enclosing a requested amendment to licenses DPR-77 and DPR-79 to change the technical specifications of SQN units 1 and 2. The proposed change to Surveillance Requirement 4.6.5.1.b.3, "Containment Systems Ice Condenser," replaces the visual inspection requirement using 0.38 inch with a surveillance program utilizing a 15-percent acceptance criteria.


The proposed technical specification change is identified in enclosure 1. The justification for the proposed technical specification change is provided in enclosure 2. A proposed determination of no significant hazards consideration performed pursuant to 10 CFR 50.92 is provided in enclosure 3.

Enclosed is a check for the \$150 amendment application fee required by 10 CFR 170.12.


Please direct questions you may have concerning this issue to J. W. Proffitt at (615) 870-7461.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

  
R. Gridley, Director  
Nuclear Licensing and  
Regulatory Affairs

Sworn to and subscribed before me  
this 27<sup>th</sup> day of July 1988

  
Notary Public  
My Commission Expires 2/7/90

Enclosures  
cc: See page 2

8808040125 880727  
PDR ADOCK 05000327  
P PNU

D030  
1/1  
w/check \$150  
#45410

JUL 27 1988

U.S. Nuclear Regulatory Commission

cc (Enclosures):

Ms. S. C. Black, Assistant Director  
for Projects  
TVA Projects Division  
U.S. Nuclear Regulatory Commission  
One White Flint, North  
11555 Rockville Pike  
Rockville, Maryland 20852

Mr. F. R. McCoy, Assistant Director  
for Inspection Programs  
TVA Projects Division  
U.S. Nuclear Regulatory Commission  
Region II  
101 Marietta Street, NW, Suite 2900  
Atlanta, Georgia 30323

Mr. Michael H. Mobley, Director (w/o enclosures)  
Division of Radiological Health  
T.E.R.R.A. Building  
150 9th Avenue, N  
Nashville, Tennessee 37203

Sequoyah Resident Inspector  
Sequoyah Nuclear Plant  
2600 Igou Ferry Road  
Soddy Daisy, Tennessee 37379