



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

PUBLIC SERVICE COMPANY OF COLORADO

DOCKET NO. 50-267

FORT ST. VRAIN NUCLEAR GENERATING STATION

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 61  
License No. DPR-34

1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by Public Service Company of Colorado (the licensee) dated March 29, 1988, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, as amended, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this license amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.D.(2) of Facility Operating License No. DPP-34 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 61, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. The license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Jose A. Calvo, Director  
Project Directorate - IV  
Division of Reactor Projects - III,  
IV, V and Special Projects  
Office of Nuclear Reactor Regulation

Attachment:  
Changes to the Technical  
Specifications

Date of Issuance: August 5, 1988

ATTACHMENT TO LICENSE AMENDMENT NO. 61

TO FACILITY OPERATING LICENSE NO. DPR-34

DOCKET NO. 50-267

Replace the following pages of the Appendix A Technical Specifications with the attached pages as indicated. The revised pages are identified by amendment number and contain vertical lines indicating the areas of change.

Remove

4.4-9

Insert

4.4-9

NOTES FOR TABLES 4.4-1 through 4.4-4 (continued)

- (r) Separate instrumentation is provided on each circulator for this functional unit. Only the affected helium circulator shall be shut down within 12 hours if the indicated requirements are not met.
- (s) Deleted.
- (t) A primary coolant dew point moisture monitor shall not be considered operable unless the following conditions are met:

- |    |                            |                            |
|----|----------------------------|----------------------------|
| 1) | <u>Reactor Power Range</u> | <u>Minimum Sample Flow</u> |
|    | Startup to 2%              | 1 scc/sec.                 |
|    | > 2% - 5%                  | 5 scc/sec.                 |
|    | > 5% - 20%                 | 15 scc/sec.                |
|    | > 20% - 35%                | 30 scc/sec.                |
|    | > 35% - 100%               | 50 scc/sec.                |
- 2) Minimum flow of item 1) is alarmed in the control room and the alarm is set in accordance with the power ranges specified.
- 3) Deleted.
- 4) Fixed alarms of 1 scc/sec and 75 scc/sec are operable.