

August 9, 1988

Docket No. 50-382

Mr. J. G. Dewease
Senior Vice President - Nuclear Operations
Louisiana Power and Light Company
317 Baronne Street, Mail Unit 17
New Orleans, Louisiana 70112

Dear Mr. Dewease:

SUBJECT: CONTROL ROOM AIR CONDITIONING, BASES CHANGE
(TAC NO. 67852)

By letter dated March 28, 1988, the Louisiana Power and Light Company proposed a revision to the Technical Specification (TS) Bases, B 3/4.7.6, "Control Room Air Conditioning System." The proposed change would allow a Control Room Air Handling Unit and Emergency Filtration Unit in opposite trains to be credited for system operability.

The purpose of the proposed revision is to more accurately reflect the control room air conditioning system design in the TS bases. Based on our review, we have determined that the proposed change is acceptable on a temporary basis until appropriate changes are incorporated into the TS Limiting Conditions for Operation and Surveillance Requirements. We have discussed this approach with your staff and it is our understanding that they are amenable to investigating possible changes to the TS to accomplish the same purpose. The change to the Bases is effective for six months from the date of this letter and may be extended by letter from this office on the demonstration of best efforts by LP&L. Our Safety Evaluation is enclosed for your information.

Sincerely,

/s/

David L. Wigginton, Project Manager
Project Directorate - IV
Division of Reactor Projects - III,
IV, V and Special Projects

Enclosures:

- 1) Safety Evaluation
- 2) Bases Pages B 3/4 7-3
and B 3/4 7-4

cc w/enclosures:
See next page

DISTRIBUTION

Docket File
L. Rubenstein
OGC-Rockville
PD4 Plant File

NRC PDR
J. Calvo
E. Jordan

Local PDR
P. Noonan
B. Grimes

PD4 Reading
D. Wigginton
ACRS (10)

PD4/LA *PM*
PNoonan
08/9/88

PD4/PM *DW*
DWigginton:sr/kb
08/8/88

PD4/D *MC*
JCalvo
08/9/88

DF01
11

8808150260 880809
PDR ADDCK 05000382
PDC



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

August 9, 1988

Docket No. 50-382

Mr. J. G. Dewease
Senior Vice President - Nuclear Operations
Louisiana Power and Light Company
317 Baronne Street, Mail Unit 17
New Orleans, Louisiana 70112

Dear Mr. Dewease:

SUBJECT: CONTROL ROOM AIR CONDITIONING; BASES CHANGE
(TAC NO. 67852)

By letter dated March 28, 1988, the Louisiana Power and Light Company proposed a revision to the Technical Specification (TS) Bases, B 3/4.7.6, "Control Room Air Conditioning System." The proposed change would allow a Control Room Air Handling Unit and Emergency Filtration Unit in opposite trains to be credited for system operability.

The purpose of the proposed revision is to more accurately reflect the control room air conditioning system design in the TS bases. Based on our review, we have determined that the proposed change is acceptable on a temporary basis until appropriate changes are incorporated into the TS Limiting Conditions for Operation and Surveillance Requirements. We have discussed this approach with your staff and it is our understanding that they are amenable to investigating possible changes to the TS to accomplish the same purpose. The change to the Bases is effective for six months from the date of this letter and may be extended by letter from this office on the demonstration of best efforts by LP&L. Our Safety Evaluation is enclosed for your information.

Sincerely,

A handwritten signature in dark ink, appearing to read "D. Wigginton", is written over the typed name.

David L. Wigginton, Project Manager
Project Directorate - IV
Division of Reactor Projects - III,
IV, V and Special Projects

Enclosures:

- 1) Safety Evaluation
- 2) Bases Pages B 3/4 7-3
and B 3/4 7-4

cc w/enclosures:
See next page

Mr. Jerrold G. Dewease
Louisiana Power & Light Company

Waterford 3

cc:
W. Malcolm Stevenson, Esq.
Monroe & Leiman
1432 Whitney Building
New Orleans, Louisiana 70103

Mr. E. Blake
Shaw, Pittman, Potts & Trowbridge
2300 N Street, NW
Washington, D.C. 20037

Resident Inspector/Waterford NPS
Post Office Box 822
Killona, Louisiana 70066

Mr. Ralph T. Lally
Manager of Quality Assurance
Middle South Services, Inc.
Post Office Box 61000
New Orleans, Louisiana 70161

Chairman
Louisiana Public Service Commission
One American Place, Suite 1630
Baton Rouge, Louisiana 70825-1697

Mr. R. F. Burski, Acting
Nuclear Safety and Regulatory Affairs Manager
Louisiana Power & Light Company
317 Baronne Street
New Orleans, Louisiana 70112

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
Office of Executive Director for
Operations
611 Ryan Plaza Drive, Suite 1000
Arlington, Texas 76011

Mr. William H. Spell, Administrator
Nuclear Energy Division
Office of Environmental Affairs
Post Office Box 14690
Baton Rouge, Louisiana 70898

President, Police Jury
St. Charles Parish
Hahnville, Louisiana 70057

William A. Cross
Bethesda Licensing Office
3 Metro Center
Suite 610
Bethesda, Maryland 20814