



**Commonwealth Edison**

One First National Plaza, Chicago, Illinois  
Address Reply to: Post Office Box 767  
Chicago, Illinois 60690 - 0767

August 9, 1988

U.S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, DC 20555

Subject: LaSalle County Station Unit 2  
Proposed Amendments to Primary Containment  
Isolation Valves Technical Specification  
for Facility Operating License NPF-18  
NRC Docket No. 50-374

Reference (a): Federal Register Volume 51, No. 44 dated  
March 6, 1986.

Dear Sir:

Pursuant to 10 CFR 50.90, Commonwealth Edison proposes to amend Facility Operating License NPF-18. This amendment is being submitted for your staff's review and approval with Reference (a).

This change modifies the table of primary containment isolation valves to identify new excess flow check valves being installed during the second refuel outage. These valves are being added as part of a modification to improve the reactor water level instrumentation system as required by NUREG-0737, Item II.F.2 and Generic Letter 84-23. Completion of this modification satisfies License Condition NPF-18, 2.C.(18)(c) which should be deleted from the Facility Operating License.

This proposed amendment is administrative in nature and is similar to one approved for LaSalle Unit 1 Amendment 34. That amendment dated February 10, 1986 added an excess flow check valve (ICM 102) for containment flood up instrumentation. This amendment should become effective 45 days after approval.

Attachment A provides an introduction and discussion. Attachment B provides copies of the changes to be made to the Technical Specifications. Commonwealth Edison has reviewed this document and finds that no significant hazards exists. This review is documented in Attachment C.

8808180293 880809  
PDR ADOCK 05000374  
P PNU

A001  
1/1  
w/ check \$150  
#0062041


August 9, 1988

Commonwealth Edison is notifying the State of Illinois of our request for this amendment by transmitting a copy of this letter and its attachments to the designated State Official.

In accordance with 10 CFR 170, a fee remittance in the amount of \$150.00 is enclosed.

If you have any additional questions regarding this matter, please contact this office.

Very truly yours,



C. M. Allen  
Nuclear Licensing Administrator


lm

Attachments

Enclosure: \$150.00 Fee

cc: P. Shemanski - NRR  
Regional Administrator - RIII  
NRC Resident Inspector - LSCS  
M.C. Parker - IDNS

SUBSCRIBED AND SWORN to  
before me this 9<sup>th</sup> day  
of August, 1988



Selia J. Mays  
Notary Public