

NUREG-0020
Vol. 10, No. 8
August 1986

LICENSED OPERATING REACTORS

STATUS SUMMARY REPORT
DATA AS OF 07-31-86

UNITED STATES NUCLEAR REGULATORY COMMISSION



8701080577 861231
PDR NUREG
0020 R PDR

Available from

NRC/GPO Sales Program

Superintendent of Documents
Government Printing Office
Washington, D. C. 20402

A year's subscription consists of 12 issues for
this publication.

Single copies of this publication
are available from National Technical
Information Service, Springfield, VA 22161

Microfiche of single copies are
available from NRC/GPO Sales Program
Washington, D. C. 20555

NUREG-0020
Vol. 10, No. 8
August 1986

LICENSED OPERATING REACTORS

STATUS SUMMARY REPORT
DATA AS OF 07-31-86

UNITED STATES NUCLEAR REGULATORY COMMISSION



8701080577 861231
PDR NUREG
0020 R PDR

Available from

NRC/GPO Sales Program

Superintendent of Documents
Government Printing Office
Washington, D. C. 20402

A year's subscription consists of 12 issues for
this publication.

Single copies of this publication
are available from National Technical
Information Service, Springfield, VA 22161

Microfiche of single copies are
available from NRC/GPO Sales Program
Washington, D. C. 20555

NUREG-0020
Vol. 10, No. 8
August 1986

LICENSED OPERATING REACTORS

STATUS SUMMARY REPORT

DATA AS OF 07-31-86

Manuscript Completed: December 1986
Date Published: December 1986

OFFICE OF INFORMATION RESOURCES MANAGEMENT
U.S. NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555



STATEMENT OF PURPOSE

The U.S. Nuclear Regulatory Commission's monthly LICENSED OPERATING REACTORS Status Summary Report provides data on the operation of nuclear units as timely and accurately as possible. This information is collected by the Office of Information Resources Management, from the Headquarters Staff of NRC's Office of Inspection and Enforcement, from NRC's Regional Offices, and from utilities. Since all of the data concerning operation of the units is provided by the utility operators less than two weeks after the end of the month, necessary corrections to published information are shown on the ERRATA page.

This report is divided into three sections: the first contains monthly highlights and statistics for commercial operating units, and errata from previously reported data; the second is a compilation of detailed information on each unit, provided by NRC Regional Offices, IE Headquarters and the Utilities; and the third section is an appendix for miscellaneous information such as spent fuel storage capability, reactor years of experience and non-power reactors in the United States.

The percentage computations, Items 20 through 24 in Section 2, the vendor capacity factors on page 1-7, and actual vs. potential energy production on Page 1-2 are computed using actual data for the period of consideration. The percentages listed in power generation on Page 1-2 are computed as an arithmetic average. The factors for the life-span of each unit (the "Cumulative" column) are reported by the utility and are not entirely re-computed by NRC. Utility power production data is checked for consistency with previously submitted statistics.

It is hoped this status report proves informative and helpful to all agencies and individuals interested in analyzing trends in the nuclear industry which might have safety implications, or in maintaining an awareness of the U.S. energy situation as a whole.

TABLE OF CONTENTS

GLOSSARY	PAGE
INDEX TO LICENSED UNITS	ii
	vii

SECTION 1 - CURRENT DATA SUMMARIES

MONTHLY HIGHLIGHTS OF COMMERCIAL NUCLEAR POWER UNITS	1-2
Licensed Power Reactors	1-2
Power Generation	1-2
Actual vs. Potential Energy Production	1-2
Outage Data	1-2
Reasons for Shutdown	1-3
Derated Units	1-3
Shutdowns Greater Than 72 Hours Each	1-3
UNIT AVAILABILITY, CAPACITY, AND FORCED OUTAGE RATE PLOT	1-4
AVERAGE DAILY POWER LEVEL FOR ALL COMMERCIAL OPERATING UNITS	1-5
AVERAGE CAPACITY FACTORS BY VENDOR	
Vendor Plot	1-6
Statistics	1-7
MEMORANDA - SPECIAL INFORMATION	1-8
ERRATA - CORRECTIONS TO PREVIOUSLY REPORTED DATA	1-9

SECTION 2 - OPERATING POWER REACTORS

ARKANSAS 1 THROUGH ZION 2	2-002 through 2-432
For each reactor:	
Operating Status	
Average Daily Power Level (MWe) Plot	
Unit Shutdowns/Reductions	
Summary	
Facility Data	
Inspection Status	
Licensee Reports	

SECTION 3 - APPENDIX

STATUS OF SPENT FUEL STORAGE CAPABILITY	3-2
REACTOR-YEARS OF OPERATION	3-6
NON-POWER REACTORS IN THE U.S.	3-7

G L O S S A R Y

AVERAGE DAILY POWER LEVEL (MWe)	The net electrical energy generated during the day (measured from 0001 to 2400 hours inclusive) in megawatts hours, divided by 24 hours.
LICENSED THERMAL POWER (MWt)	The maximum thermal power of the reactor authorized by the NRC, expressed in megawatts.
DATE OF COMMERCIAL OPERATION	Date unit was declared by utility owner to be available for the regular production of electricity; usually related to satisfactory completion of qualification tests as specified in the purchase contract and to accounting policies and practices of utility.
DESIGN ELECTRICAL RATING (DER) (NET MWe)	The nominal net electrical output of the unit specified by the utility and used for the purpose of plant design.
FORCED OUTAGE	An outage required to be initiated no later than the weekend following discovery of an offnormal condition.
FORCED OUTAGE HOURS	The clock hours during the report period that a unit is unavailable due to forced outages.
GROSS ELECTRICAL ENERGY GENERATED (MWH)	Electrical output of the unit during the report period as measured at the output terminals of the turbine generator, in megawatts hours.
GROSS HOURS	The clock hours from the beginning of a specified situation until its end. For outage durations, the clock hours during which the unit is not in power production.
GROSS THERMAL ENERGY GENERATED (MWH)	The thermal energy produced by the unit during the report period as measured or computed by the licensee in megawatt hours.
HOURS GENERATOR ON-LINE	Also, "Unit Service Hours." The total clock hours in the report period during which the unit operated with breakers closed to the station bus. These hours added to the total outage hours experienced by the unit during the report period, shall equal the hours in the report period.
HOURS IN REPORTING PERIOD	For units in power ascension at the end of the period, the gross hours from the beginning of the period or the first electrical production, whichever comes last, to the end of the period. For units in commercial operation at the end of the period, the gross hours from the beginning of the period or of commercial operation, whichever comes last, to the end of the period or decommissioning, whichever comes first.

G L O S S A R Y (continued)

HOURS REACTOR CRITICAL	The total clock hours in the report period during which the reactor sustained a controlled chain reaction.
MAXIMUM DEPENDABLE CAPACITY (GROSS) (MDC Gross) (Gross MWe)	Dependable main-unit gross capacity, winter or summer, whichever is smaller. The dependable capacity varies because the unit efficiency varies during the year due to cooling water temperature variations. It is the gross electrical output as measured at the output terminals of the turbine generator during the most restrictive seasonal conditions (usually summer).
MAXIMUM DEPENDABLE CAPACITY (NET) (MDC Net) (Net MWe)	Maximum Dependable Capacity (Gross) less the normal station service loads.
NAMEPLATE RATING (Gross MWe)	The nameplate power designation of the generator in megavolt amperes (MVA) times the nameplate power factor of the generator. NOTE: The nameplate rating of the generator may not be indicative of the maximum or dependable capacity, since some other item of equipment of a lesser rating (e.g., turbine) may limit unit output.
NET ELECTRICAL ENERGY GENERATED	Gross electrical output of the unit measured at the output terminals of the turbine generator during the reporting period, minus the normal station service electrical energy utilization. If this quantity is less than zero, a negative number should be recorded.
OUTAGE	A situation in which no electrical production takes place.
OUTAGE DATE	As reported on Appendix D of Reg. Guide 1.16, the date of the start of the outage. If continued from a previous month, report the same outage date but change "Method of Shutting Down Reactor" to "4 (continuations)" and add a note: "Continued from previous month."
OUTAGE DURATION	The Total clock hours of the outage measured from the beginning of the report period or the outage, whichever comes last, to the end of the report period or the outage, whichever comes first.
OUTAGE NUMBER	A number unique to the outage assigned by the licensee. The same number is reported each month in which the outage is in progress. One format is "76-05" for the fifth outage to occur in 1976.
PERIOD HOURS	See "Hours in Reporting Period."
POWER REDUCTION	A reduction in the Average Daily Power Level of more than 20% from the previous day. All power reductions are defined as outage of zero hours durations for the purpose of computing unit service and availability factors, and forced outage rate.

G L O S S A R Y (continued)

REACTOR AVAILABLE HOURS	The Total clock hours in the report period during which the reactor was critical or was capable of being made critical. (Reactor Reserve Shutdown Hours + Hours Reactor Critical.)
REACTOR AVAILABILITY FACTOR	$\frac{\text{Reactor Available Hours} \times 100}{\text{Period Hours}}$
REACTOR RESERVE SHUTDOWN	The cessation of criticality in the reactor for administrative or other similar reasons when operation could have been continued.
REACTOR RESERVE SHUTDOWN HOURS	The total clock hours in the report period that the reactor is in reserve shutdown mode. NOTE: No credit is given for NRC imposed shutdowns.
REACTOR SERVICE FACTOR	$\frac{\text{Hours Reactor Critical} \times 100}{\text{Period Hours}}$
REPORT PERIOD	Usually, the preceding calendar month. Can also be the preceding calendar year, (Year-to-Date), or the life-span of a unit (cumulative).
RESTRICTED POWER LEVEL	Maximum net electrical generation to which the unit is restricted during the report period due to the state of equipment, external conditions, administrative reasons, or a direction by NRC.
SCHEDULED OUTAGE	Planned removal of a unit from service for refueling, inspection, training, or maintenance. Those outages which do not fit the definition of "Forced Outage" perforce are "Scheduled Outages."
STARTUP AND POWER ASCENSION TEST PHASE	Period following initial criticality during which the unit is tested at successively higher levels, culminating with operation at full power for a sustained period and completion of warranty runs. Following this phase, the utility generally considers the unit to be available for commercial operation.
UNIT	The set of equipment uniquely associated with the reactor, including turbine generators, and ancillary equipment, considered as a single electrical energy production facility.
UNIT AVAILABLE HOURS	The total clock hours in the report period during which the unit operated on-line or was capable of such operation. (Unit Reserve Shutdown Hours + Hours Generator On-Line.)

G L O S S A R Y (continued).

UNIT AVAILABILITY FACTOR

$$\frac{\text{Unit Available Hours} \times 100}{\text{Period Hours}}$$

UNIT CAPACITY FACTORS

- Using Licensed Thermal Power $\frac{\text{Gross Thermal Energy Generated} \times 100}{\text{Period Hours} \times \text{Lic. Thermal Power}}$
- Using Nameplate Rating $\frac{\text{Gross Electrical Energy Generated} \times 100}{\text{Period Hours} \times \text{Nameplate Rating}}$
- Using DER $\frac{\text{Net Electrical Energy Generated} \times 100}{\text{Period Hours} \times \text{DER}}$
- Using MDC Gross $\frac{\text{Gross Electrical Energy Generated} \times 100}{\text{Period Hours} \times \text{MDC Gross}}$
- Using MDC Net $\frac{\text{Net Electrical Energy Generated} \times 100}{\text{Period Hours} \times \text{MDC Net}}$

NOTE: if MDC GROSS and/or MDC NET have not been determined, the DER is substituted for this quantity for Unit Capacity Factor calculations.

UNIT FORCED OUTAGE RATE

$$\frac{\text{Forced Outage Hours}}{\text{Unit Service Hours} + \text{Forced Outage Hours}}$$

UNIT RESERVE SHUTDOWN

The removal of the unit from on-line operation for economic or other similar reasons when operation could have been continued.

UNIT RESERVE SHUTDOWN HOURS

The total clock hours in the report period during which the unit was in reserve shutdown mode.

UNIT SERVICE FACTOR


$$\frac{\text{Unit Service Hours} \times 100}{\text{Period Hours}}$$

UNIT SERVICE HOURS

See "Hours Generator On-Line."


NOTE:

At the end of each statement in the Enforcement Summary for any given facility may be found numbers in parentheses. These numbers are related to the inspection, e.g., 8111 (the 11th inspection of the plant in 1981); and the severity level, e.g., 4 (severity level IV). Violations are ranked by severity levels from I through V with level I being the most serious. The severity level is used in the determination of any resulting enforcement action. Gray Book lists severity level by Arabic numbers corresponding to the Roman numerals. Details on the various severity levels and enforcement actions can be found in Appendix C to 10 CFR Part 2 published in the Federal Register of March 9, 1982 pages 9987 through 9995, and as corrected April 14, 1982.



INDEX TO OPERATING POWER REACTORS

	PAGE		PAGE
ARKANSAS 1	2-002	NINE MILE POINT 1	2-226
ARKANSAS 2	2-008	NORTH ANNA 1	2-230
BEAVER VALLEY 1	2-014	NORTH ANNA 2	2-234
BIG ROCK POINT 1	2-020	OCONEE 1	2-238
BROWNS FERRY 1	2-021	OCONEE 2	2-242
BROWNS FERRY 2	2-030	OCONEE 3	2-246
BROWNS FERRY 3	2-036	OYSTER CREEK 1	2-250
BRUNSWICK 1	2-040	PALISADES	2-254
BRUNSWICK 2	2-044	PALO VERDE 1	2-258
BYRON 1	2-048	PALO VERDE 2	2-264
CALLAWAY 1	2-052	PEACH BOTTOM 2	2-270
CALVERT CLIFFS 1	2-056	PEACH BOTTOM 3	2-274
CALVERT CLIFFS 2	2-062	PILGRIM 1	2-278
CATAWBA 1	2-066	POINT BEACH 1	2-282
COOK 1	2-070	POINT BEACH 2	2-286
COOK 2	2-076	PRAIRIE ISLAND 1	2-290
COOPER STATION	2-082	PRAIRIE ISLAND 2	2-294
CRYSTAL RIVER 3	2-088	QUAD CITIES 1	2-298
DAVIS-BESSE 1	2-092	QUAD CITIES 2	2-302
DIABLO CANYON 1	2-096	RANCHO SECO 1	2-306
DIABLO CANYON 2	2-100	RIVER BEND 1	2-312
DRESDEN 2	2-104	ROBINSON 2	2-316
DRESDEN 3	2-108	SALEM 1	2-320
DUANE ARNOLD	2-112	SALEM 2	2-324
FARLEY 1	2-116	SAN ONOFRE 1	2-328
FARLEY 2	2-122	SAN ONOFRE 2	2-332
FITZPATRICK	2-128	SAN ONOFRE 3	2-336
FORT CALHOUN 1	2-132	SEQUOYAH 1	2-340
FORT ST VRAIN	2-136	SEQUOYAH 2	2-346
GINNA	2-142	ST LUCIE 1	2-352
GRAND GULF 1	2-146	ST LUCIE 2	2-356
HADDAM NECK	2-152	SUMMER 1	2-360
HATCH 1	2-156	SURRY 1	2-364
HATCH 2	2-162	SURRY 2	2-368
INDIAN POINT 2	2-166	SUSQUEHANNA 1	2-372
INDIAN POINT 3	2-170	SUSQUEHANNA 2	2-376
KEWAUNEE	2-174	THREE MILE ISLAND 1	2-380
LA CROSSE	2-178	TROJAN	2-384
LASALLE 1	2-182	TURKEY POINT 3	2-390
LASALLE 2	2-188	TURKEY POINT 4	2-396
LIMERICK 1	2-192	VERMONT YANKEE 1	2-402
MAINE YANKEE	2-196	WASHINGTON NUCLEAR 2	2-406
MCGUIRE 1	2-200	WATERFORD 3	2-412
MCGUIRE 2	2-206	WOLF CREEK 1	2-416
MILLSTONE 1	2-210	YANKEE-ROWE 1	2-420
MILLSTONE 2	2-214	ZION 1	2-424
MILLSTONE 3	2-218	ZION 2	2-428
MONTICELLO	2-222		



SECTION 1

CURRENT DATA SUMMARIES

MONTHLY HIGHLIGHTS

***** 93 IN COMMERCIAL OPERATION 77,703 CAPACITY MWe (Net) --Based upon maximum dependable
 * LICENSED * (a) 3 IN POWER ASCENSION. 3,250 capacity; design elec. rating
 * POWER * --- used if MDC not determined
 * REACTORS * (b) 96 LICENSED TO OPERATE 80,953 TOTAL
 ***** (c) 4 LICENSED FOR FUEL LOADING
 AND LOW POWER TESTING

MDC NET		DER		DATE		DER	
(a) ENRICO FERMI 2	.. 1093	(b) Excludes these plants	1. DRESDEN 1.....	200	(c) SHOREHAM	... 07/03/85	820
RIVER BEND	.. 936	licensed for operation	2. HUMBOLDT BAY.....	65	CATAWBA 2	... 02/27/86	1145
PALO VERDE 2	... 1221	which are shut down	3. TMI 2.....	906	PERRY 1	... 03/18/86	1205
		indefinitely			HOPE CREEK 1	... 04/11/86	1067

		REPORT MONTH	PREVIOUS MONTH	YEAR-TO-DATE
***** 1. GROSS ELECTRICAL (MWHE)		37,117,973	32,282,943	236,300,508
* POWER * 2. NET ELECTRICAL (MWHE)		35,207,047	30,567,716	224,339,334
* GENERATION * 3. AVG. UNIT SERVICE FACTOR (%)		67.4	61.4	63.4
***** 4. AVG. UNIT AVAILABILITY FACTOR (%)		67.4	61.4	63.7
5. AVG. UNIT CAPACITY FACTOR (MDC) (%)		62.0	56.2	58.6
6. AVG. UNIT CAPACITY FACTOR (DER) (%)		60.6	54.9	57.3
7. FORCED OUTAGE RATE (%)		20.9	21.2	16.6

		% OF POTENTIAL PRODUCTION
***** 1. ENERGY ACTUALLY PRODUCED DURING THIS REPORT PERIOD.	35,207,047 NET	60.9
* ACTUAL VS. * 2. ENERGY NOT PRODUCED DUE TO SCHEDULED OUTAGES (NET).	6,403,509 MWHe	11.1
* POTENTIAL * 3. ENERGY NOT PRODUCED DUE TO FORCED OUTAGES (NET)	13,668,521 MWHe	23.6
* ENERGY * 4. ENERGY NOT PRODUCED FOR OTHER REASONS (NET)	2,531,955 MWHe	4.4
* PRODUCTION * POTENTIAL ENERGY PRODUCTION IN THIS PERIOD BY UNITS IN COMMERCIAL OPERATION	57,811,032 MWHe	100.0% TOTAL
(Using Maximum Dependable Capacity Net)		
5. ENERGY NOT PRODUCED DUE TO NRC-REQUIRED OUTAGES	370,402 MWHe	
6. ENERGY NOT PRODUCED DUE TO NRC RESTRICTED POWER LEVELS. MWHe	0 UNIT(S) WITH NRC RESTRICTION

	NUMBER	HOURS	PERCENT OF CLOCK TIME	MWHE LOST PRODUCTION
***** 1. FORCED OUTAGES DURING REPORT PERIOD	69	15,170.3	21.9	13,668,521
* OUTAGE * 2. SCHEDULED OUTAGES DURING REPORT PERIOD.	24	8,100.2	11.7	6,403,509
* DATA * TOTAL	93	23,270.5	33.6	20,072,030

MWHE LOST PRODUCTION = Down time X maximum dependable capacity net

Report Period JUL 1986

PAGE 1-2

MONTHLY HIGHLIGHTS


		NUMBER	HOURS LOST
*****	A - Equipment Failure	50	9,233.9
* REASONS *	B - Maintenance or Test	14	1,446.0
* FOR *	C - Refueling	12	6,843.4
* SHUTDOWNS *	D - Regulatory Restriction	3	903.9
*****	E - Operator Training & License Examination	0	0.0
	F - Administrative	6	4,464.0
	G - Operational Error	5	315.5
	H - Other	3	63.8
	TOTAL	93	23,270.5

	MDC (MWe Net)	POWER LIMIT (MWe Net)	TYPE
*****	836	616	Self-imposed
* DERATED *	*29	*52	Self-imposed
* UNITS *	965	515	Self-imposed
*****	436	390	Self-imposed

UNIT	REASON	UNIT	REASON	UNIT	REASON	UNIT	REASON
*****	C	BEAVER VALLEY 1	C	BIG ROCK POINT 1	B	BROWNS FERRY 1	F
* SHUTDOWNS *	F	BROWNS FERRY 3	F	BRUNSWICK 2	B	BYRON 1	A
* GREATER *	A	CATAWBA 1	A	COOK 1	A,G	COOK 2	C
* THAN 72 HRS *	A	DRESDEN 3	C	FARLEY 2	A	FORT ST VRAIN	D
* EACH *	A	HATCH 2	A	INDIAN POINT 3	A	LA CROSSE	A
*****	C	LASALLE 2	A	LIMERICK 1	A	MAINE YANKEE	B
LASALLE 1	C	MILLSTONE 3	A	MONTICELLO	C	NINE MILE POINT 1	A
MCGUIRE 1	C	PALISADES	A	PALO VERDE 1	A	PEACH BOTTOM 3	A
OYSTER CREEK 1	A	RANCHO SECO 1	A	SALEM 1	F	SAN ONOFRE 1	C
PILGRIM 1	A	SEQUOYAH 1	F,F	SEQUOYAH 2	F	SURRY 1	C
SAN ONOFRE 2	D	SUSQUEHANNA 2	A	TURKEY POINT 3	B	TURKEY POINT 4	C
SURRY 2	A	ZION 2	A				
WATERFORD 3							

Unit Availability, Capacity, Forced Outage

Avg. Unit Percentage as of 87-31-86




AVERAGE DAILY POWER LEVEL FOR ALL COMMERCIALY OPERATING UNITS

This chart depicts the average daily power level for the units in commercial operation during the month.

The straight line on the graph labelled "SUM OF MDC" is plotted at the value shown by summing the separate maximum dependable capacities of the commercially operating units (in Net MWe). The plot shown below the line is calculated by summing the separate average daily power levels of the same units for each day of the month.

The scale on the left vertical axis runs in 1,000 MWe increments from 0 to 55,000 MWe (Net). The right vertical axis shows the percentage in 10% increments, up to 100% of the "SUM OF MDC".


It should be recognized that the 100% line would be obtainable only if all of the commercially operating units operated at 100% capacity, 24 hours per day, for the entire month. In other words, since any power generator must occasionally shut down to refuel and/or perform needed maintenance, and also since 100% capacity production is not always required by power demands, the 100% line is a theoretical goal and not a practical one.



JULY 1966

Vendor Average Capacity Factors

No. OF 87-31-86



JUL 1986

NOTE: This display of average capacity factors provides a general performance comparison of plants supplied by the four nuclear steam supply system vendors. One must be careful when drawing conclusions regarding the reasons for the performance levels indicated, since plant performance may be affected by unspecified factors such as: (1) various plant designs and models are included for each vendor; (2) turbine/generators and (3) different architect/engineers are also involved.

Report Period JUL 1986

PAGE 1-6

AVERAGE CAPACITY FACTORS BY VENDORS

***** CFMDC	CFMDC	CFMDC	CFMDC
* GENERAL * 0.0 BROWNS FERRY 1	0.0 BROWNS FERRY 2	0.0 BROWNS FERRY 3	94.9 BRUNSWICK 1
* ELECTRIC * 79.7 BRUNSWICK 2	89.7 COOPER STATION	83.7 DRESDEN 2	0.0 DRESDEN 3
***** 92.6 DUANE ARNOLD	91.5 FITZPATRICK	68.8 GRAND GULF 1	96.2 HATCH 1
57.9 HATCH 2	0.0 LASALLE 1	0.0 LASALLE 2	66.4 LIMERICK 1
97.5 MILLSTONE 1	51.0 MONTICELLO	68.0 NINE MILE POINT 1	0.0 OYSTER CREEK 1
93.2 PEACH BOTTOM 2	57.2 PEACH BOTTOM 3	0.0 PILGRIM 1	90.1 QUAD CITIES 1
95.5 QUAD CITIES 2	97.7 SUSQUEHANNA 1	63.2 SUSQUEHANNA 2	72.5 VERMONT YANKEE 1
81.9 WASHINGTON NUCLEAR 2			
***** CFMDC	CFMDC	CFMDC	CFMDC
* BABCOCK & * 74.3 ARKANSAS 1	97.7 CRYSTAL RIVER 3	0.0 DAVIS-BESSE 1	97.8 OCONEE 1
* WILCOX * 91.7 OCONEE 2	89.0 OCONEE 3	0.0 RANCHO SECO 1	99.5 THREE MILE ISLAND 1

***** CFMDC	CFMDC	CFMDC	CFMDC
* COMBUSTION * 0.0 ARKANSAS 2	94.6 CALVERT CLIFFS 1	80.4 CALVERT CLIFFS 2	87.5 FORT CALHOUN 1
* ENGINEERING * 38.5 MAINE YANKEE	98.1 MILLSTONE 2	0.0 PALISADES	63.0 PALO VERDE 1
***** 85.8 SAN ONOFRE 2	88.7 SAN ONOFRE 3	103.4 ST LUCIE 1	103.0 ST LUCIE 2
62.6 WATERFORD 3			
***** CFMDC	CFMDC	CFMDC	CFMDC
* WESTINGHOUSE * 0.0 BEAVER VALLEY 1	22.2 BYRON 1	86.9 CALLAWAY 1	54.0 CATAWBA 1
***** 31.2 COOK 1	35.3 COOK 2	70.3 DIABLO CANYON 1	66.5 DIABLO CANYON 2
92.0 FARLEY 1	81.0 FARLEY 2	93.6 GINNA	30.1 HADDAM NECK
89.6 INDIAN POINT 2	6.8 INDIAN POINT 3	103.2 KEWAUNEE	0.0 MCGUIRE 1
94.8 MCGUIRE 2	74.8 MILLSTONE 3	98.9 NORTH ANNA 1	92.6 NORTH ANNA 2
97.2 POINT BEACH 1	95.6 POINT BEACH 2	100.4 PRAIRIE ISLAND 1	96.4 PRAIRIE ISLAND 2
106.5 ROBINSON 2	75.2 SALEM 1	78.8 SALEM 2	3.4 SAN ONOFRE 1
0.0 SEQUOYAH 1	0.0 SEQUOYAH 2	90.2 SUMMER 1	33.1 SURRY 1
69.7 SURRY 2	101.5 TROJAN	45.0 TURKEY POINT 3	0.0 TURKEY POINT 4
86.8 WOLF CREEK 1	90.9 YANKEE-ROWE 1	82.6 ZION 1	52.5 ZION 2

***** Units excluded are:
 * OTHER INFO * BIG ROCK POINT
 ***** DRESDEN 1
 FORT ST VRAIN
 HUMBOLDT BAY
 LACROSSE
 THREE MILE ISLAND 2

Capacity factor in this page, denoted as CFMDC, is a function of the net maximum dependable capacity. See the corresponding definition in the glossary. The vendor averages are computed by the formula:

$$\frac{\text{Net Electrical Energy Produced by Vendor}}{\text{Potential Electrical Production by Vendor in this Month}} \times 100\%$$

	GE BWRs	West PWRs	Comb PWRs	B&W PWRs	ALL PWRs
NET ELECTRICAL PRODUCTION.....	10,236,051	15,515,893	6,000,081	3,412,006	24,927,980
MDC NET.....	24,552	34,436	11,522	6,746	52,704
CFMDC.....	56.0	60.6	70.0	68.0	63.6

MEMORANDA

THE FOLLOWING UNITS USE WEIGHTED AVERAGES TO CALCULATE CAPACITY FACTORS:

ITEM 22

BIG ROCK POINT 1
CALVERT CLIFFS 1 & 2
FARLEY 1
FITZPATRICK
FORT CALHOUN 1
INDIAN POINT 2*
KEWAUNEE
OYSTER CREEK 1
POINT BEACH 1 & 2
THREE MILE ISLAND 1
TURKEY POINT 3 & 4

ITEM 22 & 23

GINNA
HADDAM NECK (CONNECTICUT YANKEE)
MAINE YANKEE
MILLSTONE 2
OCONEE 1, 2, & 3
YANKEE-ROWE 1

*COMPUTED SINCE 7/1/74, THE DATE OF COMPLETION OF A 100 DAY - 100% POWER OPERATION TEST.

THE FOLLOWING UNITS USE THE DATE OF FIRST ELECTRICAL GENERATION INSTEAD OF COMMERCIAL OPERATION,
FOR THEIR CUMULATIVE DATA:

ITEMS 20 THROUGH 24

COOK 1 & 2
BEAVER VALLEY 1
SAN ONOFRE 1

ITEM 24 ONLY

BIG ROCK POINT 1

ERRATA
CORRECTIONS TO PREVIOUSLY REPORTED DATA

NOTE: THESE CHANGES ARE REFLECTED IN THE DATA CONTAINED IN THE CURRENT REPORT

REVISED MONTHLY HIGHLIGHTS

N O N E
N O N E
N O N E
N O N E

SECTION 2

**OPERATING
POWER
REACTORS**

1. Docket: 50-313 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/86 Outage + On-line Hrs: 744.0

3. Utility Contact: J. N. GOBELL (501) 964-3251

4. Licensed Thermal Power (MWt): 2568

5. Nameplate Rating (Gross MWe): 1003 X 0.9 = 903

6. Design Electrical Rating (Net MWe): 850

7. Maximum Dependable Capacity (Gross MWe): 883

8. Maximum Dependable Capacity (Net MWe): 836

9. If Changes Occur Above Since Last Report, Give Reasons:

NONE

10. Power Level To Which Restricted, If Any (Net MWe): 616

11. Reasons for Restrictions, If Any:

FOULING AT THE TUBE SUPPORT PLATE CREVICE.

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,087.0</u>	<u>101,826.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>4,644.5</u>	<u>70,307.6</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>5,044.0</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>4,626.0</u>	<u>68,884.1</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>817.5</u>
17. Gross Therm Ener (MWH)	<u>1,448,799</u>	<u>9,561,784</u>	<u>162,146,546</u>
18. Gross Elec Ener (MWH)	<u>489,315</u>	<u>3,262,455</u>	<u>53,697,180</u>
19. Net Elec Ener (MWH)	<u>462,105</u>	<u>3,094,035</u>	<u>51,146,911</u>
20. Unit Service Factor	<u>100.0</u>	<u>90.9</u>	<u>67.6</u>
21. Unit Avail Factor	<u>100.0</u>	<u>90.9</u>	<u>68.5</u>
22. Unit Cap Factor (MDC Net)	<u>74.3</u>	<u>72.8</u>	<u>60.1</u>
23. Unit Cap Factor (DER Net)	<u>73.1</u>	<u>71.6</u>	<u>59.1</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>9.1</u>	<u>14.9</u>
25. Forced Outage Hours	<u>.0</u>	<u>461.0</u>	<u>12,021.5</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


REFUELING: 09/03/86 - 10 WEEKS.

27. If Currently Shutdown Estimated Startup Date: N/A

* ARKANSAS 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

ARKANSAS 1



JULY 1986

Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

* ARKANSAS 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System Component	Cause & Corrective Action to Prevent Recurrence
8605	07/11/86	F	0.0	H	5			POWER REDUCTION TO MAKE CONTROL ROD ADJUSTMENTS.

* SUMMARY *

ARKANSAS 1 OPERATED WITH 1 REDUCTION DURING JULY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* ARKANSAS 1 *

FACILITY DATA

Report Period J/L 1986

FACILITY DESCRIPTION

LOCATION
STATE.....ARKANSAS

COUNTY.....POPE

DIST AND DIRECTION FROM
NEAREST POPULATION CTR...6 MI WNW OF
RUSSELLVILLE, AR

TYPE OF REACTOR.....PWR

DATE INITIAL CRITICALITY...AUGUST 6, 1974

DATE ELEC ENER 1ST GENER...AUGUST 17, 1974

DATE COMMERCIAL OPERATE...DECEMBER 19, 1974

CONDENSER COOLING METHOD...ONCE THRU

CONDENSER COOLING WATER...DARDANELLE RESERVOIR

ELECTRIC RELIABILITY
COUNCIL.....SOUTHWEST POWER POOL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....ARKANSAS POWER & LIGHT

CORPORATE ADDRESS.....NINTH & LOUISIANA STREETS
LITTLE ROCK, ARKANSAS 72203

CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL

NUC STEAM SYS SUPPLIER...BABCOCK & WILCOX

CONSTRUCTOR.....BECHTEL

TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....IV

IE RESIDENT INSPECTOR.....B. JOHNSON

LICENSING PROJ MANAGER....G. VISSING
DOCKET NUMBER.....50-313

LICENSE & DATE ISSUANCE...DPR-51, MAY 21, 1974

PUBLIC DOCUMENT ROOM.....ARKANSAS TECH UNIVERSITY
RUSSELLVILLE, ARKANSAS 72801

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION CONDUCTED MAY 1-31, 1986 (86-15) ROUTINE, UNANNOUNCED INSPECTION INCLUDING OPERATIONAL SAFETY VERIFICATION, MAINTENANCE, SURVEILLANCE, FOLLOWUP ON PREVIOUSLY IDENTIFIED ITEMS, CONDENSATE STORAGE TANK CONSTRUCTION, RECEIVING INSPECTION AND PROCUREMENT CONTROL, AND PROCUREMENT DOCUMENT CONTROL. WITHIN THE SEVEN AREAS INSPECTED, ONE VIOLATION WAS IDENTIFIED.

INSPECTION CONDUCTED MAY 19-23, 1986 (86-17) A REGION IV TEAM INSPECTED LICENSEE MAINTENANCE ACTIVITIES INCLUDING MAINTENANCE PROGRAM, MAINTENANCE PROGRAM IMPLEMENTATION, INSTRUMENTATION AND CONTROL (I&C) MAINTENANCE, AND ELECTRICAL MAINTENANCE. OF THE FOUR AREAS INSPECTED, ONE VIOLATION WAS IDENTIFIED.

INSPECTION CONDUCTED JUNE 9-13, 1986 (86-18) ROUTINE, UNANNOUNCED INSPECTION OF ORGANIZATION AND ADMINISTRATION, TESTS AND EXPERIMENTS PROGRAM, AND SURVEILLANCE TEST AND CALIBRATION CONTROL PROGRAM. WITHIN THE THREE AREAS INSPECTED, TWO APPARENT VIOLATIONS WERE IDENTIFIED.

INSPECTION CONDUCTED JUNE 3-6, 1986 (86-19) ROUTINE, UNANNOUNCED INSPECTION OF THE LOCK AND KEY CONTROL SYSTEM, DETECTION AIDS - PROTECTED AREA (PA), ASSESMENT AIDS, LIGHTING, ACCESS CONTROL - PACKAGES, ACCESS CONTROL - VEHICLES, AND PHYSICAL BARRIERS - PA. WITHIN THE AREAS INSPECTED, ONE APPARANT VIOLATION WAS IDENTIFIED.

INSPECTION CONDUCTED JUNE 23-27, 1986 (86-20) ROUTINE, UNANNOUNCED INSPECTION OF LICENSED OPERATOR TRAINING AND NONLICENSED STAFF TRAINING. WITHIN THE TWO AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION CONDUCTED JUNE 1-30, 1986 (86-21) ROUTINE, UNANNOUNCED INSPECTION INCLUDING OPERATIONAL SAFETY VERIFICATION,

PAGE 2-004

Report Period JUL 1986

I N S P E C T I O N S T A T U S - (CONTINUED)

* ARKANSAS 1 *

INSPECTION SUMMARY

MAINTENANCE, SURVEILLANCE, FOLLOWUP ON PREVIOUSLY IDENTIFIED ITEMS, FOLLOWUP ON LICENSEE EVENT REPORTS, FOLLOWUP ON IE BULLETIN 85-03, REVIEW OF TRANSIENT REPORTS, AND 10 CFR 50.59 EVALUATIONS. WITHIN THE AREAS INSPECTED, ONE VIOLATION WAS IDENTIFIED.

ENFORCEMENT SUMMARY

FAILURE TO CONTROL ACCESS. SAFEGUARDS INFO. FAILURE TO CONTROL KEYS. SAFEGUARDS INFO
(8600 4)

AND UNITS 1 AND 2 TECHNICAL SPECIFICATIONS 6.10 AND 6.11 RESPECTIVELY, REQUIRE, IN PART, THAT "PROCEDURES FOR PERSONNEL RADIATION PROTECTION SHALL BE PREPARED CONSISTENT WITH THE REQUIREMENTS OF 10CFR PART 20 AND SHALL BE APPROVED, MAINTAINED AND ADHERED TO FOR ALL OPERATIONS INVOLVING PERSONNEL RADIATION EXPOSURE." CONTRARY TO THE ABOVE, THE NRC INSPECTOR DETERMINED ON MAY 21, 1986, THAT AN OBSOLETE PROCEDURE WAS BEING USED FOR THE SETUP AND OPERATION OF A PERSONNEL THERMOLUMINESCENT DOSIMETRY READER.
DETECTION AIDS - PA; SAFEGUARDS INFO.
(8601 4)

CONTRARY TO 10CFR 50.59(B), THE LICENSEE DID NOT PROVIDE A WRITTEN SAFETY EVALUATION WHICH PROVIDED THE BASES FOR THE DETERMINATION THAT A TEST PROCEDURE AND FIVE DESIGN CHANGES DID NOT INVOLVE AN UNREVIEWED SAFETY QUESTION.
(8602 4)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

POWER OPERATION

LAST IE SITE INSPECTION DATE: JUNE 1-30, 1986

INSPECTION REPORT NO: 50-313/86-21

* ARKANSAS 1 *

R E P O R T S F R O M L I C E N S E E

Report Period JUL 1986

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT

NONE			

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-368 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/86 Outage + On-line Hrs: 744.0

3. Utility Contact: D. F. HARRISON (501) 964-3743

4. Licensed Thermal Power (MWt): 2815

5. Nameplate Rating (Gross MWe): 943

6. Design Electrical Rating (Net MWe): 912

7. Maximum Dependable Capacity (Gross MWe): 897

8. Maximum Dependable Capacity (Net MWe): 858

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,087.0</u>	<u>55,655.0</u>
13. Hours Reactor Critical	<u>.0</u>	<u>3,853.3</u>	<u>39,535.3</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>1,430.1</u>
15. Hrs Generator On-Line	<u>.0</u>	<u>3,831.8</u>	<u>38,267.5</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>75.0</u>
17. Gross Therm Ener (MWH)	<u>0</u>	<u>10,664,834</u>	<u>97,702,184</u>
18. Gross Elec Ener (MWH)	<u>0</u>	<u>3,545,089</u>	<u>32,034,331</u>
19. Net Elec Ener (MWH)	<u>-2,608</u>	<u>3,381,883</u>	<u>30,490,999</u>
20. Unit Service Factor	<u>.0</u>	<u>75.3</u>	<u>68.8</u>
21. Unit Avail Factor	<u>.0</u>	<u>75.3</u>	<u>68.9</u>
22. Unit Cap Factor (MDC Net)	<u>.0</u>	<u>77.5</u>	<u>63.9</u>
23. Unit Cap Factor (DER Net)	<u>.0</u>	<u>72.9</u>	<u>60.1</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>2.6</u>	<u>15.6</u>
25. Forced Outage Hours	<u>.0</u>	<u>101.5</u>	<u>7,058.7</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: 08/23/86

 * ARKANSAS 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

ARKANSAS 2



JULY 1986

Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

* ARKANSAS 2 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
8607	06/13/86	S	744.0	C	4		RC	FUELXX	CONTINUATION OF REFUELING OUTAGE 2R5.

* SUMMARY *

ARKANSAS 2 REMAINS SHUTDOWN FOR REFUELING.

Type	Reason	Method	System & Component	
F-Forced	A-Equip Failure	F-Admin	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	2-Manual Scram	Instructions for
	C-Refueling	H-Other	3-Auto Scram	Preparation of
	D-Regulatory Restriction		4-Continued	Data Entry Sheet
	E-Operator Training		5-Reduced Load	Licensee Event Report
	& License Examination		9-Other	(LER) File (NUREG-0161)

* ARKANSAS 2 *

FACILITY DATA

Report Period JUL 1986

FACILITY DESCRIPTION

LOCATION
STATE.....ARKANSAS

COUNTY.....POPE

DIST AND DIRECTION FROM
NEAREST POPULATION CTR...6 MI WNW OF
RUSSELLVILLE, AR

TYPE OF REACTOR.....PWR

DATE INITIAL CRITICALITY...DECEMBER 5, 1978

DATE ELEC ENER 1ST GENER...DECEMBER 26, 1978

DATE COMMERCIAL OPERATE...MARCH 26, 1980

CONDENSER COOLING METHOD...COOLING TOWER

CONDENSER COOLING WATER...DARDANELLE RESERVOIR

ELECTRIC RELIABILITY
COUNCIL.....SOUTHWEST POWER POOL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....ARKANSAS POWER & LIGHT

CORPORATE ADDRESS.....NINTH & LOUISIANA STREETS
LITTLE ROCK, ARKANSAS 72203

CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL

NUC STEAM SYS SUPPLIER...COMBUSTION ENGINEERING

CONSTRUCTOR.....BECHTEL

TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....IV

IE RESIDENT INSPECTOR.....W. JOHNSON

LICENSING PROJ MANAGER....R. LEE
DOCKET NUMBER.....50-368

LICENSE & DATE ISSUANCE...NPF-6, SEPTEMBER 1, 1978

PUBLIC DOCUMENT ROOM.....ARKANSAS TECH UNIVERSITY
RUSSELLVILLE, ARKANSAS 72801

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION CONDUCTED MAY 1-31, 1986 (86-15) ROUTINE, UNANNOUNCED INSPECTION INCLUDING OPERATIONAL SAFETY VERIFICATION, MAINTENANCE, SURVEILLANCE, FOLLOWUP ON PREVIOUSLY IDENTIFIED ITEMS, CONDENSATE STORAGE TANK CONSTRUCTION, RECEIVING INSPECTION AND PROCUREMENT CONTROL, AND PROCUREMENT DOCUMENT CONTROL, FOLLOWUP ON LICENSEE EVENT REPORT, IMPLEMENTATION OF VENDOR OPERATION AND MAINTENANCE RECOMMENDATIONS. WITHIN THE AREAS INSPECTED, THREE VIOLATIONS WERE IDENTIFIED.

INSPECTION CONDUCTED MAY 19-23, 1986 (86-18) A REGION IV TEAM INSPECTED LICENSEE MAINTENANCE ACTIVITIES INCLUDING MAINTENANCE PROGRAM, MAINTENANCE PROGRAM IMPLEMENTATION, INSTRUMENTATION AND CONTROL (I&C) MAINTENANCE, AND ELECTRICAL MAINTENANCE. OF THE FOUR AREAS INSPECTED, ONE VIOLATION WAS IDENTIFIED.

INSPECTION CONDUCTED JUNE 9-13, 1986 (86-19) ROUTINE, UNANNOUNCED INSPECTION OF ORGANIZATION AND ADMINISTRATION, TESTS AND EXPERIMENTS PROGRAM, AND SURVEILLANCE TEST AND CALIBRATION CONTROL PROGRAM. WITHIN THE THREE AREAS INSPECTED, TWO APPARENT VIOLATIONS WERE IDENTIFIED.

INSPECTION CONDUCTED JUNE 3-6, 1986 (86-20) ROUTINE, UNANNOUNCED INSPECTION OF THE LOCK AND KEY CONTROL SYSTEM, DETECTION AIDS - PROTECTED AREA (PA), ASSESMENT AIDS, LIGHTING, ACCESS CONTROL - PACKAGES, ACCESS CONTROL - VEHICLES, AND PHYSICAL BARRIERS - PA. WITHIN THE AREAS INSPECTED, ONE APPARANT VIOLATION WAS IDENTIFIED.

INSPECTION CONDUCTED JUNE 23-27, 1986 (86-21) ROUTINE, UNANNOUNCED INSPECTION OF LICENSED OPERATOR TRAINING AND NONLICENSED STAFF TRAINING. WITHIN THE TWO AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION STATUS - (CONTINUED)

* ARKANSAS 2 *

INSPECTION CONDUCTED JUNE 1-30, 1986 (86-22) ROUTINE, UNANNOUNCED INSPECTION INCLUDING OPERATIONAL SAFETY VERIFICATION, MAINTENANCE, SURVEILLANCE, FOLLOWUP ON PREVIOUSLY IDENTIFIED ITEMS, FOLLOWUP ON LICENSEE EVENT REPORTS, FOLLOWUP ON IE BULLETIN 85-03, REVIEW OF TRANSIENT REPORTS, AND 10 CFR 50.59 EVALUATIONS. WITHIN THE AREAS INSPECTED, ONE VIOLATION WAS IDENTIFIED.

FAILURE TO CONTROL ACCESS. SAFEGUARDS INFO. FAILURE TO CONTROL KEYS. SAFEGUARDS INFO.
(8600 4)

AND UNITS 1 AND 2 TECHNICAL SPECIFICATIONS 6.10 AND 6.11 RESPECTIVELY, REQUIRE, IN PART, THAT "PROCEDURES FOR PERSONNEL RADIATION PROTECTION SHALL BE PREPARED CONSISTENT WITH THE REQUIREMENTS OF 10CFR PART 20 AND SHALL BE APPROVED, MAINTAINED AND ADHERED TO FOR ALL OPERATIONS INVOLVING PERSONNEL RADIATION EXPOSURE." CONTRARY TO THE ABOVE, THE NRC INSPECTOR DETERMINED ON MAY 21, 1986, THAT AN OBSOLETE PROCEDURE WAS BEING USED FOR THE SETUP AND OPERATION OF A PERSONNEL THERMOLUMINESCENT DOSIMETRY READER.

DETECTION AIDS - PA; SAFEGUARDS INFO CONTRARY TO TECHNICAL SPECIFICATION 6.8.1, THE POST-MAINTENANCE TEST PROCEDURE FOR BATTERY CHARGER 2D34 WAS NOT FOLLOWED.
(8602 4)

SYSTEMS AND COMPONENT PROBLEMS:

FACILITY ITEMS (PLANS AND PROCEDURES):

MANAGERIAL ITEMS:

PLANT STATUS:

LAST IE SITE INSPECTION DATE: JUNE 1-30, 1986

INSPECTION REPORT NO: 50-368/86-22

Report Period JUL 1986

REPORTS FROM LICENSEE

ARKANSAS 2

=====	=====	=====	=====	=====
NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT	
-----	-----	-----	-----	-----
NONE				
=====	=====	=====	=====	=====

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-334 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/86 Outage + On-line Hrs: 744.0

3. Utility Contact: P. A. SMITH (412) 643-1825

4. Licensed Thermal Power (Mwt): 2652

5. Nameplate Rating (Gross MWe): 1026 X 0.9 = 923

6. Design Electrical Rating (Net MWe): 835

7. Maximum Dependable Capacity (Gross MWe): 860

8. Maximum Dependable Capacity (Net MWe): 810

9. If Changes Occur Above Since Last Report, Give Reasons:

NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,087.0</u>	<u>89,855.0</u>
13. Hours Reactor Critical	<u>.0</u>	<u>3,220.1</u>	<u>48,825.0</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>4,482.7</u>
15. Hrs Generator On-Line	<u>.0</u>	<u>3,217.5</u>	<u>47,352.4</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>0</u>	<u>8,049,760</u>	<u>111,073,182</u>
18. Gross Elec Ener (MWH)	<u>0</u>	<u>2,638,550</u>	<u>35,419,990</u>
19. Net Elec Ener (MWH)	<u>-3,120</u>	<u>2,480,490</u>	<u>33,016,703</u>
20. Unit Service Factor	<u>.0</u>	<u>63.2</u>	<u>55.1</u>
21. Unit Avail Factor	<u>.0</u>	<u>63.2</u>	<u>55.1</u>
22. Unit Cap Factor (MDC Net)	<u>.0</u>	<u>60.2</u>	<u>48.8</u>
23. Unit Cap Factor (DER Net)	<u>.0</u>	<u>58.4</u>	<u>47.3</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>1.4</u>	<u>22.6</u>
25. Forced Outage Hours	<u>.0</u>	<u>44.7</u>	<u>18,534.9</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


NONE

27. If Currently Shutdown Estimated Startup Date: 08/17/86

* BEAVER VALLEY 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

BEAVER VALLEY 1



JULY 1986

Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

* BEAVER VALLEY 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
7	08/17/86	S	744.0	C	4		RC	FUELXX	STATION REMAINED SHUTDOWN FOR THE FIFTH REFUELING.

* SUMMARY *

BEAVER VALLEY 1 REMAINS SHUTDOWN FOR REFUELING.

Type	Reason	Method	System & Component	
F-Forced	A-Equip Failure	F-Admin	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	2-Manual Scram	Instructions for
	C-Refueling	H-Other	3-Auto Scram	Preparation of
	D-Regulatory Restriction		4-Continued	Data Entry Sheet
	E-Operator Training		5-Reduced Load	Licensee Event Report
	& License Examination		9-Other	(LER) File (NUREG-0161)

* BEAVER VALLEY 1 *

FACILITY DATA

Report Period JUL 1986

FACILITY DESCRIPTION

LOCATION
STATE.....PENNSYLVANIA

COUNTY.....BEAVER

DIST AND DIRECTION FROM
NEAREST POPULATION CTR...5 MI E OF
E. LIVERPOOL, OH

TYPE OF REACTOR.....PWR

DATE INITIAL CRITICALITY...MAY 10, 1976

DATE ELEC ENER 1ST GENER...JUNE 14, 1976

DATE COMMERCIAL OPERATE...OCTOBER 1, 1976

CONDENSER COOLING METHOD...COOLING TOWER

CONDENSER COOLING WATER...OHIO RIVER

ELECTRIC RELIABILITY
COUNCIL.....EAST CENTRAL AREA
RELIABILITY COORDINATION
AGREEMENT

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....DUQUESNE LIGHT

CORPORATE ADDRESS.....ONE OXFORD CENTRE, 301 GRANT STREET
PITTSBURGH, PENNSYLVANIA 15279

CONTRACTOR
ARCHITECT/ENGINEER.....STONE & WEBSTER

NUC STEAM SYS SUPPLIER...WESTINGHOUSE

CONSTRUCTOR.....STONE & WEBSTER

TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I

IE RESIDENT INSPECTOR.....W. TROSKOSKI

LICENSING PROJ MANAGER.....P. TAM
DOCKET NUMBER.....50-334

LICENSE & DATE ISSUANCE....DPR-66, JULY 2, 1976

PUBLIC DOCUMENT ROOM.....B.F. JONES MEMORIAL LIBRARY
633 FRANKLIN AVENUE
ALIQUIPPA, PA 15001

INSPECTION STATUS

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

10 CFR 71.5 PROHIBITS DELIVERY OF LICENSED MATERIAL TO A CARRIER FOR TRANSPORT UNLESS THE LICENSEE COMPLIES WITH APPLICABLE REGULATIONS OF THE DEPARTMENT OF TRANSPORTATION IN 49 CFR PARTS 170-189. 49 CFR 173.425(B)(1), "TRANSPORT REQUIREMENTS FOR LOW SPECIFIC ACTIVITY (LSA) RADIOACTIVE MATERIALS," REQUIRES THAT PACKAGED SHIPMENTS OF LSA MATERIAL CONSIGNED AS EXCLUSIVE USE BE PACKAGED IN STRONG, TIGHT PACKAGES SO THAT THERE WILL BE NO LEAKAGE OF RADIOACTIVE MATERIAL UNDER CONDITIONS NORMALLY INCIDENT TO TRANSPORTATION. CONTRARY TO THE ABOVE ON OCTOBER 17, 1985, TWO 55-GALLON STEEL DRUMS (DRUMS NO. 14 AND 24) CONTAINING LOW SPECIFIC ACTIVITY MATERIAL WERE CONSIGNED TO A CARRIER FOR EXCLUSIVE USE TO TRANSPORT TO QUADREX CORPORATION IN OAK RIDGE, TENNESSEE, AND THE DRUMS WERE NOT STRONG AND TIGHT. SPECIFICALLY, DRUM NO. 14 CONTAINING 0.021 MILLICURIES OF RADIOACTIVE MATERIAL HAD FOUR HOLES, APPROXIMATELY 1/4 INCH IN DIAMETER, THAT PENETRATED TO THE INSIDE OF THE BARREL AND WERE LOCATED ABOUT ONE INCH BELOW THE BARREL LID LOCKING RING. DRUM NO. 24 WAS PUNCTURED ON THE BOTTOM, AND THE PUNCTURES CONSISTED OF TWO "SLASHES" ABOUT THREE INCHES LONG BY 1/4 INCH WIDE, WHICH HAD BEEN COVERED WITH YELLOW TAPE. 10 CFR 71.101(B) REQUIRES EACH LICENSEE TO ESTABLISH A QUALITY ASSURANCE PROGRAM FOR PACKAGES. 10 CFR 71.101(F) STATES THAT A COMMISSION APPROVED QUALITY ASSURANCE PROGRAM THAT SATISFIES THE APPLICABLE CRITERIA OF APPENDIX B, PART 50, OF THIS CHAPTER, AND WHICH IS ESTABLISHED, MAINTAINED, AND EXECUTED WITH REGARD TO TRANSPORT PACKAGES WILL BE ACCEPTED AS SATISFYING THE REQUIREMENTS OF PARAGRAPH (B) OF

ENFORCEMENT SUMMARY

THIS SECTION. CRITERION XVIII OF APPENDIX B, PART 50, REQUIRES, IN PART, THAT A COMPREHENSIVE SYSTEM OF PLANNED AND PERIODIC AUDITS BE CARRIED OUT TO VERIFY COMPLIANCE WITH ALL ASPECTS OF THE QUALITY ASSURANCE PROGRAM AND TO DETERMINE THE EFFECTIVENESS OF THE PROGRAM. THE AUDITS SHALL BE PERFORMED BY APPROPRIATELY TRAINED PERSONNEL. CONTRARY TO THE ABOVE, DURING THE PERIOD OF JUNE-JULY 1985, QUALITY ASSURANCE MAINTENANCE PERSONNEL CONDUCTED AN AUDIT OF THE SOLID WASTE MANAGEMENT AREA, AND THE THREE AUDITORS PERFORMING THE AUDIT HAD NOT BEEN ADEQUATELY TRAINED TO ASSURE THAT SUITABLE PROFICIENCY WAS ACHIEVED AND MAINTAINED. SPECIFICALLY, ALTHOUGH THE LEAD AUDITOR RECEIVED TWO TO THREE DAYS TRAINING IN TRANSPORTATION ACTIVITIES IN MAY 1984, AND THE OTHER AUDITORS RECEIVED TWO DAYS TRAINING DURING THE PERIOD OF OCTOBER-NOVEMBER 1985, THIS TRAINING WAS NOT ADEQUATE IN THAT THE TRAINING MATERIAL PROVIDED WAS TOO VOLUMINOUS AND COMPLEX TO BE ABSORBED AND RETAINED IN A TWO DAY TRAINING PROGRAM. CONTRARY TO TS 4.3.3.5, MONTHLY REMOTE SHUTDOWN MONITORING INSTRUMENTATION CHANNEL CHECK FAILED TO QUALITATIVELY ASSESS TRB-RH-606 AS INOPERABLE WHEN INDICATED READINGS WERE OFF-SCALE LOW AT LESS THAN EXPECTED AMBIENT. CONTRARY TO TS 4.3.3.6.1, THE LICENSEE FAILED TO DEMONSTRATE INDIVIDUAL SMOKE DETECTOR OPERABILITY IN THE NO. 2 DG ROOM DURING PERFORMANCE OF A SURVEILLANCE TEST. (8600 4)

TECHNICAL SPECIFICATION 6.8, PROCEDURES, REQUIRES THAT PROCEDURES BE ESTABLISHED, IMPLEMENTED AND MAINTAINED. ITEM E.12 OF STATION ADMINISTRATION PROCEDURE, CHAPTER 6, RADIOLOGICAL CONTROL GROUP ADMINISTRATION, DEVELOPED PURSUANT TO THE ABOVE, REQUIRES THAT PROCEDURES BE REVIEWED AT A MINIMUM INTERVAL OF EVERY TWO YEARS, OR AFTER SIGNIFICANT CHANGES OR INCIDENTS, TO DETERMINE IF CHANGES TO THE PROCEDURES ARE NECESSARY OR DESIRABLE. CONTRARY TO THE ABOVE, AS OF MARCH 14, 1986, PROCEDURE NO. FO-OP-004, "DEWATERING PROCEDURE FOR THE 24 INCH DIAMETER PRESSURE DEMINERALIZER VESSEL CONTAINING ION EXCHANGE RESINS," USED ON AT LEAST ONE OCCASION DURING 1985, HAD NOT BEEN REVIEWED SINCE JUNE 15, 1983, AN INTERVAL OF MORE THAN TWO YEARS.

10 CFR 71.12(A) PERMITS A GENERAL LICENSE TO BE ISSUED TO ANY LICENSEE OF THE COMMISSION TO TRANSPORT, OR DELIVER TO A CARRIER FOR TRANSPORT, LICENSED MATERIAL IN A PACKAGE FOR WHICH A CERTIFICATE OF COMPLIANCE HAS BEEN ISSUED BY THE NRC. 10 CFR 71.12(C)(1) STATES IN PART, THAT THIS GENERAL LICENSE APPLIES ONLY TO A LICENSEE WHO HAS A COPY OF THE CERTIFICATE OF COMPLIANCE AND HAS THE DRAWINGS AND OTHER DOCUMENTS REFERENCED IN THE APPROVAL RELATING TO THE USE AND MAINTENANCE OF THE PACKAGING AND TO THE ACTIONS TO BE TAKEN PRIOR TO SHIPMENT. CONTRARY TO THE ABOVE, ON APRIL 23, 1985, THE LICENSEE DELIVERED TO A CARRIER FOR TRANSPORT 29.14 CURIES OF LICENSED MATERIAL IN A PACKAGE, MODEL NO. CNS 6-80-2, CERTIFICATE OF COMPLIANCE (C OF C) NO. 9111, AND ALTHOUGH THE LICENSEE HAD A REDUCED COPY OF A DRAWING, IT COULD NOT BE VERIFIED AS THE REFERENCED DRAWING BECAUSE IDENTIFICATION NUMBER WAS NOT LEGIBLE. (8600 5)

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

Report Period JUL 1986

I N S P E C T I O N S T A T U S - (CONTINUED)

* BEAVER VALLEY 1 *

OTHER ITEMS

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S F R O M L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT

NO INPUT PROVIDED.			

=====

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-155 OPERATING STATUS

2. Reporting Period: 07/01/86 Outage + On-line Hrs: 744.0

3. Utility Contact: J. P. JOHNSTON (616) 547-6537

4. Licensed Thermal Power (MWt): 240

5. Nameplate Rating (Gross MWe): 70.6 X 0.85 = 60

6. Design Electrical Rating (Net MWe): 72

7. Maximum Dependable Capacity (Gross MWe): 73

8. Maximum Dependable Capacity (Net MWe): 69

9. If Changes Occur Above Since Last Report, Give Reasons: NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____


11. Reasons for Restrictions, If Any: NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,087.0</u>	<u>204,618.0</u>
13. Hours Reactor Critical	<u>498.9</u>	<u>4,714.3</u>	<u>145,946.1</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>482.9</u>	<u>4,688.7</u>	<u>143,329.7</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>101,893</u>	<u>978,605</u>	<u>27,023,874</u>
18. Gross Elec Ener (MWH)	<u>32,675</u>	<u>313,248</u>	<u>8,554,436</u>
19. Net Elec Ener (MWH)	<u>30,965</u>	<u>297,468</u>	<u>8,089,631</u>
20. Unit Service Factor	<u>64.9</u>	<u>92.2</u>	<u>70.0</u>
21. Unit Avail Factor	<u>64.9</u>	<u>92.2</u>	<u>70.0</u>
22. Unit Cap Factor (MDC Net)	<u>60.3</u>	<u>84.7</u>	<u>58.8*</u>
23. Unit Cap Factor (DER Net)	<u>57.8</u>	<u>81.2</u>	<u>54.9</u>
24. Unit Forced Outage Rate	<u>35.1</u>	<u>7.8</u>	<u>14.8</u>
25. Forced Outage Hours	<u>261.1</u>	<u>398.3</u>	<u>11,747.4</u>
26. Shutoffs Sched Over Next 6 Months (Type, Date, Duration):	<u>NONE</u>		

27. If Currently Shutdown Estimated Startup Date: N/A

 * BIG ROCK POINT 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
 BIG ROCK POINT 1



JULY 1986

* Item calculated with a Weighted Average

Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

 * BIG ROCK POINT 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
86-03	07/01/86	F	261.1	B	3	86-05			THE PLANT TRIPPED DURING THE PERFORMANCE OF A ROUTINE REACTOR PROTECTION SYSTEM SURVEILLANCE TEST.

 * SUMMARY *

BIG ROCK POINT 1 OPERATED WITH 1 OUTAGE DUE TO SURVEILLANCE TESTING.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* BIG ROCK POINT 1 *

FACILITY DATA

Report Period JUL 1986

FACILITY DESCRIPTION

LOCATION
STATE.....MICHIGAN
COUNTY.....CHARLEVOIX
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...4 MI NE OF
CHARLEVOIX, MICH
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...SEPTEMBER 27, 1962
DATE ELEC ENER 1ST GENER...DECEMBER 8, 1962
DATE COMMERCIAL OPERATE...MARCH 29, 1963
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...LAKE MICHIGAN
ELECTRIC RELIABILITY
COUNCIL.....EAST CENTRAL AREA
RELIABILITY COORDINATION
AGREEMENT

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....CONSUMERS POWER
CORPORATE ADDRESS.....212 WEST MICHIGAN AVENUE
JACKSON, MICHIGAN 49201
CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III
IE RESIDENT INSPECTOR.....S. GUTHRIE
LICENSING PROJ MANAGER....T. ROTELLA
DOCKET NUMBER.....50-155
LICENSE & DATE ISSUANCE...DPR-6, AUGUST 30, 1962
PUBLIC DOCUMENT ROOM.....NORTH CENTRAL MICHIGAN COLLEGE
1515 HOWARD STREET
PETOSKEY, MICHIGAN 49770

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION ON AUGUST 13, 1985 THROUGH MARCH 14, 1986 (85015): SPECIAL INSPECTION OF ALLEGATIONS PERTAINING TO THE SECURITY PROGRAM. ALTHOUGH SOME ALLEGATIONS WERE SUBSTANTIATED, THE LICENSEE WAS FOUND TO BE IN COMPLIANCE WITHIN THE AREAS EXAMINED.

INSPECTION ON APRIL 9 THROUGH JULY 10 (86007): ROUTINE, UNANNOUNCED INSPECTION CONDUCTED BY THE SENIOR RESIDENT INSPECTOR OF LICENSEE ACTIONS ON PREVIOUS INSPECTION FINDINGS, OPERATIONAL SAFETY, MAINTENANCE OPERATION, SURVEILLANCE OBSERVATION, REACTOR TRIPS, IE BULLETINS, TMI ACTION ITEMS, LICENSEE EVENT REPORT FOLLOWUP, LICENSING ACTIONS, AND TRAINING. ONE VIOLATION WAS IDENTIFIED (FAILURE OF THE OPERATOR TO MAINTAIN DESIRED CONTROL ROD POSITION AND TO INVESTIGATE THE ABNORMAL BEHAVIOR OF SLUGGISH CONTROL ROD MOVEMENT).

INSPECTION ON JUNE 24-27 (86010): ROUTINE, ANNOUNCED INSPECTION OF THE EFFECTIVENESS OF NON-LICENSED PERSONNEL TRAINING (INSPECTION PROCEDURE 41400) AND LICENSED PERSONNEL TRAINING (INSPECTION PROCEDURE 41701). IN THE TWO AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

Report Period JUL 1986

I N S P E C T I O N S T A T U S - (CONTINUED)

* BIG ROCK POINT 1 *

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

RESTART ON 07/12/86 - NOW OPERATING ROUTINELY

LAST IE SITE INSPECTION DATE: 08/08/86

INSPECTION REPORT NO: 86012

R E P O R T S F R O M L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
86-04	06/04/86	07/25/86	BATTERY SERVICE TEST TECHNICAL SPECIFICATION CONTRADICTION
86-05	07/01/86	07/31/86	NEUTRON MONITORING SYSTEM CABLE FAILURE RESULTING IN REACTOR TRIP

=====

1. Docket: 50-259 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/86 Outage + On-line Hrs: 744.0

3. Utility Contact: K. L. CREAMER (205) 729-2955

4. Licensed Thermal Power (MWt): 3293

5. Nameplate Rating (Gross MWe): 1280 X 0.9 = 1152

6. Design Electrical Rating (Net MWe): 1065

7. Maximum Dependable Capacity (Gross MWe): 1098

8. Maximum Dependable Capacity (Net MWe): 1065

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,087.0</u>	<u>105,193.0</u>
13. Hours Reactor Critical	<u>.0</u>	<u>.0</u>	<u>59,520.9</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>6,996.8</u>
15. Hrs Generator On-Line	<u>.0</u>	<u>.0</u>	<u>58,276.4</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>0</u>	<u>0</u>	<u>167,963,338</u>
18. Gross Elec Ener (MWH)	<u>0</u>	<u>0</u>	<u>55,393,130</u>
19. Net Elec Ener (MWH)	<u>-5,300</u>	<u>-21,872</u>	<u>53,695,137</u>
20. Unit Service Factor	<u>.0</u>	<u>.0</u>	<u>55.4</u>
21. Unit Avail Factor	<u>.0</u>	<u>.0</u>	<u>55.4</u>
22. Unit Cap Factor (MDC Net)	<u>.0</u>	<u>.0</u>	<u>47.9</u>
23. Unit Cap Factor (DER Net)	<u>.0</u>	<u>.0</u>	<u>47.9</u>
24. Unit Forced Outage Rate	<u>100.0</u>	<u>100.0</u>	<u>32.7</u>
25. Forced Outage Hours	<u>744.0</u>	<u>5,087.0</u>	<u>28,265.1</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: 03/15/89

* BROWNS FERRY 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT BROWNS FERRY 1



JULY 1986

Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

* BROWNS FERRY 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System Component	Cause & Corrective Action to Prevent Recurrence
315	06/01/85	F	744.0	F	4			ADMINISTRATIVE HOLD TO RESOLVE VARIOUS TVA AND NRC CONCERNS.

* SUMMARY *

BROWNS FERRY 1 REMAINS SHUTDOWN FOR AN ADMINISTRATIVE OUTAGE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* BROWNS FERRY 1 *

FACILITY DATA

Report Period JUL 1986

FACILITY DESCRIPTION

UTILITY & CONTRACTOR INFORMATION

LOCATION
STATE.....ALABAMA
COUNTY.....LIMESTONE
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...10 MI NW OF
DECATUR, ALA
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...AUGUST 17, 1973
DATE ELEC ENER 1ST GENER...OCTOBER 15, 1973
DATE COMMERCIAL OPERATE....AUGUST 1, 1974
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER....TENNESSEE RIVER
ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY
LICENSEE.....TENNESSEE VALLEY AUTHORITY
CORPORATE ADDRESS.....500A CHESTNUT STREET TOWER II
CHATTANOOGA, TENNESSEE 37401
CONTRACTOR
ARCHITECT/ENGINEER.....TENNESSEE VALLEY AUTHORITY
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....TENNESSEE VALLEY AUTHORITY
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
IE RESIDENT INSPECTOR.....J. PAULK
LICENSING PROJ MANAGER.....J. GEARS
DOCKET NUMBER.....50-259
LICENSE & DATE ISSUANCE....DPR-33, DECEMBER 20, 1973
PUBLIC DOCUMENT ROOM.....ATHENS PUBLIC LIBRARY
SOUTH AND FORREST
ATHENS, ALABAMA 35611

INSPECTION STATUS

INSPECTION SUMMARY

+ INSPECTION MAY 19-23 (86-17): THIS WAS A ROUTINE, UNANNOUNCED INSPECTION IN THE AREAS OF OBSERVATION OF NONDESTRUCTIVE EXAMINATION ACTIVITIES PERFORMED IN ACCORDANCE WITH NRC GENERIC LETTER 84-11, NONDESTRUCTIVE EXAMINATION DATA REVIEW AND EVALUATION, INDEPENDENT RE-EXAMINATION OF RECIRCULATION SYSTEM WELDS AND FOLLOWUP ON PREVIOUS ENFORCEMENT ITEMS. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JUNE 16-20 (86-21): THIS ROUTINE, UNANNOUNCED INSPECTION WAS CONDUCTED BY TWO INSPECTORS AND CONSISTED OF A REVIEW OF THE LICENSEE'S: SECURITY PROGRAM AUDIT; RECORDS AND REPORTS; TESTING AND MAINTENANCE; PHYSICAL BARRIERS-VITAL AREAS; SECURITY SYSTEMS POWER SUPPLY; ALARM STATIONS; AND PERSONNEL TRAINING AND QUALIFICATIONS-GENERAL REQUIREMENTS. THE LICENSEE WAS FOUND TO BE IN COMPLIANCE WITH REGULATORY REQUIREMENTS WITHIN THE SEVEN AREAS INSPECTED.

INSPECTION JUNE 1-30 (86-22): THIS ROUTINE INSPECTION WAS IN THE AREAS OF OPERATIONAL SAFETY, MAINTENANCE OBSERVATION, SURVEILLANCE TESTING OBSERVATION, REPORTABLE OCCURRENCES AND DESIGN MODIFICATIONS. ONE VIOLATION - 10CFR 50, APPENDIX B, CRITERION III FOR DESIGN CONTROL OF CABLE PULLING ACTIVITIES.

INSPECTION JUNE 23-25 (86-23): THIS ROUTINE, UNANNOUNCED INSPECTION WAS IN THE AREA OF ULTRASONIC EXAMINATION OF THE REACTOR VESSEL NOZZLE THERMAL SLEEVE WELDS UTILIZING TVA'S AUTOMATED ULTRASONIC SYSTEM (INTRASPECT-98). NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

MANAGEMENT MEETING JUNE 24 (86-24): A MANAGEMENT MEETING WAS HELD AT REGION II ON JUNE 24, 1986, AT 11:00 A.M. EDT, TO DISCUSS
PAGE 2-026

* BROWNS FERRY 1 *

CABLE PULLING ISSUES. TVA'S REVISED SPECIFICATIONS FOR INSTALLATION OF ELECTRICAL CABLE AND CONDUIT WERE NOT IMPLEMENTED FOR MODIFICATIONS AT BROWNS FERRY WHEN ISSUED. TVA GAVE A CHRONOLOGY OF EVENTS CONCERNING CABLE PULLING INCLUDING: (1) WHICH SITES WERE USING THE NEW SPECIFICATIONS; (2) THE RATIONALE FOR USING THE OLD SPECIFICATION AT BFNP UNIT 2; (3) BFNP CORRECTIVE ACTIONS TAKEN SINCE THE JUNE 17TH TVA HOLD ON CABLE PULLING; (4) THE ONGOING BFNP CABLE INTEGRITY VERIFICATION PROGRAM; AND (5) THE REQUIREMENTS FOR LIFTING THE STOP WORK ORDER. TVA CHARACTERIZED THEIR EARLIER DECISION NOT TO IMPLEMENT THE G38/40 SPECIFICATIONS AT BFNP UNIT 2 AS NOT AGGRESSIVE. THE NRC CONCURRED IN THE REQUIREMENTS FOR LIFTING THE STOP WORK ORDER AND WANTED TO LOOK AT THE TEST RESULTS JUSTIFYING THE OLD INSTALLATIONS. TVA WAS REQUESTED TO PROVIDE A FORMAL WRITTEN POSITION CONCERNING CABLE PULLING ACTIVITIES AT BROWNS FERRY.

CONTRARY TO 10 CFR 50, APPENDIX B, CRITERION VI, CHANGES WERE MADE TO THE TVA NATURAL RESOURCE OPERATIONS, FIELD OPERATIONS, QUALITY ASSURANCE PROCEDURE NO. NR-FO-NRE-62.2, CALIBRATION OF ORNL RADIATION MONITORS, BROWNS FERRY NUCLEAR PLANT ONLY WITHOUT REVIEW AND APPROVAL BY AUTHORIZED PERSONNEL. THE AIRFLOW CALIBRATION SECTION OF PROCEDURE NR-FO-NRE-62.2 BECAME INADEQUATE FOLLOWING A MODIFICATION TO THE EQUIPMENT IN THE SPRING OF 1985. SINCE THE MODIFICATION WAS NOT COMPLETED, AN UNOFFICIAL SUBSTITUTE CALIBRATION PROCEDURE, WHICH ITSELF CONTAINED PEN-AND-INK CHANGES TO THE TYPED DOCUMENT, HAD BEEN USED. THE SUBSTITUTE CALIBRATION PROCEDURE AND CHANGES FOR THIS PROCEDURE HAD NOT BEEN REVIEWED AND APPROVED BY AUTHORIZED PERSONNEL AS OF MAY 21, 1986. CONTRARY TO 10 CFR 50, APPENDIX B, CRITERION VI, CHANGES WERE MADE TO THE TVA NATURAL RESOURCE OPERATIONS, FIELD OPERATIONS, QUALITY ASSURANCE PROCEDURE NO. NR-FO-NRE-62.2, CALIBRATION OF ORNL RADIATION MONITORS, BROWNS FERRY NUCLEAR PLANT ONLY WITHOUT REVIEW AND APPROVAL BY AUTHORIZED PERSONNEL. THE AIRFLOW CALIBRATION SECTION OF PROCEDURE NR-FO-NRE-62.2 BECAME INADEQUATE FOLLOWING A MODIFICATION TO THE EQUIPMENT IN THE SPRING OF 1985. SINCE THE MODIFICATION WAS NOT COMPLETED, AN UNOFFICIAL SUBSTITUTE CALIBRATION PROCEDURE, WHICH ITSELF CONTAINED PEN-AND-INK CHANGES TO THE TYPED DOCUMENT, HAD BEEN USED. THE SUBSTITUTE CALIBRATION PROCEDURE AND CHANGES FOR THIS PROCEDURE HAD NOT BEEN REVIEWED AND APPROVED BY AUTHORIZED PERSONNEL AS OF MAY 21, 1986. CONTRARY TO 10 CFR 50, APPENDIX B, CRITERION VI, CHANGES WERE MADE TO THE TVA NATURAL RESOURCE OPERATIONS, FIELD OPERATIONS, QUALITY ASSURANCE PROCEDURE NO. NR-FO-NRE-62.2, CALIBRATION OF ORNL RADIATION MONITORS, BROWNS FERRY NUCLEAR PLANT ONLY WITHOUT REVIEW AND APPROVAL BY AUTHORIZED PERSONNEL. THE AIRFLOW CALIBRATION SECTION OF PROCEDURE NR-FO-NRE-62.2 BECAME INADEQUATE FOLLOWING A MODIFICATION TO THE EQUIPMENT IN THE SPRING OF 1985. SINCE THE MODIFICATION WAS NOT COMPLETED, AN UNOFFICIAL SUBSTITUTE CALIBRATION PROCEDURE, WHICH ITSELF CONTAINED PEN-AND-INK CHANGES TO THE TYPED DOCUMENT, HAD BEEN USED. THE SUBSTITUTE CALIBRATION PROCEDURE AND CHANGES FOR THIS PROCEDURE HAD NOT BEEN REVIEWED AND APPROVED BY AUTHORIZED PERSONNEL AS OF MAY 21, 1986. CONTRARY TO TS 6.8.1.A, PROCEDURE WAS NOT IMPLEMENTED IN THAT, ON MARCH 20, 1986, THE BREAKER FOR 2-SW-V255 WAS NOT MAINTAINED CLOSED.
(8601 5)

SYSTEMS AND COMPONENT PROBLEMS:

ENVIRONMENTAL QUALIFICATION WORK.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

NONE.

Report Period JUL 1986

INSPECTION STATUS - (CONTINUED)

* BROWNS FERRY 1 *

OTHER ITEMS

PLANT STATUS:

SHUTDOWN FOR REPAIRS ON 03/19.

LAST IE SITE INSPECTION DATE: JUNE 24, 1986 +

INSPECTION REPORT NO: 50-259/86-24 +

R E P O R T S F R O M L I C E N S E E

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
85-057	10/09/85	05/23/86	WIDE RANGE TORUS WATER LEVEL TRANSMITTERS NOT QUALIFIED.
86-004	11/28/85	06/18/86	RHR SYSTEM SHOWING CONDUCTIVITY AND CHLORIDE CONCENTRATION IN EXCESS OF PERMISSIBLE LEVELS; CAUSE - SLIGHT LEAKAGE INTO RHR SIDE FROM AROUND INNER FLOATING HEAD GASKETS ON BOTH HEAT EXCHANGERS.
86-013	04/22/86	05/21/86	TECHNICAL SPECIFICATION REQUIREMENTS FOR SECONDARY CONTAINMENT INTEGRITY IN REFUEL ZONE NOT FULLY MET; CAUSE - AIR ISOLATION VALVE IDENTIFICATION TAGS REVERSED ON THE 2 DAMPERS.
86-015	04/29/86	05/28/86	REACTOR PROTECTION SYSTEM TRIP DUE TO VOLTAGE REGULATOR CONTROL SWITCH BEING ACCIDENTLY BUMPED.
86-016	04/01/86	06/24/86	FLUID LEAKAGE PROBLEM WITH LARGE BORE SNUBBERS FOR TORUS DYNAMIC RESTRAINT; SEAL DESIGN IS THE SUSPECTED PROBLEM.
86-017	02/28/86	05/23/86	FAILURE TO PROPERLY TORQUE ENCLOSING TUBE ASSEMBLY NUT.
86-019	06/08/86	07/08/86	INADVERTENT SECONDARY CONTAINMENT ISOLATION FROM RADIATION MONITOR SPIKE; CAUSE - UNKNOWN.

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-260 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/86 Outage + On-line Hrs: 744.0

3. Utility Contact: K. L. CREAMER (205) 729-2955

4. Licensed Thermal Power (Mwt): 3293

5. Nameplate Rating (Gross MWe): 1280 X 0.9 = 1152

6. Design Electrical Rating (Net MWe): 1065

7. Maximum Dependable Capacity (Gross MWe): 1098

8. Maximum Dependable Capacity (Net MWe): 1065

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,087.0</u>	<u>100,104.0</u>
13. Hours Reactor Critical	<u>.0</u>	<u>.0</u>	<u>55,859.6</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>14,200.4</u>
15. Hrs Generator On-Line	<u>.0</u>	<u>.0</u>	<u>54,338.5</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>0</u>	<u>0</u>	<u>153,245,167</u>
18. Gross Elec Ener (MWH)	<u>0</u>	<u>0</u>	<u>50,771,798</u>
19. Net Elec Ener (MWH)	<u>-3,048</u>	<u>-32,766</u>	<u>49,232,598</u>
20. Unit Service Factor	<u>.0</u>	<u>.0</u>	<u>54.3</u>
21. Unit Avail Factor	<u>.0</u>	<u>.0</u>	<u>54.3</u>
22. Unit Cap Factor (MDC Net)	<u>.0</u>	<u>.0</u>	<u>46.2</u>
23. Unit Cap Factor (DER Net)	<u>.0</u>	<u>.0</u>	<u>46.2</u>
24. Unit Forced Outage Rate	<u>100.0</u>	<u>100.0</u>	<u>30.8</u>
25. Forced Outage Hours	<u>744.0</u>	<u>5,087.0</u>	<u>24,320.4</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):

NONE

27. If Currently Shutdown Estimated Startup Date: 12/25/86

* BROWNS FERRY 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
BROWNS FERRY 2



JULY 1986

Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

 * BROWNS FERRY 2 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
305	09/15/84	F	744.0	F	4				ADMINISTRATIVE HOLD TO RESOLVE VARIOUS TVA AND NRC CONCERNS.

 * SUMMARY *

 BROWNS FERRY 2 REMAINS SHUTDOWN FOR AN ADMINISTRATIVE OUTAGE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* BROWNS FERRY 2 *

FACILITY DATA

Report Period JUL 1986

FACILITY DESCRIPTION

LOCATION
STATE.....ALABAMA
COUNTY.....LIMESTONE
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...13 MI NW OF
DECATUR, ALA
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...JULY 20, 1974
DATE ELEC ENER 1ST GENER...AUGUST 28, 1974
DATE COMMERCIAL OPERATE...MARCH 1, 1975
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...TENNESSEE RIVER
ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....TENNESSEE VALLEY AUTHORITY
CORPORATE ADDRESS.....500A CHESTNUT STREET TOWER II
CHATTANOOGA, TENNESSEE 37401
CONTRACTOR
ARCHITECT/ENGINEER.....TENNESSEE VALLEY AUTHORITY
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....TENNESSEE VALLEY AUTHORITY
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
IE RESIDENT INSPECTOR.....J. PAULK
LICENSING PROJ MANAGER.....J. GEARS
DOCKET NUMBER.....50-260
LICENSE & DATE ISSUANCE...DPR-52, AUGUST 2, 1974
PUBLIC DOCUMENT ROOM.....ATHENS PUBLIC LIBRARY
SOUTH AND FORREST
ATHENS, ALABAMA 35611

INSPECTION STATUS

INSPECTION SUMMARY

+ INSPECTION MAY 19-23 (86-17): THIS WAS A ROUTINE, UNANNOUNCED INSPECTION IN THE AREAS OF OBSERVATION OF NONDESTRUCTIVE EXAMINATION ACTIVITIES PERFORMED IN ACCORDANCE WITH NRC GENERIC LETTER 84-11, NONDESTRUCTIVE EXAMINATION DATA REVIEW AND EVALUATION, INDEPENDENT RE-EXAMINATION OF RECIRCULATION SYSTEM WELDS AND FOLLOWUP ON PREVIOUS ENFORCEMENT ITEMS. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JUNE 16-20 (86-21): THIS ROUTINE, UNANNOUNCED INSPECTION WAS CONDUCTED BY TWO INSPECTORS AND CONSISTED OF A REVIEW OF THE LICENSEE'S: SECURITY PROGRAM AUDIT; RECORDS AND REPORTS; TESTING AND MAINTENANCE; PHYSICAL BARRIERS-VITAL AREAS; SECURITY SYSTEMS POWER SUPPLY; ALARM STATIONS; AND PERSONNEL TRAINING AND QUALIFICATIONS-GENERAL REQUIREMENTS. THE LICENSEE WAS FOUND TO BE IN COMPLIANCE WITH REGULATORY REQUIREMENTS WITHIN THE SEVEN AREAS INSPECTED.

INSPECTION JUNE 1-30 (86-22): THIS ROUTINE INSPECTION WAS IN THE AREAS OF OPERATIONAL SAFETY, MAINTENANCE OBSERVATION, SURVEILLANCE TESTING OBSERVATION, REPORTABLE OCCURRENCES AND DESIGN MODIFICATIONS. ONE VIOLATION - 10CFR 50, APPENDIX B, CRITERION III FOR DESIGN CONTROL OF CABLE PULLING ACTIVITIES.

INSPECTION JUNE 23-25 (86-23): THIS ROUTINE, UNANNOUNCED INSPECTION WAS IN THE AREA OF ULTRASONIC EXAMINATION OF THE REACTOR VESSEL NOZZLE THERMAL SLEEVE WELDS UTILIZING TVA'S AUTOMATED ULTRASONIC SYSTEM (INTRASPECT-98). NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

MANAGEMENT MEETING JUNE 24 (86-24): A MANAGEMENT MEETING WAS HELD AT REGION II ON JUNE 24, 1986, AT 11:00 A.M. EDT, TO DISCUSS
PAGE 2-032

INSPECTION STATUS - (CONTINUED)

INSPECTION SUMMARY

ENFORCEMENT SUMMARY

OTHER ITEMS

INSPECTION REPORT NO: 50-260/86-24 +

Report Period JUL 1986

REPORTS FROM LICENSEE

* BROWNS FERRY 2 *

```
=====
NUMBER    DATE OF    DATE OF    SUBJECT
          EVENT     REPORT
-----
86-004    04/18/86    05/21/86    INADVERTENT CONTAINMENT ISOLATION AND HALF SCRAM OCCURRED DURING REPLACEMENT OF A RELAY COIL ON
          480V REACTOR MOTOR - OPERATED VALVE BOARD 2B; CAUSE - PERSONNEL ERROR.
86-009    05/30/86    06/27/86    INCORRECT PERFORMANCE OF LOCAL LEAK RATE TEST; PROCEDURE HAS BEEN REVISED TO CORRECT ALL
          IDENTIFIED DEFICIENCIES.
=====
```

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-296 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/86 Outage + On-line Hrs: 44.0

3. Utility Contact: K. L. CREAMER (205) 729-2955

4. Licensed Thermal Power (Mwt): 3293

5. Nameplate Rating (Gross MWe): 1280 X 0.9 = 1152

6. Design Electrical Rating (Net MWe): 1065

7. Maximum Dependable Capacity (Gross MWe): 1098

8. Maximum Dependable Capacity (Net MWe): 1065

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____
NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,087.0</u>	<u>82,559.0</u>
13. Hours Reactor Critical	<u>.0</u>	<u>.0</u>	<u>45,306.8</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>5,149.4</u>
15. Hrs Generator On-Line	<u>.0</u>	<u>.0</u>	<u>44,195.6</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>0</u>	<u>0</u>	<u>131,846,076</u>
18. Gross Elec Ener (MWH)	<u>0</u>	<u>0</u>	<u>43,473,760</u>
19. Net Elec Ener (MWH)	<u>-3,846</u>	<u>-23,590</u>	<u>42,111,083</u>
20. Unit Service Factor	<u>.0</u>	<u>.0</u>	<u>53.5</u>
21. Unit Avail Factor	<u>.0</u>	<u>.0</u>	<u>53.5</u>
22. Unit Cap Factor (MDC Net)	<u>.0</u>	<u>.0</u>	<u>47.9</u>
23. Unit Cap Factor (DER Net)	<u>.0</u>	<u>.0</u>	<u>47.9</u>
24. Unit Forced Outage Rate	<u>100.0</u>	<u>100.0</u>	<u>29.3</u>
25. Forced Outage Hours	<u>744.0</u>	<u>5,087.0</u>	<u>18,304.4</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: 03/17/87

 * BROWNS FERRY 3 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
 BROWNS FERRY 3



JULY 1986

Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

* BROWNS FERRY 3 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
157	12/01/85	F	744.0	F	4				ADMINISTRATIVE HOLD TO RESOLVE VARIOUS TVA AND NRC CONCERNS.

* SUMMARY *

BROWNS FERRY 3 REMAINS SHUTDOWN FOR AN ADMINISTRATIVE OUTAGE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* BROWNS FERRY 3 *

F A C I L I T Y D A T A

Report Period JUL 1986

FACILITY DESCRIPTION

LOCATION
STATE.....ALABAMA

COUNTY.....LIMESTONE

DIST AND DIRECTION FROM
NEAREST POPULATION CTR...10 MI NW OF
 DECATUR, ALA

TYPE OF REACTOR.....BWR

DATE INITIAL CRITICALITY...AUGUST 8, 1976

DATE ELEC ENER 1ST GENER...SEPTEMBER 12, 1976

DATE COMMERCIAL OPERATE...MARCH 1, 1977

CONDENSER COOLING METHOD...ONCE THRU

CONDENSER COOLING WATER...TENNESSEE RIVER

ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
 RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....TENNESSEE VALLEY AUTHORITY

CORPORATE ADDRESS.....500A CHESTNUT STREET TOWER II
 CHATTANOOGA, TENNESSEE 37401

CONTRACTOR
ARCHITECT/ENGINEER.....TENNESSEE VALLEY AUTHORITY

NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC

CONSTRUCTOR.....TENNESSEE VALLEY AUTHORITY

TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II

IE RESIDENT INSPECTOR.....J. PAULK

LICENSING PROJ MANAGER.....J. GEARS
DOCKET NUMBER.....50-296

LICENSE & DATE ISSUANCE...DPR-68, AUGUST 18, 1976

PUBLIC DOCUMENT ROOM.....ATHENS PUBLIC LIBRARY
 SOUTH AND FORREST
 ATHENS, ALABAMA 35611

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION MAY 19-23 (86-17): THIS WAS A ROUTINE, UNANNOUNCED INSPECTION IN THE AREAS OF OBSERVATION OF NONDESTRUCTIVE EXAMINATION ACTIVITIES PERFORMED IN ACCORDANCE WITH NRC GENERIC LETTER 84-11, NONDESTRUCTIVE EXAMINATION DATA REVIEW AND EVALUATION, INDEPENDENT RE-EXAMINATION OF RECIRCULATION SYSTEM WELDS AND FOLLOWUP ON PREVIOUS ENFORCEMENT ITEMS. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JUNE 16-20 (86-21): THIS ROUTINE, UNANNOUNCED INSPECTION WAS CONDUCTED BY TWO INSPECTORS AND CONSISTED OF A REVIEW OF THE LICENSEE'S: SECURITY PROGRAM AUDIT; RECORDS AND REPORTS; TESTING AND MAINTENANCE; PHYSICAL BARRIERS-VITAL AREAS; SECURITY SYSTEMS POWER SUPPLY; ALARM STATIONS; AND PERSONNEL TRAINING AND QUALIFICATIONS-GENERAL REQUIREMENTS. THE LICENSEE WAS FOUND TO BE IN COMPLIANCE WITH REGULATORY REQUIREMENTS WITHIN THE SEVEN AREAS INSPECTED.

INSPECTION JUNE 1-30 (86-22): THIS ROUTINE INSPECTION WAS IN THE AREAS OF OPERATIONAL SAFETY, MAINTENANCE OBSERVATION, SURVEILLANCE TESTING OBSERVATION, REPORTABLE OCCURRENCES AND DESIGN MODIFICATIONS. ONE VIOLATION - 10CFR 50, APPENDIX B, CRITERION III FOR DESIGN CONTROL OF CABLE PULLING ACTIVITIES.

INSPECTION JUNE 23-25 (86-23): THIS ROUTINE, UNANNOUNCED INSPECTION WAS IN THE AREA OF ULTRASONIC EXAMINATION OF THE REACTOR VESSEL NOZZLE THERMAL SLEEVE WELDS UTILIZING TVA'S AUTOMATED ULTRASONIC SYSTEM (INTRASPECT-98). NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

MANAGEMENT MEETING JUNE 24 (86-24): A MANAGEMENT MEETING WAS HELD AT REGION II ON JUNE 24, 1986, AT 11:00 A.M. EDT, TO DISCUSS
PAGE 2-038

Report Period JUL 1986

INSPECTION STATUS - (CONTINUED)

* BROWNS FERRY 3 *

INSPECTION SUMMARY

CABLE PULLING ISSUES. TVA'S REVISED SPECIFICATIONS FOR INSTALLATION OF ELECTRICAL CABLE AND CONDUIT WERE NOT IMPLEMENTED FOR MODIFICATIONS AT BROWNS FERRY WHEN ISSUED. TVA GAVE A CHRONOLOGY OF EVENTS CONCERNING CABLE PULLING INCLUDING: (1) WHICH SITES WERE USING THE NEW SPECIFICATIONS; (2) THE RATIONALE FOR USING THE OLD SPECIFICATION AT BFNP UNIT 2; (3) BFNP CORRECTIVE ACTIONS TAKEN SINCE THE JUNE 17TH TVA HOLD ON CABLE PULLING; (4) THE ONGOING BFNP CABLE INTEGRITY VERIFICATION PROGRAM; AND (5) THE REQUIREMENTS FOR LIFTING THE STOP WORK ORDER. TVA CHARACTERIZED THEIR EARLIER DECISION NOT TO IMPLEMENT THE G38/40 SPECIFICATIONS AT BFNP UNIT 2 AS NOT AGGRESSIVE. THE NRC CONCURRED IN THE REQUIREMENTS FOR LIFTING THE STOP WORK ORDER AND WANTED TO LOOK AT THE TEST RESULTS JUSTIFYING THE OLD INSTALLATIONS. TVA WAS REQUESTED TO PROVIDE A FORMAL WRITTEN POSITION CONCERNING CABLE PULLING ACTIVITIES AT BROWNS FERRY.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

LICENSEE EVALUATING CAUSE OF REACTOR VESSEL WATER LEVEL INDICATION PROBLEMS.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

SHUTDOWN ON MARCH 9, 1985.

LAST IE SITE INSPECTION DATE: JUNE 24, 1986 +

INSPECTION REPORT NO: 50-296/86-24 +

REPORTS FROM LICENSEE

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT

NONE.			

=====

1. Docket: 50-325 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/86 Outage + On-line Hrs: 744.0

3. Utility Contact: FRANCES HARRISON (919) 457-9521

4. Licensed Thermal Power (Mwt): 2436

5. Nameplate Rating (Gross MWe): 963 X 0.9 = 867

6. Design Electrical Rating (Net MWe): 821

7. Maximum Dependable Capacity (Gross MWe): 815

8. Maximum Dependable Capacity (Net MWe): 790

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____
NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,087.0</u>	<u>82,152.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>4,894.6</u>	<u>51,726.0</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>1,647.1</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>4,778.7</u>	<u>48,917.2</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,787,764</u>	<u>11,354,050</u>	<u>101,460,705</u>
18. Gross Elec Ener (MWH)	<u>575,235</u>	<u>3,723,164</u>	<u>33,474,434</u>
19. Net Elec Ener (MWH)	<u>557,818</u>	<u>3,612,243</u>	<u>32,170,931</u>
20. Unit Service Factor	<u>100.0</u>	<u>93.9</u>	<u>59.5</u>
21. Unit Avail Factor	<u>100.0</u>	<u>93.9</u>	<u>59.5</u>
22. Unit Cap Factor (MDC Net)	<u>94.9</u>	<u>89.9</u>	<u>49.6</u>
23. Unit Cap Factor (DER Net)	<u>91.3</u>	<u>86.5</u>	<u>47.7</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>6.1</u>	<u>17.1</u>
25. Forced Outage Hours	<u>.0</u>	<u>308.3</u>	<u>10,005.7</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

* BRUNSWICK 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT BRUNSWICK 1



JULY 1986

Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

* BRUNSWICK 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
86037	07/18/86	S	0.0	B	5				REDUCED POWER FOR ROD IMPROVEMENT, SCRAM TIME TESTING ON VARIOUS RODS AND STEAM LEAK REPAIR.
86038	07/20/86	F	0.0	A	5				REDUCED POWER TO REDUCE TURBINE BEARING VIBRATION WHILE REMOVING SECONDSTAGE REHEAT FROM SERVICE.
86-040	07/28/86	F	0.0	A	5				REDUCED POWER WHILE REMOVING HEATER DRAIN PUMP 1A FROM SERVICE DUE TO PROBLEM WITH DISCHARGE CHECK VALVE.

* SUMMARY *

BRUNSWICK 1 OPERATED WITH 3 REDUCTIONS DURING THE JULY REPORT PERIOD.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* BRUNSWICK 1 *

FACILITY DATA

Report Period JUL 1986

FACILITY DESCRIPTION

LOCATION
STATE.....NORTH CAROLINA
COUNTY.....BRUNSWICK
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...3 MI N OF
SOUTHPORT, NC
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...OCTOBER 8, 1976
DATE ELEC ENER 1ST GENER...DECEMBER 4, 1976
DATE COMMERCIAL OPERATE...MARCH 18, 1977
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...CAPE FEAR RIVER
ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....CAROLINA POWER & LIGHT
CORPORATE ADDRESS.....P. O. BOX 1551
RALEIGH, NORTH CAROLINA 27602
CONTRACTOR
ARCHITECT/ENGINEER.....UNITED ENG. & CONSTRUCTORS
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....BROWN & ROOT
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
IE RESIDENT INSPECTOR.....W. RULAND
LICENSING PROJ MANAGER.....E. SYLVESTER
DCKET NUMBER.....50-325
LICENSE & DATE ISSUANCE...DPR-71, NOVEMBER 12, 1976
PUBLIC DOCUMENT ROOM.....SOUTHPORT-BRUNSWICK COUNTY LIBRARY
108 H. MOORE STREET
SOUTHPORT, NORTH CAROLINA 28461

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION JUNE 1-30 (86-15): THIS ROUTINE SAFETY INSPECTION INVOLVED THE AREAS OF FOLLOWUP ON UNRESOLVED ITEM, MAINTENANCE OBSERVATION, SURVEILLANCE OBSERVATION, OPERATIONAL SAFETY VERIFICATION, AND ONSITE FOLLOWUP OF EVENTS. TWO VIOLATIONS - FAILURE TO TAKE ADEQUATE CORRECTIVE ACTION CONCERNING JUMPER CONTROL; FAILURE TO FOLLOW PROCEDURES BY NOT DECLARING A SUPPORT INOPERABLE WHEN REQUIRED.

INSPECTION JUNE 9-13 (86-16): THIS ROUTINE, UNANNOUNCED INSPECTION WAS CONDUCTED IN THE AREAS OF POST-REFUELING INITIAL CRITICALITY AND TESTS AND ROUTINE CORE PERFORMANCE SURVEILLANCE. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JULY 8-10 (86-18): THIS SPECIAL, ANNOUNCED INSPECTION INVOLVED A REVIEW OF ALLEGATIONS RELATED TO THE CONDUCT OF OPERATIONS AT THE LICENSEE'S FACILITY. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

Report Period JUL 1986

I N S P E C T I O N S T A T U S - (C O N T I N U E D)

* BRUNSWICK 1 *

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

NORMAL OPERATION.

LAST IE SITE INSPECTION DATE: JULY 8-10, 1986 +

INSPECTION REPORT NO: 50-325/86-18 +

R E P O R T S F R O M L I C E N S E E

=====			
NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT

86-013	05/30/86	06/25/86	TRAIN 2A OF CONTROL BUILDING EMERGENCY AIR FILTRATION SYSTEM AUTOMATICALLY STARTED DUE TO ACTUATION OF AREA RADIATION MONITOR/INDICATOR TRIP UNIT 1-D22-RM-K600-1-2 FOR CONTROL BUILDING COMMON AIR INTAKE SUPPLY DUCT.
86-017	06/14/86	07/14/86	LATE PERFORMANCE OF REQUIRED HOURLY FIRE WATCHES.
=====			

1. Docket: 50-324 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/86 Outage + On-line Hrs: 744.0

3. Utility Contact: FRANCES HARRISON (919) 457-9521

4. Licensed Thermal Power (MWt): 2436

5. Nameplate Rating (Gross MWe): 963 X 0.9 = 867

6. Design Electrical Rating (Net MWe): 821

7. Maximum Dependable Capacity (Gross MWe): 815

8. Maximum Dependable Capacity (Net MWe): 790

9. If Changes Occur Above Since Last Report, Give Reasons: NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any: NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,087.0</u>	<u>94,176.0</u>
13. Hours Reactor Critical	<u>667.4</u>	<u>956.2</u>	<u>55,468.4</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>652.2</u>	<u>822.0</u>	<u>51,833.1</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,512,107</u>	<u>1,767,167</u>	<u>100,595,625</u>
18. Gross Elec Ener (MWH)	<u>486,417</u>	<u>561,680</u>	<u>33,357,068</u>
19. Net Elec Ener (MWH)	<u>468,352</u>	<u>510,392</u>	<u>31,948,081</u>
20. Unit Service Factor	<u>87.7</u>	<u>16.2</u>	<u>55.0</u>
21. Unit Avail Factor	<u>87.7</u>	<u>16.2</u>	<u>55.0</u>
22. Unit Cap Factor (MDC Net)	<u>79.7</u>	<u>12.7</u>	<u>42.9</u>
23. Unit Cap Factor (DER Net)	<u>76.7</u>	<u>12.2</u>	<u>41.3</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>3.3</u>	<u>16.8</u>
25. Forced Outage Hours	<u>.0</u>	<u>28.4</u>	<u>10,898.7</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration): NONE

27. If Currently Shutdown Estimated Startup Date: N/A

 * BRUNSWICK 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
 BRUNSWICK 2



JULY 1986

Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

* BRUNSWICK 2 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
86-012	07/10/86	S	91.8	B	1				PLANNED OFF-LINE OUTAGE TO REPAIR REACTOR WATER CLEANUP VALVE G31-F001.
86-016	07/18/86	F	0.0	A	5				REDUCED POWER DUE TO RECIRC PUMP "B" RUNBACK.
86-017	07/22/86	F	0.0	A	5				REDUCED POWER TO RESOLVE TIP PROBLEM (TIP LOCATIONS SWITCHED).

* SUMMARY *

BRUNSWICK 2 OPERATED WITH 1 OUTAGE AND 2 REDUCTIONS DURING THE JULY REPORT PERIOD.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* BRUNSWICK 2 *

FACILITY DATA

Report Period JUL 1986

FACILITY DESCRIPTION

LOCATION
STATE.....NORTH CAROLINA
COUNTY.....BRUNSWICK
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...3 MI N OF
SOUTHPORT, NC
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...MARCH 20, 1975
DATE ELEC ENER 1ST GENER...APRIL 29, 1975
DATE COMMERCIAL OPERATE...NOVEMBER 3, 1975
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...CAPE FEAR RIVER
ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....CAROLINA POWER & LIGHT
CORPORATE ADDRESS.....411 FAYETTEVILLE STREET
RALEIGH, NORTH CAROLINA 27602
CONTRACTOR
ARCHITECT/ENGINEER.....UNITED ENG. & CONSTRUCTORS
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....BROWN & ROOT
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
IE RESIDENT INSPECTOR.....W. RULAND
LICENSING PROJ MANAGER.....E. SYLVESTER
DOCKET NUMBER.....50-324
LICENSE & DATE ISSUANCE...DPR-62, DECEMBER 27, 1974
PUBLIC DOCUMENT ROOM.....SOUTHPORT-BRUNSWICK COUNTY LIBRARY
108 W. MOORE STREET
SOUTHPORT, NORTH CAROLINA 28461

INSPECTION STATUS

INSPECTION SUMMARY

+ INSPECTION JUNE 1-30 (86-16): THIS ROUTINE SAFETY INSPECTION INVOLVED THE AREAS OF FOLLOWUP ON UNRESOLVED ITEM, MAINTENANCE OBSERVATION, SURVEILLANCE OBSERVATION, OPERATIONAL SAFETY VERIFICATION, AND ONSITE FOLLOWUP OF EVENTS. TWO VIOLATIONS - FAILURE TO TAKE ADEQUATE CORRECTIVE ACTION CONCERNING JUMPER CONTROL; FAILURE TO FOLLOW PROCEDURES BY NOT DECLARING A SUPPORT INOPERABLE WHEN REQUIRED.

INSPECTION JUNE 9-13 (86-17): THIS ROUTINE, UNANNOUNCED INSPECTION WAS CONDUCTED IN THE AREAS OF POST-REFUELING INITIAL CRITICALITY AND TESTS AND ROUTINE CORE PERFORMANCE SURVEILLANCE. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JULY 8-10 (86-19): THIS SPECIAL, ANNOUNCED INSPECTION INVOLVED A REVIEW OF ALLEGATIONS RELATED TO THE CONDUCT OF OPERATIONS AT THE LICENSEE'S FACILITY. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

INSPECTION STATUS - (CONTINUED)

```

XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX
X                BRUNSWICK 2                X
XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX

```

SYSTEMS AND COMPONENT PROBLEMS:

NONE.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

NORMAL OPERATIONS.

LAST IE SITE INSPECTION DATE: JULY 8-10, 1986 +

INSPECTION REPORT NO: 50-324/86-19 +

REPORTS FROM LICENSEE

1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	93	94	95	96	97	98	99	100	101	102	103	104	105	106	107	108	109	110	111	112	113	114	115	116	117	118	119	120	121	122	123	124	125	126	127	128	129	130	131	132	133	134	135	136	137	138	139	140	141	142	143	144	145	146	147	148	149	150	151	152	153	154	155	156	157	158	159	160	161	162	163	164	165	166	167	168	169	170	171	172	173	174	175	176	177	178	179	180	181	182	183	184	185	186	187	188	189	190	191	192	193	194	195	196	197	198	199	200	201	202	203	204	205	206	207	208	209	210	211	212	213	214	215	216	217	218	219	220	221	222	223	224	225	226	227	228	229	230	231	232	233	234	235	236	237	238	239	240	241	242	243	244	245	246	247	248	249	250	251	252	253	254	255	256	257	258	259	260	261	262	263	264	265	266	267	268	269	270	271	272	273	274	275	276	277	278	279	280	281	282	283	284	285	286	287	288	289	290	291	292	293	294	295	296	297	298	299	300	301	302	303	304	305	306	307	308	309	310	311	312	313	314	315	316	317	318	319	320	321	322	323	324	325	326	327	328	329	330	331	332	333	334	335	336	337	338	339	340	341	342	343	344	345	346	347	348	349	350	351	352	353	354	355	356	357	358	359	360	361	362	363	364	365	366	367	368	369	370	371	372	373	374	375	376	377	378	379	380	381	382	383	384	385	386	387	388	389	390	391	392	393	394	395	396	397	398	399	400	401	402	403	404	405	406	407	408	409	410	411	412	413	414	415	416	417	418	419	420	421	422	423	424	425	426	427	428	429	430	431	432	433	434	435	436	437	438	439	440	441	442	443	444	445	446	447	448	449	450	451	452	453	454	455	456	457	458	459	460	461	462	463	464	465	466	467	468	469	470	471	472	473	474	475	476	477	478	479	480	481	482	483	484	485	486	487	488	489	490	491	492	493	494	495	496	497	498	499	500	501	502	503	504	505	506	507	508	509	510	511	512	513	514	515	516	517	518	519	520	521	522	523	524	5
---	---	---	---	---	---	---	---	---	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	---

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
--------	------------------	-------------------	---------

86-014 04/29/86 05/20/86 UPSCALE TRIP OF REACTOR POWER INTERMEDIATE RANGE MONITOR 'D' OCCURRED WHEN CONTROL ROD 02-19 WAS SELECTED IN REACTOR MANUAL CONTROL SYSTEM WHILE PERFORMING PT-18.1; CAUSE - ELECTRONIC NOISE SPIKE.

80-015 05/30/86 06/27/86 AUTO INITIATION OF CORE SPRAY AND RESIDUAL HEAT REMOVAL LOW PRESSURE COOLANT INJECTION SYSTEM
AND EXCEEDING ALLOWED TIME FRAME FOR INOPERABILITY OF 2-B21-N021A.

	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	93	94	95	96	97	98	99	100
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	93	94	95	96	97	98	99	100	

1. Docket: 50-454 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/86 Outage + On-line Hrs: 744.0

3. Utility Contact: P. DANDREA (815) 234-5441 X2341

4. Licensed Thermal Power (Mwt): 3411

5. Nameplate Rating (Gross MWe): 1175

6. Design Electrical Rating (Net MWe): 1120

7. Maximum Dependable Capacity (Gross MWe): 1175

8. Maximum Dependable Capacity (Net MWe): 1129

9. If Changes Occur Above Since Last Report, Give Reasons:

10. Power Level To Which Restricted, If Any (Net MWe): 1152

11. Reasons for Restrictions, If Any: _____


SPLIT FEEDWATER FLOW

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,087.0</u>	<u>7,656.0</u>
13. Hours Reactor Critical	<u>241.7</u>	<u>4,202.8</u>	<u>5,483.8</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>21.7</u>	<u>37.8</u>
15. Hrs Generator On-Line	<u>236.1</u>	<u>4,152.1</u>	<u>5,344.5</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>615,385</u>	<u>12,234,086</u>	<u>15,573,278</u>
18. Gross Elec Ener (MWH)	<u>208,906</u>	<u>4,136,033</u>	<u>5,224,623</u>
19. Net Elec Ener (MWH)	<u>186,841</u>	<u>3,894,103</u>	<u>4,907,001</u>
20. Unit Service Factor	<u>31.7</u>	<u>81.6</u>	<u>69.8</u>
21. Unit Avail Factor	<u>31.7</u>	<u>81.6</u>	<u>69.8</u>
22. Unit Cap Factor (MDC Net)	<u>22.2</u>	<u>67.8</u>	<u>56.8</u>
23. Unit Cap Factor (DER Net)	<u>22.4</u>	<u>68.3</u>	<u>57.2</u>
24. Unit Forced Outage Rate	<u>68.3</u>	<u>12.8</u>	<u>11.8</u>
25. Forced Outage Hours	<u>507.9</u>	<u>610.6</u>	<u>713.2</u>
26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):	<u>NONE</u>		

27. If Currently Shutdown Estimated Startup Date: N/A

* BYRON 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
BYRON 1



JULY 1986

Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

* BYRON 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
10	07/03/86	F	507.9	A	1	86-020	RC	VALVE	PLANT SHUTDOWN DUE TO EXCESSIVE REACTOR COOLANT SYSTEM LEAKAGE FROM RESISTANCE TEMPERATURE DETECTOR ISOLATION VALVE.

* SUMMARY *

BYRON 1 OPERATED WITH 1 OUTAGE DUE TO EQUIPMENT FAILURE IN JULY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* BYRON 1 *

F A C I L I T Y D A T A

Report Period JUL 1986

FACILITY DESCRIPTION

LOCATION
STATE.....ILLINOIS
COUNTY.....OGLE
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...17 MI SW OF
ROCKFORD, ILL
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...FEBRUARY 2, 1985
DATE ELEC ENER 1ST GENER...MARCH 1, 1985
DATE COMMERCIAL OPERATE...SEPTEMBER 16, 1985
CONDENSER COOLING METHOD...CC HNDCT
CONDENSER COOLING WATER...ROCK RIVER
ELECTRIC RELIABILITY
COUNCIL.....MID-AMERICA
INTERPOOL NETWORK

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....COMMONWEALTH EDISON
CORPORATE ADDRESS.....P.O. BOX 767
CHICAGO, ILLINOIS 60690
CONTRACTOR
ARCHITECT/ENGINEER.....SARGENT & LUNDY
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....COMMONWEALTH EDISON
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III
IE RESIDENT INSPECTOR.....J. HINDS
LICENSING PROJ MANAGER.....L. OLSHAN
DOCKET NUMBER.....50-454
LICENSE & DATE ISSUANCE...NPF-37, FEBRUARY 14, 1985
PUBLIC DOCUMENT ROOM.....LIBRARIAN
BUSINESS SCIENCE & TECHNOLOGY DEPT.
ROCKFORD PUBLIC LIBRARY
215 NORTH WYMAN STREET
ROCKFORD, ILLINOIS 61101

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION ON MAY 31 THROUGH JUNE 30 (86021): ROUTINE UNANNOUNCED SAFETY INSPECTION BY THE RESIDENT INSPECTORS AND A HEADQUARTERS INSPECTOR OF LICENSEE ACTION ON PREVIOUS INSPECTION FINDINGS; IEBS; SERS; LERS; OPERATIONS SUMMARY; SURVEILLANCE; MAINTENANCE; OPERATIONAL SAFETY AND ESF WALKDOWN; HEADQUARTERS AND REGION III REQUESTS; EVENT FOLLOWUP; LICENSEE ACTIONS CONCERNING SUSPECTED DRUG USE; MANAGEMENT MEETINGS; AND OTHER ACTIVITIES. OF THE 11 AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED IN 10 AREAS; TWO VIOLATIONS WERE IDENTIFIED IN THE REMAINING AREA; HOWEVER, IN ACCORDANCE WITH 10 CFR 2, APPENDIX C, SECTION V.A., A NOTICE OF VIOLATION WAS NOT ISSUED. NO ITEMS WERE IDENTIFIED WHICH COULD IMPACT THE PUBLIC HEALTH AND SAFETY.

INSPECTION ON JUNE 19-26 (86022): INCLUDED A REVIEW OF ALLEGATIONS RECEIVED BY THE NRC RESIDENT INSPECTOR OFFICE AT THE BYRON STATION OF PERCEIVED SECURITY VIOLATION COVER-UP. THE INSPECTION BEGAN DURING THE DAY SHIFT AND SOME OFF-SHIFT INSPECTION ACTIVITIES WERE PERFORMED. THE LICENSEE WAS FOUND TO BE IN COMPLIANCE WITH NRC REQUIREMENTS WITHIN THE AREAS EXAMINED DURING THIS INSPECTION. THE ALLEGATIONS WERE NOT SUBSTANTIATED.

INSPECTION ON JUNE 24-26 (86023; 86020): INCLUDED A REVIEW OF LICENSEE SECURITY EVENT REPORT NO. 86-001, AND THE LICENSEE'S PROGRESS TOWARDS FULL IMPLEMENTATION OF THE SECURITY PROGRAM REQUIRED FOR THE LICENSING OF UNIT NO. 2. SPECIFICALLY, REGARDING UNIT 2, THE INSPECTION INCLUDED THE SPECIFIED SECTIONS 02 "INSPECTION REQUIREMENTS" OF THE 81100 SERIES INSPECTION PROCEDURE. THE REVIEW OF LICENSEE SECURITY EVENT REPORT NO. 86-001 SHOWED THAT THE EVENT WAS A VIOLATION OF SECURITY PLAN COMMITMENTS REQUIRED FOR UNIT 1, BUT THAT THE VIOLATION MET ALL OF THE CRITERIA FOR NOT ISSUING A NOTICE OF VIOLATION IN ACCORDANCE WITH THE "GENERAL
PAGE 2-050

INSPECTION STATUS - (CONTINUED)

```

*****
*          BYRON 1          *
*****

```

INSPECTION SUMMARY

POLICY AND PROCEDURES FOR NRC ENFORCEMENT ACTIONS," 10 CFR PART 2, APPENDIX C (1985). THE LICENSEE'S PROGRESS IN THE IMPLEMENTATION OF SECURITY FOR UNIT NO. 2 APPEARS ADEQUATE AT THIS TIME. NO VIOLATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

R. KROWZACK REPLACED T. BLACKMAN AS GSEP COORDINATOR FOR COMMONWEALTH EDISON APPROXIMATELY APRIL 1, 1986.

PLANT STATUS:

REDUCED POWER IS DUE TO DISCRETIONARY LOAD REDUCTION TO MINIMIZE COOLANT TEMPERATURES.

LAST IE SITE INSPECTION DATE: 08/08/86

INSPECTION REPORT NO: 86029

REPORTS FROM LICENSEE

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
86-19	06/30/86	06/30/86	TECHNICAL SPECIFICATION ACTION STATEMENT FOR POWER RANGE NUCLEAR INSTRUMENT NOT SATISFIED DUE TO PERSONNEL ERROR
86-20	07/02/86	07/02/86	PLANT SHUTDOWN DUE TO EXCESSIVE REACTOR COOLANT SYSTEM LEAKAGE FROM RESISTANCE TEMPERATURE DETECTOR ISOLATION VALVE
86-21	06/14/86	07/14/86	TECHNICAL SPECIFICATION ACTION STATEMENT EXCEEDED DUE TO MISINTERPRETATION OF THE REQUIREMENT
86-22	07/03/86	07/03/86	NUCLEAR INSTRUMENTATION ACTION RESPONSE EXCEEDED DUE TO PERSONNEL ERROR

1. Docket: 50-483 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/86 Outage + On-line Hrs: 744.0

3. Utility Contact: DAN PRATTE (314) 676-8460

4. Licensed Thermal Power (MWt): 3411

5. Nameplate Rating (Gross MWe): 1373 X .9 = 1236

6. Design Electrical Rating (Net MWe): 1171

7. Maximum Dependable Capacity (Gross MWe): 1174

8. Maximum Dependable Capacity (Net MWe): 1120

9. If Changes Occur Above Since Last Report, Give Reasons:

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,087.0</u>	<u>14,149.5</u>
13. Hours Reactor Critical	<u>718.6</u>	<u>3,681.3</u>	<u>12,144.8</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>697.9</u>	<u>3,510.4</u>	<u>11,697.8</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>2,279,207</u>	<u>10,964,179</u>	<u>36,891,673</u>
18. Gross Elec Ener (MWH)	<u>761,723</u>	<u>3,679,861</u>	<u>12,493,804</u>
19. Net Elec Ener (MWH)	<u>723,828</u>	<u>3,490,183</u>	<u>11,858,970</u>
20. Unit Service Factor	<u>93.8</u>	<u>69.0</u>	<u>82.7</u>
21. Unit Avail Factor	<u>93.8</u>	<u>69.0</u>	<u>82.7</u>
22. Unit Cap Factor (MDC Net)	<u>86.9</u>	<u>61.3</u>	<u>74.8</u>
23. Unit Cap Factor (DER Net)	<u>83.1</u>	<u>58.6</u>	<u>71.6</u>
24. Unit Forced Outage Rate	<u>6.2</u>	<u>9.6</u>	<u>7.2</u>
25. Forced Outage Hours	<u>46.1</u>	<u>373.1</u>	<u>909.9</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


NONE

27. If Currently Shutdown Estimated Startup Date: N/A

* CALLAWAY 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

CALLAWAY 1



JULY 1986

Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

* CALLAWAY 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
15	07/25/86	F	0.0	A	5				REDUCTION IN POWER DUE TO TURBINE RUNBACK ON LOSS OF CIRCULATING WATER.
16	07/16/86	F	46.1	A	3				TURBINE TRIP/REACTOR TRIP DURING TURBINE SURVEILLANCE TESTING. LER 85-027-00.

* SUMMARY *

CALLAWAY OPERATED WITH 1 REDUCTION AND 1 OUTAGE FOR EQUIPMENT FAILURE IN JULY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* CALLAWAY 1 *

FACILITY DATA

Report Period JUL 1986

FACILITY DESCRIPTION

LOCATION
STATE.....MISSOURI
COUNTY.....CALLAWAY
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...10 MI SE OF
FULTON, MO
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...OCTOBER 2, 1984
DATE ELEC ENER 1ST GENER...OCTOBER 24, 1984
DATE COMMERCIAL OPERATE...DECEMBER 19, 1984
CONDENSER COOLING METHOD...COOLING TOWER
CONDENSER COOLING WATER...MISSOURI RIVER
ELECTRIC RELIABILITY
COUNCIL.....MID-AMERICA
INTERPOOL NETWORK

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....UNION ELECTRIC
CORPORATE ADDRESS.....P.O. BOX 149
ST LOUIS, MISSOURI 63166
CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....DANIEL INTERNATIONAL
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III
IE RESIDENT INSPECTOR.....B. LITTLE
LICENSING PROJ MANAGER.....T. ALEXION
DOCKET NUMBER.....50-483
LICENSE & DATE ISSUANCE...NPF-30, OCTOBER 18, 1984
PUBLIC DOCUMENT ROOM.....CALLAWAY COUNTY PUBLIC LIBRARY
WASHINGTON UNIVERSITY
JOHN M. OLIN LIBRARY
SKINKER & LINDELL BLVD.
ST. LOUIS, MO. 63130

INSPECTION STATUS

INSPECTION SUMMARY

INSPECTION ON JUNE 4 THROUGH 11 (86017): A SPECIAL UNANNOUNCED SAFETY INSPECTION BY THE SENIOR RESIDENT INSPECTOR REGARDING THE BLOCKING OF AUXILIARY FEEDWATER ACTUATION INSTRUMENTATION AND NRC REGION III MANAGEMENT SITE VISIT. ONE APPARENT VIOLATION WAS IDENTIFIED (FAILURE TO MAINTAIN THE AUXILIARY FEEDWATER ACTUATION SYSTEM INSTRUMENTATION OPERABLE WHILE IN MODES 1 AND 2).

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

Report Period JUL 1986

INSPECTION STATUS - (CONTINUED)

* CALLAWAY 1 *

OTHER ITEMS

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

THE UNIT HAS BEEN OPERATING AT POWER LEVELS UP TO 100%

LAST IE SITE INSPECTION DATE: 09/27/86

INSPECTION REPORT NO: 86019

REPORTS FROM LICENSEE

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
86-19	06/06/86	07/30/86	LOW PRESSURIZER PRESSURE REACTOR TRIP
86-20	06/14/86	07/11/86	ENGINEERED SAFETY FEATURES ACTUATIONS ON CONTAINMENT NOBLE GAS ACTIVITY
86-21	06/17/86	07/17/86	PERSONNEL ERROR CAUSES T/S 3.3.3.1 VIOLATION AFTER RAD MONITOR FAILED
86-22	06/21/86	07/21/86	S/G LOW LEVEL REACTOR TRIP WHEN FEEDWATER ISOLATION VALVE CARD FAILED
86-23	05/19/86	07/24/86	PERSONNEL OPENED PENETRATION IN MODE 4 - VIOLATION OF TECH SPECS 3/4.6.1.1 AND 3/4.6.3
86-24	07/01/86	07/30/86	TECHNICAL SPECIFICATION 3.0.3 ENTERED DUE TO A ROD CONTROL CARD FAILURE
86-26	07/07/86	08/01/86	TECH SPEC 125-VOLT BATTERIES NOT SURVEILLED DUE TO PERSONNEL ERROR

1. Docket: 50-317 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/86 Outage + On-line Hrs: 744.0

3. Utility Contact: H. PORTER (301) 260-4868

4. Licensed Thermal Power (MWt): 2700

5. Nameplate Rating (Gross MWe): 1020 X 0.9 = 918

6. Design Electrical Rating (Net MWe): 845

7. Maximum Dependable Capacity (Gross MWe): 860

8. Maximum Dependable Capacity (Net MWe): 825

9. If Changes Occur Above Since Last Report, Give Reasons: NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,087.0</u>	<u>98,460.0</u>
13. Hours Reactor Critical	<u>706.4</u>	<u>4,882.8</u>	<u>77,748.3</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>2,299.2</u>
15. Hrs Generator On-Line	<u>704.1</u>	<u>4,849.4</u>	<u>76,208.9</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,850,976</u>	<u>12,869,980</u>	<u>190,194,173</u>
18. Gross Elec Ener (MWH)	<u>607,564</u>	<u>4,324,370</u>	<u>62,927,147</u>
19. Net Elec Ener (MWH)	<u>580,549</u>	<u>4,143,440</u>	<u>60,059,742</u>
20. Unit Service Factor	<u>94.6</u>	<u>95.3</u>	<u>77.4</u>
21. Unit Avail Factor	<u>94.6</u>	<u>95.3</u>	<u>77.4</u>
22. Unit Cap Factor (MDC Net)	<u>94.6</u>	<u>98.7</u>	<u>74.3*</u>
23. Unit Cap Factor (DER Net)	<u>92.3</u>	<u>96.4</u>	<u>72.2</u>
24. Unit Forced Outage Rate	<u>5.4</u>	<u>1.7</u>	<u>7.8</u>
25. Forced Outage Hours	<u>39.9</u>	<u>81.6</u>	<u>6,376.7</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


REFUELING: OCTOBER 25, 1986 - JANUARY 4, 1987.

27. If Currently Shutdown Estimated Startup Date: N/A

* CALVERT CLIFFS 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

CALVERT CLIFFS 1



JULY 1986

* Item calculated with a Weighted Average

Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

 * CALVERT CLIFFS 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
86-06	07/20/86	F	39.9	A	3	86-04	CB	CKTBKR	THE UNIT TRIPPED WHEN A SURGE CAPACITOR FOR 12B REACTOR COOLANT PUMP FAILED.

 * SUMMARY *

CALVERT CLIFFS 1 OPERATED WITH 1 OUTAGE DUE TO EQUIPMENT FAILURE DURING JULY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

 * CALVERT CLIFFS 1 *

F A C I L I T Y D A T A

Report Period JUL 1986

FACILITY DESCRIPTION

UTILITY & CONTRACTOR INFORMATION

LOCATION
 STATE.....MARYLAND
 COUNTY.....CALVERT
 DIST AND DIRECTION FROM
 NEAREST POPULATION CTR...40 MI S OF
 ANNAPOLIS, MD
 TYPE OF REACTOR.....PWR
 DATE INITIAL CRITICALITY...OCTOBER 7, 1974
 DATE ELEC ENER 1ST GENER...DECEMBER 30, 1974
 DATE COMMERCIAL OPERATE....MAY 8, 1975
 CONDENSER COOLING METHOD...ONCE THRU
 CONDENSER COOLING WATER....CHESAPEAKE BAY
 ELECTRIC RELIABILITY
 COUNCIL.....MID-ATLANTIC
 AREA COUNCIL

UTILITY
 LICENSEE.....BALTIMORE GAS & ELEC
 CORPORATE ADDRESS.....P.O. BOX 1475
 BALTIMORE, MARYLAND 21203
 CONTRACTOR
 ARCHITECT/ENGINEER.....BECHTEL
 NUC STEAM SYS SUPPLIER...COMBUSTION ENGINEERING
 CONSTRUCTOR.....BECHTEL
 TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I
 IE RESIDENT INSPECTOR.....T. FOLEY
 LICENSING PROJ MANAGER.....S. MCNEIL
 DOCKET NUMBER.....50-317
 LICENSE & DATE ISSUANCE....DPR-53, JULY 31, 1974
 PUBLIC DOCUMENT ROOM.....CALVERT COUNTY LIBRARY
 FOURTH STREET
 PRINCE FREDERICK, MARYLAND 20678

INSPECTION SUMMARY

I N S P E C T I O N S T A T U S

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

FAILURE TO FOLLOW SECURITY EVENT REPORTING PROCEDURES. FAILURE TO INCLUDE AN INTRUSION DEVICE IN THE TESTING PROGRAM. TECHNICAL SPECIFICATIONS 4.6.3.1, 4.6.6.1, 4.7.6. 1, 4.7.7.1, AND 4.9.12 REQUIRE THAT A LABORATORY ANALYSIS OF A CARBON SAMPLE FROM AT LEAST TWO CARBON SAMPLES REMOVED FROM ONE OF THE CHARCOAL ABSORBERS DEMONSTRATES A REMOVAL EFFICIENCY OF GREATER THAN 90% FOR RADIOACTIVE METHYL IODIDE. CONTRARY TO THE ABOVE, ONLY ONE CARBON SAMPLE HAD BEEN REMOVED AND TESTED FOR SURVEILLANCE CONDUCTED DURING 1984-85. FAILURE TO FOLLOW SECURITY EVENT REPORTING PROCEDURES. FAILURE TO INCLUDE AN INTRUSION DEVICE IN THE TESTING PROGRAM. TECHNICAL SPECIFICATIONS 4.6.3.1, 4.6.6.1, 4.7.6. 1, 4.7.7.1, AND 4.9.12 REQUIRE THAT A LABORATORY ANALYSIS OF A CARBON SAMPLE FROM AT LEAST TWO CARBON SAMPLES REMOVED FROM ONE OF THE CHARCOAL ABSORBERS DEMONSTRATES A REMOVAL EFFICIENCY OF GREATER THAN 90% FOR RADIOACTIVE METHYL IODIDE. CONTRARY TO THE ABOVE, ONLY ONE CARBON SAMPLE HAD BEEN REMOVED AND TESTED FOR SURVEILLANCE CONDUCTED DURING 1984-85. TECHNICAL SPECIFICATION 6.11 REQUIRES ADHERENCE TO RADIATION PROTECTION PROCEDURES. PROCEDURE 12 THP 6010.RAD.404, ESTABLISHING POSTED AREAS, REQUIRES ANY AREA IN WHICH THE REMOVABLE CONTAMINATION ON ANY ACCESSIBLE SURFACE OR EQUIPMENT EXCEEDS 500 DPM/100 CM2 BETA-GAMMA TO BE POSTED AS A CONTAMINATION AREA. CONTRARY TO THE ABOVE, ON MAY 6, 1986, THE INSPECTORS FOUND EQUIPMENT WITH REMOVABLE CONTAMINATION GREATER THAN 500 DPM/100 CM2 BETA-GAMMA LOCATED IN UNPOSTED AREAS ON THE 633-FOOT ELEVATION LEVEL OF THE AUXILIARY BUILDING, IN THAT: (A) PIPE FITTINGS STORED IN AN OPEN CABINET ADJACENT TO

Report Period JUL 1986

INSPECTION STATUS - (CONTINUED)

* CALVERT CLIFFS 1 *

ENFORCEMENT SUMMARY

THE FREON TOOL DECONTAMINATION AREA HAD REMOVABLE CONTAMINATION OF 4000 DPM/100 CM2 BETA-GAMMA; (B) A CART LOCATED ADJACENT TO THE HOT TOOL CRIB DECONTAMINATION AREA HAD REMOVABLE CONTAMINATION OF 5 000 DPM/100 CM2 BETA-GAMMA; (C) A SLAG HAMMER STORED ON A RACK AFFIXED TO THE OUTSIDE OF AN EQUIPMENT CABINET, LOCATED ADJACENT TO THE HOT TOOL CRIB, HAD REMOVABLE CONTAMINATION OF 220,000 DPM/100 CM2 BETA-GAMMA. TECHNICAL SPECIFICATION 6.8.1 REQUIRES ADHERENCE TO THE PROCEDURES COVERING PROCESS CONTROL PROGRAM IMPLEMENTATION. PROCEDURE 12 PMP 3150 PCP.001, RADIOACTIVE WASTE PROCESS CONTROL MANUAL, REQUIRES THAT ALL PLANT GENERATED RADIOACTIVE WASTES BE TRANSFERRED, PACKAGED, AND SHIPPED SUCH THAT RADIOACTIVE WASTE SHIPMENT AND BURIAL REGULATIONS ARE SATISFIED. CONTRARY TO THE ABOVE, ON SEPTEMBER 17, 1985, AT THE BARNWELL WASTE BURIAL FACILITY, A STATE OF SOUTH CAROLINA INSPECTOR FOUND THAT THE LICENSEE WAS IN VIOLATION OF SOUTH CAROLINA DEPARTMENT OF HEALTH AND ENVIRONMENTAL CONTROL REGULATION 61-83, SECTION 1.2, FOR RADIOACTIVE WASTE SHIPMENT NO. 0985-292-A FROM D. C. COOK TO BARNWELL, IN THAT: (A) THE DISPOSAL CONTAINER WAS FOUND TO HAVE ONE END OF THE LIFTING CABLE NOT PROPERLY ATTACHED, CONTRARY TO THE REQUIREMENTS OF CONDITION 64 OF SOUTH CAROLINA RADIOACTIVE MATERIAL LICENSE NO. 097; (B) THE SHIPPING CASK WAS FOUND TO CONTAIN LOOSE CONTAMINATED MATERIAL, CONTRARY TO REQUIREMENTS OF CONDITION 60 OF SOUTH CAROLINA RADIOACTIVE MATERIAL LICENSE NO. 097. 10 CFR 71.5 PROHIBITS TRANSPORT OF ANY LICENSED MATERIAL OUTSIDE THE CONFINES OF A PLANT OR OTHER PLACE OF USE OR DELIVERY OF LICENSED MATERIAL TO A CARRIER FOR TRANSPORT UNLESS THE LICENSEE COMPLIES WITH APPLICABLE REGULATIONS OF THE DEPARTMENT OF TRANSPORTATION IN 49 CFR PARTS 170-189. 49 CFR 173.425(B)(6) REQUIRES THAT EXCLUSIVE USE SHIPMENTS OF LOW SPECIFIC ACTIVITY (LSA) MATERIAL MUST BE BRACED SO AS TO PREVENT SHIFTING OF LADING. CONTRARY TO THE ABOVE, ON APRIL 25, 1986, AT THE BARNWELL WASTE BURIAL FACILITY, A STATE OF SOUTH CAROLINA INSPECTOR FOUND THAT, DUE TO INADEQUATE BLOCKING AND BRACING, ALL THREE PACKAGES ON THE FLATBED TRAILER HAD UNDERGONE A SHIFT OF LADING DURING THE TRANSPORTATION OF LSA EXCLUSIVE USE SHIPMENT NO. 0486-293-A FROM D. C. COOK TO BARNWELL.
(8600 4)

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

Report Period JUL 1986

REPORTS FROM LICENSEE

* CALVERT CLIFFS 1 *

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
--------	------------------	-------------------	---------

NO INPUT PROVIDED.

=====

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-318 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/86 Outage + On-line Hrs: 744.0

3. Utility Contact: R. PORTER (301) 260-4868

4. Licensed Thermal Power (Mwt): 2700

5. Nameplate Rating (Gross MWe): 1012 X 0.9 = 911

6. Design Electrical Rating (Net MWe): 845

7. Maximum Dependable Capacity (Gross MWe): 860

8. Maximum Dependable Capacity (Net MWe): 825

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,087.0</u>	<u>81,815.0</u>
13. Hours Reactor Critical	<u>592.3</u>	<u>4,853.2</u>	<u>68,295.4</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>24.3</u>	<u>1,285.2</u>
15. Hrs Generator On-Line	<u>591.6</u>	<u>4,841.7</u>	<u>67,252.1</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,557,132</u>	<u>12,449,838</u>	<u>168,931,873</u>
18. Gross Elec Ener (MWH)	<u>515,538</u>	<u>4,202,500</u>	<u>55,724,059</u>
19. Net Elec Ener (MWH)	<u>493,574</u>	<u>4,026,032</u>	<u>53,176,287</u>
20. Unit Service Factor	<u>79.5</u>	<u>95.2</u>	<u>82.2</u>
21. Unit Avail Factor	<u>79.5</u>	<u>95.2</u>	<u>82.2</u>
22. Unit Cap Factor (MDC Net)	<u>80.4</u>	<u>95.9</u>	<u>78.9*</u>
23. Unit Cap Factor (DER Net)	<u>78.5</u>	<u>93.7</u>	<u>76.9</u>
24. Unit Forced Outage Rate	<u>20.5</u>	<u>4.8</u>	<u>5.9</u>
25. Forced Outage Hours	<u>152.4</u>	<u>245.3</u>	<u>4,247.1</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: 08/02/86

* CALVERT CLIFFS 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
CALVERT CLIFFS 2



JULY 1986

* Item calculated with a Weighted Average

Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

* CALVERT CLIFFS 2 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
86-08	07/07/86	F	0.0	H	5				POWER WAS REDUCED WHEN THE LOAD DISPATCHER REQUESTED A REDUCTION DUE TO A PROBLEM ON THE GRID.
86-09	07/25/86	F	152.4	A	1	86-05	CB	INSTRU	THE UNIT WAS SHUTDOWN TO REPAIR A FAILED FLEXIBLE HOSE ON A SEAL PRESSURE TRANSMITTER FOR 21B REACTOR COOLANT PUMP.

* SUMMARY *

CALVERT CLIFFS 2 OPERATED WITH 1 REDUCTION AND SHUTDOWN FOR REPAIRS ON JULY 25TH.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* CALVERT CLIFFS 2 *

F A C I L I T Y D A T A

Report Period JUL 1986

FACILITY DESCRIPTION

LOCATION
STATE.....MARYLAND
COUNTY.....CALVERT
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...40 MI S OF
ANNAPOLIS, MD
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...NOVEMBER 30, 1976
DATE ELEC ENER 1ST GENER...DECEMBER 7, 1976
DATE COMMERCIAL OPERATE....APRIL 1, 1977
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER....CHESAPEAKE BAY
ELECTRIC RELIABILITY
COUNCIL.....MID-ATLANTIC
AREA COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....BALTIMORE GAS & ELEC
CORPORATE ADDRESS.....P.O. BOX 1475
BALTIMORE, MARYLAND 21203
CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...COMBUSTION ENGINEERING
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I
IE RESIDENT INSPECTOR.....T. FOLEY
LICENSING PROJ MANAGER.....S. MCNEIL
DOCKET NUMBER.....50-318
LICENSE & DATE ISSUANCE....DPR-69, NOVEMBER 30, 1976
PUBLIC DOCUMENT ROOM.....CALVERT COUNTY LIBRARY
FOURTH STREET
PRINCE FREDERICK, MARYLAND 20678

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

Report Period JUL 1986

INSPECTION STATUS - (CONTINUED)

* CALVERT CLIFFS 2 *

OTHER ITEMS

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

REPORTS FROM LICENSEE

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT

NO INPUT PROVIDED.			
=====			

1. Docket: 50-413 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/86 Outage + On-line Hrs: 744.0

3. Utility Contact: J. A. REAVIS (704) 373-7567

4. Licensed Thermal Power (MWt): 3411

5. Nameplate Rating (Gross MWe): 1205

6. Design Electrical Rating (Net MWe): 1145

7. Maximum Dependable Capacity (Gross MWe): 1145

8. Maximum Dependable Capacity (Net MWe): 1145

9. If Changes Occur Above Since Last Report, Give Reasons:

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,087.0</u>	<u>9,552.0</u>
13. Hours Reactor Critical	<u>532.2</u>	<u>4,173.4</u>	<u>7,785.8</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>517.6</u>	<u>4,030.4</u>	<u>7,546.1</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,454,365</u>	<u>12,632,503</u>	<u>23,322,683</u>
18. Gross Elec Ener (MWH)	<u>502,127</u>	<u>4,451,740</u>	<u>8,136,009</u>
19. Net Elec Ener (MWH)	<u>460,250</u>	<u>4,151,818</u>	<u>7,592,332</u>
20. Unit Service Factor	<u>69.6</u>	<u>79.2</u>	<u>79.0</u>
21. Unit Avail Factor	<u>69.6</u>	<u>79.2</u>	<u>79.0</u>
22. Unit Cap Factor (MDC Net)	<u>54.0</u>	<u>71.3</u>	<u>69.4</u>
23. Unit Cap Factor (DER Net)	<u>54.0</u>	<u>71.3</u>	<u>69.4</u>
24. Unit Forced Outage Rate	<u>30.4</u>	<u>20.8</u>	<u>21.0</u>
25. Forced Outage Hours	<u>226.4</u>	<u>1,056.6</u>	<u>2,005.9</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):

REFUELING - AUGUST 9, 1986 - 8 WEEKS.

27. If Currently Shutdown Estimated Startup Date: N/A

 * CATAWBA 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
 CATAWBA 1



JULY 1986

Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

* CATAWBA 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
11	06/13/86	F	201.1	A	4		CJ	PIPEXX	REACTOR COOLANT LEAKAGE OUT OF SPEC DUE TO RUPTURED SOCKET-WELD ON LETDOWN.
60-P	07/09/86	S	0.0	B	5		CC	VALVEX	POWER INCREASE DELAY DUE TO CONTROL VALVE MOVEMENT TEST.
61-P	07/09/86	F	0.0	H	5		CG	ACCUMU	POWER INCREASE DELAY DUE TO INSUFFICIENT RECYCLE HOLDUP TANK VOLUME.
62-P	07/10/86	S	0.0	F	5		RC	ZZZZZZ	CORE COASTDOWN.
12	07/17/86	F	25.3	A	3		ED	INSTRU	REACTOR TRIP DUE TO RELAY LIGHT SOCKET SHORT RESULTING IN TURBINE LOAD IMBALANCE TRIP.
63-P	07/18/86	F	0.0	D	5		RC	XXXXXX	POWER INCREASE DELAY DUE TO AXIAL FLUX DIFFERENCE TIME ACQUIRED.
64-P	07/18/86	S	0.0	F	5		RC	ZZZZZZ	CORE COASTDOWN.
65-P	07/29/86	S	0.0	F	5		RC	ZZZZZZ	CORE COASTDOWN.

* SUMMARY *

CATAWBA 1 OPERATED WITH 2 OUTAGES AND 6 REDUCTIONS LISTED IN DETAIL ABOVE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)
	F-Admin		
	G-Oper Error		
	H-Other		

* CATANBA 1 *

FACILITY DATA

Report Period JUL 1986

FACILITY DESCRIPTION

LOCATION
STATE.....SOUTH CAROLINA

COUNTY.....YORK

DIST AND DIRECTION FROM
NEAREST POPULATION CTR...6 MI NNW OF
ROCK HILL, SC

TYPE OF REACTOR.....PWR

DATE INITIAL CRITICALITY...JANUARY 7, 1985

DATE ELEC ENER 1ST GENER...JANUARY 22, 1985

DATE COMMERCIAL OPERATE....JUNE 29, 1985

CONDENSER COOLING METHOD...MDCT

CONDENSER COOLING WATER....LAKE WYLIE

ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....DUKE POWER

CORPORATE ADDRESS.....422 SOUTH CHURCH STREET
CHARLOTTE, NORTH CAROLINA 28242

CONTRACTOR
ARCHITECT/ENGINEER.....DUKE POWER

NUC STEAM SYS SUPPLIER...WESTINGHOUSE

CONSTRUCTOR.....DUKE POWER

TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II

IE RESIDENT INSPECTOR.....P. SKINNER

LICENSING PROJ MANAGER....K. JABBOUR
DOCKET NUMBER.....50-413

LICENSE & DATE ISSUANCE...NPF-35, JANUARY 17, 1985

PUBLIC DOCUMENT ROOM.....YORK COUNTY LIBRARY
138 E. BLACK STREET
ROCK HILL, SOUTH CAROLINA 29730

INSPECTION STATUS

INSPECTION SUMMARY

+ INSPECTION APRIL 26 - MAY 25 (86-19): THIS ROUTINE, UNANNOUNCED INSPECTION WAS CONDUCTED ON SITE IN THE AREAS OF REVIEW OF PLANT OPERATIONS; SURVEILLANCE OBSERVATION; MAINTENANCE OBSERVATION; REVIEW OF LICENSEE NONROUTINE EVENT REPORTS; AND FOLLOWUP OF PREVIOUSLY IDENTIFIED ITEMS. OF THE SIX (6) AREAS INSPECTED, NO APPARENT VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION MAY 13-16 AND JUNE 2 (86-20): THIS ROUTINE, UNANNOUNCED INSPECTION INVOLVED ONSITE INSPECTION IN THE AREA OF RADIATION PROTECTION INCLUDING: STARTUP SHIELDING SURVEYS; INTERNAL EXPOSURE CONTROL AND ASSESSMENT; EXTERNAL EXPOSURE CONTROL AND PERSONAL DOSIMETRY; RADIOACTIVE MATERIALS CONTROL, POSTING AND LABELING; SOLID RADIOACTIVE WASTE CLASSIFICATION AND CHARACTERIZATION; TRANSPORTATION OF RADIOACTIVE MATERIALS; AND PROGRAM FOR MAINTAINING EXPOSURE AS LOW AS REASONABLY ACHIEVABLE (ALARA). ONE VIOLATION - FAILURE TO MAINTAIN RADIATION EXPOSURE RECORDS IN ACCORDANCE WITH INSTRUCTIONS CONTAINED ON FORM NRC-5.

INSPECTION MAY 8-13, 19-23 AND 27-29 (86-21): THIS ROUTINE, UNANNOUNCED INSPECTION ADDRESSED THE AREAS OF REVIEW OF PRECRITICAL DATA, WITNESSING OF INITIAL CRITICALITY, WITNESSING OF STARTUP TESTS AND REVIEW OF PROPOSED TESTS FOR UNIT 2, AND REVIEW OF SURVEILLANCE TESTS FOR UNIT 1. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION MAY 26 - JUNE 25 (86-24): THIS ROUTINE, UNANNOUNCED INSPECTION WAS CONDUCTED ON SITE INSPECTING IN THE AREAS OF REVIEW OF PLANT OPERATIONS; SURVEILLANCE OBSERVATION; MAINTENANCE OBSERVATION; REVIEW OF LICENSEE NONROUTINE EVENT REPORTS; PROCEDURES; SURVEY OF LICENSEE RESPONSE TO SAFETY ISSUES; FOLLOWUP OF INFORMATION NOTICES; AND PREPARATIONS FOR REFUELING; OF THE 8 AREAS INSPECTED, 2 APPARENT VIOLATIONS WERE IDENTIFIED, (FAILURE TO FOLLOW PROCEDURES; AND FAILURE TO PROVIDE ADEQUATE PROCEDURES).

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

NONE.

LAST IE SITE INSPECTION DATE: MAY 26 - JUNE 25, 1986 +

INSPECTION REPORT NO: 50-413/86-24 +

REPORTS FROM LICENSEE

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
86-021	04/17/86	05/16/86	INADVERTENT START OF TURBINE DRIVEN AUXILIARY FEEDWATER PUMP DUE TO DEFECTIVE PROCEDURE.
86-022	04/19/86	05/19/86	REACTOR TRIPPED WHEN ALL 3 FLOW TRANSMITTERS ON LOOP C OF REACTOR COOLANT SYSTEM INDICATED A LOW FLOW; CAUSE - DEFECTIVE PROCEDURE.
86-028	06/06/86	07/07/86	UNIT SHUTDOWN DUE TO UNIDENTIFIED REACTOR COOLANT LEAKAGE; CAUSE - UNKNOWN.
86-029	06/06/86	07/07/86	ESF ACTUATION OCCURRED DURING TESTING OF THE 2B SEQUENCER; CAUSE - UNKNOWN.
86-030	06/11/86	07/11/86	REACTOR TRIP ON LOW-LOW STEAM GENERATOR LEVEL DUE TO PERSONNEL ERROR.
86-031	06/13/86	07/11/86	WELD BREAK ON LETDOWN PIPING RESULTED IN EXCESSIVE REACTOR COOLANT SYSTEM LEAKAGE CAUSING A FORCED SHUTDOWN; CAUSE - DESIGN, MANUFACTURING, CONSTRUCTION/INSTALLATION DEFICIENCY.

27. If Currently Shutdown Estimated Startup Date: 08/15/86

JULY 1986

Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

* COOK 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
250	05/28/86	F	163.6	A	4	86-012-0	HA	INSTRU	THE OUTAGE WHICH BEGAN ON 05/28/86 FOLLOWING A TURBINE TRIP FROM 90% RTP HAS BEEN COMPLETED. THE UNIT WAS RETURNED TO SERVICE AT 1937 HOURS ON 07/07/86 AND WAS HELD AT 25% FOR TURBINE ROTOR WARMING IN PREPARATION FOR TURBINE OVERSPEED TESTING.
251	07/07/86	S	1.0	B	1		ZZ	ZZZZZZ	THE TURBINE GENERATOR WAS REMOVED FROM PARALLEL AT 0307 HOURS FOR TURBINE OVERSPEED TESTING. THE UNIT WAS RETURNED TO SERVICE AT 0405 HOURS THE SAME DAY.
252	07/10/86	F	15.1	B	1	86-007	ZZ	ZZZZZZ	THE UNIT WAS REMOVED FROM SERVICE WHEN IT WAS DETERMINED THAT A NON-COMPLIANCE EXISTED ON TWO TECHNICAL SPECIFICATION REQUIRED SURVEILLANCE TESTS. THE TESTING WAS COMPLETED AND THE UNIT RETURNED TO SERVICE ON 07/11/86.
253	07/22/86	F	226.9	G	3		ZZ	ZZZZZZ	A TURBINE/REACTOR TRIP OCCURRED WHILE PERFORMING A ROUTINE CALIBRATION OF THE TURBINE GENERATOR STATOR COOLING WATER LOW PRESSURE TRIP. THE TRIP OCCURRED DUE TO INADEQUATE BLOCKING OF THE TRIP CIRCUIT.

* SUMMARY *

COOK 1 OPERATED WITH 4 OUTAGES IN JULY, AND SHUTDOWN FOR REPAIRS ON THE 27TH.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* COOK 1 *

FACILITY DATA

Report Period JUL 1986

FACILITY DESCRIPTION

LOCATION
STATE.....MICHIGAN

COUNTY.....BERRIEN

DIST AND DIRECTION FROM
NEAREST POPULATION CTR...11 MI S OF
BENTON HARBOR, MI

TYPE OF REACTOR.....PWR

DATE INITIAL CRITICALITY...JANUARY 18, 1975

DATE ELEC ENER 1ST GENER...FEBRUARY 10, 1975

DATE COMMERCIAL OPERATE...AUGUST 27, 1975

CONDENSER COOLING METHOD...ONCE THRU

CONDENSER COOLING WATER...LAKE MICHIGAN

ELECTRIC RELIABILITY
COUNCIL.....EAST CENTRAL AREA
RELIABILITY COORDINATION
AGREEMENT

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....INDIANA & MICHIGAN ELECTRIC

CORPORATE ADDRESS.....1 RIVERSIDE PLAZA
COLUMBUS, OHIO 43216

CONTRACTOR
ARCHITECT/ENGINEER.....AMERICAN ELEC. POWER SERVICE CORP.

NUC STEAM SYS SUPPLIER...WESTINGHOUSE

CONSTRUCTOR.....AMERICAN ELEC. POWER SERVICE CORP.

TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III

IE RESIDENT INSPECTOR.....B. JORGENSEN

LICENSING PROJ MANAGER....D. WIGGINTON
DOCKET NUMBER.....50-315

LICENSE & DATE ISSUANCE...DPR-58, OCTOBER 25, 1974

PUBLIC DOCUMENT ROOM.....MAUDE PRESTON PALENSKE MEMORIAL LIBRARY
500 MARKET STREET
ST. JOSEPH, MICHIGAN 49085

INSPECTION STATUS

INSPECTION SUMMARY

INSPECTION DURING THE PERIOD APRIL 7 THROUGH MAY 29 (86001; 86001): UNANNOUNCED INSPECTION OF THE RADIATION PROTECTION PROGRAM DURING A REFUELING AND MAINTENANCE OUTAGE INCLUDING: STATUS OF THE RADIATION PROTECTION IMPROVEMENT PROGRAM; CHANGES IN ORGANIZATION, PERSONNEL, FACILITIES, EQUIPMENT, PROGRAMS, AND PROCEDURES; AUDITS AND APPRAISALS; PLANNING AND PREPARATION; TRAINING AND QUALIFICATIONS OF NEW PERSONNEL; INTERNAL AND EXTERNAL EXPOSURE CONTROL; CONTROL OF RADIOACTIVE MATERIALS AND CONTAMINATION, SURVEYS, AND MONITORING; AND THE ALARA PROGRAM. ALSO, CERTAIN TMI ACTION PLAN ITEMS, OPEN ITEMS, RADIATION PROTECTION STAFF STABILITY, USE OF THE HNS WASTE SORTER, IE INFORMATION NOTICES NO. 85-61 AND 86-22, AND CERTAIN RADIOACTIVE MATERIAL SHIPMENT CONCERNS IDENTIFIED AT THE BARNWELL WASTE BURIAL FACILITY BY STATE OF SOUTH CAROLINA INSPECTORS WERE REVIEWED. THREE VIOLATIONS WERE IDENTIFIED (FAILURE TO COMPLY WITH RADIOACTIVE WASTE BURIAL SITE REGULATIONS; FAILURE TO PREVENT SHIFTING OF RADIOACTIVE WASTE SHIPMENT LADING; AND FAILURE TO POST CONTAMINATED AREAS).

INSPECTION ON JUNE 9-11 (86016; 86016): ROUTINE, ANNOUNCED INSPECTION OF THE ANNUAL D. C. COOK EMERGENCY PREPAREDNESS EXERCISE INVOLVING OBSERVATIONS BY FIVE NRC REPRESENTATIVES OF KEY FUNCTIONS AND LOCATIONS DURING THE EXERCISE. THE INSPECTION WAS CONDUCTED BY THREE NRC INSPECTORS AND TWO CONSULTANTS. ALTHOUGH NO ITEMS OF NONCOMPLIANCE, DEFICIENCIES, OR DEVIATIONS WERE IDENTIFIED, FIVE EXERCISE WEAKNESSES WERE IDENTIFIED AND SUMMARIZED IN THE ATTACHMENT TO THE REPORT'S TRANSMITTAL LETTER.

INSPECTION ON MAY 13 THROUGH JUNE 16 (86022; 86022): ROUTINE, UNANNOUNCED INSPECTION BY THE RESIDENT INSPECTORS OF LICENSEE ACTIONS ON PREVIOUSLY IDENTIFIED ITEMS; OPERATIONAL SAFETY VERIFICATION; REACTOR TRIP; MAINTENANCE; SURVEILLANCE; REPORTABLE EVENTS; REGIONAL REQUESTS; AND MISCELLANEOUS INSPECTION. OF THE EIGHT AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED IN SEVEN AREAS. ONE VIOLATION (PROCEDURE FAILED TO PROPERLY RESTORE SYSTEM AFTER TEST) WAS IDENTIFIED IN THE REMAINING

INSPECTION STATUS - (CONTINUED)

```

XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX
X                                COOK 1                                X
XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX

```

AREA.

INSPECTION ON JUNE 26 (86026): ROUTINE, UNANNOUNCED INSPECTION OF THE RESOLUTION OF AN IEIE BULLETIN. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

UNIT 1 TECHNICAL SPECIFICATION 6.8.1.A REQUIRES WRITTEN PROCEDURES BE ESTABLISHED, IMPLEMENTED AND MAINTAINED COVERING THE APPLICABLE PROCEDURES RECOMMENDED IN REGULATORY GUIDE 1.33 APPENDIX A, NOVEMBER 1972, WHICH INCLUDES ADMINISTRATIVE PROCEDURES FOR EQUIPMENT CONTROL AND FOR PROCEDURE REVIEW AND APPROVAL. PLANT MANAGER'S INSTRUCTION PMI-2010, "PLANT MANAGER AND DEPARTMENT HEAD INSTRUCTIONS, PROCEDURES, AND ASSOCIATED INDEXES," AN ADMINISTRATIVE PROCEDURE FOR EQUIPMENT CONTROL AND PROCEDURE REVIEW AND APPROVAL REQUIRES IN PARAGRAPH 3.7.1 THAT PROCEDURES BE PREPARED UTILIZING THE FORMAT SPECIFIED IN THE ASSOCIATED ATTACHMENTS 1 AND 2. ATTACHMENT 2, "FORMAT OF PROCEDURES" AT PARAGRAPH 4.1 ENTITLED, "RESTORATION" REQUIRES STEPS BE PROVIDED TO ASSURE NECESSARY RESTORATION OF ALL CONTROLS AND EQUIPMENT WHOSE STATUS WAS CHANGED DURING THE PROCEDURE. CONTRARY TO THE ABOVE, LICENSEE PROCEDURE 1 THP 6030 IMP.076, "INCORE THERMOCOUPLE AND REACTOR COOLANT SYSTEM RTD CROSS CALIBRATION PROCEDURE" PROVIDES FOR INSTALLATION OF CALIBRATED PRESSURE GAUGES AT VARIOUS POINTS IN THE MAIN STEAM SYSTEM, BUT DOES NOT CONTAIN STEPS TO REMOVE THE INSTALLED GAUGES ON COMPLETION OF THE TEST. AS A CONSEQUENCE, FOLLOWING COMPLETION OF THE SUBJECT TEST ON OCTOBER 31, 1985 WITH THE PLANT IN MODE 3, FOUR PRESSURE GAUGES, ONE UPSTREAM OF EACH OF THE FOUR MAIN STEAM ISOLATION VALVES, WERE NOT REMOVED. THE PLANT SUBSEQUENTLY OPERATED IN MODE 1 FOR AN EXTENDED PERIOD WITH THE GAUGES STILL INSTALLED. SOME ITEMS WERE NOT SEARCHED OR SECURED AT REQUIRED BY THE SECURITY PLAN.

(8602 4)

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

SHUTDOWN FOR REPAIRS.

LAST IE SITE INSPECTION DATE: 08/22/86

INSPECTION REPORT NO: 86031

Report Period JUL 1986

REPORTS FROM LICENSEE

```
*****
*          COOK 1          *
*****
```

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
85-48	09/17/85	07/01/86	INCORRECT REPLACEMENT PART INSTALLED ON THE TURBINE DRIVEN FEEDWATER PUMP, CAUSED BY INADEQUATE PROGRAM CONTROLS
85-64	11/23/85	07/15/86	NON-CONSERVATIVE FLUX RATE TRIP SETPOINTS DUE TO INADEQUATE CALIBRATION PROCEDURES
85-69	11/17/85	07/07/86	OPERATION WITH INOPERABLE INTERMEDIATE RANGE NEUTRON FLUX DETECTOR, CAUSED BY INSTRUMENT DRIFT
86-13	05/13/86	07/14/86	FAILURE TO LITERALLY COMPLY WITH TECHNICAL SPECIFICATION REQUIREMENTS DUE TO PROCEDURAL DEFICIENCIES
86-14	06/28/86	07/28/86	FAILURE TO VERIFY RESIDUAL HEAT REMOVAL SYSTEM INTERLOCK ACTION DUE TO PROCEDURAL DEFICIENCY

INSPECTION STATUS - (CONTINUED)

PAGE 2-073

Report Period JUL 1986

REPORTS FROM LICENSEE

XXXXXXXXXXXXXXXXXXXXXXXXXXXXX
X COOK 1 X
XXXXXXXXXXXXXXXXXXXXXXXXXXXXX

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
85-48	09/17/85	07/01/86	INCORRECT REPLACEMENT PART INSTALLED ON THE TURBINE DRIVEN FEEDWATER PUMP, CAUSED BY INADEQUATE PROGRAM CONTROLS
85-64	11/23/85	07/15/86	NON-CONSERVATIVE FLUX RATE TRIP SETPOINTS DUE TO INADEQUATE CALIBRATION PROCEDURES
85-69	11/17/85	07/07/86	OPERATION WITH INOPERABLE INTERMEDIATE RANGE NEUTRON FLUX DETECTOR, CAUSED BY INSTRUMENT DRIFT
86-13	05/13/86	07/14/86	FAILURE TO LITERALLY COMPLY WITH TECHNICAL SPECIFICATION REQUIREMENTS DUE TO PROCEDURAL DEFICIENCIES
86-14	06/28/86	07/28/86	FAILURE TO VERIFY RESIDUAL HEAT REMOVAL SYSTEM INTERLOCK ACTION DUE TO PROCEDURAL DEFICIENCY

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-316 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/86 Outage + On-line Hrs: 744.0

3. Utility Contact: C. ZAJKA (616) 465-5901

4. Licensed Thermal Power (MWt): 3411

5. Nameplate Rating (Gross MWe): 1333 X 0.85 = 1133

6. Design Electrical Rating (Net MWe): 1100

7. Maximum Dependable Capacity (Gross MWe): 1100

8. Maximum Dependable Capacity (Net MWe): 1060

9. If Changes Occur Above Since Last Report, Give Reasons: NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any: NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,087.0</u>	<u>75,215.0</u>
13. Hours Reactor Critical	<u>534.9</u>	<u>1,887.5</u>	<u>50,916.3</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>444.2</u>	<u>1,716.7</u>	<u>49,570.6</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>980,980</u>	<u>4,385,577</u>	<u>158,060,029</u>
18. Gross Elec Ener (MWH)	<u>294,480</u>	<u>1,392,260</u>	<u>51,078,670</u>
19. Net Elec Ener (MWH)	<u>278,587</u>	<u>1,332,059</u>	<u>49,233,409</u>
20. Unit Service Factor	<u>59.7</u>	<u>33.7</u>	<u>68.1</u>
21. Unit Avail Factor	<u>59.7</u>	<u>33.7</u>	<u>68.1</u>
22. Unit Cap Factor (MDC Net)	<u>35.3</u>	<u>24.7</u>	<u>63.8</u>
23. Unit Cap Factor (DER Net)	<u>34.0</u>	<u>23.8</u>	<u>62.4</u>
24. Unit Forced Outage Rate	<u>10.3</u>	<u>10.0</u>	<u>15.6</u>
25. Forced Outage Hours	<u>51.2</u>	<u>190.4</u>	<u>9,155.9</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration): NONE

27. If Currently Shutdown Estimated Startup Date: N/A

 * COOK 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
 COOK 2



JULY 1986

Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

* COOK 2 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
172	02/28/86	S	248.6	C	4		RC	FUELXX	THE UNIT WAS REMOVED FROM SERVICE ON 02/28/86 FOR THE SCHEDULED CYCLE 5 OR 6 REFUELING/MAINTENANCE OUTAGE. THE OUTAGE WORK HAS BEEN COMPLETED AND INITIAL CRITICALITY FOR CYCLE 6 OCCURRED ON 07/07/86.
173	07/18/86	F	51.2	A	3	LATER	CH	INSTRU	WHILE HOLDING REACTOR POWER AT 69% FOR THE POWER TESTING PROGRAM, A TURBINE/REACTOR TRIP OCCURRED DUE TO HIGH-HIGH LEVEL IN NO. 22 STEAM GENERATOR. THE HIGH LEVEL RESULTED FROM A FAILURE OF A FEED WATER FLOW TRANSMITTER.

* SUMMARY *

COOK 2 RETURNED ONLINE FROM REFUELING AND MAINTENANCE ON JULY 11TH, AND OPERATED WITH 1 ADDITIONAL OUTAGE FOR EQUIPMENT REPAIR.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* COOK 2 *

FACILITY DATA

Report Period JUL 1986

FACILITY DESCRIPTION

LOCATION
STATE.....MICHIGAN
COUNTY.....BERRIEN
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...11 MI S OF
BENTON HARBOR, MI
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...MARCH 10, 1978
DATE ELEC ENER 1ST GENER...MARCH 22, 1978
DATE COMMERCIAL OPERATE...JULY 1, 1978
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...LAKE MICHIGAN
ELECTRIC RELIABILITY
COUNCIL.....EAST CENTRAL AREA
RELIABILITY COORDINATION
AGREEMENT

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....INDIANA & MICHIGAN ELECTRIC
CORPORATE ADDRESS.....1 RIVERSIDE PLAZA
COLUMBUS, OHIO 43216
CONTRACTOR
ARCHITECT/ENGINEER.....AMERICAN ELEC. POWER SERVICE CORP.
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....J. A. JONES CONSTRUCTION
TURBINE SUPPLIER.....BROWN BOVERI

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III
IE RESIDENT INSPECTOR.....B. JORGENSEN
LICENSING PROJ MANAGER.....D. WIGGINTON
DOCKET NUMBER.....50-316
LICENSE & DATE ISSUANCE...DPR-74, DECEMBER 23, 1977
PUBLIC DOCUMENT ROOM.....MAUDE PRESTON PALENSKE MEMORIAL LIBRARY
500 MARKET STREET
ST. JOSEPH, MICHIGAN 49085

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION DURING THE PERIOD APRIL 7 THROUGH MAY 29 (86001; 86001): UNANNOUNCED INSPECTION OF THE RADIATION PROTECTION PROGRAM DURING A REFUELING AND MAINTENANCE OUTAGE INCLUDING: STATUS OF THE RADIATION PROTECTION IMPROVEMENT PROGRAM; CHANGES IN ORGANIZATION, PERSONNEL, FACILITIES, EQUIPMENT, PROGRAMS, AND PROCEDURES; AUDITS AND APPRAISALS; PLANNING AND PREPARATION; TRAINING AND QUALIFICATIONS OF NEW PERSONNEL; INTERNAL AND EXTERNAL EXPOSURE CONTROL; CONTROL OF RADIOACTIVE MATERIALS AND CONTAMINATION, SURVEYS, AND MONITORING; AND THE ALARA PROGRAM. ALSO, CERTAIN TMI ACTION PLAN ITEMS, OPEN ITEMS, RADIATION PROTECTION STAFF STABILITY, USE OF THE HNS WASTE SORTER, IE INFORMATION NOTICES NO. 85-61 AND 86-22, AND CERTAIN RADIOACTIVE MATERIAL SHIPMENT CONCERNS IDENTIFIED AT THE BARNWELL WASTE BURIAL FACILITY BY STATE OF SOUTH CAROLINA INSPECTORS WERE REVIEWED. THREE VIOLATIONS WERE IDENTIFIED (FAILURE TO COMPLY WITH RADIOACTIVE WASTE BURIAL SITE REGULATIONS; FAILURE TO PREVENT SHIFTING OF RADIOACTIVE WASTE SHIPMENT LADING; AND FAILURE TO POST CONTAMINATED AREAS).

INSPECTION ON JUNE 9-11 (86016; 86016): ROUTINE, ANNOUNCED INSPECTION OF THE ANNUAL D. C. COOK EMERGENCY PREPAREDNESS EXERCISE INVOLVING OBSERVATIONS BY FIVE NRC REPRESENTATIVES OF KEY FUNCTIONS AND LOCATIONS DURING THE EXERCISE. THE INSPECTION WAS CONDUCTED BY THREE NRC INSPECTORS AND TWO CONSULTANTS. ALTHOUGH NO ITEMS OF NONCOMPLIANCE, DEFICIENCIES, OR DEVIATIONS WERE IDENTIFIED, FIVE EXERCISE WEAKNESSES WERE IDENTIFIED AND SUMMARIZED IN THE ATTACHMENT TO THE REPORT'S TRANSMITTAL LETTER.

INSPECTION ON MAY 13 THROUGH JUNE 16 (86022; 86022): ROUTINE, UNANNOUNCED INSPECTION BY THE RESIDENT INSPECTORS OF LICENSEE ACTIONS ON PREVIOUSLY IDENTIFIED ITEMS; OPERATIONAL SAFETY VERIFICATION; REACTOR TRIP; MAINTENANCE; SURVEILLANCE; REPORTABLE EVENTS; REGIONAL REQUESTS; AND MISCELLANEOUS INSPECTION. OF THE EIGHT AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED IN SEVEN AREAS. ONE VIOLATION (PROCEDURE FAILED TO PROPERLY RESTORE SYSTEM AFTER TEST) WAS IDENTIFIED IN THE REMAINING

INSPECTION SUMMARY

AREA.

INSPECTION OF JUNE 26 (86026): ROUTINE, UNANNOUNCED INSPECTION OF THE RESOLUTION OF AN IEEE BULLETIN. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

TECHNICAL SPECIFICATION 6.11 REQUIRES ADHERENCE TO RADIATION PROTECTION PROCEDURES. PROCEDURE 12 THP 6010.RAD.404, ESTABLISHING POSTED AREAS, REQUIRES ANY AREA IN WHICH THE REMOVABLE CONTAMINATION ON ANY ACCESSIBLE SURFACE OR EQUIPMENT EXCEEDS 500 DPM/100 CM2 BETA-GAMMA TO BE POSTED AS A CONTAMINATION AREA. CONTRARY TO THE ABOVE, ON MAY 6, 1986, THE INSPECTORS FOUND EQUIPMENT WITH REMOVABLE CONTAMINATION GREATER THAN 500 DPM/100 CM2 BETA-GAMMA LOCATED IN UNPOSTED AREAS ON THE 633-FOOT ELEVATION LEVEL OF THE AUXILIARY BUILDING, IN THAT: (A) PIPE FITTINGS STORED IN AN OPEN CABINET ADJACENT TO THE FREON TOOL DECONTAMINATION AREA HAD REMOVABLE CONTAMINATION OF 4000 DPM/100 CM2 BETA-GAMMA; (B) A CART LOCATED ADJACENT TO THE HOT TOOL CRIB DECONTAMINATION AREA HAD REMOVABLE CONTAMINATION OF 5 000 DPM/100 CM2 BETA-GAMMA; (C) A SLAG HAMMER STORED ON A RACK AFFIXED TO THE OUTSIDE OF AN EQUIPMENT CABINET, LOCATED ADJACENT TO THE HOT TOOL CRIB, HAD REMOVABLE CONTAMINATION OF 220,000 DPM/100 CM2 BETA-GAMMA. TECHNICAL SPECIFICATION 6.8.1 REQUIRES ADHERENCE TO THE PROCEDURES COVERING PROCESS CONTROL PROGRAM IMPLEMENTATION. PROCEDURE 12 PMP 3150 PCP.001, RADIOACTIVE WASTE PROCESS CONTROL MANUAL, REQUIRES THAT ALL PLANT GENERATED RADIOACTIVE WASTES BE TRANSFERRED, PACKAGED, AND SHIPPED SUCH THAT RADIOACTIVE WASTE SHIPMENT AND BURIAL REGULATIONS ARE SATISFIED. CONTRARY TO THE ABOVE, ON SEPTEMBER 17, 1985, AT THE BARNWELL WASTE BURIAL FACILITY, A STATE OF SOUTH CAROLINA INSPECTOR FOUND THAT THE LICENSEE WAS IN VIOLATION OF SOUTH CAROLINA DEPARTMENT OF HEALTH AND ENVIRONMENTAL CONTROL REGULATION 61-83, SECTION 1.2, FOR RADIOACTIVE WASTE SHIPMENT NO. 0985-292-A FROM D. C. COOK TO BARNWELL, IN THAT: (A) THE DISPOSAL CONTAINER WAS FOUND TO HAVE ONE END OF THE LIFTING CABLE NOT PROPERLY ATTACHED, CONTRARY TO THE REQUIREMENTS OF CONDITION 64 OF SOUTH CAROLINA RADIOACTIVE MATERIAL LICENSE NO. 097; (B) THE SHIPPING CASK WAS FOUND TO CONTAIN LOOSE CONTAMINATED MATERIAL, CONTRARY TO REQUIREMENTS OF CONDITION 60 OF SOUTH CAROLINA RADIOACTIVE MATERIAL LICENSE NO. 097. 10 CFR 71.5 PROHIBITS TRANSPORT OF ANY LICENSED MATERIAL OUTSIDE THE CONFINES OF A PLANT OR OTHER PLACE OF USE OR DELIVERY OF LICENSED MATERIAL TO A CARRIER FOR TRANSPORT UNLESS THE LICENSEE COMPLIES WITH APPLICABLE REGULATIONS OF THE DEPARTMENT OF TRANSPORTATION IN 49 CFR PARTS 170-189. 49 CFR 173.425(b)(6) REQUIRES THAT EXCLUSIVE USE SHIPMENTS OF LOW SPECIFIC ACTIVITY (LSA) MATERIAL MUST BE BRACED SO AS TO PREVENT SHIFTING OF LADING. CONTRARY TO THE ABOVE, ON APRIL 25, 1986, AT THE BARNWELL WASTE BURIAL FACILITY, A STATE OF SOUTH CAROLINA INSPECTOR FOUND THAT, DUE TO INADEQUATE BLOCKING AND BRACING, ALL THREE PACKAGES ON THE FLATBED TRAILER HAD UNDERGONE A SHIFT OF LADING DURING THE TRANSPORTATION OF LSA EXCLUSIVE USE SHIPMENT NO. 0486-294-A FROM D. C. COOK TO BARNWELL. (8600 4)

UNIT 1 TECHNICAL SPECIFICATION 6.8.1.A REQUIRES WRITTEN PROCEDURES BE ESTABLISHED, IMPLEMENTED AND MAINTAINED COVERING THE APPLICABLE PROCEDURES RECOMMENDED IN REGULATORY GUIDE 1.33 APPENDIX A, NOVEMBER 1972, WHICH INCLUDES ADMINISTRATIVE PROCEDURES FOR EQUIPMENT CONTROL AND FOR PROCEDURE REVIEW AND APPROVAL. PLANT MANAGER'S INSTRUCTION PMI-2010, "PLANT MANAGER AND DEPARTMENT HEAD INSTRUCTIONS, PROCEDURES, AND ASSOCIATED INDEXES," AN ADMINISTRATIVE PROCEDURE FOR EQUIPMENT CONTROL AND PROCEDURE REVIEW AND APPROVAL REQUIRES IN PARAGRAPH 3.7.1 THAT PROCEDURES BE PREPARED UTILIZING THE FORMAT SPECIFIED IN THE ASSOCIATED ATTACHMENTS 1 AND 2. ATTACHMENT 2, "FORMAT OF PROCEDURES" AT PARAGRAPH 4.1 ENTITLED, "RESTORATION" REQUIRES STEPS BE PROVIDED TO ASSURE NECESSARY RESTORATION OF ALL CONTROLS AND EQUIPMENT WHOSE STATUS WAS CHANGED DURING THE PROCEDURE. CONTRARY TO THE ABOVE, LICENSEE PROCEDURE 1 THP 6030 IMP.076, "INCORE THERMOCOUPLE AND REACTOR COOLANT SYSTEM RTD CROSS CALIBRATION PROCEDURE" PROVIDES FOR INSTALLATION OF CALIBRATED PRESSURE GAUGES AT VARIOUS POINTS IN THE MAIN S.FAM SYSTEM, BUT DOES NOT CONTAIN STEPS TO REMOVE THE INSTALLED GAUGES ON COMPLETION OF THE TEST. AS A CONSEQUENCE, FOLLOWING COMPLETION OF THE SUBJECT TEST ON OCTOBER 31, 1985 WITH THE PLANT IN MODE 3, FOUR PRESSURE GAUGES, ONE UPSTREAM OF EACH OF THE FOUR MAIN STEAM ISOLATION VALVES, WERE NOT REMOVED. THE PLANT SUBSEQUENTLY OPERATED IN MODE 1 FOR AN EXTENDED PERIOD WITH THE GAUGES STILL INSTALLED. SOME ITEMS WERE NOT SEARCHED OR SECURED AT REQUIRED BY THE SECURITY PLAN. (8602 4)

OTHER ITEMS

INSPECTION STATUS - (CONTINUED)

```
*****  
*                COOK 2                *  
*****
```

INSPECTION REPORT NO: 86031

REPORTS FROM LICENSEE

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
86-15	04/08/86	06/06/86	INOPERABLE FIRE SEALS, NOT IDENTIFIED DURING PRIOR INSPECTIONS
86-18	05/09/86	06/09/86	MISSED SURVEILLANCE, CAUSED BY MIS-INTERPRETATION OF TECHNICAL SPECIFICATIONS
86-19	06/05/86	07/03/86	MISSED FIRE INSPECTION OF INOPERABLE FIRE DOOR DUE TO PERSONNEL ERROR
86-20	06/23/86	07/22/86	MISSED T/S SURVEILLANCE DUE TO THE FAILURE TO IDENTIFY/PERFORM APPROPRIATE POST-DESIGN CHANGE TESTING

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-298 O P E R A T I N G S T A T U S
2. Reporting Period: 07/01/86 Outage + On-line Hrs: 744.0

3. Utility Contact: K. E. SUTTON (402) 825-3811

4. Licensed Thermal Power (MWt): 2381

5. Nameplate Rating (Gross MWe): 983 X 0.85 = 836

6. Design Electrical Rating (Net MWe): 778

7. Maximum Dependable Capacity (Gross MWe): 787

8. Maximum Dependable Capacity (Net MWe): 764

9. If Changes Occur Above Since Last Report, Give Reasons: NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any: NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,087.0</u>	<u>105,936.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>5,059.0</u>	<u>80,072.1</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>5,047.0</u>	<u>78,752.8</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,599,720</u>	<u>9,994,570</u>	<u>154,857,236</u>
18. Gross Elec Ener (MWH)	<u>529,844</u>	<u>3,338,360</u>	<u>49,478,333</u>
19. Net Elec Ener (MWH)	<u>510,041</u>	<u>3,217,205</u>	<u>47,671,565</u>
20. Unit Service Factor	<u>100.0</u>	<u>99.2</u>	<u>74.3</u>
21. Unit Avail Factor	<u>100.0</u>	<u>99.2</u>	<u>74.3</u>
22. Unit Cap Factor (MDC Net)	<u>89.7</u>	<u>82.8</u>	<u>58.9</u>
23. Unit Cap Factor (DER Net)	<u>88.1</u>	<u>81.3</u>	<u>57.8</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.8</u>	<u>4.8</u>
25. Forced Outage Hours	<u>.0</u>	<u>40.0</u>	<u>3,314.7</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):

REFUELING & MAINTENANCE: 10/3/86 - 10 WEEKS.

27. If Currently Shutdown Estimated Startup Date: N/A

* COOPER STATION *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
COOPER STATION



JULY 1986

Report Period JUL 1956

UNIT SHUTDOWNS / REDUCTIONS

* COOPER STATION *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
-----	------	------	-------	--------	--------	------------	--------	-----------	---

NONE

* SUMMARY *

COOPER STATION OPERATED ROUTINELY DURING THE JULY REPORT PERIOD.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

X COOPER STATION X

FACILITY DATA

Report Period JUL 1986

FACILITY DESCRIPTION

LOCATION
STATE.....NEBRASKA
COUNTY.....NEMAHA
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...23 MI S OF
NEBRASKA CITY, NEB
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...FEBRUARY 21, 1974
DATE ELEC ENER 1ST GENER...MAY 10, 1974
DATE COMMERCIAL OPERATE....JULY 1, 1974
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...MISSOURI RIVER
ELECTRIC RELIABILITY
COUNCIL.....MID-CONTINENT AREA
RELIABILITY COORDINATION
AGREEMENT

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....NEBRASKA PUBLIC POWER DISTRICT
CORPORATE ADDRESS.....P.O. BOX 499
COLUMBUS, NEBRASKA 68601
CONTRACTOR
ARCHITECT/ENGINEER.....BURNS & ROE
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....BURNS & ROE
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....IV
IE RESIDENT INSPECTOR.....D. DUBOIS
LICENSING PROJ MANAGER.....W. LONG
DOCKET NUMBER.....50-298
LICENSE & DATE ISSUANCE...DPR-46, JANUARY 18, 1974
PUBLIC DOCUMENT ROOM.....AUBURN PUBLIC LIBRARY
1118 15TH STREET
AUBURN, NEBRASKA 68305

INSPECTION STATUS

INSPECTION SUMMARY

INSPECTION CONDUCTED APRIL 1-MAY 31, 1986 (86-14) ROUTINE, UNANNOUNCED INSPECTION OF PREVIOUS IDENTIFIED INSPECITON FINDINGS, LICENSEE EVENT REPORTS, SPENT FUEL SHIPMENTS, OPERATIONAL SAFETY VERIFICATION, AND MONTHLY SURVEILLANCE AND MAINTENANCE ACTIVITIES. WITHIN THE SIX AREAS INSPECTED, THREE VIOLATIONS AND TWO DEVIATIONS WERE IDENTIFIED.

INSPECTION CONDUCTED APRIL 21-25, 1986 (86-15) NONROUTINE, ANNOUNCED INSPECTION FOR IMPLEMENTATION OF AND COMPLIANCE TO THE SAFE SHUTDOWN REQUIREMENTS OF 10 CFR 50, APPENDIX R. WITHIN THE AREAS INSPECTED, THREE VIOLATIONS WERE IDENTIFIED.

INSPECTION CONDUCTED APRIL 21-25, 1986 (86-16) ROUTINE, UNANNOUNCED INSPECTION OF THE VITAL AREA PHYSICAL BARRIERS AND DETECTION AIDS, PERSONNEL ACCESS CONTROL, ALARM STATION, SECURITY SYSTEM POWER SUPPLY, AND COMMUNICATIONS. WITHIN THE SIX AREAS INSPECTED, ONE VIOLATION WAS IDENTIFIED.

INSPECTION CONDUCTED JUNE 23-27, 1986 (86-20) ROUTINE, UNANNOUNCED INSPECTION OF THE CORRECTIVE ASTION SYSTEM. WITHIN THE AREA INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION CONDUCTED JUNE 1-30, 1986 (86-21) ROUTINE, UNANNOUNCED INSPECTION OF PREVIOUSLY IDENTIFIED INSPECTION FINDINGS, LICENSEE EVENT REPORTS, SPENT FUEL SHIPMENTS, OPERATIONAL SAFETY VERIFICATION, AND MONTHLY SURVEILLANCE AND MAINTENANCE ACTIVITIES. WITHIN THE AREAS INSPECTED, ONE VIOLATION WAS IDENTIFIED.

Report Period JUL 1986

I N S P E C T I O N S T A T U S - (CONTINUED)

* COOPER STATION *

ENFORCEMENT SUMMARY

10 CFR PART 50.55A REQUIRES THAT THE REACTOR COOLANT PRESSURE BOUNDARY BE CONSTRUCTED IN ACCORDANCE WITH ASME CODE III FOR CLASS I SYSTEMS. ASME CODE III FOR CLASS I SYSTEMS. ASME BOILER AND PRESSURE VESSEL CODE, SECTION III, NB 5320, REQUIRES THAT INDICATIONS OBSERVED IN INTERPRETING RADIOGRAPHIC FILM ARE RECORDED AND DISPOSITIONED. THE PROPER DISPOSITION OF LINEAR INDICATIONS, THAT EXCEED CODE, IS REPAIR OF THE AFFECTED AREA. CONTRARY TO THE ABOVE, AN NRC REVIEW OF SITE RADIOGRAPHS DURING MARCH 11-22, 1985, DISCLOSED THAT CODE INSPECTED AND ACCEPTED CLASS I WELD N2H CONTAINED UNACCEPTABLE LINEAR INDICATIONS THAT EXCEEDED CODE REQUIREMENTS AND WHICH HAD NOT BEEN RECORDED OR DISPOSITIONED.
(8501 4)

FAILURE TO POSITIVELY CONTROL ACCESS TO VITAL AREAS.

(8601 4)

CONTRARY TO CNS TECHNICAL SPECIFICATIONS, SECTION 6.1.4 AND CNS PROCEDURE 0.17, THREE INDIVIDUALS EXCEEDED THE TIME FRAME FOR SECURITY REFRESHER TRAINING AND TWO INDIVIDUALS EXCEEDED THE TIME FRAME FOR EMERGENCY PLAN REFRESHER TRAINING.
(8601 5)

CONTRARY TO 10 CFR PART 50, APPENDIX B, CRITERION V, THE LICENSEE DID NOT HAVE A PROCEDURE FOR ENSURING THAT TECHNICAL SPECIFICATION AMENDMENT REQUIREMENTS RESULTED IN REVISIONS TO AFFECTED STATION PROCEDURES.
(8602 4)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

NORMAL POWER OPERATION

LAST IE SITE INSPECTION DATE: JUNE 30, 1986

INSPECTION REPORT NO: 50-298/86-21

Report Period JUL 1986

R E P O R T S F R O M L I C E N S E E

* COOPER STATION *

```
=====
NUMBER   DATE OF   DATE OF   SUBJECT
        EVENT   REPORT
-----
86-012   6/10/86   7/02/86   LOSS OF EMERGENCY TRANSFORMER SUPPLY
86-013   6/17/86   7/17/86   BREACH OF PRIMARY CONTAINMENT INTERGRITY
=====
```

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-302 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/86 Outage + On-line Hrs: 744.0

3. Utility Contact: D. GRAHAM (904) 795-3802

4. Licensed Thermal Power (MWT): 2544

5. Nameplate Rating (Gross MWe): 989 X 0.9 = 890

6. Design Electrical Rating (Net MWe): 825

7. Maximum Dependable Capacity (Gross MWe): 860

8. Maximum Dependable Capacity (Net MWe): 821

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,087.0</u>	<u>82,271.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>1,033.9</u>	<u>51,335.7</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>1,275.5</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>1,013.2</u>	<u>50,104.1</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,807,807</u>	<u>2,424,534</u>	<u>112,893,399</u>
18. Gross Elec Ener (MWH)	<u>627,223</u>	<u>837,271</u>	<u>38,593,155</u>
19. Net Elec Ener (MWH)	<u>596,860</u>	<u>796,142</u>	<u>36,655,728</u>
20. Unit Service Factor	<u>100.0</u>	<u>19.9</u>	<u>60.9</u>
21. Unit Avail Factor	<u>100.0</u>	<u>19.9</u>	<u>60.9</u>
22. Unit Cap Factor (MDC Net)	<u>97.7</u>	<u>19.1</u>	<u>54.3</u>
23. Unit Cap Factor (DER Net)	<u>97.2</u>	<u>19.0</u>	<u>54.0</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>80.1</u>	<u>24.5</u>
25. Forced Outage Hours	<u>.0</u>	<u>4,073.8</u>	<u>16,234.6</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

* CRYSTAL RIVER 3 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
CRYSTAL RIVER 3



JULY 1986

Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

 * CRYSTAL RIVER 3 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
86-03	07/06/86	F	0.0	A	5		HC	HTEXCH	REDUCED POWER TO LOCATE AND REPAIR A CONDENSER SALT WATER LEAK IN THE "C" WATERBOX.
86-04	07/26/86	F	0.0	A	5		HH	MOTORX	LOST POWER TO THE 1A CONDENSATE PUMP MOTOR CONTROLLER. PLANT REDUCED POWER TO REPAIR.

 * SUMMARY *

 CRYSTAL RIVER 3 OPERATED WITH 2 REDUCTIONS FOR EQUIPMENT FAILURE IN JULY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

 * CRYSTAL RIVER 3 *

FACILITY DATA

Report Period JUL 1986

FACILITY DESCRIPTION

UTILITY & CONTRACTOR INFORMATION

LOCATION
 STATE.....FLORIDA
 COUNTY.....CITRUS
 DIST AND DIRECTION FROM
 NEAREST POPULATION CTR...7 MI NW OF
 CRYSTAL RIVER, FLA
 TYPE OF REACTOR.....PWR
 DATE INITIAL CRITICALITY...JANUARY 14, 1977
 DATE ELEC ENER 1ST GENER...JANUARY 30, 1977
 DATE COMMERCIAL OPERATE....MARCH 13, 1977
 CONDENSER COOLING METHOD...ONCE THRU
 CONDENSER COOLING WATER....GULF OF MEXICO
 ELECTRIC RELIABILITY
 COUNCIL.....SOUTHEASTERN ELECTRIC
 RELIABILITY COUNCIL

UTILITY
 LICENSEE.....FLORIDA POWER CORPORATION
 CORPORATE ADDRESS.....3201 34TH STREET, SOUTH
 ST PETERSBURG, FLORIDA 33733
 CONTRACTOR
 ARCHITECT/ENGINEER.....GILBERT ASSOCIATES
 NUC STEAM SYS SUPPLIER...BABCOCK & WILCOX
 CONSTRUCTOR.....J. A. JONES CONSTRUCTION
 TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
 IE RESIDENT INSPECTOR.....T. STETKA
 LICENSING PROJ MANAGER.....H. SILVER
 DOCKET NUMBER.....50-302
 LICENSE & DATE ISSUANCE....DPR-72, JANUARY 28, 1977
 PUBLIC DOCUMENT ROOM.....CRYSTAL RIVER PUBLIC LIBRARY
 668 N.W. FIRST
 CRYSTAL RIVER, FLORIDA 32639

INSPECTION SUMMARY

INSPECTION STATUS

+ INSPECTION APRIL 12 - JUNE 6 (86-14): THIS ROUTINE INSPECTION WAS CONDUCTED BY TWO RESIDENT INSPECTORS IN THE AREAS OF PLANT OPERATIONS, SECURITY, RADIOLOGICAL CONTROLS, LICENSEE EVENT REPORTS AND NONCONFORMING OPERATIONS REPORTS, FACILITY MODIFICATIONS, BIOFOULING OF COOLING WATER HEAT EXCHANGERS, AND LICENSEE ACTION ON PREVIOUS INSPECTION ITEMS. NUMEROUS FACILITY TOURS WERE CONDUCTED AND OPERATIONS OBSERVED. SOME OF THESE TOURS AND OBSERVATIONS WERE CONDUCTED ON BACKSHIFTS. TWO VIOLATIONS WERE IDENTIFIED: FAILURE TO TAKE ADEQUATE CORRECTIVE ACTION AND FAILURE TO HAVE AN ADEQUATE MAINTENANCE PROCEDURE.

INSPECTION MAY 19-23 (86-17): THIS ROUTINE, ANNOUNCED INSPECTION WAS CONDUCTED ON SITE IN THE AREAS OF LICENSEE ACTIONS ON PREVIOUS ENFORCEMENT MATTERS, TO ASSESS QUALITY ASSURANCE EFFECTIVENESS, AND LICENSEE ACTION ON PREVIOUSLY IDENTIFIED INSPECTION FINDINGS. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JUNE 17-20 (86-18): THIS ROUTINE, UNANNOUNCED INSPECTION INVOLVED EVALUATION OF THE ANNUAL RADIOLOGICAL EMERGENCY PREPAREDNESS EXERCISE. OF THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JUNE 2-6 (86-19): THIS ROUTINE, UNANNOUNCED PHYSICAL SECURITY INSPECTION WAS ACCOMPLISHED INSPECTING: ACCESS CONTROLS - PERSONNEL; TRAINING AND QUALIFICATION - GENERAL REQUIREMENTS; RECORDS AND REPORTS; SECURITY SYSTEM POWER SUPPLY; AND SAFEGUARDS INFORMATION. THE LICENSEE WAS FOUND TO BE IN COMPLIANCE WITH NRC REQUIREMENTS IN THE FIVE AREAS INSPECTED EXCEPT FOR A VIOLATION IDENTIFIED IN THE TRAINING AND QUALIFICATION AREA.

INSPECTION STATUS - (CONTINUED)

* CRYSTAL RIVER 3 *

CONTRARY TO TS 6.8.1.A AND MAINTENANCE PROCEDURE MP-405, INSTALLING, REPAIRING AND TERMINATING CONTROLS, POWER AND INSTRUMENTATION CABLES, ON JUNE 3, 1986, PROCEDURE MP-405 WAS FOUND TO BE INADEQUATE, IN THAT NUCLEAR INSTRUMENTATION CABLE THAT WAS REPLACED AND TESTED WITH THIS PROCEDURE HAS A NORMAL OPERATING VOLTAGE OF APPROXIMATELY 2000 VOLTS DC, THEREFORE MAKING A 1000 VOLT DC TEST INADEQUATE TO VERIFY PROPER INSULATION RESISTANCE. CONTRARY TO 10 CFR PART 50, APPENDIX B, CRITERION V AND COMPLIANCE PROCEDURE CP-125, CORRECTIVE ACTION PROCEDURE, THAT WAS WRITTEN TO ACCOMPLISH CRITERION XVI, AS OF JUNE 4, 1986, A DEFICIENCY IN A SAFETY-RELATED MOTOR OPERATED VALVE (DHV-39), WHICH WAS IDENTIFIED BY THE LICENSEE ON MAY 2, 1986, DID NOT HAVE A CAA COMPLETED AS REQUIRED BY PROCEDURE CP-125. AS A RESULT THE DEFICIENCY IN DHV-39 WAS NOT CORRECTED. FAILURE TO SATISFY REQUIREMENTS OF LICENSEE'S TRAINING AND QUALIFICATION.

(8601 4)

REPORTS FROM LICENSEE

1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80 81 82 83 84 85 86 87 88 89 90 91 92 93 94 95 96 97 98 99 100 101 102 103 104 105 106 107 108 109 110 111 112 113 114 115 116 117 118 119 120 121 122 123 124 125 126 127 128 129 130 131 132 133 134 135 136 137 138 139 140 141 142 143 144 145 146 147 148 149 150 151 152 153 154 155 156 157 158 159 160 161 162 163 164 165 166 167 168 169 170 171 172 173 174 175 176 177 178 179 180 181 182 183 184 185 186 187 188 189 190 191 192 193 194 195 196 197 198 199 200 201 202 203 204 205 206 207 208 209 210 211 212 213 214 215 216 217 218 219 220 221 222 223 224 225 226 227 228 229 230 231 232 233 234 235 236 237 238 239 240 241 242 243 244 245 246 247 248 249 250 251 252 253 254 255 256 257 258 259 260 261 262 263 264 265 266 267 268 269 270 271 272 273 274 275 276 277 278 279 280 281 282 283 284 285 286 287 288 289 290 291 292 293 294 295 296 297 298 299 300 301 302 303 304 305 306 307 308 309 310 311 312 313 314 315 316 317 318 319 320 321 322 323 324 325 326 327 328 329 330 331 332 333 334 335 336 337 338 339 340 341 342 343 344 345 346 347 348 349 350 351 352 353 354 355 356 357 358 359 360 361 362 363 364 365 366 367 368 369 370 371 372 373 374 375 376 377 378 379 380 381 382 383 384 385 386 387 388 389 390 391 392 393 394 395 396 397 398 399 400 401 402 403 404 405 406 407 408 409 410 411 412 413 414 415 416 417 418 419 420 421 422 423 424 425 426 427 428 429 430 431 432 433 434 435 436 437 438 439 440 441 442 443 444 445 446 447 448 449 450 451 452 453 454 455 456 457 458 459 460 461 462 463 464 465 466 467 468 469 470 471 472 473 474 475 476 477 478 479 480 481 482 483 484 485 486 487 488 489 490 491 492 493 494 495 496 497 498 499 500 501 502 503 504 505 506 507 508 509 510 511 512 513 514 515 516 517 518 519 520 521 522 523 524 525 526 527 528 529 530 531 532 533 534 535 536 537 538 539 540 541 542 543 544 545 546 547 548 549 550 551 552 553 554 555 556 557 558 559 560 561 562 563 564 565 566 567 568 569 570 571 572 573 574 575 576 577 578 579 580 581 582 583 584 585 586 587 588 589 590 591 592 593 594 595 596 597 598 599 600 601 602 603 604 605 606 607 608 609 610 611 612 613 614 615 616 617 618 619 620 621 622 623 624 625 626 627 628 629 630 631 632 633 634 635 636 637 638 639 640 641 642 643 644 645 646 647 648 649 650 651 652 653 654 655 656 657 658 659 660 661 662 663 664 665 666 667 668 669 670 671 672 673 674 675 676 677 678 679 680 681 682 683 684 685 686 687 688 689 690 691 692 693 694 695 696 697 698 699 700 701 702 703 704 705 706 707 708 709 710 711 712 713 714 715 716 717 718 719 720 721 722 723 724 725 726 727 728 729 730 731 732 733 734 735 736 737 738 739 740 741 742 743 744 745 746 747 748 749 750 751 752 753 754 755 756 757 758 759 760 761 762 763 764 765 766 767 768 769 770 771 772 773 774 775 776 777 778 779 780 781 782 783 784 785 786 787 788 789 790 791 792 793 794 795 796 797 798 799 800 801 802 803 804 805 806 807 808 809 810 811 812 813 814 815 816 817 818 819 820 821 822 823 824 825 826 827 828 829 830 831 832 833 834 835 836 837 838 839 840 841 842 843 844 845 846 847 848 849 850 851 852 853 854 855 856 857 858 859 860 861 862 863 864 865 866 867 868 869 870 871 872 873 874 875 876 877 878 879 880 881 882 883 884 885 886 887 888 889 890 891 892 893 894 895 896 897 898 899 900 901 902 903 904 905 906 907 908 909 910 911 912 913 914 915 916 917 918 919 920 921 922 923 924 925 926 927 928 929 930 931 932 933 934 935 936 937 938 939 940 941 942 943 944 945 946 947 948 949 950 951 952 953 954 955 956 957 958 959 960 961 962 963 964 965 966 967 968 969 970 971 972 973 974 975 976 977 978 979 980 981 982 983 984 985 986 987 988 989 990 991 992 993 994 995 996 997 998 999 1000 1001 1002 1003 1004 1005 1006 1007 1008 1009 1010 1011 1012 1013 1014 1015 1016 1017 1018 1019 1020 1021 1022 1023 1024 1025 1026 1027 1028 1029 1030 1031 1032 1033 1034 1035 1036 1037 1038 1039 104

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
86-003	02/02/86	05/15/86	LOSS OF DECAY HEAT REMOVAL CAPABILITY; DUE TO A MOTOR OVERLOAD CAUSED BY A PUMP SHAFT FAILURE.
86-008	06/20/86	07/17/86	LOW LEVEL ALARM RECEIVED ON THE 'B' OTSG AND WAS FOLLOWED BY AN AUTOMATIC ACTUATION OF EMERGENCY FEEDWATER SYSTEM; CAUSE - UNKNOWN.

.....

1. Docket: 50-346 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/86 Outage + On-line Hrs: 744.0

3. Utility Contact: MORTEZA KHARZRAI (419) 249-5000 X290

4. Licensed Thermal Power (Mwt): 2772

5. Nameplate Rating (Gross MWe): 1069 X 0.9 = 962

6. Design Electrical Rating (Net MWe): 906

7. Maximum Dependable Capacity (Gross MWe): 904

8. Maximum Dependable Capacity (Net MWe): 860

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,087.0</u>	<u>70,152.0</u>
13. Hours Reactor Critical	<u>.0</u>	<u>.0</u>	<u>35,878.0</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>4,058.8</u>
15. Hrs Generator On-Line	<u>.0</u>	<u>.0</u>	<u>34,371.8</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>1,732.7</u>
17. Gross Therm Ener (MWH)	<u>0</u>	<u>0</u>	<u>81,297,599</u>
18. Gross Elec Ener (MWH)	<u>0</u>	<u>0</u>	<u>26,933,622</u>
19. Net Elec Ener (MWH)	<u>0</u>	<u>0</u>	<u>25,233,177</u>
20. Unit Service Factor	<u>.0</u>	<u>.0</u>	<u>49.0</u>
21. Unit Avail Factor	<u>.0</u>	<u>.0</u>	<u>51.5</u>
22. Unit Cap Factor (MDC Net)	<u>.0</u>	<u>.0</u>	<u>41.8</u>
23. Unit Cap Factor (DER Net)	<u>.0</u>	<u>.0</u>	<u>39.7</u>
24. Unit Forced Outage Rate	<u>100.0</u>	<u>100.0</u>	<u>32.8</u>
25. Forced Outage Hours	<u>744.0</u>	<u>5,087.0</u>	<u>17,378.8</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


NONE

27. If Currently Shutdown Estimated Startup Date: 10/18/86

* DAVIS-BESSE 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

DAVIS-BESSE 1



JULY 1986

Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

 * DAVIS-BESSE 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
7	06/09/85	F	744.0	A	4	85-013	JK	SC	THE UNIT REMAINED SHUTDOWN FOLLOWING THE REACTOR TRIP ON JUNE 9, 1985, DUE TO MAIN FEED CONTROL PUMP PROBLEMS.

 * SUMMARY *

 DAVIS BESSE 1 REMAINS SHUTDOWN FOR EQUIPMENT REPAIRS.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	1-Manual
S-Sched	B-Maint or Test	G-Oper Error	2-Manual Scram
	C-Refueling	H-Other	3-Auto Scram
	D-Regulatory Restriction		4-Continued
	E-Operator Training		5-Reduced Load
	& License Examination		9-Other
			Exhibit F & H
			Instructions for
			Preparation of
			Data Entry Sheet
			Licensee Event Report
			(LER) File (NUREG-0161)

* DAVIS-BESSE 1 *

FACILITY DATA

Report Period JUL 1986

FACILITY DESCRIPTION

LOCATION
STATE.....OHIO
COUNTY.....OTTAWA
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...21 MI E OF
TOLEDO, OH
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...AUGUST 12, 1977
DATE ELEC ENER 1ST GENER...AUGUST 28, 1977
DATE COMMERCIAL OPERATE...JULY 31, 1978
CONDENSER COOLING METHOD...COOLING TOWER
CONDENSER COOLING WATER...LAKE ERIE
ELECTRIC RELIABILITY
COUNCIL.....EAST CENTRAL AREA
RELIABILITY COORDINATION
AGREEMENT

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....TOLEDO EDISON
CORPORATE ADDRESS.....300 MADISON AVENUE
TOLEDO, OHIO 43652
CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...BABCOCK & WILCOX
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III
IE RESIDENT INSPECTOR.....W. ROGERS
LICENSING PROJ MANAGER....A. DEGAZIO
DOCKET NUMBER.....50-346
LICENSE & DATE ISSUANCE...NPF-3, APRIL 22, 1977
PUBLIC DOCUMENT ROOM.....UNIVERSITY OF TOLEDO LIBRARY
GOVERNMENT DOCUMENTS COLLECTION
2801 WEST BANCROFT AVENUE
TOLEDO, OHIO 43606

INSPECTION STATUS

INSPECTION SUMMARY

INSPECTION ON MAY 1 THROUGH JUNE 15 (86014): ROUTINE, UNANNOUNCED INSPECTION BY RESIDENT INSPECTORS OF LICENSEE ACTION ON PREVIOUS INSPECTION FINDINGS, OPERATIONAL SAFETY, LICENSEE EVENT REPORTS, MAINTENANCE, SURVEILLANCE, EMERGENCY PLANNING, PERFORMANCE ENHANCEMENT PROGRAM, STRIKE ACTIVITIES AND MANAGEMENT MEETINGS. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION ON JUNE 27 (86018): ROUTINE, UNANNOUNCED INSPECTION OF THE RESOLUTION OF AN IE BULLETIN. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

Report Period JUL 1986

I N S P E C T I O N S T A T U S - (CONTINUED)

* DAVIS-BESSE 1 *

OTHER ITEMS

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

THE UNIT IS IN COLD SHUTDOWN FOLLOWING THE JUNE 9, 1985 TRIP.

LAST IE SITE INSPECTION DATE: 08/07/86

INSPECTION REPORT NO: 86024

R E P O R T S F R O M L I C E N S E E

=====			
NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT

84-15	10/25/86	07/02/86	VELAN CHECK VALVE ANTIROTATION BINDING
86-05	12/30/85	07/01/86	IMPROPER BOOT-SEAL INSTALLATION
86-06	01/02/86	08/01/86	ENVIRONMENTAL QUALIFICATION PROGRAM NOT ADEQUATELY ESTABLISHED
86-10	01/29/86	07/11/86	FIRE DAMPER INSTALLATION DEFICIENCIES VOIDING UL RATING
86-25	07/01/86	07/31/86	DISCREPANCIES BETWEEN TECHNICAL SPECIFICATIONS AND INSTALLED FIRE DETECTION
86-26	07/03/86	08/04/86	DESIGN AND TESTING DEFICIENCIES FOR THE ATMOSPHERIC VENT VALVES
86-27	06/25/86	07/31/86	FIRE DOORS INOPERABLE BY NFPA 80 STANDARDS
=====			

1. Docket: 50-275 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/86 Outage + On-line Hrs: 744.0

3. Utility Contact: A. T. KELLER (805) 595-7351

4. Licensed Thermal Power (MWt): 3338

5. Nameplate Rating (Gross MWe): 1137

6. Design Electrical Rating (Net MWe): 1086

7. Maximum Dependable Capacity (Gross MWe): 1125

8. Maximum Dependable Capacity (Net MWe): 1073

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any: NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,087.0</u>	<u>10,821.3</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>5,055.5</u>	<u>10,351.1</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>5,030.0</u>	<u>10,237.3</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,842,336</u>	<u>15,561,760</u>	<u>32,127,213</u>
18. Gross Elec Ener (MWH)	<u>597,800</u>	<u>5,185,300</u>	<u>10,699,632</u>
19. Net Elec Ener (MWH)	<u>560,977</u>	<u>4,928,258</u>	<u>10,162,492</u>
20. Unit Service Factor	<u>100.0</u>	<u>98.9</u>	<u>94.6</u>
21. Unit Avail Factor	<u>100.0</u>	<u>98.9</u>	<u>94.6</u>
22. Unit Cap Factor (MDC Net)	<u>70.3</u>	<u>90.3</u>	<u>87.5</u>
23. Unit Cap Factor (DER Net)	<u>69.4</u>	<u>89.2</u>	<u>86.5</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>1.1</u>	<u>2.9</u>
25. Forced Outage Hours	<u>.0</u>	<u>57.0</u>	<u>304.4</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
REFUELING OUTAGE: SEPTEMBER 1, 1986, 63 DAYS.

27. If Currently Shutdown Estimated Startup Date: N/A

* DIABLO CANYON 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
DIABLO CANYON 1



JULY 1986

Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

* DIABLO CANYON 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System Component	Cause & Corrective Action to Prevent Recurrence
-----	------	------	-------	--------	--------	------------	------------------	---

NONE

* SUMMARY *

DIABLO CANYON 1 OPERATED ROUTINELY DURING JULY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* DIABLO CANYON 1 *

FACILITY DATA

Report Period JUL 1986

FACILITY DESCRIPTION

LOCATION
STATE.....CALIFORNIA
COUNTY.....SAN LUIS OBISPO
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...12 MI WSW OF
SAN LUIS OBISPO
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...APRIL 29, 1984
DATE ELEC ENER 1ST GENER...NOVEMBER 11, 1984
DATE COMMERCIAL OPERATE...MAY 7, 1985
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...PACIFIC OCEAN
ELECTRIC RELIABILITY
COUNCIL.....WESTERN SYSTEMS
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....PACIFIC GAS & ELECTRIC
CORPORATE ADDRESS.....77 BEALE STREET
SAN FRANCISCO, CALIFORNIA 94106
CONTRACTOR
ARCHITECT/ENGINEER.....PACIFIC GAS & ELECTRIC
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....PACIFIC GAS & ELECTRIC
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....V
IE RESIDENT INSPECTOR.....M. MENDONCA
LICENSING PROJ MANAGER.....H. SCHIERLING
DOCKET NUMBER.....50-275
LICENSE & DATE ISSUANCE...DPR-80, NOVEMBER 2, 1984
PUBLIC DOCUMENT ROOM.....ROBERT F. KENNEDY LIBRARY
CALIFORNIA POLYTECHNIC STATE UNIVERSITY
SAN LUIS OBISPO, CA. 93407

INSPECTION STATUS

INSPECTION SUMMARY

+ INSPECTION ON JUNE 9-12, 1986 (REPORT NO. 50-275/86-10) AREAS INSPECTED: ANNOUNCED INSPECTION OF THE EMERGENCY PREPAREDNESS EXERCISE AND ASSOCIATED CRITIQUE. DURING THIS INSPECTION, ONE INSPECTION PROCEDURE WAS UTILIZED.

RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

+ INSPECTION ON APRIL 28 - MAY 2, 1986 (REPORT NO. 50-275/86-15) AREAS INSPECTED: ROUTINE, UNANNOUNCED INSPECTION BY HEADQUARTERS OF THE OPERATION, MAINTENANCE AND SURVEILLANCE TESTING OF THE AUXILIARY FEEDWATER (AFW) SYSTEM. DURING THIS INSPECTION, VARIOUS INSPECTION PROCEDURES WERE UTILIZED.

RESULTS: DURING THIS INSPECTION, ONE UNRESOLVED ITEM WAS IDENTIFIED CONCERNING THE DETERMINATION OF THE AFW SYSTEM OPERABILITY DURING PUMP MAINTENANCE.

+ INSPECTION ON MAY 25 - JULY 5, 1986 (REPORT NO. 50-275/86-18) AREAS INSPECTED: THE INSPECTION INCLUDED ROUTINE INSPECTIONS OF PLANT OPERATIONS, MAINTENANCE AND SURVEILLANCE ACTIVITIES, FOLLOWUP OF ONSITE EVENTS, OPEN ITEMS, AND LERS, AS WELL AS SELECTED INDEPENDENT INSPECTION ACTIVITIES. DURING THIS INSPECTION, VARIOUS INSPECTION PROCEDURES WERE UTILIZED.

RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

+ INSPECTION ON JULY 7 - AUGUST 1, 1986 (REPORT NO. 50-275/86-19) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

INSPECTION STATUS - (CONTINUED)

INSPECTION SUMMARY

- + INSPECTION ON JULY 6 - AUGUST 9, 1986 (REPORT NO. 50-275/86-20) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.
- + INSPECTION ON JULY 21-25, 1986 (REPORT NO. 50-275/86-21) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.
- + INSPECTION ON AUGUST 1, 1985 - JULY 31, 1986 (REPORT NO. 50-275/86-22) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

NONE

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

THE PLANT IS IN COMMERCIAL OPERATION.

LAST IE SITE INSPECTION DATE: 07/06-08/09/86

INSPECTION REPORT NO: 50-275/86-20

REPORTS FROM LICENSEE

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
--------	------------------	-------------------	---------

NONE

1. Docket: 50-323 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/86 Outage + On-line Hrs: 744.0

3. Utility Contact: A. T. KELLER (805) 595-7351

4. Licensed Thermal Power (MWt): 3411

5. Nameplate Rating (Gross MWe): 1164

6. Design Electrical Rating (Net MWe): 1119

7. Maximum Dependable Capacity (Gross MWe): 1124

8. Maximum Dependable Capacity (Net MWe): 1073

9. If Changes Occur Above Since Last Report, Give Reasons:

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>3,380.0</u>	<u>3,380.0</u>
13. Hours Reactor Critical	<u>693.5</u>	<u>3,220.5</u>	<u>3,220.5</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>637.5</u>	<u>3,117.5</u>	<u>3,117.5</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,782,564</u>	<u>9,519,687</u>	<u>9,519,687</u>
18. Gross Elec Ener (MWH)	<u>566,500</u>	<u>3,100,199</u>	<u>3,100,199</u>
19. Net Elec Ener (MWH)	<u>531,133</u>	<u>2,932,317</u>	<u>2,932,317</u>
20. Unit Service Factor	<u>85.7</u>	<u>92.2</u>	<u>92.2</u>
21. Unit Avail Factor	<u>85.7</u>	<u>92.2</u>	<u>92.2</u>
22. Unit Cap Factor (MDC Net)	<u>66.5</u>	<u>80.7</u>	<u>80.9</u>
23. Unit Cap Factor (DER Net)	<u>63.8</u>	<u>77.5</u>	<u>77.5</u>
24. Unit Forced Outage Rate	<u>10.8</u>	<u>7.0</u>	<u>7.0</u>
25. Forced Outage Hours	<u>77.2</u>	<u>233.2</u>	<u>233.2</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):

NONE

27. If Currently Shutdown Estimated Startup Date: N/A

 * DIABLO CANYON 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
 DIABLO CANYON 2



JULY 1986

Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

 * DIABLO CANYON 2 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
1	07/03/86	S	29.3	B	1				THE GENERATOR WAS SEPARATED FROM THE PG&E SYSTEM IN PREPARATION FOR OVERSPEED TRIP TESTING ON THE MAIN TURBINE.
2	07/05/86	F	18.4	H	3	2-86-020	SJ	FCV	WHILE MANUALLY ADJUSTING THE FLOW RATE TO SG 2-2, THE AUTOMATIC FLOW CONTROL VALVE FOR SG 2-1 ALLOWED EXCESSIVE FEED CAUSING A HIGH HIGH SG WATER LEVEL TURBINE TRIP AND SUBSEQUENT REACTOR TRIP. NO CORRECTIVE ACTION WAS DEEMED NECESSARY SINCE OPERATORS ARE ALREADY TRAINED FOR THIS SENSITIVE TRANSITION FROM MANUAL TO AUTOMATIC SG FEED CONTROL.
3	07/06/86	F	3.4	A	1		SE	PSF	THE GENERATOR WAS SEPARATED FROM THE PG&E SYSTEM TO REPAIR A STEAM LEAK ON AN EXTRACTION STEAM LINE FROM THE MAIN TURBINE.
4	07/09/86	F	55.4	A	3	86-021	SJ	P	MAIN FEEDWATER PUMP (MFP) 2-1 TRIPPED ON OVERSPEED RESULTING IN A REACTOR TRIP. NO APPARENT CAUSE OF THE PUMP TRIP COULD BE FOUND.

***** DIABLO CANYON 2 OPERATED WITH 4 OUTAGES DURING JULY.

* SUMMARY *

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* DIABLO CANYON 2 *

FACILITY DATA

Report Period JUL 1986

FACILITY DESCRIPTION

LOCATION
STATE.....CALIFORNIA

COUNTY.....SAN LUIS OBISPO

DIST AND DIRECTION FROM
NEAREST POPULATION CTR...12 MI WSW OF
SAN LUIS OBISPO

TYPE OF REACTOR.....PWR

DATE INITIAL CRITICALITY...AUGUST 19, 1985
DATE ELEC ENER 1ST GENER...OCTOBER 20, 1985
DATE COMMERCIAL OPERATE...MARCH 13, 1986

CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...PACIFIC OCEAN

ELECTRIC RELIABILITY
COUNCIL.....WESTERN SYSTEMS
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....PACIFIC GAS & ELECTRIC

CORPORATE ADDRESS.....77 BEALE STREET
SAN FRANCISCO, CALIFORNIA 94106

CONTRACTOR
ARCHITECT/ENGINEER.....PACIFIC GAS & ELECTRIC

NUC STEAM SYS SUPPLIER...WESTINGHOUSE

CONSTRUCTOR.....PACIFIC GAS & ELECTRIC

TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....V
IE RESIDENT INSPECTOR.....M. MENDOUCA

LICENSING PROJ MANAGER....H. SCHIERLING
DOCKET NUMBER.....50-323

LICENSE & DATE ISSUANCE...DPR-82, AUGUST 26, 1985

PUBLIC DOCUMENT ROOM.....ROBERT F. KENNEDY LIBRARY
CALIFORNIA POLYTECHNIC STATE UNIVERSITY
SAN LUIS OBISPO, CA. 93407

INSPECTION STATUS

INSPECTION SUMMARY

+ INSPECTION ON JUNE 9-12, 1986 (REPORT NO. 50-323/86-11) AREAS INSPECTED: ANNOUNCED INSPECTION OF THE EMERGENCY PREPAREDNESS EXERCISE AND ASSOCIATED CRITIQUE. DURING THIS INSPECTION, ONE INSPECTION PROCEDURE WAS UTILIZED.

RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

+ INSPECTION ON MAY 25 - JULY 5, 1986 (REPORT NO. 50-323/86-18) AREAS INSPECTED: THE INSPECTION INCLUDED ROUTINE INSPECTIONS OF PLANT OPERATIONS, MAINTENANCE AND SURVEILLANCE ACTIVITIES, FOLLOWUP OF ONSITE EVENTS, OPEN ITEMS, AND LERS, AS WELL AS SELECTED INDEPENDENT INSPECTION ACTIVITIES. ADDITIONALLY, S/U TESTING PHASE OF THE LIGHT WATER REACTOR INSPECTION PROGRAM WAS CONCLUDED DURING THIS PERIOD. DURING THIS INSPECTION, VARIOUS INSPECTION PROCEDURES WERE UTILIZED.

RESULTS: ONE VIOLATION AND NO DEVIATIONS WERE IDENTIFIED.

+ INSPECTION ON JULY 7 - AUGUST 1, 1986 (REPORT NO. 50-323/86-19) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

+ INSPECTION ON JULY 6 - AUGUST 9, 1986 (REPORT NO. 50-323/86-20) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

+ INSPECTION ON JULY 21-25, 1986 (REPORT NO. 50-323/86-21) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

+ INSPECTION ON AUGUST 1, 1985 - JULY 31, 1986 (REPORT NO. 50-323/86-22) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

INSPECTION STATUS - (CONTINUED)

INSPECTION SUMMARY

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

THE PLANT IS IN COMMERCIAL OPERATION.

LAST IE SITE INSPECTION DATE: 07/06-08/09/86

INSPECTION REPORT NO: 50-323/86-20

REPORTS FROM LICENSEE

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
--------	------------------	-------------------	---------

86-14-L0	05-06-86	06-05-86	DIESEL GENERATOR START AND LOADING DUE TO INCORRECTLY TERMINATED JUMPER
86-15-L0	02-14-86	05-30-86	MISSSED SURVEILLANCE OF RADIATION MONITOR

1. Docket: 50-237 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/86 Outage + On-line Hrs: 744.0

3. Utility Contact: D. C. MAXWELL (815) 942-2920

4. Licensed Thermal Power (MWt): 2527

5. Nameplate Rating (Gross MWe): 920 X 0.9 = 828

6. Design Electrical Rating (Net MWe): 794

7. Maximum Dependable Capacity (Gross MWe): 812

8. Maximum Dependable Capacity (Net MWe): 772

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE


10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,087.0</u>	<u>142,151.0</u>
13. Hours Reactor Critical	<u>701.5</u>	<u>4,280.1</u>	<u>107,978.6</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>683.0</u>	<u>3,981.4</u>	<u>102,966.4</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,583,834</u>	<u>9,295,771</u>	<u>210,972,370</u>
18. Gross Elec Ener (MWH)	<u>504,650</u>	<u>3,013,678</u>	<u>67,496,854</u>
19. Net Elec Ener (MWH)	<u>480,972</u>	<u>2,869,382</u>	<u>63,814,674</u>
20. Unit Service Factor	<u>91.8</u>	<u>78.3</u>	<u>72.4</u>
21. Unit Avail Factor	<u>91.8</u>	<u>78.3</u>	<u>72.4</u>
22. Unit Cap Factor (MDC Net)	<u>83.7</u>	<u>73.1</u>	<u>58.2</u>
23. Unit Cap Factor (DER Net)	<u>81.4</u>	<u>71.0</u>	<u>56.5</u>
24. Unit Forced Outage Rate	<u>8.2</u>	<u>21.7</u>	<u>12.0</u>
25. Forced Outage Hours	<u>61.0</u>	<u>1,105.6</u>	<u>6,552.5</u>
26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration): <u>REFUELING OUTAGE: DECEMBER, 1986-FEBRUARY, 1987.</u>			
27. If Currently Shutdown Estimated Startup Date: <u>N/A</u>			

* D R E S D E N 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
DRESDEN 2



JULY 1986

Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

 * DRESDEN 2 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
6	07/12/86	F	61.0	A	3	86-017-0			RX SCRAM, 1C MSIV FULL CLOSED DURING SURVEILLANCE TESTING, CAUSING A PRESSURE AND HIGH FLUX SPIKE.

 * SUMMARY *

 DRESDEN 2 OPERATED WITH 1 OUTAGE DUE TO EQUIPMENT FAILURE IN JULY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* DRESDEN 2 *

FACILITY DATA

Report Period JUL 1986

FACILITY DESCRIPTION

LOCATION
STATE.....ILLINOIS

COUNTY.....GRUNDY

DIST AND DIRECTION FROM
NEAREST POPULATION CTR...9 MI E OF
MORRIS, ILL

TYPE OF REACTOR.....BWR

DATE INITIAL CRITICALITY...JANUARY 7, 1970

DATE ELEC ENER 1ST GENER...APRIL 13, 1970

DATE COMMERCIAL OPERATE....JUNE 9, 1970

CONDENSER COOLING METHOD...COOLING LAKE

CONDENSER COOLING WATER...KANKAKEE RIVER

ELECTRIC RELIABILITY
COUNCIL.....MID-AMERICA
INTERPOOL NETWORK

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....COMMONWEALTH EDISON

CORPORATE ADDRESS.....P.O. BOX 767
CHICAGO, ILLINOIS 60690

CONTRACTOR
ARCHITECT/ENGINEER.....SARGENT & LUNDY

NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC

CONSTRUCTOR.....UNITED ENG. & CONSTRUCTORS

TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III

IE RESIDENT INSPECTOR.....L. MCGREGOR

LICENSING PROJ MANAGER.....J. STANG
DOCKET NUMBER.....50-237

LICENSE & DATE ISSUANCE....DPR-19, DECEMBER 22, 1969

PUBLIC DOCUMENT ROOM.....MORRIS PUBLIC LIBRARY
604 LIBERTY STREET
MORRIS, ILLINOIS 60450

INSPECTION STATUS

INSPECTION SUMMARY

INSPECTION DURING THE PERIOD OF APRIL 26 THROUGH JUNE 13 (86011; 86014): ROUTINE UNANNOUNCED RESIDENT INSPECTION OF OPERATIONAL SAFETY, FOLLOWUP OF EVENTS, REGIONAL REQUESTS, MAINTENANCE, SURVEILLANCE, LICENSEE EVENT REPORTS AND TMI MODIFICATIONS. OF THE SEVEN AREAS INSPECTED, NO VIOLATIONS OF NRC REQUIREMENTS WERE IDENTIFIED.

INSPECTION ON MAY 19 THROUGH 23 (86015; 86017): SPECIAL TEAM INSPECTION TO FOLLOWUP ON MODIFICATION PACKAGE PROBLEMS IDENTIFIED BY THE SAFETY SYSTEMS OUTAGE MODIFICATION INSPECTION TEAM FROM THE OFFICE OF INSPECTION AND ENFORCEMENT ON UNIT 3 TO DETERMINE IF SIMILAR PROBLEMS WERE PRESENT ON UNIT 2 AND, IF PROBLEMS WERE PRESENT, TO DETERMINE IF THEY JEOPARDIZED THE RETURN TO OPERATION OF UNIT 2. THE INSPECTION TEAM DETERMINED THAT IN THE THIRTEEN UNIT 2 MODIFICATION PACKAGES INSPECTED ABOUT HALF CONTAINED SIMILAR PROBLEMS AS HAD BEEN IDENTIFIED FOR UNIT 3. THE PROBLEMS IDENTIFIED WERE EVALUATED BY THE TEAM TO NOT JEOPARDIZE THE RETURN TO OPERATION OF UNIT 2. ONE VIOLATION WAS IDENTIFIED IN THE AREA OF AS-BUILT DRAWINGS VERSUS AS-FOUND ELECTRICAL CONFIGURATION (FAILURE TO ENSURE DRAWINGS ARE KEPT UPDATED AND INSTALLATION IS PERFORMED IN ACCORDANCE WITH DRAWINGS.

INSPECTION ON JUNE 30 THROUGH JULY 3 (86019; 86023): ROUTINE UNANNOUNCED INSPECTION OF THE RESOLUTION OF IE BULLETIN 79-02, "PIPE SUPPORT BASEPLATE DESIGN USING CONCRETE EXPANSION ANCHORS." NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

INSPECTION STATUS - (CONTINUED)

```

*****
*          DRESDEN 2          *
*****

```

SYSTEMS AND COMPONENT PROBLEMS:

FACILITY ITEMS (PLANS AND PROCEDURES):

THE LICENSEE'S MODIFICATION PROCESS AND ASSOCIATED DRAWING CONTROL PROCESS WERE NOTED TO HAVE SEVERAL PROBLEMS SUCH THAT "AS-BUILT" DRAWINGS DID NOT EFFECTIVELY EXIST.

E. O'CONNOR WILL REPLACE S. MCDONALD AS THE RAD CHEM SUPERVISOR THIS SUMMER.

UNIT IS OPERATING NORMALLY.

LAST IE SITE INSPECTION DATE: 08/18/86

INSPECTION REPORT NO: 86022

REPORTS FROM LICENSEE

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
86-14	06/16/86	07/15/86	DFPP 4185-2 SMOKE DETECTOR SEMI-ANNUAL MAINTENANCE TEST EXCEEDED SCHEDULED COMPLETION DATE DUE TO PERSONNEL ERROR

1. Docket: 50-249 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/86 Outage + On-line Hrs: 744.0

3. Utility Contact: D. C. MAXWELL (815) 942-2920

4. Licensed Thermal Power (MWt): 2527

5. Nameplate Rating (Gross MWe): 920 X 0.9 = 828

6. Design Electrical Rating (Net MWe): 794

7. Maximum Dependable Capacity (Gross MWe): 812

8. Maximum Dependable Capacity (Net MWe): 773

9. If Changes Occur Above Since Last Report, Give Reasons: NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,087.0</u>	<u>131,736.0</u>
13. Hours Reactor Critical	<u>.0</u>	<u>.0</u>	<u>93,442.9</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>.0</u>	<u>.0</u>	<u>89,794.8</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>0</u>	<u>0</u>	<u>181,765,542</u>
18. Gross Elec Ener (MWH)	<u>0</u>	<u>0</u>	<u>58,821,103</u>
19. Net Elec Ener (MWH)	<u>-5,590</u>	<u>-36,276</u>	<u>55,690,017</u>
20. Unit Service Factor	<u>.0</u>	<u>.0</u>	<u>68.2</u>
21. Unit Avail Factor	<u>.0</u>	<u>.0</u>	<u>68.2</u>
22. Unit Cap Factor (MDC Net)	<u>.0</u>	<u>.0</u>	<u>54.7</u>
23. Unit Cap Factor (DER Net)	<u>.0</u>	<u>.0</u>	<u>53.2</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.0</u>	<u>12.2</u>
25. Forced Outage Hours	<u>.0</u>	<u>.0</u>	<u>7,365.0</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration): NONE

27. If Currently Shutdown Estimated Startup Date: 08/08/86

 * DRESDEN 3 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
 DRESDEN 3



JULY 1986

Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

* DRESDEN 3 *

No.	Date	Type	Hours	Reason	Method	LER Number	System Component	Cause & Corrective Action to Prevent Recurrence
6	10/23/85	S	744.0	C	4			OFF-LINE MANUALLY TO 9TH REFUELING/RECIRCULATION PIPE REPLACEMENT OUTAGE.

* SUMMARY *

DRESDEN 3 REMAINS SHUTDOWN FOR REFUELING.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* DRESDEN 3 *

FACILITY DATA

Report Period JUL 1986

FACILITY DESCRIPTION

LOCATION
STATE.....ILLINOIS
COUNTY.....GRUNDY
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...9 MI E OF
MORRIS, ILL
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...JANUARY 31, 1971
DATE ELEC ENER 1ST GENER...JULY 22, 1971
DATE COMMERCIAL OPERATE...NOVEMBER 16, 1971
CONDENSER COOLING METHOD...COOLING LAKE
CONDENSER COOLING WATER...KANKAKEE RIVER
ELECTRIC RELIABILITY
COUNCIL.....MID-AMERICA
INTERPOOL NETWORK

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....COMMONWEALTH EDISON
CORPORATE ADDRESS.....P.O. BOX 767
CHICAGO, ILLINOIS 60690
CONTRACTOR
ARCHITECT/ENGINEER.....SARGENT & LUNDY
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....UNITED ENG. & CONSTRUCTORS
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III
IE RESIDENT INSPECTOR.....L. MCGREGOR
LICENSING PROJ MANAGER.....J. STANG
DOCKET NUMBER.....50-249
LICENSE & DATE ISSUANCE...DPR-25, MARCH 2, 1971
PUBLIC DOCUMENT ROOM.....MORRIS PUBLIC LIBRARY
604 LIBERTY STREET
MORRIS, ILLINOIS 60450

INSPECTION STATUS

INSPECTION SUMMARY

INSPECTION DURING THE PERIOD OF APRIL 26 THROUGH JUNE 13 (86011; 86014): ROUTINE UNANNOUNCED RESIDENT INSPECTION OF OPERATIONAL SAFETY, FOLLOWUP OF EVENTS, REGIONAL REQUESTS, MAINTENANCE, SURVEILLANCE, LICENSEE EVENT REPORTS AND TMI MODIFICATIONS. OF THE SEVEN AREAS INSPECTED, NO VIOLATIONS OF NRC REQUIREMENTS WERE IDENTIFIED.

INSPECTION ON MAY 19 THROUGH 23 (86015; 86017): SPECIAL TEAM INSPECTION TO FOLLOWUP ON MODIFICATION PACKAGE PROBLEMS IDENTIFIED BY THE SAFETY SYSTEMS OUTAGE MODIFICATION INSPECTION TEAM FROM THE OFFICE OF INSPECTION AND ENFORCEMENT ON UNIT 3 TO DETERMINE IF SIMILAR PROBLEMS WERE PRESENT ON UNIT 2 AND, IF PROBLEMS WERE PRESENT, TO DETERMINE IF THEY JEOPARDIZED THE RETURN TO OPERATION OF UNIT 2. THE INSPECTION TEAM DETERMINED THAT IN THE THIRTEEN UNIT 2 MODIFICATION PACKAGES INSPECTED ABOUT HALF CONTAINED SIMILAR PROBLEMS AS HAD BEEN FOR UNIT 3. THE PROBLEMS IDENTIFIED WERE EVALUATED BY THE TEAM TO NOT JEOPARDIZE THE RETURN TO OPERATION OF UNIT 2. ONE VIOLATION WAS IDENTIFIED IN THE AREA OF AS-BUILT RSUS AS-FOUND ELECTRICAL CONFIGURATION (FAILURE TO ENSURE DRAWINGS ARE KEPT INSTALLATION IS PERFORMED IN ACCORDANCE WITH DRAWINGS).

INSPECTION ON JUNE 2-4 (86018): UNANNOUNCED, SPECIAL INSPECTION OF ALLEGATIONS. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION ON JUNE 30 THROUGH JULY 3 (86019; 86023): ROUTINE UNANNOUNCED INSPECTION OF THE RESOLUTION OF IE BULLETIN 79-02, "PIPE SUPPORT BASEPLATE DESIGN USING CONCRETE EXPANSION ANCHORS." NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

Report Period JUL 1986

INSPECTION STATUS - (CONTINUED)

* DRESDEN 3 *

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

DRESDEN 3 RECIRCULATING SYSTEM PIPING REPLACEMENT PROJECT IN PROGRESS

FACILITY ITEMS (PLANS AND PROCEDURES):

THE LICENSEE'S MODIFICATION PROCESS AND ASSOCIATED DRAWING CONTROL PROCESS WERE NOTED TO HAVE SEVERAL PROBLEMS SUCH THAT "AS-BUILT" DRAWINGS DID NOT EFFECTIVELY EXIST.

MANAGERIAL ITEMS:

E. O'CONNOR WILL REPLACE S. MCDONALD AS THE RAD CHEM SUPERVISOR THIS COMING SUMMER

PLANT STATUS:

PLANT IS NOW TOTALLY REFUELED AND IS PERFORMING THE REQUIRED TESTING PRIOR TO RESTART. RESTART IS SCHEDULED FOR 08/20/86.

LAST IE SITE INSPECTION DATE: 08/18/86

INSPECTION REPORT NO: 86027

REPORTS FROM LICENSEE

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
86-07	06/12/86	07/11/86	AUTOMATIC INITIATION OF STANDBY GAS TREATMENT AND ISOLATION OF REACTOR BUILDING VENTILATION SYSTEM DUE TO PERSONNEL ERROR
86-08	06/18/86	07/17/86	DRYWELL RADIATION MONITOR FAILURE CAUSED BY PERSONNEL ERROR RESULTING IN A GROUP II PRIMARY CONTAINMENT ISOLATION
86-09	07/08/86	08/06/86	AUTOMATIC START OF THE UNIT 2/3 DIESEL GENERATOR DUE TO PERSONNEL ERROR

=====

1. Docket: 50-331 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/86 Outage + On-line Hrs: 744.0

3. Utility Contact: BRADFORD THOMAS (319) 851-7339

4. Licensed Thermal Power (MWt): 1658

5. Nameplate Rating (Gross MWe): 663 X 0.9 = 597

6. Design Electrical Rating (Net MWe): 538

7. Maximum Dependable Capacity (Gross MWe): 545

8. Maximum Dependable Capacity (Net MWe): 515

9. If Changes Occur Above Since Last Report, Give Reasons: NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____


NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,087.0</u>	<u>100,775.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>4,413.5</u>	<u>71,708.8</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>42.5</u>	<u>172.8</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>4,316.2</u>	<u>69,875.7</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,127,340</u>	<u>5,574,487</u>	<u>88,180,690</u>
18. Gross Elec Ener (MWH)	<u>376,524</u>	<u>1,880,606</u>	<u>29,536,667</u>
19. Net Elec Ener (MWH)	<u>354,717</u>	<u>1,766,770</u>	<u>27,661,188</u>
20. Unit Service Factor	<u>100.0</u>	<u>84.8</u>	<u>69.3</u>
21. Unit Avail Factor	<u>100.0</u>	<u>84.8</u>	<u>69.3</u>
22. Unit Cap Factor (MDC Net)	<u>92.6</u>	<u>67.4</u>	<u>53.3</u>
23. Unit Cap Factor (DER Net)	<u>88.6</u>	<u>64.6</u>	<u>51.0</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>2.7</u>	<u>15.2</u>
25. Forced Outage Hours	<u>.0</u>	<u>121.1</u>	<u>12,505.9</u>
26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):	<u>NONE</u>		

27. If Currently Shutdown Estimated Startup Date: N/A

 * DUANE ARNOLD *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
 DUANE ARNOLD



JULY 1986

Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

 * DUANE ARNOLD *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
7	07/10/86	S	0.0	F	5		ZZ	ZZZZZZ	POWER REDUCED APPROXIMATELY 21% FOR 12 HOURS AT THE REQUEST OF THE LOAD DISPATCHER (LOAD FOLLOWING).
8	07/26/86	S	0.0	F	5		ZZ	ZZZZZZ	POWER REDUCED APPROXIMATELY 21% FOR 24 HOURS AT THE REQUEST OF THE LOAD DISPATCHER (LOAD FOLLOWING).

 < SUMMARY >

DUANE ARNOLD OPERATED WITH 2 REDUCTIONS DURING JULY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* DUANE ARNOLD *

FACILITY DATA

Report Period JUL 1986

FACILITY DESCRIPTION

LOCATION
STATE.....IOWA
COUNTY.....LINN
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...8 MI NW OF
CEDAR RAPIDS, IA
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...MARCH 23, 1974
DATE ELEC ENER 1ST GENER...MAY 19, 1974
DATE COMMERCIAL OPERATE...FEBRUARY 1, 1975
CONDENSER COOLING METHOD...COOLING TOWER
CONDENSER COOLING WATER...CEDAR RAPIDS RIVER
ELECTRIC RELIABILITY
COUNCIL.....MID-CONTINENT AREA
RELIABILITY COORDINATION
AGREEMENT

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....IOWA ELECTRIC LIGHT & POWER
CORPORATE ADDRESS.....I E TOWERS, P.O. BOX 351
CEDAR RAPIDS, IOWA 52406
CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III
IE RESIDENT INSPECTOR.....J. WEIBE
LICENSING PROJ MANAGER.....R. GILBERT
DOCKET NUMBER.....50-331
LICENSE & DATE ISSUANCE...DPR-49, FEBRUARY 22, 1974
PUBLIC DOCUMENT ROOM.....CEDAR RAPIDS PUBLIC LIBRARY
500 FIRST STREET, S.E.
CEDAR RAPIDS, IOWA 52401

INSPECTION STATUS

INSPECTION SUMMARY

INSPECTION ON MAY 20 THROUGH JULY 14 (86009): ROUTINE, UNANNOUNCED INSPECTION BY THE RESIDENT INSPECTORS OF LICENSEE ACTION ON PREVIOUS INSPECTION FINDINGS, OPERATIONAL SAFETY, MAINTENANCE, SURVEILLANCE, LICENSEE EVENT REPORTS, OUTAGE ACTIVITIES, PLANT TRIPS, LOW-LEVEL RADIOACTIVE WASTE STORAGE FACILITY, RESOLUTION OF REGULATORY EFFECTIVENESS REVIEW TEAM COMMENTS, GENERIC LETTERS, TMI ACTION ITEMS, AND LICENSEE RESPONSE TO SELECTED SAFETY ISSUES. OF THE 12 AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION ON MAY 27-30 (86011): INCLUDED A REVIEW OF ALLEGATIONS RECEIVED BY NRC REGION III OF PERCEIVED SECURITY DEFICIENCIES IN THE LICENSEE'S SECURITY PROGRAM. THE INSPECTION BEGAN DURING THE DAY SHIFT AND SOME OFFSHIFT INSPECTION ACTIVITIES WERE PERFORMED. THE LICENSEE WAS FOUND TO BE IN COMPLIANCE WITH NRC REQUIREMENTS WITHIN THE AREAS EXAMINED DURING THIS INSPECTION.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

Report Period JUL 1986

I N S P E C T I O N S T A T U S - (CONTINUED)

* DUANE ARNOLD *

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

OPERATING ROUTINELY

LAST IE SITE INSPECTION DATE: 08/05/86

INSPECTION REPORT NO: 86013

R E P O R T S F R O M L I C E N S E E

```
=====
NUMBER   DATE OF   DATE OF   SUBJECT
EVENT    REPORT
-----
86-17    06/13/86   07/11/86   MANUAL SCRAM IN RESPONSE TO FEEDWATER LEVEL CONTROL PROBLEMS DURING REACTOR STARTUP
=====
```

1. Docket: 50-348 OPERATING STATUS

2. Reporting Period: 07/01/86 Outage + On-line Hrs: 744.0

3. Utility Contact: J. D. WOODARD (205) 899-5156

4. Licensed Thermal Power (Mwt): 2652

5. Nameplate Rating (Gross MWe): 1045 X 0.85 = 888

6. Design Electrical Rating (Net MWe): 829

7. Maximum Dependable Capacity (Gross MWe): 873

8. Maximum Dependable Capacity (Net MWe): 827

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,087.0</u>	<u>75,959.0</u>
13. Hours Reactor Critical	<u>720.6</u>	<u>5,015.2</u>	<u>54,648.3</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>3,650.7</u>
15. Hrs Generator On-Line	<u>711.6</u>	<u>4,995.3</u>	<u>53,400.9</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,846,629</u>	<u>12,892,512</u>	<u>135,764,052</u>
18. Gross Elec Ener (MWH)	<u>597,758</u>	<u>4,248,844</u>	<u>43,451,028</u>
19. Net Elec Ener (MWH)	<u>565,850</u>	<u>4,030,184</u>	<u>41,027,902</u>
20. Unit Service Factor	<u>95.6</u>	<u>98.2</u>	<u>70.3</u>
21. Unit Avail Factor	<u>95.6</u>	<u>98.2</u>	<u>70.3</u>
22. Unit Cap Factor (MDC Net)	<u>92.0</u>	<u>95.8</u>	<u>67.4*</u>
23. Unit Cap Factor (DER Net)	<u>91.7</u>	<u>95.6</u>	<u>65.2</u>
24. Unit Forced Outage Rate	<u>4.4</u>	<u>1.8</u>	<u>10.8</u>
25. Forced Outage Hours	<u>32.4</u>	<u>91.7</u>	<u>6,474.6</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):

REFUELING/MAINTENANCE OUTAGE: 10/4/86, 44 DAYS.

27. If Currently Shutdown Estimated Startup Date: N/A

* FARLEY 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
FARLEY 1



JULY 1986

* Item calculated with a Weighted Average

Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

 * FARLEY 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
004	07/02/86	F	32.4	A	3	86-008-00	AA	PEN	A REACTOR TRIP OCCURRED AS A RESULT OF A DROPPED CONTROL ROD. A SHORT OCCURRED IN THE CONTAINMENT ELECTRICAL PENETRATION MODULE BETWEEN THE TWO CONDUCTORS SUPPLYING POWER TO THE STATIONARY GRIPPER COIL OF THE ROD. THE ASSOCIATED FUSES FOR THE CONDUCTORS WERE ALSO BLOWN. THE AFFECTED CIRCUITS WERE REROUTED THROUGH SPARE TERMINALS IN THE PENETRATION. THE BLOWN FUSES WERE REPLACED AND ALL OTHER CONTROL RODS DRIVE SYSTEM CABLES WERE CHECKED FOR GROUNDS OR SHORTS. NO OTHER SHORTED OR GROUNDED CONDUCTORS WERE FOUND.

 * SUMMARY *

 FARLEY 1 OPERATED WITH 1 OUTAGE FOR EQUIPMENT REPAIRS DURING JULY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* FARLEY 1 *

FACILITY DATA

Report Period JUL 1986

FACILITY DESCRIPTION

LOCATION
STATE.....ALABAMA
COUNTY.....HOUSTON
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...18 MI SE OF
DOTHAN, ALA
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...AUGUST 9, 1977
DATE ELEC ENER 1ST GENER...AUGUST 18, 1977
DATE COMMERCIAL OPERATE...DECEMBER 1, 1977
CONDENSER COOLING METHOD...COOLING TOWER
CONDENSER COOLING WATER...CHATAHOOCHEE RIVER
ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....ALABAMA POWER CO.
CORPORATE ADDRESS.....600 NORTH 18TH STREET
BIRMINGHAM, ALABAMA 35203
CONTRACTOR
ARCHITECT/ENGINEER.....SOUTHERN SERVICES INCORPORATED
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....DANIEL INTERNATIONAL
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
IE RESIDENT INSPECTOR.....W. BRADFORD
LICENSING PROJ MANAGER.....E. REEVES
DOCKET NUMBER.....50-348
LICENSE & DATE ISSUANCE...NPF-2, JUNE 25, 1977
PUBLIC DOCUMENT ROOM.....HOUSTON/LOVE MEMORIAL LIBRARY
212 W. BURDESHAW STREET
DOTHAN, ALABAMA 36301

INSPECTION STATUS

INSPECTION SUMMARY

+ INSPECTION APRIL 11 - MAY 10 AND JUNE 3 (86-10): THIS ROUTINE AND REACTIVE INSPECTION AND ENFORCEMENT CONFERENCE INCLUDED ONSITE INSPECTION IN THE AREAS OF MONTHLY SURVEILLANCE OBSERVATION, MONTHLY MAINTENANCE OBSERVATION, OPERATIONAL SAFETY VERIFICATION, INOPERABLE ECCS SUBSYSTEM, INOPERABLE FIRE DOOR, ENGINEERED SAFETY SYSTEM INSPECTION, PART 21 REPORTS, AND REFUELING ACTIVITIES. TWO VIOLATIONS WERE IDENTIFIED: (1) VIOLATION OF TECHNICAL SPECIFICATION 3.5.2.D - EXCEEDING LIMITING CONDITION FOR OPERATION AND (2) VIOLATION OF TECHNICAL SPECIFICATION 3.7.12 - INOPERABLE FIRE BARRIER.

INSPECTION MAY 14 - JUNE 10 (86-11): THIS ROUTINE INSPECTION WAS CONDUCTED IN THE AREAS OF MONTHLY SURVEILLANCE OBSERVATION, MONTHLY MAINTENANCE OBSERVATION, OPERATIONAL SAFETY VERIFICATION, LICENSEE EVENT REPORTS, ONSITE FOLLOWUP OF EVENTS, FOLLOWUP SURVEY OF LICENSEE RESPONSE TO SELECTED SAFETY ISSUES AND PLANT STARTUP FROM REFUELING OUTAGE. TWO VIOLATIONS WERE IDENTIFIED: VIOLATION OF TECHNICAL SPECIFICATION 3.7.12 - INOPERABLE FIRE DAMPER; VIOLATION OF TECHNICAL SPECIFICATION 6.8.1 - FAILURE TO FOLLOW PROCEDURES.

INSPECTION JUNE 16-20 (86-12): THIS ROUTINE, UNANNOUNCED INSPECTION INSPECTED: SECURITY SYSTEM POWER SUPPLY; LIGHTING, ACCESS CONTROLS-PERSONNEL; ACCESS CONTROLS-PACKAGES, VEHICLES AND PERSONNEL TRAINING AND QUALIFICATIONS. THERE WERE NO VIOLATIONS OR DEVIATIONS IDENTIFIED.

INSPECTION JUNE 11 - JULY 10 (86-13): THIS ROUTINE INSPECTION IN THE AREAS OF MONTHLY SURVEILLANCE OBSERVATION, MONTHLY MAINTENANCE OBSERVATION, OPERATIONAL SAFETY VERIFICATION, ENGINEERED SAFETY FEATURE WALKDOWN, AND ONSITE FOLLOWUP OF EVENTS. ONE VIOLATION WAS IDENTIFIED: FAILURE TO UPDATE PROCEDURES AND DRAWINGS.

Report Period JUL 1986

INSPECTION STATUS - (CONTINUED)

* FARLEY 1 *

INSPECTION SUMMARY

ENFORCEMENT SUMMARY

CONTRARY TO TS 3.5.2D AND TS 6.8.1, FROM 10:00 A.M. ON APRIL 25, 1986 TO 9:45 A.M. ON APRIL 29, 1986, A PERIOD OF APPROXIMATELY 96 HOURS, WITH THE PLANT IN MODE 1, UNIT 1 ECCS SUBSYSTEM "B" TRAIN RHR PUMP SUCTION WAS NOT CAPABLE OF BEING TRANSFERRED TO THE CONTAINMENT SUMP. THE INOPERABLE SUBSYSTEM WAS NOT RESTORED TO OPERABLE STATUS WITHIN 72 HOURS, AND THE UNIT WAS NOT PLACED IN HOT STANDBY WITHIN THE NEXT 6 HOURS OR HOT SHUTDOWN WITHIN THE FOLLOWING 6 HOURS. IN ADDITION, ON APRIL 25, 1986, A SHIFT FOREMAN INSPECTOR (SFI) WHO WAS NOT THE DESIGNATED OPERATOR ATTEMPTED TO REHANG A TAG ON UNIT 2'S MOTOR OPERATED VALVE (MOV) 8811-B'S BREAKER FV-B5. THE SFI MISTAKENLY HUNG THE TAG ON THE UNIT 1 MOV 8811-B'S BREAKER FV-B5, NOTICED THE BREAKER WAS NOT OPEN AS THE TAB INDICATED, OPENED THE BREAKER WITHOUT PROPER TAGGING ORDERS, AND RENDERED CERTAIN FUNCTIONS OF THE UNIT 1 EMERGENCY CORE COOLING SYSTEM'S (ECCS) SUBSYSTEM INOPERABLE. IN ADDITION, FROM APRIL 25, 1986 AT 10:00 A.M. UNTIL APRIL 29, 1986 AT 9:45 A.M., DURING WHICH TIME 12 SHIFT RELIEFS OCCURRED, UNIT 1 CONTROL ROOM PERSONNEL DID NOT OBSERVE THE ABSENCE OF INDICATING LIGHTS FOR MOV 8811-B DURING SHIFT CHANGE WALKDOWNS.
(8601 3)

CONTRARY TO TS 6.8.1 AND ADMINISTRATIVE PROCEDURE 35, ON MAY 16, 1986, COMBUSTIBLE LIQUIDS WERE FOUND UNATTENDED IN THE HOT MACHINE SHOP LOCATED IN THE AUXILIARY BUILDING.
(8601 5)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

NORMAL OPERATIONS.

LAST IE SITE INSPECTION DATE: JUNE 11 - JULY 10, 1986 +

INSPECTION REPORT NO: 50-348/86-13 +

Report Period JUL 1986

R E P O R T S F R O M L I C E N S E E

* FARLEY 1 *

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
=====			

NONE.

=====

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-364 O P E R A T I N G S T A T U S
 2. Reporting Period: 07/01/86 Outage + On-line Hrs: 744.0
 3. Utility Contact: J. D. WOODARD (205) 899-5156

4. Licensed Thermal Power (MWt): 2652
 5. Nameplate Rating (Gross MWe): 860
 6. Design Electrical Rating (Net MWe): 829
 7. Maximum Dependable Capacity (Gross MWe): 872
 8. Maximum Dependable Capacity (Net MWe): 829

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,087.0</u>	<u>43,872.0</u>
13. Hours Reactor Critical	<u>651.9</u>	<u>3,892.3</u>	<u>37,692.9</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>138.4</u>
15. Hrs Generator On-Line	<u>640.7</u>	<u>3,804.8</u>	<u>37,197.2</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,625,000</u>	<u>9,503,899</u>	<u>95,347,297</u>
18. Gross Elec Ener (MWH)	<u>529,128</u>	<u>3,141,914</u>	<u>30,864,524</u>
19. Net Elec Ener (MWH)	<u>499,398</u>	<u>2,964,882</u>	<u>29,254,122</u>
20. Unit Service Factor	<u>86.1</u>	<u>74.8</u>	<u>84.8</u>
21. Unit Avail Factor	<u>86.1</u>	<u>74.8</u>	<u>84.8</u>
22. Unit Cap Factor (MDC Net)	<u>81.0</u>	<u>70.3</u>	<u>80.4</u>
23. Unit Cap Factor (DER Net)	<u>81.0</u>	<u>70.3</u>	<u>80.4</u>
24. Unit Forced Outage Rate	<u>13.9</u>	<u>4.2</u>	<u>4.7</u>
25. Forced Outage Hours	<u>103.3</u>	<u>166.0</u>	<u>1,852.8</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


NONE

27. If Currently Shutdown Estimated Startup Date: N/A

 * FARLEY 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

FARLEY 2



JULY 1986

Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

 * FARLEY 2 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
007	07/18/86	F	103.3	A	1	86-009-00	BQ	MO	THE 2B CHARGING PUMP TRIPPED ON OVERLOAD. THE MOTOR WAS FOUND TO HAVE FAILED DUE TO AN ARC IN THE WINDING. NO SPARES WERE AVAILABLE.

 * SUMMARY *

FARLEY 2 OPERATED WITH 1 OUTAGES FOR EQUIPMENT REPAIRS DURING JULY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	1-Manual
S-Sched	B-Maint or Test	G-Oper Error	2-Manual Scram
	C-Refueling	H-Other	3-Auto Scram
	D-Regulatory Restriction		4-Continued
	E-Operator Training		5-Reduced Load
	& License Examination		9-Other
			Exhibit F & H
			Instructions for
			Preparation of
			Data Entry Sheet
			Licensee Event Report
			(LER) File (NUREG-0161)

* FARLEY 2 *

FACILITY DATA

Report Period JUL 1986

FACILITY DESCRIPTION

UTILITY & CONTRACTOR INFORMATION

LOCATION
STATE.....ALABAMA
COUNTY.....HOUSTON
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...28 MI SE OF
DOTHAN, ALA
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...MAY 5, 1981
DATE ELEC ENER 1ST GENER...MAY 25, 1981
DATE COMMERCIAL OPERATE...JULY 30, 1981
CONDENSER COOLING METHOD...COOLING TOWER
CONDENSER COOLING WATER...CHATAHOOCHEE RIVER
ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY
LICENSEE.....ALABAMA POWER CO.
CORPORATE ADDRESS.....600 NORTH 18TH STREET
BIRMINGHAM, ALABAMA 35203
CONTRACTOR
ARCHITECT/ENGINEER.....SOUTHERN SERVICES INCORPORATED
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
IE RESIDENT INSPECTOR.....W. BRADFORD
LICENSING PROJ MANAGER.....E. REEVES
DOCKET NUMBER.....50-364
LICENSE & DATE ISSUANCE...NPF-8, MARCH 31, 1981
PUBLIC DOCUMENT ROOM.....HOUSTON/LOVE MEMORIAL LIBRARY
212 W. BURDESHAW STREET
DOTHAN, ALABAMA 36301

INSPECTION SUMMARY

I N S P E C T I O N S T A T U S

+ INSPECTION APRIL 11 - MAY 10 AND JUNE 3 (86-10): THIS ROUTINE AND REACTIVE INSPECTION AND ENFORCEMENT CONFERENCE INCLUDED ONSITE INSPECTION IN THE AREAS OF MONTHLY SURVEILLANCE OBSERVATION, MONTHLY MAINTENANCE OBSERVATION, OPERATIONAL SAFETY VERIFICATION, INOPERABLE ECCS SUBSYSTEM, INOPERABLE FIRE DOOR, ENGINEERED SAFETY SYSTEM INSPECTION, PART 21 REPORTS, AND REFUELING ACTIVITIES. TWO VIOLATIONS WERE IDENTIFIED: (1) VIOLATION OF TECHNICAL SPECIFICATION 3.5.2.D - EXCEEDING LIMITING CONDITION FOR OPERATION AND (2) VIOLATION OF TECHNICAL SPECIFICATION 3.7.12 - INOPERABLE FIRE BARRIER.

INSPECTION MAY 14 - JUNE 10 (86-11): THIS ROUTINE INSPECTION WAS CONDUCTED IN THE AREAS OF MONTHLY SURVEILLANCE OBSERVATION, MONTHLY MAINTENANCE OBSERVATION, OPERATIONAL SAFETY VERIFICATION, LICENSEE EVENT REPORTS, ONSITE FOLLOWUP OF EVENTS, FOLLOWUP SURVEY OF LICENSEE RESPONSE TO SELECTED SAFETY ISSUES AND PLANT STARTUP FROM REFUELING OUTAGE. TWO VIOLATIONS WERE IDENTIFIED: VIOLATION OF TECHNICAL SPECIFICATION 3.7.12 - INOPERABLE FIRE DAMPER; VIOLATION OF TECHNICAL SPECIFICATION 6.8.1 - FAILURE TO FOLLOW PROCEDURES.

INSPECTION JUNE 16-20 (86-12): THIS ROUTINE, UNANNOUNCED INSPECTION INSPECTED: SECURITY SYSTEM POWER SUPPLY; LIGHTING, ACCESS CONTROLS-PERSONNEL; ACCESS CONTROLS-PACKAGES, VEHICLES AND PERSONNEL TRAINING AND QUALIFICATIONS. THERE WERE NO VIOLATIONS OR DEVIATIONS IDENTIFIED.

INSPECTION JUNE 11 - JULY 10 (86-13): THIS ROUTINE INSPECTION IN THE AREAS OF MONTHLY SURVEILLANCE OBSERVATION, MONTHLY MAINTENANCE OBSERVATION, OPERATIONAL SAFETY VERIFICATION, ENGINEERED SAFETY FEATURE WALKDOWN, AND ONSITE FOLLOWUP OF EVENTS. ONE VIOLATION WAS IDENTIFIED: FAILURE TO UPDATE PROCEDURES AND DRAWINGS.

Report Period JUL 1986

I N S P E C T I O N S T A T U S - (CONTINUED)

* FARLEY 2 *

INSPECTION SUMMARY

ENFORCEMENT SUMMARY

CONTRARY TO TS 3.7.12, ON APRIL 29, 1986, AT 9:30 A.M., FIRE DOOR NO. 2406, THE HOT MACHINE SHOP ENTRANCE TO UNIT 2, WAS FOUND BLOCKED OPEN BY A RUBBER HOSE WITHOUT A CONTINUOUS FIRE WATCH POSTED NOR WAS THE OPERABILITY OF FIRE DETECTORS ON AT LEAST ONE SIDE OF THE DOOR VERIFIED OPERABLE OR AN HOURLY FIRE WATCH PATROL INITIATED.
(8601 4)

CONTRARY TO TS 6.8.1 AND ADMINISTRATIVE PROCEDURE 35, ON MAY 16, 1986, COMBUSTIBLE LIQUIDS WERE FOUND UNATTENDED IN THE HOT MACHINE SHOP LOCATED IN THE AUXILIARY BUILDING. CONTRARY TO TS 3.7.12, AT 8:55 A.M. ON MAY 21, 1986, UNIT 2 FIRE DAMPER PENETRATION 05-139-06, LOCATED BETWEEN THE ELECTRICAL PENETRATION ROOM AND THE PIPING PENETRATION ROOM WAS NOT FUNCTIONAL DUE TO A SOUND POWERED TELEPHONE CORD BLOCKING THE CLOSURE OF THE DAMPER.
(8601 5)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

LICENSEE CONTINUES TENDON FIELD ANCHORS INSPECTION.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

NORMAL OPERATION.

LAST IE SITE INSPECTION DATE: JUNE 11 - JULY 10, 1986 +

INSPECTION REPORT NO: 50-364/86-13 +

Report Period JUL 1986

REPORTS FROM LICENSEE

* FARLEY 2 *

```
=====
NUMBER    DATE OF    DATE OF    SUBJECT
          EVENT     REPORT
-----
86-006    05/21/86    06/17/86    FIRE DAMPER IN PENETRATION 05-139-06 INOPERABLE BECAUSE A CABLE FOR SOUND POWERED HEADPHONES
          Routed through fire damper; cause - personnel error.
86-007    06/08/86    07/03/86    REACTOR TRIP DUE TO MALFUNCTION OF BOTH CONTROL ROD DRIVE MOTOR GENERATOR SETS.
=====
```


THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-333 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/86 Outage + On-line Hrs: 744.0

3. Utility Contact: J. COOK (315) 342-3840

4. Licensed Thermal Power (MWt): 2436

5. Nameplate Rating (Gross MWe): 981 X 0.9 = 883

6. Design Electrical Rating (Net MWe): 816

7. Maximum Dependable Capacity (Gross MWe): 823

8. Maximum Dependable Capacity (Net MWe): 796

9. If Changes Occur Above Since Last Report, Give Reasons:

NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,087.0</u>	<u>96,528.0</u>
13. Hours Reactor Critical	<u>719.0</u>	<u>4,656.2</u>	<u>70,071.8</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>707.2</u>	<u>4,532.8</u>	<u>68,059.2</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,680,120</u>	<u>10,761,504</u>	<u>146,474,218</u>
18. Gross Elec Ener (MWH)	<u>560,760</u>	<u>3,656,610</u>	<u>49,687,950</u>
19. Net Elec Ener (MWH)	<u>541,760</u>	<u>3,532,515</u>	<u>48,097,040</u>
20. Unit Service Factor	<u>95.1</u>	<u>89.1</u>	<u>70.5</u>
21. Unit Avail Factor	<u>95.1</u>	<u>89.1</u>	<u>70.5</u>
22. Unit Cap Factor (MDC Net)	<u>91.5</u>	<u>87.0</u>	<u>64.4*</u>
23. Unit Cap Factor (DER Net)	<u>89.2</u>	<u>85.0</u>	<u>61.1</u>
24. Unit Forced Outage Rate	<u>4.9</u>	<u>3.0</u>	<u>12.6</u>
25. Forced Outage Hours	<u>36.8</u>	<u>142.4</u>	<u>9,988.4</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):

MAINTENANCE: 09/86 - 10 DAYS.

27. If Currently Shutdown Estimated Startup Date: N/A

* FITZPATRICK *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
FITZPATRICK



JULY 1986

* Item calculated with a Weighted Average

Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

 * FITZPATRICK *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
4	07/03/86	F	36.8	A	3		EL	IC	RX SCRAM CAUSED BY GENERATOR/TURBINE TRIP ON LOAD REJECT, THE RESULT OF A FAILED PK TEST BLOCK IN THE 345KV BUS CURRENT TRANSFORMER DIFFERENTIAL CIRCUITRY.

 * SUMMARY *

 THE FITZPATRICK PLANT OPERATED AT NEAR FULL THERMAL POWER FOR THIS REPORTING PERIOD WITH ONE TRIP ON 860703 FOR EQUIPMENT REPAIRS.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)
	F-Admin		
	G-Oper Error		
	H-Other		

* FITZPATRICK *

F A C I L I T Y D A T A

Report Period JUL 1986

FACILITY DESCRIPTION

LOCATION
STATE.....NEW YORK
COUNTY.....OSWEGO
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...8 MI NE OF
OSWEGO, NY
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...NOVEMBER 17, 1974
DATE ELEC ENER 1ST GENER...FEBRUARY 1, 1975
DATE COMMERCIAL OPERATE....JULY 28, 1975
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER....LAKE ONTARIO
ELECTRIC RELIABILITY
COUNCIL.....NORTHEAST POWER
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....NEW YORK POWER AUTHORITY
CORPORATE ADDRESS.....10 COLUMBUS CIRCLE
NEW YORK, NEW YORK 10019
CONTRACTOR
ARCHITECT/ENGINEER.....STONE & WEBSTER
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....STONE & WEBSTER
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I
IE RESIDENT INSPECTOR.....A. LUPTAK
LICENSING PROJ MANAGER....H. ABELSON
DOCKET NUMBER.....50-333
LICENSE & DATE ISSUANCE...DPR-59, OCTOBER 17, 1974
PUBLIC DOCUMENT ROOM.....STATE UNIVERSITY COLLEGE OF OSWEGO
PENFIELD LIBRARY - GOVERNMENT DOCUMENTS COL
OSWEGO, NY 13126
(315) 341-2323

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

INSPECTION STATUS - (CONTINUED)

```

XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX
X              FITZPATRICK              X
XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX

```

NO INPUT PROVIDED.

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

REPORTS FROM LICENSEE

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
--------	------------------	-------------------	---------

NO INPUT PROVIDED.

1. Docket: 50-285 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/86 Outage + On-line Hrs: 744.0

3. Utility Contact: T. P. MATTHEWS (402) 536-4733

4. Licensed Thermal Power (Mwt): 1500

5. Nameplate Rating (Gross MWe): 591 X 0.85 = 502

6. Design Electrical Rating (Net MWe): 478

7. Maximum Dependable Capacity (Gross MWe): 502

8. Maximum Dependable Capacity (Net MWe): 478

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE


10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,087.0</u>	<u>112,632.0</u>
13. Hours Reactor Critical	<u>711.2</u>	<u>4,858.7</u>	<u>87,325.0</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>1,309.5</u>
15. Hrs Generator On-Line	<u>703.1</u>	<u>4,674.8</u>	<u>85,747.8</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,003,268</u>	<u>6,206,805</u>	<u>109,957,850</u>
18. Gross Elec Ener (MWH)	<u>327,442</u>	<u>2,052,799</u>	<u>36,349,223</u>
19. Net Elec Ener (MWH)	<u>311,118</u>	<u>1,955,737</u>	<u>34,433,622</u>
20. Unit Service Factor	<u>94.5</u>	<u>91.9</u>	<u>76.1</u>
21. Unit Avail Factor	<u>94.5</u>	<u>91.9</u>	<u>76.1</u>
22. Unit Cap Factor (MDC Net)	<u>87.5</u>	<u>80.4</u>	<u>66.2*</u>
23. Unit Cap Factor (DER Net)	<u>87.5</u>	<u>80.4</u>	<u>64.0</u>
24. Unit Forced Outage Rate	<u>5.5</u>	<u>.9</u>	<u>3.4</u>
25. Forced Outage Hours	<u>40.9</u>	<u>40.9</u>	<u>1,791.2</u>
26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration): <u>NONE</u>			
27. If Currently Shutdown Estimated Startup Date: <u>N/A</u>			

* FORT CALHOUN 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
FORT CALHOUN 1



JULY 1986

* Item calculated with a Weighted Average

Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

* FORT CALHOUN 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
86-03	07/02/86	F	39.3	A	3	8601	EF	INUT	ON JULY 2, 1986, AT 0534, THE REACTOR AND TURBINE-GENERATOR WERE AUTOMATICALLY TRIPPED ON LOW STEAM GENERATOR LEVEL AFTER THE FAILURE OF A SAFETY RELATED INSTRUMENT INVERTERS. THE UNIT RETURNED TO SERVICE JULY 3, AT 2052. SEE LER-86-01 FOR DETAILS OF THE CORRECTIVE ACTIONS TAKEN.
86-04	07/04/86	F	1.6	H	3		XX	XXXX	ON JULY 4, AT 0138, THE TURBINE-GENERATOR WAS TAKEN OFF-LINE TO FIX AN EHC LEAK. THE UNIT RETURNED TO SERVICE THE SAME DAY AT 0316.

* SUMMARY *

FORT CALHOUN OPERATED WITH 2 OUTAGES DURING JULY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* FORT CALHOUN 1 *

FACILITY DATA

Report Period JUL 1986

FACILITY DESCRIPTION

LOCATION
STATE.....NEBRASKA
COUNTY.....WASHINGTON
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...19 MI N OF
OMAHA, NEB
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...AUGUST 6, 1973
DATE ELEC ENER 1ST GENER...AUGUST 25, 1973
DATE COMMERCIAL OPERATE....JUNE 20, 1974
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...MISSOURI RIVER
ELECTRIC RELIABILITY
COUNCIL.....MID-CONTINENT AREA
RELIABILITY COORDINATION
AGREEMENT

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....OMAHA PUBLIC POWER DISTRICT
CORPORATE ADDRESS.....1623 HARNEY STREET
OMAHA,, NEBRASKA 68102
CONTRACTOR
ARCHITECT/ENGINEER.....GIBBS, HILL, DURHAM & RICHARDSON
NUC STEAM SYS SUPPLIER...COMBUSTION ENGINEERING
CONSTRUCTOR.....GIBBS, HILL, DURHAM & RICHARDSON
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....IV
IE RESIDENT INSPECTOR.....P. HARRELL
LICENSING PROJ MANAGER.....D. SELLS
DOCKET NUMBER.....50-285
LICENSE & DATE ISSUANCE....DPR-40, AUGUST 9, 1973
PUBLIC DOCUMENT ROOM.....W. DALE CLARK LIBRARY
215 S. 15TH STREET
OMAHA, NEBRASKA 68102

INSPECTION STATUS

INSPECTION SUMMARY

INSPECTION CONDUCTED MAY 1-31, 1986 (86-14) ROUTINE, UNANNOUNCED INSPECTION OF OPERATIONAL SAFETY VERIFICATION, MAINTENANCE, SURVEILLANCE, PLANT TOURS, SAFETY-RELATED SYSTEM WALKDOWNS, FOLLOWUP ON PREVIOUSLY IDENTIFIED ITEMS, FOLLOWUP ON A LICENSEE EVENT REPORT (LER), AND FOLLOWUP ON A 10 CFR PART 21 REPORT ON VALCOR VALVES. WITHIN THE AREAS INSPECTED, ONE VIOLATION WAS IDENTIFIED.

INSPECTION CONDUCTED MAY 19-23, 1986 (86-15) ROUTINE, UNANNOUNCED INSPECTION CONSISTING OF SECURITY ORGANIZATION, MANAGEMENT, RECORDS AND REPORTS, AND PERSONNEL TRAINING AND QUALIFICATIONS. WITHIN THE AREAS INSPECTED, THREE APPARENT VIOLATIONS WERE IDENTIFIED.

INSPECTION CONDUCTED JUNE 9-13, 1986 (86-17) ROUTINE, UNANNOUNCED INSPECTION CONSISTING OF PHYSICAL BARRIERS - VITAL AREA (VA), DETECTION AIDS - VA, ACCESS CONTROL - PERSONNEL, SECURITY SYSTEM POWER SUPPLY, ALARM STATIONS, AND COMMUNICATIONS. WITHIN THE AREAS INSPECTED AN APPARENT VIOLATION WAS IDENTIFIED.

INSPECTION CONDUCTED JUNE 1-30, 1986 (86-18) ROUTINE, UNANNOUNCED INSPECTION INCLUDING OPERATIONAL SAFETY VERIFICATION; MAINTENANCE; SURVEILLANCE; PLANT TOURS; SAFETY-RELATED SYSTEM WALKDOWNS; FOLLOWUP ON A PREVIOUSLY IDENTIFIED ITEM; FOLLOWUP ON IE INFORMATION NOTICES AND IE BULLETINS ISSUED FOR INFORMATION ONLY; FOLLOWUP ON A LICENSEE EVENT REPORT; AND FOLLOWUP ON NUREG-0737 (TMI) I.D.2, IMPLEMENTATION OF THE SPDS. WITHIN THE NINE AREAS INSPECTED, ONE DEVIATION WAS IDENTIFIED.

Report Period JUL 1986

I N S P E C T I O N S T A T U S - (CONTINUED)

* FORT CALHOUN 1 *

ENFORCEMENT SUMMARY

CONTRARY TO PART 50, CRITERION V; DRAWINGS 11405-E-60 AND 11405-E-151, CABLE AND CABLE TRAYS ARE NOT BEING MAINTAINED IN ACCORDANCE WITH BASIC DESIGN DOCUMENTATION.
(8601 4)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

LAST IE SITE INSPECTION DATE: JUNE 1-30, 1986

INSPECTION REPORT NO: 50-285/86-18

R E P O R T S F R O M L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT

NONE			

=====

1. Docket: 50-267 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/86 Outage + On-line Hrs: 744.0

3. Utility Contact: FRANK NOVACHEK (303) 785-2224

4. Licensed Thermal Power (Mwt): 842

5. Nameplate Rating (Gross MWe): 403 X 0.85 = 343

6. Design Electrical Rating (Net MWe): 330

7. Maximum Dependable Capacity (Gross MWe): 342

8. Maximum Dependable Capacity (Net MWe): 330

9. If Changes Occur Above Since Last Report, Give Reasons: NONE

10. Power Level To Which Restricted, If Any (Net MWe):


11. Reasons for Restrictions, If Any: NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,087.0</u>	<u>62,112.0</u>
13. Hours Reactor Critical	<u>.0</u>	<u>2,456.6</u>	<u>30,492.8</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>.0</u>	<u>1,087.1</u>	<u>19,550.6</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>0</u>	<u>370,315</u>	<u>10,113,482</u>
18. Gross Elec Ener (MWH)	<u>0</u>	<u>85,402</u>	<u>3,334,290</u>
19. Net Elec Ener (MWH)	<u>-2,215</u>	<u>61,174</u>	<u>2,957,220</u>
20. Unit Service Factor	<u>.0</u>	<u>21.4</u>	<u>31.5</u>
21. Unit Avail Factor	<u>.0</u>	<u>21.4</u>	<u>31.5</u>
22. Unit Cap Factor (MDC Net)	<u>.0</u>	<u>3.6</u>	<u>14.4</u>
23. Unit Cap Factor (DER Net)	<u>.0</u>	<u>3.6</u>	<u>14.4</u>
24. Unit Forced Outage Rate	<u>100.0</u>	<u>78.6</u>	<u>59.8</u>
25. Forced Outage Hours	<u>744.0</u>	<u>3,999.9</u>	<u>29,089.4</u>
26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):	<u>NONE</u>		

27. If Currently Shutdown Estimated Startup Date: 10/09/86

 * FORT ST VRAIN *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
 FORT ST VRAIN



JULY 1986

Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

* FORT ST VRAIN *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
86-03	05/30/86	F	744.0	D	1 4		ZZ	ZZZZZ	ENVIRONMENTAL QUALIFICATION MODIFICATIONS.

* SUMMARY *

FORT ST. VRAIN REMAINS SHUTDOWN FOR ENVIRONMENTAL QUALIFICATION MODIFICATIONS.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* FORT ST VRAIN *

FACILITY DATA

Report Period JUL 1986

FACILITY DESCRIPTION

LOCATION
STATE.....COLORADO
COUNTY.....WELD
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...35 MI N OF
DENVER, COL
TYPE OF REACTOR.....HTGR
DATE INITIAL CRITICALITY...JANUARY 31, 1974
DATE ELEC ENER 1ST GENER...DECEMBER 11, 1976
DATE COMMERCIAL OPERATE....JULY 1, 1979
CONDENSER COOLING METHOD...COOLING TOWER
CONDENSER COOLING WATER....S. PLATTE RIVER
ELECTRIC RELIABILITY
COUNCIL.....WESTERN SYSTEMS
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....PUBLIC SERVICE OF COLORADO
CORPORATE ADDRESS.....P.O. BOX 840
DENVER, COLORADO 80201
CONTRACTOR
ARCHITECT/ENGINEER.....SARGENT & LUNDY
NUC STEAM SYS SUPPLIER...GENERAL ATOMIC CORP.
CONSTRUCTOR.....EBASCO
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....IV
IE RESIDENT INSPECTOR.....R. FARRELL
LICENSING PROJ MANAGER....C. HINSON
DOCKET NUMBER.....50-267
LICENSE & DATE ISSUANCE...DPR-34, DECEMBER 21, 1973
PUBLIC DOCUMENT ROOM.....GREELEY PUBLIC LIBRARY
CITY COMPLEX BUILDING
GREELEY, COLORADO 80631

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION CONDUCTED MARCH 31 - APRIL 4, 1986 (86-09) ROUTINE, ANNOUNCED INSPECTION OF LICENSEE MAINTENANCE ACTIVITIES, COVERING THE MAINTENANCE PROGRAM, MAINTENANCE PROGRAM IMPLEMENTATION, INSTRUMENTATION AND CONTROL (I&C) MAINTENANCE, AND ELECTRICAL MAINTENANCE. WITHIN THE AREAS INSPECTED, ONE VIOLATION WAS IDENTIFIED.

INSPECTION CONDUCTED MAY 1 - JUNE 6, 1986 (86-13) ROUTINE, UNANNOUNCED INSPECTION OF OPERATIONAL SAFETY VERIFICATION, SURVEILLANCES, ENGINEERED SAFETY FEATURES, MAINTENANCE, AND SECURITY. WITHIN THE FIVE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION CONDUCTED MAY 12-16, 1986 (86-14) ROUTINE, UNANNOUNCED INSPECTION OF PHYSICAL BARRIERS - VITAL AREA (VA), ACCESS CONTROL - PERSONNEL, DETECTION AIDS - VA, ALARM STATIONS, SECURITY SYSTEMS POWER SUPPLY, AND COMMUNICATIONS. WITHIN THE SIX AREAS INSPECTED, THREE VIOLATIONS WERE IDENTIFIED.

INSPECTION CONDUCTED MAY 19-22, 1986 (86-15) ROUTINE, UNANNOUNCED EMERGENCY PREPAREDNESS INSPECTION IN THE AREAS OF EMERGENCY DETECTION AND CLASSIFICATION, PROTECTIVE ACTION DECISIONMAKING, DOSE CALCULATION AND ASSESSMENT, NOTIFICATION AND COMMUNICATION, PUBLIC INFORMATION PROGRAM, AND SHIFT STAFFING AND AUGMENTATION. WITHIN THE EMERGENCY RESPONSE AREAS INSPECTED, ONE VIOLATION WAS IDENTIFIED.

INSPECTION CONDUCTED JUNE 16-20, 1986 (86-18) ROUTINE, UNANNOUNCED INSPECTION OF ACCESS CONTROL - VEHICLES, ACCESS CONTROL - PACKAGES, ACCESS CONTROL - PERSONNEL, AND COMPENSATORY MEASURES. WITHIN THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE

Report Period JUL 1986

I N S P E C T I O N S T A T U S - (CONTINUED)

* FORT ST VRAIN *

INSPECTION SUMMARY

IDENTIFIED.

INSPECTION CONDUCTED JUNE 23-27, 1986 (86-19) ROUTINE, UNANNOUNCED INSPECTION OF THE LICENSEE'S QUALITY ASSURANCE PROGRAM EQUIPMENT QUALIFICATION (EQ) OUTAGE PLANNING, AND REVIEW OF 10 CFR 50, APPENDIX R. WITHIN THE AREAS INSPECTED, ONE APPARENT VIOLATION WAS IDENTIFIED.

ENFORCEMENT SUMMARY

CONTRARY TO 10CFR 50, CRITERION VI, THE LICENSEE WAS USING SCHEMATIC DRAWINGS THAT WERE NOT UP TO DATE.
(8600 4)

SUITABILITY, TRAINING AND QUALIFICATIONS. SAFEGUARDS INFO. INADEQUATE ACCESS - CONTROL- FAILURE TO MAINTAIN POSITIVE ACCESS CONTROL OF PERSONNEL IAW 10CFR 73.55(D)(7) UNBADGED INDIVIDUALS IN PROTECTED AREA ACCESS - CONTROL PERSONNEL - FAILURE TO ESCORT 10 CFR 50.47(B)(15) REQUIRES THAT ADEQUATE PROVISIONS EXIST IN THE EMERGENCY PLAN TO ENSURE THAT RADIOLOGICAL EMERGENCY RESPONSE TRAINING IS PROVIDED TO THOSE WHO MAY BE CALLED ON TO ASSIST IN AN EMERGENCY. SECTION 8.1.1 OF THE EMERGENCY PLAN STATES, IN PART, "A TRAINING AND ANNUAL RETRAINING PROGRAM IS IN EFFECT TO ENSURE THAT STATION PERSONNEL WHO ACTIVELY PARTICIPATE IN EMERGENCY SITUATIONS ARE FAMILIAR WITH THE CONTENTS AND RESPONSES SET FORTH IN THIS RERP. THE FT.ST.VRAIN TRAINING PROGRAMS ADMINISTRATIVE MANUAL (TPAM), SITUATION RESPONSE TRAINING PROGRAM - RERP, DELINEATES SPECIFIC TRAINING...." CONTRARY TO THE ABOVE, ON MAY22, 1986, THE NRC INSPECTORS DETERMINED THAT TWO KEY PERSONS ASSIGNED EMERGENCY RESPONSE FUNCTIONS (CORPORATE EMERGENCY DIRECTOR) HAD NOT RECEIVED ALL OF THE EMERGENCY RESPONSE TRAINING DELINEATED IN THE TPAM PRIOR TO HAVING BEEN ASSIGNED TO THE EMERGENCY RESPONSE ORGANIZATION, AS EVIDENCED BY THE LACK OF RECORDS DOCUMENTING THE COMPLETION OF REQUIRED TRAINING.
(8601 4)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

R.O.WILLIAMS NAMED VICE PRESIDENT, NUCLEAR OPERATIONS

PLANT STATUS:

SHUTDOWN FOR EQUIPMENT QUALIFICATION WORK

LAST IE SITE INSPECTION DATE: JUNE 23-27, 1986

INSPECTION REPORT NO: 50-267/86-19

Report Period JUL 1986

REPORTS FROM LICENSEE

* FORT ST VRAIN *

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT

NONE			

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-244 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/86 Outage + On-line Hrs: 744.0

3. Utility Contact: ANDREW MC NAMARA (315) 524-4446

4. Licensed Thermal Power (Mwt): 1520

5. Nameplate Rating (Gross MWe): 608 X 0.85 = 517

6. Design Electrical Rating (Net MWe): 470

7. Maximum Dependable Capacity (Gross MWe): 490

8. Maximum Dependable Capacity (Net MWe): 470

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,087.0</u>	<u>146,207.0</u>
13. Hours Reactor Critical	<u>711.9</u>	<u>4,064.6</u>	<u>112,351.2</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>1,687.7</u>
15. Hrs Generator On-Line	<u>692.0</u>	<u>4,015.5</u>	<u>110,009.3</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>8.5</u>
17. Gross Therm Ener (MWH)	<u>1,035,216</u>	<u>5,873,136</u>	<u>153,595,361</u>
18. Gross Elec Ener (MWH)	<u>344,174</u>	<u>1,976,496</u>	<u>50,287,353</u>
19. Net Elec Ener (MWH)	<u>327,280</u>	<u>1,879,116</u>	<u>47,682,434</u>
20. Unit Service Factor	<u>93.0</u>	<u>78.9</u>	<u>75.2</u>
21. Unit Avail Factor	<u>93.0</u>	<u>78.9</u>	<u>75.2</u>
22. Unit Cap Factor (MDC Net)	<u>93.6</u>	<u>78.6</u>	<u>70.9*</u>
23. Unit Cap Factor (DER Net)	<u>93.6</u>	<u>78.6</u>	<u>70.9*</u>
24. Unit Forced Outage Rate	<u>7.0</u>	<u>1.3</u>	<u>6.9</u>
25. Forced Outage Hours	<u>52.0</u>	<u>52.0</u>	<u>4,295.8</u>
26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration): <u>NONE</u>			

27. If Currently Shutdown Estimated Startup Date: N/A

 * GINNA *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

GINNA



JULY 1986

* Item calculated with a Weighted Average

PAGE 2-142

Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

 * GINNA *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
86-2	07/29/86	F	39.0	A	1	86-4	HJ	PIPEXX	2A MSR DRAIN LINE TO 5B HEATER - ELBOW RUPTURE.
86-3	07/30/86	F	13.0	A	3	86-5	IA	RELAYX	AUTOMATIC REACTOR TRIP DUE TO TWO FAULTY RELAYS IN THE "A" TRAIN OF THE INTERMEDIATE RANGE BLOCKING CIRCUIT.

 * SUMMARY *

 GINNA OPERATED WITH 2 OUTAGES FOR EQUIPMENT REPAIRS IN JULY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* GINNA *

F A C I L I T Y D A T A

Report Period JUL 1986

FACILITY DESCRIPTION

LOCATION
STATE.....NEW YORK
COUNTY.....WAYNE
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...15 MI NE OF
ROCHESTER, NY
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...NOVEMBER 8, 1969
DATE ELEC ENER 1ST GENER...DECEMBER 2, 1969
DATE COMMERCIAL OPERATE....JULY 1, 1970
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...LAKE ONTARIO
ELECTRIC RELIABILITY
COUNCIL.....NORTHEAST POWER
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....ROCHESTER GAS & ELECTRIC
CORPORATE ADDRESS.....89 EAST AVENUE
ROCHESTER, NEW YORK 14604
CONTRACTOR
ARCHITECT/ENGINEER.....GILBERT ASSOCIATES
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I
IE RESIDENT INSPECTOR.....W. COOK
LICENSING PROJ MANAGER.....M. FAIRTILE
DOCKET NUMBER.....50-244
LICENSE & DATE ISSUANCE....DPR-18, DECEMBER 10, 1984
PUBLIC DOCUMENT ROOM.....ROCHESTER PUBLIC LIBRARY
BUSINESS AND SOCIAL SCIENCE DIVISION
115 SOUTH AVENUE
ROCHESTER, NEW YORK 14604

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

Report Period JUL 1986

INSPECTION STATUS - (CONTINUED)

XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX
X GINNA X
XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX

OTHER ITEMS

NO INPUT PROVIDED.

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

REPORTS FROM LICENSEE

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
--------	------------------	-------------------	---------

NO INPUT PROVIDED.

1. Docket: 50-416 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/86 Outage + On-line Hrs: 744.0

3. Utility Contact: S. H. HOBBS (601) 969-2458

4. Licensed Thermal Power (MWh): 3833

5. Nameplate Rating (Gross MWe): 1373

6. Design Electrical Rating (Net MWe): 1250

7. Maximum Dependable Capacity (Gross MWe): 1157

8. Maximum Dependable Capacity (Net MWe): 1108

9. If Changes Occur Above Since Last Report, Give Reasons:

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,087.0</u>	<u>9,504.0</u>
13. Hours Reactor Critical	<u>715.2</u>	<u>4,735.4</u>	<u>7,618.8</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>700.2</u>	<u>4,614.8</u>	<u>7,307.3</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>2,040,720</u>	<u>12,582,529</u>	<u>21,663,360</u>
18. Gross Elec Ener (MWH)	<u>598,250</u>	<u>3,745,780</u>	<u>6,538,670</u>
19. Net Elec Ener (MWH)	<u>567,106</u>	<u>3,544,276</u>	<u>6,198,425</u>
20. Unit Service Factor	<u>94.1</u>	<u>90.7</u>	<u>76.9</u>
21. Unit Avail Factor	<u>94.1</u>	<u>90.7</u>	<u>76.9</u>
22. Unit Cap Factor (MDC Net)	<u>68.0</u>	<u>62.9</u>	<u>58.9</u>
23. Unit Cap Factor (DER Net)	<u>61.0</u>	<u>55.7</u>	<u>52.2</u>
24. Unit Forced Outage Rate	<u>5.9</u>	<u>9.3</u>	<u>9.7</u>
25. Forced Outage Hours	<u>43.8</u>	<u>472.2</u>	<u>781.9</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


REFUELING OUTAGE: 09/5/86; APPROX. 60 DAYS.

27. If Currently Shutdown Estimated Startup Date: N/A

 * GRAND GULF 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

GRAND GULF 1



JULY 1986

Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

 * GRAND GULF 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
86-09	07/25/86	F	43.8	H	3	86-025	ZZ	ZZZZZZ	A POWER SUPPLY BREAKER WAS INADVERTENTLY BUMPED OPEN CAUSING A LOSS OF AIR TO SCRAM VALVES. THE REACTOR SCRAMMED ON THE SCRAM DISCHARGE VOLUME HIGH HIGH LEVEL THAT OCCURRED AS THE SCRAM VALVES DRIFTED OPEN.

 * SUMMARY *

 GRAND GULF 1 OPERATED WITH 1 OUTAGE AND SEVERAL REDUCTIONS FOR ECONOMIC AND SYSTEM LOAD DEMAND CONSIDERATIONS.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	1-Manual
S-Sched	B-Maint or Test	G-Oper Error	2-Manual Scram
	C-Refueling	H-Other	3-Auto Scram
	D-Regulatory Restriction		4-Continued
	E-Operator Training		5-Reduced Load
	& License Examination		9-Other
			Exhibit F & H
			Instructions for
			Preparation of
			Data Entry Sheet
			Licensee Event Report
			(LER) File (NUREG-0161)

* GRAND GULF 1 *

FACILITY DATA

Report Period JUL 1986

FACILITY DESCRIPTION

LOCATION
STATE.....MISSISSIPPI
COUNTY.....CLAIBORNE
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...25 MI S OF
VICKSBURG, MISS
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...AUGUST 18, 1982
DATE ELEC ENER 1ST GENER...OCTOBER 20, 1984
DATE COMMERCIAL OPERATE....JULY 1, 1985
CONDENSER COOLING METHOD...CCHNDCT
CONDENSER COOLING WATER....MISSISSIPPI RIVER
ELECTRIC RELIABILITY
COUNCIL.....SOUTHWEST POWER POOL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....MISSISSIPPI POWER & LIGHT COMPANY
CORPORATE ADDRESS.....P.O. BOX 1640
JACKSON, MISSISSIPPI 39205
CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....ALLIS-CHALMERS

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
IE RESIDENT INSPECTOR.....R. BUTCHER
LICENSING PROJ MANAGER.....L. KINTNER
DOCKET NUMBER.....50-416
LICENSE & DATE ISSUANCE...NPF-29, NOVEMBER 1, 1984
PUBLIC DOCUMENT ROOM.....HINDS JUNIOR COLLEGE
MC LENDON LIBRARY
RAYMOND, MISSISSIPPI 39154

INSPECTION STATUS

INSPECTION SUMMARY

+ INSPECTION MAY 12-16 AND 21 (86-12): THIS ROUTINE, UNANNOUNCED INSPECTION WAS CONDUCTED IN THE AREA OF EMERGENCY PREPAREDNESS. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION MAY 20 - JUNE 12 (86-17): THIS ROUTINE INSPECTION WAS CONDUCTED IN THE AREAS OF LICENSEE ACTION ON PREVIOUS ENFORCEMENT MATTERS, OPERATIONAL SAFETY VERIFICATION, MAINTENANCE OBSERVATION, SURVEILLANCE OBSERVATION, ESF SYSTEM WALKDOWN, REPORTABLE OCCURRENCES, OPERATING REACTOR EVENTS, INSPECTOR FOLLOWUP AND UNRESOLVED ITEMS, AND IE BULLETIN, CONFIRMATORY ACTION LETTER AND GENERIC LETTER FOLLOWUP. ONE VIOLATION - FAILURE TO HAVE PROCEDURAL CONTROLS REQUIRING PERSONNEL REVISING PROCEDURES WHICH AFFECT NUCLEAR SAFETY TO MAKE A DETERMINATION THAT AN UNREVIEWED SAFETY QUESTION IS OR IS NOT INVOLVED.

INSPECTION JUNE 9-13 (86-18): THIS ROUTINE, ANNOUNCED INSPECTION WAS CONDUCTED AT THE CORPORATE OFFICE IN THE AREAS OF OFFSITE SUPPORT STAFF AND OFFSITE REVIEW COMMITTEE. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JUNE 13 - JULY 14 (86-20): THIS ROUTINE INSPECTION WAS CONDUCTED BY THE RESIDENT INSPECTORS AT THE SITE IN THE AREAS OF LICENSEE ACTION ON PREVIOUS ENFORCEMENT MATTERS, OPERATIONAL SAFETY VERIFICATION, MAINTENANCE OBSERVATION, SURVEILLANCE OBSERVATION, ESF SYSTEM WALKDOWN, REPORTABLE OCCURRENCES, INSPECTOR FOLLOWUP AND UNRESOLVED ITEMS, INFORMATION MEETINGS WITH LOCAL OFFICIALS, DESIGN CHANGES AND MODIFICATIONS, AND SPENT FUEL STORAGE RACKS. ONE VIOLATION WITH TWO EXAMPLES WERE IDENTIFIED: 1) INADEQUATE SURVEILLANCE PROCEDURE IN THAT ISOLATION VALVES WERE NOT REQUIRED TO BE RESTORED TO THE LOCKED OPEN POSITION; AND 2) FAILURE TO FOLLOW PROCEDURES WHEN INITIATING TEMPORARY ALTERATIONS.

Report Period JUL 1986

I N S P E C T I O N S T A T U S - (CONTINUED)

* GRAND GULF 1 *

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE.

FACILITY ITEMS (PLANS AND PROCEDURES):

+ FIRST REFUELING OUTAGE TO BEGIN 09/05/86.

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

OPERATING AT 100% POWER.

LAST IE SITE INSPECTION DATE: JUNE 13 - JULY 14, 1986 +

INSPECTION REPORT NO: 50-416/86-20 +

Report Period JUL 1986

REPORTS FROM LICENSEE

* GRAND GULF 1 *

```
=====
NUMBER    DATE OF    DATE OF    SUBJECT
EVENT     REPORT
-----
85-043    11/07/85   12/09/85   WORK ON THE HYDROGEN ANALYZERS FOUND TERMINAL STRIPS IN ALL FOUR HYDROGEN ANALYZERS BRITTLE,
CRACKED OR BROKEN; CAUSE - EXCESSIVE HEAT.
86-012    04/10/86   05/12/86   CONTAINMENT ISOLATION VALVE E12-F008 AUTOMATICALLY CLOSED DUE TO A FAILED COIL IN A LOGIC RELAY.
86-013    04/21/86   05/02/86   PROCEDURAL AND DESIGN DEFICIENCIES; CAUSE - UNMONITORED CONTROL ROOM AIR INFLUENT.
86-014    04/11/86   05/16/86   FAILURE TO PERFORM A NONROUTINE SURVEILLANCE RETEST FOR A MOTOR OPERATED ISOLATION VALVE'S
THERMAL OVERLOAD BYPASS CIRCUITRY; DUE TO PROCEDURAL ERROR.
86-016    04/17/86   05/16/86   PROCEDURAL ERROR CAUSES MISSED ISOLATION TIME MEASUREMENT; CAUSE - REQUIREMENT TO MEASURE
INADVERTENTLY DELETED FROM PROCEDURE DATA TABLE.
86-019    12/15/84   06/23/86   TWO UNDESIGNATED AND IMPROPERLY SEALED PENETRATIONS IN FIRE RATED WALL BETWEEN CONTROL BUILDING
COMPUTER ROOM AND LOWER CABLE SPREADING ROOM; CAUSE - IMPROPER INSTALLATION DURING CONSTRUCTION
PHASE.
86-020    06/03/86   07/03/86   NONQUALIFIED RELAY COULD CAUSE LOSS OF SGTS SAFETY FUNCTION.
86-021    06/07/86   07/07/86   UNPLANNED REACTOR CORE ISOLATION COOLING SYSTEM ISOLATION OCCURRED DUE TO A FALSE HIGH STEAM
FLOW TRIP SIGNAL.
=====
```


THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-213 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/86 Outage + On-line Hrs: 744.0

3. Utility Contact: J. P. DRAGO (203) 267-2556 X452

4. Licensed Thermal Power (MWt): 1825

5. Nameplate Rating (Gross MWe): 667 X 0.9 = 600

6. Design Electrical Rating (Net MWe): 582

7. Maximum Dependable Capacity (Gross MWe): 596

8. Maximum Dependable Capacity (Net MWe): 569

9. If Changes Occur Above Since Last Report, Give Reasons: NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,087.0</u>	<u>162,887.0</u>
13. Hours Reactor Critical	<u>249.3</u>	<u>1,633.0</u>	<u>138,032.4</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>1,221.5</u>
15. Hrs Generator On-Line	<u>246.3</u>	<u>1,418.7</u>	<u>132,219.4</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>398.0</u>
17. Gross Therm Ener (MWH)	<u>445,484</u>	<u>1,935,473</u>	<u>229,051,385</u>
18. Gross Elec Ener (MWH)	<u>137,608</u>	<u>900,261</u>	<u>75,430,699</u>
19. Net Elec Ener (MWH)	<u>127,327</u>	<u>542,287</u>	<u>71,443,378</u>
20. Unit Service Factor	<u>33.1</u>	<u>27.9</u>	<u>81.2</u>
21. Unit Avail Factor	<u>33.1</u>	<u>27.9</u>	<u>81.4</u>
22. Unit Cap Factor (MDC Net)	<u>30.1</u>	<u>18.7</u>	<u>80.4*</u>
23. Unit Cap Factor (DER Net)	<u>29.4</u>	<u>18.3</u>	<u>75.4*</u>
24. Unit Forced Outage Rate	<u>66.9</u>	<u>31.3</u>	<u>6.0</u>
25. Forced Outage Hours	<u>497.7</u>	<u>646.6</u>	<u>1,972.7</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


NONE

27. If Currently Shutdown Estimated Startup Date: 08/25/86

* HADDAM NECK *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

HADDAM NECK



JULY 1986

* Item calculated with a Weighted Average

Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

 * HADDAM NECK *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
86-07	07/11/86	F	497.7	A	1	86-036	SF	PUMPXX	METAL FATIGUE OF CHARGING PUMP SHAFT. IMPROVED INSPECTION, PERIODIC MAINTENANCE, AND ENGINEERING EVALUATION OF PRESENT PUMP DESIGN. ALSO, PRIMARY WATER STRESS CORROSION CRACKING OF STEAM GENERATOR TUBES.

 * SUMMARY *

CONNECTICUT YANKEE HADDAM NECK SHUTDOWN ON JULY 11TH FOR EQUIPMENT REPAIRS.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* HADDAM NECK *

FACILITY DATA

Report Period JUL 1986

FACILITY DESCRIPTION

LOCATION
STATE.....CONNECTICUT
COUNTY.....MIDDLESEX
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...13 MI E OF
MERIDEN, CONN
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...JULY 24, 1967
DATE ELEC ENER 1ST GENER...AUGUST 7, 1967
DATE COMMERCIAL OPERATE...JANUARY 1, 1968
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...CONNECTICUT RIVER
ELECTRIC RELIABILITY
COUNCIL.....NORTHEAST POWER
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....CONNECTICUT YANKEE ATOMIC POWER
CORPORATE ADDRESS.....P.O. BOX 270
HARTFORD, CONNECTICUT 06101
CONTRACTOR
ARCHITECT/ENGINEER.....STONE & WEBSTER
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....STONE & WEBSTER
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I
IE RESIDENT INSPECTOR.....P. SWETLAND
LICENSING PROJ MANAGER.....F. AKSTULEWICZ
DOCKET NUMBER.....50-213
LICENSE & DATE ISSUANCE...DPR-61, DECEMBER 27, 1974
PUBLIC DOCUMENT ROOM.....RUSSELL LIBRARY
123 BROAD STREET
MIDDLETOWN, CONNECTITCUT 06457

INSPECTION STATUS

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

TECHNICAL SPECIFICATION 4.4 STATES THAT A LLRT WILL BE PERFORMED BY A METHOD THAT IS EQUIVALENT SENSITIVE. THE LICENSEE IS USING A METHOD (WATER COLLECTION METHOD) WHICH HAS BEEN DISAPPROVED BY THE NRC. SA-V-413 IS CLASSIFIED AS A MANUAL CONTAINMENT ISOLATION VALVE WHICH DURING OPERATION OF THE PLANT SHOULD BE IN THE CLOSED POSITION AND LOCKED ACCORDING TO TECHNICAL SPECIFICATION 1.8. CONTRARY TO THE ABOVE THE LICENSEE UNLOCKED AND OPENED THE VALVE 3 DIFFERENT TIMES IN 1985 TO PERFORM SURVEILLANCE TESTING. THE LICENSEE HAD TO REDESIGNATE TWO VALVES AS CONTAINMENT ISOLATION VALVES BECAUSE OF THE FOLLOWING: (1) PENETRATION 80 - UNABLE TO PERFORM LLRT OF THE CHECK VALVE WHICH WAS DESIGNATED AS THE CIV BECAUSE OF THE CONFIGURATION (COULD NOT PRESSURIZE) COULD ONLY BE PERFORMED DURING ILRT. (2) PENETRATION 62 - DOUBLE CHECK VALVES ONE INSIDE CONTAINMENT AND ONE OUTSIDE SHOWED EXCESSIVE LEAKAGE SO A MOTOR OPERATED VALVE DOWNSTREAM WAS REDESIGNATED AS THE ISOLATION VALVE. THE LICENSEE FAILED TO PERFORM REQUIRED 50.59 SAFETY EVALUATION REPORT TO DEMONSTRATE THAT AN UNREVIEWED SAFETY ISSUE DOES NOT EXIST. (8600 4)

FAILURE TO FOLLOW PROCEDURE 1.2-3.1, DESIGN CHANGES SUCH THAT OPERATING PROCEDURES WERE NOT IMPLEMENTED UPON TURNOVER OF A MODIFIED STEAM GENERATOR CHEMICAL CONTROL SYSTEM.

Report Period JUL 1986

I N S P E C T I O N S T A T U S - (CONTINUED)

* HADDAM NECK *

ENFORCEMENT SUMMARY

(8600 5)

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S F R O M L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT

NO INPUT PROVIDED.			
=====			

1. Docket: 50-321 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/86 Outage + On-line Hrs: 744.0

3. Utility Contact: T. KILROY (912) 367-7781 X2882

4. Licensed Thermal Power (MWT): 2436

5. Nameplate Rating (Gross MWe): 1000 X 0.85 = 850

6. Design Electrical Rating (Net MWe): 777

7. Maximum Dependable Capacity (Gross MWe): 801

8. Maximum Dependable Capacity (Net MWe): 768

9. If Changes Occur Above Since Last Report, Give Reasons: NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,087.0</u>	<u>92,759.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>2,055.1</u>	<u>64,107.1</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>1,770.4</u>	<u>60,336.7</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,782,168</u>	<u>3,952,824</u>	<u>128,385,079</u>
18. Gross Elec Ener (MWH)	<u>574,690</u>	<u>1,264,890</u>	<u>41,497,730</u>
19. Net Elec Ener (MWH)	<u>549,811</u>	<u>1,200,910</u>	<u>39,410,088</u>
20. Unit Service Factor	<u>100.0</u>	<u>34.8</u>	<u>65.0</u>
21. Unit Avail Factor	<u>100.0</u>	<u>34.8</u>	<u>65.0</u>
22. Unit Cap Factor (MDC Net)	<u>96.2</u>	<u>30.7</u>	<u>55.3</u>
23. Unit Cap Factor (DER Net)	<u>95.1</u>	<u>30.4</u>	<u>54.7</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>7.6</u>	<u>15.3</u>
25. Forced Outage Hours	<u>.0</u>	<u>144.8</u>	<u>10,664.8</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):

NONE

27. If Currently Shutdown Estimated Startup Date: N/A

* HATCH 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
HATCH 1



JULY 1986

Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

* HATCH 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
86-023	07/02/86	F	0.0	A	5		CH	VALVEX	DECREASED RECIRC. FLOW DUE TO N21-F200A HYDRAULIC MALFUNCTION.
86-024	07/05/86	S	0.0	B	5		HA	TURBIN	WEEKLY TURBINE TESTING.
86-025	07/13/86	F	0.0	A	5		CB	PUMPXX	"1B" RECIRC. PUMP TRIP.
86-026	07/19/86	S	0.0	B	5		HA	TURBIN	WEEKLY TURBINE TESTING.
86-027	07/23/86	F	0.0	A	5		CH	TURBIN	"1A" REACTOR FEED PUMP TURBINE (RFPT) TRIP.
86-028	07/27/86	S	0.0	B	5		HA	TURBIN	WEEKLY TURBINE TESTING.

* SUMMARY *

HATCH 1 OPERATED WITH 6 REDUCTIONS LISTED IN DETAIL ABOVE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* HATCH 1 *

FACILITY DATA

Report Period JUL 1986

FACILITY DESCRIPTION

LOCATION
STATE.....GEORGIA
COUNTY.....APPLING
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...11 MI N OF
BAXLEY, GA
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...SEPTEMBER 12, 1974
DATE ELEC ENER 1ST GENER...NOVEMBER 11, 1974
DATE COMMERCIAL OPERATE...DECEMBER 31, 1975
CONDENSER COOLING METHOD...COOLING TOWER
CONDENSER COCLING WATER...ALTAMAHA RIVER
ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....GEORGIA POWER
CORPORATE ADDRESS.....333 PIEDMONT AVENUE
ATLANTA, GEORGIA 30308
CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....GEORGIA POWER CO.
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
IE RESIDENT INSPECTOR.....P. HOLMES RAY
LICENSING PROJ MANAGER.....G. RIVENBARK
DOCKET NUMBER.....50-321
LICENSE & DATE ISSUANCE...DPR-57, OCTOBER 13, 1974
PUBLIC DOCUMENT ROOM.....APPLING COUNTY PUBLIC LIBRARY
301 CITY HALL DRIVE
BAXLEY, GEORGIA 31563

INSPECTION STATUS

INSPECTION SUMMARY

+ INSPECTION MAY 31 - JUNE 30 (86-17): THIS ROUTINE INSPECTION WAS CONDUCTED AT THE SITE IN THE AREAS OF LICENSEE ACTION ON PREVIOUS ENFORCEMENT MATTERS, OPERATIONAL SAFETY VERIFICATION, MAINTENANCE OBSERVATION, PLANT MODIFICATION AND SURVEILLANCE OBSERVATION, AND REPORTABLE OCCURRENCES. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JUNE 23-27 (86-18): THIS ROUTINE, UNANNOUNCED INSPECTION INVOLVED A REVIEW OF THE LICENSEE'S HEALTH PHYSICS PROGRAM, INCLUDING ORGANIZATION AND MANAGEMENT CONTROLS, INTERNAL EXPOSURE, EXTERNAL EXPOSURE CONTROL, CONTROL AND PERSONAL DOSIMETRY, THE LICENSEE'S PROGRAM TO MAINTAIN EXPOSURES AS LOW AS REASONABLY ACHIEVABLE (ALARA), AND THE CONTROL OF MATERIALS RELEASED FROM THE RCA. ONE VIOLATION - INADEQUATE RELEASE SURVEYS OF MATERIALS FOR UNRESTRICTED USE.

ENFORCEMENT SUMMARY

CONTRARY TO TS 3.5.B.1, ON APRIL 15, 1986 FROM APPROXIMATELY 1:00 A.M. UNTIL APPROXIMATELY 1:45 A.M., SHUTDOWN COOLING WAS NOT OPERABLE SINCE THE IN SERVICE RHR PUMP DISCHARGE VALVE (1E11-F015B) WAS, UNKNOWN TO THE REACTOR OPERATORS, SHUT DUE TO A BLOWN FUSE. THE FUSE WAS REPLACED ABOUT 1:45 A.M. THE RESET OF AND REOPENING OF VALVE 1E11-F015B AND THEREBY RESUMPTION OF SHUTDOWN COOLING DID NOT OCCUR UNTIL APPROXIMATELY 4:00 A.M. WHEN A PLANT EQUIPMENT OPERATOR CALLED THE CONTROL ROOM TO REPORT THAT THE RUNNING RHR PUMP DID NOT SOUND NORMAL. NO INCREASE IN REACTOR VESSEL TEMPERATURE WAS NOTED DURING THE THREE HOURS OF THIS OCCURRENCE. CONTRARY TO TS 4.7.4.B, ON FEBRUARY 26, 1986, HYDRAULIC SNUBBER 2E11-RHR-R90, WAS FOUND LEAKING AND NOT DECLARED

INSPECTION STATUS - (CONTINUED)

ENFORCEMENT SUMMARY

INOPERABLE AS REQUIRED BY TS 4.7.4.B, AMENDMENT NO. 51. THIS CONDITION WAS ATTRIBUTED TO AN INADEQUATE SNUBBER, INSPECTION AND FUNCTIONAL TEST PROCEDURE 52 SV-SUV-001-2 WHICH THE LICENSEE FAILED TO REVISE FOLLOWING IMPLEMENTATION OF TS AMENDMENT NO. 51. TS AMENDMENT NO. 51 WAS IMPLEMENTED BY THE LICENSEE ON SEPTEMBER 4, 1985, AND CHANGED THE SNUBBER VISUAL INSPECTION CRITERIA. PREVIOUS LICENSEE CORRECTIVE ACTIONS DISCUSSED IN LICENSEE CORRECTIVE ACTIONS DISCUSSED IN LICENSEE EVENT REPORT NUMBERS 50-321/85-28 AND 50-366/85-28 FAILED TO PREVENT THIS TYPE OF RECURRENCE.
(8601 4)

SYSTEMS AND COMPONENT PROBLEMS:

NONE.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

+ NONE.

PLANT STATUS:

NORMAL OPERATION.

LAST IE SITE INSPECTION DATE: JUNE 23-27, 1986 +

INSPECTION REPORT NO: 50-321/86-18 +

Report Period JUL 1986

REPORTS FROM LICENSEE

* HATCH 1 *

```
=====
NUMBER    DATE OF    DATE OF    SUBJECT
          EVENT     REPORT
-----
86-017    04/15/86
          06/20/86    PERSONNEL ERROR CAUSES LOSS OF SHUTDOWN COOLING.
86-018    05/21/86    06/20/86    HIGH TURBINE BUILDING TEMPERATURE CAUSES ESF ACTUATIONS; CAUSE - STEAM LEAK AROUND PACKING OF
          05/23/86    MAIN STEAM LINE DRAIN VALVE.
86-019    04/13/86    05/23/86    DEFECTIVE PROCEDURE COULD PREVENT DIESEL GENERATOR FROM BEING OPERABLE.
86-020    04/25/86    05/23/86    REACTOR WATER CLEANUP SYSTEM'S INBOARD AND OUTBOARD PRIMARY CONTAINMENT ISOLATION VALVES
          06/20/86    ISOLATED ON A "HIGH LEAKAGE FLOW" SIGNAL; CAUSE - JUMPER DISCONNECTED.
86-025    05/22/86    06/20/86    PERSONNEL ERROR DURING TROUBLESHOOTING, BLOWS FUSE RESULTING IN MULTIPLE ESF ACTUATIONS.
86-026    06/05/86    07/07/86    DEFECTIVE PROCEDURE CAUSES NON-COMPLIANCE WITH TECHNICAL SPECIFICATION; CAUSE - DELETED THE STEP
          07/14/86    REQUIRING PERTURBATION OF THE REACTOR WATER LEVEL.
86-027    06/12/86    07/14/86    TWO DRYWELL VENT VALVES FAILED TO PRESSURIZE DURING PERFORMANCE OF SPECIAL PURPOSE LLRT
          PROCEDURE 42SP-061286-OU-1S, 'T' RINGS ON BOTH VALVES REPLACED AND DISCS WERE ADJUSTED.
=====
```

INSPECTION STATUS - (CONTINUED)

```

XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX
X                HATCH 1                X
XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX

```

INOPERABLE AS REQUIRED BY TS 4.7.4.B, AMENDMENT NO. 51. THIS CONDITION WAS ATTRIBUTED TO AN INADEQUATE SNUBBER, INSPECTION AND FUNCTIONAL TEST PROCEDURE 52 SV-SUV-001-2 WHICH THE LICENSEE FAILED TO REVISE FOLLOWING IMPLEMENTATION OF TS AMENDMENT NO. 51. TS AMENDMENT NO. 51 WAS IMPLEMENTED BY THE LICENSEE ON SEPTEMBER 4, 1985, AND CHANGED THE SNUBBER VISUAL INSPECTION CRITERIA. PREVIOUS LICENSEE CORRECTIVE ACTIONS DISCUSSED IN LICENSEE CORRECTIVE ACTIONS DISCUSSED IN LICENSEE EVENT REPORT NUMBERS 50-321/85-28 AND 50-366/85-28 FAILED TO PREVENT THIS TYPE OF RECURRENCE.
(8601 4)

SYSTEMS AND COMPONENT PROBLEMS:

FACILITY ITEMS (PLANS AND PROCEDURES):

MANAGERIAL ITEMS:

PLANT STATUS:

LAST IE SITE INSPECTION DATE: JUNE 23-27, 1986 +

INSPECTION REPORT NO: 50-321/86-18 +

Report Period JUL 1986

REPORTS FROM LICENSEE

* HATCH 1 *

```
=====
NUMBER    DATE OF    DATE OF    SUBJECT
          EVENT      REPORT
-----
86-017    04/15/86          PERSONNEL ERROR CAUSES LOSS OF SHUTDOWN COOLING.
86-018    05/21/86    06/20/86    HIGH TURBINE BUILDING TEMPERATURE CAUSES ESF ACTUATIONS; CAUSE - STEAM LEAK AROUND PACKING OF
          MAIN STEAM LINE DRAIN VALVE.
86-019    04/13/86    05/23/86    DEFECTIVE PROCEDURE COULD PREVENT DIESEL GENERATOR FROM BEING OPERABLE.
86-020    04/25/86    05/23/86    REACTOR WATER CLEANUP SYSTEM'S INBOARD AND OUTBOARD PRIMARY CONTAINMENT ISOLATION VALVES
          ISOLATED ON A "HIGH LEAKAGE FLOW" SIGNAL; CAUSE - JUMPER DISCONNECTED.
86-025    05/22/86    06/20/86    PERSONNEL ERROR DURING TROUBLESHOOTING, BLOWS FUSE RESULTING IN MULTIPLE ESF ACTUATIONS.
86-026    06/05/86    07/07/86    DEFECTIVE PROCEDURE CAUSES NON-COMPLIANCE WITH TECHNICAL SPECIFICATION; CAUSE - DELETED THE STEP
          REQUIRING PERTURBATION OF THE REACTOR WATER LEVEL.
86-027    06/12/86    07/14/86    TWO DRYWELL VENT VALVES FAILED TO PRESSURIZE DURING PERFORMANCE OF SPECIAL PURPOSE LLRT
          PROCEDURE 42SP-061286-OU-1S, 'T' RINGS ON BOTH VALVES REPLACED AND DISCS WERE ADJUSTED.
=====
```


THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-366 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/86 Outage + On-line Hrs: 744.0

3. Utility Contact: T. KILROY (912) 367-7781 X2882

4. Licensed Thermal Power (MWh): 2436

5. Nameplate Rating (Gross MWe): 1000 X 0.85 = 850

6. Design Electrical Rating (Net MWe): 784

7. Maximum Dependable Capacity (Gross MWe): 804

8. Maximum Dependable Capacity (Net MWe): 777

9. If Changes Occur Above Since Last Report, Give Reasons: NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,087.0</u>	<u>60,528.0</u>
13. Hours Reactor Critical	<u>672.3</u>	<u>4,799.9</u>	<u>42,520.6</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>651.0</u>	<u>4,703.4</u>	<u>40,714.1</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,142,516</u>	<u>9,430,716</u>	<u>87,963,963</u>
18. Gross Elec Ener (MWH)	<u>353,870</u>	<u>3,046,180</u>	<u>28,961,170</u>
19. Net Elec Ener (MWH)	<u>334,433</u>	<u>2,897,218</u>	<u>27,567,411</u>
20. Unit Service Factor	<u>87.5</u>	<u>92.5</u>	<u>67.3</u>
21. Unit Avail Factor	<u>87.5</u>	<u>92.5</u>	<u>67.3</u>
22. Unit Cap Factor (MDC Net)	<u>57.9</u>	<u>73.3</u>	<u>58.6</u>
23. Unit Cap Factor (DER Net)	<u>57.3</u>	<u>72.6</u>	<u>58.1</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>4.6</u>	<u>9.2</u>
25. Forced Outage Hours	<u>.0</u>	<u>228.3</u>	<u>4,114.3</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


REFUELING OUTAGE: SEPTEMBER 8, 1986 - 8 WEEKS.

27. If Currently Shutdown Estimated Startup Date: N/A

 * HATCH 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

HATCH 2



JULY 1986

Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

* HATCH 2 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
86-045	06/23/86	S	93.0	A	4	028612	CH	XXXXXX	SHUTDOWN TO REPAIR CONDENSER BAY STEAM LEAKS CONTINUES.
86-046	07/04/86	S	0.0	A	5		CH	XXXXX	RAMPING TO 85% POWER FOLLOWING REPAIRS.
86-047	07/10/86	S	0.0	H	5		ZZ	ZZZZZZ	MANAGEMENT DECISION TO HOLD AT 85% POWER DUE TO HIGH OFFGAS ACTIVITY.
86-048	07/12/86	F	0.0	A	5		ZZ	ZZZZZ	RECIRC. FLOW DECREASED MANUALLY AFTER PROCESS COMPUTER PROBLEMS.
86-049	07/13/86	S	0.0	B	5		HA	VALVEX	REDUCED LOAD FOR STOP VALVE TESTING.
86-050	07/14/86	S	0.0	H	5		ZZ	ZZZZZZ	MANAGEMENT DECISION TO HOLD AT 85% POWER DUE TO HIGH OFFGAS ACTIVITY.
86-051	07/18/86	F	0.0	A	5		HH	PUMPXX	"2B" CONDENSATE PUMP TRIP.
86-052	07/19/86	S	0.0	H	5		ZZ	ZZZZZZ	MANAGEMENT DECISION TO HOLD AT 85% POWER DUE TO HIGH OFFGAS ACTIVITY.
86-053	07/22/86	F	0.0	A	5		CB	PUMPXX	"2B" CIRCULATING WATER PUMP BEARING FAILURE.

* SUMMARY *

HATCH 2 RETURNED ONLINE JULY 5TH FROM AN EQUIPMENT REPAIR OUTAGE AND OPERATED WITH
8 REDUCTIONS LISTED IN DETAIL ABOVE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* HATCH 2 *

FACILITY DATA

Report Period JUL 1986

FACILITY DESCRIPTION

LOCATION
STATE.....GEORGIA
COUNTY.....APPLING
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...11 MI N OF
BAXLEY, GA
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...JULY 4, 1978
DATE ELEC ENER 1ST GENER...SEPTEMBER 22, 1978
DATE COMMERCIAL OPERATE...SEPTEMBER 5, 1979
CONDENSER COOLING METHOD...COOLING TOWER
CONDENSER COOLING WATER...ALTAMAHA RIVER
ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....GEORGIA POWER
CORPORATE ADDRESS.....333 PIEDMONT AVENUE
ATLANTA, GEORGIA 30308
CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....GEORGIA POWER CO.
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
IE RESIDENT INSPECTOR.....P. HOLMES RAY
LICENSING PROJ MANAGER.....G. RIVENBARK
DOCKET NUMBER.....50-366
LICENSE & DATE ISSUANCE...NPF-5, JUNE 13, 1978
PUBLIC DOCUMENT ROOM.....APPLING COUNTY PUBLIC LIBRARY
301 CITY HALL DRIVE
BAXLEY, GEORGIA 31563

INSPECTION STATUS

INSPECTION SUMMARY

+ INSPECTION MAY 31 - JUNE 30 (86-17): THIS ROUTINE INSPECTION WAS CONDUCTED AT THE SITE IN THE AREAS OF LICENSEE ACTION ON PREVIOUS ENFORCEMENT MATTERS, OPERATIONAL SAFETY VERIFICATION, MAINTENANCE OBSERVATION, PLANT MODIFICATION AND SURVEILLANCE OBSERVATION, AND REPORTABLE OCCURRENCES. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JUNE 23-27 (86-18): THIS ROUTINE, UNANNOUNCED INSPECTION INVOLVED A REVIEW OF THE LICENSEE'S HEALTH PHYSICS PROGRAM, INCLUDING ORGANIZATION AND MANAGEMENT CONTROLS, INTERNAL EXPOSURE, EXTERNAL EXPOSURE CONTROL, CONTROL AND PERSONAL DOSIMETRY, THE LICENSEE'S PROGRAM TO MAINTAIN EXPOSURES AS LOW AS REASONABLY ACHIEVABLE (ALARA), AND THE CONTROL OF MATERIALS RELEASED FROM THE RCA. ONE VIOLATION - INADEQUATE RELEASE SURVEYS OF MATERIALS FOR UNRESTRICTED USE.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE.

FACILITY ITEMS (PLANS AND PROCEDURES):

MANAGERIAL ITEMS:

+ NONE.

PLANT STATUS:

+ UNIT IS OPERATING AT REDUCED POWER.

LAST IE SITE INSPECTION DATE: JUNE 23-27, 1986 +

INSPECTION REPORT NO: 50-366/86-18 +

REPORTS FROM LICENSEE

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
86-011	04/25/86	05/23/86	COMPONENT FAILURES PREVENT 4 HOUR GRAB SAMPLING; DUE TO A BLOWN POWER FUSE TO THE VACUUM PUMP DRIVE MOTOR.

1. Docket: 50-247 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/86 Outage + On-line Hrs: 744.0

3. Utility Contact: K. KRIEGER (914) 526-5155

4. Licensed Thermal Power (MWt): 2758

5. Nameplate Rating (Gross MWe): 1126 X 0.9 = 1013

6. Design Electrical Rating (Net MWe): 873

7. Maximum Dependable Capacity (Gross MWe): 885

8. Maximum Dependable Capacity (Net MWe): 849

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):


11. Reasons for Restrictions, If Any:
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,087.0</u>	<u>105,936.0</u>
13. Hours Reactor Critical	<u>726.2</u>	<u>1,690.0</u>	<u>70,860.1</u>
14. Rx Reserve Shtdwn Hrs	<u>17.7</u>	<u>214.3</u>	<u>2,711.9</u>
15. Hrs Generator On-Line	<u>695.6</u>	<u>1,552.6</u>	<u>68,689.1</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,894,314</u>	<u>3,907,943</u>	<u>178,742,150</u>
18. Gross Elec Ener (MWH)	<u>589,870</u>	<u>1,208,970</u>	<u>55,459,446</u>
19. Net Elec Ener (MWH)	<u>566,135</u>	<u>1,125,016</u>	<u>52,303,874</u>
20. Unit Service Factor	<u>93.5</u>	<u>30.5</u>	<u>64.8</u>
21. Unit Avail Factor	<u>93.5</u>	<u>30.5</u>	<u>64.8</u>
22. Unit Cap Factor (MDC Net)	<u>89.6</u>	<u>25.9</u>	<u>58.2*</u>
23. Unit Cap Factor (DER Net)	<u>87.2</u>	<u>25.3</u>	<u>56.6</u>
24. Unit Forced Outage Rate	<u>6.5</u>	<u>18.9</u>	<u>9.4</u>
25. Forced Outage Hours	<u>48.4</u>	<u>361.6</u>	<u>6,835.4</u>
26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration): <u>NONE</u>			
27. If Currently Shutdown Estimated Startup Date: <u>N/A</u>			

 * INDIAN POINT 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

INDIAN POINT 2



JULY 1986

* Item calculated with a Weighted Average

Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

 * INDIAN POINT 2 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
7	07/07/86	F	0.0		5		CH	PUMPXX	22 MBFP REPAIR.
8	07/18/86	F	48.4	G	3	86-024	EG	GENERA	MG SET OPERATOR ERROR/DISCIPLINARY ACTION TAKEN.

 * SUMMARY *

 INDIAN POINT 2 - OPERATED WITH 1 OUTAGE AND 1 REDUCTION DURING JULY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* INDIAN POINT 2 *

F A C I L I T Y D A T A

Report Period JUL 1986

FACILITY DESCRIPTION

LOCATION
STATE.....NEW YORK
COUNTY.....WESTCHESTER
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...25 MI N OF
NEW YORK CITY, NY
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...MAY 22, 1973
DATE ELEC ENER 1ST GENER...JUNE 26, 1973
DATE COMMERCIAL OPERATE...AUGUST 1, 1974
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...HUDSON RIVER
ELECTRIC RELIABILITY
COUNCIL.....NORTHEAST POWER
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....CONSOLIDATED EDISON
CORPORATE ADDRESS.....4 IRVING PLACE
NEW YORK, NEW YORK 10003
CONTRACTOR
ARCHITECT/ENGINEER.....UNITED ENG. & CONSTRUCTORS
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....WESTINGHOUSE DEVELOPMENT CORP
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I
IE RESIDENT INSPECTOR.....L. ROSSBACH
LICENSING PROJ MANAGER....M. SLOSSON
DOCKET NUMBER.....50-247
LICENSE & DATE ISSUANCE...DPR-26, SEPTEMBER 28, 1973
PUBLIC DOCUMENT ROOM.....WHITE PLAINS PUBLIC LIBRARY
100 MARTINE AVENUE
WHITE PLAINS, NEW YORK 10601

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

TECHNICAL SPECIFICATION 6.9.1.3 REQUIRES THAT THE ANNUAL RADIATION EXPOSURE REPORT BE SUBMITTED NO LATER THAN MARCH 1 OF EACH YEAR. TECHNICAL SPECIFICATION 3.13.A.3 REQUIRES THAT A TELEPHONE NOTIFICATION BE MADE TO REGION I WITHIN 24 HOURS OF IDENTIFYING THAT THE FIRE PROTECTION SYSTEM IS INOPERABLE. CONTRARY TO THE ABOVE, IN APRIL 1986, THE INSPECTOR IDENTIFIED THE FOLLOWING: (A) THE ANNUAL RADIATION EXPOSURE REPORT WAS SUBMITTED ON MARCH 31, 1986. (B) THE FIRE PROTECTION SYSTEM BECAME INOPERABLE ON MARCH 28, 1986, BUT THE TELEPHONE NOTIFICATION TO REGION I WAS NOT MADE UNTIL MARCH 31, 1986.
(8601 5)

OTHER ITEMS

SYSTEMS AND COMPONENTS:

Report Period JUL 1986

I N S P E C T I O N S T A T U S - (CONTINUED)

* INDIAN POINT 2 *

OTHER ITEMS

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S F R O M L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
--------	------------------	-------------------	---------

NO INPUT PROVIDED.

=====

1. Docket: 50-286 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/86 Outage + On-line Hrs: 744.0

3. Utility Contact: L. KELLY (914) 739-8200

4. Licensed Thermal Power (MWt): 3025

5. Nameplate Rating (Gross MWe): 1126 X 0.9 = 1013

6. Design Electrical Rating (Net MWe): 965

7. Maximum Dependable Capacity (Gross MWe): 1000

8. Maximum Dependable Capacity (Net MWe): 965

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe): 515

11. Reasons for Restrictions, If Any: _____
#32 MAIN TRANSFORMER IS OUT OF SERVICE.

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,087.0</u>	<u>86,952.0</u>
13. Hours Reactor Critical	<u>135.3</u>	<u>3,788.5</u>	<u>51,055.7</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>110.0</u>	<u>3,696.4</u>	<u>49,330.0</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>181,463</u>	<u>9,823,102</u>	<u>128,545,066</u>
18. Gross Elec Ener (MWH)	<u>52,400</u>	<u>3,212,310</u>	<u>40,816,696</u>
19. Net Elec Ener (MWH)	<u>48,957</u>	<u>3,091,473</u>	<u>39,105,864</u>
20. Unit Service Factor	<u>14.8</u>	<u>72.7</u>	<u>56.7</u>
21. Unit Avail Factor	<u>14.8</u>	<u>72.7</u>	<u>56.7</u>
22. Unit Cap Factor (MDC Net)	<u>6.8</u>	<u>63.0</u>	<u>46.6</u>
23. Unit Cap Factor (DER Net)	<u>6.8</u>	<u>63.0</u>	<u>46.6</u>
24. Unit Forced Outage Rate	<u>85.2</u>	<u>18.0</u>	<u>19.6</u>
25. Forced Outage Hours	<u>634.0</u>	<u>812.5</u>	<u>12,005.5</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):

NONE

27. If Currently Shutdown Estimated Startup Date: 09/15/86

 * INDIAN POINT 3 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
 INDIAN POINT 3



JULY 1986

Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

 * INDIAN POINT 3 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
09	07/05/86	F	634.0	A	1		HC	XXXXXX	THE PLANT WAS REMOVED FROM SERVICE BECAUSE OF DECREASING CONDENSER VACUUM. THE DECREASING CONDENSER VACUUM WAS CAUSED BY A LEAKING FLEXIBLE EXPANSION JOINT BETWEEN LOW PRESSURE TURBINE 33 AND ITS ASSOCIATED MAIN CONDENSER 31.

 * SUMMARY *

 INDIAN POINT 3 SHUTDOWN ON JULY 5TH FOR EQUIPMENT REPAIRS.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* INDIAN POINT 3 *

FACILITY DATA

Report Period JUL 1986

FACILITY DESCRIPTION

LOCATION
STATE.....NEW YORK
COUNTY.....WESTCHESTER
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...25 MI N OF
NEW YORK CITY, NY
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...APRIL 6, 1976
DATE ELEC ENER 1ST GENER...APRIL 27, 1976
DATE COMMERCIAL OPERATE...AUGUST 30, 1976
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...HUDSON RIVER
ELECTRIC RELIABILITY
COUNCIL.....NORTHEAST POWER
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....NEW YORK POWER AUTHORITY
CORPORATE ADDRESS.....10 COLUMBUS CIRCLE
NEW YORK, NEW YORK 10019
CONTRACTOR
ARCHITECT/ENGINEER.....UNITED ENG. & CONSTRUCTORS
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....WESTINGHOUSE DEVELOPMENT CORP
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I
IE RESIDENT INSPECTOR.....P. KOLTAY
LICENSING PROJ MANAGER.....D. NEIGHBORS
DOCKET NUMBER.....50-286
LICENSE & DATE ISSUANCE....DPR-64, APRIL 5, 1976
PUBLIC DOCUMENT ROOM.....WHITE PLAINS PUBLIC LIBRARY
100 MARTINE AVENUE
WHITE PLAINS, NEW YORK 10601

INSPECTION STATUS

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

Report Period JUL 1986

I N S P E C T I O N S T A T U S - (CONTINUED)

* INDIAN POINT 3 *

OTHER ITEMS

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S F R O M L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
--------	------------------	-------------------	---------

NO INPUT PROVIDED.

=====

1. Docket: 50-305 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/86 Outage + On-line Hrs: 744.0

3. Utility Contact: G.RUITER (414) 388-2560 X207

4. Licensed Thermal Power (MWt): 1650

5. Nameplate Rating (Gross MWe): 622 X 0.9 = 560

6. Design Electrical Rating (Net MWe): 535

7. Maximum Dependable Capacity (Gross MWe): 529

8. Maximum Dependable Capacity (Net MWe): 503

9. If Changes Occur Above Since Last Report, Give Reasons: NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,087.0</u>	<u>106,296.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>3,911.3</u>	<u>89,928.4</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>2,330.5</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>3,842.2</u>	<u>88,397.8</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>10.0</u>
17. Gross Therm Ener (MWH)	<u>1,218,187</u>	<u>6,139,763</u>	<u>138,847,496</u>
18. Gross Elec Ener (MWH)	<u>405,600</u>	<u>2,056,100</u>	<u>45,794,600</u>
19. Net Elec Ener (MWH)	<u>386,122</u>	<u>1,960,101</u>	<u>43,601,313</u>
20. Unit Service Factor	<u>100.0</u>	<u>75.5</u>	<u>83.2</u>
21. Unit Avail Factor	<u>100.0</u>	<u>75.5</u>	<u>83.2</u>
22. Unit Cap Factor (MDC Net)	<u>103.2</u>	<u>76.6</u>	<u>79.3*</u>
23. Unit Cap Factor (DER Net)	<u>97.0</u>	<u>72.0</u>	<u>76.7</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.7</u>	<u>3.2</u>
25. Forced Outage Hours	<u>.0</u>	<u>28.5</u>	<u>2,819.9</u>
26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):	<u>NONE</u>		

27. If Currently Shutdown Estimated Startup Date: N/A

* KEWAUNEE *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

KEWAUNEE



JULY 1986

* Item calculated with a Weighted Average

PAGE 2-174

Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

* KEWAUNEE *

No.	Date	Type	Hours	Reason	Method	LER Number	System Component	Cause & Corrective Action to Prevent Recurrence
-----	------	------	-------	--------	--------	------------	------------------	---

NONE

* SUMMARY *

KEWAUNEE OPERATED AT FULL POWER DURING THE JULY REPORT PERIOD.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* Kewaunee *

FACILITY DATA

Report Period JUL 1986

FACILITY DESCRIPTION

LOCATION
STATE.....WISCONSIN

COUNTY.....KEWAUNEE

DIST AND DIRECTION FROM
NEAREST POPULATION CTR...27 MI E OF
GREEN BAY, WI.

TYPE OF REACTOR.....PWR

DATE INITIAL CRITICALITY...MARCH 7, 1974

DATE ELEC ENER 1ST GENER...APRIL 8, 1974

DATE COMMERCIAL OPERATE....JUNE 16, 1974

CONDENSER COOLING METHOD...ONCE THRU

CONDENSER COOLING WATER....LAKE MICHIGAN

ELECTRIC RELIABILITY
COUNCIL.....MID-AMERICA
INTERPOOL NETWORK

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....WISCONSIN PUBLIC SERVICE

CORPORATE ADDRESS.....P.O. BOX 19002
GREEN BAY, WISCONSIN 54307

CONTRACTOR
ARCHITECT/ENGINEER.....PIONEER SERVICES & ENGINEERING

NUC STEAM SYS SUPPLIER...WESTINGHOUSE

CONSTRUCTOR.....PIONEER SERVICES & ENGINEERING

TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III

IE RESIDENT INSPECTOR.....R. NELSON

LICENSING PROJ MANAGER....M. FAIRTILE
DOCKET NUMBER.....50-305

LICENSE & DATE ISSUANCE....DPR-43, DECEMBER 21, 1973

PUBLIC DOCUMENT ROOM.....UNIVERSITY OF WISCONSIN
LIBRARY LEARNING CENTER
2420 NICOLET DRIVE
GREEN BAY, WISCONSIN 54301

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

NONE

ENFORCEMENT SUMMARY

10 CFR, PART 50, APPENDIX B, CRITERION V, "INSTRUCTIONS, PROCEDURES, AND DRAWINGS" STATES, IN PART; "ACTIVITIES AFFECTING QUALITY SHALL BE PRESCRIBED BY DOCUMENTED INSTRUCTIONS, PROCEDURES, OR DRAWINGS, OF A TYPE APPROPRIATE TO THE CIRCUMSTANCES AND SHALL BE ACCOMPLISHED IN ACCORDANCE WITH THESE INSTRUCTIONS, PROCEDURES, OR DRAWINGS." THIS CRITERION IS IMPLEMENTED BY THE LICENSEE'S OPERATIONAL QUALITY ASSURANCE PROGRAM, SECTION 12, "PLANT PROCEDURES." CONTRARY TO THE ABOVE, ACTIVITIES WERE NOT ACCOMPLISHED IN ACCORDANCE WITH APPROVED SURVEILLANCE PROCEDURES (SP) ON TWO IDENTIFIED OCCASIONS: ON APRIL 24, 1986, WITH THE PLANT AT 63% POWER, WHILE PERFORMING SP 06-033, "STEAM GENERATOR FLOW MISMATCH INSTRUMENT CHANNEL TEST," THE CONTROL ROOM OPERATOR DID NOT PLACE THE STEAM GENERATOR LEVEL LOOP B CONTROLLER IN THE MANUAL MODE PRIOR TO SHIFTING CONTROLLING CHANNELS, AS REQUIRED BY PROCEDURE STEP 6.7.A. A PLANT TRIP WAS EXPERIENCED DURING THE PERFORMANCE OF THIS PROCEDURE. ON MAY 13, 1986, WITH THE PLANT AT 100% POWER, WHILE PERFORMING SP 48-003D, "NUCLEAR POWER RANGE N-44 INSTRUMENT CHANNEL TEST", A TEST SIGNAL WAS MISTAKENLY APPLIED TO NUCLEAR POWER RANGE CHANNEL N-43, CAUSING A PLANT TRIP. CRITERION V, APPENDIX B, 10 CFR 50 REQUIRES ACTIVITIES AFFECTING QUALITY TO BE PRESCRIBED BY AND ACCOMPLISHED IN ACCORDANCE WITH PROCEDURES OF A TYPE APPROPRIATE TO THE CIRCUMSTANCES. THE LICENSEE'S QUALITY ASSURANCE PROGRAM SECTION V.B.2 REQUIRES THAT APPLICABLE DEPARTMENTS SHALL BE RESPONSIBLE FOR THE

Report Period JUL 1986

INSPECTION STATUS - (CONTINUED)

* Kewaunee *

ENFORCEMENT SUMMARY

PREPARATION, REVIEW AND IMPLEMENTATION OF ALL INSTRUCTIONS AND PROCEDURES AFFECTING QUALITY. CONTRARY TO THE ABOVE, AS OF MARCH 14, 19 86, QUALITY-AFFECTING ACTIVITIES, RELATING TO THE SURVEYS OF SAFETY RELATED MASONRY WALLS THAT WERE CONDUCTED IN RESPONSE TO IE BULLETIN 80-11, WERE NOT PERFORMED UTILIZING CONTROLLED PROCEDURES AND INSTRUCTIONS.
(8600 4)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

UNIT OPERATING NORMALLY

LAST IE SITE INSPECTION DATE: 08/07/86

INSPECTION REPORT NO: 86006

REPORTS FROM LICENSEE

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT

NONE			
=====			

1. Docket: 50-409 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/86 Outage + On-line Hrs: 744.0

3. Utility Contact: LOREE MALIN (608) 689-2331

4. Licensed Thermal Power (MWt): 165

5. Nameplate Rating (Gross MWe): 76.8 X 0.85 = 65

6. Design Electrical Rating (Net MWe): 50

7. Maximum Dependable Capacity (Gross MWe): 50

8. Maximum Dependable Capacity (Net MWe): 48

9. If Changes Occur Above Since Last Report, Give Reasons: NONE

10. Power Level To Which Restricted, If Any (Net MWe):


11. Reasons for Restrictions, If Any: NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,087.0</u>	<u>146,810.0</u>
13. Hours Reactor Critical	<u>358.8</u>	<u>2,866.1</u>	<u>98,804.7</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>478.0</u>
15. Hrs Generator On-Line	<u>348.3</u>	<u>2,591.2</u>	<u>92,092.4</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>79.0</u>
17. Gross Therm Ener (MWH)	<u>51,138</u>	<u>358,594</u>	<u>12,817,541</u>
18. Gross Elec Ener (MWH)	<u>15,543</u>	<u>109,788</u>	<u>3,848,997</u>
19. Net Elec Ener (MWH)	<u>14,266</u>	<u>100,926</u>	<u>3,569,674</u>
20. Unit Service Factor	<u>46.8</u>	<u>50.9</u>	<u>62.7</u>
21. Unit Avail Factor	<u>46.8</u>	<u>50.9</u>	<u>62.8</u>
22. Unit Cap Factor (MDC Net)	<u>39.9</u>	<u>41.3</u>	<u>50.7</u>
23. Unit Cap Factor (DER Net)	<u>38.3</u>	<u>39.7</u>	<u>48.6</u>
24. Unit Forced Outage Rate	<u>53.2</u>	<u>24.3</u>	<u>10.2</u>
25. Forced Outage Hours	<u>395.7</u>	<u>832.5</u>	<u>9,428.2</u>
26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):	<u>NONE</u>		

27. If Currently Shutdown Estimated Startup Date: 09/01/86

* LA CROSSE *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
LA CROSSE



JULY 1986

Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

 * LA CROSSE *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
86-20	07/08/86	F	35.2	A	3	86-20	RB	CRDRVE	REACTOR AUTOMATICALLY SHUT DOWN WHEN A SOLENOID ON CONTROL ROD DRIVE MECHANISM (CRDM) NO. 12 FAILED. OPENING OF THE SOLENOID RESULTED IN LOW GAS PRESSURE FOR THAT CRDM, WHICH IS A SCRAM SIGNAL.
86-21	07/16/86	F	360.5	A	3	86-21	ED	GENERA	REACTOR AUTOMATICALLY SHUT DOWN WHEN THE 1A STATIC INVERTER TRANSFERRED TO ITS ALTERNATE SOURCE, MOMENTARILY DE-ENERGIZING A SCRAM TRAIN. EXTENSIVE TROUBLESHOOTING HAS BEEN CONDUCTED ON THE CAUSE OF THE INVERTER TRANSFER.

 * SUMMARY *

 LA CROSSE OPERATED WITH 2 OUTAGES DURING JULY, SHUTTING DOWN ON THE 16TH FOR EQUIPMENT REPAIRS.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* LA CROSSE *

F A C I L I T Y D A T A

Report Period JUL 1986

FACILITY DESCRIPTION

LOCATION
STATE.....WISCONSIN
COUNTY.....VERNON
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...19 MI S OF
LACROSSE, WISC
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...JULY 11, 1967
DATE ELEC ENER 1ST GENER...APRIL 26, 1968
DATE COMMERCIAL OPERATE...NOVEMBER 1, 1969
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...MISSISSIPPI RIVER
ELECTRIC RELIABILITY
COUNCIL.....MID-CONTINENT AREA
RELIABILITY COORDINATION
AGREEMENT

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....DAIRYLAND POWER
CORPORATE ADDRESS.....2615 EAST AVENUE SOUTH
LACROSSE, WISCONSIN 54601
CONTRACTOR
ARCHITECT/ENGINEER.....SARGENT & LUNDY
NUC STEAM SYS SUPPLIER...ALLIS-CHALMERS
CONSTRUCTOR.....MAXON CONSTRUCTION COMPANY
TURBINE SUPPLIER.....ALLIS-CHALMERS

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III
IE RESIDENT INSPECTOR.....I. VILLALVA
LICENSING PROJ MANAGER.....R. BEVAN
DOCKET NUMBER.....50-409
LICENSE & DATE ISSUANCE...DPR-45, AUGUST 28, 1973
PUBLIC DOCUMENT ROOM.....LA CROSSE PUBLIC LIBRARY
800 MAIN STREET
LA CROSSE, WISCONSIN 54601

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

NONE

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

Report Period JUL 1986

I N S P E C T I O N S T A T U S - (CONTINUED)

* LA CROSSE *

OTHER ITEMS

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

PLANT SHUTDOWN ON 07/16/86, DISCOVERED THRU-WALL LEAKS ON DECAY HEAT REMOVAL PIPING. PIPE REPLACEMENT IN PROGRESS. START-UP EXPECTED DURING LAST WEEK OF AUGUST 1986.

LAST IE SITE INSPECTION DATE: 08/30/86

INSPECTION REPORT NO: 86010

R E P O R T S F R O M L I C E N S E E

```
=====
NUMBER    DATE OF    DATE OF    SUBJECT
          EVENT    REPORT
-----
86-18     06/22/86   07/18/86   REACTOR SCRAM DUE TO RELAY MALFUNCTION/ LINE SEPARATION AT REACTOR WATER LEVEL TRANSMITTER
86-19     06/27/86   07/21/86   REACTOR SCRAM ON HIGH POWER/FLOW DUE TO REACTOR FEED PUMP MALFUNCTION
=====
```


1. Docket: 50-373 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/86 Outage + On-line Hrs: 744.0

3. Utility Contact: JAMES P. PETERS (815) 357-6761

4. Licensed Thermal Power (MWt): 3323

5. Nameplate Rating (Gross MWe): 1078

6. Design Electrical Rating (Net MWe): 1078

7. Maximum Dependable Capacity (Gross MWe): 1078

8. Maximum Dependable Capacity (Net MWe): 1036

9. If Changes Occur Above Since Last Report, Give Reasons: NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,087.0</u>	<u>22,631.0</u>
13. Hours Reactor Critical	<u>.0</u>	<u>.0</u>	<u>12,037.5</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>1,640.9</u>
15. Hrs Generator On-Line	<u>.0</u>	<u>.0</u>	<u>11,639.9</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>1.0</u>
17. Gross Therm Ener (MWH)	<u>0</u>	<u>0</u>	<u>38,349,668</u>
18. Gross Elec Ener (MWH)	<u>0</u>	<u>0</u>	<u>10,499,394</u>
19. Net Elec Ener (MWH)	<u>-11,191</u>	<u>-69,983</u>	<u>9,945,621</u>
20. Unit Service Factor	<u>.0</u>	<u>.0</u>	<u>51.4</u>
21. Unit Avail Factor	<u>.0</u>	<u>.0</u>	<u>51.4</u>
22. Unit Cap Factor (MDC Net)	<u>.0</u>	<u>.0</u>	<u>42.4</u>
23. Unit Cap Factor (DER Net)	<u>.0</u>	<u>.0</u>	<u>40.8</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.0</u>	<u>17.4</u>
25. Forced Outage Hours	<u>.0</u>	<u>.0</u>	<u>2,458.4</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


NONE

27. If Currently Shutdown Estimated Startup Date: 09/15/86

* LASALLE 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

LASALLE 1



JULY 1986

Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

 * LASALLE 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
18	10/19/85	S	744.0	C	4				REFUELING CONTINUES.

 * SUMMARY *

LASALLE 1 REMAINS SHUTDOWN FOR REFUELING.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	1-Manual
S-Sched	B-Maint or Test	G-Oper Error	2-Manual Scram
	C-Refueling	H-Other	3-Auto Scram
	D-Regulatory Restriction		4-Continued
	E-Operator Training		5-Reduced Load
	& License Examination		9-Other
			Exhibit F & H
			Instructions for
			Preparation of
			Data Entry Sheet
			Licensee Event Report
			(LER) File (NUREG-0161)

* LASALLE 1 *

F A C I L I T Y D A T A

Report Period JUL 1986

FACILITY DESCRIPTION

LOCATION
STATE.....ILLINOIS
COUNTY.....LA SALLE
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...11 MI SE OF
OTTAWA, ILL
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...JUNE 21, 1982
DATE ELEC ENER 1ST GENER...SEPTEMBER 4, 1982
DATE COMMERCIAL OPERATE....JANUARY 1, 1984
CONDENSER COOLING METHOD...POND
CONDENSER COOLING WATER....RESERVOIR
ELECTRIC RELIABILITY
COUNCIL.....MID-AMERICA
INTERPOOL NETWORK

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....COMMONWEALTH EDISON
CORPORATE ADDRESS.....P.O. BOX 767
CHICAGO, ILLINOIS 60690
CONTRACTOR
ARCHITECT/ENGINEER.....SARGENT & LUNDY
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....COMMONWEALTH EDISON
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III
IE RESIDENT INSPECTOR.....M. JORDAN
LICENSING PROJ MANAGER.....A. BOURNIA
DOCKET NUMBER.....50-373
LICENSE & DATE ISSUANCE....NPF-11, AUGUST 13, 1982
PUBLIC DOCUMENT ROOM.....ILLINOIS VALLEY COMMUNITY COLLEGE
RURAL ROUTE NO. 1
OGLESBY, ILLINOIS 16348

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION ON OCTOBER 23-24, NOVEMBER 5, DECEMBER 10-12, 1985, AND JANUARY 14-16, 29-30, FEBRUARY 12-13, MARCH 5-6, AND 13-14, 1986 (85035; 85036): ROUTINE UNANNOUNCED INSPECTION OF LICENSEE ACTION ON OPEN ITEMS, INSERVICE INSPECTION ACTIVITIES, IMPLEMENTATION OF ACTIONS SET FORTH IN NRC GENERIC LETTERS 84-11, AND ACTIVITIES RELATED TO INDUCTION HEATING STRESS IMPROVEMENT (IHSI). NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION BETWEEN MARCH 24 - JUNE 16 (86020; 86019): INCLUDED INSPECTION OF ALLEGATIONS PERTAINING TO OFF DUTY DRUG AND ALCOHOL USE BY CONTRACTOR PERSONNEL, AND INADEQUATE SECURITY SCREENING PROCEDURES FOR CONTRACTOR PERSONNEL. THE LICENSEE WAS FOUND TO BE IN COMPLIANCE WITH NRC REQUIREMENTS WITHIN THE AREAS EXAMINED. AN ALLEGATION PERTAINING TO EXCESSIVE CONSUMPTION OF ALCOHOL BY CERTAIN CRAFT PERSONNEL PRIOR TO REPORTING TO WORK HAS BEEN FORWARDED TO THE LICENSEE FOR ACTION. NRC REGION III WILL REVIEW THE INVESTIGATION RESULTS.

INSPECTION ON JUNE 3 - JULY 3 (86022): ROUTINE, ANNOUNCED INSPECTION BY TWO REGIONAL INSPECTORS OF CONTAINMENT INTEGRATED LEAK RATE TEST (CILRT); CILRT PERFORMANCE WITNESSING; LOCAL LEAK RATE AND TEST RESULTS; AS-FOUND CILRT RESULTS; ACTION ON A PREVIOUS INSPECTION FINDING; AND LICENSEE EVENT REPORT FOLLOWUP. NRC INSPECTION MODULES UTILIZED DURING THIS INSPECTION INCLUDE 70307, 70313, 70323, 61720, AND 92701. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION ON MAY 27-30 AND JUNE 2-3 (86023; 86022): ROUTINE UNANNOUNCED INSPECTION OF THE SOLID RADWASTE MANAGEMENT AND TRANSPORTATION PROGRAMS. ALSO REVIEWED WERE CORRECTIVE ACTIONS FOR PAST INSPECTION FINDINGS, OPEN ITEMS, SELECTED IE INFORMATION NOTICES, AN AIRBORNE RADIOACTIVE MATERIALS OCCURRENCE, AND A REVIEW OF PROGRESS MADE CONCERNING THE RADIATION PROTECTION

Report Period JUL 1986

INSPECTION STATUS - (CONTINUED)

* LASALLE 1 *

INSPECTION SUMMARY

IMPROVEMENT PROGRAM. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION ON JUNE 18-19 AND 23-24 1986 (86026; 86027): ROUTINE, UNANNOUNCED INSPECTION OF GASEOUS AND LIQUID RADIOACTIVE EFFLUENTS INCLUDING: EFFLUENT RELEASES; RECORDS AND REPORTS OF EFFLUENTS; EFFLUENT CONTROL INSTRUMENTATION, REACTOR COOLANT CHEMISTRY AND ACTIVITY; AND GASEOUS EFFLUENT FILTRATION. ONE VIOLATION INVOLVING FAILURE TO ANALYZE FOR TRITIUM IN MONTHLY COMPOSITE SAMPLES FROM COOLING LAKE BLOWDOWN BETWEEN JUNE 18, 1985 AND MARCH 1, 1986.

INSPECTION ON JULY 2 (86027; 86028): ROUTINE UNANNOUNCED INSPECTION OF THE RESOLUTION OF AN IE BULLETIN. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

SHUT DOWN FOR ITS FIRST REFUELING ON OCTOBER 18, 1985

LAST IE SITE INSPECTION DATE: 07/01/86

INSPECTION REPORT NO: 86034

Report Period JUL 1986

R E P O R T S F R O M L I C E N S E E

* LASALLE 1 *

```
=====
NUMBER      DATE OF   DATE OF   SUBJECT
            EVENT    REPORT
-----
84-54      09/21/86   07/07/86   RCIC INOPERABLE AND STEAM LINE ISOLATION
85-32      03/28/85   07/15/86   INBOARD FEEDWATER CHECK VALVE LLRT FAILURE
86-21      06/08/86   07/01/86   CONTROL ROOM VENTILATION ACTUATION DUE TO SPURIOUS RADIATION MONITOR TRIP
86-22      06/12/86   07/02/86   SHUTDOWN COOLING ISOLATION DUE TO OPERATOR ERROR (INATTENTION TO DETAIL)
86-23      06/13/86   07/07/86   SECONDARY CONTAINMENT DAMPER ISOLATION DURING RPS BUS TRANSFER PROCEDURE PREPARATION
86-24      04/22/86   07/30/86   SMALL BORE PIPING DESIGN ERROR
86-25      06/25/86   07/22/86   SPURIOUS TRIP OF CONTROL ROOM VENTILATION HI RADIATION MONITOR DUE TO INCOMPLETE STABILIZATION
            FOLLOWING CALIBRATION
86-26      06/23/86   07/22/86   FREQUENCY OF PRIMARY CONTAINMENT AIR LOCK LEAKAGE RATE TEST EXCEEDED
86-27      06/28/86   07/28/86   SPURIOUS AMMONIA DETECTOR TRIP CAUSED BY WARPED CAPSTAN ROLLER
86-28      07/02/86   07/31/86   CONTROL ROOM HVAC SYSTEM "B" AMMONIA DETECTOR TRIP DUE TO BROKEN POWER LEAD
86-29      07/03/86   08/01/86   IRM FUSE DESIGN PROBLEM
86-30      07/04/86   08/04/86   CONTROL ROOM VENTILATION ACTUATION DUE TO SPURIOUS RADIATION MONITOR TRIP
=====
```

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-374 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/86 Outage + On-line Hrs: 744.0

3. Utility Contact: JAMES P. PETERS (815) 357-6761

4. Licensed Thermal Power (MWt): 3323

5. Nameplate Rating (Gross MWe): 1078

6. Design Electrical Rating (Net MWe): 1078

7. Maximum Dependable Capacity (Gross MWe): 1078

8. Maximum Dependable Capacity (Net MWe): 1036

9. If Changes Occur Above Since Last Report, Give Reasons:

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,087.0</u>	<u>15,623.0</u>
13. Hours Reactor Critical	<u>.0</u>	<u>3,213.3</u>	<u>8,602.7</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>29.8</u>	<u>1,716.7</u>
15. Hrs Generator On-Line	<u>.0</u>	<u>3,152.2</u>	<u>8,389.5</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>0</u>	<u>9,148,872</u>	<u>24,657,423</u>
18. Gross Elec Ener (MWH)	<u>0</u>	<u>3,050,559</u>	<u>8,160,628</u>
19. Net Elec Ener (MWH)	<u>-10,758</u>	<u>2,932,374</u>	<u>7,755,389</u>
20. Unit Service Factor	<u>.0</u>	<u>62.0</u>	<u>53.7</u>
21. Unit Avail Factor	<u>.0</u>	<u>62.0</u>	<u>53.7</u>
22. Unit Cap Factor (MDC Net)	<u>.0</u>	<u>55.6</u>	<u>47.9</u>
23. Unit Cap Factor (DER Net)	<u>.0</u>	<u>53.5</u>	<u>46.0</u>
24. Unit Forced Outage Rate	<u>100.0</u>	<u>38.0</u>	<u>31.0</u>
25. Forced Outage Hours	<u>744.0</u>	<u>1,934.8</u>	<u>3,775.5</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


NONE

27. If Currently Shutdown Estimated Startup Date: 08/07/86

 * LASALLE 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

LASALLE 2



JULY 1986

Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

 * LASALLE 2 *

No.	Date	Type	Hours	Reason	Method	LER Number	System Component	Cause & Corrective Action to Prevent Recurrence
23	06/02/86	F	744.0	A	4			STATIC O-RING PROBLEMS.

 * SUMMARY *

LASALLE 2 REMAINS SHUTDOWN FOR EQUIPMENT REPAIRS.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* LASALLE 2 *

FACILITY DATA

Report Period JUL 1986

FACILITY DESCRIPTION

LOCATION
STATE.....ILLINOIS
COUNTY.....LA SALLE
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...11 MI SE OF
OTTAWA, ILL
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...MARCH 10, 1984
DATE ELEC ENER 1ST GENER...APRIL 20, 1984
DATE COMMERCIAL OPERATE...OCTOBER 19, 1984
CONDENSER COOLING METHOD...POND
CONDENSER COOLING WATER...RESERVOIR
ELECTRIC RELIABILITY
COUNCIL.....MID-AMERICA
INTERPOOL NETWORK

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....COMMONWEALTH EDISON
CORPORATE ADDRESS.....P.O. BOX 767
CHICAGO, ILLINOIS 60690
CONTRACTOR
ARCHITECT/ENGINEER.....SARGENT & LUNDY
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....COMMONWEALTH EDISON
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III
IE RESIDENT INSPECTOR.....M. JORDAN
LICENSING PROJ MANAGER.....A. BOURNIA
DOCKET NUMBER.....50-374
LICENSE & DATE ISSUANCE...NPF-18, MARCH 23, 1984
PUBLIC DOCUMENT ROOM.....ILLINOIS VALLEY COMMUNITY COLLEGE
RURAL ROUTE NO. 1
OGLESBY, ILLINOIS 16348

INSPECTION STATUS

INSPECTION SUMMARY

INSPECTION ON OCTOBER 23-24, NOVEMBER 5, DECEMBER 10-12, 1985, AND JANUARY 14-16, 29-30, FEBRUARY 12-13, MARCH 5-6, AND 13-14, 1986 (85035; 85036): ROUTINE UNANNOUNCED INSPECTION OF LICENSEE ACTION ON OPEN ITEMS, INSERVICE INSPECTION ACTIVITIES, IMPLEMENTATION OF ACTIONS SET FORTH IN NRC GENERIC LETTERS 84-11, AND ACTIVITIES RELATED TO INDUCTION HEATING STRESS IMPROVEMENT (IHSI). NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION BETWEEN MARCH 24 - JUNE 16 (86020; 86019): INCLUDED INSPECTION OF ALLEGATIONS PERTAINING TO OFF DUTY DRUG AND ALCOHOL USE BY CONTRACTOR PERSONNEL, AND INADEQUATE SECURITY SCREENING PROCEDURES FOR CONTRACTOR PERSONNEL. THE LICENSEE WAS FOUND TO BE IN COMPLIANCE WITH NRC REQUIREMENTS WITHIN THE AREAS EXAMINED. AN ALLEGATION PERTAINING TO EXCESSIVE CONSUMPTION OF ALCOHOL BY CERTAIN CRAFT PERSONNEL PRIOR TO REPORTING TO WORK HAS BEEN FORWARDED TO THE LICENSEE FOR ACTION. NRC REGION III WILL REVIEW THE INVESTIGATION RESULTS.

INSPECTION ON MAY 27-30 AND JUNE 2-3 (86023; 86022): ROUTINE UNANNOUNCED INSPECTION OF THEHE SOLID RADWASTE MANAGEMENT AND TRANSPORTATION PROGRAMS. ALSO REVIEWED WERE CORRECTIVE ACTIONS FOR PAST INSPECTION FINDINGS, OPEN ITEMS, SELECTED IE INFORMATION NOTICES, AN AIRBORNE RADIOACTIVE MATERIALS OCCURRENCE, AND A REVIEW OF PROGRESS MADE CONCERNING THE RADIATION PROTECTION IMPROVEMENT PROGRAM. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION ON JUNE 18-19 AND 23-24 1986 (86026; 86027): ROUTINE, UNANNOUNCED INSPECTION OF GASEOUS AND LIQUID RADIOACTIVE EFFLUENTS INCLUDING: EFFLUENT RELEASES; RECORDS AND REPORTS OF EFFLUENTS; EFFLUENT CONTROL INSTRUMENTATION, REACTOR COOLANT CHEMISTRY AND ACTIVITY; AND GASEOUS EFFLUENT FILTRATION. ONE VIOLATION INVOLVING FAILURE TO ANALYZE FOR TRITIUM IN MONTHLY

Report Period JUL 1986

I N S P E C T I O N S T A T U S - (CONTINUED)

* LASALLE 2 *

INSPECTION SUMMARY

COMPOSITE SAMPLES FROM COOLING LAKE BLOWDOWN BETWEEN JUNE 18, 1985 AND MARCH 1, 1986.

INSPECTION ON JULY 2 (86027; 86028): ROUTINE UNANNOUNCED INSPECTION OF THE RESOLUTION OF AN IE BULLETIN. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

SHUT DOWN 06/02/86 DUE TO SOR SWITCH PROBLEMS

LAST IE SITE INSPECTION DATE: 07/31/86

INSPECTION REPORT NO: 86035

R E P O R T S F R O M L I C E N S E E

=====			
NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT

84-16	04/23/86	07/21/86	REACTOR WATER CLEANUP HIGH AMBIENT TEMPERATURE ISOLATION
85-48	12/24/86	07/10/86	RCIC WATER LEG PUMP FAILURE
86-11	06/01/86	07/01/86	FAILURE OF LEVEL 3 SCRAM SWITCHES TO OPERATE AT CALIBRATED SETPOINT
86-12	06/20/86	07/16/86	IMPROPER TERMINATIONS AT ENVIRONMENTALLY QUALIFIED EQUIPMENT
=====			

1. Docket: 50-352 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/86 Outage + On-line Hrs: 744.0

3. Utility Contact: BILL ALDEN (215) 841-5022

4. Licensed Thermal Power (Mwt): 3293

5. Nameplate Rating (Gross MWe): 1092

6. Design Electrical Rating (Net MWe): 1055

7. Maximum Dependable Capacity (Gross MWe): 1092

8. Maximum Dependable Capacity (Net MWe): 1055

9. If Changes Occur Above Since Last Report, Give Reasons:

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>4,343.0</u>	<u>4,343.0</u>
13. Hours Reactor Critical	<u>45.3</u>	<u>3,044.0</u>	<u>3,044.0</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>532.7</u>	<u>2,963.0</u>	<u>2,963.0</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,679,930</u>	<u>9,638,998</u>	<u>9,638,998</u>
18. Gross Elec Ener (MWH)	<u>545,730</u>	<u>3,177,130</u>	<u>3,177,130</u>
19. Net Elec Ener (MWH)	<u>521,012</u>	<u>3,044,102</u>	<u>3,044,102</u>
20. Unit Service Factor	<u>71.6</u>	<u>68.2</u>	<u>68.2</u>
21. Unit Avail Factor	<u>71.6</u>	<u>68.2</u>	<u>68.2</u>
22. Unit Cap Factor (MDC Net)	<u>66.4</u>	<u>66.4</u>	<u>66.4</u>
23. Unit Cap Factor (DER Net)	<u>66.4</u>	<u>66.4</u>	<u>66.4</u>
24. Unit Forced Outage Rate	<u>28.4</u>	<u>7.4</u>	<u>7.4</u>
25. Forced Outage Hours	<u>211.3</u>	<u>237.7</u>	<u>237.7</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


NONE

27. If Currently Shutdown Estimated Startup Date: N/A

* LIMERICK 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

LIMERICK 1



JULY 1986

Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

 * LIMERICK 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
1	07/04/86	F	211.3	A	1		CF	VALVEX	INCREASING DRYWELL UNIDENTIFIED LEAKAGE, AS MEASURED BY FLOOR DRAIN FLOW (FI-61-115) AND AIR COOLER DRAIN FLOW (FI-87-120), APPROPRIATE TECH SPEC 3.4.3.2 LIMIT OF 5GPM INITIATED DECISION TO SHUTDOWN. PACKING WAS REPLACED ON 'A' LPCI MANUAL ISOLATION VALVE 51-1F065.
2	07/24/86	S	0.0	H	5		ZZ	ZZZZZZ	POWER REDUCTION FROM 1070MWE TO 700MWE FOR SCHEDULED CONTROL ROD PATTERN ADJUSTMENT.

 * SUMMARY *

 LIMERICK 1 OPERATED WITH 1 OUTAGE AND 1 REDUCTION IN JULY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* LIMERICK 1 *

F A C I L I T Y D A T A

Report Period JUL 1986

FACILITY DESCRIPTION

LOCATION
STATE.....PENNSYLVANIA
COUNTY.....MONTGOMERY
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...21 MI NW OF
PHILADELPHIA, PA
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...DECEMBER 22, 1984
DATE ELEC ENER 1ST GENER...APRIL 13, 1985
DATE COMMERCIAL OPERATE...FEBRUARY 1, 1986
CONDENSER COOLING METHOD...CC HNDCT
CONDENSER COOLING WATER...SCHUYLKILL RIVER
ELECTRIC RELIABILITY
COUNCIL.....MID-ATLANTIC
AREA COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....PHILADELPHIA ELECTRIC
CORPORATE ADDRESS.....2301 MARKET STREET
PHILADELPHIA, PENNSYLVANIA 19105
CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I
IE RESIDENT INSPECTOR.....G. KELLY
LICENSING PROJ MANAGER.....R. MARTIN
DOCKET NUMBER.....50-352
LICENSE & DATE ISSUANCE...NPF-39, AUGUST 8, 1985
PUBLIC DOCUMENT ROOM.....POTTSTOWN PUBLIC LIBRARY
500 HIGH STREET
POTTSTOWN, PENNSYLVANIA 19464

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

INSPECTION STATUS - (CONTINUED)

```

XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX
X          LIMERICK 1              X
XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX

```

MANAGERIAL ITEMS:

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

REPORTS FROM LICENSEE

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
--------	------------------	-------------------	---------

NO INPUT PROVIDED.

1. Docket: 50-309 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/86 Outage + On-line Hrs: 744.0

3. Utility Contact: STEVEN L. JACOBS (207) 623-3521

4. Licensed Thermal Power (Mwt): 2630

5. Nameplate Rating (Gross MWe): 864

6. Design Electrical Rating (Net MWe): 825

7. Maximum Dependable Capacity (Gross MWe): 850

8. Maximum Dependable Capacity (Net MWe): 810

9. If Changes Occur Above Since Last Report, Give Reasons: NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any: NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,087.0</u>	<u>120,323.6</u>
13. Hours Reactor Critical	<u>320.0</u>	<u>4,169.7</u>	<u>96,507.1</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>304.3</u>	<u>4,084.9</u>	<u>93,633.6</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>724,170</u>	<u>9,972,953</u>	<u>211,973,637</u>
18. Gross Elec Ener (MWH)	<u>240,350</u>	<u>3,352,660</u>	<u>69,592,380</u>
19. Net Elec Ener (MWH)	<u>232,241</u>	<u>3,233,728</u>	<u>66,424,020</u>
20. Unit Service Factor	<u>40.9</u>	<u>80.3</u>	<u>77.8</u>
21. Unit Avail Factor	<u>40.9</u>	<u>80.3</u>	<u>77.8</u>
22. Unit Cap Factor (MDC Net)	<u>38.5</u>	<u>78.5</u>	<u>69.9*</u>
23. Unit Cap Factor (DER Net)	<u>37.8</u>	<u>77.1</u>	<u>68.1*</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>11.4</u>	<u>7.1</u>
25. Forced Outage Hours	<u>.0</u>	<u>523.5</u>	<u>6,296.0</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration): NONE

27. If Currently Shutdown Estimated Startup Date: N/A

 * MAINE YANKEE *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
 MAINE YANKEE



JULY 1986

* Item calculated with a Weighted Average

Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

* MAINE YANKEE *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
86-9	06/30/86	S	439.7	B	4		CD	VALVEX	MAINTENANCE OUTAGE TO REPAIR EFCV AIR CYLINDERS AND TO INSPECT CONDENSER. INSTALLED NEW TYPE RUPTURE DISK ASSEMBLY IN EFCV AIR CYLINDERS. INSPECTED CONDENSER AND LP TURBINE.

* SUMMARY *

MAINE YANKEE RETURNED ONLINE FROM A MAINTENANCE OUTAGE ON JULY 19TH AND OPERATED ROUTINELY THE REMAINDER OF THE MONTH.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* MAINE YANKEE *

FACILITY DATA

Report Period JUL 1986

FACILITY DESCRIPTION

LOCATION
STATE.....MAINE
COUNTY.....LINCOLN
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...10 MI N OF
BATH, ME
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...OCTOBER 23, 1972
DATE ELEC ENER 1ST GENER...NOVEMBER 8, 1972
DATE COMMERCIAL OPERATE...DECEMBER 28, 1972
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...BACK RIVER
ELECTRIC RELIABILITY
COUNCIL.....NORTHEAST POWER
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....MAINE YANKEE ATOMIC POWER
CORPORATE ADDRESS.....83 EDISON DRIVE
AUGUSTA, MAINE 04366
CONTRACTOR
ARCHITECT/ENGINEER.....STONE & WEBSTER
NUC STEAM SYS SUPPLIER...COMBUSTION ENGINEERING
CONSTRUCTOR.....STONE & WEBSTER
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I
IE RESIDENT INSPECTOR.....C. HOLDEN
LICENSING PROJ MANAGER.....P. SEARS
DOCKET NUMBER.....50-309
LICENSE & DATE ISSUANCE...DPR-36, JUNE 29, 1973
PUBLIC DOCUMENT ROOM.....WISCASSET PUBLIC LIBRARY
HIGH STREET
WISCASSET, MAINE 04578

INSPECTION STATUS

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

TECHNICAL SPECIFICATION 5.8.1.A AND REGULATORY GUIDE 1.33 REQUIRE PROCEDURES FOR ACTIVITIES AFFECTING QUALITY. OPERATIONS PROCEDURE 1-26-4, RESPONSIBILITIES AND AUTHORITIES OF OPERATING PERSONNEL, ASSIGNS THE RESPONSIBILITY FOR OPERATION AND MONITORING OF EQUIPMENT TO THE AUXILIARY OPERATOR THROUGH THE SHIFT OPERATING SUPERVISORS. CONTRARY TO THE ABOVE, ON FEBRUARY 10, 1986 A PLANT ENGINEER OPERATED A VALVE IN THE AUXILIARY FEEDWATER SYSTEM IN ORDER TO OBTAIN A PRESSURE READING.
(8600 5)

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

Report Period JUL 1986

I N S P E C T I O N S T A T U S - (CONTINUED)

* MAINE YANKEE *

OTHER ITEMS

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S F R O M L I C E N S E E

=====			
NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT

NO INPUT PROVIDED.			
=====			

1. Docket: 50-369 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/86 Outage + On-line Hrs: 744.0

3. Utility Contact: J. A. REAVIS (704) 373-7567

4. Licensed Thermal Power (MWt): 3411

5. Nameplate Rating (Gross MWe): 1305

6. Design Electrical Rating (Net MWe): 1150

7. Maximum Dependable Capacity (Gross MWe): 1225

8. Maximum Dependable Capacity (Net MWe): 1150

9. If Changes Occur Above Since Last Report, Give Reasons: NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,087.0</u>	<u>40,895.0</u>
13. Hours Reactor Critical	<u>.0</u>	<u>3,113.4</u>	<u>28,119.9</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>.0</u>	<u>3,094.7</u>	<u>27,806.5</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>0</u>	<u>9,789,256</u>	<u>77,154,669</u>
18. Gross Elec Ener (MWH)	<u>0</u>	<u>3,415,928</u>	<u>26,726,581</u>
19. Net Elec Ener (MWH)	<u>-4,339</u>	<u>3,265,836</u>	<u>25,417,850</u>
20. Unit Service Factor	<u>.0</u>	<u>60.8</u>	<u>68.0</u>
21. Unit Avail Factor	<u>.0</u>	<u>60.8</u>	<u>68.0</u>
22. Unit Cap Factor (MDC Net)	<u>.0</u>	<u>55.8</u>	<u>54.0</u>
23. Unit Cap Factor (DER Net)	<u>.0</u>	<u>55.8</u>	<u>54.0</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>4.6</u>	<u>13.3</u>
25. Forced Outage Hours	<u>.0</u>	<u>150.0</u>	<u>4,261.5</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration): NONE

27. If Currently Shutdown Estimated Startup Date: 09/02/86

 * MCGUIRE 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
 MCGUIRE 1



JULY 1986

Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

 * MCGUIRE 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
7	05/16/86	S	744.0	C	4		RC	FUELXX	END OF CYCLE 3 REFUELING OUTAGE CONTINUES.

 * SUMMARY *

MCGUIRE 1 REMAINS SHUTDOWN FOR REFUELING.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	1-Manual
S-Sched	B-Maint or Test	G-Oper Error	2-Manual Scram
	C-Refueling	H-Other	3-Auto Scram
	D-Regulatory Restriction		4-Continued
	E-Operator Training		5-Reduced Load
	& License Examination		9-Other
			Exhibit F & H
			Instructions for
			Preparation of
			Data Entry Sheet
			Licensee Event Report
			(LER) File (NUREG-0161)

* MCGUIRE 1 *

FACILITY DATA

Report Period JUL 1986

FACILITY DESCRIPTION

LOCATION
STATE.....NORTH CAROLINA
COUNTY.....MECKLENBURG
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...17 MI N OF
CHARLOTTE, NC
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...AUGUST 8, 1981
DATE ELEC ENER 1ST GENER...SEPTEMBER 12, 1981
DATE COMMERCIAL OPERATE...DECEMBER 1, 1981
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...LAKE NORMAN
ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....DUKE POWER
CORPORATE ADDRESS.....422 SOUTH CHURCH STREET
CHARLOTTE, NORTH CAROLINA 28242
CONTRACTOR
ARCHITECT/ENGINEER.....DUKE POWER
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....DUKE POWER
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
IE RESIDENT INSPECTOR.....W. ORDERS
LICENSING PROJ MANAGER.....D. HOOD
DOCKET NUMBER.....50-369
LICENSE & DATE ISSUANCE...NPF-9, JULY 8, 1981
PUBLIC DOCUMENT ROOM.....MS. DAWN HUBBS
ATKINS LIBRARY
UNIVERSITY OF NORTH CAROLINA - CHARLOTTE
UNCC STATION,
CHARLOTTE, NC 28223

INSPECTION STATUS

INSPECTION SUMMARY

+ INSPECTION MARCH 1 - APRIL 20 (86-08): THIS ROUTINE, UNANNOUNCED INSPECTION WAS CONDUCTED ON SITE IN THE AREAS OF OPERATIONS, SURVEILLANCE TESTING AND MAINTENANCE ACTIVITIES. OF THE AREAS INSPECTED, TWO VIOLATIONS WERE IDENTIFIED IN THE AREAS OF SURVEILLANCE TESTING AND PROCEDURE ADHERENCE.

INSPECTION APRIL 21 - MAY 20 (86-12): THIS ROUTINE, UNANNOUNCED INSPECTION WAS CONDUCTED ON SITE IN THE AREAS OF OPERATIONS, SURVEILLANCE TESTING AND MAINTENANCE ACTIVITIES. OF THE AREAS INSPECTED, NO VIOLATIONS WERE IDENTIFIED IN THE AREAS OF SURVEILLANCE TESTING AND MAINTENANCE ACTIVITIES.

INSPECTION MAY 27-30 (86-13): THIS ROUTINE, UNANNOUNCED INSPECTION WAS SCHEDULED FOR THE PURPOSE OF OBSERVING INSERVICE INSPECTION (ISI) ACTIVITIES ON SAFETY-RELATED COMPONENTS. HOWEVER, THE PRESENCE OF UNEXPECTEDLY HIGH AIRBORNE ACTIVITY PRECLUDED THE LICENSEE FROM PERFORMING ISI WORK SCHEDULED FOR THIS TIME. THEREFORE, THE INSPECTOR DISCUSSED THE REPLACEMENT OF FLOW ELEMENTS IN THE NUCLEAR SERVICE WATER SYSTEM, REVIEWED LICENSEE ACTIONS ON IE BULLETINS, PREVIOUS ENFORCEMENT MATTERS, AND INSPECTOR IDENTIFIED ITEMS. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JUNE 9-13 (86-14): THIS ROUTINE, UNANNOUNCED INSPECTION WAS CONDUCTED ON SITE IN THE AREAS OF INSERVICE INSPECTION (ISI), WORK OBSERVATION, EVALUATION AND REVIEW OF RECORDS, EDDY CURRENT (EC) EXAMINATION RESULTS OF STEAM GENERATORS (SG) TUBES; NUCLEAR SERVICE WATER FLOW ELEMENT REPLACEMENT ON PUMP 1-B; SHOT PEENING OF S&G TUBES; REVIEW OF SNUBBER FUNCTIONAL TEST RECORDS.

Report Period JUL 1986

INSPECTION STATUS - (CONTINUED)

* MCGUIRE 1 *

INSPECTION SUMMARY

ONE VIOLATION WAS IDENTIFIED - VIOLATION 369/86-14-01, INSTRUMENTS AND SHOT PEENING MATERIAL USED TO QUALIFY SG TUBE SHOT PEENING PROCEDURE AND PERSONNEL NOT IDENTIFIED.

INSPECTION JUNE 3-5 (86-15): THIS SPECIAL, UNANNOUNCED INSPECTION INVOLVED ONSITE INSPECTION DURING NORMAL DUTY HOURS IN THE AREA OF EXTERNAL EXPOSURE CONTROL. ONE VIOLATION - FAILURE TO FOLLOW RADIOLOGICAL PROTECTION PROCEDURES.

ENFORCEMENT SUMMARY

CONTRARY TO TS 6.8.1.A, THE REACTIVITY BALANCE CALCULATION PROCEDURE, AND OPERATIONS MANAGEMENT PROCEDURE 2.5, SECTION 6.6: (1) ON MARCH 11, 1986, MCGUIRE UNIT 1 WAS BEING TAKEN CRITICAL WHEN THE CONTROL RODS WERE WITHDRAWN TO THE WITHDRAWAL LIMIT SPECIFIED IN THE REACTIVITY BALANCE PROCEDURE AND THE CONTROL RODS WERE NOT INSERTED AS REQUIRED. (2) ON MARCH 12, 1986 TRAIN 'B' OF CONTAINMENT SPRAY AND TRAIN 'A' OF SSPS (SOLID STATE PROTECTION SYSTEM) WERE REMOVED FROM SERVICE SIMULTANEOUSLY. THUS, BOTH TRAINS OF CONTAINMENT SPRAY WERE REMOVED FROM SERVICE SIMULTANEOUSLY. CONTRARY TO TS 4.11.1.2, 4.11.2.2, 4.11.2.3 AND 4.11.4.1, THE CONTRIBUTIONS FROM LIQUID AND GASEOUS EFFLUENTS FOR THE CURRENT CALENDAR QUARTER OR YEAR WERE NOT CALCULATED WITHIN THE 31 DAY SPAN PRECEDING JANUARY 29, 1986.
(8600 4)

CONTRARY TO TS 6.8.1, APPENDIX A, REGULATORY GUIDE 1.33, PARAGRAPH 7.E.1, AND HEALTH PHYSICS MANUAL SECTION 2.4, RADIATION WORK PERMITS, PARAGRAPH 2.4.1, SPECIFIC PROTECTIVE CLOTHING REQUIREMENTS WERE NOT DELINEATED ON RWP NO. 86-1183 IN THAT VERBAL UPGRADES IN RADIOLOGICAL CONTROL REQUIREMENTS HAD BEEN MADE WITHOUT WRITTEN RWP REVISIONS SUCH THAT ON MAY 29, 1986, AN INDIVIDUAL IN UNIT 1 LOWER CONTAINMENT, WHO WAS FOLLOWING THE WRITTEN RWP, DRESSED INAPPROPRIATELY FOR THE RADIATION HAZARD THAT HAD BEEN DETERMINED TO BE PRESENT.
(8601 4)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

REFUELING.

LAST IE SITE INSPECTION DATE: JUNE 3-5, 1986 +

INSPECTION REPORT NO: 50-369/86-15 +

Report Period JUL 1986

R E P O R T S F R O M L I C E N S E E

* MCGUIRE 1 *

```
=====
NUMBER    DATE OF    DATE OF    SUBJECT
EVENT     REPORT
-----
86-011    06/05/86   07/18/86   DIESEL GENERATOR 1A AUTOMATICALLY STARTED DUE TO A UNIT 1 TRAIN "A" BLACKOUT ACTUATION; CAUSE -
          DESIGN DEFICIENCY.
=====
```

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-370 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/86 Outage + On-line Hrs: 744.0

3. Utility Contact: J. A. REAVIS EXT (704) 373-7567

4. Licensed Thermal Power (MWt): 3411

5. Nameplate Rating (Gross MWe): 1450 X .9 = 1305

6. Design Electrical Rating (Net MWe): 1150

7. Maximum Dependable Capacity (Gross MWe): 1225

8. Maximum Dependable Capacity (Net MWe): 1150

9. If Changes Occur Above Since Last Report, Give Reasons:

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,087.0</u>	<u>21,191.0</u>
13. Hours Reactor Critical	<u>728.5</u>	<u>2,614.3</u>	<u>14,243.1</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>725.7</u>	<u>2,480.7</u>	<u>13,746.5</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>2,419,839</u>	<u>9,155,531</u>	<u>45,306,561</u>
18. Gross Elec Ener (MWH)	<u>843,355</u>	<u>2,861,132</u>	<u>15,561,124</u>
19. Net Elec Ener (MWH)	<u>811,080</u>	<u>2,724,707</u>	<u>14,878,360</u>
20. Unit Service Factor	<u>97.5</u>	<u>48.8</u>	<u>64.9</u>
21. Unit Avail Factor	<u>97.5</u>	<u>48.8</u>	<u>64.9</u>
22. Unit Cap Factor (MDC Net)	<u>94.8</u>	<u>46.6</u>	<u>61.1</u>
23. Unit Cap Factor (DER Net)	<u>94.8</u>	<u>46.6</u>	<u>61.1</u>
24. Unit Forced Outage Rate	<u>2.5</u>	<u>5.5</u>	<u>16.0</u>
25. Forced Outage Hours	<u>18.3</u>	<u>143.4</u>	<u>2,610.9</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


NONE

27. If Currently Shutdown Estimated Startup Date: N/A

 * MCGUIRE 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

MCGUIRE 2



JULY 1986

Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

 * MCGUIRE 2 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
11-P	07/01/86	S	0.0	B	5		IB	INSTRU	NUCLEAR INSTRUMENTATION CALIBRATION.
12-P	07/21/86	F	0.0	A	5		HA	INSTRU	TURBINE GOVERNING SYSTEM PROBLEM.
9	07/22/86	F	18.3	A	3		HA	INSTRU	A FAILURE IN TURBINE CONTROL CIRCUITRY CAUSED TURBINE GOVERNOR VALVES TO CLOSE.
13-P	07/23/86	F	0.0	F	5		XX	ZZZZZZ	HOLD FOR SECONDARY CHEMISTRY.
14-P	07/23/86	F	0.0	B	5		IB	INSTRU	NUCLEAR INSTRUMENTATION CALIBRATION.
15-P	07/23/86	F	0.0	F	5		XX	ZZZZZZ	HOLD FOR SECONDARY CHEMISTRY (SULFATES 100 PPB).
16-P	07/23/86	F	0.0	B	5		RC	ZZZZZZ	REACTOR COOLANT SYSTEM LEAKAGE CALCULATION.
17-P	07/24/86	F	0.0	H	5		HH	PUMPXX	PUT HEATER DRAIN PUMPS IN SERVICE.
18-P	07/24/86	F	0.0	B	5		RC	ZZZZZZ	REACTOR COOLANT SYSTEM LEAKAGE CALCULATION.

MCGUIRE 2 OPERATED WITH 1 OUTAGE AND NUMEROUS REDUCTIONS LISTED IN DETAIL ABOVE.

 * SUMMARY *

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* MCGUIRE 2 *

F A C I L I T Y D A T A

Report Period JUL 1986

FACILITY DESCRIPTION

LOCATION
STATE.....NORTH CAROLINA
COUNTY.....MECKLENBURG
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...17 MI N OF
CHARLOTTE, NC
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...MAY 8, 1983
DATE ELEC ENER 1ST GENER...MAY 23, 1983
DATE COMMERCIAL OPERATE...MARCH 1, 1984
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...LAKE NORMAN
ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....DUKE POWER
CORPORATE ADDRESS.....POWER BLDG., BOX 2178
CHARLOTTE, NORTH CAROLINA 28201
CONTRACTOR
ARCHITECT/ENGINEER.....DUKE POWER
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....DUKE POWER
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
IE RESIDENT INSPECTOR.....W. ORDERS
LICENSING PROJ MANAGER.....D. HOOD
DOCKET NUMBER.....50-370
LICENSE & DATE ISSUANCE...NPF-17, MAY 27, 1983
PUBLIC DOCUMENT ROOM.....MS. DAWN HUBBS
ATKINS LIBRARY
UNIVERSITY OF NORTH CAROLINA - CHARLOTTE
UNCC STATION,
CHARLOTTE, NC 28223

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION MARCH 1 - APRIL 20 (86-08): THIS ROUTINE, UNANNOUNCED INSPECTION WAS CONDUCTED ON SITE IN THE AREAS OF OPERATIONS, SURVEILLANCE TESTING AND MAINTENANCE ACTIVITIES. OF THE AREAS INSPECTED, TWO VIOLATIONS WERE IDENTIFIED IN THE AREAS OF SURVEILLANCE TESTING AND PROCEDURE ADHERENCE.

INSPECTION APRIL 21 - MAY 20 (86-12): THIS ROUTINE, UNANNOUNCED INSPECTION WAS CONDUCTED ON SITE IN THE AREAS OF OPERATIONS, SURVEILLANCE TESTING AND MAINTENANCE ACTIVITIES. OF THE AREAS INSPECTED, NO VIOLATIONS WERE IDENTIFIED IN THE AREAS OF SURVEILLANCE TESTING AND MAINTENANCE ACTIVITIES.

INSPECTION MAY 27-30 (86-13): THIS ROUTINE, UNANNOUNCED INSPECTION WAS SCHEDULED FOR THE PURPOSE OF OBSERVING INSERVICE INSPECTION (ISI) ACTIVITIES ON SAFETY-RELATED COMPONENTS. HOWEVER, THE PRESENCE OF UNEXPECTEDLY HIGH AIRBORNE ACTIVITY PRECLUDED THE LICENSEE FROM PERFORMING ISI WORK SCHEDULED FOR THIS TIME. THEREFORE, THE INSPECTOR DISCUSSED THE REPLACEMENT OF FLOW ELEMENTS IN THE NUCLEAR SERVICE WATER SYSTEM, REVIEWED LICENSEE ACTIONS ON IE BULLETINS, PREVIOUS ENFORCEMENT MATTERS, AND INSPECTOR IDENTIFIED ITEMS. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JUNE 9-13 (86-14): THIS ROUTINE, UNANNOUNCED INSPECTION WAS CONDUCTED ON SITE IN THE AREAS OF INSERVICE INSPECTION (ISI), WORK OBSERVATION, EVALUATION AND REVIEW OF RECORDS, EDDY CURRENT (EC) EXAMINATION RESULTS OF STEAM GENERATORS (SG) TUBES; NUCLEAR SERVICE WATER FLOW ELEMENT REPLACEMENT ON PUMP 1-B; SHOT PEENING OF S&G TUBES; REVIEW OF SNUBBER FUNCTIONAL TEST RECORDS.

Report Period JUL 1986

INSPECTION STATUS - (CONTINUED)

* MCGUIRE 2 *

INSPECTION SUMMARY

ONE VIOLATION WAS IDENTIFIED - VIOLATION 369/86-14-01, INSTRUMENTS AND SHOT PEENING MATERIAL USED TO QUALIFY SG TUBE SHOT PEENING PROCEDURE AND PERSONNEL NOT IDENTIFIED.

INSPECTION JUNE 3-5 (86-15): THIS SPECIAL, UNANNOUNCED INSPECTION INVOLVED ONSITE INSPECTION DURING NORMAL DUTY HOURS IN THE AREA OF EXTERNAL EXPOSURE CONTROL. ONE VIOLATION - FAILURE TO FOLLOW RADIOLOGICAL PROTECTION PROCEDURES.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

POWER OPERATION.

LAST IE SITE INSPECTION DATE: JUNE 3-5, 1986 +

INSPECTION REPORT NO: 50-370/86-15 +

REPORTS FROM LICENSEE

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
--------	------------------	-------------------	---------

NONE.

=====

1. Docket: 50-245 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/86 Outage + On-line Hrs: 744.0

3. Utility Contact: G. NEWBURGH (203) 447-1791 X4400

4. Licensed Thermal Power (MWt): 2011

5. Nameplate Rating (Gross MWe): 735 X 0.9 = 662

6. Design Electrical Rating (Net MWe): 660

7. Maximum Dependable Capacity (Gross MWe): 684

8. Maximum Dependable Capacity (Net MWe): 654

9. If Changes Occur Above Since Last Report, Give Reasons: NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,087.0</u>	<u>137,375.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>4,903.4</u>	<u>105,982.5</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>148.9</u>	<u>2,983.4</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>4,862.0</u>	<u>103,051.2</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>183.7</u>	<u>277.4</u>
17. Gross Therm Ener (MWH)	<u>1,471,518</u>	<u>9,630,694</u>	<u>190,244,892</u>
18. Gross Elec Ener (MWH)	<u>496,000</u>	<u>3,285,600</u>	<u>63,986,896</u>
19. Net Elec Ener (MWH)	<u>474,229</u>	<u>3,141,789</u>	<u>61,034,302</u>
20. Unit Service Factor	<u>100.0</u>	<u>95.6</u>	<u>75.0</u>
21. Unit Avail Factor	<u>100.0</u>	<u>99.2</u>	<u>75.2</u>
22. Unit Cap Factor (MDC Net)	<u>97.5</u>	<u>94.4</u>	<u>67.9</u>
23. Unit Cap Factor (DER Net)	<u>96.6</u>	<u>93.6</u>	<u>67.3</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.8</u>	<u>11.9</u>
25. Forced Outage Hours	<u>.0</u>	<u>41.3</u>	<u>5,855.6</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration): NONE

27. If Currently Shutdown Estimated Startup Date: N/A

* MILLSTONE 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

MILLSTONE 1



JULY 1986

Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

* MILLSTONE 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
6	07/16/86	S	0.0	B	5				POWER REDUCTION FOR CONTROL ROD PATTERN ADJUSTMENT AND TO FIND AND REPAIR CONDENSER TUBE LEAKS.

* SUMMARY *

MILLSTONE 1 OPERATED WITH 1 REDUCTION FOR MAINTENANCE DURING JULY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

 * MILLSTONE 1 *

F A C I L I T Y D A T A

Report Period JUL 1986

FACILITY DESCRIPTION

LOCATION
 STATE.....CONNECTICUT
 COUNTY.....NEW LONDON
 DIST AND DIRECTION FROM
 NEAREST POPULATION CTR...5 MI SW OF
 NEW LONDON, CONN
 TYPE OF REACTOR.....BWR
 DATE INITIAL CRITICALITY...OCTOBER 26, 1970
 DATE ELEC ENER 1ST GENER...NOVEMBER 29, 1970
 DATE COMMERCIAL OPERATE...MARCH 1, 1971
 CONDENSER COOLING METHOD...ONCE THRU
 CONDENSER COOLING WATER...LONG ISLAND SOUND
 ELECTRIC RELIABILITY
 COUNCIL.....NORTHEAST POWER
 COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
 LICENSEE.....NORTHEAST NUCLEAR ENERGY
 CORPORATE ADDRESS.....P.O. BOX 270
 HARTFORD, CONNECTICUT 06101
 CONTRACTOR
 ARCHITECT/ENGINEER.....EBASCO
 NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
 CONSTRUCTOR.....EBASCO
 TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I
 IE RESIDENT INSPECTOR.....J. SHEDLOSKY
 LICENSING PROJ MANAGER.....J. SHEA
 DOCKET NUMBER.....50-245
 LICENSE & DATE ISSUANCE....DPR-21, OCTOBER 26, 1970
 PUBLIC DOCUMENT ROOM.....WATERFORD PUBLIC LIBRARY
 49 ROPE FERRY ROAD
 WATERFORD, CONNECTICUT 06385

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

Report Period JUL 1986

I N S P E C T I O N S T A T U S - (CONTINUED)

* MILLSTONE 1 *

OTHER ITEMS

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S F R O M L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
--------	------------------	-------------------	---------

NO INPUT PROVIDED.

=====

1. Docket: 50-336 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/86 Outage + On-line Hrs: 744.0

3. Utility Contact: G. NERON (203) 447-1791 X4417

4. Licensed Thermal Power (MWh): 2700

5. Nameplate Rating (Gross MWe): 1011 X 0.9 = 910

6. Design Electrical Rating (Net MWe): 870

7. Maximum Dependable Capacity (Gross MWe): 889

8. Maximum Dependable Capacity (Net MWe): 857

9. If Changes Occur Above Since Last Report, Give Reasons:

NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,087.0</u>	<u>92,903.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>5,080.4</u>	<u>66,502.8</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>2,166.9</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>4,986.9</u>	<u>63,704.3</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>468.2</u>
17. Gross Therm Ener (MWH)	<u>2,007,906</u>	<u>13,356,360</u>	<u>162,264,869</u>
18. Gross Elec Ener (MWH)	<u>648,700</u>	<u>4,323,900</u>	<u>52,656,373</u>
19. Net Elec Ener (MWH)	<u>625,598</u>	<u>4,165,559</u>	<u>50,488,340</u>
20. Unit Service Factor	<u>100.0</u>	<u>98.0</u>	<u>68.6</u>
21. Unit Avail Factor	<u>100.0</u>	<u>98.0</u>	<u>69.1</u>
22. Unit Cap Factor (MDC Net)	<u>98.1</u>	<u>95.6</u>	<u>64.4*</u>
23. Unit Cap Factor (DER Net)	<u>96.7</u>	<u>94.1</u>	<u>63.4*</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.3</u>	<u>16.2</u>
25. Forced Outage Hours	<u>.0</u>	<u>13.0</u>	<u>11,075.8</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


REFUELING: SEPTEMBER, 1986 - 14 WEEKS.

27. If Currently Shutdown Estimated Startup Date: N/A

* MILLSTONE 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

MILLSTONE 2



JULY 1986

* Item calculated with a Weighted Average

Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

* MILLSTONE 2 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
-----	------	------	-------	--------	--------	------------	--------	-----------	---

NONE

* SUMMARY *

MILLSTONE 2 OPERATED AT NEAR FULL POWER IN JULY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* MILLSTONE 2 *

F A C I L I T Y D A T A

Report Period JUL 1986

FACILITY DESCRIPTION

LOCATION
STATE.....CONNECTICUT
COUNTY.....NEW LONDON
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...5 MI SW OF
NEW LONDON, CONN
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...OCTOBER 17, 1975
DATE ELEC ENER 1ST GENER...NOVEMBER 9, 1975
DATE COMMERCIAL OPERATE...DECEMBER 26, 1975
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...LONG ISLAND SOUND
ELECTRIC RELIABILITY
COUNCIL.....NORTHEAST POWER
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....NORTHEAST NUCLEAR ENERGY
CORPORATE ADDRESS.....P.O. BOX 270
HARTFORD, CONNECTICUT 06101
CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...COMBUSTION ENGINEERING
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I
IE RESIDENT INSPECTOR.....T. REBELOWSKI
LICENSING PROJ MANAGER.....D. JAFFE
DOCKET NUMBER.....50-336
LICENSE & DATE ISSUANCE...DPR-65, SEPTEMBER 30, 1975
PUBLIC DOCUMENT ROOM.....WATERFORD PUBLIC LIBRARY
49 ROPE FERRY ROAD
WATERFORD, CONNECTICUT 06385

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

Report Period JUL 1986

INSPECTION STATUS - (CONTINUED)

* MILLSTONE 2 *

OTHER ITEMS

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

REPORTS FROM LICENSEE

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT

NO INPUT PROVIDED.			
=====			

1. Docket: 50-423 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/86 Outage + On-line Hrs: 744.0

3. Utility Contact: A. ELMS (203) 444-5388

4. Licensed Thermal Power (MWt): 3411

5. Nameplate Rating (Gross MWe): 1253

6. Design Electrical Rating (Net MWe): 1154

7. Maximum Dependable Capacity (Gross MWe): 1197

8. Maximum Dependable Capacity (Net MWe): 1149

9. If Changes Occur Above Since Last Report, Give Reasons:

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>2,399.0</u>	<u>2,399.0</u>
13. Hours Reactor Critical	<u>575.0</u>	<u>2,135.3</u>	<u>2,135.3</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>83.2</u>	<u>83.2</u>
15. Hrs Generator On-Line	<u>575.0</u>	<u>2,119.2</u>	<u>2,119.2</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,943,450</u>	<u>11,049,833</u>	<u>11,049,833</u>
18. Gross Elec Ener (MWH)	<u>669,546</u>	<u>2,449,912</u>	<u>2,449,912</u>
19. Net Elec Ener (MWH)	<u>639,674</u>	<u>2,342,519</u>	<u>2,342,519</u>
20. Unit Service Factor	<u>77.3</u>	<u>88.3</u>	<u>88.3</u>
21. Unit Avail Factor	<u>77.3</u>	<u>88.3</u>	<u>88.3</u>
22. Unit Cap Factor (MDC Net)	<u>74.8</u>	<u>85.0</u>	<u>85.0</u>
23. Unit Cap Factor (DER Net)	<u>74.5</u>	<u>84.6</u>	<u>84.6</u>
24. Unit Forced Outage Rate	<u>22.7</u>	<u>11.7</u>	<u>11.7</u>
25. Forced Outage Hours	<u>169.0</u>	<u>279.8</u>	<u>279.8</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


NONE

27. If Currently Shutdown Estimated Startup Date: 09/13/86

* MILLSTONE 3 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

MILLSTONE 3



JULY 1986

Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

* MILLSTONE 3 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
86-04	07/21/86	F	0.0	G	5		SM	P	LEVEL CONTROL VALVE FAILURE DUE TO IMPROPER TAGGING CAUSES HEATER DRAIN PUMP TRIP.
86-05	07/24/86	F	169.0	A	3	86-41	SJ	TC	TRIP DURING SHUTDOWN TO REPAIR MAIN GENERATOR STATOR COOLANT LEAK AND VALVE IN LETDOWN SYSTEM.

* SUMMARY *

MILLSTONE 3 OPERATED WITH 1 REDUCTION AND SHUTDOWN FOR REPAIRS ON JULY 24TH.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* MILLSTONE 3 *

F A C I L I T Y D A T A

Report Period JUL 1986

FACILITY DESCRIPTION

LOCATION
STATE.....CONNECTICUT
COUNTY.....NEW LONDON
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...3.2 MI WSW OF
NEW LONDON CT.
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...JANUARY 23, 1986
DATE ELEC ENER 1ST GENER...FEBRUARY 12, 1986
DATE COMMERCIAL OPERATE....APRIL 23, 1986
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...NIANTIC BAY
ELECTRIC RELIABILITY
COUNCIL.....NORTHEAST POWER
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....NORTHEAST NUCLEAR ENERGY
CORPORATE ADDRESS.....P.O. BOX 270
HARTFORD, CONNECTICUT 06101
CONTRACTOR
ARCHITECT/ENGINEER.....STONE & WEBSTER
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....STONE & WEBSTER
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I
IE RESILENT INSPECTOR.....T. REBELOWSKI
LICENSING PROJ MANAGER....E. DOOLITTLE
DOCKET NUMBER.....50-423
LICENSE & DATE ISSUANCE...NPF-49, JANUARY 31, 1986
PUBLIC DOCUMENT ROOM.....WATERFORD PUBLIC LIBRARY
49 ROPE FERRY ROAD
WATERFORD, CONNECTICUT 06385

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INFO. NOT SUPPLIED BY REGION

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

INFO. NOT SUPPLIED BY REGION

FACILITY ITEMS (PLANS AND PROCEDURES):

INFO. NOT SUPPLIED BY REGION

MANAGERIAL ITEMS:

INFO. NOT SUPPLIED BY REGION

Report Period JUL 1986

I N S P E C T I O N S T A T U S - (CONTINUED)

* MILLSTONE 3 *

PLANT STATUS:

INFO. NOT SUPPLIED BY REGION

LAST IE SITE INSPECTION DATE: INFO. NOT SUPPLIED BY REGION

INSPECTION REPORT NO: INFO. NOT SUPPLIED BY REGION

R E P O R T S F R O M L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
--------	------------------	-------------------	---------

INFO. NOT SUPPLIED BY REGION

=====

1. Docket: 50-263 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/86 Outage + On-line Hrs: 744.0

3. Utility Contact: A. L. Myrabo (612) 295-5151

4. Licensed Thermal Power (Mwt): 1670

5. Nameplate Rating (Gross MWe): 632 X 0.9 = 569

6. Design Electrical Rating (Net MWe): 545

7. Maximum Dependable Capacity (Gross MWe): 564

8. Maximum Dependable Capacity (Net MWe): 536

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____
NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,087.0</u>	<u>132,240.0</u>
13. Hours Reactor Critical	<u>485.0</u>	<u>3,354.6</u>	<u>101,433.1</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>940.7</u>
15. Hrs Generator On-Line	<u>442.2</u>	<u>3,309.9</u>	<u>99,343.5</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>642,029</u>	<u>4,561,363</u>	<u>158,854,873</u>
18. Gross Elec Ener (MWH)	<u>215,959</u>	<u>1,549,567</u>	<u>51,200,844</u>
19. Net Elec Ener (MWH)	<u>203,211</u>	<u>1,475,967</u>	<u>48,938,378</u>
20. Unit Service Factor	<u>59.4</u>	<u>65.1</u>	<u>75.1</u>
21. Unit Avail Factor	<u>59.4</u>	<u>65.1</u>	<u>75.1</u>
22. Unit Cap Factor (MDC Net)	<u>51.0</u>	<u>54.1</u>	<u>69.0</u>
23. Unit Cap Factor (DER Net)	<u>50.1</u>	<u>53.2</u>	<u>67.9</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.0</u>	<u>4.8</u>
25. Forced Outage Hours	<u>.0</u>	<u>.0</u>	<u>1,335.0</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

* MONTICELLO *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
MONTICELLO



JULY 1986

Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

* MONTICELLO *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
1	04/30/86	S	288.8	C	4		Z		CONTINUATION OF THE 1986 REFUELING OUTAGE.
2	07/13/86	S	13.0	B	1		HA	TURBIN	GENERATOR TAKEN OFF-LINE FOR TURBINE OVERSPEED TEST.

* SUMMARY *

MONTICELLO COMPLETED A REFUELING OUTAGE ON JULY 13.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* MONTICELLO *

F A C I L I T Y D A T A

Report Period JUL 1986

FACILITY DESCRIPTION

LOCATION
STATE.....MINNESOTA
COUNTY.....WRIGHT
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...30 MI NW OF
MINNEAPOLIS, MINN
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...DECEMBER 10, 1970
DATE ELEC ENER 1ST GENER...MARCH 5, 1971
DATE COMMERCIAL OPERATE...JUNE 30, 1971
CONDENSER COOLING METHOD...COOLING TOWER
CONDENSER COOLING WATER...MISSISSIPPI RIVER
ELECTRIC RELIABILITY
COUNCIL.....MID-CONTINENT AREA
RELIABILITY COORDINATION
AGREEMENT

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....NORTHERN STATES POWER
CORPORATE ADDRESS.....414 NICOLLET MALL
MINNEAPOLIS, MINNESOTA 55401
CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III
IE RESIDENT INSPECTOR.....P. HARTMAN
LICENSING PROJ MANAGER.....D. LYNCH
DOCKET NUMBER.....50-263
LICENSE & DATE ISSUANCE...DPR-22, JANUARY 9, 1981
PUBLIC DOCUMENT ROOM.....ENVIRONMENTAL CONSERVATION LIBRARY
MINNEAPOLIS PUBLIC LIBRARY
300 NICOLLET MALL
MINNEAPOLIS, MINNESOTA 55401

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION ON JUNE 30 (86005): ROUTINE UNANNOUNCED INSPECTION OF THE RESOLUTION OF AN IE BULLETIN. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION ON JUNE 23-25 (86006): SPECIAL, ANNOUNCED INSPECTION BY REGIONAL INSPECTORS OF THE CAUSE(S) WHICH CREATED THE INTERMEDIATE RANGE MONITOR (IRMS) INOPERABILITY EVENT OF JUNE 14, 1986; THE ADEQUACY OF PLANT PROCEDURES TO ENSURE SAFE OPERATION HAD THE EVENT OCCURRED DURING UNIT STARTUP OR SHUTDOWN; AND THE CORRECTIVE ACTIONS TAKEN TO PREVENT RECURRENCE. THE INSPECTION WAS CONDUCTED IN ACCORDANCE WITH NRC INSPECTION PROCEDURE 93702. OF THE THREE AREAS INSPECTED NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED IN TWO AREAS. TWO VIOLATIONS WERE IDENTIFIED IN THE REMAINING AREA (FAILURE TO FOLLOW PROCEDURES AND TECHNICAL SPECIFICATION LCO 3.1.A AND 3.2.C)

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

INSPECTION STATUS - (CONTINUED)

 * MONTICELLO *

SYSTEMS AND COMPONENT PROBLEMS:

FACILITY ITEMS (PLANS AND PROCEDURES):

MANAGERIAL ITEMS:

PLANT STATUS:

OPERATING ROUTINELY.

LAST IE SITE INSPECTION DATE: 06/25/86

INSPECTION REPORT NO: 86006

REPORTS FROM LICENSEE

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
86-15	06/03/86	07/03/86	RHR SHUTDOWN COOLING INTERLOCK TRIP
86-16	06/11/86	07/11/86	STANDBY LIQUID CONTROL SYSTEM IMPROPER FUSE COORDINATION
86-17	06/15/86	07/15/86	ECCS INITIATION DURING REACTOR VESSEL WATER LEVEL INSTRUMENTATION INSTALLATION
86-16	06/16/86	07/16/86	INOPERABLE INTERMEDIATE RANGE MONITORS #15, 16 AND 17
86-19	06/17/86	07/17/86	REACTOR PROTECTION SYSTEM INITIATION
86-20	06/19/86	07/18/86	RPS AND GROUP II TRIP FROM LOSS OF POWER
86-21	06/20/86	07/18/86	ESF ACTUATIONS FROM WRGM TRIPS
86-22	06/23/86	07/18/86	RBV ISOLATION, CONTAINMENT GROUP II ISOLATION, AND SBGTS INITIATION DURING SWITCHING
86-23	07/03/86	08/01/86	LPCI LOOP SELECTION DESIGN PROBLEMS

1. Docket: 50-220 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/86 Outage + On-line Hrs: 744.0

3. Utility Contact: THOMAS W. ROMAN (315) 349-2422

4. Licensed Thermal Power (MWt): 1850

5. Nameplate Rating (Gross MWe): 755 X 0.85 = 642

6. Design Electrical Rating (Net MWe): 620

7. Maximum Dependable Capacity (Gross MWe): 630

8. Maximum Dependable Capacity (Net MWe): 610

9. If Changes Occur Above Since Last Report, Give Reasons: NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,087.0</u>	<u>146,807.0</u>
13. Hours Reactor Critical	<u>608.8</u>	<u>2,336.9</u>	<u>103,577.4</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>1,204.2</u>
15. Hrs Generator On-Line	<u>590.3</u>	<u>2,254.4</u>	<u>100,502.4</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>20.2</u>
17. Gross Therm Ener (MWH)	<u>974,468</u>	<u>3,400,222</u>	<u>167,895,897</u>
18. Gross Elec Ener (MWH)	<u>319,537</u>	<u>1,117,479</u>	<u>55,586,935</u>
19. Net Elec Ener (MWH)	<u>308,401</u>	<u>1,076,549</u>	<u>53,838,876</u>
20. Unit Service Factor	<u>79.3</u>	<u>44.3</u>	<u>68.5</u>
21. Unit Avail Factor	<u>79.3</u>	<u>44.3</u>	<u>68.5</u>
22. Unit Cap Factor (MDC Net)	<u>68.0</u>	<u>34.7</u>	<u>60.1</u>
23. Unit Cap Factor (DER Net)	<u>66.9</u>	<u>34.1</u>	<u>59.2</u>
24. Unit Forced Outage Rate	<u>20.7</u>	<u>12.5</u>	<u>15.4</u>
25. Forced Outage Hours	<u>153.7</u>	<u>322.6</u>	<u>13,699.1</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):

NONE

27. If Currently Shutdown Estimated Startup Date: N/A

* NINE MILE POINT 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
NINE MILE POINT 1



JULY 1986

Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

 * NINE MILE POINT 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
2	07/08/86	F	153.7	A	1				CONTROL ROD DRIVE PUMP #11 HAD FAILED AND POSSIBLE FAILURE TO CONTROL ROD DRIVE PUMP #12.

 * SUMMARY *

 NINE MILE POINT 1 HAD 1 SHUTDOWN IN JULY FOR EQUIPMENT FAILURE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	1-Manual
S-Sched	B-Maint or Test	G-Oper Error	2-Manual Scram
	C-Refueling	H-Other	3-Auto Scram
	D-Regulatory Restriction		4-Continued
	E-Operator Training		5-Reduced Load
	& License Examination		9-Other
			Exhibit F & H
			Instructions for
			Preparation of
			Data Entry Sheet
			Licensee Event Report
			(LER) File (NUREG-0161)

* NINE MILE POINT 1 *

F A C I L I T Y D A T A

Report Period JUL 1986

FACILITY DESCRIPTION

LOCATION
STATE.....NEW YORK
COUNTY.....OSWEGO
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...8 MI NE OF
OSWEGO, NY
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...SEPTEMBER 5, 1969
DATE ELEC ENER 1ST GENER...NOVEMBER 9, 1969
DATE COMMERCIAL OPERATE...DECEMBER 1, 1969
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...LAKE ONTARIO
ELECTRIC RELIABILITY
COUNCIL.....NORTHEAST POWER
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....NIAGARA MOHAWK POWER CORP.
CORPORATE ADDRESS.....300 ERIE BOULEVARD WEST
SYRACUSE, NEW YORK 13202
CONTRACTOR
ARCHITECT/ENGINEER.....NIAGARA MOHAWK POWER CORP.
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....STONE & WEBSTER
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I
IE RESIDENT INSPECTOR.....S. HUDSON
LICENSING PROJ MANAGER.....J. KELLY
DOCKET NUMBER.....50-220
LICENSE & DATE ISSUANCE...DPR-63, DECEMBER 26, 1974
PUBLIC DOCUMENT ROOM.....STATE UNIVERSITY COLLEGE OF OSWEGO
PENFIELD LIBRARY - DOCUMENTS
OSWEGO, NY 13126
(315) 341-2323

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

TECHNICAL SPECIFICATIONS, SECTION 6.12.1, REQUIRES IN PART THAT EACH HIGH RADIATION AREA NORMALLY ACCESSIBLE BY PERSONNEL IN WHICH THE INTENSITY OF RADIATION IS GREATER THAN 100 MREM/HR BUT LESS THAN 1000 MREM/HR SHALL BE BARRICADED AND CONSPICUOUSLY POSTED AS A HIGH RADIATION AREA. CONTRARY TO THE ABOVE, ON MARCH 7, 1986, A HIGH RADIATION AREA ACCESSIBLE TO PERSONNEL AND MEASURING UP TO 400 MREM/HR, ON THE TURBINE DECK, 300 FT. ELEVATION, WAS LEFT NOT BARRICADED AND NOT POSTED.
(8600 4)

OTHER ITEMS

SYSTEMS AND COMPONENTS:

Report Period JUL 1986

I N S P E C T I O N S T A T U S - (CONTINUED)

* NINE MILE POINT 1 *

OTHER ITEMS

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S F R O M L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT

NO INPUT PROVIDED.			
=====			

1. Docket: 50-338 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/86 Outage + On-line Hrs: 744.0

3. Utility Contact: B. GARNER (703) 894-5151 X2527

4. Licensed Thermal Power (MWt): 2775

5. Nameplate Rating (Gross MWe): 947

6. Design Electrical Rating (Net MWe): 907

7. Maximum Dependable Capacity (Gross MWe): 941

8. Maximum Dependable Capacity (Net MWe): 893

9. If Changes Occur Above Since Last Report, Give Reasons: NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any: NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,087.0</u>	<u>71,472.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>4,619.4</u>	<u>49,905.2</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>467.6</u>	<u>4,474.2</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>4,524.9</u>	<u>48,437.0</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>2,062,274</u>	<u>12,263,735</u>	<u>127,240,287</u>
18. Gross Elec Ener (MWH)	<u>692,430</u>	<u>4,124,805</u>	<u>41,602,431</u>
19. Net Elec Ener (MWH)	<u>657,005</u>	<u>3,916,296</u>	<u>39,331,244</u>
20. Unit Service Factor	<u>100.0</u>	<u>89.0</u>	<u>67.8</u>
21. Unit Avail Factor	<u>100.0</u>	<u>89.0</u>	<u>67.8</u>
22. Unit Cap Factor (MDC Net)	<u>98.9</u>	<u>86.2</u>	<u>61.6</u>
23. Unit Cap Factor (DER Net)	<u>97.4</u>	<u>84.9</u>	<u>60.7</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>11.0</u>	<u>12.1</u>
25. Forced Outage Hours	<u>.0</u>	<u>558.1</u>	<u>6,542.6</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):

NONE

27. If Currently Shutdown Estimated Startup Date: N/A

 * NORTH ANNA 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
 NORTH ANNA 1



JULY 1986

Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

* NORTH ANNA 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System Component	Cause & Corrective Action to Prevent Recurrence
-----	------	------	-------	--------	--------	------------	------------------	---

NONE

* SUMMARY *

NORTH ANNA 1 OPERATED ROUTINELY IN JULY WITH NO OUTAGES OR POWER REDUCTIONS REPORTED.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* NORTH ANNA 1 *

FACILITY DATA

Report Period JUL 1986

FACILITY DESCRIPTION

LOCATION
STATE.....VIRGINIA
COUNTY.....LOUISA
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...40 MI NW OF
RICHMOND, VA
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...APRIL 5, 1978
DATE ELEC ENER 1ST GENER...APRIL 17, 1978
DATE COMMERCIAL OPERATE...JUNE 6, 1978
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...LAKE ANNA
ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....VIRGINIA POWER
CORPORATE ADDRESS.....P.O. BOX 26666
RICHMOND, VIRGINIA 23261
CONTRACTOR
ARCHITECT/ENGINEER.....STONE & WEBSTER
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....STONE & WEBSTER
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
IE RESIDENT INSPECTOR.....M. BRANCH
LICENSING PROJ MANAGER.....L. ENGLE
DOCKET NUMBER.....50-338
LICENSE & DATE ISSUANCE...NPF-4, APRIL 1, 1978
PUBLIC DOCUMENT ROOM.....ALDERMAN LIBRARY/MANUSCRIPTS DEPT.
UNIV. OF VIRGINIA/CHARLOTTESVILLE VA 22901

INSPECTION STATUS

INSPECTION SUMMARY

+ INSPECTION MAY 5 - JUNE 1 (86-13): THIS ROUTINE INSPECTION BY THE RESIDENT INSPECTOR INVOLVED THE AREAS OF LICENSEE EVENT REPORT (LER) REVIEW, ENGINEERING SAFETY FEATURES (ESF) WALKDOWN, OPERATIONAL SAFETY VERIFICATION, MONTHLY MAINTENANCE, MONTHLY SURVEILLANCE AND SAFEGUARDS. ONE VIOLATION WAS IDENTIFIED - FAILURE TO FOLLOW DESIGN CHANGE PROCEDURES FOR THE BATTERY INSTALLATION.

INSPECTION JUNE 17-19 (86-16): THIS WAS A ROUTINE, ANNOUNCED INSPECTION OF THE LICENSEE'S PERFORMANCE AND CAPABILITIES DURING AN EXERCISE OF THE EMERGENCY PLAN AND PROCEDURES. OF THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JUNE 2 - JULY 6 (86-17): THIS ROUTINE INSPECTION BY THE RESIDENT INSPECTORS INVOLVED THE FOLLOWING AREAS: PLANT STATUS, INSPECTOR FOLLOW-UP AND UNRESOLVED ITEMS, LICENSEE EVENT REPORT (LER) FOLLOWUP, ROUTINE INSPECTION, MONTHLY MAINTENANCE OBSERVATION, MONTHLY SURVEILLANCE OBSERVATION, ESF SYSTEM WALKDOWN, AND POTENTIAL GENERIC ITEMS. TWO VIOLATIONS WERE IDENTIFIED - FAILURE TO REQUIRE A REVIEW OF DESIGN CHANGE ACCEPTANCE TESTS FOR TECHNICAL SPECIFICATION REQUIREMENTS AND FAILURE TO PERFORM A WRITTEN SAFETY EVALUATION.

ENFORCEMENT SUMMARY

FAILURE TO CONTROL PROTECTED AREA ACCESS.
(8600 3)

Report Period JUL 1986

I N S P E C T I O N S T A T U S - (CONTINUED)

* NORTH ANNA 1 *

ENFORCEMENT SUMMARY

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

NORMAL OPERATION.

LAST IE SITE INSPECTION DATE: JUNE 2 - JULY 6, 1986 +

INSPECTION REPORT NO: 50-338/86-17 +

R E P O R T S F R O M L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
86-012	06/10/86	07/08/86	FIRE DETECTION SYSTEM OUT-OF-SERVICE GREATER THAN 14 DAYS; CAUSE - LACK OF COORDINATION BETWEEN CONSTRUCTION PLANNING AND STATION PLANNING.

=====

1. Docket: 50-339 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/86 Outage + On-line Hrs: 744.0

3. Utility Contact: B. GARNER (703) 894-5151 X2527

4. Licensed Thermal Power (MWt): 2775

5. Nameplate Rating (Gross MWe): 947

6. Design Electrical Rating (Net MWe): 907

7. Maximum Dependable Capacity (Gross MWe): 941

8. Maximum Dependable Capacity (Net MWe): 893

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,087.0</u>	<u>49,343.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>3,978.7</u>	<u>38,296.0</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>1,108.3</u>	<u>3,680.4</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>3,896.2</u>	<u>37,328.3</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,979,991</u>	<u>10,039,481</u>	<u>97,188,870</u>
18. Gross Elec Ener (MWH)	<u>650,235</u>	<u>3,329,605</u>	<u>32,231,787</u>
19. Net Elec Ener (MWH)	<u>615,238</u>	<u>3,153,752</u>	<u>30,536,612</u>
20. Unit Service Factor	<u>100.0</u>	<u>76.6</u>	<u>75.7</u>
21. Unit Avail Factor	<u>100.0</u>	<u>76.6</u>	<u>75.7</u>
22. Unit Cap Factor (MDC Net)	<u>92.6</u>	<u>69.4</u>	<u>69.3</u>
23. Unit Cap Factor (DER Net)	<u>91.2</u>	<u>68.4</u>	<u>68.2</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>4.3</u>	<u>10.7</u>
25. Forced Outage Hours	<u>.0</u>	<u>176.5</u>	<u>4,456.3</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

* NORTH ANNA 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
NORTH ANNA 2



JULY 1986

Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

* NORTH ANNA 2 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
86-07	07/19/86	S	0.0	H	5				RAMPED UNIT DOWN TO 30% POWER FOR REPAIRS ON MAIN FEED REGULATOR VALVE. REPAIRS WERE COMPLETED AND UNIT RETURNED TO 100 POWER.

* SUMMARY *

NORTH ANNA 2 OPERATED ROUTINELY IN JULY WITH NO OUTAGES AND 1 POWER REDUCTION REPORTED.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	1-Manual
S-Sched	B-Maint or Test	G-Oper Error	2-Manual Scram
	C-Refueling	H-Other	3-Auto Scram
	D-Regulatory Restriction		4-Continued
	E-Operator Training		5-Reduced Load
	& License Examination		9-Other
			Exhibit F & H
			Instructions for
			Preparation of
			Data Entry Sheet
			Licensee Event Report
			(LER) File (NUREG-0161)

* NORTH ANNA 2 *

FACILITY DATA

Report Period JUL 1986

FACILITY DESCRIPTION

LOCATION
STATE.....VIRGINIA

COUNTY.....LOUISA

DIST AND DIRECTION FROM
NEAREST POPULATION CTR...40 MI NW OF
RICHMOND, VA

TYPE OF REACTOR.....PWR

DATE INITIAL CRITICALITY...JUNE 12, 1980

DATE ELEC ENER 1ST GENER...AUGUST 25, 1980

DATE COMMERCIAL OPERATE...DECEMBER 14, 1980

CONDENSER COOLING METHOD...ONCE THRU

CONDENSER COOLING WATER...LAKE ANNA

ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....VIRGINIA POWER

CORPORATE ADDRESS.....P.O. BOX 26666
RICHMOND, VIRGINIA 23261

CONTRACTOR
ARCHITECT/ENGINEER.....STONE & WEBSTER

NUC STEAM SYS SUPPLIER...WESTINGHOUSE

CONSTRUCTOR.....STONE & WEBSTER

TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II

IE RESIDENT INSPECTOR.....M. BRANCH

LICENSING PROJ MANAGER.....L. ENGLE
DOCKET NUMBER.....50-339

LICENSE & DATE ISSUANCE...NPF-7, AUGUST 21, 1980

PUBLIC DOCUMENT ROOM.....ALDERMAN LIBRARY/MANUSCRIPTS DEPT.
UNIV. OF VIRGINIA/CHARLOTTESVILLE VA 22901

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION MAY 5 - JUNE 1 (86-13): THIS ROUTINE INSPECTION BY THE RESIDENT INSPECTOR INVOLVED THE AREAS OF LICENSEE EVENT REPORT (LER) REVIEW, ENGINEERING SAFETY FEATURES (ESF) WALKDOWN, OPERATIONAL SAFETY VERIFICATION, MONTHLY MAINTENANCE, MONTHLY SURVEILLANCE AND SAFEGUARDS. ONE VIOLATION WAS IDENTIFIED - FAILURE TO FOLLOW DESIGN CHANGE PROCEDURES FOR THE BATTERY INSTALLATION.

INSPECTION JUNE 17-19 (86-16): THIS WAS A ROUTINE, ANNOUNCED INSPECTION OF THE LICENSEE'S PERFORMANCE AND CAPABILITIES DURING AN EXERCISE OF THE EMERGENCY PLAN AND PROCEDURES. OF THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JUNE 2 - JULY 6 (86-17): THIS ROUTINE INSPECTION BY THE RESIDENT INSPECTORS INVOLVED THE FOLLOWING AREAS: PLANT STATUS, INSPECTOR FOLLOW-UP AND UNRESOLVED ITEMS, LICENSEE EVENT REPORT (LER) FOLLOWUP, ROUTINE INSPECTION, MONTHLY MAINTENANCE OBSERVATION, MONTHLY SURVEILLANCE OBSERVATION, ESF SYSTEM WALKDOWN, AND POTENTIAL GENERIC ITEMS. TWO VIOLATIONS WERE IDENTIFIED FAILURE TO REQUIRE A REVIEW OF DESIGN CHANGE ACCEPTANCE TESTS FOR TECHNICAL SPECIFICATION REQUIREMENTS AND FAILURE TO PERFORM A WRITTEN SAFETY EVALUATION.

ENFORCEMENT SUMMARY

NONE

Report Period JUL 1986

I N S P E C T I O N S T A T U S - (CONTINUED)

* NORTH ANNA 2 *

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

DIESEL GENERATOR RELIABILITY PROBLEM - LICENSEE IS INVESTIGATING.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

NORMAL OPERATION.

LAST IE SITE INSPECTION DATE: JUNE 2 - JULY 6, 1986 +

INSPECTION REPORT NO: 50-339/86-17 +

R E P O R T S F R O M L I C E N S E E

=====			
NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT

86-006	04/16/86	05/15/86	SPECIFIC GRAVITIES OF VARIOUS BATTERY CELLS ON THREE OF FOUR DC BUSES BELOW TECHNICAL SPECIFICATION, UNIT SHUTDOWN.
86-007	04/16/86	05/09/86	REACTOR TRIP CAUSED BY TURBINE FIRST STAGE PRESSURE SPIKE; DUE TO THROTTLE STOP VALVE LIMIT SWITCHES INDICATING A CLOSED POSITION ON ALL FOUR VALVES.
=====			

1. Docket: 50-269 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/86 Outage + On-line Hrs: 744.0

3. Utility Contact: J. A. REAVIS (704) 373-7567

4. Licensed Thermal Power (MWT): 2568

5. Nameplate Rating (Gross MWe): 1038 X 0.9 = 934

6. Design Electrical Rating (Net MWe): 887

7. Maximum Dependable Capacity (Gross MWe): 899

8. Maximum Dependable Capacity (Net MWe): 860

9. If Changes Occur Above Since Last Report, Give Reasons: NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____


NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,087.0</u>	<u>114,336.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>2,918.9</u>	<u>83,365.6</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>2,859.6</u>	<u>79,989.7</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,911,216</u>	<u>7,119,737</u>	<u>193,419,937</u>
18. Gross Elec Ener (MWH)	<u>656,210</u>	<u>2,463,680</u>	<u>67,210,520</u>
19. Net Elec Ener (MWH)	<u>625,931</u>	<u>2,331,825</u>	<u>63,730,074</u>
20. Unit Service Factor	<u>100.0</u>	<u>56.2</u>	<u>70.0</u>
21. Unit Avail Factor	<u>100.0</u>	<u>56.2</u>	<u>70.0</u>
22. Unit Cap Factor (MDC Net)	<u>97.8</u>	<u>53.3</u>	<u>64.7*</u>
23. Unit Cap Factor (DER Net)	<u>94.8</u>	<u>51.7</u>	<u>62.9*</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>9.0</u>	<u>14.7</u>
25. Forced Outage Hours	<u>.0</u>	<u>283.8</u>	<u>12,823.3</u>
26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):	<u>NONE</u>		

27. If Currently Shutdown Estimated Startup Date: N/A

* OCONEE 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
OCONEE 1



JULY 1986

* Item calculated with a Weighted Average

Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

 * OCONEE 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
32-P	07/25/86	S	0.0	B	5		CC	VALVEX	TURBINE CONTROL & STOP VALVE MOVEMENT PT'S.
33-P	07/25/86	F	0.0	A	5		CA	INSTRU	CHANGE OUT BAD DIODE ON ROD GROUP 6.

 * SUMMARY *

 OCONEE 1 HAD NO SHUTDOWNS AND 2 POWER REDUCTIONS IN JULY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* OCONEE 1 *

FACILITY DATA

Report Period JUL 1986

FACILITY DESCRIPTION

LOCATION
STATE.....SOUTH CAROLINA

COUNTY.....OCONEE

DIST AND DIRECTION FROM
NEAREST POPULATION CTR...30 MI W OF
GREENVILLE, SC

TYPE OF REACTOR.....PWR

DATE INITIAL CRITICALITY...APRIL 19, 1973

DATE ELEC ENER 1ST GENER...MAY 6, 1973

DATE COMMERCIAL OPERATE....JULY 15, 1973

CONDENSER COOLING METHOD...ONCE THRU

CONDENSER COOLING WATER...LAKE KEOWEE

ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....DUKE POWER

CORPORATE ADDRESS.....422 SOUTH CHURCH STREET
CHARLOTTE, NORTH CAROLINA 28242

CONTRACTOR
ARCHITECT/ENGINEER.....DUKE & BECHTEL

NUC STEAM SYS SUPPLIER...BABCOCK & WILCOX

CONSTRUCTOR.....DUKE POWER

TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II

IE RESIDENT INSPECTOR.....J. BRYANT

LICENSING PROJ MANAGER.....H. PASTIS
DOCKET NUMBER.....50-269

LICENSE & DATE ISSUANCE....DPR-38, FEBRUARY 6, 1973

PUBLIC DOCUMENT ROOM.....OCONEE COUNTY LIBRARY
501 W. SOUTH BROAD ST.
WALHALLA, SOUTH CAROLINA 29691

INSPECTION STATUS

INSPECTION SUMMARY

+ INSPECTION MAY 20 - JUNE 9 (86-18): THIS ROUTINE, ANNOUNCED INSPECTION WAS CONDUCTED ONSITE IN THE AREAS OF OPERATIONS, SURVEILLANCE, MAINTENANCE, VERIFICATION OF ENGINEERED SAFETY FEATURES LINEUPS, FOLLOWUP OF EVENTS, AND FOLLOWUP OF UNRESOLVED AND INSPECTOR FOLLOWUP ITEMS. OF THE SIX AREAS INSPECTED, ONE ITEM OF NONCOMPLIANCE WAS IDENTIFIED: VIOLATION 269/86-18-02, FAILURE TO FOLLOW PROCEDURE DURING VALVE SURVEILLANCE.

INSPECTION JUNE 23-26 (86-19): THIS ROUTINE, UNANNOUNCED INSPECTION INVOLVED ONSITE REVIEW OF QUALITY CONTROL AND CONFIRMATORY MEASUREMENTS INCLUDING: REVIEW OF THE LABORATORY QUALITY PROGRAM; REVIEW OF CHEMICAL AND RADIOCHEMICAL PROCEDURES; REVIEW OF QUALITY CONTROL RECORDS AND LOGS; AND COMPARISON OF THE RESULTS OF SPLIT SAMPLES ANALYZED BY THE LICENSEE AND NRC REGION II MOBILE LABORATORY. IN THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

CONTRARY TO TS 6.4.1, ON APRIL 4, 1986, DURING SURVEILLANCE TESTING ON VALVE 1LP-21, THE TECHNICIAN INACCURATELY SIGNED THE PROCEDURE STEP STATING THAT ACCEPTANCE CRITERIA HAD BEEN MET; WHEREAS, IN FACT THE VALVE HAD NOT PASSED ITS EXERCISE TEST. THE VALVE REQUIRED 16 SECONDS TO OPEN WHILE THE MAXIMUM STROKE TIME ALLOWED BY THE PROCEDURE IS 15 SECONDS. THE COMPLETED TEST WAS SUBSEQUENTLY REVIEWED AND APPROVED. WHILE THE VALVE WAS TECHNICALLY INOPERABLE DURING THE PERIOD APRIL 4 UNTIL IT PASSED A SURVEILLANCE TEST ON JUNE 4, THE OPERABILITY OF THE LOW PRESSURE INJECTION SYSTEM WAS NOT IN QUESTION SINCE THE VALVE IS OPEN FOR

INSPECTION STATUS - (CONTINUED)

* OCONEE 1 *

NORMAL OPERATION. THE VALVE WOULD BE REQUIRED TO BE OPEN FOLLOWING ENGINEERED SAFETY FEATURES ACTUATION.
(8601 4)

SYSTEMS AND COMPONENT PROBLEMS:

FACILITY ITEMS (PLANS AND PROCEDURES):

MANAGERIAL ITEMS:

PLANT STATUS:

POWER OPERATION.

LAST IE SITE INSPECTION DATE: JUNE 23-26, 1986 +

INSPECTION REPORT NO: 50-269/86-19 +

REPORTS FROM LICENSEE

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
86-006	04/10/86	05/12/86	END OF CYCLE HOT FULL POWER LOWER MODERATOR TEMPERATURE COEFFICIENT; CAUSE - A DISPARITY BETWEEN MEASURED DATA AND CALCULATED VALVE TABULATED IN 01C9 RELOAD REPORT.
86-007	05/02/86	06/02/86	TWO CHANNELS OF REACTOR PROTECTIVE SYSTEM INOPERABLE AT THE SAME TIME DURING ADJUSTMENT OF HI-FLUX TRIP SETPOINT; CAUSE - FAILURE TO PROPERLY TAG INOPERABLE MODULE.
86-009	06/13/86	07/14/86	KEOWEE BATTERY RACKS OUTSIDE OF SEISMIC DESIGN BASIS; CAUSE - POOR COMMUNICATION BETWEEN CLEARANCE BETWEEN END CELL AND STRINGER.

1. Docket: 50-270 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/85 Outage + On-line Hrs: 744.0

3. Utility Contact: J. A. REAVIS (704) 373-7567

4. Licensed Thermal Power (MWT): 2568

5. Nameplate Rating (Gross MWe): 1038 X 0.9 = 934

6. Design Electrical Rating (Net MWe): 887

7. Maximum Dependable Capacity (Gross MWe): 899

8. Maximum Dependable Capacity (Net MWe): 860

9. If Changes Occur Above Since Last Report, Give Reasons:

NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,087.0</u>	<u>104,256.0</u>
13. Hours Reactor Critical	<u>736.0</u>	<u>5,071.0</u>	<u>77,909.1</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>725.8</u>	<u>5,047.7</u>	<u>76,649.5</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,841,568</u>	<u>12,871,231</u>	<u>183,275,133</u>
18. Gross Elec Ener (MWH)	<u>616,060</u>	<u>4,365,530</u>	<u>62,417,871</u>
19. Net Elec Ener (MWH)	<u>586,641</u>	<u>4,175,925</u>	<u>59,343,486</u>
20. Unit Service Factor	<u>97.6</u>	<u>99.2</u>	<u>73.5</u>
21. Unit Avail Factor	<u>97.6</u>	<u>99.2</u>	<u>73.5</u>
22. Unit Cap Factor (MDC Net)	<u>91.7</u>	<u>95.5</u>	<u>66.0*</u>
23. Unit Cap Factor (DER Net)	<u>88.9</u>	<u>92.5</u>	<u>64.2*</u>
24. Unit Forced Outage Rate	<u>2.4</u>	<u>.8</u>	<u>13.1</u>
25. Forced Outage Hours	<u>18.2</u>	<u>39.3</u>	<u>10,713.1</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


REFUELING - AUGUST 14, 1986 - 9 WEEKS.

27. If Currently Shutdown Estimated Startup Date: N/A

* OCONEE 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

OCONEE 2



JULY 1986

* Item calculated with a Weighted Average

Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

 * OCONEE 2 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
34-P	07/01/86	F	0.0	A	5		HB	HTEXCH	SECOND STAGE REHEATER VALVED OUT.
35-P	07/04/86	S	0.0	B	5		CC	VALVEX	CONTROL VALVE & STOP VALVE MOVEMENT PT'S.
36-P	07/04/86	F	0.0	A	5		HB	HTEXCH	SECOND STAGE REHEATER VALVED OUT.
3	07/08/86	F	9.6	A	3		IF	INSTRU	REACTOR, TURBINE & FEEDWATER PUMP TRIP ON STEAM GENERATOR "2B" HIGH LEVEL.
37-P	07/09/86	S	0.0	B	5		SF	PUMPXX	HOLDING POWER DUE TO HIGH PRESSURE INJECTION PUMP "2B" PERFORMANCE TESTING.
38-P	07/09/86	F	0.0	A	5		HB	HTEXCH	SECOND STAGE REHEATER VALVED OUT.
39-P	07/22/86	F	0.0	A	5		HH	PUMPXX	REDUCED REACTOR POWER DUE TO "2D2" HEATER DRAIN PUMP OIL LEAK.
40-P	07/22/86	F	0.0	A	5		HB	HTEXCH	SECOND STAGE REHEATER VALVED OUT.
4	07/23/86	F	8.6	A	3		CB	INSTRU	REACTOR/TURBINE TRIP FOLLOWING LOSS OF "A" REACTOR LOOP FLOW TRANSMITTER.
41-P	07/24/86	F	0.0	A	5		HH	VALVEX	HOLDING POWER DUE TO OPENING "2D1" HEATER DRAIN PUMP DISCHARGE CHECK VALVE.
42-P	07/24/86	F	0.0	A	5		HB	HTEXCH	SECOND STAGE REHEATER VALVED OUT.

 * SUMMARY *

 OCONEE 2 INCURRED 2 SHUTDOWNS AND SEVERAL POWER REDUCTIONS IN JULY AS DISCUSSED ABOVE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* OCONEE 2 *

FACILITY DATA

Report Period JUL 1986

FACILITY DESCRIPTION

LOCATION
STATE.....SOUTH CAROLINA
COUNTY.....OCONEE
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...30 MI W OF
GREENVILLE, SC
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...NOVEMBER 11, 1973
DATE ELEC ENER 1ST GENER...DECEMBER 5, 1973
DATE COMMERCIAL OPERATE...SEPTEMBER 9, 1974
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...LAKE KEOWEE
ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....DUKE POWER
CORPORATE ADDRESS.....422 SOUTH CHURCH STREET
CHARLOTTE, NORTH CAROLINA 28242
CONTRACTOR
ARCHITECT/ENGINEER.....DUKE & BECHTEL
NUC STEAM SYS SUPPLIER...BABCOCK & WILCOX
CONSTRUCTOR.....DUKE POWER
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
IE RESIDENT INSPECTOR.....J. BRYANT
LICENSING PROJ MANAGER.....H. PASTIS
DOCKET NUMBER.....50-270
LICENSE & DATE ISSUANCE...DPR-47, OCTOBER 6, 1973
PUBLIC DOCUMENT ROOM.....OCONEE COUNTY LIBRARY
501 W. SOUTH BROAD ST.
WALHALLA, SOUTH CAROLINA 29691

INSPECTION STATUS

INSPECTION SUMMARY

+ INSPECTION MAY 20 - JUNE 9 (86-13): THIS ROUTINE, ANNOUNCED INSPECTION WAS CONDUCTED ONSITE IN THE AREAS OF OPERATIONS, SURVEILLANCE, MAINTENANCE, VERIFICATION OF ENGINEERED SAFETY FEATURES LINEUPS, FOLLOWUP OF EVENTS, AND FOLLOWUP OF UNRESOLVED AND INSPECTOR FOLLOWUP ITEMS. OF THE SIX AREAS INSPECTED, ONE ITEM OF NONCOMPLIANCE WAS IDENTIFIED: VIOLATION 269/86-18-02, FAILURE TO FOLLOW PROCEDURE DURING VALVE SURVEILLANCE.

INSPECTION JUNE 23-26 (86-19): THIS ROUTINE, UNANNOUNCED INSPECTION INVOLVED ONSITE REVIEW OF QUALITY CONTROL AND CONFIRMATORY MEASUREMENTS INCLUDING: REVIEW OF THE LABORATORY QUALITY PROGRAM; REVIEW OF CHEMICAL AND RADIOCHEMICAL PROCEDURES; REVIEW OF QUALITY CONTROL RECORDS AND LOGS; AND COMPARISON OF THE RESULTS OF SPLIT SAMPLES ANALYZED BY THE LICENSEE AND NRC REGION II MOBILE LABORATORY. IN THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

Report Period JUL 1986

I N S P E C T I O N S T A T U S - (CONTINUED)

* OCONEE 2 *

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

POWER OPERATION.

LAST IE SITE INSPECTION DATE: JUNE 23-26, 1986 +

INSPECTION REPORT NO: 50-270/86-19 +

R E P O R T S F R O M L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT

NONE.			
=====			

1. Docket: 50-287 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/86 Outage + On-line Hrs: 744.0

3. Utility Contact: J. A. REAVIS (704) 373-7567

4. Licensed Thermal Power (MWt): 2568

5. Nameplate Rating (Gross MWe): 1038 X 0.9 = 934

6. Design Electrical Rating (Net MWe): 887

7. Maximum Dependable Capacity (Gross MWe): 899

8. Maximum Dependable Capacity (Net MWe): 860

9. If Changes Occur Above Since Last Report, Give Reasons:

NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,087.0</u>	<u>101,903.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>5,083.8</u>	<u>74,455.3</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>5,063.3</u>	<u>73,196.5</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,807,056</u>	<u>12,732,560</u>	<u>179,401,005</u>
18. Gross Elec Ener (MWH)	<u>597,760</u>	<u>4,359,380</u>	<u>61,887,434</u>
19. Net Elec Ener (MWH)	<u>569,299</u>	<u>4,173,925</u>	<u>58,953,282</u>
20. Unit Service Factor	<u>100.0</u>	<u>99.5</u>	<u>71.8</u>
21. Unit Avail Factor	<u>100.0</u>	<u>99.5</u>	<u>71.8</u>
22. Unit Cap Factor (MDC Net)	<u>89.0</u>	<u>95.4</u>	<u>67.1*</u>
23. Unit Cap Factor (DER Net)	<u>86.3</u>	<u>92.5</u>	<u>65.3*</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.5</u>	<u>13.7</u>
25. Forced Outage Hours	<u>.0</u>	<u>23.7</u>	<u>11,789.1</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):

NONE

27. If Currently Shutdown Estimated Startup Date: N/A

* OCONEE 3 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT OCONEE 3



JULY 1986

* Item calculated with a Weighted Average

Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

 * OCONEE 3 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
20-P	07/15/86	F	0.0	A	5		HH	PUMPXX	"3D2" HEATER DRAIN PUMP REPAIR.

 * SUMMARY *

OCONEE 3 HAD NO OUTAGES AND 1 POWER REDUCTION IN JULY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* OCONEE 3 *

FACILITY DATA

Report Period JUL 1986

FACILITY DESCRIPTION

LOCATION
STATE.....SOUTH CAROLINA
COUNTY.....OCONEE
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...30 MI W OF
GREENVILLE, SC
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...SEPTEMBER 5, 1974
DATE ELEC ENER 1ST GENER...SEPTEMBER 18, 1974
DATE COMMERCIAL OPERATE...DECEMBER 16, 1974
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...LAKE KEOWEE
ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....DUKE POWER
CORPORATE ADDRESS.....422 SOUTH CHURCH STREET
CHARLOTTE, NORTH CAROLINA 28242
CONTRACTOR
ARCHITECT/ENGINEER.....DUKE & BECHTEL
NUC STEAM SYS SUPPLIER...BABCOCK & WILCOX
CONSTRUCTOR.....DUKE POWER
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
IE RESIDENT INSPECTOR.....J. BRYANT
LICENSING PROJ MANAGER.....H. PASTIS
DOCKET NUMBER.....50-287
LICENSE & DATE ISSUANCE....DPR-55, JULY 19, 1974
PUBLIC DOCUMENT ROOM.....OCONEE COUNTY LIBRARY
501 W. SOUTH BROAD ST.
WALHALLA, SOUTH CAROLINA 29691

INSPECTION STATUS

INSPECTION SUMMARY

+ INSPECTION MAY 20 - JUNE 9 (86-18): THIS ROUTINE, ANNOUNCED INSPECTION WAS CONDUCTED ONSITE IN THE AREAS OF OPERATIONS, SURVEILLANCE, MAINTENANCE, VERIFICATION OF ENGINEERED SAFETY FEATURES LINEUPS, FOLLOWUP OF EVENTS, AND FOLLOWUP OF UNRESOLVED AND INSPECTOR FOLLOWUP ITEMS. OF THE SIX AREAS INSPECTED, ONE ITEM OF NONCOMPLIANCE WAS IDENTIFIED: VIOLATION 269/86-18-02, FAILURE TO FOLLOW PROCEDURE DURING VALVE SURVEILLANCE.

INSPECTION JUNE 23-26 (86-19): THIS ROUTINE, UNANNOUNCED INSPECTION INVOLVED ONSITE REVIEW OF QUALITY CONTROL AND CONFIRMATORY MEASUREMENTS INCLUDING: REVIEW OF THE LABORATORY QUALITY PROGRAM; REVIEW OF CHEMICAL AND RADIOCHEMICAL PROCEDURES; REVIEW OF QUALITY CONTROL RECORDS AND LOGS; AND COMPARISON OF THE RESULTS OF SPLIT SAMPLES ANALYZED BY THE LICENSEE AND NRC REGION II MOBILE LABORATORY. IN THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

INSPECTION STATUS - (CONTINUED)

```

*****
*                                OCONEE 3                                *
*****

```

SYSTEMS AND COMPONENT PROBLEMS:

FACILITY ITEMS (PLANS AND PROCEDURES):

MANAGERIAL ITEMS:

PLANT STATUS:

POWER OPERATION.

LAST IE SITE INSPECTION DATE: JUNE 23-26, 1986 +

INSPECTION REPORT NO: 50-287/86-19 +

REPORTS FROM LICENSEE

[illegible]

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
--------	------------------	-------------------	---------

NONE.

NONE.

1. Docket: 50-219 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/86 Outage + On-line Hrs: 744.0

3. Utility Contact: JOSEPH R. MOLNAR (609) 971-4699

4. Licensed Thermal Power (MWt): 1930

5. Nameplate Rating (Gross MWe): 722 X .9 = 650

6. Design Electrical Rating (Net MWe): 650

7. Maximum Dependable Capacity (Gross MWe): 650

8. Maximum Dependable Capacity (Net MWe): 620

9. If Changes Occur Above Since Last Report, Give Reasons: NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____


11. Reasons for Restrictions, If Any: NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,087.0</u>	<u>145,559.0</u>
13. Hours Reactor Critical	<u>.0</u>	<u>2,311.5</u>	<u>95,453.9</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>448.5</u>	<u>1,208.0</u>
15. Hrs Generator On-Line	<u>.0</u>	<u>2,273.9</u>	<u>92,332.0</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>452.8</u>	<u>1,761.4</u>
17. Gross Therm Ener (MWH)	<u>0</u>	<u>4,074,338</u>	<u>153,028,338</u>
18. Gross Elec Ener (MWH)	<u>0</u>	<u>1,371,480</u>	<u>51,662,165</u>
19. Net Elec Ener (MWH)	<u>-1,840</u>	<u>1,311,153</u>	<u>49,621,646</u>
20. Unit Service Factor	<u>.0</u>	<u>44.7</u>	<u>63.4</u>
21. Unit Avail Factor	<u>.0</u>	<u>53.6</u>	<u>64.6</u>
22. Unit Cap Factor (MDC Net)	<u>.0</u>	<u>41.6</u>	<u>55.0*</u>
23. Unit Cap Factor (DER Net)	<u>.0</u>	<u>39.7</u>	<u>52.4</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>6.3</u>	<u>12.3</u>
25. Forced Outage Hours	<u>0</u>	<u>152.3</u>	<u>11,057.5</u>
26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration): * <u>NONE</u>			

27. If Currently Shutdown Estimated Startup Date: 10/12/86

* OYSTER CREEK 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
OYSTER CREEK 1



JULY 1986

* Item calculated with a Weighted Average

Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

 * OYSTER CREEK 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
46	04/12/86	S	744.0	C	4		RC	FUELXX	REFUELING/MAINTENANCE OUTAGE CONTINUES.

 * SUMMARY *

 OYSTER CREEK 1 REMAINS SHUTDOWN FOR REFUELING AND MAINTENANCE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* OYSTER CREEK 1 *

FACILITY DATA

Report Period JUL 1986

FACILITY DESCRIPTION

LOCATION
STATE.....NEW JERSEY
COUNTY.....OCEAN
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...9 MI S OF
TOMS RIVER, NJ
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...MAY 3, 1969
DATE ELEC ENER 1ST GENER...SEPTEMBER 23, 1969
DATE COMMERCIAL OPERATE...DECEMBER 1, 1969
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...BARNEGAT BAY
ELECTRIC RELIABILITY
COUNCIL.....MID-ATLANTIC
AREA COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....GPU NUCLEAR CORPORATION
CORPORATE ADDRESS.....100 INTERPACE PARKWAY
PARSIPPANY, NEW JERSEY 07054
CONTRACTOR
ARCHITECT/ENGINEER.....BURNS & ROE
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....BURNS & ROE
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I
IE RESIDENT INSPECTOR.....W. BATEMAN
LICENSING PROJ MANAGER.....J. DONOHEW
DOCKET NUMBER.....50-219
LICENSE & DATE ISSUANCE...DPR-16, AUGUST 1, 1969
PUBLIC DOCUMENT ROOM.....OCEAN COUNTY LIBRARY
101 WASHINGTON STREET
TOMS RIVER, NEW JERSEY 08753

INSPECTION STATUS

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

10 CFR 50, APPENDIX B, CRITERION V AND SECTION 3 OF THE OYSTER CREEK OPERATION QUALITY ASSURANCE PLAN REQUIRE, IN PART, THAT ACTIVITIES AFFECTING QUALITY BE PRESCRIBED BY AND ACCOMPLISHED IN ACCORDANCE WITH DOCUMENTED INSTRUCTIONS, PROCEDURES, AND DRAWINGS. CONTRARY TO THE ABOVE, AS OF MARCH 27, 1986, THE LICENSEE FAILED TO: (1) FOLLOW THE REQUIREMENTS OF TECH FUNCTIONS PROCEDURE EMP-014, REV. 1-01, PROJECT REVIEWS, BY NOT ISSUING A MEMORANDUM OF CONCURRENCE FOR MODIFICATION PACKAGES BA 402786 AND BA 402775. (2) ASSIGN A PRELIMINARY ENGINEERING DESIGN REVIEW CHAIRMAN FOR BA 402786 WHO WAS INDEPENDENT OF THE ENGINEERING OR MANAGING OF THE DESIGN PACKAGE AS REQUIRED BY EMP-014. (3) ENFORCE THE MANDATORY ATTENDANCE REQUIREMENTS FOR THE OPERABILITY, MAINTAINABILITY, AND CONSTRUCTABILITY REVIEW FOR BA 402786 AND BA 402775. (4) PROPERLY SCHEDULE THE RESPONSIBLE TECHNICAL REVIEW PRIOR TO THE SAFETY EVALUATION FOR BA 402775 AS REQUIRED BY TECH FUNCTIONS PROCEDURES LP-009, REV. 1-00, INDEPENDENT SAFETY REVIEWS AND EP-016, REV. 0, NUCLEAR SAFETY/ENVIRONMENTAL IMPACT EVALUATIONS. TECH SPEC 6.8.1 REQUIRES THAT WRITTEN PROCEDURES SHALL BE ESTABLISHED, IMPLEMENTED AND MAINTAINED. CONTRARY TO ABOVE, AS OF 4/3/86, STAT PROC NO. 125 WAS NOT BEING MAINTAINED. SIGNIFICANT DISCREPANCIES EXISTED BETWEEN PROCEDURAL DESCRIPTIONS AND REQUIREMENTS AND WAY PLANT ENGINEERING ORGAN WAS CONDUCTING ACTIVITIES. THESE DISCREPANCIES INCLUDED: (1) DESCRIPTION OF ORGANIZATION AND RESPONSIBILITIES, (2) PERFORMANCE OF ENGINEERING TASKS INCLUDING INITIAL REVIEW AND ASSIGNMENT OF ENGINEERING TASKS, ACKNOWLEDGEMENT TO REQUESTOR AND CLOSE OUT OF TASKS INCLUDING

Report Period JUL 1986

I N S P E C T I O N S T A T U S - (CONTINUED)

* OYSTER CREEK 1 *

ENFORCEMENT SUMMARY

RESPONSE TO REQUESTOR, (3) MAINTENANCE OF RECORDS, AND (4) PRIORITIZATION OF PLANT ENGINEERING TASK ASSIGNMENTS. CONTRARY TO ABOVE, AS OF 4/4/86, STAT PROC NO. 125 WAS NOT ADEQUATELY IMPLEMENTED IN THAT A PLANT ENGINEERING WORK REQUEST WRITTEN 8/19/85 BY PLANT MATERIAL DEPT AND RECEIVED BY PLANT ENGINEERING ON 8/20/85 HAD BEEN GIVEN A PRIORITY TWO RATING AND WAS NOT SCHEDULED FOR REVIEW. THE ISSUE INVOLVED LACK OF PLANS AND PROCEDURES GOVERNING MOVEMENT OF HEAVY LOADS (NUREG-0612) USING A PORTABLE CRANE AT THE INTAKE STRUCTURE IN THE VICINITY OF THE EMERGENCY SERVICE WATER PUMPS. A SAFETY EVALUATION, IN PART, DOCUMENTING THE LICENSEE'S COMMITMENTS REGARDING MOVEMENT OF HEAVY LOADS, WAS ISSUED 6/21/83. IN THIS DOCUMENT IT WAS EXPLAINED THAT MOVEMENT OF HEAVY LOADS AT THE INTAKE WAS NOT A CONCERN BECAUSE THE INTAKE GANTRY CRANE HAD BEEN REMOVED BUT THAT, IF AT SOME TIME IN THE FUTURE THIS CRANE IS PLACED BACK IN SERVICE, AN EVALUATION WOULD BE PERFORMED TO ENSURE THAT NUREG-0612 CRITERIA ARE SATISFIED. ALTHOUGH THE GANTRY CRANE HAS NOT BEEN PLACED IN SERVICE, THE USE OF A PORTABLE CRANE TO MOVE HEAVY LOADS IS AN EQUIVALENT SITUATION.

(8600 4)

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S F R O M L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
--------	------------------	-------------------	---------

NO INPUT PROVIDED.

=====

1. Docket: 50-255 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/86 Outage + On-line Hrs: 744.0

3. Utility Contact: P. A. SMITH (616) 764-8913

4. Licensed Thermal Power (MWt): 2530

5. Nameplate Rating (Gross MWe): 955 X 0.85 = 812

6. Design Electrical Rating (Net MWe): 805

7. Maximum Dependable Capacity (Gross MWe): 770

8. Maximum Dependable Capacity (Net MWe): 730

9. If Changes Occur Above Since Last Report, Give Reasons: NONE


10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any: NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,087.0</u>	<u>128,126.0</u>
13. Hours Reactor Critical	<u>.0</u>	<u>1,490.5</u>	<u>69,790.9</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>.0</u>	<u>1,324.4</u>	<u>66,283.6</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>0</u>	<u>2,760,600</u>	<u>138,362,640</u>
18. Gross Elec Ener (MWH)	<u>0</u>	<u>896,530</u>	<u>43,113,930</u>
19. Net Elec Ener (MWH)	<u>0</u>	<u>841,244</u>	<u>40,582,604</u>
20. Unit Service Factor	<u>.0</u>	<u>26.0</u>	<u>51.7</u>
21. Unit Avail Factor	<u>.0</u>	<u>26.0</u>	<u>51.7</u>
22. Unit Cap Factor (MDC Net)	<u>.0</u>	<u>22.7</u>	<u>43.4</u>
23. Unit Cap Factor (DER Net)	<u>.0</u>	<u>20.5</u>	<u>39.3</u>
24. Unit Forced Outage Rate	<u>100.0</u>	<u>63.3</u>	<u>32.5</u>
25. Forced Outage Hours	<u>744.0</u>	<u>2,285.1</u>	<u>17,841.2</u>
26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):	<u>NONE</u>		
27. If Currently Shutdown Estimated Startup Date:	<u>09/15/86</u>		

 * PALISADES *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
 PALISADES



JULY 1986

Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

 * PALISADES *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
7	05/19/86	F	744.0	A	4				TURBINE EHC CONTROL SYSTEM PROBLEMS.

 * SUMMARY *

 PALISADES REMAINS SHUT DOWN FOR TURBINE EHC CONTROL PROBLEMS.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* PALISADES *

FACILITY DATA

Report Period JUL 1986

FACILITY DESCRIPTION

UTILITY & CONTRACTOR INFORMATION

LOCATION
STATE.....MICHIGAN
COUNTY.....VANBUREN
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...5 MI S OF
SOUTH HAVEN, MI
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...MAY 24, 1971
DATE ELEC ENER 1ST GENER...DECEMBER 31, 1971
DATE COMMERCIAL OPERATE...DECEMBER 31, 1971
CONDENSER COOLING METHOD...COOLING TOWERS
CONDENSER COOLING WATER...LAKE MICHIGAN
ELECTRIC RELIABILITY
COUNCIL.....EAST CENTRAL AREA
RELIABILITY COORDINATION
AGREEMENT

UTILITY
LICENSEE.....CONSUMERS POWER
CORPORATE ADDRESS.....212 WEST MICHIGAN AVENUE
JACKSON, MICHIGAN 49201
CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...COMBUSTION ENGINEERING
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III
IE RESIDENT INSPECTOR.....E. SWANSON
LICENSING PROJ MANAGER.....T. WAMBACH
DOCKET NUMBER.....50-255
LICENSE & DATE ISSUANCE....DPR-20, OCTOBER 16, 1972
PUBLIC DOCUMENT ROOM.....VAN ZOEREN LIBRARY
HOPE COLLEGE
HOLLAND, MICHIGAN
49423

INSPECTION STATUS

INSPECTION SUMMARY

INSPECTION ON JUNE 16-20 (86012): ROUTINE, UNANNOUNCED INSPECTION OF THE RADIATION PROTECTION PROGRAM INCLUDING: ORGANIZATION AND MANAGEMENT CONTROLS, INTERNAL AND EXTERNAL EXPOSURE CONTROLS, CONTROL OF RADIOACTIVE MATERIALS AND CONTAMINATION, TRAINING AND QUALIFICATION, AUDITS AND APPRAISALS, SOLID RADWASTE, TRANSPORTATION, AND THE ALARA PROGRAM. ALSO, HVAC FILTER HOUSING DRAIN SYSTEMS, THE DECONTAMINATION PROGRAM, IE INFORMATION NOTICE NO. 86-22, TERMINATION DOSE RECORDS, AND OPEN ITEMS WERE REVIEWED. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION ON JULY 1-3 (86020): ROUTINE UNANNOUNCED INSPECTION OF GASEOUS AND LIQUID RADIOACTIVE EFFLUENTS INCLUDING: EFFLUENT RELEASES; RECORDS AND REPORTS OF EFFLUENTS; EFFLUENT CONTROL INSTRUMENTATION; GASEOUS EFFLUENT FILTRATION; AUDITS; AND FOLLOWUP OF A VIOLATION AND TWO OPEN ITEMS. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

INSPECTION STATUS - (CONTINUED)

```

XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX
X                PALISADES                X
XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX

```

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

JR SCHEPERS IS THE CHEMISTRY SUPERINTENDENT IN THE OPERATIONS DEPARTMENT.

PLANT STATUS:

THE UNIT IS IN COLD SHUTDOWN

LAST IE SITE INSPECTION DATE: 08/20/86

INSPECTION REPORT NO: 86025

REPORTS FROM LICENSEE

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
86-19	06/10/86	07/10/86	INADVERTENT EMERGENCY DIESEL GENERATOR ACTUATION
86-20	06/17/86	07/17/86	INADVERTENT EMERGENCY DIESEL GENERATOR ACTUATION

1. Docket: 50-528 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/86 Outage + On-line Hrs: 744.0

3. Utility Contact: J. M. COLVILLE (602) 932-5300 X6593

4. Licensed Thermal Power (Mwt): 3800

5. Nameplate Rating (Gross MWe): 1403

6. Design Electrical Rating (Net MWe): 1221

7. Maximum Dependable Capacity (Gross MWe): 1303

8. Maximum Dependable Capacity (Net MWe): 1221

9. If Changes Occur Above Since Last Report, Give Reasons:
DER CHANGED TO REFLECT LIC. THERM. PWR.

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>4,055.0</u>	<u>4,055.0</u>
13. Hours Reactor Critical	<u>506.9</u>	<u>1,958.2</u>	<u>1,958.2</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>498.9</u>	<u>1,905.8</u>	<u>1,905.8</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,814,285</u>	<u>6,897,623</u>	<u>6,897,623</u>
18. Gross Elec Ener (MWH)	<u>626,200</u>	<u>2,377,800</u>	<u>2,377,800</u>
19. Net Elec Ener (MWH)	<u>572,632</u>	<u>2,188,757</u>	<u>2,188,757</u>
20. Unit Service Factor	<u>67.1</u>	<u>47.0</u>	<u>47.0</u>
21. Unit Avail Factor	<u>67.1</u>	<u>47.0</u>	<u>47.0</u>
22. Unit Cap Factor (MDC Net)	<u>63.0</u>	<u>44.4</u>	<u>44.2</u>
23. Unit Cap Factor (DER Net)	<u>63.0</u>	<u>43.7</u>	<u>44.2</u>
24. Unit Forced Outage Rate	<u>32.9</u>	<u>45.5</u>	<u>45.5</u>
25. Forced Outage Hours	<u>245.1</u>	<u>1,589.4</u>	<u>1,589.4</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

 * PALO VERDE 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

PALO VERDE 1



JULY 1986

Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

 * PALO VERDE 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
5	07/12/86	F	245.1	A	3	86-047	JC	PD	RX TRIP ON CHANNEL "A" & "B" LOW SG 2 RC FLOW.

 * SUMMARY *

PALO VERDE 1 INCURRED 1 SHUTDOWN IN JULY BECAUSE OF A REACTOR TRIP.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

PALO VERDE 1

Report Period JUL 1986

PAGE 2-260

* PALO VERDE 1 *

INSPECTION SUMMARY

* INSPECTION ON JUNE 23 - JULY 16, 1986 (REPORT NO. 50-528/86-22) AREAS INSPECTED: ROUTINE, UNANNOUNCED INSPECTION OF LICENSEE ACTION ON PREVIOUS INSPECTION FINDINGS, RADIATION PROTECTION, PLANT CHEMISTRY, AND RADWASTE ORGANIZATION AND MANAGEMENT CONTROLS, INTERNAL EXPOSURE CONTROL, CONTAINMENT ATMOSPHERE MONITOR RU-1, REVIEW OF LICENSEE'S REPORTS, FOLLOWUP ON IE INFORMATION NOTICES AND FACILITY TOURS. DURING THIS INSPECTION, VARIOUS INSPECTION PROCEDURES WERE UTILIZED.

RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED. ONE UNRESOLVED ITEM RELATING TO THE OPERABILITY OF THE CONTAINMENT ATMOSPHERE MONITOR WAS IDENTIFIED.

+ INSPECTION ON JULY 7-25, 1986 (REPORT NO. 50-528/86-23) AREAS INSPECTED: UNANNOUNCED INSPECTION BY A REGIONALLY BASED INSPECTOR OF 10 CFR 50.55(E) CONSTRUCTION DEFICIENCIES, LICENSEE ACTION IN RESPONSE TO PART 21 REPORTS, ALLEGATIONS, TMI ACTION PLAN ITEMS, FOLLOWUP OF LICENSEE ACTION ON INSPECTOR-IDENTIFIED ITEMS, AND LERS. DURING THIS INSPECTION, VARIOUS INSPECTION PROCEDURES WERE UTILIZED.

RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

+ INSPECTION ON JULY 1 - AUGUST 3, 1986 (REPORT NO. 50-528/86-24) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

+ INSPECTION ON JULY 14-18, 1986 (REPORT NO. 50-528/86-25) REPORT CANCELLED.

+ INSPECTION ON JULY 28 - AUGUST 1, 1986 (REPORT NO. 50-528/86-26) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

AUXILIARY SPRAY SYSTEM SAFETY GRADE ISSUE IS BEING RESOLVED BY NRR.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

ANNUAL SALP BOARD MEETING HELD ON NOVEMBER 14, 1985; SALP REPORT TRANSMITTED TO THE LICENSEE ON DECEMBER 19, 1985.

PLANT STATUS:

THE PLANT ACHIEVED INITIAL CRITICALITY ON MAY 25, 1985. THE PLANT ACHIEVED 100% POWER ON DECEMBER 9, 1985. POWER ASCENSION TESTING IS COMPLETED. COMMERCIAL OPERATION WAS DECLARED ON FEBRUARY 13, 1986. CURRENTLY, THE PLANT IS IN MODE 3 AFTER A MAINTENANCE OUTAGE.

LAST IE SITE INSPECTION DATE: 07/01-08/03/86+

INSPECTION STATUS - (CONTINUED)

[illegible]

INSPECTION REPORT NO: 50-528/86-24+

REPORTS FROM LICENSEE

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
86-28-L0	05-16-86	06-16-86	SURVEILLANCE TESTING OF HALON SYSTEMS INVALIDATED DUE TO PERSONNEL ERROR
86-30-L0	05-12-86	06-11-86	MAIN STEAM ISOLATION SIGNAL DUE TO PERSONNEL ERROR
86-32-L0	05-15-86	06-16-86	PROCEDURAL DEFICIENCY RESULTS IN CONTROL ROOM EMERGENCY FEEDWATER ACTUATION SIGNAL ACTUATION
86-42-X0	04-28-86	05-27-86	APPARENT NONVALID DIESEL FAILURE (SPECIAL REPORT)

1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	93	94	95	96	97	98	99	100	101	102	103	104	105	106	107	108	109	110	111	112	113	114	115	116	117	118	119	120	121	122	123	124	125	126	127	128	129	130	131	132	133	134	135	136	137	138	139	140	141	142	143	144	145	146	147	148	149	150	151	152	153	154	155	156	157	158	159	160	161	162	163	164	165	166	167	168	169	170	171	172	173	174	175	176	177	178	179	180	181	182	183	184	185	186	187	188	189	190	191	192	193	194	195	196	197	198	199	200	201	202	203	204	205	206	207	208	209	210	211	212	213	214	215	216	217	218	219	220	221	222	223	224	225	226	227	228	229	230	231	232	233	234	235	236	237	238	239	240	241	242	243	244	245	246	247	248	249	250	251	252	253	254	255	256	257	258	259	260	261	262	263	264	265	266	267	268	269	270	271	272	273	274	275	276	277	278	279	280	281	282	283	284	285	286	287	288	289	290	291	292	293	294	295	296	297	298	299	300	301	302	303	304	305	306	307	308	309	310	311	312	313	314	315	316	317	318	319	320	321	322	323	324	325	326	327	328	329	330	331	332	333	334	335	336	337	338	339	340	341	342	343	344	345	346	347	348	349	350	351	352	353	354	355	356	357	358	359	360	361	362	363	364	365	366	367	368	369	370	371	372	373	374	375	376	377	378	379	380	381	382	383	384	385	386	387	388	389	390	391	392	393	394	395	396	397	398	399	400	401	402	403	404	405	406	407	408	409	410	411	412	413	414	415	416	417	418	419	420	421	422	423	424	425	426	427	428	429	430	431	432	433	434	435	436	437	438	439	440	441	442	443	444	445	446	447	448	449	450	451	452	453	454	455	456	457	458	459	460	461	462	463	464	465	466	467	468	469	470	471	472	473	474	475	476	477	478	479	480	481	482	483	484	485	486	487	488	489	490	491	492	493	494	495	496	497	498	499	500	501	502	503	504	505	506	507	508	509	510	511	512	513	514	515	516	517	518	519	520	521	522	523	524	5
---	---	---	---	---	---	---	---	---	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	---

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-529 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/86 Outage + On-line Hrs: 744.0

3. Utility Contact: J. M. COLVILLE (602) 932-5300 X6593

4. Licensed Thermal Power (Mwt): 3800

5. Nameplate Rating (Gross MWe): 1403

6. Design Electrical Rating (Net MWe): 1221

7. Maximum Dependable Capacity (Gross MWe): 1221

8. Maximum Dependable Capacity (Net MWe): 1221

9. If Changes Occur Above Since Last Report, Give Reasons:

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>1,734.3</u>	<u>1,734.3</u>
13. Hours Reactor Critical	<u>171.3</u>	<u>962.6</u>	<u>962.6</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>117.6</u>	<u>794.0</u>	<u>794.0</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>179,055</u>	<u>1,106,307</u>	<u>1,106,307</u>
18. Gross Elec Ener (MWH)	<u>50,900</u>	<u>296,500</u>	<u>296,500</u>
19. Net Elec Ener (MWH)	<u>26,475</u>	<u>204,271</u>	<u>204,271</u>
20. Unit Service Factor			
21. Unit Avail Factor		NOT IN	
22. Unit Cap Factor (MDC Net)		COMMERCIAL	
23. Unit Cap Factor (DER Net)		OPERATION	
24. Unit Forced Outage Rate			
25. Forced Outage Hours	<u>626.4</u>	<u>807.5</u>	<u>807.5</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


NONE

27. If Currently Shutdown Estimated Startup Date: 08/15/86

 * PALO VERDE 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

PALO VERDE 2



JULY 1986

Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

 * PALO VERDE 2 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
11	07/01/86	F	529.0	D	1		AB	SEAL	COMMENCED A UNIT SHUTDOWN DUE TO UNIDENTIFIED LEAKAGE BEING HIGH. SHUTDOWN REQUIRED BY TECH. SPEC. LCO PROBLEM CORRECTED BY REPLACING RCP SEALS.
12	07/25/86	F	25.4	A	3	86-047	JC	CPU	REACTOR TRIP ON CPC GENERATED HI LPD TRIP.
13	07/28/86	F	72.0	A	1		SG	COND	MAIN TURBINE TRIP UNABLE TO MAINTAIN VACUUM IN CONDENSER.

 * SUMMARY *

 PALO VERDE 2 CONTINUES IN POWER ASCENSION AND TESTING.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)
	F-Admin		
	G-Oper Error		
	H-Other		

* PALO VERDE 2 *

FACILITY DATA

Report Period JUL 1986

FACILITY DESCRIPTION

LOCATION
STATE.....ARIZONA
COUNTY.....MARICOPA
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...36 MI W OF
PHOENIX, AZ
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY... APRIL 18, 1986
DATE ELEC ENER 1ST GENER... MAY 20, 1986
DATE COMMERCIAL OPERATE...*****
CONDENSER COOLING METHOD...COOLING TOWERS
CONDENSER COOLING WATER...SEWAGE TREATMENT
ELECTRIC RELIABILITY
COUNCIL.....WESTERN SYSTEMS
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....ARIZONA PUBLIC SERVICE
CORPORATE ADDRESS.....P.O. BOX 21666
PHOENIX, ARIZONA 85036
CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...COMBUSTION ENGINEERING
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....V
IE RESIDENT INSPECTOR.....G. FIORELLI
LICENSING PROJ MANAGER.....E. LICITRA
DOCKET NUMBER.....50-529
LICENSE & DATE ISSUANCE....NPF-51, APRIL 24, 1986
PUBLIC DOCUMENT ROOM.....

MS STEFANIE MORITZ
DOCUMENTS LIBRARIAN
PHOENIX PUBLIC LIBRARY
12 EAST MCDOWELL ROAD
PHOENIX, ARIZONA 85004

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION ON MAY 19 - AUGUST 2, 1986 (REPORT NO. 50-529/86-15) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.
+ INSPECTION ON MAY 27 - JUNE 30, 1986 (REPORT NO. 50-529/86-20) AREAS INSPECTED: ROUTINE, ONSITE INSPECTION BY THE FOUR RESIDENT INSPECTORS AND ONE REGIONALLY BASED REACTOR INSPECTOR. AREAS INSPECTED INCLUDED: FOLLOWUP OF PREVIOUSLY IDENTIFIED ITEMS; REVIEW OF PLANT ACTIVITIES; ENGINEERED SAFETY SYSTEM WALKDOWNS; SURVEILLANCE TESTING; MAINTENANCE; CONSTRUCTION ACTIVITIES; PREOPERATIONAL AND POWER ASCENSION TEST WITNESSING; PREOPERATIONAL TEST PROCEDURE REVIEW; POWER ASCENSION TEST RESULTS REVIEW; DIESEL GENERATOR BRIDGE CRANE SEISMIC QUALIFICATION REVIEW; ALLEGATION FOLLOWUP; REACTOR COOLANT PRESSURE ISOLATION VALVE LEAK TEST; LICENSEE EVENT REPORT FOLLOWUP; CONSTRUCTION DEFICIENCY REPORT, PART 21 REPORT, AND IE BULLETIN AND INFORMATION NOTICE FOLLOWUP; PERIODIC AND SPECIAL REPORT REVIEW; AND PLANT TOURS. DURING THIS INSPECTION, VARIOUS INSPECTION PROCEDURES WERE UTILIZED.
RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.
+ INSPECTION ON JUNE 9-26, 1986 (REPORT NO. 50-529/86-21) AREAS INSPECTED: ROUTINE, UNANNOUNCED INSPECTION BY A REGIONALLY BASED INSPECTOR OF LICENSEE ACTION ON INSPECTOR-IDENTIFIED ITEMS. DURING THIS INSPECTION, ONE INSPECTION PROCEDURE WAS UTILIZED.
RESULT: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

INSPECTION STATUS - (CONTINUED)

INSPECTION SUMMARY

+ INSPECTION ON JULY 28 - AUGUST 1, 1986 (REPORT NO. 50-529/86-25) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

1. BALANCE OF PLANT ENGINEERED SAFETY FEATURES ACTUATION SYSTEM. 2. SECONDARY CHEMISTRY

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

POWER ASCENSION TESTING IS ONGOING. UNIT IS AT 50% POWER.

LAST IE SITE INSPECTION DATE: 07/01-08/03/86+

INSPECTION REPORT NO: 50-529/86-24+

Report Period JUL 1986

R E P O R T S F R O M L I C E N S E E

* PALO VERDE 2 *

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
--------	------------------	-------------------	---------

86-15-X0	05-25-86	05-30-86	REACTOR TRIP RESULTING IN OVERCOOLING EVENT (SPECIAL REPORT)
----------	----------	----------	--

86-24-L0	05-14-86	06-13-86	INOPERABLE STEAM GENERATOR SNUBBERS DUE TO PERSONNEL ERROR
----------	----------	----------	--

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-277 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/86 Outage + On-line Hrs: 744.0

3. Utility Contact: W. M. Alden (215) 841-5022

4. Licensed Thermal Power (MWt): 3293

5. Nameplate Rating (Gross MWe): 1280 X 0.9 = 1152

6. Design Electrical Rating (Net MWe): 1065

7. Maximum Dependable Capacity (Gross MWe): 1098

8. Maximum Dependable Capacity (Net MWe): 1051

9. If Changes Occur Above Since Last Report, Give Reasons: NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____


11. Reasons for Restrictions, If Any: NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,087.0</u>	<u>105,839.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>4,400.7</u>	<u>69,594.3</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>715.1</u>	<u>4,273.8</u>	<u>67,402.6</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (i*WH)	<u>2,334,648</u>	<u>12,972,182</u>	<u>199,238,697</u>
18. Gross Elec Ener (MWH)	<u>760,260</u>	<u>4,286,460</u>	<u>65,499,420</u>
19. Net Elec Ener (MWH)	<u>729,091</u>	<u>4,130,025</u>	<u>62,722,320</u>
20. Unit Service Factor	<u>96.1</u>	<u>84.0</u>	<u>63.7</u>
21. Unit Avail Factor	<u>96.1</u>	<u>84.0</u>	<u>63.7</u>
22. Unit Cap Factor (MDC Net)	<u>93.2</u>	<u>77.2</u>	<u>56.4</u>
23. Unit Cap Factor (DER Net)	<u>92.0</u>	<u>76.2</u>	<u>55.6</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>13.4</u>	<u>13.0</u>
25. Forced Outage Hours	<u>.0</u>	<u>662.7</u>	<u>10,075.2</u>
26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):	<u>NONE</u>		
27. If Currently Shutdown Estimated Startup Date:	<u>N/A</u>		

 * PEACH BOTTOM 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

PEACH BOTTOM 2



JULY 1986

Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

* PEACH BOTTOM 2 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
1	07/19/86	S	28.9	B	3		HB	PIPEXX	GENERATOR SHUTDOWN FOR FLANGE LEAK REPAIR ON HIGH PRESSURE TURBINE "C" MOISTURE SEPARATOR STEAM LINE. REACTOR REMAINED AT 22% POWER.
2	07/22/86	S	0.0	H	5		RD	CONROD	LOAD REDUCTION TO 650MW FOR CONTROL ROD PATTERN ADJUSTMENTS.

* SUMMARY *

PEACH BOTTOM 2 INCURRED 1 OUTAGE AND 1 POWER REDUCTION IN JULY AS DISCUSSED ABOVE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* PEACH BOTTOM 2 *

FACILITY DATA

Report Period JUL 1986

FACILITY DESCRIPTION

LOCATION
STATE.....PENNSYLVANIA
COUNTY.....YORK
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...19 MI S OF
LANCASTER, PA
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...SEPTEMBER 16, 1973
DATE ELEC ENER 1ST GENER...FEBRUARY 18, 1974
DATE COMMERCIAL OPERATE...JULY 5, 1974
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...SUSQUEHANNA RIVER
ELECTRIC RELIABILITY
COUNCIL.....MID-ATLANTIC
AREA COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....PHILADELPHIA ELECTRIC
CORPORATE ADDRESS.....2301 MARKET STREET
PHILADELPHIA, PENNSYLVANIA 19105
CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I
IE RESIDENT INSPECTOR.....T. JOHNSON
LICENSING PROJ MANAGER.....R. CLARK
DOCKET NUMBER.....50-277
LICENSE & DATE ISSUANCE...DPR-44, DECEMBER 14, 1973
PUBLIC DOCUMENT ROOM.....GOVERNMENT PUBLICATIONS SECTION
STATE LIBRARY OF PENNSYLVANIA
FORUM BUILDING
COMMONWEALTH AND WALNUT STREET
HARRISBURG, PENNSYLVANIA 17105

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

Report Period JUL 1986

I N S P E C T I O N S T A T U S - (CONTINUED)

* PEACH BOTTOM 2 *

OTHER ITEMS

NO INPUT PROVIDED.

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S F R O M L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT

NO INPUT PROVIDED.			
=====			

1. Docket: 50-278 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/86 Outage + On-line Hrs: 744.0

3. Utility Contact: W. M. Alden (215) 841-5022

4. Licensed Thermal Power (MWt): 3293

5. Nameplate Rating (Gross MWe): 1280 X 0.9 = 1152

6. Design Electrical Rating (Net MWe): 1065

7. Maximum Dependable Capacity (Gross MWe): 1098

8. Maximum Dependable Capacity (Net MWe): 1035

9. If Changes Occur Above Since Last Report, Give Reasons: NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,087.0</u>	<u>101,735.0</u>
13. Hours Reactor Critical	<u>448.2</u>	<u>2,938.1</u>	<u>71,551.6</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>448.2</u>	<u>2,681.5</u>	<u>69,535.9</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,409,544</u>	<u>7,314,605</u>	<u>202,311,269</u>
18. Gross Elec Ener (MWH)	<u>463,720</u>	<u>2,368,950</u>	<u>66,362,620</u>
19. Net Elec Ener (MWH)	<u>440,295</u>	<u>2,257,687</u>	<u>63,650,428</u>
20. Unit Service Factor	<u>60.2</u>	<u>52.7</u>	<u>68.4</u>
21. Unit Avail Factor	<u>60.2</u>	<u>52.7</u>	<u>68.4</u>
22. Unit Cap Factor (MDC Net)	<u>57.2</u>	<u>42.9</u>	<u>60.4</u>
23. Unit Cap Factor (DER Net)	<u>55.6</u>	<u>41.7</u>	<u>58.7</u>
24. Unit Forced Outage Rate	<u>39.8</u>	<u>13.4</u>	<u>7.4</u>
25. Forced Outage Hours	<u>295.8</u>	<u>415.5</u>	<u>5,542.1</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
SAFE-END/PIPE WELD INSPECTION: 1/3/87 TO 1/23/87.

27. If Currently Shutdown Estimated Startup Date: 08/20/86

 * PEACH BOTTOM 3 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

PEACH BOTTOM 3



JULY 1986

Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

* PEACH BOTTOM 3 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
0	07/19/86	F	295.8	A	3	3-86-16	ED	CKTBRK	REACTOR SCRAM FROM 87% POWER ON HIGH NEUTRON FLUX AS A RESULT OF THE TRIP OF THE 83 STARTUP FEED BREAKER WHICH CAUSED THE FAST CLOSURE OF THE 80-B MSIV.

* SUMMARY *

PEACH BOTTOM 3 HAD 1 REACTOR SCRAM IN JULY AS DISCUSSED ABOVE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* PEACH BOTTOM 3 *

F A C I L I T Y D A T A

Report Period JUL 1986

FACILITY DESCRIPTION

LOCATION
STATE.....PENNSYLVANIA
COUNTY.....YORK
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...19 MI S OF
LANCASTER, PA
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...AUGUST 7, 1974
DATE ELEC ENER 1ST GENER...SEPTEMBER 1, 1974
DATE COMMERCIAL OPERATE...DECEMBER 23, 1974
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...SUSQUEHANNA RIVER
ELECTRIC RELIABILITY
COUNCIL.....MID-ATLANTIC
AREA COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....PHILADELPHIA ELECTRIC
CORPORATE ADDRESS.....2301 MARKET STREET
PHILADELPHIA, PENNSYLVANIA 19105
CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I
IE RESIDENT INSPECTOR.....T. JOHNSON
LICENSING PROJ MANAGER.....R. CLARK
DOCKET NUMBER.....50-278
LICENSE & DATE ISSUANCE...DPR-56, JULY 2, 1974
PUBLIC DOCUMENT ROOM.....GOVERNMENT PUBLICATIONS SECTION
STATE LIBRARY OF PENNSYLVANIA
FORUM BUILDING
COMMONWEALTH AND WALNUT STREET
HARRISBURG, PENNSYLVANIA 17105

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

Report Period JUL 1986

I N S P E C T I O N S T A T U S - (CONTINUED)

* PEACH BOTTOM 3 *

OTHER ITEMS

NO INPUT PROVIDED.

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S F R O M L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
--------	------------------	-------------------	---------

NO INPUT PROVIDED.

=====

1. Docket: 50-293 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/86 Outage + On-line Hrs: 744.0

3. Utility Contact: P. HAMILTON (617) 746-7900

4. Licensed Thermal Power (MWt): 1998

5. Nameplate Rating (Gross MWe): 780 X 0.87 = 678

6. Design Electrical Rating (Net MWe): 655

7. Maximum Dependable Capacity (Gross MWe): 690

8. Maximum Dependable Capacity (Net MWe): 670

9. If Changes Occur Above Since Last Report, Give Reasons:

NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,087.0</u>	<u>119,591.0</u>
13. Hours Reactor Critical	<u>.0</u>	<u>1,715.5</u>	<u>79,778.7</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>.0</u>	<u>1,646.0</u>	<u>77,216.9</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>0</u>	<u>3,094,416</u>	<u>135,480,048</u>
18. Gross Elec Ener (MWH)	<u>0</u>	<u>1,068,000</u>	<u>45,444,604</u>
19. Net Elec Ener (MWH)	<u>0</u>	<u>1,027,531</u>	<u>43,675,429</u>
20. Unit Service Factor	<u>.0</u>	<u>32.4</u>	<u>64.6</u>
21. Unit Avail Factor	<u>.0</u>	<u>32.4</u>	<u>64.6</u>
22. Unit Cap Factor (MDC Net)	<u>.0</u>	<u>30.1</u>	<u>54.5</u>
23. Unit Cap Factor (DER Net)	<u>.0</u>	<u>30.8</u>	<u>55.8</u>
24. Unit Forced Outage Rate	<u>100.0</u>	<u>67.2</u>	<u>12.4</u>
25. Forced Outage Hours	<u>744.0</u>	<u>3,378.5</u>	<u>10,922.7</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


NONE

27. If Currently Shutdown Estimated Startup Date: 02/14/87

* PILGRIM 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

PILGRIM 1



JULY 1986

Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

 * PILGRIM 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
08	07/01/86	F	744.0	A	4				THE UNIT REMAINED SHUTDOWN TO ADDRESS VARIOUS HARDWARE AND ADMINISTRATIVE ITEMS INCLUDING RHR PUMP WEAR RING INSPECTIONS AND LOCAL LEAK RATE TESTING. RFO 7 COMMENCED 7/25/86.

 * SUMMARY *

PILGRIM 1 REMAINS SHUT DOWN FOR VARIOUS HARDWARE AND ADMINISTRATIVE ITEMS.

Type	Reason	Method	System & Component	
F-Forced	A-Equip Failure	F-Admin	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	2-Manual Scram	Instructions for
	C-Refueling	H-Other	3-Auto Scram	Preparation of
	D-Regulatory Restriction		4-Continued	Data Entry Sheet
	E-Operator Training		5-Reduced Load	Licensee Event Report
	& License Examination		9-Other	(LER) File (NUREG-0161)

* PILGRIM 1 *

FACILITY DATA

Report Period JUL 1986

FACILITY DESCRIPTION

UTILITY & CONTRACTOR INFORMATION

LOCATION
STATE.....MASSACHUSETTS
COUNTY.....PLYMOUTH
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...4 MI SE OF
PLYMOUTH, MASS
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...JUNE 16, 1972
DATE ELEC ENER 1ST GENER...JULY 19, 1972
DATE COMMERCIAL OPERATE...DECEMBER 1, 1972
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...CAPE COD BAY
ELECTRIC RELIABILITY
COUNCIL.....NORTHEAST POWER
COORDINATING COUNCIL

UTILITY
LICENSEE.....BOSTON EDISON
CORPORATE ADDRESS.....800 BOYLSTON STREET
BOSTON, MASSACHUSETTS 02199
CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I
IE RESIDENT INSPECTOR.....M. MCBRIDE
LICENSING PROJ MANAGER.....R. AULUCK
DOCKET NUMBER.....50-293
LICENSE & DATE ISSUANCE...DPR-35, SEPTEMBER 15, 1972
PUBLIC DOCUMENT ROOM.....PLYMOUTH PUBLIC LIBRARY
11 NORTH STREET
PLYMOUTH, MASSACHUSETTS 02360

INSPECTION SUMMARY

INSPECTION STATUS

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

TECHNICAL SPECIFICATION 6.8 REQUIRES THAT WRITTEN PROCEDURES AND ADMINISTRATIVE POLICIES BE ESTABLISHED, IMPLEMENTED AND MAINTAINED, THAT MEET OR EXCEED THE REQUIREMENTS AND RECOMMENDATIONS OF APPENDIX 'A' OF REGULATORY GUIDE 1.33 - 1972. STATION APPROVED WRITTEN PROCEDURES BE ADHERED TO BY ALL STATION PERSONNEL. PROCEDURE PNPS-6.9-160, REVISION 20 SPECIFIED IN PART, TO SURVEY MATERIAL TO BE PACKAGED AND TO ENTER THE MAXIMUM RADIATION LEVEL AT THE SURFACE OF THE PACKAGE, AND TO LIST THE TOTAL ACTIVITY WITHIN THE PACKAGE. APPROPRIATE RADIATION SURVEY FORMS AND MAPS ARE ALSO SPECIFIED. CONTRARY TO THE ABOVE, ON JANUARY 23, 1985, JULY 9, 1985, AND AUGUST 2, 1985, RADIATION SURVEYS OF PACKAGED IRRADIATED REACTOR COMPONENTS WERE NOT DOCUMENTED ON APPROPRIATE RADIATION SURVEY FORMS AND MAPS; AND THE MAXIMUM RADIATION LEVEL AT THE SURFACE OF THE PACKAGE WAS INCORRECT FOR SHIPMENT NUMBERS 85-06 AND 85-66; AND THE TOTAL RADIOACTIVITY CONTAINED WITHIN SHIPMENT NUMBER 85-79 WAS INCORRECTLY LISTED DURING TRANSPORT. 10 CFR 20.31(D)(3), "TRANSFER FOR DISPOSAL AND MANIFESTS" REQUIRES LICENSEE WHO TRANSFERS RADIOACTIVE WASTE TO A LAND DISPOSAL FACILITY TO CONDUCT A QUALITY CONTROL PROGRAM TO ASSURE COMPLIANCE WITH 10 CFR 61.56. CONTRARY TO THE ABOVE, THE LICENSEE HAD TRANSFERRED SEVERAL RADIOACTIVE WASTE SHIPMENTS COMPOSED OF DEWATERED RESINS AND DIATOMACEOUS EARTH ABSORBERS TO A LAND DISPOSAL FACILITY DURING 1984, 1985 AND THE LICENSEE HAD NOT CONDUCTED A QUALITY CONTROL PROGRAM TO ASSURE THAT THE PACKAGES DID NOT CONTAIN FREE STANDING LIQUID GREATER THAN 1% OF THE WASTE VOLUME, AND THAT THE WASTE WAS STRUCTURALLY STABLE FOR

Report Period JUL 1986

I N S P E C T I O N S T A T U S - (CONTINUED)

* PILGRIM 1 *

ENFORCEMENT SUMMARY

COMPLIANCE WITH 10 CFR 61.56.
(8601 4)

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S F R O M L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
--------	------------------	-------------------	---------

NO INPUT PROVIDED.

=====

1. Docket: 50-266 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/86 Outage + On-line Hrs: 744.0

3. Utility Contact: C. W. KRAUSE (414) 277-2001

4. Licensed Thermal Power (MWt): 1518

5. Nameplate Rating (Gross MWe): 582 X 0.9 = 524

6. Design Electrical Rating (Net MWe): 497

7. Maximum Dependable Capacity (Gross MWe): 509

8. Maximum Dependable Capacity (Net MWe): 485

9. If Changes Occur Above Since Last Report, Give Reasons: NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,087.0</u>	<u>137,927.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>4,236.3</u>	<u>111,709.3</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>11.0</u>	<u>645.4</u>
15. Hrs Generator On-Line	<u>714.8</u>	<u>4,121.5</u>	<u>109,028.3</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>28.0</u>	<u>832.0</u>
17. Gross Therm Ener (MWH)	<u>1,070,864</u>	<u>6,062,657</u>	<u>149,230,601</u>
18. Gross Elec Ener (MWH)	<u>366,870</u>	<u>2,075,070</u>	<u>50,226,750</u>
19. Net Elec Ener (MWH)	<u>350,671</u>	<u>1,983,036</u>	<u>47,814,302</u>
20. Unit Service Factor	<u>96.1</u>	<u>81.0</u>	<u>79.0</u>
21. Unit Avail Factor	<u>96.1</u>	<u>81.6</u>	<u>79.7</u>
22. Unit Cap Factor (MDC Net)	<u>97.2</u>	<u>80.4</u>	<u>71.0*</u>
23. Unit Cap Factor (DER Net)	<u>94.8</u>	<u>78.4</u>	<u>69.8</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.6</u>	<u>2.3</u>
25. Forced Outage Hours	<u>.0</u>	<u>24.0</u>	<u>2,437.4</u>
26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):	<u>NONE</u>		

27. If Currently Shutdown Estimated Startup Date: N/A

* POINT BEACH 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

POINT BEACH 1



JULY 1986

* Item calculated with a Weighted Average

Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

* POINT BEACH 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
5	07/12/86	S	29.2	B	1		ZZ	ZZZZZ	SCHEDULED SHUTDOWN TO ALLOW REPAIRS TO THE 1A MOISTURE SEPARATOR REHEATER.

* SUMMARY *

POINT BEACH 1 HAD 1 SHUTDOWN IN JULY FOR MOISTURE SEPARATOR REHEATER REPAIRS.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	1-Manual
S-Sched	B-Maint or Test	G-Oper Error	2-Manual Scram
	C-Refueling	H-Other	3-Auto Scram
	D-Regulatory Restriction		4-Continued
	E-Operator Training		5-Reduced Load
	& License Examination		9-Other
			Exhibit F & H
			Instructions for
			Preparation of
			Data Entry Sheet
			Licensee Event Report
			(LER) File (NUREG-0161)

* POINT BEACH 1 *

F A C I L I T Y D A T A

Report Period JUL 1986

FACILITY DESCRIPTION

LOCATION
STATE.....WISCONSIN
COUNTY.....MANITOWOC
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...15 MI N OF
MANITOWOC, WISC
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...NOVEMBER 2, 1970
DATE ELEC ENER 1ST GENER...NOVEMBER 6, 1970
DATE COMMERCIAL OPERATE...DECEMBER 21, 1970
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER....LAKE MICHIGAN
ELECTRIC RELIABILITY
COUNCIL.....MID-AMERICA
INTERPOOL NETWORK

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....WISCONSIN ELECTRIC POWER COMPANY
CORPORATE ADDRESS.....231 WEST MICHIGAN STREET
MILWAUKEE, WISCONSIN 53201
CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III
IE RESIDENT INSPECTOR.....R. HAGUE
LICENSING PROJ MANAGER.....T. COLBURN
DOCKET NUMBER.....50-266
LICENSE & DATE ISSUANCE...DPR-24, OCTOBER 5, 1970
PUBLIC DOCUMENT ROOM.....JOSEPH MANN PUBLIC LIBRARY
1516 16TH ST.
TWO RIVERS, WISCONSIN 54241

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION ON JUNE 16-19 AND 23-27 (86011): ROUTINE UNANNOUNCED INSPECTION BY ONE REGIONAL INSPECTOR OF QA IMPLEMENTATION; TESTS AND EXPERIMENTS; RECORDS; OFFSITE SUPPORT STAFF; AND NONROUTINE REPORTING. THE INSPECTION ADDRESSED SELECTED SECTIONS OF NRC INSPECTION PROCEDURES NO. 35701, 37703, 39701, 40703 AND 90714. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

INSPECTION STATUS - (CONTINUED)

* POINT BEACH 1 *

NONE

NONE

THE UNIT IS OPERATING NORMALLY.

LAST IE SITE INSPECTION DATE: 09/30/86

INSPECTION REPORT NO: 86015

REPORTS FROM LICENSEE

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
86-03	06/03/86	07/03/86	REACTOR TRIP DUE TO LOSS OF POWER ON THE WHITE INSTRUMENT BUS
86-04	06/29/86	07/07/86	INDICATION OF ROD CONTROL CLUSTER ASSEMBLY MISALIGNMENT

1. Docket: 50-301 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/86 Outage + On-line Hrs: 744.0

3. Utility Contact: C. W. KRAUSE (414) 277-2001

4. Licensed Thermal Power (MWt): 1518

5. Nameplate Rating (Gross MWe): 582 X 0.9 = 524

6. Design Electrical Rating (Net MWe): 497

7. Maximum Dependable Capacity (Gross MWe): 509

8. Maximum Dependable Capacity (Net MWe): 485

9. If Changes Occur Above Since Last Report, Give Reasons: NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,087.0</u>	<u>122,712.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>5,083.2</u>	<u>108,631.8</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>207.4</u>
15. Hrs Generator On-Line	<u>718.4</u>	<u>5,037.6</u>	<u>106,838.3</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>9.9</u>	<u>244.2</u>
17. Gross Therm Ener (MWH)	<u>1,069,310</u>	<u>7,460,114</u>	<u>150,339,984</u>
18. Gross Elec Ener (MWH)	<u>362,010</u>	<u>2,523,670</u>	<u>50,939,520</u>
19. Net Elec Ener (MWH)	<u>345,048</u>	<u>2,410,766</u>	<u>48,531,485</u>
20. Unit Service Factor	<u>96.6</u>	<u>99.0</u>	<u>87.1</u>
21. Unit Avail Factor	<u>96.6</u>	<u>99.2</u>	<u>87.3</u>
22. Unit Cap Factor (MDC Net)	<u>95.6</u>	<u>97.7</u>	<u>80.6*</u>
23. Unit Cap Factor (DER Net)	<u>93.3</u>	<u>95.4</u>	<u>79.6</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.5</u>	<u>1.3</u>
25. Forced Outage Hours	<u>.0</u>	<u>23.8</u>	<u>768.7</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):

REFUELING OUTAGE: SEPTEMBER 27, 1986, 8 - WEEKS.

27. If Currently Shutdown Estimated Startup Date: N/A

* POINT BEACH 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
POINT BEACH 2



JULY 1986

* Item calculated with a Weighted Average

Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

* POINT BEACH 2 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
5	07/03/86	S	25.6	B	1		ZZ	ZZZZZZ	REPAIR LEAK ON "A" STEAM GENERATOR INBOARD MANWAY AND REPLACE A REACTOR COOLANT FLOW TRANSMITTER MANIFOLD VALVE.

* SUMMARY *

POINT BEACH 2 HAD 1 MAINTENANCE SHUTDOWN IN JULY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* POINT BEACH 2 *

FACILITY DATA

Report Period JUL 1986

FACILITY DESCRIPTION

LOCATION
STATE.....WISCONSIN
COUNTY.....MANITOWOC
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...15 MI N OF
MANITOWOC, WISC
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...MAY 30, 1972
DATE ELEC ENER 1ST GENER...AUGUST 2, 1972
DATE COMMERCIAL OPERATE...OCTOBER 1, 1972
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...LAKE MICHIGAN
ELECTRIC RELIABILITY
COUNCIL.....MID-AMERICA
INTERPOOL NETWORK

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....WISCONSIN ELECTRIC POWER COMPANY
CORPORATE ADDRESS.....231 WEST MICHIGAN STREET
MILWAUKEE, WISCONSIN 53201
CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III
IE RESIDENT INSPECTOR.....R. HAGUE
LICENSING PROJ MANAGER....T. COLBURN
DOCKET NUMBER.....50-301
LICENSE & DATE ISSUANCE...DPR-27, MARCH 8, 1973
PUBLIC DOCUMENT ROOM.....JOSEPH MANN PUBLIC LIBRARY
1516 16TH ST.
TWO RIVERS, WISCONSIN 54241

INSPECTION STATUS

INSPECTION SUMMARY

INSPECTION ON JUNE 16-19 AND 23-27 (86011): ROUTINE UNANNOUNCED INSPECTION BY ONE REGIONAL INSPECTOR OF QA IMPLEMENTATION; TESTS AND EXPERIMENTS; RECORDS; OFFSITE SUPPORT STAFF; AND NONROUTINE REPORTING. THE INSPECTION ADDRESSED SELECTED SECTIONS OF NRC INSPECTION PROCEDURES NO. 35701, 37703, 39701, 40703 AND 90714. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

INSPECTION STATUS - (CONTINUED)

OTHER ITEMS

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

THE UNIT IS OPERATING NORMALLY.

LAST IE SITE INSPECTION DATE: 09/30/86

INSPECTION REPORT NO: 86014

REPORTS FROM LICENSEE

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
85-02	10/17/85	07/23/86	FAILURE OF CONTAINMENT ISOLATION VALVE 2-755A
86-03	06/03/86	07/03/86	RUNBACK DUE TO LOSS OF INSTRUMENT BUS

1. Docket: 50-282 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/86 Outage + On-line Hrs: 744.0

3. Utility Contact: DALE DUGSTAD (612) 388-1121

4. Licensed Thermal Power (MWt): 1650

5. Nameplate Rating (Gross MWe): 659 X 0.9 = 593

6. Design Electrical Rating (Net MWe): 530

7. Maximum Dependable Capacity (Gross MWe): 534

8. Maximum Dependable Capacity (Net MWe): 503

9. If Changes Occur Above Since Last Report, Give Reasons: NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,087.0</u>	<u>110,663.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>4,239.4</u>	<u>91,596.9</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>5,571.1</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>4,216.5</u>	<u>90,219.0</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,222,014</u>	<u>6,264,415</u>	<u>141,633,028</u>
18. Gross Elec Ener (MWH)	<u>399,710</u>	<u>2,060,120</u>	<u>46,261,390</u>
19. Net Elec Ener (MWH)	<u>375,586</u>	<u>1,930,131</u>	<u>43,357,965</u>
20. Unit Service Factor	<u>100.0</u>	<u>82.9</u>	<u>81.5</u>
21. Unit Avail Factor	<u>100.0</u>	<u>82.9</u>	<u>81.5</u>
22. Unit Cap Factor (MDC Net)	<u>100.4</u>	<u>75.4</u>	<u>77.9</u>
23. Unit Cap Factor (DER Net)	<u>95.2</u>	<u>71.6</u>	<u>73.9</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.1</u>	<u>7.3</u>
25. Forced Outage Hours	<u>.0</u>	<u>6.1</u>	<u>3,396.8</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

* PRAIRIE ISLAND 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

PRAIRIE ISLAND 1



JULY 1986

Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

 * PRAIRIE ISLAND 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
1	07/02/86	F	0.0	A	5				STEAM LEAK ON 12 FWP DISCHARGE PIPING.
2	07/02/86	S	0.0	B	5				TURBINE VALVES TEST.

 * SUMMARY *

PRAIRIE ISLAND 1 OPERATED ROUTINELY IN JULY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* PRAIRIE ISLAND 1 *

FACILITY DATA

Report Period JUL 1986

FACILITY DESCRIPTION

LOCATION
STATE.....MINNESOTA
COUNTY.....GOODHUE
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...28 MI SE OF
MINNEAPOLIS, MINN
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...DECEMBER 1, 1973
DATE ELEC ENER 1ST GENER...DECEMBER 4, 1973
DATE COMMERCIAL OPERATE...DECEMBER 16, 1973
CONDENSER COOLING METHOD...COOLING TOWERS
CONDENSER COOLING WATER...MISSISSIPPI RIVER
ELECTRIC RELIABILITY
COUNCIL.....MID-CONTINENT AREA
RELIABILITY COORDINATION
AGREEMENT

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....NORTHERN STATES POWER
CORPORATE ADDRESS.....414 NICOLLET MALL
MINNEAPOLIS, MINNESOTA 55401
CONTRACTOR
ARCHITECT/ENGINEER.....FLUOR PIONEER, INC.
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....NORTHERN STATES POWER COMPANY
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III
IE RESIDENT INSPECTOR.....J. HARD
LICENSING PROJ MANAGER.....D. DIANNI
DOCKET NUMBER.....50-282
LICENSE & DATE ISSUANCE...DPR-42, APRIL 5, 1974
PUBLIC DOCUMENT ROOM.....ENVIRONMENTAL CONSERVATION LIBRARY
MINNEAPOLIS PUBLIC LIBRARY
300 NICOLLET MALL
MINNEAPOLIS, MINNESOTA 55401

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION ON JUNE 16-19 (86006; 86006): ROUTINE ANNOUNCED INSPECTION OF PRAIRIE ISLAND NUCLEAR GENERATING PLANT EMERGENCY PREPAREDNESS EXERCISE INVOLVING OBSERVATIONS BY SEVEN NRC REPRESENTATIVES OF KEY FUNCTIONS AND LOCATIONS DURING THE EXERCISE. THE INSPECTION WAS CONDUCTED BY FIVE NRC INSPECTORS AND TWO CONSULTANTS. NO VIOLATIONS, DEFICIENCIES OR DEVIATIONS WERE IDENTIFIED AS A RESULT OF THIS INSPECTION.

INSPECTION ON JUNE 30 (86008; 86010): ROUTINE UNANNOUNCED INSPECTION OF THE RESOLUTION OF AN IE BULLETIN. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

Report Period JUL 1986

I N S P E C T I O N S T A T U S - (CONTINUED)

* PRAIRIE ISLAND 1 *

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

THE UNIT IS OPERATING NORMALLY.

LAST IE SITE INSPECTION DATE: 08/16/86

INSPECTION REPORT NO: 86009

R E P O R T S F R O M L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT

NONE			

=====

1. Docket: 50-306 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/86 Outage + On-line Hrs: 744.0

3. Utility Contact: DALE DUGSTAD (612) 388-1121

4. Licensed Thermal Power (MWt): 1650

5. Nameplate Rating (Gross MWe): 659 X 0.9 = 593

6. Design Electrical Rating (Net MWe): 530

7. Maximum Dependable Capacity (Gross MWe): 531

8. Maximum Dependable Capacity (Net MWe): 500

9. If Changes Occur Above Since Last Report, Give Reasons:

NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,087.0</u>	<u>101,781.0</u>
13. Hours Reactor Critical	<u>732.1</u>	<u>5,053.1</u>	<u>88,556.0</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>1,516.1</u>
15. Hrs Generator On-Line	<u>727.6</u>	<u>5,043.5</u>	<u>87,546.0</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,164,946</u>	<u>8,235,697</u>	<u>137,908,088</u>
18. Gross Elec Ener (MWH)	<u>381,080</u>	<u>2,732,220</u>	<u>44,791,660</u>
19. Net Elec Ener (MWH)	<u>358,511</u>	<u>2,586,704</u>	<u>42,076,021</u>
20. Unit Service Factor	<u>97.8</u>	<u>99.1</u>	<u>86.0</u>
21. Unit Avail Factor	<u>97.8</u>	<u>99.1</u>	<u>86.0</u>
22. Unit Cap Factor (MDC Net)	<u>96.4</u>	<u>101.7</u>	<u>82.7</u>
23. Unit Cap Factor (DER Net)	<u>90.9</u>	<u>95.9</u>	<u>78.0</u>
24. Unit Forced Outage Rate	<u>2.2</u>	<u>.9</u>	<u>3.5</u>
25. Forced Outage Hours	<u>16.4</u>	<u>43.5</u>	<u>3,359.0</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


REFUELING-OCTOBER 16, 1986.

27. If Currently Shutdown Estimated Startup Date: N/A

* PRAIRIE ISLAND 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

PRAIRIE ISLAND 2



JULY 1986

Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

* PRAIRIE ISLAND 2 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
1	07/15/86	S	0.0	B	5				AXIAL OFFSET CALIBRATION.
2	07/27/86	S	0.0	B	5				TURBINE VALVES TESTING.
3	07/28/86	F	16.4	G	3	86-003			ERROR DURING SAFEGUARDS LOGIC TESTING.

* SUMMARY *

PRAIRIE ISLAND 2 OPERATED ROUTINELY IN JULY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)
	F-Admin		
	G-Oper Error		
	H-Other		

* PRAIRIE ISLAND 2 *

FACILITY DATA

Report Period JUL 1986

FACILITY DESCRIPTION

LOCATION
STATE.....MINNESOTA
COUNTY.....GOODHUE
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...28 MI SE OF
MINNEAPOLIS, MINN
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...DECEMBER 17, 1974
DATE ELEC ENER 1ST GENER...DECEMBER 21, 1974
DATE COMMERCIAL OPERATE...DECEMBER 21, 1974
CONDENSER COOLING METHOD...COOLING TOWERS
CONDENSER COOLING WATER...MISSISSIPPI RIVER
ELECTRIC RELIABILITY
COUNCIL.....MID-CONTINENT AREA
RELIABILITY COORDINATION
AGREEMENT

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....NORTHERN STATES POWER
CORPORATE ADDRESS.....414 NICOLLET MALL
MINNEAPOLIS, MINNESOTA 55401
CONTRACTOR
ARCHITECT/ENGINEER.....FLUOR PIONEER, INC.
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....NORTHERN STATES POWER COMPANY
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III
IE RESIDENT INSPECTOR.....J. HARD
LICENSING PROJ MANAGER.....D. DIANNI
DOCKET NUMBER.....50-306
LICENSE & DATE ISSUANCE....DPR-60, OCTOBER 29, 1974
PUBLIC DOCUMENT ROOM.....ENVIRONMENTAL CONSERVATION LIBRARY
MINNEAPOLIS PUBLIC LIBRARY
300 NICOLLET MALL
MINNEAPOLIS, MINNESOTA 55401

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION ON JUNE 16-19 (86006; 86005): ROUTINE ANNOUNCED INSPECTION OF PRAIRIE ISLAND NUCLEAR GENERATING PLANT EMERGENCY PREPAREDNESS EXERCISE INVOLVING OBSERVATIONS BY SEVEN NRC REPRESENTATIVES OF KEY FUNCTIONS AND LOCATIONS DURING THE EXERCISE. THE INSPECTION WAS CONDUCTED BY FIVE NRC INSPECTORS AND TWO CONSULTANTS. NO VIOLATIONS, DEFICIENCIES OR DEVIATIONS WERE IDENTIFIED AS A RESULT OF THIS INSPECTION.

INSPECTION ON JUNE 30 (86008; 86010): ROUTINE UNANNOUNCED INSPECTION OF THE RESOLUTION OF AN IE BULLETIN. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

Report Period JUL 1986

I N S P E C T I O N S T A T U S - (CONTINUED)

* PRAIRIE ISLAND 2 *

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

UNIT IS OPERATING NORMALLY

LAST IE SITE INSPECTION DATE: 08/16/86

INSPECTION REPORT NO: 86011

R E P O R T S F R O M L I C E N S E E

=====			
NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT

NONE			
=====			

1. Docket: 50-254 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/86 Outage + On-line Hrs: 744.0

3. Utility Contact: CAROL KRONICH (309) 654-2241 X193

4. Licensed Thermal Power (Mwt): 2511

5. Nameplate Rating (Gross MWe): 920 X 0.9 = 828

6. Design Electrical Rating (Net MWe): 789

7. Maximum Dependable Capacity (Gross MWe): 813

8. Maximum Dependable Capacity (Net MWe): 769

9. If Changes Occur Above Since Last Report, Give Reasons:

NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,087.0</u>	<u>124,655.0</u>
13. Hours Reactor Critical	<u>702.3</u>	<u>2,858.6</u>	<u>99,520.1</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>3,421.9</u>
15. Hrs Generator On-Line	<u>690.5</u>	<u>2,800.5</u>	<u>96,079.2</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>909.2</u>
17. Gross Therm Ener (MWH)	<u>1,668,413</u>	<u>6,629,226</u>	<u>201,594,383</u>
18. Gross Elec Ener (MWH)	<u>539,577</u>	<u>2,151,347</u>	<u>65,272,834</u>
19. Net Elec Ener (MWH)	<u>515,725</u>	<u>2,048,352</u>	<u>61,075,666</u>
20. Unit Service Factor	<u>92.8</u>	<u>55.1</u>	<u>77.1</u>
21. Unit Avail Factor	<u>92.8</u>	<u>55.1</u>	<u>77.8</u>
22. Unit Cap Factor (MDC Net)	<u>90.1</u>	<u>52.4</u>	<u>63.7</u>
23. Unit Cap Factor (DER Net)	<u>87.9</u>	<u>51.0</u>	<u>62.1</u>
24. Unit Forced Outage Rate	<u>7.2</u>	<u>2.7</u>	<u>5.5</u>
25. Forced Outage Hours	<u>53.5</u>	<u>76.3</u>	<u>3,257.9</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


NONE

27. If Currently Shutdown Estimated Startup Date: N/A

* QUAD CITIES 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

QUAD CITIES 1



JULY 1986

Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

 * QUAD CITIES 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
86-20	07/05/86	S	0.0	B	5		HA	TURBIN	REDUCED LOAD TO 700 MWE FOR TURBINE SURVEILLANCES.
86-21	07/08/86	F	53.5	A	2		HC	HTEXCH	UNIT OUTAGE DUE TO HIGH CONDUCTIVITY -- CONDENSER TUBE LEAK.
86-22	07/19/86	S	0.0	H	5		HC	HTEXCH	REDUCED LOAD TO 700 MWE TO REVERSE CONDENSER FLOW.
86-23	07/22/86	S	0.0	H	5		ZZ	ZZZZZZ	REDUCED LOAD TO 700 MWE AS PER LOAD DISPATCHER.
86-24	07/26/86	S	0.0	B	5		HA	TURBIN	REDUCED LOAD TO 700 MWE FOR TURBINE SURVEILLANCE.

 * SUMMARY *

 QUAD CITIES 1 HAD 1 OUTAGE AND 4 POWER REDUCTIONS IN JULY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)
	F-Admin		
	G-Oper Error		
	H-Other		

* QUAD CITIES 1 *

FACILITY DATA

Report Period JUL 1986

FACILITY DESCRIPTION

LOCATION
STATE.....ILLINOIS
COUNTY.....ROCK ISLAND
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...20 MI NE OF
MOLINE, ILL
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...OCTOBER 18, 1971
DATE ELEC ENER 1ST GENER...APRIL 12, 1972
DATE COMMERCIAL OPERATE...FEBRUARY 18, 1973
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...MISSISSIPPI RIVER
ELECTRIC RELIABILITY
COUNCIL.....MID-AMERICA
INTERPOOL NETWORK

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....COMMONWEALTH EDISON
CORPORATE ADDRESS.....P.O. BOX 767
CHICAGO, ILLINOIS 60690
CONTRACTOR
ARCHITECT/ENGINEER.....SARGENT & LUNDY
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....UNITED ENG. & CONSTRUCTORS
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III
IE RESIDENT INSPECTOR.....A. MADISON
LICENSING PROJ MANAGER.....T. ROTELLA
DOCKET NUMBER.....50-254
LICENSE & DATE ISSUANCE...DPR-29, DECEMBER 14, 1972
PUBLIC DOCUMENT ROOM.....MOLINE PUBLIC LIBRARY
504 17TH STREET
MOLINE, ILLINOIS 61265

INSPECTION STATUS

INSPECTION SUMMARY

INSPECTION ON MAY 28-30 AND JUNE 4-5 AND 17 (86012; 86011): ROUTINE, UNANNOUNCED INSPECTION OF GASEOUS AND LIQUID RADIOACTIVE EFFLUENTS INCLUDING: EFFLUENT RELEASES; RECORDS AND REPORTS OF EFFLUENTS; EFFLUENT CONTROL INSTRUMENTATION; PROCEDURES FOR CONTROLLING RELEASES; REACTOR COOLANT CHEMISTRY AND ACTIVITY; GASEOUS EFFLUENT FILTRATION; AND AUDITS. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

Report Period JUL 1986

I N S P E C T I O N S T A T U S - (CONTINUED)

* QUAD CITIES 1 *

OTHER ITEMS

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

H. TOREN, SITE EMERGENCY PLANNING COORDINATOR SINCE OCTOBER 1985, WILL BE LEAVING QUAD-CITIES NUCLEAR PLANT ON MARCH 21, 1986. HIS REPLACEMENT HAS NOT YET BEEN SELECTED BY MANAGEMENT.

PLANT STATUS:

OPERATING ROUTINELY

LAST IE SITE INSPECTION DATE: 10/04/86

INSPECTION REPORT NO: 86014

R E P O R T S F R O M L I C E N S E E

```
=====
```

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
86-01	01/06/86	07/09/86	LEAK RATE FROM ALL VALVES AND PENETRATIONS ON UNIT ONE IN EXCESS OF TECHNICAL SPECIFICATION LIMIT
86-02	01/07/86	06/11/86	LEAK RATE FOR MSIV (MAIN STEAM ISOLATION VALVE) IN EXCESS OF TECHNICAL SPECIFICATION LIMIT

```
=====
```


1. Docket: 50-265 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/86 Outage + On-line Hrs: 744.0

3. Utility Contact: CAROL KRONICH (309) 654-2241 X193

4. Licensed Thermal Power (MWt): 2511

5. Nameplate Rating (Gross MWe): 920 X 0.9 = 828

6. Design Electrical Rating (Net MWe): 789

7. Maximum Dependable Capacity (Gross MWe): 813

8. Maximum Dependable Capacity (Net MWe): 769

9. If Changes Occur Above Since Last Report, Give Reasons: NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____


11. Reasons for Restrictions, If Any: NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,087.0</u>	<u>123,765.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>4,757.7</u>	<u>96,025.7</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>2,985.8</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>4,715.3</u>	<u>93,013.0</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>702.9</u>
17. Gross Therm Ener (MWH)	<u>1,805,766</u>	<u>11,234,663</u>	<u>197,343,686</u>
18. Gross Elec Ener (MWH)	<u>571,627</u>	<u>3,655,476</u>	<u>63,072,248</u>
19. Net Elec Ener (MWH)	<u>546,418</u>	<u>3,498,990</u>	<u>59,374,655</u>
20. Unit Service Factor	<u>100.0</u>	<u>92.7</u>	<u>75.2</u>
21. Unit Avail Factor	<u>100.0</u>	<u>92.7</u>	<u>75.7</u>
22. Unit Cap Factor (MDC Net)	<u>95.5</u>	<u>89.4</u>	<u>62.4</u>
23. Unit Cap Factor (DER Net)	<u>93.1</u>	<u>87.2</u>	<u>60.8</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.8</u>	<u>7.7</u>
25. Forced Outage Hours	<u>.0</u>	<u>39.4</u>	<u>3,857.6</u>
26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):	<u>NONE</u>		

27. If Currently Shutdown Estimated Startup Date: N/A

 X Q U A D C I T I E S 2 X

AVERAGE DAILY POWER LEVEL (MWe) PLOT
 Q U A D C I T I E S 2



JULY 1986

Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

 * QUAD CITIES 2 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
86-22	07/05/86	S	0.0	B	5		HH	DEMINX	REDUCED LOAD TO 650 MWE -- CONDENSATE DEMINERALIZER MAINTENANCE.
86-23	07/13/86	S	0.0	H	5		RC	CONROD	REDUCED LOAD TO 650 MWE FOR A CONTROL ROD PATTERN ADJUSTMENT.
86-24	07/14/86	F	0.0	H	5		CB	MOTORX	REDUCED LOAD TO 420 MWE DUE TO RECIRCULATION MOTOR-GENERATOR SET PROBLEMS.
86-25	07/17/86	S	0.0	H	5		HF	PUMPXX	REDUCED LOAD TO 715 MWE TO TAKE 2A CIRCULATION WATER PUMP OUT OF SERVICE.
86-26	07/19/86	S	0.0	B	5		CH	PUMPXX	REDUCED LOAD TO 600 MWE TO CHANGE OVER REACTOR FEED PUMPS.
86-27	07/22/86	S	0.0	H	5		ZZ	ZZZZ	REDUCED LOAD TO 700 MWE AS PER LOAD DISPATCHER.
86-28	07/24/86	S	0.0	B	5		HH	DEMINX	REDUCED LOAD TO 715 MWE TO REMOVE 2E CONDENSATE DEMINERALIZER FROM SERVICE.
86-29	07/26/86	S	0.0	B	5		HA	TURBIN	REDUCED LOAD TO 735 MWE FOR TURBINE SURVEILLANCES.

 * SUMMARY *

 QUAD CITIES 2 HAD NO OUTAGES AND SEVERAL POWER REDUCTIONS IN JULY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* QUAD CITIES 2 *

FACILITY DATA

Report Period JUL 1986

FACILITY DESCRIPTION

LOCATION
STATE.....ILLINOIS
COUNTY.....ROCK ISLAND
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...20 MI NE OF
MOLINE, ILL
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...APRIL 26, 1972
DATE ELEC ENER 1ST GENER...MAY 23, 1972
DATE COMMERCIAL OPERATE...MARCH 10, 1973
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...MISSISSIPPI RIVER
ELECTRIC RELIABILITY
COUNCIL.....MID-AMERICA
INTERPOOL NETWORK

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....COMMONWEALTH EDISON
CORPORATE ADDRESS.....P.O. BOX 767
CHICAGO, ILLINOIS 60690
CONTRACTOR
ARCHITECT/ENGINEER.....SARGENT & LUNDY
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....UNITED ENG. & CONSTRUCTORS
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III
IE RESIDENT INSPECTOR.....A. MADISON
LICENSING PROJ MANAGER.....T. ROTELLA
DOCKET NUMBER.....50-265
LICENSE & DATE ISSUANCE...DPR-30, DECEMBER 14, 1972
PUBLIC DOCUMENT ROOM.....MOLINE PUBLIC LIBRARY
504 17TH STREET
MOLINE, ILLINOIS 61265

INSPECTION STATUS

INSPECTION SUMMARY

INSPECTION ON MAY 28-30 AND JUNE 4-5 AND 17 (86012; 86011): ROUTINE, UNANNOUNCED INSPECTION OF GASEOUS AND LIQUID RADIOACTIVE EFFLUENTS INCLUDING: EFFLUENT RELEASES; RECORDS AND REPORTS OF EFFLUENTS; EFFLUENT CONTROL INSTRUMENTATION; PROCEDURES FOR CONTROLLING RELEASES; REACTOR COOLANT CHEMISTRY AND ACTIVITY; GASEOUS EFFLUENT FILTRATION; AND AUDITS. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

Report Period JUL 1986

I N S P E C T I O N S T A T U S - (CONTINUED)

* QUAD CITIES 2 *

OTHER ITEMS

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

H. TOREN, SITE EMERGENCY PLANNING COORDINATOR SINCE OCTOBER 1985, WILL BE LEAVING QUAD-CITIES NUCLEAR PLANT ON MARCH 21, 1986.
HIS REPLACEMENT HAS NOT YET BEEN SELECTED BY MANAGEMENT.

PLANT STATUS:

OPERATING ROUTINELY

LAST IE SITE INSPECTION DATE: 10/04/86

INSPECTION REPORT NO: 86013

R E P O R T S F R O M L I C E N S E E

```
=====
NUMBER      DATE OF      DATE OF      SUBJECT
            EVENT       REPORT
-----
86-09      06/26/86    07/16/86    2B CORE SPRAY ROOM COOLER INOPERABLE DUE TO DRIVE BELT FAILURE
86-10      06/27/86    07/22/86    UNIT 2 SPURIOUS CLEAN-UP SYSTEM ISOLATION CAUSED BY ELECTRICAL SPIKE DUE TO PERSONNEL ERROR
=====
```

1. Docket: 50-312 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/86 Outage + On-line Hrs: 744.0

3. Utility Contact: RON COLOMBO (916) 452-3211

4. Licensed Thermal Power (MWt): 2772

5. Nameplate Rating (Gross MWe): 1070 X 0.9 = 963

6. Design Electrical Rating (Net MWe): 918

7. Maximum Dependable Capacity (Gross MWe): 917

8. Maximum Dependable Capacity (Net MWe): 873

9. If Changes Occur Above Since Last Report, Give Reasons: NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any: NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,087.0</u>	<u>98,952.0</u>
13. Hours Reactor Critical	<u>.0</u>	<u>.0</u>	<u>52,565.0</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>10,647.7</u>
15. Hrs Generator On-Line	<u>.0</u>	<u>.0</u>	<u>50,363.8</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>1,210.2</u>
17. Gross Therm Ener (MWH)	<u>0</u>	<u>0</u>	<u>124,228,535</u>
18. Gross Elec Ener (MWH)	<u>0</u>	<u>0</u>	<u>41,528,149</u>
19. Net Elec Ener (MWH)	<u>-3,010</u>	<u>-14,641</u>	<u>39,063,470</u>
20. Unit Service Factor	<u>.0</u>	<u>.0</u>	<u>50.9</u>
21. Unit Avail Factor	<u>.0</u>	<u>.0</u>	<u>52.1</u>
22. Unit Cap Factor (MDC Net)	<u>.0</u>	<u>.0</u>	<u>45.2</u>
23. Unit Cap Factor (DER Net)	<u>.0</u>	<u>.0</u>	<u>43.0</u>
24. Unit Forced Outage Rate	<u>100.0</u>	<u>100.0</u>	<u>34.5</u>
25. Forced Outage Hours	<u>744.0</u>	<u>5,087.0</u>	<u>26,472.5</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration): NONE

27. If Currently Shutdown Estimated Startup Date: 12/25/86

 * RANCHO SECO 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
 RANCHO SECO 1



JULY 1986

Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

 * RANCHO SECO 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
1	12/26/86	F	744.0	A	4	85-25	CB	INSTRU	REACTOR TRIP ON HIGH PRESSURE PRECEDED BY TOTAL LOSS OF ICS POWER. CORRECTIVE ACTIONS BEING IMPLEMENTED.

 * SUMMARY *

 RANCHO SECO 1 REMAINS SHUT DOWN FOLLOWING A REACTOR TRIP ON DECEMBER 26, 1985.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* RANCHO SECO 1 *

FACILITY DATA

Report Period JUL 1986

FACILITY DESCRIPTION

LOCATION
STATE.....CALIFORNIA
COUNTY.....SACRAMENTO
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...25 MI SE OF
SACRAMENTO, CA
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...SEPTEMBER 16, 1974
DATE ELEC ENER 1ST GENER...OCTOBER 13, 1974
DATE COMMERCIAL OPERATE...APRIL 17, 1975
CONDENSER COOLING METHOD...COOLING TOWERS
CONDENSER COOLING WATER...FOLSOM CANAL
ELECTRIC RELIABILITY
COUNCIL.....WESTERN SYSTEMS
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....SACRAMENTO MUN. UTIL. DISTRICT
CORPORATE ADDRESS.....6201 S STREET P.O. BOX 15830
SACRAMENTO, CALIFORNIA 95813
CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...BABCOCK & WILCOX
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....V
IE RESIDENT INSPECTOR.....J. ECKHARD
LICENSING PROJ MANAGER.....S. MINER
DOCKET NUMBER.....50-312
LICENSE & DATE ISSUANCE...DPR-54, AUGUST 16, 1974
PUBLIC DOCUMENT ROOM.....BUSINESS AND MUNICIPAL DEPARTMENT
SACRAMENTO LIBRARY
828 I STREET
SACRAMENTO, CALIFORNIA 95814

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

- + INSPECTION ON MAY 27 - JULY 9, 1986 (REPORT NO. 50-312/86-19) AREAS INSPECTED: SECURITY PLAN AND IMPLEMENTING PROCEDURES; PHYSICAL BARRIERS; AND LIGHTING. DURING THIS INSPECTION, VARIOUS INSPECTION PROCEDURES WERE UTILIZED.
RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.
- + INSPECTION ON JUNE 2 - JULY 11, 1986 (REPORT NO. 50-312/86-21) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.
- + INSPECTION ON JUNE 10 - JULY 11, 1986 (REPORT NO. 50-312/86-22) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.
- + ENFORCEMENT CONFERENCE ON JUNE 20, 1986 (REPORT NO. 50-312/86-23) SUMMARY: THE FOLLOWING TOPICS WERE DISCUSSED: 1. APPARENT VIOLATIONS IDENTIFIED DURING INSPECTIONS OF THE EMERGENCY PREPAREDNESS PROGRAM AND RADIOACTIVE EFFLUENT MANAGEMENT (INSPECTION REPORT NOS. 50-312/86-14 AND 50-312/86-15); 2. MATTERS OF CONCERN TO THE NRC.
- + INSPECTION ON JUNE 24 - JULY 17, 1986 (REPORT NO. 50-312/86-24) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.
- + INSPECTION ON JULY 7-11, 1986 (REPORT NO. 50-312/86-25) AREAS INSPECTED: ROUTINE, UNANNOUNCED INSPECTION BY REGIONALLY BASED INSPECTOR OF LICENSEE ACTION ON INSPECTOR-IDENTIFIED ITEMS AND IMPLEMENTATION OF QUALITY ASSURANCE PROGRAM REQUIREMENTS. DURING THIS INSPECTION, VARIOUS INSPECTION PROCEDURES WERE UTILIZED.

Report Period JUL 1986

INSPECTION STATUS - (CONTINUED)

* RANCHO SECO 1 *

INSPECTION SUMMARY

RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

- + INSPECTION ON JULY 14 - AUGUST 6, 1986 (REPORT NO. 50-312/86-27) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.
- + INSPECTION ON AUGUST 4-15, 1986 (REPORT NO. 50-312/86-28) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.
- + INSPECTION ON JUNE 1, 1985 - JUNE 30, 1986 (REPORT NO. 50-312/86-29) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.
- + INSPECTION ON JULY 14 - AUGUST 15, 1986 (REPORT NO. 50-312/86-30) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.
- + INSPECTION ON JULY 30-31, 1986 (REPORT NO. 50-312/86-31) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

ENFORCEMENT SUMMARY

RANCHO SECO T.S. 6.8.1.A REQUIRES THAT THE APPLICABLE PROCEDURES RECOMMENDED IN APP. A OF REGULATORY GUIDE 1.33 (NOVEMBER, 1972) SHALL BE ESTABLISHED. SECTION C OF APP. A, REGULATORY GUIDE 1.33, RECOMMENDS PROCEDURES FOR STARTUP, OPERATION, AND SHUTDOWN OF SAFETY-RELATED PWR SYSTEMS INCLUDING INSTRUCTIONS FOR CHANGING MODES OF OPERATION. SECTION F OF APP. A, REGULATORY GUIDE 1.33 (NOVEMBER 1972) RECOMMENDS PROCEDURES FOR COMBATING EMERGENCIES AND OTHER SIGNIFICANT EVENTS. CONTRARY TO THE REQUIREMENT: 1) ON DECEMBER 26, 1985, NO WRITTEN PROCEDURES EXISTED FOR THE EXERCISE OF THE MANUALLY OPERATED AUXILIARY FEEDWATER SYSTEM VALVE FWS-063, WHICH WAS NORMALLY IDLE; 2) THE LICENSEE GUIDANCE FOR LOSS OF 120 VAC AND 125 VDC POWER SUPPLIES, LOSS OF FLUX INDICATION, TORNADO, DAM FAILURE, AND IRRADIATED FUEL DAMAGE WHILE REFUELING DID NOT HAVE THE ELEMENTS CONTAINED IN SECTION 5.3.8.1 OF ANSI 18.7-1972 WHICH IS REFERENCED BY REGULATORY GUIDE 1.33; 3) NO WRITTEN PROCEDURES FOR MANUAL EMERGENCY OPERATION OF AUXILIARY FEEDWATER CONTROL VALVE FV20527 EXISTED DURING THE DECEMBER 26, 1985 LOSS OF ICS POWER EVENT. CONSEQUENTLY THE VALVE WAS OPERATED USING EXCESSIVE LEVERAGE ON THE MANUAL OPERATOR; 4) DURING THE COOLDOWN TRANSIENT OF DECEMBER 26, 1985, AFW PUMP P-318 WAS NOT STOPPED WHEN THE LEVEL IN 'A' OTSG REACHED 95%. ALSO, THE AFW FLOW WAS NOT STOPPED TO THE STEAM GENERATORS TO PREVENT EXCESSIVE HEAT TRANSFER. CONSEQUENTLY, WATER OVERFLOWED INTO THE MAIN STEAM LINES OF THE 'A' OTSG AND THE REACTOR COOLANT SYSTEM WAS EXCESSIVELY COOLED; 5) NO WRITTEN PROCEDURES HAD BEEN ESTABLISHED FOR SECURING THE SAFETY-RELATED HIGH PRESSURE INJECTION SYSTEM FOLLOWING SAFETY FEATURES ACTUATION. CONSEQUENTLY, DURING THE DECEMBER 26TH EVENT, THE MAKEUP AUXILIARY PUMP (P-236) CONTINUED TO OPERATE WITHOUT A SOURCE OF COOLANT, WAS DAMAGED AND PRIMARY COOLANT WAS RELEASED TO THE AUXILIARY BUILDING; 6) NO WRITTEN PROCEDURES FOR THE LOSS OF POWER TO THE INTEGRATED CONTROL SYSTEM HAD BEEN ESTABLISHED FOR USE AT RANCHO SECO ON DECEMBER 26, 1985, WHEN LOSS OF DC POWER SUPPLY TO THE INTEGRATED CONTROL SYSTEM OCCURRED. THE LOSS OF POWER RESULTED IN A SIGNIFICANT PLANT TRANSIENT THAT INVOLVED EXCESSIVE COOLDOWN OF THE PRIMARY COOLANT SYSTEM. TECHNICAL SPECIFICATION 3.13.1 REQUIRES THE CONTROL ROOM/TECHNICAL SUPPORT CENTER (CR/TSC) EMERGENCY FILTER SYSTEM TO BE OPERABLE AT ALL TIMES WHEN CONTAINMENT INTEGRITY IS REQUIRED. TECHNICAL SPECIFICATION 4.10 REQUIRES A SYSTEM AIR FLOW OF 3200 CFM (+/-10% DURING PERIODIC TESTING OF THE CONTROL ROOM/TECHNICAL SUPPORT CENTER EMERGENCY FILTERING SYSTEM TO DEMONSTRATE THAT THE SYSTEM IS OPERABLE. CONTRARY TO THE REQUIREMENT, ON OCTOBER 1, 1985, OPERATING AIRFLOW RATES THROUGH THE CR/TSC EMERGENCY FILTRATION SYSTEM WERE MEASURED TO RANGE FROM 3581 TO 4170 CFM DURING THE ENTIRE DURATION OF THE 24 MINUTE SURVEILLANCE TEST. FURTHERMORE, DURING ACTUAL EMERGENCY OPERATION OF THE 'B' TRAIN ON DECEMBER 26, 1985, WHILE CONTAINMENT INTEGRITY WAS REQUIRED AIR FLOW RATES RANGED FROM 4071 TO 4575 CFM DURING EMERGENCY OPERATION FOR 8 MINUTES. NO CORRECTIVE ACTIONS WERE TAKEN TO CORRECT THE EXCESSIVE AIR FLOW RATES AFTER THE OCTOBER 1, 1985, SURVEILLANCE TEST.
(8600 3)

RANCHO SECO TECHNICAL SPECIFICATION 6.8.1.A REQUIRES THAT THE APPLICABLE PROCEDURES RECOMMENDED IN APPENDIX A OF REGULATORY GUIDE 1.33 (NOVEMBER, 1972) SHALL BE ESTABLISHED. SECTION H OF APPENDIX A, REGULATORY GUIDE 1.33 RECOMMENDS THAT "PROCEDURES OF A TYPE APPROPRIATE TO THE CIRCUMSTANCES SHOULD BE PROVIDED TO ASSURE THAT TOOLS, GAUGES, INSTRUMENTS, CONTROLS, AND OTHER MEASURING AND TESTING DEVICES ARE PROPERLY CONTROLLED, CALIBRATED, AND ADJUSTED AT SPECIFIED PERIODS TO MAINTAIN ACCURACY." CONTRARY TO THE REQUIREMENT, ON APRIL 11, 1986, NO WRITTEN PROCEDURES EXISTED SPECIFICALLY ADDRESSING CRIMPING TOOL CALIBRATION AND CONTROL.
(8600 4)

Report Period JUL 1986

INSPECTION STATUS - (CONTINUED)

* RANCHO SECO 1 *

ENFORCEMENT SUMMARY

RANCHO SECO TECHNICAL SPECIFICATION 6.5.1.6.D STATES THAT THE PRC SHALL BE RESPONSIBLE FOR REVIEW OF ALL PROPOSED CHANGES OR MODIFICATIONS TO PLANT SYSTEMS OR EQUIPMENT THAT AFFECT NUCLEAR SAFETY. CONTRARY TO THE REQUIREMENT, THE PRC DID NOT REVIEW NRC #5218, WHICH MODIFIED A REACTOR COOLANT SYSTEM PRESSURE BOUNDARY VALVE. (8601 4)

10 CFR 50.59(B) STATES, IN PART, "...THE LICENSEE SHALL FURNISH ... ANNUALLY OR AT SUCH SHORTER INTERVALS AS MAY BE SPECIFIED IN THE LICENSE, A REPORT CONTAINING A BRIEF DESCRIPTION OF SUCH CHANGES ... INCLUDING A SUMMARY OF THE SAFETY EVALUATION OF EACH." PARAGRAPH 6.9.3 OF THE RANCHO SECO TECHNICAL SPECIFICATIONS SPECIFIES, IN PART, "... TABULATION OF FACILITY CHANGES, TESTS OR EXPERIMENTS REQUIRED PURSUANT TO 10 CFR 50.59(B), SHALL BE SUBMITTED ON A MONTHLY BASIS ..." CONTRARY TO THE REQUIREMENT, THE LICENSEE'S MONTHLY REPORT TABULATIONS FOR 10 CFR 50.59 MODIFICATIONS DO NOT MEET, IN MANY CASES, THE REPORTING REQUIREMENTS OF ANNUAL OR SHORTER INTERVAL; NOR DO THEY MEET THE REQUIREMENT FOR A SUMMARY SAFETY EVALUATION TO BE INCLUDED WITH EACH 10 CFR 50.59 CHANGE DESCRIPTION. RANCHO SECO TECHNICAL SPECIFICATION 6.8.1 STATES IN PART: "WRITTEN PROCEDURES SHOULD BE ESTABLISHED, IMPLEMENTED AND MAINTAINED COVERING ... THE APPLICABLE PROCEDURES RECOMMENDED IN APP. A OF REG. GUIDE 1.33, NOVEMBER 1972." PARAGRAPH A.3 RECOMMENDS ADMINISTRATIVE PROCEDURES FOR EQUIPMENT CONTROL. CONTRARY TO THE REQUIREMENT, ON DECEMBER 8, 1985, NO ABNORMAL TAG WAS HUNG ON VALVE SFV-22006 AFTER BEING TEMPORARILY MODIFIED AND RETURNED TO SERVICE UNDER NCR #5218. (8601 5)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

INTEGRATED CONTROL SYSTEM UNDER REVIEW FOLLOWING EXCESSIVE COOLDOWN RATE PRODUCED WHEN SYSTEM LOST DC POWER AT 100% REACTOR POWER.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

RESTART ACTION PLAN IMPLEMENTATION IS BEING REVIEWED BY NRR AND REGION V PRIOR TO RETURN TO OPERATION.

ENFORCEMENT CONFERENCE WAS HELD ON MAY 16, 1986, ON VIOLATIONS RELATED TO THE DECEMBER 26, 1985, EVENT AND FOLLOWUP ACTIVITIES.

+ NRC SALP BOARD MEETING WAS HELD ON AUGUST 12, 1986.

PLANT STATUS:

PLANT REMAINS IN COLD SHUTDOWN FOLLOWING PLANT TRIP FROM 100% DUE TO LOSS OF ICS DC POWER ON DECEMBER 26, 1985.

LAST IE SITE INSPECTION DATE: 07/14-08/15/86+

INSPECTION REPORT NO: 50-312/86-30+

Report Period JUL 1986

REPORTS FROM LICENSEE

* RANCHO SECO 1 *

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
86-01-L0	12-18-85	01-14-86	DIESEL GENERATORS 'A' AND 'B' DECLARED INOPERABLE DURING COLD SHUTDOWN
86-06-L0	04-14-86	05-12-86	FIRE PROTECTION SYSTEMS OVERDUE FOR SURVEILLANCE
86-07-L0	04-14-86	05-19-86	CONTROL ROOM EMERGENCY HEATING, VENTILATING, AND AIR CONDITIONING HIGH FLOW CONDITION
86-08-L0	04-29-86	05-29-86	FAILURE TO INSTITUTE FIRE WATCH FOR BREACHED PENETRATION
86-09-L0	05-09-86	06-09-86	INADVERTENT ENGINEERED SAFETY FEATURES SYSTEM ACTUATIONS
86-10-L0	05-22-86	06-19-86	REDUNDANT CABLING IN THE SAME FIRE AREA

=====

1. Docket: 50-458 OPERATING STATUS

2. Reporting Period: 07/01/86 Outage + On-line Hrs: 744.0

3. Utility Contact: J. H. SIMMONS (504) 635-6094

4. Licensed Thermal Power (MWt): 2894

5. Nameplate Rating (Gross MWe): 2894

6. Design Electrical Rating (Net MWe): 936

7. Maximum Dependable Capacity (Gross MWe): 936

8. Maximum Dependable Capacity (Net MWe): 936

9. If Changes Occur Above Since Last Report, Give Reasons:

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>4,343.0</u>	<u>4,343.0</u>
13. Hours Reactor Critical	<u>469.5</u>	<u>2,755.4</u>	<u>2,755.4</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>400.3</u>	<u>2,338.7</u>	<u>2,338.7</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,076,579</u>	<u>4,769,129</u>	<u>4,769,129</u>
18. Gross Elec Ener (MWH)	<u>353,301</u>	<u>1,506,369</u>	<u>1,506,369</u>
19. Net Elec Ener (MWH)	<u>329,568</u>	<u>1,378,481</u>	<u>1,378,481</u>
20. Unit Service Factor			
21. Unit Avail Factor		NOT IN	
22. Unit Cap Factor (MDC Net)		COMMERCIAL	
23. Unit Cap Factor (DER Net)		OPERATION	
24. Unit Forced Outage Rate			
25. Forced Outage Hours	<u>343.7</u>	<u>1,013.1</u>	<u>1,013.1</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):

TURBINE TORSIONAL VIBRATION TEST: AUGUST 15, 1986, 12 DAYS

27. If Currently Shutdown Estimated Startup Date: N/A

 * RIVER BEND 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
 RIVER BEND 1



JULY 1986

Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

 * RIVER BEND 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
1	07/01/86	F	168.9	A	1				CONTINUED FROM JULY OUTAGE TO REPAIR EHC LINE LEAK AND TESTABLE CHECK VALVE LEAK IN DRYWELL.
2	07/08/86	F	71.9	A	3				MSR DRAIN TANK MANWAY GASKET BLEW OUT. TURBINE BUILDING HIGH AREA TEMPERATURE/MSIV ISOLATION AND REACTOR SCRAM.
3	07/13/86	F	102.9	A	3				STEAM SEAL EVAPORATOR LEVEL CONTROL FAILED TO MAINTAIN LEVEL. LOSS OF STEAM SEALS TO MAIN TURBINE RESULTED IN LOSS OF VACUUM, TURBINE TRIP AND REACTOR SCRAM.

 * SUMMARY *

 RIVER BEND 1 INCURRED 3 SHUTDOWNS IN JULY AS DISCUSSED ABOVE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* RIVER BEND 1 *

F A C I L I T Y D A T A

Report Period JUL 1986

FACILITY DESCRIPTION

UTILITY & CONTRACTOR INFORMATION

LOCATION
STATE.....LOUISIANA
COUNTY.....WEST FELICIANA
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...24 MI NNW OF
BATON ROUGE, LA
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...OCTOBER 31, 1985
DATE ELEC ENER 1ST GENER...DECEMBER 3, 1985
DATE COMMERCIAL OPERATE....*****
CONDENSER COOLING METHOD...MDCT
CONDENSER COOLING WATER...MISSISSIPPI RIVER
ELECTRIC RELIABILITY
COUNCIL.....SOUTHWEST POWER POOL

UTILITY
LICENSEE.....GULF STATES UTILITIES
CORPORATE ADDRESS.....P.O. BOX 2951
BEAUMONT, LOUISIANA 77704
CONTRACTOR
ARCHITECT/ENGINEER.....STONE & WEBSTER
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....STONE & WEBSTER
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....IV
IE RESIDENT INSPECTOR.....D. CHAMBERLAIN
LICENSING PROJ MANAGER.....S. STERN
DOCKET NUMBER.....50-458
LICENSE & DATE ISSUANCE...NPF-47, NOVEMBER 20, 1985
PUBLIC DOCUMENT ROOM.....GOVERNMENT DOCUMENTS DEPARTMENT
TROY H. MIDDLETON LIBRARY
LOUISIANA STATE UNIVERSITY
BATON ROUGE, LOUISIANA 70803

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INFO. NOT SUPPLIED BY REGION

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

INFO. NOT SUPPLIED BY REGION

FACILITY ITEMS (PLANS AND PROCEDURES):

INFO. NOT SUPPLIED BY REGION

MANAGERIAL ITEMS:

INFO. NOT SUPPLIED BY REGION

Report Period JUL 1986

I N S P E C T I O N S T A T U S - (C O N T I N U E D)

* R I V E R B E N D 1 *

PLANT STATUS:

INFO. NOT SUPPLIED BY REGION

LAST IE SITE INSPECTION DATE: INFO. NOT SUPPLIED BY REGION

INSPECTION REPORT NO: INFO. NOT SUPPLIED BY REGION

R E P O R T S F R O M L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
--------	------------------	-------------------	---------

INFO. NOT SUPPLIED BY REGION

=====

1. Docket: 50-261 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/86 Outage + On-line Hrs: 744.0

3. Utility Contact: ANITA E. SCOTT (803) 383-4524

4. Licensed Thermal Power (MWh): 2300

5. Nameplate Rating (Gross MWe): 854 X 0.9 = 769

6. Design Electrical Rating (Net MWe): 700

7. Maximum Dependable Capacity (Gross MWe): 700

8. Maximum Dependable Capacity (Net MWe): 665

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,087.0</u>	<u>135,077.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>3,708.1</u>	<u>95,764.7</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>280.8</u>	<u>2,936.4</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>3,624.0</u>	<u>93,391.9</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>23.2</u>
17. Gross Therm Ener (MWH)	<u>1,693,508</u>	<u>7,653,284</u>	<u>187,145,197</u>
18. Gross Elec Ener (MWH)	<u>533,076</u>	<u>2,537,891</u>	<u>60,397,382</u>
19. Net Elec Ener (MWH)	<u>527,016</u>	<u>2,403,303</u>	<u>57,052,877</u>
20. Unit Service Factor	<u>100.0</u>	<u>71.2</u>	<u>69.1</u>
21. Unit Avail Factor	<u>100.0</u>	<u>71.2</u>	<u>69.2</u>
22. Unit Cap Factor (MDC Net)	<u>106.5</u>	<u>71.0</u>	<u>63.5</u>
23. Unit Cap Factor (DER Net)	<u>101.2</u>	<u>67.5</u>	<u>60.3</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>7.1</u>	<u>13.9</u>
25. Forced Outage Hours	<u>.0</u>	<u>278.8</u>	<u>9,323.8</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

* ROBINSON 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
ROBINSON 2



JULY 1986

Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

* ROBINSON 2 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
-----	------	------	-------	--------	--------	------------	--------	-----------	---

NONE

* SUMMARY *

ROBINSON 2 OPERATED ROUTINELY IN JULY WITH NO OUTAGES OR
POWER REDUCTIONS REPORTED.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* ROBINSON 2 *

FACILITY DATA

Report Period JUL 1986

FACILITY DESCRIPTION

LOCATION
STATE.....SOUTH CAROLINA
COUNTY.....DARLINGTON
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...5 MI NW OF
HARTSVILLE, SC
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...SEPTEMBER 20, 1970
DATE ELEC ENER 1ST GENER...SEPTEMBER 26, 1970
DATE COMMERCIAL OPERATE...MARCH 7, 1971
CONDENSER COOLING METHOD...RECIRCULATION
CONDENSER COOLING WATER...ROBINSON IMPOUNDMENT
ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....CAROLINA POWER & LIGHT
CORPORATE ADDRESS.....411 FAYETTEVILLE STREET
RALEIGH, NORTH CAROLINA 27601
CONTRACTOR
ARCHITECT/ENGINEER.....EBASCO
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....EBASCO
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
IE RESIDENT INSPECTOR.....P. KRUG
LICENSING PROJ MANAGER....G. REQUA
DOCKET NUMBER.....50-261
LICENSE & DATE ISSUANCE...DPR-23, SEPTEMBER 23, 1970
PUBLIC DOCUMENT ROOM.....HARTSVILLE MEMORIAL LIBRARY
220 N. FIFTH ST.
HARTSVILLE, SOUTH CAROLINA 29550

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION APRIL 28 - MAY 2 (86-11): THIS ROUTINE, UNANNOUNCED INSPECTION WAS CONDUCTED ON SITE IN THE AREAS OF LICENSED OPERATOR TRAINING AND TRAINING OF NON-LICENSED PERSONNEL. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JUNE 11 - JULY 10 (86-15): THIS ROUTINE, ANNOUNCED INSPECTION WAS CONDUCTED IN THE AREAS OF TECHNICAL SPECIFICATION (TS) COMPLIANCE, PLANT TOUR, OPERATIONS PERFORMANCE, REPORTABLE OCCURRENCES, HOUSEKEEPING, SITE SECURITY, SURVEILLANCE ACTIVITIES, MAINTENANCE ACTIVITIES, QUALITY ASSURANCE PRACTICES, RADIATION CONTROL ACTIVITIES, OUTSTANDING ITEMS REVIEW, IE BULLETIN AND IE NOTICE FOLLOWUP, ORGANIZATION AND ADMINISTRATION, INDEPENDENT INSPECTION, SYSTEMATIC ASSESSMENT OF LICENSEE PERFORMANCE (SALP) AND ENFORCEMENT ACTION FOLLOWUP. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED WITHIN THE AREAS INSPECTED.

INSPECTION JUNE 9-13 (86-16): THIS ROUTINE, UNANNOUNCED INSPECTION WAS CONDUCTED IN THE AREAS OF FIRE PREVENTION/PROTECTION AND FOLLOWUP ON PREVIOUSLY IDENTIFIED ITEMS. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

Report Period JUL 1986

I N S P E C T I O N S T A T U S - (CONTINUED)

* ROBINSON 2 *

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

NORMAL OPERATION.

LAST IE SITE INSPECTION DATE: JUNE 9-13, 1986 +

INSPECTION REPORT NO: 50-261/86-16 +

R E P O R T S F R O M L I C E N S E E

=====			
NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT

NONE.			
=====			

1. Docket: 50-272 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/86 Outage + On-line Hrs: 744.0

3. Utility Contact: PELL WHITE (609) 935-6000 X4451

4. Licensed Thermal Power (MWt): 3338

5. Nameplate Rating (Gross MWe): 1300 X 0.9 = 1170

6. Design Electrical Rating (Net MWe): 1090

7. Maximum Dependable Capacity (Gross MWe): 1124

8. Maximum Dependable Capacity (Net MWe): 1079

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____
NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,087.0</u>	<u>79,656.0</u>
13. Hours Reactor Critical	<u>595.4</u>	<u>3,741.7</u>	<u>47,927.1</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>3,088.4</u>
15. Hrs Generator On-Line	<u>589.0</u>	<u>3,585.1</u>	<u>46,089.7</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,897,838</u>	<u>11,421,037</u>	<u>141,907,272</u>
18. Gross Elec Ener (MWH)	<u>633,030</u>	<u>3,715,970</u>	<u>47,009,778</u>
19. Net Elec Ener (MWH)	<u>603,687</u>	<u>3,538,662</u>	<u>44,644,654</u>
20. Unit Service Factor	<u>79.2</u>	<u>70.5</u>	<u>57.9</u>
21. Unit Avail Factor	<u>79.2</u>	<u>70.5</u>	<u>57.9</u>
22. Unit Cap Factor (MDC Net)	<u>75.2</u>	<u>64.5</u>	<u>51.9</u>
23. Unit Cap Factor (DER Net)	<u>74.4</u>	<u>63.8</u>	<u>51.4</u>
24. Unit Forced Outage Rate	<u>20.8</u>	<u>10.1</u>	<u>28.8</u>
25. Forced Outage Hours	<u>155.0</u>	<u>402.9</u>	<u>18,891.7</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

 * SALEM 1 *

 AVERAGE DAILY POWER LEVEL (MWe) PLOT
 SALEM 1



JULY 1986

Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

* SALEM 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
594	07/21/86	F	155.0	A	1		ZZ	GENERA	H2 LEAK ON GENERATOR.

* SUMMARY *

SALEM 1 HAD 1 OUTAGE IN JULY BECAUSE OF A GENERATOR HYDROGEN LEAK.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* SALEM 1 *

FACILITY DATA

Report Period JUL 1986

FACILITY DESCRIPTION

LOCATION
STATE.....NEW JERSEY
COUNTY.....SALEM
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...20 MI S OF
WILMINGTON, DEL
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...DECEMBER 11, 1976
DATE ELEC ENER 1ST GENER...DECEMBER 25, 1976
DATE COMMERCIAL OPERATE....JUNE 30, 1977
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...DELAWARE RIVER
ELECTRIC RELIABILITY
COUNCIL.....MID-ATLANTIC
AREA COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....PUBLIC SERVICE ELECTRIC & GAS
CORPORATE ADDRESS.....80 PARK PLACE
NEWARK, NEW JERSEY 07101
CONTRACTOR
ARCHITECT/ENGINEER.....PUBLIC SERVICES & GAS CO.
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....UNITED ENG. & CONSTRUCTORS
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I
IE RESIDENT INSPECTOR.....T. LINVILLE
LICENSING PROJ MANAGER.....D. FISCHER
DOCKET NUMBER.....50-272
LICENSE & DATE ISSUANCE....DPR-70, DECEMBER 1, 1976
PUBLIC DOCUMENT ROOM.....SALEM FREE PUBLIC LIBRARY
112 WEST BROADWAY
SALEM, NEW JERSEY 08079

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

REGULATORY GUIDE 1.33, NOVEMBER 1972, APPENDIX "A", PART J STATES IN PART "CHEMICAL AND RADIOCHEMICAL CONTROL PROCEDURES SHOULD BE WRITTEN TO PRESCRIBE THE NATURE AND FREQUENCY OF SAMPLING AND ANALYSIS, INSTRUCTIONS MAINTAINING WATER CHEMISTRY WITHIN PRESCRIBED LIMITS...AND THAT THESE PROCEDURES SHOULD SPECIFY LABORATORY INSTRUCTIONS AND CALIBRATION OF LABORATORY EQUIPMENT. TECHNICAL SPECIFICATIONS 6.8.1 STATES: WRITTEN PROCEDURES SHALL BE ESTABLISHED, IMPLEMENTED AND MAINTAINED COVERING THE ACTIVITY REFERENCED BELOW: THE APPLICABLE PROCEDURES RECOMMENDED IN APPENDIX "A" OF REGULATORY GUIDE 1.33, NOVEMBER 1972. PSE&G CHEMISTRY ORGANIZATION MANUAL, CHAPTER 7, "CHEMISTRY QUALITY CONTROL," PART 4, "SELECTION AND CONTROL OF REAGENTS," STATES IN PART "CHEMICALS AND REAGENTS SHOULD HAVE EXPIRATION DATE STICKERS ON THEIR CONTAINERS. THE CHEMICALS SHOULD NOT BE USED AFTER THEIR EXPIRATION DATE." PART 5, "SELECTION AND CONTROL OF STANDARDS" STATES IN PART "SHELF LIFE SHALL BE AFFIXED TO STANDARDS AS WELL AS REAGENTS." CONTRARY TO THE ABOVE, ON MARCH 11, 1986 CHEMICALS THAT WERE OUT OF DATE WERE IDENTIFIED, BY THE INSPECTOR, ON THE CHEMISTRY LABORATORY SHELVES. FURTHER INVESTIGATION IDENTIFIED INSTANCES WHERE OUT OF DATE CHEMICAL WERE USED IN THE PRODUCTION OF STANDARDS WHICH WERE USED IN CHEMICAL ANALYSIS.

(8600 5)

INSPECTION STATUS - (CONTINUED)

REPORTS FROM LICENSEE

PAGE 2-323

OPERATING STATUS

2. Reporting Period: 07/01/86 Outage + On-line Hrs: 744.0

3. Utility Contact: PELL WHITE (609) 935-6000 X4451

4. Licensed Thermal Power (MWt): 3411

5. Nameplate Rating (Gross MWe): 1162

6. Design Electrical Rating (Net MWe): 1115

7. Maximum Dependable Capacity (Gross MWe): 1149

8. Maximum Dependable Capacity (Net MWe): 1106

9. If Changes Occur Above Since Last Report, Give Reasons:

NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,087.0</u>	<u>42,072.0</u>

13. Hours Reactor Critical	673.2	4,536.5	24,862.2
----------------------------	-------	---------	----------

14. Rx Reserve Shtdwn Hrs	.0	.0	3,533.6
---------------------------	----	----	---------

15. Hrs Generator On-Line	<u>655.3</u>	<u>4,478.3</u>	<u>24,015.1</u>
---------------------------	--------------	----------------	-----------------

16. Unit Reserve Shtdwn Hrs .0 .0 .0

17. Gross Therm Ener (MWH)	2,147,440	14,810,717	74,556,415
----------------------------	-----------	------------	------------

18. Gross Elec Ener (MWH)	682,460	4,823,890	24,400,370
---------------------------	---------	-----------	------------

19. Net Elec Ener (MWH)	<u>648,747</u>	<u>4,614,063</u>	<u>23,148,918</u>
-------------------------	----------------	------------------	-------------------

20. Unit Service Factor	<u>88.1</u>	<u>88.0</u>	<u>57.1</u>
-------------------------	-------------	-------------	-------------

21. Unit Avail Factor	<u>88.1</u>	<u>88.0</u>	<u>57.1</u>
-----------------------	-------------	-------------	-------------

22. Unit Cap Factor (MDC Net) 78.8 82.0 49.7

23. Unit Cap Factor (DER Net) 78.2 81.3 49.3

24. Unit Forced Outage Rate	<u>11.9</u>	<u>11.8</u>	<u>36.7</u>
-----------------------------	-------------	-------------	-------------

25. Forced Outage Hours	<u>88.7</u>	<u>600.0</u>	<u>13,895.6</u>
-------------------------	-------------	--------------	-----------------

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):

SCHEDULED REFUELING: 10/4/86 - 11/26/86

27. If Currently Shutdown Estimated Startup Date: N/A


```

XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX
X                SALEM 2                X
XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX

```

AVERAGE DAILY POWER LEVEL (MWe) PLOT

SALEM 2



JULY 1986

Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

 * SALEM 2 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
442	07/14/86	F	38.0	A	3		ED	GENERA	CONDUCTORS & BUSES AC INSTRUMENT POWER.
444	07/16/86	F	50.7	A	3		CC	PUMPXX	FEEDWATER PUMP/DRIVE LUBE OIL SYSTEM.

 * SUMMARY *

 SALEM 2 HAD 2 SHUTDOWNS IN JULY AS DESCRIBED ABOVE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* SALEM 2 *

FACILITY DATA

Report Period JUL 1986

FACILITY DESCRIPTION

LOCATION
STATE.....NEW JERSEY
COUNTY.....SALEM
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...20 MI S OF
WILMINGTON, DEL
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...AUGUST 8, 1980
DATE ELEC ENER 1ST GENER...JUNE 3, 1981
DATE COMMERCIAL OPERATE...OCTOBER 13, 1981
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...DELAWARE RIVER
ELECTRIC RELIABILITY
COUNCIL.....MID-ATLANTIC
AREA COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....PUBLIC SERVICE ELECTRIC & GAS
CORPORATE ADDRESS.....80 PARK PLACE
NEWARK, NEW JERSEY 07101
CONTRACTOR
ARCHITECT/ENGINEER.....PUBLIC SERVICES & GAS CO.
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....UNITED ENG. & CONSTRUCTORS
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I
IE RESIDENT INSPECTOR.....T. LINVILLE
LICENSING PROJ MANAGER.....D. FISCHER
DOCKET NUMBER.....50-311
LICENSE & DATE ISSUANCE....DPR-75, MAY 20, 1981
PUBLIC DOCUMENT ROOM.....SALEM FREE PUBLIC LIBRARY
112 WEST BROADWAY
SALEM, NEW JERSEY 08079

INSPECTION STATUS

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

Report Period JUL 1986

INSPECTION STATUS - (CONTINUED)

* SALEM 2 *

OTHER ITEMS

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

REPORTS FROM LICENSEE

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
--------	------------------	-------------------	---------

NO INPUT PROVIDED.

=====

1. Docket: 50-206 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/86 Outage + On-line Hrs: 744.0

3. Utility Contact: E. R. SIACOR (714) 368-6223

4. Licensed Thermal Power (MWt): 1347

5. Nameplate Rating (Gross MWe): 500 X 0.9 = 450

6. Design Electrical Rating (Net MWe): 436

7. Maximum Dependable Capacity (Gross MWe): 456

8. Maximum Dependable Capacity (Net MWe): 436

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe): 390

11. Reasons for Restrictions, If Any: STEAM GENERATOR TUBE CORROSION.


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,087.0</u>	<u>167,671.0</u>
13. Hours Reactor Critical	<u>271.5</u>	<u>271.5</u>	<u>96,384.7</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>125.2</u>	<u>125.2</u>	<u>92,500.7</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>75,740</u>	<u>75,740</u>	<u>117,386,864</u>
18. Gross Elec Ener (MWH)	<u>21,913</u>	<u>21,913</u>	<u>39,851,547</u>
19. Net Elec Ener (MWH)	<u>10,997</u>	<u>3,696</u>	<u>37,664,773</u>
20. Unit Service Factor	<u>16.8</u>	<u>2.5</u>	<u>55.2</u>
21. Unit Avail Factor	<u>16.8</u>	<u>2.5</u>	<u>55.2</u>
22. Unit Cap Factor (MDC Net)	<u>3.4</u>	<u>.2</u>	<u>51.5</u>
23. Unit Cap Factor (DER Net)	<u>3.4</u>	<u>.2</u>	<u>51.5</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.0</u>	<u>21.1</u>
25. Forced Outage Hours	<u>.0</u>	<u>.0</u>	<u>12,129.7</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

* SAN ONOFRE 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
SAN ONOFRE 1



JULY 1986

Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

 * SAN ONOFRE 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
93	11/21/85	S	618.8	C	4				REFUELING/BACKFIT WORK.
94	07/29/86	S	0.0	A	5	86-007	BA	PT	POWER REDUCTION DUE TO FAILURE OF STEAM DENSITY COMPENSATOR PRESSURE TRANSMITTER PT-459. PT-459 HAS BEEN REPLACED AND RETURNED TO SERVICE.

 * SUMMARY *

SAN ONOFRE 1 COMPLETED A REFUELING OUTAGE ON JULY 26.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* SAN ONOFRE 1 *

FACILITY DATA

Report Period JUL 1986

FACILITY DESCRIPTION

LOCATION
STATE.....CALIFORNIA
COUNTY.....SAN DIEGO
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...5 MI S OF
SAN CLEMENTE, CA
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...JUNE 14, 1967
DATE ELEC ENER 1ST GENER...JULY 16, 1967
DATE COMMERCIAL OPERATE...JANUARY 1, 1968
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...PACIFIC OCEAN
ELECTRIC RELIABILITY
COUNCIL.....WESTERN SYSTEMS
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....SOUTHERN CALIFORNIA EDISON
CORPORATE ADDRESS.....2244 WALNUT GROVE AVENUE
ROSEMEAD, CALIFORNIA 91770
CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....V
IE RESIDENT INSPECTOR.....A. DANGELO
LICENSING PROJ MANAGER.....R. DUDLEY
DOCKET NUMBER.....50-206
LICENSE & DATE ISSUANCE...DPR-13, MARCH 27, 1967
PUBLIC DOCUMENT ROOM.....UNIVERSITY OF CALIFORNIA
GENERAL LIBRARY
IRVINE, CA. 92713

INSPECTION STATUS

INSPECTION SUMMARY

- + INSPECTION ON OCTOBER 1, 1984 - JUNE 18, 1986 (REPORT NO. 50-206/86-10) YEARLY SYSTEMATIC ASSESSMENT OF LICENSEE PERFORMANCE. LETTER ISSUED ON AUGUST 7, 1986.
 - + INSPECTION ON JULY 22-25, 1986 (REPORT NO. 50-206/86-23) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.
 - + INSPECTION ON AUGUST 4-8, 1986 (REPORT NO. 50-206/86-32) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.
 - + INSPECTION ON JUNE 28 - JULY 25, 1986 (REPORT NO. 50-206/86-34) AREAS INSPECTED: ROUTINE, RESIDENT INSPECTION OF OPERATIONS PROGRAM INCLUDING THE FOLLOWING AREAS: OPERATIONAL SAFETY VERIFICATION, EVALUATION OF PLANT TRIPS AND EVENTS, MONTHLY SURVEILLANCE ACTIVITIES, MONTHLY MAINTENANCE ACTIVITIES, PLANT STARTUP FROM REFUELING AND INDEPENDENT INSPECTION. DURING THIS INSPECTION, VARIOUS INSPECTION PROCEDURES WERE UTILIZED.
- RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.
- + INSPECTION ON JULY 28 - AUGUST 15, 1986 (REPORT NO. 50-206/86-35) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

INSPECTION STATUS - (CONTINUED)

[illegible]

FAILURE TO MARK WELD DATUM AND REFERENCE POINTS FOR ISI UT EXAMS.
(8601 4)

SYSTEMS AND COMPONENT PROBLEMS:

4. THE UNIT EXPERIENCED A FAILURE OF PRESSURE TRANSMITTER, PT-459, ON JULY 30, WHICH RESULTED IN ALL THREE STEAM FLOW/FED FLOW MISMATCH TRIP CIRCUITS BECOMING INOPERABLE. BECAUSE OF THIS, AN UNUSUAL EVENT WAS DECLARED AND A TECHNICAL SPECIFICATION-REQUIRED SHUTDOWN WAS COMMENCED FROM 65% POWER. THE CAUSE OF THE FAILURE WAS DETERMINED TO BE A FAILED ELECTRONIC CARD IN THE AMPLIFIER FOR THE TRANSMITTER. THE AMPLIFIER WAS REPLACED, THE LICENSEE SECURED FROM THE UNUSUAL EVENT, AND THE SHUTDOWN WAS TERMINATED AT 31% POWER.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

* THE UNIT, WHICH HAD BEEN IN ITS 8TH REFUELING AND MODIFICATION OUTAGE SINCE NOVEMBER, 1985, ENTERED MODE 3 ON JULY 6, AND RESUMED POWER OPERATION ON JULY 15. THE UNIT EXPERIENCED A TRIP DURING ITS RETURN TO FULL POWER ON JULY 17 WHEN THE OPERATORS PERFORMED A MANUAL TRANSFER OF VITAL BUS 4 POWER FROM THE BACKUP TO THE NORMAL SUPPLY. A VOLTAGE TRANSIENT RESULTED FROM THE BREAK BEFORE MAKE NATURE OF THE TRANSFER SWITCH DESIGN.

LAST IE SITE INSPECTION DATE: 07/28-08/15/86+

INSPECTION REPORT NO: 50-206/86-35+

REPORTS FROM LICENSEE

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
--------	------------------	-------------------	---------

NONE

1. Docket: 50-361 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/86 Outage + On-line Hrs: 744.0

3. Utility Contact: E. R. SIACOR (714) 368-6223

4. Licensed Thermal Power (MWt): 3410

5. Nameplate Rating (Gross MWe): 1127

6. Design Electrical Rating (Net MWe): 1070

7. Maximum Dependable Capacity (Gross MWe): 1127

8. Maximum Dependable Capacity (Net MWe): 1070

9. If Changes Occur Above Since Last Report, Give Reasons:

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,087.0</u>	<u>26,136.0</u>
13. Hours Reactor Critical	<u>655.1</u>	<u>2,928.6</u>	<u>16,049.5</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>646.2</u>	<u>2,741.0</u>	<u>15,590.7</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>2,127,171</u>	<u>8,467,793</u>	<u>50,003,755</u>
18. Gross Elec Ener (MWH)	<u>721,383</u>	<u>2,816,636</u>	<u>16,786,836</u>
19. Net Elec Ener (MWH)	<u>682,756</u>	<u>2,642,145</u>	<u>15,838,784</u>
20. Unit Service Factor	<u>86.9</u>	<u>53.9</u>	<u>59.7</u>
21. Unit Avail Factor	<u>86.9</u>	<u>53.9</u>	<u>59.7</u>
22. Unit Cap Factor (MDC Net)	<u>85.8</u>	<u>48.5</u>	<u>56.6</u>
23. Unit Cap Factor (DER Net)	<u>85.8</u>	<u>48.5</u>	<u>56.6</u>
24. Unit Forced Outage Rate	<u>13.1</u>	<u>6.9</u>	<u>5.6</u>
25. Forced Outage Hours	<u>97.8</u>	<u>203.6</u>	<u>917.5</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):

NONE

27. If Currently Shutdown Estimated Startup Date: N/A

 * SAN ONOFRE 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
 SAN ONOFRE 2



JULY 1986

Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

 * SAN ONOFRE 2 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
27	07/07/86	F	77.5	A	3	86-018	AA	CHU	THE REACTOR TRIPPED FROM 47% POWER ON DEPARTURE FROM NUCLEATE BOILING RATIO/LOCAL POWER DENSITY (DNBR/LPD) AS A RESULT OF MISALIGNMENT PENALTY FACTORS GENERATED BY THE CORE PROTECTION CALCULATORS (CPC) WHEN CONTROL ELEMENT ASSEMBLY (CEA) 49 DROPPED TO ITS FULLY INSERTED POSITION IN ADDITION TO CEA 55 THAT HAD DROPPED PREVIOUSLY.
28	07/14/86	F	20.3	A	3	86-019	JM	RLY	A REACTOR TRIP FROM 100% POWER OCCURRED WHEN THE REACTOR COOLANT SYSTEM (RCS) PRESSURE REACHED THE CORE PROTECTION CALCULATORS (CPC) AUXILIARY TRIP SETPOINT.

 * SUMMARY *

 SAN ONOFRE 2 INCURRED 2 SHUTDOWNS IN JULY AS DISCUSSED ABOVE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

 * SAN ONOFRE 2 *

FACILITY DATA

Report Period JUL 1986

FACILITY DESCRIPTION

UTILITY & CONTRACTOR INFORMATION

LOCATION
 STATE.....CALIFORNIA
 COUNTY.....SAN DIEGO
 DIST AND DIRECTION FROM
 NEAREST POPULATION CTR...5 MI S OF
 SAN CLEMENTE, CA
 TYPE OF REACTOR.....PWR
 DATE INITIAL CRITICALITY...JULY 26, 1982
 DATE ELEC ENER 1ST GENER...SEPTEMBER 20, 1982
 DATE COMMERCIAL OPERATE...AUGUST 8, 1983
 CONDENSER COOLING METHOD...ONCE THRU
 CONDENSER COOLING WATER...PACIFIC OCEAN
 ELECTRIC RELIABILITY
 COUNCIL.....WESTERN SYSTEMS
 COORDINATING COUNCIL

UTILITY
 LICENSEE.....SOUTHERN CALIFORNIA EDISON
 CORPORATE ADDRESS.....P.O. BOX 800
 ROSEMEAD, CALIFORNIA 91770
 CONTRACTOR
 ARCHITECT/ENGINEER.....BECHTEL
 NUC STEAM SYS SUPPLIER...COMBUSTION ENGINEERING
 CONSTRUCTOR.....BECHTEL
 TURBINE SUPPLIER.....GENERAL ELECTRIC COM (ENG VERSION)

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....V
 IE RESIDENT INSPECTOR.....R. HUEY
 LICENSING PROJ MANAGER.....H. ROOD
 DOCKET NUMBER.....50-361
 LICENSE & DATE ISSUANCE...NPF-10, SEPTEMBER 7, 1982
 PUBLIC DOCUMENT ROOM.....UNIVERSITY OF CALIFORNIA
 GENERAL LIBRARY
 IRVINE, CA. 92713

INSPECTION STATUS

INSPECTION SUMMARY

- + INSPECTION ON OCTOBER 1, 1984 - JUNE 18, 1986 (REPORT NO. 50-361/86-09) YEARLY SYSTEMATIC ASSESSMENT OF LICENSEE PERFORMANCE. LETTER ISSUED ON AUGUST 7, 1986.
- + INSPECTION ON MAY 1 - JULY 5, 1986 (REPORT NO. 50-361/86-19) AREAS INSPECTED: ROUTINE, RESIDENT INSPECTION OF OPERATIONS PROGRAM INCLUDING THE FOLLOWING AREAS: OPERATIONAL SAFETY VERIFICATION, EVALUATION OF PLANT TRIPS AND EVENTS, MONTHLY SURVEILLANCE ACTIVITIES, MONTHLY MAINTENANCE ACTIVITIES, REFUELING ACTIVITIES, INDEPENDENT INSPECTION, LICENSEE EVENTS REPORT REVIEW, AND FOLLOWUP OF PREVIOUSLY IDENTIFIED ITEMS. DURING THIS INSPECTION, VARIOUS INSPECTION PROCEDURES WERE UTILIZED.
- RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.
- + INSPECTION ON AUGUST 4-8, 1986 (REPORT NO. 50-361/86-22) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.
- + ENFORCEMENT CONFERENCE ON JULY 26, 1986 (REPORT NO. 50-361/86-23) 1. DESCRIPTION OF THE VIOLATIONS ASSOCIATED WITH THE APRIL 21 - JUNE 2, 1986, INSPECTION AND DOCUMENTED IN INSPECTION REPORT NO. 50-200/86-17, 50-361/86-12, 50-362/86-12 (IE-V-748), DATED JUNE 12, 1986; 2. NRC CONCERNS; 3. LICENSEE CORRECTIVE ACTIONS PLANNED AND IMPLEMENTED.
- + INSPECTION ON JUNE 28 - AUGUST 15, 1986 (REPORT NO. 50-361/86-24) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.
- + INSPECTION ON SEPTEMBER 15-26, 1986 (REPORT NO. 50-361/86-25) INSPECTION TO BE COMPLETED IN SEPTEMBER, 1986.

Report Period JUL 1986

I N S P E C T I O N S T A T U S - (CONTINUED)

* SAN ONOFRE 2 *

INSPECTION SUMMARY

+ INSPECTION ON JULY 28 - AUGUST 15, 1986 (REPORT NO. 50-361/86-26) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

+ THE UNIT EXPERIENCED SEVERAL CONTROL ELEMENT ASSEMBLY (CEA) DROPS DURING JULY. THE FIRST CEA DROP OCCURRED ON JULY 25, AND POWER WAS REDUCED FROM 98% TO 87%. THE SECOND CEA DROP OCCURRED ON JULY 29, AND POWER WAS REDUCED FROM 100% TO 82%. NORMAL CEA RECOVERIES WERE PERFORMED IN BOTH CASES.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

+ THE UNIT CONTINUED FULL POWER OPERATIONS IN JULY. A REACTOR TRIP OCCURRED ON JULY 14 FROM A CONTAINMENT ISOLATION ACTUATION SYSTEM SIGNAL DUE TO A FAILED RELAY. THE RELAY WAS REPLACED AND NORMAL POWER OPERATIONS WERE CONTINUED.

LAST IE SITE INSPECTION DATE: 09/15-26/86+

INSPECTION REPORT NO: 50-361/86-25+

R E P O R T S F R O M L I C E N S E E

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
86-11-L0	06-07-86	06-27-86	SPURIOUS CPIS
86-12-L0	06-03-86	06-27-86	PPS ACTUATION ON LOW REACTOR COOLANT SYSTEM FLOW
86-13-L0	06-10-86	07-08-86	REACTOR TRIP ON HIGH STEAM GENERATOR LEVEL
86-14-L0	06-13-86	06-30-86	125 VDC BATTERY SURVEILLANCE

1. Docket: 50-362 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/86 Outage + On-line Hrs: 744.0

3. Utility Contact: E. R. SIACOR (714) 368-6223

4. Licensed Thermal Power (MWt): 3390

5. Nameplate Rating (Gross MWe): 1127

6. Design Electrical Rating (Net MWe): 1080

7. Maximum Dependable Capacity (Gross MWe): 1127

8. Maximum Dependable Capacity (Net MWe): 1080

9. If Changes Occur Above Since Last Report, Give Reasons: NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,087.0</u>	<u>20,447.0</u>
13. Hours Reactor Critical	<u>726.6</u>	<u>4,280.9</u>	<u>13,466.0</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>714.7</u>	<u>3,959.8</u>	<u>12,775.1</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>2,129,940</u>	<u>12,518,254</u>	<u>37,517,818</u>
18. Gross Elec Ener (MWH)	<u>751,978</u>	<u>4,247,764</u>	<u>12,619,166</u>
19. Net Elec Ener (MWH)	<u>712,797</u>	<u>3,996,075</u>	<u>11,803,422</u>
20. Unit Service Factor	<u>96.1</u>	<u>77.8</u>	<u>62.5</u>
21. Unit Avail Factor	<u>96.1</u>	<u>77.8</u>	<u>62.5</u>
22. Unit Cap Factor (MDC Net)	<u>88.7</u>	<u>72.7</u>	<u>53.5</u>
23. Unit Cap Factor (DER Net)	<u>88.7</u>	<u>72.7</u>	<u>53.5</u>
24. Unit Forced Outage Rate	<u>3.9</u>	<u>16.8</u>	<u>15.0</u>
25. Forced Outage Hours	<u>29.3</u>	<u>801.5</u>	<u>2,250.4</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
CYCLE 3 REFUELING OUTAGE: NOVEMBER 28, 1986.

27. If Currently Shutdown Estimated Startup Date: N/A

 * SAN ONOFRE 3 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
 SAN ONOFRE 3



JULY 1986

Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

 * SAN ONOFRE 3 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
28	07/29/86	F	29.3	A	2	86-010	SJ	P	THE REACTOR WAS MANUALLY TRIPPED DUE TO LOSS OF MAIN FEEDWATER. INVESTIGATION INTO THE CAUSE IS CONTINUING. THE RESULTS OF THE INVESTIGATION AND APPROPRIATE CORRECTIVE ACTIONS TO BE TAKEN WILL BE ADDRESSED IN LER 86-010.
29	07/29/86	S	0.0	A	5		SJ	SHV	POWER REDUCTION TO REMOVE MAIN FEEDWATER BLOCK VALVE 3HV-4051 FROM SERVICE FOR N2 LEAK REPAIR OF HYDRAULIC DUMP VALVE.

 * SUMMARY *

 SAN ONOFRE 3 HAD 1 OUTAGE AND 1 POWER REDUCTION IN JULY AS DISCUSSED ABOVE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* SAN ONOFRE 3 *

FACILITY DATA

Report Period JUL 1986

FACILITY DESCRIPTION

LOCATION
STATE.....CALIFORNIA
COUNTY.....SAN DIEGO
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...5 MI S OF
SAN CLEMENTE, CA
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...AUGUST 29, 1983
DATE ELEC ENER 1ST GENER...SEPTEMBER 25, 1983
DATE COMMERCIAL OPERATE...APRIL 1, 1984
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...PACIFIC OCEAN
ELECTRIC RELIABILITY
COUNCIL.....WESTERN SYSTEMS
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....SOUTHERN CALIFORNIA EDISON
CORPORATE ADDRESS.....P.O. BOX 800
ROSEMEAD, CALIFORNIA 91770
CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...COMBUSTION ENGINEERING
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....GENERAL ELECTRIC COM (ENG VERSION)

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....V
IE RESIDENT INSPECTOR.....R. HUEY
LICENSING PROJ MANAGER.....H. ROOD
DOCKET NUMBER.....50-362
LICENSE & DATE ISSUANCE...NPF-15, NOVEMBER 15, 1982
PUBLIC DOCUMENT ROOM.....UNIVERSITY OF CALIFORNIA
GENERAL LIBRARY
IRVINE, CA. 92713

INSPECTION SUMMARY

I N S P E C T I O N S T A T U S

+ INSPECTION ON OCTOBER 1, 1984 - JUNE 18, 1986 (REPORT NO. 50-362/86-09) YEARLY SYSTEMATIC ASSESSMENT OF LICENSEE PERFORMANCE. LETTER ISSUED ON AUGUST 7, 1986.

+ INSPECTION ON MAY 1 - JULY 5, 1986 (REPORT NO. 50-362/86-19) AREAS INSPECTED: ROUTINE, RESIDENT INSPECTION OF OPERATIONS PROGRAM INCLUDING THE FOLLOWING AREAS: OPERATIONAL SAFETY VERIFICATION, EVALUATION OF PLANT TRIPS AND EVENTS, MONTHLY SURVEILLANCE ACTIVITIES, MONTHLY MAINTENANCE ACTIVITIES, REFUELING ACTIVITIES, INDEPENDENT INSPECTION, LICENSEE EVENTS REPORT REVIEW, AND FOLLOWUP OF PREVIOUSLY IDENTIFIED ITEMS. DURING THIS INSPECTION, VARIOUS INSPECTION PROCEDURES WERE UTILIZED.

RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

+ INSPECTION ON JUNE 16-27, 1986 (REPORT NO. 50-362/86-21) REPORT CANCELLED.

+ INSPECTION ON AUGUST 4-8, 1986 (REPORT NO. 50-362/86-22) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

+ INSPECTION ON JUNE 28 - AUGUST 15, 1986 (REPORT NO. 50-362/86-23) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

+ INSPECTION ON JULY 28 - AUGUST 15, 1986 (REPORT NO. 50-362/86-24) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

Report Period JUL 1986

I N S P E C T I O N S T A T U S - (CONTINUED)

* SAN ONOFRE 3 *

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

+ THE UNIT WAS OPERATED AT VARIOUS POWER LEVELS TO FACILITATE CLEANING OF CONDENSER WATER BOXES. IN ADDITION, A POWER REDUCTION TO 18% OCCURRED ON JULY 28, IN ORDER TO PERFORM MAIN FEEDWATER BLOCK VALVE REPAIRS.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

+ THE UNIT CONTINUED FULL POWER OPERATIONS IN JULY. ONE MANUAL REACTOR TRIP WAS INITIATED ON JULY 26, AS A RESULT OF A CONDENSATE TRIP WHICH RESULTED IN A LOSS OF MAIN FEED PUMP DUE TO LOW SUCTION PRESSURE.

LAST IE SITE INSPECTION DATE: 07/28-08/15/86+

INSPECTION REPORT NO: 50-362/86-24+

R E P O R T S F R O M L I C E N S E E

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT

NONE			
=====			

1. Docket: 50-327 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/86 Outage + On-line Hrs: 1488.0

3. Utility Contact: DAVID DUPREE (615) 870-6544

4. Licensed Thermal Power (MWt): 3411

5. Nameplate Rating (Gross MWe): 1220

6. Design Electrical Rating (Net MWe): 1148

7. Maximum Dependable Capacity (Gross MWe): 1183

8. Maximum Dependable Capacity (Net MWe): 1148

9. If Changes Occur Above Since Last Report, Give Reasons:

NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,087.0</u>	<u>44,568.0</u>
13. Hours Reactor Critical	<u>.0</u>	<u>.0</u>	<u>24,444.7</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>.0</u>	<u>.0</u>	<u>23,871.0</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>0</u>	<u>0</u>	<u>77,060,921</u>
18. Gross Elec Ener (MWH)	<u>0</u>	<u>0</u>	<u>25,978,386</u>
19. Net Elec Ener (MWH)	<u>-3,653</u>	<u>-24,034</u>	<u>24,918,703</u>
20. Unit Service Factor	<u>.0</u>	<u>.0</u>	<u>53.6</u>
21. Unit Avail Factor	<u>.0</u>	<u>.0</u>	<u>53.6</u>
22. Unit Cap Factor (MDC Net)	<u>.0</u>	<u>.0</u>	<u>48.7</u>
23. Unit Cap Factor (DER Net)	<u>.0</u>	<u>.0</u>	<u>48.7</u>
24. Unit Forced Outage Rate	<u>100.0</u>	<u>100.0</u>	<u>32.4</u>
25. Forced Outage Hours	<u>488.0</u>	<u>5,831.0</u>	<u>11,458.1</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):

NONE

27. If Currently Shutdown Estimated Startup Date: 12/25/86

* SEQUOYAH 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT SEQUOYAH 1



JULY 1986

Report Period JUL 1986

U N I T S H U T D O W N S / R E D U C T I O N S

 * SEQUOYAH 1 *

<u>No.</u>	<u>Date</u>	<u>Type</u>	<u>Hours</u>	<u>Reason</u>	<u>Method</u>	<u>LER Number</u>	<u>System</u>	<u>Component</u>	<u>Cause & Corrective Action to Prevent Recurrence</u>
7	12/20/85	F	744.0	F	4				DESIGN CONTROL, CONFIGURATION UPDATING, AND EMPLOYEE CONCERNS.

 * SUMMARY *

SEQUOYAH 1 REMAINS IN AN EXTENDED ADMINISTRATIVE SHUTDOWN.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	Instructions for
	C-Refueling	H-Other	Preparation of
	D-Regulatory Restriction		Data Entry Sheet
	E-Operator Training		Licensee Event Report
	& License Examination		(LER) File (NUREG-0161)
		1-Manual	
		2-Manual Scram	
		3-Auto Scram	
		4-Continued	
		5-Reduced Load	
		9-Other	

* SEQUOYAH 1 *

FACILITY DATA

Report Period JUL 1986

FACILITY DESCRIPTION

LOCATION
STATE.....TENNESSEE
COUNTY.....HAMILTON
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...9.5 MI NE OF
CHATTANOOGA, TN
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...JULY 5, 1980
DATE ELEC ENER 1ST GENER...JULY 22, 1980
DATE COMMERCIAL OPERATE...JULY 1, 1981
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...CHICKAMAUGA LAKE
ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....TENNESSEE VALLEY AUTHORITY
CORPORATE ADDRESS.....6 NORTH 38A LOOKOUT PLACE
CHATTANOOGA, TENNESSEE 37401
CONTRACTOR
ARCHITECT/ENGINEER.....TENNESSEE VALLEY AUTHORITY
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....TENNESSEE VALLEY AUTHORITY
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
IE RESIDENT INSPECTOR.....E. FORD
LICENSING PROJ MANAGER.....C. STAHL
DOCKET NUMBER.....50-327
LICENSE & DATE ISSUANCE...DPR-77, SEPTEMBER 17, 1980
PUBLIC DOCUMENT ROOM.....CHATTANOOGA - HAMILTON BICENTENNIAL LIBRARY
1001 BROAD STREET
CHATTANOOGA, TENNESSEE 37402

INSPECTION SUMMARY

INSPECTION STATUS

+ INSPECTION JUNE 16-20 (86-36): THIS WAS A SPECIAL, ANNOUNCED INSPECTION IN THE AREAS OF PREVIOUS ENFORCEMENT MATTERS; HEALTH PHYSICS RESTART ISSUES; FOLLOW-UP ON ALLEGATIONS; ORGANIZATION AND MANAGEMENT CONTROLS; EXTERNAL EXPOSURE CONTROL; INTERNAL EXPOSURE CONTROL; CONTROL OF RADIOACTIVE MATERIAL; FACILITIES AND EQUIPMENT; LICENSEE'S PROGRAM FOR MAINTAINING OCCUPATIONAL RADIATION EXPOSURES AS LOW AS REASONABLY ACHIEVABLE (ALARA); SOLID WASTES; TRANSPORTATION; FOLLOW-UP ON PREVIOUS INSPECTOR IDENTIFIED ITEMS; AND IE INFORMATION NOTICES. ONE VIOLATION WAS IDENTIFIED FOR FAILURE TO PERFORM RADIATION SURVEYS ON THE TOP SURFACES OF EXCLUSIVE USE CLOSED TRANSPORT VEHICLES.

ENFORCEMENT SUMMARY

CONTRARY TO TS 6.8.1.C, A WRITTEN PROCEDURE WAS NOT ESTABLISHED FOR SURVEILLANCE REQUIREMENT OF TS 4.3.1.1.1, TABLE 4.3-1, ITEM 19, NOTE (4), WHICH REQUIRES A MANUAL ENGINEERED SAFETY FEATURE (ESF) FUNCTIONAL INPUT CHECK OF THE REACTOR TRIP SYSTEM EVERY 18 MONTHS. THIS INVOLVED ONE MISSED RELAY ON EACH OF TWO MULTICONTACT SWITCHES. AS SUCH, A FUNCTIONAL CHECK OF THESE RELAYS WAS NOT CONDUCTED. CONTRARY TO TS 4.6.1.1.A, IN UNIT 1, 20 VENT, DRAIN AND TEST CONTAINMENT ISOLATION VALVES WERE NOT VERIFIED TO BE IN THE PROPER POSITION WHEN SI-14, VERIFICATION OF CONTAINMENT INTEGRITY - UNIT 1, WAS PERFORMED ON MAY 20, 1985 PRIOR TO HEAT UP TO MODE 4 AND WHILE IN MODE 4 ON MAY 17, 1985; JUNE 3, 6, 19 AND 27, 1985; AND JULY 25, 1985. THIS INVOLVED CONTAINMENT ISOLATION VALVES 62-707, 70-735, 70-737, 70-678B, 70-691B, 70-702B, C, E AND F, 70-703, 70-760, 70-762, 70-763, 72-546, 72-554, 70-543, 72-545, 78-226A, 78-228A AND 87-523.

INSPECTION STATUS - (CONTINUED)

* SEQUOYAH 1 *

(8602 4)

(8602 4)
CONTRARY TO TECHNICAL SPECIFICATION 6.5.1.2, THE SEQUOYAH PROCEDURE IMPLEMENTING THE ABOVE REQUIREMENTS, SQA21, PROVIDED FOR A PORC COMPOSITION OF THE CHAIRMAN AND EIGHT MEMBERS. THE TWO "EXTRA MEMBERS", BEYOND THE TS REQUIRED COMPOSITION, COULD LEGALLY FUNCTION AS ALTERNATES, BUT WERE RECOGNIZED BY THE LICENSEE AS MEMBERS. THE TWO "EXTRA MEMBERS" RESULTED IN THE QUORUM REQUIREMENTS BEING VIOLATED WITH RESPECT TO PORC MEMBERS PRESENT DURING MEETINGS 3351, 3364, 3367, 3378, 3381, 3389 IN MAY, 1985). THE PERSONS SERVING AS THE "EXTRA MEMBERS" DO MEET ANSI N18.1 QUALIFICATIONS.
(8602 5)

(8602 5)
CONTRARY TO 10 CFR 71.5(A), 49 CFR 173.475(I) AND 49 CFR 173.441(B)(2), ON MAY 2 AND JUNE 5, 1986, THE LICENSEE FAILED TO COMPLY WITH DOT REQUIREMENTS FOR RADIOACTIVE MATERIAL SHIPMENTS SNP-428 AND SNP-430, TRANSFERRED TO THE CHEM-NUCLEAR SYSTEMS, INC. LOW LEVEL WASTE DISPOSAL SITE NEAR BARNWELL, S.C. IN THAT, PRIOR TO THE SHIPMENT, NO RADIATION LEVEL MEASUREMENTS WERE PERFORMED ON THE TOP SURFACES OF THE EXCLUSIVE USE CLOSED TRANSPORT VEHICLES.
(8603 4)

SYSTEMS AND COMPONENT PROBLEMS:

ENVIRONMENTAL QUALIFICATION OF EQUIPMENT.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

MODE 5.

LAST IE SITE INSPECTION DATE: JUNE 16-20, 1986 +

INSPECTION REPORT NO: 50-327/86-36 +

Report Period JUL 1986

REPORTS FROM LICENSEE

* SEQUOYAH 1 *

```
=====
NUMBER    DATE OF    DATE OF    SUBJECT
          EVENT     REPORT
-----
86-012    04/15/86    05/14/86    FAILURE TO PROPERLY STROKE TIME CONTAINMENT ISOLATION VALVES.
86-017    04/19/86    05/19/86    FAILURE TO TEST RADIATION MONITORS DURING CORE ALTERATIONS; CAUSE - INADEQUATE PROCEDURE.
86-018    04/21/86    05/20/86    FAILURE TO VERIFY INDICATED POWER AVAILABILITY DUE TO INADEQUATE PROCEDURE.
86-022    05/15/86    06/13/86    INADVERTENT CONTAINMENT VENTILATION ISOLATION CAUSED BY RADIATION MONITOR SPIKES.
86-023    05/08/86    06/06/86    CHANNEL CALIBRATION OF FLOW INDICATOR NOT PERFORMED AS REQUIRED.
86-024    05/25/86    06/20/86    SECURITY COMPUTER MALFUNCTION CAUSES MISSED FIRE WATCH; CAUSE - LACK OF A PM PROGRAM ON THE
          BACKUP BATTERY FOR THE MAC-540 MEMORY.
=====
```

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-328 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/86 Outage + On-line Hrs: 744.0

3. Utility Contact: DAVID DUPREE (615) 870-6544

4. Licensed Thermal Power (MWt): 3411

5. Nameplate Rating (Gross MWe): 1220

6. Design Electrical Rating (Net MWe): 1148

7. Maximum Dependable Capacity (Gross MWe): 1183

8. Maximum Dependable Capacity (Net MWe): 1148

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,087.0</u>	<u>36,528.0</u>
13. Hours Reactor Critical	<u>.0</u>	<u>.0</u>	<u>21,984.5</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>.0</u>	<u>.0</u>	<u>21,494.4</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>0</u>	<u>0</u>	<u>69,127,974</u>
18. Gross Elec Ener (MWH)	<u>0</u>	<u>0</u>	<u>23,536,780</u>
19. Net Elec Ener (MWH)	<u>-5,769</u>	<u>-34,539</u>	<u>22,597,419</u>
20. Unit Service Factor	<u>.0</u>	<u>.0</u>	<u>58.8</u>
21. Unit Avail Factor	<u>.0</u>	<u>.0</u>	<u>58.8</u>
22. Unit Cap Factor (MDC Net)	<u>.0</u>	<u>.0</u>	<u>53.9</u>
23. Unit Cap Factor (DER Net)	<u>.0</u>	<u>.0</u>	<u>53.9</u>
24. Unit Forced Outage Rate	<u>100.0</u>	<u>100.0</u>	<u>32.2</u>
25. Forced Outage Hours	<u>744.0</u>	<u>5,087.0</u>	<u>10,210.3</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: 01/15/87

* SEQUOYAH 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

SEQUOYAH 2



JULY 1986

Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

 * SEQUOYAH 2 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
7	08/21/85	F	744.0	F	4				DESIGN CONTROL, CONFIGURATION UPDATING, AND EMPLOYEE CONCERNS.

 * SUMMARY *

 SEQUOYAH 2 REMAINS IN AN EXTENDED ADMINISTRATIVE SHUTDOWN.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* SEQUOYAH 2 *

FACILITY DATA

Report Period JUL 1986

FACILITY DESCRIPTION

LOCATION
STATE.....TENNESSEE
COUNTY.....HAMILTON
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...9.5 MI NE OF
CHATTANOOGA, TN
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...NOVEMBER 5, 1981
DATE ELEC ENER 1ST GENER...DECEMBER 23, 1981
DATE COMMERCIAL OPERATE...JUNE 1, 1982
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...CHICKAMAUGA LAKE
ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....TENNESSEE VALLEY AUTHORITY
CORPORATE ADDRESS.....6 NORTH 38A LOOKOUT PLACE
CHATTANOOGA, TENNESSEE 37401
CONTRACTOR
ARCHITECT/ENGINEER.....TENNESSEE VALLEY AUTHORITY
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....TENNESSEE VALLEY AUTHORITY
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
IE RESIDENT INSPECTOR.....E. FORD
LICENSING PROJ MANAGER.....C. STAHL
DOCKET NUMBER.....50-328
LICENSE & DATE ISSUANCE....DPR-79, SEPTEMBER 15, 1981
PUBLIC DOCUMENT ROOM.....CHATTANOOGA - HAMILTON BICENTENNIAL LIBRARY
1001 BROAD STREET
CHATTANOOGA, TENNESSEE 37402

INSPECTION STATUS

INSPECTION SUMMARY

+ INSPECTION JUNE 16-20 (86-36): THIS WAS A SPECIAL, ANNOUNCED INSPECTION IN THE AREAS OF PREVIOUS ENFORCEMENT MATTERS; HEALTH PHYSICS RESTART ISSUES; FOLLOW-UP ON ALLEGATIONS; ORGANIZATION AND MANAGEMENT CONTROLS; EXTERNAL EXPOSURE CONTROL; INTERNAL EXPOSURE CONTROL; CONTROL OF RADIOACTIVE MATERIAL; FACILITIES AND EQUIPMENT; LICENSEE'S PROGRAM FOR MAINTAINING OCCUPATIONAL RADIATION EXPOSURES AS LOW AS REASONABLY ACHIEVABLE (ALARA); SOLID WASTES; TRANSPORTATION; FOLLOW-UP ON PREVIOUS INSPECTOR IDENTIFIED ITEMS; AND IE INFORMATION NOTICES. ONE VIOLATION WAS IDENTIFIED FOR FAILURE TO PERFORM RADIATION SURVEYS ON THE TOP SURFACES OF EXCLUSIVE USE CLOSED TRANSPORT VEHICLES.

ENFORCEMENT SUMMARY

CONTRARY TO TS 6.8.1.C, A WRITTEN PROCEDURE WAS NOT ESTABLISHED FOR SURVEILLANCE REQUIREMENT OF TS 4.3.1.1.1, TABLE 4.3-1, ITEM 19, NOTE (4), WHICH REQUIRES A MANUAL ENGINEERED SAFETY FEATURE (ESF) FUNCTIONAL INPUT CHECK OF THE REACTOR TRIP SYSTEM EVERY 18 MONTHS. THIS INVOLVED ONE MISSED RELAY ON EACH OF TWO MULTICONTACT SWITCHES. AS SUCH, A FUNCTIONAL CHECK OF THESE RELAYS WAS NOT CONDUCTED.
(8602 4)

CONTRARY TO TECHNICAL SPECIFICATION 6.5.1.2, THE SEQUOYAH PROCEDURE IMPLEMENTING THE ABOVE REQUIREMENTS, SQA21, PROVIDED FOR A PORC COMPOSITION OF THE CHAIRMAN AND EIGHT MEMBERS. THE TWO "EXTRA MEMBERS", BEYOND THE TS REQUIRED COMPOSITION, COULD LEGALLY

INSPECTION STATUS - (CONTINUED)

* SEQUOYAH 2 *

ENFORCEMENT SUMMARY

FUNCTION AS ALTERNATES, BUT WERE RECOGNIZED BY THE LICENSEE AS MEMBERS. THE TWO "EXTRA MEMBERS" RESULTED IN THE QUORUM REQUIREMENTS BEING VIOLATED WITH RESPECT TO PORC MEMBERS PRESENT DURING MEETINGS 3351, 3364, 3367, 3378, 3381, 3389 IN MAY, 1985). THE PERSONS SERVING AS THE "EXTRA MEMBERS" DO MEET ANSI N18.1 QUALIFICATIONS.

(8602 5)

OTHER ITEMS

INSPECTION REPORT NO: 50-328/86-36 +

Report Period JUL 1986

R E P O R T S F R O M L I C E N S E E

* SEQUOYAH 2 *

```
=====
NUMBER    DATE OF    DATE OF    SUBJECT
          EVENT     REPORT
-----
86-001    04/26/86    06/24/86    FAILURE TO PERFORM A COMPLETE BORATION FLOW PATH VERIFICATION - MODE 5.  ROOT CAUSE - AN
          05/13/86    06/11/86    INCORRECT STATEMENT IN THE SAFETY INJECTION (SI).
86-002    05/13/86    06/11/86    CONTAINMENT VENTILATION ISOLATION DUE TO SPIKE ON RADIATION MONITOR; CAUSED BY A COGNITIVE
          05/30/86    06/27/86    PERSONNEL ERROR.
86-003    05/30/86    06/27/86    CONTAINMENT VENTILATION ISOLATIONS CAUSED BY SPIKES ON RADIATION MONITORS.
=====
```

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-335 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/86 Outage + On-line Hrs: 744.0

3. Utility Contact: N. W. GRANT (305) 552-3675

4. Licensed Thermal Power (MWt): 2700

5. Nameplate Rating (Gross MWe): 1000 X 0.89 = 890

6. Design Electrical Rating (Net MWe): 830

7. Maximum Dependable Capacity (Gross MWe): 867

8. Maximum Dependable Capacity (Net MWe): 827

9. If Changes Occur Above Since Last Report, Give Reasons: NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,087.0</u>	<u>84,239.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>4,767.3</u>	<u>61,923.5</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>205.3</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>4,735.8</u>	<u>60,538.6</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>39.3</u>
17. Gross Therm Ener (MWH)	<u>2,008,970</u>	<u>12,704,116</u>	<u>153,594,351</u>
18. Gross Elec Ener (MWH)	<u>669,460</u>	<u>4,254,470</u>	<u>50,310,975</u>
19. Net Elec Ener (MWH)	<u>636,363</u>	<u>4,040,687</u>	<u>47,464,901</u>
20. Unit Service Factor	<u>100.0</u>	<u>93.1</u>	<u>71.9</u>
21. Unit Avail Factor	<u>100.0</u>	<u>93.1</u>	<u>71.9</u>
22. Unit Cap Factor (MDC Net)	<u>103.4</u>	<u>96.0</u>	<u>68.1</u>
23. Unit Cap Factor (DER Net)	<u>103.1</u>	<u>95.7</u>	<u>67.9</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.4</u>	<u>4.1</u>
25. Forced Outage Hours	<u>.0</u>	<u>20.6</u>	<u>2,575.4</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):

NONE

27. If Currently Shutdown Estimated Startup Date: N/A

 * ST LUCIE 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
 ST LUCIE 1



JULY 1986

Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

* ST LUCIE 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
-----	------	------	-------	--------	--------	------------	--------	-----------	---

NONE

* SUMMARY *

ST. LUCIE 1 OPERATED ROUTINELY IN JULY WITH NO SHUTDOWNS OR POWER REDUCTIONS REPORTED.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* ST LUCIE 1 *

FACILITY DATA

Report Period JUL 1986

FACILITY DESCRIPTION

LOCATION
STATE.....FLORIDA
COUNTY.....ST LUCIE
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...12 MI SE OF
FT. PIERCE, FLA
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...APRIL 22, 1976
DATE ELEC ENER 1ST GENER...MAY 7, 1976
DATE COMMERCIAL OPERATE...DECEMBER 21, 1976
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...ATLANTIC OCEAN
ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....FLORIDA POWER & LIGHT
CORPORATE ADDRESS.....9250 WEST FLAGLER STREET P.O. BOX 529100
MIAMI, FLORIDA 33152
CONTRACTOR
ARCHITECT/ENGINEER.....EBASCO
NUC STEAM SYS SUPPLIER...COMBUSTION ENGINEERING
CONSTRUCTOR.....EBASCO
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
IE RESIDENT INSPECTOR.....R. CRLENJAK
LICENSING PROJ MANAGER.....E. TOURNIGNY
DOCKET NUMBER.....50-335
LICENSE & DATE ISSUANCE...DPR-67, MARCH 1, 1976
PUBLIC DOCUMENT ROOM.....INDIAN RIVER COMMUNITY COLLEGE LIBRARY
3209 VIRGINIA AVENUE
FT. PIERCE, FLORIDA 33450

INSPECTION STATUS

INSPECTION SUMMARY

+ THERE WERE NO INSPECTIONS CONDUCTED AT ST. LUCIE UNIT 1 FOR THE MONTH OF JULY.

ENFORCEMENT SUMMARY

CONTRARY TO 10 CFR 71.5 AND 49 CFR 173.441(A), ON DECEMBER 13, 1985, THE LICENSEE SHIPPED TWO BOXES OF RADIOACTIVE MATERIALS, BOX NO. 85-105 AND BOX NO. 85-112, TO A LAND DISPOSAL FACILITY AT BARNWELL, S.C. WITH DOSE RATES OF 250 AND 400 MILLIREM PER HOUR, RESPECTIVELY, ON THE EXTERNAL SURFACES OF THE PACKAGES. THE EXCEPTIONS OF 49 CFR 173.441(B) DID NOT APPLY BECAUSE THE SHIPMENT WAS NOT MADE IN AN ENCLOSED VEHICLE.
(8600 3)

CONTRARY TO 10 CFR 71.5 AND 49 CFR 173.425(B)(1), THE LICENSEE FAILED TO PACKAGE A SHIPMENT OF LSA RADIOACTIVE MATERIAL IN A DOT SPECIFICATION 7A TYPE A PACKAGE OR A STRONG, TIGHT PACKAGE IN THAT ON OCTOBER 22, 1985, SHIPMENT NO. 85-49 ARRIVED AT THE BURIAL FACILITY WITH A HOLE IN ONE B-25 METAL BOX.

CONTRARY TO 10 CFR 20.103(C)(2), ON APRIL 18, 1986, THE NRC INSPECTOR NOTED THE LICENSEE WAS MAKING ALLOWANCE IN ITS MAXIMUM PERMISSIBLE CONCENTRATION HOUR ASSIGNMENT RECORDS FOR USE OF RESPIRATORY PROTECTIVE EQUIPMENT IN ESTIMATING EXPOSURES OF INDIVIDUALS TO RADIOACTIVE MATERIAL IN AIR FOR PURPOSES OF DETERMINING COMPLIANCE WITH 10 CFR 20.103. HOWEVER, THE LICENSEE DID

INSPECTION STATUS - (CONTINUED)

```

XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX
*                ST LUCIE 1                *
XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX

```

NOT HAVE WRITTEN PROCEDURES REGARDING MAINTENANCE OF RECORDS SHOWING THAT AN INDIVIDUAL HAD BEEN ISSUED A RESPIRATOR. CONTRARY TO THE REQUIREMENTS OF 10 CFR 73.71(C) CERTAIN SECURITY EVENTS WERE NOT REPORTED AS REQUIRED.

CONTRARY TO THE REQUIREMENTS OF THE SECURITY PLAN CERTAIN VITAL AREA BARRIERS DID NOT MEET THE CRITERIA OF 10 CFR 73.2(F).
CONTRARY TO COMMITMENTS IN THE APPROVED SECURITY PLAN PROPER ISSUANCE AND CONTROL OF CARD KEYS WAS NOT MAINTAINED IN ALL CASES.
(8600 4)

SYSTEMS AND COMPONENT PROBLEMS:

NONE.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

NORMAL OPERATIONS.

LAST IE SITE INSPECTION DATE: MAY 13 - JUNE 16, 1986

INSPECTION REPORT NO: 50-335/86-16

REPORTS FROM LICENSEE

1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	93	94	95	96	97	98	99	100	101	102	103	104	105	106	107	108	109	110	111	112	113	114	115	116	117	118	119	120	121	122	123	124	125	126	127	128	129	130	131	132	133	134	135	136	137	138	139	140	141	142	143	144	145	146	147	148	149	150	151	152	153	154	155	156	157	158	159	160	161	162	163	164	165	166	167	168	169	170	171	172	173	174	175	176	177	178	179	180	181	182	183	184	185	186	187	188	189	190	191	192	193	194	195	196	197	198	199	200	201	202	203	204	205	206	207	208	209	210	211	212	213	214	215	216	217	218	219	220	221	222	223	224	225	226	227	228	229	230	231	232	233	234	235	236	237	238	239	240	241	242	243	244	245	246	247	248	249	250	251	252	253	254	255	256	257	258	259	260	261	262	263	264	265	266	267	268	269	270	271	272	273	274	275	276	277	278	279	280	281	282	283	284	285	286	287	288	289	290	291	292	293	294	295	296	297	298	299	300	301	302	303	304	305	306	307	308	309	310	311	312	313	314	315	316	317	318	319	320	321	322	323	324	325	326	327	328	329	330	331	332	333	334	335	336	337	338	339	340	341	342	343	344	345	346	347	348	349	350	351	352	353	354	355	356	357	358	359	360	361	362	363	364	365	366	367	368	369	370	371	372	373	374	375	376	377	378	379	380	381	382	383	384	385	386	387	388	389	390	391	392	393	394	395	396	397	398	399	400	401	402	403	404	405	406	407	408	409	410	411	412	413	414	415	416	417	418	419	420	421	422	423	424	425	426	427	428	429	430	431	432	433	434	435	436	437	438	439	440	441	442	443	444	445	446	447	448	449	450	451	452	453	454	455	456	457	458	459	460	461	462	463	464	465	466	467	468	469	470	471	472	473	474	475	476	477	478	479	480	481	482	483	484	485	486	487	488	489	490	491	492	493	494	495	496	497	498	499	500	501	502	503	504	505	506	507	508	509	510	511	512	513	514	515	516	517	518	519	520	521	522	523	524	5
---	---	---	---	---	---	---	---	---	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	---

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
--------	------------------	-------------------	---------

NONE.

1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	93	94	95	96	97	98	99	100	101	102	103	104	105	106	107	108	109	110	111	112	113	114	115	116	117	118	119	120	121	122	123	124	125	126	127	128	129	130	131	132	133	134	135	136	137	138	139	140	141	142	143	144	145	146	147	148	149	150	151	152	153	154	155	156	157	158	159	160	161	162	163	164	165	166	167	168	169	170	171	172	173	174	175	176	177	178	179	180	181	182	183	184	185	186	187	188	189	190	191	192	193	194	195	196	197	198	199	200	201	202	203	204	205	206	207	208	209	210	211	212	213	214	215	216	217	218	219	220	221	222	223	224	225	226	227	228	229	230	231	232	233	234	235	236	237	238	239	240	241	242	243	244	245	246	247	248	249	250	251	252	253	254	255	256	257	258	259	260	261	262	263	264	265	266	267	268	269	270	271	272	273	274	275	276	277	278	279	280	281	282	283	284	285	286	287	288	289	290	291	292	293	294	295	296	297	298	299	300	301	302	303	304	305	306	307	308	309	310	311	312	313	314	315	316	317	318	319	320	321	322	323	324	325	326	327	328	329	330	331	332	333	334	335	336	337	338	339	340	341	342	343	344	345	346	347	348	349	350	351	352	353	354	355	356	357	358	359	360	361	362	363	364	365	366	367	368	369	370	371	372	373	374	375	376	377	378	379	380	381	382	383	384	385	386	387	388	389	390	391	392	393	394	395	396	397	398	399	400	401	402	403	404	405	406	407	408	409	410	411	412	413	414	415	416	417	418	419	420	421	422	423	424	425	426	427	428	429	430	431	432	433	434	435	436	437	438	439	440	441	442	443	444	445	446	447	448	449	450	451	452	453	454	455	456	457	458	459	460	461	462	463	464	465	466	467	468	469	470	471	472	473	474	475	476	477	478	479	480	481	482	483	484	485	486	487	488	489	490	491	492	493	494	495	496	497	498	499	500	501	502	503	504	505	506	507	508	509	510	511	512	513	514	515	516	517	518	519	520	521	522	523	524	5
---	---	---	---	---	---	---	---	---	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	---

1. Docket: 50-389 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/86 Outage + On-line Hrs: 744.0

3. Utility Contact: N. W. GRANT (305) 552-3675

4. Licensed Thermal Power (MWT): 2700

5. Nameplate Rating (Gross MWe): 0850

6. Design Electrical Rating (Net MWe): 830

7. Maximum Dependable Capacity (Gross MWe): 882

8. Maximum Dependable Capacity (Net MWe): 837

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,087.0</u>	<u>26,136.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>3,661.3</u>	<u>21,710.2</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>3,604.1</u>	<u>21,176.3</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>2,008,268</u>	<u>9,584,356</u>	<u>54,230,890</u>
18. Gross Elec Ener (MWH)	<u>674,790</u>	<u>3,206,580</u>	<u>18,123,260</u>
19. Net Elec Ener (MWH)	<u>641,224</u>	<u>3,031,730</u>	<u>17,102,773</u>
20. Unit Service Factor	<u>100.0</u>	<u>70.8</u>	<u>81.0</u>
21. Unit Avail Factor	<u>100.0</u>	<u>70.8</u>	<u>81.0</u>
22. Unit Cap Factor (MDC Net)	<u>103.0</u>	<u>71.2</u>	<u>78.2</u>
23. Unit Cap Factor (DER Net)	<u>103.8</u>	<u>71.8</u>	<u>78.8</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>1.5</u>	<u>9.3</u>
25. Forced Outage Hours	<u>.0</u>	<u>53.2</u>	<u>?,179.8</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


NONE

27. If Currently Shutdown Estimated Startup Date: N/A

* ST LUCIE 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

ST LUCIE 2



JULY 1986

Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

* ST LUCIE 2 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
-----	------	------	-------	--------	--------	------------	--------	-----------	---

NONE

* SUMMARY *

ST. LUCIE 2 OPERATED ROUTINELY IN JULY WITH NO SHUTDOWNS OR POWER REDUCTIONS REPORTED.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* ST LUCIE 2 *

FACILITY DATA

Report Period JUL 1986

FACILITY DESCRIPTION

LOCATION
STATE.....FLORIDA
COUNTY.....ST LUCIE
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...12 MI SE OF
FT. PIERCE, FLA
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...JUNE 2, 1983
DATE ELEC ENER 1ST GENER...JUNE 13, 1983
DATE COMMERCIAL OPERATE...AUGUST 8, 1983
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...ATLANTIC OCEAN
ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....FLORIDA POWER & LIGHT
CORPORATE ADDRESS.....9250 WEST FLAGLER ST., P.O. BOX 529100
MIAMI, FLORIDA 33152
CONTRACTOR
ARCHITECT/ENGINEER.....EBASCO
NUC STEAM SYS SUPPLIER...COMBUSTION ENGINEERING
CONSTRUCTOR.....EBASCO
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
IE RESIDENT INSPECTOR.....R. CRLJAK
LICENSING PROJ MANAGER....E. TOURIGNY
DOCKET NUMBER.....50-389
LICENSE & DATE ISSUANCE...NPF-16, JUNE 10, 1983
PUBLIC DOCUMENT ROOM.....INDIAN RIVER COMMUNITY COLLEGE LIBRARY
3209 VIRGINIA AVENUE
FT. PIERCE, FLORIDA 33450

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ THERE WERE NO INSPECTIONS CONDUCTED AT ST. LUCIE UNIT 2 FOR THE MONTH OF JULY.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

Report Period JUL 1986

I N S P E C T I O N S T A T U S - (CONTINUED)

* ST LUCIE 2 *

OTHER ITEMS

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

NORMAL OPERATIONS.

LAST IE SITE INSPECTION DATE: MAY 13 - JUNE 16, 1986

INSPECTION REPORT NO: 50-389/86-15

R E P O R T S F R O M L I C E N S E E

=====			
NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT

86-007	04/17/86	05/19/86	PRESSURIZER CODE SAFETIES INOPERABLE DUE TO LIFT SETPOINT DRIFT.
86-009	05/22/86	06/21/86	LLRT ON CONTAINMENT PENETRATION 28A EXCEEDED TECHNICAL SPECIFICATION; CAUSE - A DEGRADED DISC.
86-010	06/04/86	07/07/86	REACTOR TRIP BY LOW STEAM GENERATOR WATER LEVEL DUE TO PERSONNEL ERROR.
=====			

1. Docket: 50-395 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/86 Outage + On-line Hrs: 744.0

3. Utility Contact: G. A. LOIGNON (803) 345-5209

4. Licensed Thermal Power (MWt): 2775

5. Nameplate Rating (Gross MWe): 0900

6. Design Electrical Rating (Net MWe): 900

7. Maximum Dependable Capacity (Gross MWe): 900

8. Maximum Dependable Capacity (Net MWe): 885

9. If Changes Occur Above Since Last Report, Give Reasons:

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____

NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,087.0</u>	<u>22,631.0</u>
13. Hours Reactor Critical	<u>730.9</u>	<u>4,858.8</u>	<u>16,852.1</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>710.8</u>	<u>4,797.9</u>	<u>16,438.2</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,898,812</u>	<u>13,018,234</u>	<u>42,855,800</u>
18. Gross Elec Ener (MWH)	<u>620,750</u>	<u>4,338,560</u>	<u>14,269,183</u>
19. Net Elec Ener (MWH)	<u>593,664</u>	<u>4,154,920</u>	<u>13,581,967</u>
20. Unit Service Factor	<u>95.5</u>	<u>94.3</u>	<u>72.6</u>
21. Unit Avail Factor	<u>95.5</u>	<u>94.3</u>	<u>72.6</u>
22. Unit Cap Factor (MDC Net)	<u>90.2</u>	<u>92.3</u>	<u>67.8</u>
23. Unit Cap Factor (DER Net)	<u>88.7</u>	<u>90.8</u>	<u>66.7</u>
24. Unit Forced Outage Rate	<u>4.5</u>	<u>5.7</u>	<u>7.6</u>
25. Forced Outage Hours	<u>33.2</u>	<u>289.1</u>	<u>1,349.8</u>
26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):	<u>NONE</u>		

27. If Currently Shutdown Estimated Startup Date: N/A

* SUMMER 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

SUMMER 1



JULY 1986

Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

 * SUMMER 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
4	06/29/86	F	14.3	A	4				CONTINUATION OF OUTAGE FROM PREVIOUS MONTH.
5	07/27/86	F	18.9	A	3				LOW EHC PRESSURE DURING CONTROL VALVE TESTING.

 * SUMMARY *

SUMMER 1 HAD 2 OUTAGES IN JULY AS DISCUSSED ABOVE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* SUMMER 1 *

FACILITY DATA

Report Period JUL 1986

FACILITY DESCRIPTION

LOCATION
STATE.....SOUTH CAROLINA
COUNTY.....FAIRFIELD
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...26 MI NW OF
COLUMBIA, SC
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...OCTOBER 22, 1982
DATE ELEC ENER 1ST GENER...NOVEMBER 16, 1982
DATE COMMERCIAL OPERATE....JANUARY 1, 1984
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...MONTICELLO RESERVOIR
ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....SOUTH CAROLINA ELECTRIC & GAS CO.
CORPORATE ADDRESS.....P.O. BOX 764
COLUMBIA, SOUTH CAROLINA 29202
CONTRACTOR
ARCHITECT/ENGINEER.....GILBERT ASSOCIATES
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....DANIEL INTERNATIONAL
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
IE RESIDENT INSPECTOR.....R. PREVATTE
LICENSING PROJ MANAGER.....J. HOPKINS
DOCKET NUMBER.....50-395
LICENSE & DATE ISSUANCE....NPF-12, NOVEMBER 12, 1982
PUBLIC DOCUMENT ROOM.....FAIRFIELD COUNTY LIBRARY
GARDEN & WASHINGTON STREETS
WINNSBORO, SOUTH CAROLINA 29180

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION APRIL 1- MAY 31 (86-09): THIS ROUTINE, ANNOUNCED INSPECTION WAS CONDUCTED IN THE AREAS OF LICENSEE ACTION ON PREVIOUS ENFORCEMENT MATTERS, ON SITE FOLLOWUP OF EVENTS AND SUBSEQUENT WRITTEN REPORTS, MONTHLY SURVEILLANCE OBSERVATIONS, ENGINEERED SAFETY FEATURES SYSTEM WALKDOWN, MONTHLY MAINTENANCE OBSERVATION, AND OPERATIONAL SAFETY VERIFICATION. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE.

INSPECTION STATUS - (CONTINUED)

PAGE 2-363

1. Docket: 50-280 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/86 Outage + On-line Hrs: 744.0

3. Utility Contact: VIVIAN H. JONES (804) 357-3184

4. Licensed Thermal Power (MWt): 2441

5. Nameplate Rating (Gross MWe): 942 X 0.9 = 848

6. Design Electrical Rating (Net MWe): 788

7. Maximum Dependable Capacity (Gross MWe): 820

8. Maximum Dependable Capacity (Net MWe): 781

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,087.0</u>	<u>119,279.0</u>
13. Hours Reactor Critical	<u>441.0</u>	<u>3,171.2</u>	<u>75,499.3</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>3,774.5</u>
15. Hrs Generator On-Line	<u>327.8</u>	<u>3,023.9</u>	<u>73,862.0</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>3,736.2</u>
17. Gross Therm Ener (MWH)	<u>648,190</u>	<u>6,973,390</u>	<u>170,330,316</u>
18. Gross Elec Ener (MWH)	<u>205,250</u>	<u>2,308,945</u>	<u>55,080,728</u>
19. Net Elec Ener (MWH)	<u>192,484</u>	<u>2,191,310</u>	<u>52,221,439</u>
20. Unit Service Factor	<u>44.1</u>	<u>59.4</u>	<u>61.9</u>
21. Unit Avail Factor	<u>44.1</u>	<u>59.4</u>	<u>65.1</u>
22. Unit Cap Factor (MDC Net)	<u>33.1</u>	<u>55.2</u>	<u>56.1</u>
23. Unit Cap Factor (DER Net)	<u>32.8</u>	<u>54.7</u>	<u>55.6</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>1.8</u>	<u>18.5</u>
25. Forced Outage Hours	<u>.0</u>	<u>56.0</u>	<u>13,037.3</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: 07/04/86

* SURRY 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
SURRY 1



JULY 1986

Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

 * SURRY 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
86-05	05/10/86	S	416.2	C	1				PLANT SHUTDOWN FOR REFUELING.

 * SUMMARY *

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint -r Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* SURRY 1 *

FACILITY DATA

Report Period JUL 1986

FACILITY DESCRIPTION

LOCATION
STATE.....VIRGINIA
COUNTY.....SURRY
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...17 MI NW OF
NEWPORT NEWS, VA
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...JULY 1, 1972
DATE ELEC ENER 1ST GENER...JULY 4, 1972
DATE COMMERCIAL OPERATE...DECEMBER 22, 1972
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...JAMES RIVER
ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....VIRGINIA POWER
CORPORATE ADDRESS.....P.O. BOX 26666
RICHMOND, VIRGINIA 23261
CONTRACTOR
ARCHITECT/ENGINEER.....STONE & WEBSTER
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....STONE & WEBSTER
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
IE RESIDENT INSPECTOR.....D. BURKE
LICENSING PROJ MANAGER.....C. PATEL
DOCKET NUMBER.....50-280
LICENSE & DATE ISSUANCE....DPR-32, MAY 25, 1972
PUBLIC DOCUMENT ROOM.....SWEM LIBRARY
COLLEGE OF WILLIAM AND MARY
WILLIAMSBURG, VIRGINIA 23185

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION JUNE 2-6 (86-13): THIS WAS A ROUTINE, UNANNOUNCED INSPECTION IN THE AREAS OF INSERVICE INSPECTION, REPAIR ACTIVITIES AND REVIEW OF PREVIOUS OPEN ITEMS. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE.

FACILITY ITEMS (PLANS AND PROCEDURES):

INSPECTION STATUS - (CONTINUED)

```
*****  
*                SURRY 1                *  
*****
```

NONE.

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

REFUELING OUTAGE

LAST IE SITE INSPECTION DATE: JUNE 2-6, 1986 +

INSPECTION REPORT NO: 50-280/86-13 +

REPORTS FROM LICENSEE

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
86-020	06/09/86		AN ENVIRONMENTAL QUALIFICATION INSPECTION MADE OF LIMITORQUE MOTOR VALVE OPERATOR WIRING AS A RESULT OF IEN 86-03 (LACK OF IDENTIFICATION WIRING NOT ENVIRONMENTALLY QUALIFIED).

1. Docket: 50-281 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/86 Outage + On-line Hrs: 744.0

3. Utility Contact: VIVIAN H. JONES (804) 357-3184

4. Licensed Thermal Power (MWt): 2441

5. Nameplate Rating (Gross MWe): 942 X 0.9 = 848

6. Design Electrical Rating (Net MWe): 788

7. Maximum Dependable Capacity (Gross MWe): 811

8. Maximum Dependable Capacity (Net MWe): 781

9. If Changes Occur Above Since Last Report, Give Reasons: NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any: NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,087.0</u>	<u>116,159.0</u>
13. Hours Reactor Critical	<u>592.1</u>	<u>4,411.1</u>	<u>76,353.5</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>23.8</u>
15. Hrs Generator On-Line	<u>584.1</u>	<u>4,374.8</u>	<u>75,140.2</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,331,725</u>	<u>10,495,120</u>	<u>175,802,147</u>
18. Gross Elec Ener (MWH)	<u>427,750</u>	<u>3,447,660</u>	<u>57,030,964</u>
19. Net Elec Ener (MWH)	<u>405,202</u>	<u>3,274,891</u>	<u>54,063,778</u>
20. Unit Service Factor	<u>78.5</u>	<u>86.0</u>	<u>64.7</u>
21. Unit Avail Factor	<u>78.5</u>	<u>86.0</u>	<u>64.7</u>
22. Unit Cap Factor (MDC Net)	<u>69.7</u>	<u>82.5</u>	<u>59.6</u>
23. Unit Cap Factor (DER Net)	<u>69.1</u>	<u>81.7</u>	<u>59.1</u>
24. Unit Forced Outage Rate	<u>21.5</u>	<u>10.4</u>	<u>12.9</u>
25. Forced Outage Hours	<u>159.9</u>	<u>506.1</u>	<u>8,437.9</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


NONE

27. If Currently Shutdown Estimated Startup Date: N/A

* SURRY 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

SURRY 2



JULY 1986

Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

 * SURRY 2 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
86-04	06/17/86	F	52.8	D	4	86-006			UNIT SHUTDOWN FOR REPAIR ON SW EXPANSION JOINT IN RS-E-1A AND PLUGGING OF S/G TUBE LEAK. CONTINUATION OF 6/17/86 OUTAGE.
86-05	07/23/86	F	107.1	D	1	86-007			UNIT WAS SHUTDOWN TO REPAIR TUBE LEAK IN RS-E-1B.

 * SUMMARY *

 SURRY 2 EXPERIENCED 2 SHUTDOWNS IN JULY AS DISCUSSED ABOVE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* SURRY 2 *

FACILITY DATA

Report Period JUL 1986

FACILITY DESCRIPTION

LOCATION
STATE.....VIRGINIA
COUNTY.....SURRY
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...17 MI NW OF
NEWPORT NEWS, VA
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...MARCH 7, 1973
DATE ELEC ENER 1ST GENER...MARCH 10, 1973
DATE COMMERCIAL OPERATE...MAY 1, 1973
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...JAMES RIVER
ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....VIRGINIA POWER
CORPORATE ADDRESS.....P.O. BOX 26666
RICHMOND, VIRGINIA 23261
CONTRACTOR
ARCHITECT/ENGINEER.....STONE & WEBSTER
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....STONE & WEBSTER
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
IE RESIDENT INSPECTOR.....D. BURKE
LICENSING PROJ MANAGER.....C. PATEL
DOCKET NUMBER.....50-281
LICENSE & DATE ISSUANCE....DPR-37, JANUARY 29, 1973
PUBLIC DOCUMENT ROOM.....SWEM LIBRARY
COLLEGE OF WILLIAM AND MARY
WILLIAMSBURG, VIRGINIA 23185

INSPECTION STATUS

INSPECTION SUMMARY

+ INSPECTION JUNE 2-6 (86-13): THIS WAS A ROUTINE, UNANNOUNCED INSPECTION IN THE AREAS OF INSERVICE INSPECTION, REPAIR ACTIVITIES AND REVIEW OF PREVIOUS OPEN ITEMS. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE.

FACILITY ITEMS (PLANS AND PROCEDURES):

Report Period JUL 1986

INSPECTION STATUS - (CONTINUED)

* SURRY 2 *

OTHER ITEMS

NONE.

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

NORMAL OPERATION.

LAST IE SITE INSPECTION DATE: JUNE 2-6, 1986 +

INSPECTION REPORT NO: 50-281/86-13 +

REPORTS FROM LICENSEE

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
86-007	06/17/86	07/14/86	MANUAL REACTOR TRIP DUE TO HIGH STEAM GENERATOR LEVEL; CAUSED BY FAILURE OF VALVE FCV-2478 (ELLS FCV) TO CLOSE.

=====

1. Docket: 50-387 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/86 Outage + On-line Hrs: 744.0

3. Utility Contact: J. A. HIRT (717) 542-3917

4. Licensed Thermal Power (MWt): 3293

5. Nameplate Rating (Gross MWe): 1280 X 0.9 = 1152

6. Design Electrical Rating (Net MWe): 1065

7. Maximum Dependable Capacity (Gross MWe): 1068

8. Maximum Dependable Capacity (Net MWe): 1032

9. If Changes Occur Above Since Last Report, Give Reasons:

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,087.0</u>	<u>27,600.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>2,931.9</u>	<u>18,925.0</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>102.1</u>	<u>773.2</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>2,791.8</u>	<u>18,412.4</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>2,407,031</u>	<u>8,674,169</u>	<u>56,254,442</u>
18. Gross Elec Ener (MWH)	<u>777,958</u>	<u>2,822,192</u>	<u>18,321,184</u>
19. Net Elec Ener (MWH)	<u>750,278</u>	<u>2,685,596</u>	<u>17,574,822</u>
20. Unit Service Factor	<u>100.0</u>	<u>54.9</u>	<u>66.7</u>
21. Unit Avail Factor	<u>100.0</u>	<u>54.9</u>	<u>66.7</u>
22. Unit Cap Factor (MDC Net)	<u>97.7</u>	<u>51.2</u>	<u>61.7</u>
23. Unit Cap Factor (DER Net)	<u>94.7</u>	<u>49.6</u>	<u>59.8</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>19.6</u>	<u>12.6</u>
25. Forced Outage Hours	<u>.0</u>	<u>681.5</u>	<u>2,661.6</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):

NONE

27. If Currently Shutdown Estimated Startup Date: N/A

* SUSQUEHANNA 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
SUSQUEHANNA 1



JULY 1986

Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

 * SUSQUEHANNA 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System Component	Cause & Corrective Action to Prevent Recurrence
8	07/05/86	S	0.0	F	5		ZZ ZZZZZZ	POWER REDUCTION FOR CONTROL ROD SEQUENCE EXCHANGE. MSIV STROKE TIME TESTING ALSO COMPLETED.

 * SUMMARY *

SUSQUEHANNA 1 OPERATED ROUTINELY IN JULY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* SUSQUEHANNA 1 *

FACILITY DATA

Report Period JUL 1986

FACILITY DESCRIPTION

UTILITY & CONTRACTOR INFORMATION

LOCATION
STATE.....PENNSYLVANIA
COUNTY.....LUZERNE
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...7 MI NE OF
BERWICK, PA
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...SEPTEMBER 10, 1982
DATE ELEC ENER 1ST GENER.. NOVEMBER 16, 1982
DATE COMMERCIAL OPERATE....JUNE 8, 1983
CONDENSER COOLING METHOD...CC,HNDCT
CONDENSER COOLING WATER....SUSQUEHANNA RIVER
ELECTRIC RELIABILITY
COUNCIL.....MID-ATLANTIC
AREA COUNCIL

UTILITY
LICENSEE.....PENNSYLVANIA POWER & LIGHT
CORPORATE ADDRESS.....2 NORTH NINTH STREET
ALLENTOWN, PENNSYLVANIA 18101
CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I
IE RESIDENT INSPECTOR.....R. JACOBS
LICENSING PROJ MANAGER....M. THADANI
DOCKET NUMBER.....50-387
LICENSE & DATE ISSUANCE...NPF-14, NOVEMBER 12, 1982
PUBLIC DOCUMENT ROOM.....OSTERHOUT FREE LIBRARY
71 SOUTH FRANKLIN STREET
WILKES-BARRE, PENNSYLVANIA 18701

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

Report Period JUL 1986

I N S P E C T I O N S T A T U S - (CONTINUED)

X SUSQUEHANNA 1 X

OTHER ITEMS

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S F R O M L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT

NO INPUT PROVIDED.			
=====			

1. Docket: 50-388 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/86 Outage + On-line Hrs: 744.0

3. Utility Contact: J. A. HIRT (717) 542-3917

4. Licensed Thermal Power (MWt): 3293

5. Nameplate Rating (Gross MWe): 1152

6. Design Electrical Rating (Net MWe): 1065

7. Maximum Dependable Capacity (Gross MWe): 1068

8. Maximum Dependable Capacity (Net MWe): 1032

9. If Changes Occur Above Since Last Report, Give Reasons:

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,087.0</u>	<u>12,839.0</u>
13. Hours Reactor Critical	<u>659.1</u>	<u>4,273.8</u>	<u>11,395.0</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>133.6</u>	<u>693.9</u>
15. Hrs Generator On-Line	<u>637.6</u>	<u>4,201.6</u>	<u>11,196.7</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,608,845</u>	<u>12,829,982</u>	<u>34,860,780</u>
18. Gross Elec Ener (MWH)	<u>509,494</u>	<u>4,205,628</u>	<u>11,418,428</u>
19. Net Elec Ener (MWH)	<u>485,229</u>	<u>4,040,611</u>	<u>10,994,921</u>
20. Unit Service Factor	<u>85.7</u>	<u>82.6</u>	<u>87.2</u>
21. Unit Avail Factor	<u>85.7</u>	<u>82.6</u>	<u>87.2</u>
22. Unit Cap Factor (MDC Net)	<u>63.2</u>	<u>77.0</u>	<u>83.0</u>
23. Unit Cap Factor (DER Net)	<u>61.2</u>	<u>74.6</u>	<u>80.4</u>
24. Unit Forced Outage Rate	<u>14.3</u>	<u>17.4</u>	<u>12.8</u>
25. Forced Outage Hours	<u>106.4</u>	<u>885.4</u>	<u>1,642.3</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):

REFUELING OUTAGE: AUGUST 9, 1986; 84 DAYS.

27. If Currently Shutdown Estimated Startup Date: N/A

* SUSQUEHANNA 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
SUSQUEHANNA 2



JULY 1986

Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

 * SUSQUEHANNA 2 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
6	07/12/86	F	0.0	A	5		CE	VALVOP	POWER REDUCTION TO FACILITATE MAINTENANCE ON RCIC INJECTION VALVE DUE TO ALARA CONCERNS.
7	07/17/86	F	106.4	A	2	86-010	CF	VALVEX	CONTROLLED SHUTDOWN DUE TO REACTOR COOLANT UNIDENTIFIED LEAKAGE EXCEEDING 5 GPM. THE PACKING OF RHR LOOP "B" TESTABLE CHECK VALVE HAD FAILED AND WAS REPLACED.

 * SUMMARY *

 SUSQUEHANNA INCURRED 1 SHUTDOWN AND 1 POWER REDUCTION IN JULY AS DISCUSSED ABOVE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* SUSQUEHANNA 2 *

F A C I L I T Y D A T A

Report Period JUL 1986

FACILITY DESCRIPTION

UTILITY & CONTRACTOR INFORMATION

LOCATION
STATE.....PENNSYLVANIA
COUNTY.....LUZERNE
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...7 MI NE OF
BERWICK, PA
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...MAY 8, 1984
DATE ELEC ENER 1ST GENER...JULY 3, 1984
DATE COMMERCIAL OPERATE....FEBRUARY 12, 1985
CONDENSER COOLING METHOD...CC,HNDCT
CONDENSER COOLING WATER....SUSQUEHANNA RIVER
ELECTRIC RELIABILITY
COUNCIL.....MID-ATLANTIC
AREA COUNCIL

UTILITY
LICENSEE.....PENNSYLVANIA POWER & LIGHT
CORPORATE ADDRESS.....2 NORTH NINTH STREET
ALLENTOWN, PENNSYLVANIA 18101
CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I
IE RESIDENT INSPECTOR.....L. PLISCO
LICENSING PROJ MANAGER.....M. THADANI
DOCKET NUMBER.....50-388
LICENSE & DATE ISSUANCE...NPF-22, JUNE 27, 1984
PUBLIC DOCUMENT ROOM.....OSTERHOUT FREE LIBRARY
71 SOUTH FRANKLIN STREET
WILKES-BARRE, PENNSYLVANIA 18701

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

Report Period JUL 1986

I N S P E C T I O N S T A T U S - (CONTINUED)

* SUSQUEHANNA 2 *

OTHER ITEMS

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S F R O M L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT

NO INPUT PROVIDED.			
=====			

1. Docket: 50-289 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/86 Outage + On-line Hrs: 744.0

3. Utility Contact: C. W. MYTH (717) 948-8551

4. Licensed Thermal Power (MWt): 2535

5. Nameplate Rating (Gross MWe): 968 X 0.9 = 871

6. Design Electrical Rating (Net MWe): 819

7. Maximum Dependable Capacity (Gross MWe): 840

8. Maximum Dependable Capacity (Net MWe): 776

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,087.0</u>	<u>104,424.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>4,061.6</u>	<u>37,878.2</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>990.8</u>	<u>1,875.0</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>4,005.6</u>	<u>37,039.5</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,879,956</u>	<u>10,012,439</u>	<u>89,362,835</u>
18. Gross Elec Ener (MWH)	<u>608,815</u>	<u>3,302,856</u>	<u>29,695,009</u>
19. Net Elec Ener (MWH)	<u>574,180</u>	<u>3,098,185</u>	<u>27,749,898</u>
20. Unit Service Factor	<u>100.0</u>	<u>78.7</u>	<u>35.5</u>
21. Unit Avail Factor	<u>100.0</u>	<u>78.7</u>	<u>35.5</u>
22. Unit Cap Factor (MDC Net)	<u>99.5</u>	<u>78.5</u>	<u>34.0*</u>
23. Unit Cap Factor (DER Net)	<u>94.2</u>	<u>74.4</u>	<u>32.4</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>4.1</u>	<u>61.4</u>
25. Forced Outage Hours	<u>.0</u>	<u>171.3</u>	<u>58,939.8</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


REFUELING OUTAGE: NOVEMBER 1, 1986 - 4 TO 5 MONTHS.

27. If Currently Shutdown Estimated Startup Date: N/A

* THREE MILE ISLAND 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

THREE MILE ISLAND 1



JULY 1986

* Item calculated with a Weighted Average

Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

* THREE MILE ISLAND 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
-----	------	------	-------	--------	--------	------------	--------	-----------	---

NONE

* SUMMARY *

THREE MILE ISLAND 1 OPERATED ROUTINELY IN JULY WITH NO SHUTDOWNS A POWER REDUCTIONS REPORTED.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* THREE M^TE ISLAND 1 *

FACILITY DATA

Report Period JUL 1986

FACILITY DESCRIPTION

LOCATION
STATE.....PENNSYLVANIA
COUNTY.....DAUPHIN
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...10 MI SE OF
HARRISBURG, PA
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...JUNE 5, 1974
DATE ELEC ENER 1ST GENER...JUNE 19, 1974
DATE COMMERCIAL OPERATE....SEPTEMBER 2, 1974
CONDENSER COOLING METHOD... COOLING TOWERS
CONDENSER COOLING WATER...SUSQUEHANNA RIVER
ELECTRIC RELIABILITY
COUNCIL.....MID-ATLANTIC
AREA COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....GPU NUCLEAR CORP.
CORPORATE ADDRESS.....P.O. BOX 480
MIDDLETOWN, PENNSYLVANIA 17057
CONTRACTOR
ARCHITECT/ENGINEER.....GILBERT ASSOCIATES
NUC STEAM SYS SUPPLIER...BABCOCK & WILCOX
CONSTRUCTOR.....UNITED ENG. & CONSTRUCTORS
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I
IE RESIDENT INSPECTOR.....R. CONTE
LICENSING PROJ MANAGER.....J. THOMA
DOCKET NUMBER.....50-289
LICENSE & DATE ISSUANCE....DPR-50, APRIL 19, 1974
PUBLIC DOCUMENT ROOM.....GOVERNMENT PUBLICATIONS SECTION
STATE LIBRARY OF PENNSYLVANIA
FORUM BUILDING
COMMONWEALTH AND WALNUT STREET
HARRISBURG, PENNSYLVANIA 17105

INSPECTION STATUS

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

Report Period: JUL 1986

I N S P E C T I O N S T A T U S - (CONTINUED)

* THREE MILE ISLAND 1 *

OTHER ITEMS

NO INPUT PROVIDED.

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S F R O M L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
--------	------------------	-------------------	---------

NO INPUT PROVIDED.

=====

1. Docket: 50-344 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/86 Outage + On-line Hrs: 744.0

3. Utility Contact: F. J. UHMER (503) 556-3713 X495

4. Licensed Thermal Power (MWt): 3411

5. Nameplate Rating (Gross MWe): 1280 X 0.95 = 1216

6. Design Electrical Rating (Net MWe): 1130

7. Maximum Dependable Capacity (Gross MWe): 1122

8. Maximum Dependable Capacity (Net MWe): 1050

9. If Changes Occur Above Since Last Report, Give Reasons:

NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,087.0</u>	<u>86,903.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>3,554.1</u>	<u>54,104.5</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>3,875.4</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>3,494.7</u>	<u>52,549.0</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>3,237.0</u>
17. Gross Therm Ener (MWH)	<u>2,536,944</u>	<u>11,288,621</u>	<u>167,819,204</u>
18. Gross Elec Ener (MWH)	<u>831,253</u>	<u>3,629,381</u>	<u>54,447,697</u>
19. Net Elec Ener (MWH)	<u>792,740</u>	<u>3,439,164</u>	<u>51,500,438</u>
20. Unit Service Factor	<u>100.0</u>	<u>68.7</u>	<u>60.5</u>
21. Unit Avail Factor	<u>100.0</u>	<u>68.7</u>	<u>64.2</u>
22. Unit Cap Factor (MDC Net)	<u>101.5</u>	<u>64.4</u>	<u>56.4</u>
23. Unit Cap Factor (DER Net)	<u>94.3</u>	<u>59.8</u>	<u>52.4</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>1.6</u>	<u>14.7</u>
25. Forced Outage Hours	<u>.0</u>	<u>55.6</u>	<u>9,066.0</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):

NONE

27. If Currently Shutdown Estimated Startup Date: N/A

* TROJAN *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
TROJAN



JULY 1986

Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

* TROJAN *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
-----	------	------	-------	--------	--------	------------	--------	-----------	---

NONE

* SUMMARY *

TROJAN OPERATED ROUTINELY IN JULY WITH NO SHUTDOWNS OR POWER REDUCTIONS REPORTED.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* TROJAN *

FACILITY DATA

Report Period JUL 1986

FACILITY DESCRIPTION

LOCATION
STATE.....OREGON
COUNTY.....COLUMBIA
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...32 MI N OF
PORTLAND, ORE
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...DECEMBER 15, 1975
DATE ELEC ENER 1ST GENER...DECEMBER 23, 1975
DATE COMMERCIAL OPERATE...MAY 20, 1976
CONDENSER COOLING METHOD...COOLING TOWERS
CONDENSER COOLING WATER...COOLING TOWER
ELECTRIC RELIABILITY
COUNCIL.....WESTERN SYSTEMS
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....PORTLAND GENERAL ELECTRIC
CORPORATE ADDRESS.....121 S.W. SALMON STREET
PORTLAND, OREGON 97204
CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....V
IE RESIDENT INSPECTOR.....S. RICHARDS
LICENSING PROJ MANAGER.....T. CHAN
DOCKET NUMBER.....50-344
LICENSE & DATE ISSUANCE...NPF-1, NOVEMBER 21, 1975
PUBLIC DOCUMENT ROOM.....LIBRARY ASSOCIATION OF PORTLAND
SOCIAL SCIENCES & SCIENCE DEPARTMENT
801 SW 10TH AVENUE
PORTLAND, OREGON 97205

INSPECTION STATUS

INSPECTION SUMMARY

- + INSPECTION ON AUGUST 11-22, 1986 (REPORT NO. 50-344/86-23) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.
 - + INSPECTION ON JUNE 16 - AUGUST 4, 1986 (REPORT NO. 50-344/86-25) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.
 - + INSPECTION ON JULY 14-18, 1986 (REPORT NO. 50-344/86-26) AREAS INSPECTED: ROUTINE, UNANNOUNCED INSPECTION OF THE PROCUREMENT PROGRAM, AND ONSITE FOLLOWUP OF WRITTEN REPORTS OF NONROUTINE EVENTS BY ONE NRC INSPECTOR. DURING THIS INSPECTION, TWO INSPECTION PROCEDURES WERE UTILIZED.
- RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.
- + ENFORCEMENT CONFERENCE ON JULY 9, 1986 (REPORT NO. 50-344/86-27) SUMMARY: AN ENFORCEMENT CONFERENCE WAS HELD ON JULY 9, 1986, CONCERNING AN APPARENT VIOLATION IDENTIFIED DURING A SPECIAL INSPECTION OF QUALITY CONTROL ACTIVITIES (INSPECTION REPORT 50-344/86-24).
 - + INSPECTION ON JULY 22-31, 1986 (REPORT NO. 50-344/86-28) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.
 - + INSPECTION ON JULY 28 - AUGUST 1, 1986 (REPORT NO. 50-344/86-29) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

```

XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX
X                TROJAN                X
XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX

```

TECHNICAL SPECIFICATION 6.11 REQUIRES THAT PROCEDURES FOR PERSONNEL RADIATION PROTECTION SHALL BE PREPARED CONSISTENT WITH THE REQUIREMENTS OF 10 CFR PART 20 AND SHALL BE APPROVED, MAINTAINED, AND ADHERED TO FOR ALL OPERATIONS INVOLVING PERSONNEL RADIATION EXPOSURE. THE LICENSEE'S RADIATION PROTECTION MANUAL DEVELOPED PURSUANT TO THIS SPECIFICATION REQUIRES IN SECTION II.B.4.A THAT A DETERMINATION OF THE MEDICAL STATUS OF EACH PERSON WHO MAY BE REQUIRED TO WEAR RESPIRATORY PROTECTIVE EQUIPMENT WILL BE MADE PRIOR TO HIS ASSIGNMENT TO USE IT, AND REPEATED ANNUALLY THEREAFTER. SECTION II.H.2.C STATES THAT, "RESPIRATOR WILL ONLY BE ISSUED TO PERSONNEL QUALIFIED TO USE THE RESPIRATOR. QUALIFICATIONS CONSIST OF ... 2) MEDICAL EVALUATION ..." CONTRARY TO THE REQUIREMENT, ON APRIL 16 AND 18, 1986, A WORKER WAS ISSUED A RESPIRATOR FOR USE WHOSE MEDICAL REEVALUATION HAD EXPIRED ON FEBRUARY 28, 1986, AND ANOTHER WORKER WAS ISSUED A RESPIRATOR FOR USE ON APRIL 30, 1986, WHOSE MEDICAL REEVALUATION HAD EXPIRED ON FEBRUARY 19, 1986. IN EACH CASE, RESPIRATORS WERE ISSUED FOR AND USED PURSUANT TO RADIATION WORK PERMIT REQUIREMENTS.

(8601 4)

10 CFR 20.401(B) REQUIRES, IN PART, THAT EACH LICENSEE SHALL MAINTAIN RECORDS SHOWING THE RESULTS OF SURVEYS REQUIRED BY 10 CFR 20.201(B) "SURVEYS." 10 CFR 20.201(B) REQUIRES THAT EACH LICENSEE MAKE OR CAUSE TO BE MADE SURVEYS AS: (1) MAY BE NECESSARY FOR THE LICENSEE TO COMPLY WITH THE REGULATIONS IN 10 CFR 20, AND (2) ARE REASONABLE UNDER THE CIRCUMSTANCES TO EVALUATE THE EXTENT OF RADIATION HAZARDS THAT MAY BE PRESENT. CONTRARY TO THE REQUIREMENT, THE LICENSEE DID NOT MAINTAIN RECORDS OF SURVEYS PERFORMED ON MAY 12 AND APRIL 19 AND 25, 1986, TO EVALUATE THE POSSIBLE INTAKE OF RADIOACTIVE MATERIALS OF WORKERS WHO RECEIVED OPEN SKIN OR FLESH WOUNDS WHILE WORKING IN CONTAMINATED AREAS.
(8601 5)

10 CFR 50, APPENDIX B, CRITERION V, AND THE TROJAN NUCLEAR PLANT NUCLEAR QUALITY ASSURANCE PROGRAM, SECTION 5.0, REQUIRE IN PART THAT ACTIVITIES AFFECTING QUALITY BE PRESCRIBED BY AND ACCOMPLISHED IN ACCORDANCE WITH DOCUMENTED PROCEDURES. MAINTENANCE PROCEDURE MP-5-1, "PRESSURIZER SAFETY VALVE INSERVICE TEST," ATTACHMENT I.B.5, STEPS 6.H AND 6.K, AND MAINTENANCE REQUEST 86-2120, WORK INSTRUCTIONS STEP 7, REQUIRED A QUALITY CONTROL INSPECTOR TO WITNESS THE BOLT TORQUING OF THE INLET FLANGE OF PRESSURIZER SAFETY VALVE #PSV-8010A, IN ACCORDANCE WITH QUALITY CONTROL PROCEDURE (QCP) 3, "VERIFICATION/WITNESSING INSPECTIONS." QCP 3, SECTION II, DEFINES WITNESSING AS, "AN INDEPENDENT CONFIRMATION, BY MEANS OF ACTUAL PHYSICAL OBSERVATION, THAT A CONDITION OR PROCESS COMPLIES WITH SPECIFIED REQUIREMENTS." CONTRARY TO THE REQUIREMENT, ON MAY 13, 1986, BOLT TORQUING OF THE INLET FLANGE OF VALVE PSV-8010A WAS NOT WITNESSED BY A QUALITY CONTROL INSPECTOR. THE QUALITY CONTROL INSPECTOR SIGNED DOCUMENTATION THAT THE BOLT TORQUING WAS WITNESSED.
(8602 3)

10 CFR 50, APPENDIX B, CRITERION XVI AND THE TROJAN NUCLEAR PLANT NUCLEAR QUALITY ASSURANCE PROGRAM, SECTION 15.2.3, REQUIRE IN PART THAT NONCONFORMANCES BE IDENTIFIED AND CORRECTED. NUCLEAR DIVISION PROCEDURE 600-1, "CONTROL OF NONCONFORMING MATERIALS, PARTS, AND COMPONENTS," SECTION 5.0, REQUIRES IN PART, THAT CORRECTIVE ACTION BE ASSIGNED AND IMPLEMENTED FOR NONCONFORMANCES. CONTRARY TO THE REQUIREMENT, CORRECTIVE ACTION WAS NOT ASSIGNED AND IMPLEMENTED FOR NONCONFORMANCE REPORT (NCR) NUMBER 86-024, WHICH DOCUMENTED NONCONFORMANCES ASSOCIATED WITH ELECTRICAL CONDUIT SUPPORT FOR THE 'A' TRAIN OF THE HYDROGEN RECOMBINER SYSTEM. (8602 4)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

INSPECTION STATUS - (CONTINUED)

OTHER ITEMS

NONE

100% POWER OPERATIONS.

LAST IE SITE INSPECTION DATE: 08/04-15/86

INSPECTION REPORT NO: 50-344/86-23

REPORTS FROM LICENSEE

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
--------	------------------	-------------------	---------

86-06-L0	06-10-86	07-10-86	NAOH ADDITIVE FLOWRATE TEST FAILED DUE TO MISAPPLICATION OF KEROTEST GLOBE VALVES
86-07-L0	06-19-86	07-16-86	REACTOR TRIP DUE TO PERSONNEL ERROR RESULTING IN EXCEEDING LOW POWER RANGE TRIP SETPOINT

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-250 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/86 Outage + On-line Hrs: 744.0

3. Utility Contact: N. W. GRANT (305) 552-3675

4. Licensed Thermal Power (MWt): 2200

5. Nameplate Rating (Gross MWe): 894 X 0.85 = 760

6. Design Electrical Rating (Net MWe): 693

7. Maximum Dependable Capacity (Gross MWe): 700

8. Maximum Dependable Capacity (Net MWe): 666

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,087.0</u>	<u>119,696.6</u>
13. Hours Reactor Critical	<u>337.9</u>	<u>3,539.4</u>	<u>84,336.3</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>844.3</u>
15. Hrs Generator On-Line	<u>337.6</u>	<u>3,489.1</u>	<u>81,896.1</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>121.8</u>
17. Gross Therm Ener (MWH)	<u>737,454</u>	<u>7,541,205</u>	<u>169,746,726</u>
18. Gross Elec Ener (MWH)	<u>237,900</u>	<u>2,469,640</u>	<u>54,341,185</u>
19. Net Elec Ener (MWH)	<u>222,954</u>	<u>2,335,244</u>	<u>51,444,82</u>
20. Unit Service Factor	<u>45.4</u>	<u>68.6</u>	<u>68.4</u>
21. Unit Avail Factor	<u>45.4</u>	<u>68.6</u>	<u>68.5</u>
22. Unit Cap Factor (MDC Net)	<u>45.0</u>	<u>68.9</u>	<u>66.1*</u>
23. Unit Cap Factor (DER Net)	<u>43.2</u>	<u>66.2</u>	<u>62.7</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>25.5</u>	<u>7.6</u>
25. Forced Outage Hours	<u>.0</u>	<u>1,191.5</u>	<u>6,226.3</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: 08/08/86

* TURKEY POINT 3 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

TURKEY POINT 3



JULY 1986

* Item calculated with a Weighted Average

PAGE 2-390

Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

* TURKEY POINT 3 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
08	07/15/86	S	406.4	B	1		EB	ENGINE	THE UNIT WAS SHUTDOWN TO PERFORM ELECTRICAL SYSTEM MODIFICATIONS REQUIRED FOR EMERGENCY DIESEL GENERATOR LOAD CONSIDERATIONS.

* SUMMARY *

TURKEY POINT 3 HAD 1 OUTAGE IN JULY AS DISCUSSED ABOVE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* TURKEY POINT 3 *

FACILITY DATA

Report Period JUL 1986

FACILITY DESCRIPTION

LOCATION
STATE.....FLORIDA
COUNTY.....DADE
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...25 MI S OF
MIAMI, FLA
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...OCTOBER 20, 1972
DATE ELEC ENER 1ST GENER...NOVEMBER 2, 1972
DATE COMMERCIAL OPERATE...DECEMBER 14, 1972
CONDENSER COOLING METHOD...CLOSED CANAL
CONDENSER COOLING WATER...CLOSED CYCLE CANAL
ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....FLORIDA POWER & LIGHT
CORPORATE ADDRESS.....9250 WEST FLAGLER STREET P.O. BOX 013100
MIAMI, FLORIDA 33174
CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
IE RESIDENT INSPECTOR.....T. PEEBLES
LICENSING PROJ MANAGER.....D. MCDONALD
DOCKET NUMBER.....50-250
LICENSE & DATE ISSUANCE...DPR-31, JULY 19, 1972
PUBLIC DOCUMENT ROOM.....ENVIRONMENTAL AND URBAN AFFAIRS LIBRARY
FLORIDA INTERNATIONAL UNIVERSITY
MIAMI, FLORIDA 33199

INSPECTION STATUS

INSPECTION SUMMARY

+ INSPECTION MARCH 23-28 AND APRIL 7-11 (86-18): THIS ROUTINE, ANNOUNCED INSPECTION WAS CONDUCTED ON SITE IN THE AREAS OF THE LICENSEE'S PHASE 1 AND PHASE 2 SELECTED SAFETY SYSTEM REVIEW, INSTRUMENT CALIBRATION, AND SELECTED SURVEILLANCES. ONE VIOLATION WAS IDENTIFIED FOR FOUR EXAMPLES OF FAILURE TO EITHER ESTABLISH OR IMPLEMENT PROCEDURES IN AREAS OF LIMITORQUE MAINTENANCE NORMAL VALVE LINEUPS FOR INTAKE COOLING WATER (ICW) AND COMPONENT COOLING WATER (CCW) SYSTEMS, AND MAINTENANCE OF THE EQUIPMENT OUT OF SERVICE (E00S) LOG. ANOTHER VIOLATION WAS IDENTIFIED FOR FAILURE TO PROMPTLY IDENTIFY AND CORRECT DEFICIENCIES WITH RESPECT TO CONTROL OF COMPONENT COOLING WATER (CCW) FLOW TO THE SAFETY INJECTION (SI) PUMPS. THIS ITEM IS BEING CONSIDERED FOR ESCALATED ENFORCEMENT ACTION, THEREFORE, NO NOTICE OF VIOLATION FOR THIS ITEM IS BEING ISSUED AT THIS TIME.

INSPECTION APRIL 3-6, 16-18 (86-24): THIS SPECIAL INSPECTION INVOLVED THE AREAS OF ACCELERATED REQUALIFICATION TRAINING, EMERGENCY OPERATING PROCEDURES, AND THE EMERGENCY DIESEL GENERATOR LOADING SAFETY EVALUATION AND ASSOCIATED CONFIRMATION OF ACTION LETTER. TWO VIOLATIONS AND ONE DEVIATION WERE IDENTIFIED: A. DEVIATION (250,251/86-24-04) - FAILURE TO REVISE PROCEDURES TO ASSURE THAT DIESEL GENERATOR LOADING REMAINED NO MORE THAN 2845 KW AS COMMITTED BY CONFIRMATION OF ACTION LETTER; (B) VIOLATION (250,251/86-24-06) - FAILURE TO PROVIDE ADEQUATE CORRECTIVE ACTIONS TO PRECLUDE REPETITION OF TRAINING DEFICIENCIES ON THE GAMMA METRICS NEUTRON FLUX MONITOR; AND (C) VIOLATION (250,251/86-24-08) - FAILURE TO PERFORM 10CFR 50.59 EVALUATION OF EDG LOADS BEYOND THOSE ANALYZED IN JPE-L-86-59, REVISION 1. NO NOTICE OF VIOLATION FOR THIS ITEM WILL BE INCLUDED IN THE REPORT AS THIS MATTER IS BEING CONSIDERED FOR ENFORCEMENT ACTION AS PART OF A SEPARATE REPORT.

INSPECTION APRIL 28 - MAY 2 (86-29): THIS SPECIAL, ANNOUNCED INSPECTION WAS PERFORMED AT THE LICENSEE'S ENGINEERING OFFICE AND THE PLANT SITE TO REVIEW THE CONTROL AND DISTRIBUTION OF EMERGENCY ELECTRICAL LOADS WHICH ARE CONNECTED TO THE EMERGENCY DIESEL

XXX
 X TURKEY POINT 3 X
 XXX

GENERATORS (EDG) IN THE EVENT OF A DESIGN BASE ACCIDENT (LOCA). THIS REPORT INCLUDES THE EVALUATION MADE AS THE RESULT OF A MEETING HELD IN REGION II OFFICES ON MAY 20, 1986 BETWEEN FP&L PERSONNEL AND NRC. ONE UNRESOLVED ITEM WAS IDENTIFIED - EMERGENCY DIESEL GENERATOR LOAD CONTROL.

INSPECTION MAY 12 - JUNE 9 (86-30): THIS ROUTINE, UNANNOUNCED INSPECTION ENTAILED DIRECT INSPECTION AT THE SITE, INCLUDING BACKSHIFT INSPECTION, IN THE AREAS OF LICENSEE ACTION ON PREVIOUS INSPECTION FINDINGS, ANNUAL AND MONTHLY SURVEILLANCE OBSERVATIONS, MAINTENANCE OBSERVATIONS AND REVIEWS, OPERATIONAL SAFETY VERIFICATION, ENGINEERED SAFETY FEATURES WALKDOWN, INDEPENDENT INSPECTION, AND FOLLOW-UP OF PLANT EVENTS. VIOLATION - FAILURE TO MEET THE REQUIREMENTS OF TECHNICAL SPECIFICATION (TS) 6.8.1.

INSPECTION JUNE 2-6 (86-31): THIS ROUTINE, UNANNOUNCED INSPECTION INVOLVED THE AREAS OF LICENSEE ACTIONS ON PREVIOUS ENFORCEMENT MATTERS (92701B AND 92702B), HOUSEKEEPING (54834B), MATERIAL IDENTIFICATION AND CONTROL (42902B), MATERIAL CONTROL (42940B), GULFALLOY SUPPLIED MATERIALS (92705B), INSERVICE TESTING OF PUMPS AND VALVES (6170u AND 61726), IE BULLETINS (IEBS) (92703B), FOLLOWUP ON IE NOTICES (IEN) (92717) AND INSPECTOR FOLLOWUP ITEMS. ONE VIOLATION WAS IDENTIFIED - 50-250/86-31-04: "FAILURE TO LOCK AND VERIFY THE LOCKED CONDITION OF VALVE 3-891A DURING IST". ONE DEVIATION WAS IDENTIFIED 50-250, 251/86-31-01: "FAILURE TO SUBMIT ISI RELIEF REQUEST AS COMMITTED".

CONTRARY TO TS 6.8.1 AND APPENDIX A OF USNRC REGULATORY GUIDE 1.33, THE LICENSEE APPROVED A NEW PROCEDURE FOR MOV MAINTENANCE, O-CME-102.1, BUT IT HAD NOT BEEN ISSUED FOR USE YET. THIS PROCEDURE ALSO INCLUDED THE SAME TORQUE SWITCH SETTINGS AS THE TOP. THE LICENSEE WAS INFORMED THAT TOP 166 AND O-CME-102.1 WERE INADEQUATE, IN THAT THEY SPECIFY THE INCORRECT TORQUE SWITCH SETTINGS RECOMMENDED BY LIMITORQUE. THE INSPECTOR CONSIDERS THAT THE LICENSEE SET MOV5-4-750/751 TORQUE SWITCHES TO TECHNICALLY ACCEPTABLE VALUE BUT DID NOT REVISE THE PROCEDURES PRIOR TO ACCOMPLISHING THESE ACTIONS AND CONSEQUENTLY PERFORMED WORK CONTRARY TO THE PROCEDURE.

(8601 4)

CONTRARY TO 10 CFR 50, APPENDIX B, CRITERION XVI, AFTER THE NRC RESIDENT INSPECTION STAFF IDENTIFIED THAT PRIOR TO AUGUST 14, 1985, NO OPERATOR TRAINING HAD BEEN PROVIDED ON THE USE OF THE GAMMA METRICS NEUTRON FLUX MONITOR PURSUANT TO LICENSEE COMMITMENTS, THE LICENSEE'S CORRECTIVE ACTIONS FAILED TO PRECLUDE REPETITION, IN THAT, REPLACEMENT HOT LICENSE CLASS 10 OPERATORS RECEIVING LICENSES AFTER FEBRUARY 1986, WERE NOT PROVIDED TRAINING IN THE USE OF THE GAMMA METRICS NEUTRON FLUX MONITOR. CONTRARY TO TS 6.8.1, REGULATORY GUIDE 1.33 AND AP 0190.19: (1) ON APRIL 9, 1986, PWO 6230 WAS ISSUED AS A PRIORITY CLASS "AA" WORK ORDER BUT THE MAINTENANCE TECHNICIAN DID NOT THOROUGHLY DOCUMENT HIS MAINTENANCE ACTIONS, IN THAT HE FAILED TO ORIGINATE A CALIBRATION RECORD SHEET FOR A FLOW METER HE INSTALLED. ADDITIONALLY, HE FAILED TO INDICATE ON THE PWO THAT HE HAD PERFORMED THE REQUIRED METER CALIBRATION. (2) ON MAY 3, 1986, THE PSN AUTHORIZED WORK TO START ON PRIORITY CLASS "AA" PWO 6379 WHEN THE PLANT WAS NOT IN A LOAD THREATENING CONDITION NOR IN AN ACTION STATEMENT OF TS 3.0.1. ADDITIONALLY, THE PWO WAS NOT MADE AVAILABLE FOR REVIEW BY THE QC DEPARTMENT WITHIN ONE DAY. TECHNICAL SPECIFICATION 6.8.1 REQUIRES THAT WRITTEN PROCEDURES AND ADMINISTRATIVE POLICIES BE IMPLEMENTED THAT MEET OR EXCEED THE REQUIREMENTS AND RECOMMENDATIONS OF SECTIONS 5.1 AND 5.3 OF ANSI N18.7-1972 AND APPENDIX A OF USNRC REGULATORY GUIDE 1.33. (1) CONTRARY TO THE ABOVE, ON MAY 2, 1986, AN OPERATOR FAILED TO PROPERLY IMPLEMENT OP 1004.2, IN THAT WHILE PERFORMING STEP 8.61 HE REMAINED AT PROTECTION INSTRUMENT RACK 36 AND, WHILE PERFORMING STEP 8.63, TRIPPED THE "A" REACTOR TRIP BREAKER THEREBY INADVERTENTLY TRIPPING THE UNIT 3 REACTOR. (2) CONTRARY TO THE ABOVE, ON MAY 2, 1986, AN OPERATOR FAILED TO PROPERLY IMPLEMENT OP 4304.1 ON TWO CONSECUTIVE OCCASIONS, IN THAT DURING AN INITIAL START OF THE "B" EDG, SECTION 8.7 WAS NOT IMPLEMENTED, CAUSING THE EDG TO FAIL TO START. WHILE REALIGNING THE "B" EDG FOR A SUBSEQUENT START ATTEMPT, THE OPERATOR IMPROPERLY IMPLEMENTED SECTION 8.3 IN THAT HE CLOSED THE STARTING AIR SUPPLY VALVE FOR THE "A" EDG, RENDERING THE "A" EDG TEMPORARILY INOPERABLE. (3) CONTRARY TO THE ABOVE, ON MAY 9, 1986, AN OPERATOR FAILED TO PROPERLY IMPLEMENT OP 4304.1 IN THAT, DURING A LINEUP TO START THE "B" EDG, SECTION 8.11 WAS NOT PROPERLY IMPLEMENTED BECAUSE THE OPERATOR PRESSED THE LOCAL START PUSHBUTTON INSTEAD OF THE FUEL OIL PRIME PUSHBUTTON. THIS ACTION CAUSED AN UNEXPECTED LOCAL START OF THE "B" EDG. CONTRARY TO 10 CFR, APPENDIX B, CRITERION VI, AS IMPLEMENTED BY THE FPLTQR, TQR 6.0, QP 6.6, AND AP 0103.10, AS OF MAY 13, 1986, DRAWING

Report Period JUL 1986

INSPECTION STATUS - (CONTINUED)

* TURKEY POINT 3 *

ENFORCEMENT SUMMARY

5610-T-E-4536, REVISION 0, SHEETS 1 AND 2, ENTITLED "DIESEL GENERATOR B", RESPECTIVELY, WERE NOT ACCURATE, IN THAT: (1) THE DRAWING SHEETS FAILED TO SHOW THE EXISTENCE OF A FUEL OIL SKID TANK DRAIN VALVE FOR EACH EDG; (2) THE DRAWING SHEETS SHOWED THAT VALVE 292A AND 292B, DRAINS FOR THE EDG RADIATOR COOLING SYSTEM, WERE NORMALLY CLOSED VALVES WHEN ACTUALLY THEY WERE NORMALLY OPEN VALVES; (3) NUMEROUS VALVE NUMBERS SPECIFIED ON THE DRAWING SHEETS CONFLICTED WITH THE VALVE NUMBERS UTILIZED BY APPROVED OPERATING PROCEDURE 0-OP-023; AND (4) DRAWING SHEET 1 SHOWED THE PRESENCE OF STARTING AIR FLASK DRAIN VALVE 269A, WHICH DOES NOT EXIST, AND DRAWING SHEET 2 SHOWED A STARTING AIR FLASK DRAIN PIPING CONFIGURATION WHICH WAS NOT ACCURATE. CONTRARY TO THE REQUIREMENTS OF TS 6.8.1, AS OF MAY 12, 1986, PROCEDURE 0-OP-023, EMERGENCY DIESEL GENERATOR, DID NOT ADEQUATELY ESTABLISH PROCEDURES FOR THE STARTUP AND OPERATION OF THE "A" AND "B" EDGS, IN THAT: (1) THE PROCEDURE DID NOT ADDRESS THE CONTROL OF VALVES 292 AND 293 FOR EITHER THE "A" OR "B" EDG RADIATOR COOLING WATER SYSTEM DRAINS, AND THE DRAIN VALVES FOR THE "A" OR "B" EDG FUEL OIL SKID TANK; (2) THE PROCEDURE ADDRESSED THE POSITION OF SKID TANK SOLENOID VALVE SV-3-3522 BYPASS LINE ISOLATION VALVE 70-048A, WHICH HAS NOT BEEN INSTALLED FOR THE "A" EDG; AND (3) THE PROCEDURE DID NOT ADDRESS THE CONTROL OF VALVE 269B FOR THE STARTING AIR FLASK DRAINS FOR THE "B" EDG.
(8602 4)

CONTRARY TO TS 6.8.1 AND APPENDIX A OF USNRC REGULATORY GUIDE 1.33, OPERATING PROCEDURE 14004.1, STEAM GENERATOR PROTECTION CHANNELS - PERIODIC TEST, DATED OCTOBER 25, 1985 WAS NOT PROPERLY IMPLEMENTED ON JUNE 5, 1986. WHILE PERFORMING STEPS 8.3.79 THROUGH 8.3.83, THE CHANNEL 3 STEAM HEADER PRESSURE AND STEAM BREAK PROTECTION PORTION OF THE PROCEDURE, A POWER SUPPLY WAS SUBSTITUTED FOR THE PROCEDURALLY REQUIRED TRANSMITTER SIMULATOR, AND TEST SIGNAL INPUT AND MONITORING LOCATIONS OTHER THAN THOSE SPECIFIED BY THE PROCEDURE WERE USED.
(8603 4)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

SELECT SAFETY SYSTEM OPERABILITY REVIEW IN PROGRESS.

FACILITY ITEMS (PLANS AND PROCEDURES):

PROCEDURE UPGRADE PROGRAM (PUP) IN PROGRESS.

MANAGERIAL ITEMS:

PEP IN PROGRESS.

PLANT STATUS:

NORMAL OPERATION.

LAST IE SITE INSPECTION DATE: JUNE 2-6, 1986 +

INSPECTION REPORT NO: 50-250/86-31 +

Report Period JUL 1986

R E P O R T S F R O M L I C E N S E E

* TURKEY POINT 3 *

```
=====
```

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
86-018	04/16/86	05/15/86	UNIT SHUTDOWN DUE TO EXCEEDING ADMINISTRATIVE GUIDELINES FOR INTAKE COOLING WATER SYSTEM OPERATION; CAUSE - ICW INLET TEMPERATURE INCREASED SUCH THAT 3 CCW HEAT EXCHANGERS WERE REQUIRED.
86-024	06/11/86	07/11/86	'3B' INTAKE COOLING WATER PUMP OUT-OF-SERVICE AND NOT RETURNED TO OPERABLE STATUS WITHIN TECHNICAL SPECIFICATION REQUIREMENTS; CAUSE - ADDITIONAL VERIFICATION PERFORMED.
86-025	06/12/86	07/14/86	TECHNICAL SPECIFICATION 3.6.D.1 EXCEEDED - 3A AND 3C CHARGING PUMPS OUT-OF-SERVICE, UNIT IN A 24 HOUR LCO; CAUSE - A CRACKED WELD ON THE DISCHARGE LINE DISCOVERED.
86-026	06/12/86	07/14/86	LEFT TURBINE STOP VALVE FAILED TO CLOSE COMPLETELY; CAUSE - MECHANICAL FAILURE OF THE STOP VALVE'S PILOT VALVE.
86-028	06/25/86	06/30/86	10CFR PART 21 DEFICIENCY EXISTED CONCERNING THE POTENTIAL FOR LOSS OF THE MINIMUM FLOW FOR THE SAFETY INJECTION PUMPS.

```
=====
```

1. Docket: 50-251 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/86 Outage + On-line Hrs: 744.0

3. Utility Contact: N. W. GRANT (305) 552-3675

4. Licensed Thermal Power (MWt): 2200

5. Nameplate Rating (Gross MWe): 894 X 0.85 = 760

6. Design Electrical Rating (Net MWe): 693

7. Maximum Dependable Capacity (Gross MWe): 700

8. Maximum Dependable Capacity (Net MWe): 666

9. If Changes Occur Above Since Last Report, Give Reasons: NONE

10. Power Level To Which Restricted, If Any (Net MWe):


11. Reasons for Restrictions, If Any: NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,087.0</u>	<u>113,424.0</u>
13. Hours Reactor Critical	<u>.0</u>	<u>225.4</u>	<u>77,860.8</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>166.6</u>
15. Hrs Generator On-Line	<u>.0</u>	<u>225.1</u>	<u>75,327.5</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>31.2</u>
17. Gross Therm Ener (MWH)	<u>0</u>	<u>440,167</u>	<u>159,486,896</u>
18. Gross Elec Ener (MWH)	<u>0</u>	<u>139,235</u>	<u>50,781,867</u>
19. Net Elec Ener (MWH)	<u>-3,807</u>	<u>121,220</u>	<u>48,085,477</u>
20. Unit Service Factor	<u>.0</u>	<u>4.4</u>	<u>66.4</u>
21. Unit Avail Factor	<u>.0</u>	<u>4.4</u>	<u>66.4</u>
22. Unit Cap Factor (MDC Net)	<u>.0</u>	<u>3.6</u>	<u>65.1*</u>
23. Unit Cap Factor (DER Net)	<u>.0</u>	<u>3.4</u>	<u>61.2</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.0</u>	<u>6.5</u>
25. Forced Outage Hours	<u>.0</u>	<u>.0</u>	<u>4,824.7</u>
26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):	<u>NONE</u>		

27. If Currently Shutdown Estimated Startup Date: 08/19/86

* TURKEY POINT 4 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
TURKEY POINT 4



JULY 1986

* Item calculated with a Weighted Average

Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

 * TURKEY POINT 4 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
02	01/10/86	S	744.0	C	4		RC	FUELXX	UNIT #4 REMAINED SHUTDOWN FOR REFUELING AND SCHEDULED MAINTENANCE.

 * SUMMARY *

 TURKEY POINT 4 REMAINS SHUTDOWN FOR REFUELING AND MAINTENANCE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* TURKEY POINT 4 *

FACILITY DATA

Report Period JUL 1986

FACILITY DESCRIPTION

LOCATION
STATE.....FLOR. DA
COUNTY.....DADE
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...25 MI S OF
MIAMI, FLA
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...JUNE 11, 1973
DATE ELEC ENER 1ST GENER...JUNE 21, 1973
DATE COMMERCIAL OPERATE...SEPTEMBER 7, 1973
CONDENSER COOLING METHOD...CLOSED CANAL
CONDENSER COOLING WATER...CLOSED CYCLE CANAL
ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....FLORIDA POWER & LIGHT
CORPORATE ADDRESS.....9250 WEST FLAGLER STREET P.O. BOX 013100
MIAMI, FLORIDA 33174
CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
IE RESIDENT INSPECTOR.....T. PEEBLES
LICENSING PROJ MANAGER.....D. MCDONALD
DOCKET NUMBER.....50-251
LICENSE & DATE ISSUANCE...DPR-41, APRIL 10, 1973
PUBLIC DOCUMENT ROOM.....ENVIRONMENTAL AND URBAN AFFAIRS LIBRARY
FLORIDA INTERNATIONAL UNIVERSITY
MIAMI, FLORIDA 33199

INSPECTION STATUS

INSPECTION SUMMARY

+ INSPECTION MARCH 23-28 AND APRIL 7-11 (86-18): THIS ROUTINE, ANNOUNCED INSPECTION WAS CONDUCTED ON SITE IN THE AREAS OF THE LICENSEE'S PHASE 1 AND PHASE 2 SELECTED SAFETY SYSTEM REVIEW, INSTRUMENT CALIBRATION, AND SELECTED SURVEILLANCES. ONE VIOLATION WAS IDENTIFIED FOR FOUR EXAMPLES OF FAILURE TO EITHER ESTABLISH OR IMPLEMENT PROCEDURES IN AREAS OF LIMITORQUE MAINTENANCE NORMAL VALVE LINEUPS FOR INTAKE COOLING WATER (ICW) AND COMPONENT COOLING WATER (CCW) SYSTEMS, AND MAINTENANCE OF THE EQUIPMENT OUT OF SERVICE (EODS) LOG. ANOTHER VIOLATION WAS IDENTIFIED FOR FAILURE TO PROMPTLY IDENTIFY AND CORRECT DEFICIENCIES WITH RESPECT TO CONTROL OF COMPONENT COOLING WATER (CCW) FLOW TO THE SAFETY INJECTION (SI) PUMPS. THIS ITEM IS BEING CONSIDERED FOR ESCALATED ENFORCEMENT ACTION, THEREFORE, NO NOTICE OF VIOLATION FOR THIS ITEM IS BEING ISSUED AT THIS TIME.

INSPECTION APRIL 3-6, 16-18 (86-24): THIS SPECIAL INSPECTION INVOLVED THE AREAS OF ACCELERATED REQUALIFICATION TRAINING, EMERGENCY OPERATING PROCEDURES, AND THE EMERGENCY DIESEL GENERATOR LOADING SAFETY EVALUATION AND ASSOCIATED CONFIRMATION OF ACTION LETTER. TWO VIOLATIONS AND ONE DEVIATION WERE IDENTIFIED: A. DEVIATION (250,251/86-24-04) - FAILURE TO REVISE PROCEDURES TO ASSURE THAT DIESEL GENERATOR LOADING REMAINED NO MORE THAN 2845 KW AS COMMITTED BY CONFIRMATION OF ACTION LETTER; (B) VIOLATION (250,251/86-24-06) - FAILURE TO PROVIDE ADEQUATE CORRECTIVE ACTIONS TO PRECLUDE REPETITION OF TRAINING DEFICIENCIES ON THE GAMMA METRICS NEUTRON FLUX MONITOR; AND (C) VIOLATION (250,251/86-24-08) - FAILURE TO PERFORM 10CFR 50.59 EVALUATION OF EDG LOADS BEYOND THOSE ANALYZED IN JPE-L-86-59, REVISION 1. NO NOTICE OF VIOLATION FOR THIS ITEM WILL BE INCLUDED IN THE REPORT AS THIS MATTER IS BEING CONSIDERED FOR ENFORCEMENT ACTION AS PART OF A SEPARATE REPORT.

INSPECTION APRIL 28 - MAY 2 (86-29): THIS SPECIAL, ANNOUNCED INSPECTION WAS PERFORMED AT THE LICENSEE'S ENGINEERING OFFICE AND THE PLANT SITE TO REVIEW THE CONTROL AND DISTRIBUTION OF EMERGENCY ELECTRICAL LOADS WHICH ARE CONNECTED TO THE EMERGENCY DIESEL

Report Period JUL 1986

INSPECTION STATUS - (CONTINUED)

* TURKEY POINT 4 *

INSPECTION SUMMARY

GENERATORS (EDG) IN THE EVENT OF A DESIGN BASE ACCIDENT (LOCA). THIS REPORT INCLUDES THE EVALUATION MADE AS THE RESULT OF A MEETING HELD IN REGION II OFFICES ON MAY 20, 1986 BETWEEN FP&L PERSONNEL AND NRC. ONE UNRESOLVED ITEM WAS IDENTIFIED - EMERGENCY DIESEL GENERATOR LOAD CONTROL.

INSPECTION MAY 12 - JUNE 9 (86-30): THIS ROUTINE, UNANNOUNCED INSPECTION ENTAILED DIRECT INSPECTION AT THE SITE, INCLUDING BACKSHIFT INSPECTION, IN THE AREAS OF LICENSEE ACTION ON PREVIOUS INSPECTION FINDINGS, ANNUAL AND MONTHLY SURVEILLANCE OBSERVATIONS, MAINTENANCE OBSERVATIONS AND REVIEWS, OPERATIONAL SAFETY VERIFICATION, ENGINEERED SAFETY FEATURES WALKDOWN, INDEPENDENT INSPECTION, AND FOLLOW-UP OF PLANT EVENTS. VIOLATION - FAILURE TO MEET THE REQUIREMENTS OF TECHNICAL SPECIFICATION (TS) 6.8.1.

INSPECTION JUNE 2-6 (86-31): THIS ROUTINE, UNANNOUNCED INSPECTION INVOLVED THE AREAS OF LICENSEE ACTIONS ON PREVIOUS ENFORCEMENT MATTERS (92701B AND 92702B), HOUSEKEEPING (54834B), MATERIAL IDENTIFICATION AND CONTROL (42902B), MATERIAL CONTROL (42940B), GULFALLOY SUPPLIED MATERIALS (92705B), INSERVICE TESTING OF PUMPS AND VALVES (61700 AND 61726), IE BULLETINS (IEBS) (92703B), FOLLOWUP ON IE NOTICES (IEN) (92717) AND INSPECTOR FOLLOWUP ITEMS. ONE VIOLATION WAS IDENTIFIED - 50-250/86-31-04: "FAILURE TO LOCK AND VERIFY THE LOCKED CONDITION OF VALVE 3-891A DURING IST". ONE DEVIATION WAS IDENTIFIED 50-250, 251/86-31-01: "FAILURE TO SUBMIT ISI RELIEF REQUEST AS COMMITTED".

ENFORCEMENT SUMMARY

CONTRARY TO TS 6.8.1 AND APPENDIX A OF USNRC REGULATORY GUIDE 1.33, THE LICENSEE APPROVED A NEW PROCEDURE FOR MOV MAINTENANCE, O-CME-102.1, BUT IT HAD NOT BEEN ISSUED FOR USE YET. THIS PROCEDURE ALSO INCLUDED THE SAME TORQUE SWITCH SETTINGS AS THE TOP. THE LICENSEE WAS INFORMED THAT TOP 166 AND O-CME-102.1 WERE INADEQUATE, IN THAT THEY SPECIFY THE INCORRECT TORQUE SWITCH SETTINGS RECOMMENDED BY LIMITORQUE. THE INSPECTOR CONSIDERS THAT THE LICENSEE SET MOV5-4-750/751 TORQUE SWITCHES TO TECHNICALLY ACCEPTABLE VALUE BUT DID NOT REVISE THE PROCEDURES PRIOR TO ACCOMPLISHING THESE ACTIONS AND CONSEQUENTLY PERFORMED WORK CONTRARY TO THE PROCEDURE.

(8601 4)

CONTRARY TO 10 CFR 50, APPENDIX B, CRITERION XVI, AFTER THE NRC RESIDENT INSPECTION STAFF IDENTIFIED THAT PRIOR TO AUGUST 14, 1985, NO OPERATOR TRAINING HAD BEEN PROVIDED ON THE USE OF THE GAMMA METRICS NEUTRON FLUX MONITOR PURSUANT TO LICENSEE COMMITMENTS, THE LICENSEE'S CORRECTIVE ACTIONS FAILED TO PRECLUDE REPETITION, IN THAT, REPLACEMENT HOT LICENSE CLASS 10 OPERATORS RECEIVING LICENSES AFTER FEBRUARY 1986, WERE NOT PROVIDED TRAINING IN THE USE OF THE GAMMA METRICS NEUTRON FLUX MONITOR. TECHNICAL SPECIFICATION 6.8.1 REQUIRES THAT WRITTEN PROCEDURES AND ADMINISTRATIVE POLICIES BE IMPLEMENTED THAT MEET OR EXCEED THE REQUIREMENTS AND RECOMMENDATIONS OF SECTIONS 5.1 AND 5.3 OF ANSI N18.7-1972 AND APPENDIX A OF USNRC REGULATORY GUIDE 1.33. (1) CONTRARY TO THE ABOVE, ON MAY 2, 1986, AN OPERATOR FAILED TO PROPERLY IMPLEMENT OP 1004.2, IN THAT WHILE PERFORMING STEP 8.61 HE REMAINED AT PROTECTION INSTRUMENT RACK 36 AND, WHILE PERFORMING STEP 8.63, TRIPPED THE "A" REACTOR TRIP BREAKER THEREBY INADVERTENTLY TRIPPING THE UNIT 3 REACTOR. (2) CONTRARY TO THE ABOVE, ON MAY 2, 1986, AN OPERATOR FAILED TO PROPERLY IMPLEMENT OP 4304.1 ON TWO CONSECUTIVE OCCASIONS, IN THAT DURING AN INITIAL START OF THE "B" EDG, SECTION 8.7 WAS NOT IMPLEMENTED, CAUSING THE EDG TO FAIL TO START. WHILE REALIGNING THE "B" EDG FOR A SUBSEQUENT START ATTEMPT, THE OPERATOR IMPROPERLY IMPLEMENTED SECTION 8.3 IN THAT HE CLOSED THE STARTING AIR SUPPLY VALVE FOR THE "A" EDG, RENDERING THE "A" EDG TEMPORARILY INOPERABLE. (3) CONTRARY TO THE ABOVE, ON MAY 9, 1986, AN OPERATOR FAILED TO PROPERLY IMPLEMENT OP 4304.1 IN THAT, DURING A LINEUP TO START THE "B" EDG, SECTION 8.11 WAS NOT PROPERLY IMPLEMENTED BECAUSE THE OPERATOR PRESSED THE LOCAL START PUSHBUTTON INSTEAD OF THE FUEL OIL PRIME PUSHBUTTON. THIS ACTION CAUSED AN UNEXPECTED LOCAL START OF THE "B" EDG. CONTRARY TO 10 CFR, APPENDIX B, CRITERION VI, AS IMPLEMENTED BY THE FPLTQR, TQR 6.0, QP 6.6, AND AP 0103.10, AS OF MAY 13, 1986, DRAWING 5610-T-E-4536, REVISION 0, SHEETS 1 AND 2, ENTITLED "DIESEL GENERATOR B", RESPECTIVELY, WERE NOT ACCURATE, IN THAT: (1) THE DRAWING SHEETS FAILED TO SHOW THE EXISTENCE OF A FUEL OIL SKID TANK DRAIN VALVE FOR EACH EDG; (2) THE DRAWING SHEETS SHOWED THAT VALVE 292A AND 292B, DRAINS FOR THE EDG RADIATOR COOLING SYSTEM, WERE NORMALLY CLOSED VALVES WHEN ACTUALLY THEY WERE NORMALLY OPEN VALVES; (3) NUMEROUS VALVE NUMBERS SPECIFIED ON THE DRAWING SHEETS CONFLICTED WITH THE VALVE NUMBERS UTILIZED BY APPROVED OPERATING PROCEDURE O-OP-023; AND (4) DRAWING SHEET 1 SHOWED THE PRESENCE OF STARTING AIR FLASK DRAIN VALVE 269A, WHICH DOES NOT EXIST, AND DRAWING SHEET 2 SHOWED A

Report Period JUL 1986

I N S P E C T I O N S T A T U S - (CONTINUED)

* TURKEY POINT 4 *

ENFORCEMENT SUMMARY

STARTING AIR FLASK DRAIN PIPING CONFIGURATION WHICH WAS NOT ACCURATE. CONTRARY TO THE REQUIREMENTS OF TS 6.8.1, AS OF MAY 12, 1986, PROCEDURE 0-OP-023, EMERGENCY DIESEL GENERATOR, DID NOT ADEQUATELY ESTABLISH PROCEDURES FOR THE STARTUP AND OPERATION OF THE "A" AND "B" EDGS, IN THAT: (1) THE PROCEDURE DID NOT ADDRESS THE CONTROL OF VALVES 292 AND 293 FOR EITHER THE "A" OR "B" EDG RADIATOR COOLING WATER SYSTEM DRAINS, AND THE DRAIN VALVES FOR THE "A" OR "B" EDG FUEL OIL SKID TANK; (2) THE PROCEDURE ADDRESSED THE POSITION OF SKID TANK SOLENOID VALVE SV-3-3522 BYPASS LINE ISOLATION VALVE 70-048A, WHICH HAS NOT BEEN INSTALLED FOR THE "A" EDG; AND (3) THE PROCEDURE DID NOT ADDRESS THE CONTROL OF VALVE 269B FOR THE STARTING AIR FLASK DRAINS FOR THE "B" EDG.
(8602 4)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

SELECT SAFETY SYSTEM OPERABILITY REVIEW IN PROGRESS.

FACILITY ITEMS (PLANS AND PROCEDURES):

PROCEDURE UPGRADE PROGRAM (PUP) IN PROGRESS.

MANAGERIAL ITEMS:

PEP IN PROGRESS.

PLANT STATUS:

REFUELING OUTAGE. PLANT IN COLD SHUTDOWN.

LAST IE SITE INSPECTION DATE: JUNE 2-6, 1986 +

INSPECTION REPORT NO: 50-251/86-31 +

R E P O R T S F R O M L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
86-011	06/13/86	07/14/86	PROCESS RADIATION MONITOR R-11 SPIKED HIGH, ACTUATING THE CONTAINMENT AND CONTROL ROOM VENTILATION ISOLATION LOGIC; CAUSE - KEYING OF A FM RADIO IN THE CONTROL ROOM.

=====

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-271 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/86 Outage + On-line Hrs: 744.0

3. Utility Contact: G. A. WALLIN (802) 257-7711 X2272

4. Licensed Thermal Power (MWt): 1593

5. Nameplate Rating (Gross MWe): 626 X 0.9 = 563

6. Design Electrical Rating (Net MWe): 514

7. Maximum Dependable Capacity (Gross MWe): 535

8. Maximum Dependable Capacity (Net MWe): 504

9. If Changes Occur Above Since Last Report, Give Reasons: NONE


10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,087.0</u>	<u>121,489.8</u>
13. Hours Reactor Critical	<u>714.1</u>	<u>714.5</u>	<u>93,825.4</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>648.6</u>	<u>648.6</u>	<u>91,366.8</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>915,088</u>	<u>915,088</u>	<u>133,024,706</u>
18. Gross Elec Ener (MWH)	<u>290,965</u>	<u>290,965</u>	<u>44,246,867</u>
19. Net Elec Ener (MWH)	<u>271,725</u>	<u>271,725</u>	<u>41,971,975</u>
20. Unit Service Factor	<u>87.2</u>	<u>12.8</u>	<u>75.2</u>
21. Unit Avail Factor	<u>87.2</u>	<u>12.8</u>	<u>75.2</u>
22. Unit Cap Factor (MDC Net)	<u>72.5</u>	<u>10.6</u>	<u>68.5</u>
23. Unit Cap Factor (DER Net)	<u>71.1</u>	<u>10.4</u>	<u>67.2</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.0</u>	<u>6.9</u>
25. Forced Outage Hours	<u>.0</u>	<u>.0</u>	<u>5,466.6</u>
26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration): <u>NONE</u>			
27. If Currently Shutdown Estimated Startup Date: <u>N/A</u>			

* V E R M O N T Y A N K E E 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
VERMONT YANKEE 1



JULY 1986

Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

* VERMONT YANKEE 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
85-14	07/01/86	S	63.0	C	1				1985/1986 REFUELING/MAINTENANCE/RECIRC PIPE REPLACEMENT OUTAGE.
86-01	07/03/86	S	32.4	B	1				TURBINE OVERSPEED TESTING.
86-02	07/10/86	S	0.0	B	5		CB	PUMPXX	POWER REDUCTION FOR RECIRC PIPING STABILITY TESTING.
86-03	07/13/86	S	0.0	B	5		CB	PUMPXX	POWER REDUCTION FOR RECIRC PIPING STABILITY TESTING.
86-03-	07/13/86	S	0.0	B	5		RB	CONROD	POWER REDUCTION FOR TURBINE AND CONTROL ROD SURVEILLANCE.

* SUMMARY *

VERMONT YANKEE EXPERIENCED 2 OUTAGES AND 3 POWER REDUCTIONS IN JULY AS DISCUSSED ABOVE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* VERMONT YANKEE 1 *

FACILITY DATA

Report Period JUL 1986

FACILITY DESCRIPTION

LOCATION
STATE.....VERMONT
COUNTY.....WINDHAM
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...5 MI S OF
BRATTLEBORO, VT
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...MARCH 24, 1972
DATE ELEC ENER 1ST GENER...SEPTEMBER 20, 1972
DATE COMMERCIAL OPERATE...NOVEMBER 30, 1972
CONDENSER COOLING METHOD...COOLING TOWER
CONDENSER COOLING WATER...CONNECTICUT RIVER
ELECTRIC RELIABILITY
COUNCIL.....NORTHEAST POWER
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....VERMONT YANKEE NUCLEAR POWER
CORPORATE ADDRESS.....RD #5, BOX 169, FERRY ROAD
BRATTLEBORO, VERMONT 05301
CONTRACTOR
ARCHITECT/ENGINEER.....EBASCO
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....EBASCO
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I
IE RESIDENT INSPECTOR.....W. RAYMOND
LICENSING PROJ MANAGER.....V. ROONEY
DOCKET NUMBER.....50-271
LICENSE & DATE ISSUANCE...DPR-28, FEBRUARY 28, 1973
PUBLIC DOCUMENT ROOM.....BROOKS MEMORIAL LIBRARY
224 MAIN STREET
BRATTLEBORO, VERMONT 05301

INSPECTION STATUS

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

Report Period JUL 1986

INSPECTION STATUS - (CONTINUED)

* VERMONT YANKEE 1 *

OTHER ITEMS

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

REPORTS FROM LICENSEE

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT

NO INPUT PROVIDED.			
=====			

1. Docket: 50-397 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/86 Outage + On-line Hrs: 744.0

3. Utility Contact: LEONARD HUTCHISON (509) 377-2501 X2486

4. Licensed Thermal Power (MWt): 3323

5. Nameplate Rating (Gross MWe): 1201

6. Design Electrical Rating (Net MWe): 1100

7. Maximum Dependable Capacity (Gross MWe): 1140

8. Maximum Dependable Capacity (Net MWe): 1095

9. If Changes Occur Above Since Last Report, Give Reasons:

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,087.0</u>	<u>14,287.2</u>
13. Hours Reactor Critical	<u>717.4</u>	<u>2,875.0</u>	<u>10,191.2</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>340.4</u>	<u>340.4</u>
15. Hrs Generator On-Line	<u>729.2</u>	<u>2,656.9</u>	<u>9,683.4</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>381.7</u>	<u>381.7</u>
17. Gross Therm Ener (MWH)	<u>2,078,400</u>	<u>6,318,330</u>	<u>23,882,610</u>
18. Gross Elec Ener (MWH)	<u>696,850</u>	<u>2,086,620</u>	<u>7,909,870</u>
19. Net Elec Ener (MWH)	<u>667,000</u>	<u>1,998,390</u>	<u>7,585,163</u>
20. Unit Service Factor	<u>95.3</u>	<u>52.2</u>	<u>67.8</u>
21. Unit Avail Factor	<u>95.3</u>	<u>59.7</u>	<u>70.4</u>
22. Unit Cap Factor (MDC Net)	<u>81.9</u>	<u>35.9</u>	<u>48.5</u>
23. Unit Cap Factor (DER Net)	<u>81.5</u>	<u>35.7</u>	<u>48.3</u>
24. Unit Forced Outage Rate	<u>4.7</u>	<u>3.6</u>	<u>8.4</u>
25. Forced Outage Hours	<u>34.8</u>	<u>100.0</u>	<u>885.0</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


NONE

27. If Currently Shutdown Estimated Startup Date: N/A

 * WASHINGTON NUCLEAR 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

WASHINGTON NUCLEAR 2



JULY 1986

Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

 * WASHINGTON NUCLEAR 2 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
86-08	07/10/86	F	17.1	G	3	86-023	EC	INSTRU	REACTOR SCRAMMED AT 100% POWER ON HIGH APRM NEUTRON FLUX, WHEN POWER TO MICROWAVE TELEMETRY EQUIPMENT WAS MOMENTARILY INTERRUPTED WHILE TROUBLE SHOOTING A GROUND ON 125VDC DISTRIBUTION SYSTEM. AN ENGINEERING EVALUATION WILL BE MADE TO PROPERLY IDENTIFY CRITICAL POWER SUPPLIES.
86-09	07/25/86	F	17.7	A	3	86-025	HB	VALVEX	REACTOR SCRAMMED AT 72% POWER ON RPV HIGH PRESSURE, WHILE PERFORMING WEEKLY TURBINE VALVE TESTS. A BROKEN PIN TO LINKAGE ON A GOVERNOR VALVE CAUSED FALSE VALVE POSITION SIGNAL AND RESULTED IN FAILURE OF DEH SYSTEM TO CONTROL PRESSURE. THE PIN WAS REPLACED AND PLANT RETURNED TO SERVICE.

 * SUMMARY *

 WNP-2 EXPERIENCED 2 SHUTDOWNS IN JULY AS DISCUSSED ABOVE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* WASHINGTON NUCLEAR 2 *

F A C I L I T Y D A T A

Report Period JUL 1986

FACILITY DESCRIPTION

LOCATION
STATE.....WASHINGTON
COUNTY.....BENTON
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...12 MI. NW OF
RICHLAND, WASH.
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...JANUARY 19, 1984
DATE ELEC ENER 1ST GENER...MAY 27, 1984
DATE COMMERCIAL OPERATE...DECEMBER 13, 1984
CONDENSER COOLING METHOD...COOLING TOWERS
CONDENSER COOLING WATER...MECHANICAL TOWERS
ELECTRIC RELIABILITY
COUNCIL.....WESTERN SYSTEMS
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....WASHINGTON PUBLIC POWER SUPPLY SYSTEM
CORPORATE ADDRESS.....P.O. BOX 968
RICHLAND, WASHINGTON 99352
CONTRACTOR
ARCHITECT/ENGINEER.....BURNS & ROE
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....V
IE RESIDENT INSPECTOR.....R. DODDS
LICENSING PROJ MANAGER.....J. BRADFUTE
DOCKET NUMBER.....50-397
LICENSE & DATE ISSUANCE...NPF-21, APRIL 13, 1984
PUBLIC DOCUMENT ROOM.....RICHLAND PUBLIC LIBRARY
SWIFT AND NORTHGATE STREETS
RICHLAND, WA 99352

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION ON JUNE 16-27, 1986 (REPORT NO. 50-397/86-11) AREAS INSPECTED: ANNUAL ANNOUNCED TEAM INSPECTION OF THE WNP-2 PLANT, FOCUSED ON MANAGEMENT CONTROLS (PROCEDURES, POLICIES, ADMINISTRATIVE ORDERS, ETC.) AND THE INVOLVEMENT OF MANAGEMENT IN THE IMPLEMENTATION OF THESE CONTROLS AS THEY APPLIED TO THE OPERATION AND MAINTENANCE OF WNP-2. THE FOLLOWING ACTIVITIES OF THE LICENSEE WERE EXAMINED: 1) OPERATOR RECOVERY ACTIONS; 2) QUALITY ASSURANCE PROGRAM; 3) MEASURING AND TEST EQUIPMENT; 4) TECHNICAL SPECIFICATION SURVEILLANCES AND TESTS; 5) CORRECTIVE AND PREVENTIVE MAINTENANCE PROGRAMS; 6) PLANT PROCEDURES; 7) PLANT MODIFICATIONS; 8) QUALITY ASSURANCE SURVEILLANCE; 9) SYSTEM WALKDOWN. TO THE MAXIMUM EXTENT FEASIBLE THE EFFECTIVENESS OF THESE ACTIVITIES WERE ASSESSED AS THEY APPLY TO THE FOLLOWING PLANT PHYSICAL SYSTEMS: 1) RESIDUAL HEAT REMOVAL SYSTEM (RHR); 2) STANDBY SERVICE WATER (SSW); 3) EMERGENCY POWER.

RESULTS: IN THE AREAS INSPECTED, SEVERAL VIOLATIONS OF NRC REQUIREMENTS WERE IDENTIFIED, SOME WITH MULTIPLE EXAMPLES. ENFORCEMENT ACTION AS A RESULT OF THIS INSPECTION WILL BE THE SUBJECT OF SEPARATE CORRESPONDENCE.

+ INSPECTION ON APRIL 28 - MAY 2, 1986 (REPORT NO. 50-397/86-12) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

+ INSPECTION ON JUNE 9 - AUGUST 7, 1986 (REPORT NO. 50-397/86-19) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

+ INSPECTION ON JUNE 1 - JULY 12, 1986 (REPORT NO. 50-397/86-21) AREAS INSPECTED: ROUTINE INSPECTION BY THE RESIDENT INSPECTORS OF AND A REGIONALLY BASED INSPECTOR OF CONTROL ROOM OPERATIONS, ENGINEERED SAFETY FEATURE (ESF) STATUS, SURVEILLANCE PROGRAM, MAINTENANCE PROGRAM, LICENSEE EVENT REPORTS, SPECIAL INSPECTION TOPICS, AND LICENSEE ACTION ON PREVIOUS INSPECTION FINDINGS.

Report Period JUL 1986

I N S P E C T I O N S T A T U S - (CONTINUED)

* WASHINGTON NUCLEAR 2 *

INSPECTION SUMMARY

DURING THIS INSPECTION, VARIOUS INSPECTION PROCEDURES WERE UTILIZED.

RESULTS: TWO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED PERTAINING TO RADIATION CONTROLS AND TOOL AND EQUIPMENT ACCOUNTABILITY DURING THE REPAIR OF AN RHR SYSTEM VALVE.

+ INSPECTION ON JUNE 10 - JULY 10, 1986 (REPORT NO. 50-397/86-22) AREAS INSPECTED: UNANNOUNCED INSPECTION BY A REGIONALLY BASED INSPECTOR OF THE IMPLEMENTATION OF THE WNP-2 NUCLEAR POWER PLANT FIRE PROTECTION PROGRAM, QUALITY ASSURANCE PROGRAM, AND OTHER ITEMS IDENTIFIED DURING THE OUTAGE. DURING THIS INSPECTION, VARIOUS INSPECTION PROCEDURES WERE UTILIZED.

RESULTS: OF THE AREAS EXAMINED, VIOLATIONS WERE IDENTIFIED IN THE FIRE PROTECTION AREA.

+ INSPECTION ON JUNE 25-27, 1986 (REPORT NO. 50-397/86-23) AREAS INSPECTED: ROUTINE, UNANNOUNCED INSPECTION BY A REGIONALLY BASED INSPECTOR OF THE LICENSEE'S INTERNAL EXPOSURE CONTROL PROGRAM; RADIATION PROTECTION, CHEMISTRY, RADWASTE, AND ENVIRONMENTAL MONITORING ORGANIZATION, STAFFING, QUALIFICATIONS, AND TRAINING; FACILITY TOUR, AND A REVIEW OF THE RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM ANNUAL REPORT. DURING THIS INSPECTION, VARIOUS INSPECTION PROCEDURES WERE UTILIZED.

RESULTS: OF THE ELEVEN AREAS EXAMINED, ONE VIOLATION WAS IDENTIFIED IN ONE AREA: TECHNICAL SPECIFICATIONS, SECTION 6.11.1, ADHERENCE TO HEALTH PHYSICS PROCEDURES.

+ INSPECTION ON AUGUST 4-8, 1986 (REPORT NO. 50-397/86-24) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

+ INSPECTION ON JULY 14 - AUGUST 15, 1986 (REPORT NO. 50-397/86-25) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

THE PLANT HAS RESUMED OPERATION AT FULL POWER.

LAST IE SITE INSPECTION DATE: 07/14-08/15/86+

Report Period JUL 1986

I N S P E C T I O N S T A T U S - (CONTINUED)

* WASHINGTON NUCLEAR 2 *

INSPECTION REPORT NO: 50-397/86-25+

R E P O R T S F R O M L I C E N S E E

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
86-11-L0	05-09-86	06-05-86	MOMENTARY LOSS OF RPS 'B' POWER RESULTS IN A HALF SCRAM AND NUCLEAR STEAM SUPPLY SHUTOFF SYSTEM ACTUATION
86-12-L0	05-12-86	06-11-86	RPS ACTUATION DURING RECIRCULATION PUMP START
86-13-L0	05-14-86	06-05-86	SPURIOUS NOISE IN NEUTRON MONITOR CHANNEL DUE TO WELDING RESULTS IN A SCRAM
86-14-L0	05-23-86	06-20-86	TYPE 'C' CONT LRT NOT PERFORMED ON TWO VALVES

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-382 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/86 Outage + On-line Hrs: 744.0

3. Utility Contact: GEORGE MILLER (504) 467-8211

4. Licensed Thermal Power (MWt): 3390

5. Nameplate Rating (Gross MWe): 1153

6. Design Electrical Rating (Net MWe): 1104

7. Maximum Dependable Capacity (Gross MWe): 1120

8. Maximum Dependable Capacity (Net MWe): 1104

9. If Changes Occur Above Since Last Report, Give Reasons:
MAXIMUM DEPENDABLE CAPACITIES HAVE BEEN REVISED.


10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,087.0</u>	<u>7,464.0</u>
13. Hours Reactor Critical	<u>527.4</u>	<u>4,249.3</u>	<u>6,118.0</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>511.9</u>	<u>4,196.8</u>	<u>5,998.6</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,646,157</u>	<u>13,809,476</u>	<u>19,451,915</u>
18. Gross Elec Ener (MWH)	<u>544,650</u>	<u>4,661,540</u>	<u>6,559,390</u>
19. Net Elec Ener (MWH)	<u>513,837</u>	<u>4,441,617</u>	<u>6,246,770</u>
20. Unit Service Factor	<u>68.8</u>	<u>82.5</u>	<u>80.4</u>
21. Unit Avail Factor	<u>68.8</u>	<u>82.5</u>	<u>80.4</u>
22. Unit Cap Factor (MDC Net)	<u>62.6</u>	<u>79.4</u>	<u>75.8</u>
23. Unit Cap Factor (DER Net)	<u>62.6</u>	<u>79.1</u>	<u>75.8</u>
24. Unit Forced Outage Rate	<u>31.2</u>	<u>7.4</u>	<u>13.0</u>
25. Forced Outage Hours	<u>232.1</u>	<u>333.7</u>	<u>898.5</u>
26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration): <u>REFUELING/MAINT.: NOVEMBER - DECEMBER 1986, 8 WEEKS.</u>			
27. If Currently Shutdown Estimated Startup Date: <u>N/A</u>			

 * WATERFORD 3 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
 WATERFORD 3



JULY 1986

Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

* WATERFORD 3 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
86-10	06/30/86	F	16.8	A	4	86-013	JC	CON	AT 100% POWER, A REACTOR TRIP OCCURRED ON LOW DNB&R DUE TO A POSITION INDICATION FAILURE FOR CONTROL ELEMENT ASSEMBLY #35.
86-11	07/08/86	F	215.3	A	1		AB	SEAL	UNIT WAS MANUALLY SHUT DOWN TO REPLACE REACTOR COOLANT PUMP 2B SEAL.

***** WATERFORD 3 HAD 2 OUTAGES IN JULY AS DISCUSSED ABOVE.

* SUMMARY *

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* WATERFORD 3 *

FACILITY DATA

Report Period JUL 1986

FACILITY DESCRIPTION

LOCATION
STATE.....LOUISIANA
COUNTY.....ST CHARLES
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...20 MI W OF
NEW ORLEANS, LA
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...MARCH 4, 1985
DATE ELEC ENER 1ST GENER...MARCH 18, 1985
DATE COMMERCIAL OPERATE...SEPTEMBER 24, 1985
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...MISSISSIPPI RIVER
ELECTRIC RELIABILITY
COUNCIL.....SOUTHWEST POWER POOL

UTILITY / CONTRACTOR INFORMATION

UTILITY
LICENSEE.....LOUISIANA POWER & LIGHT
CORPORATE ADDRESS.....142 DELARONDE STREET
NEW ORLEANS, LOUISIANA 70174
CONTRACTOR
ARCHITECT/ENGINEER.....EBASCO
NUC STEAM SYS SUPPLIER...COMBUSTION ENGINEERING
CONSTRUCTOR.....EBASCO
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....IV
IE RESIDENT INSPECTOR.....J. LUEHMAN
LICENSING PROJ MANAGER.....J. WILSON
DOCKET NUMBER.....50-382
LICENSE & DATE ISSUANCE...NPF-38, MARCH 16, 1985
PUBLIC DOCUMENT ROOM.....HEAD LIBRARIAN
LOUISIANA COLLECTION
EARL K. LONG LIBRARY
UNIVERSITY OF NEW ORLEANS
LAKEFRONT DRIVE
NEW ORLEANS, LOUISIANA 70148

INSPECTION STATUS

INSPECTION SUMMARY

INSPECTION CONDUCTED APRIL 21-25, 1986 (86-10) ROUTINE, UNANNOUNCED INSPECTION OF SECURITY ORGANIZATION MANAGEMENT, SECURITY PROGRAM AUDIT, RECORDS AND REPORTS, MANAGEMENT EFFECTIVENESS-SECURITY, AND SECURITY PLAN CHANGES. WITHIN THE AREAS INSPECTED ONE APPARENT VIOLATION WAS IDENTIFIED.

INSPECTION CONDUCTED MAY 1-30, 1986 (86-11) ROUTINE, UNANNOUNCED INSPECTION OF PLANT STATUS; LICENSEE EVENT REPORT (LER) FOLLOWUP; MONTHLY SURVEILLANCE; ROUTINE INSPECTION; LICENSE CONDITIONS; LICENSEE'S RESPONSE TO SELECTED SAFETY ISSUES; LICENSEE FOLLOWUP ON PREVIOUSLY IDENTIFIED ITEMS; REPORT OF FACILITY CHANGES, TESTS AND CALIBRATION CONTROL PROGRAM; AND ESF SYSTEM WALKDOWN. WITHIN THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED. ONE RESOLVED ITEM WAS IDENTIFIED.

INSPECTION CONDUCTED JUNE 1-30, 1986 (86-13) ROUTINE, UNANNOUNCED INSPECTION OF: PLANT STATUS, LICENSEE EVENT REPORT (LER) FOLLOWUP, MONTHLY SURVEILLANCE, ROUTINE INSPECTION, LICENSEE FOLLOWUP ON PREVIOUSLY IDENTIFIED ITEMS, MONTHLY MAINTENANCE, POTENTIAL GENERIC PROBLEMS, LICENSE CONDITIONS, AND IE BULLETINS. WITHIN THE AREAS INSPECTED, TWO VIOLATIONS AND ONE DEVIATION WERE IDENTIFIED.

Report Period JUL 1986

I N S P E C T I O N S T A T U S - (CONTINUED)

* WATERFORD 3 *

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

LAST IE SITE INSPECTION DATE: JUNE 1-30, 1986

INSPECTION REPORT NO: 50-382/86-13

R E P O R T S F R O M L I C E N S E E

=====			
NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT

86-008 (LER)	5/04/86	5/29/86	OPERATOR ERROR DURING SURVEILLANCE TESTING RESULTED IN INADVERTENT ACTUATION OF EMERGENCY FEEDWATER SYSTEM
86-009 (LER)	5/09/86	6/09/86	REED SWITCH FAILURE RESULTS IN REACTOR TRIP ON LOW DEPARTURE FROM NUCLEATE BOILING RATIO
86-010 (LER)	6/02/86	7/01/86	IMPROPERLY FIELD SCHEDULING CARDS RESULTS IN EXCEEDING THE SURVEILLANCE FREQUENCY FOR SECONDARY ACTIVITY SAMPLE
86-011	6/05/86	7/07/86	WALKDOWN AS A RESULT OF PART 21 REPORT IDENTIFIED TWO MISSING INTERNAL PENETRATION SEALS IN ADDITION TO SEVERAL DEFICIENT SEAL ARRANGEMENTS
86-012	6/25/86	7/22/86	LACK OF INTER-DEPARTMENTAL COMMUNICATIONS RESULTED IN DEFICIENT FIRE DOOR SURVEILLANCE
=====			

1. Docket: 50-482 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/86 Outage + On-line Hrs: 744.0

3. Utility Contact: M. WILLIAMS (316) 364-8831

4. Licensed Thermal Power (MWt): 3411

5. Nameplate Rating (Gross MWe): 1250

6. Design Electrical Rating (Net MWe): 1170

7. Maximum Dependable Capacity (Gross MWe): 1170

8. Maximum Dependable Capacity (Net MWe): 1128

9. If Changes Occur Above Since Last Report, Give Reasons:

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,087.0</u>	<u>7,966.7</u>
13. Hours Reactor Critical	<u>683.7</u>	<u>4,389.6</u>	<u>7,179.9</u>
14. Rx Reserve Shtdwn Hrs	<u>51.1</u>	<u>92.5</u>	<u>171.2</u>
15. Hrs Generator On-Line	<u>664.8</u>	<u>4,352.4</u>	<u>7,124.0</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>19.0</u>
17. Gross Therm Ener (MWH)	<u>2,210,358</u>	<u>14,154,316</u>	<u>23,029,249</u>
18. Gross Elec Ener (MWH)	<u>762,270</u>	<u>4,946,805</u>	<u>8,017,895</u>
19. Net Elec Ener (MWH)	<u>728,383</u>	<u>4,727,486</u>	<u>7,669,586</u>
20. Unit Service Factor	<u>89.4</u>	<u>85.6</u>	<u>89.4</u>
21. Unit Avail Factor	<u>89.4</u>	<u>85.6</u>	<u>89.7</u>
22. Unit Cap Factor (MDC Net)	<u>86.8</u>	<u>82.4</u>	<u>55.0*</u>
23. Unit Cap Factor (DER Net)	<u>83.7</u>	<u>79.4</u>	<u>82.3</u>
24. Unit Forced Outage Rate	<u>1.9</u>	<u>5.8</u>	<u>5.0</u>
25. Forced Outage Hours	<u>12.7</u>	<u>269.1</u>	<u>377.2</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


REFUELING: 10/09/86 - 55 DAYS.

27. If Currently Shutdown Estimated Startup Date: N/A

* WOLF CREEK 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

WOLF CREEK 1



JULY 1986

* Item calculated with a Weighted Average

PAGE 2-416

Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

* WOLF CREEK 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
7	07/01/86	F	6.0	B	3				EXTENSION ON JUNE UNIT TRIP CAUSED BY LOW-LOW CONDENSER HOTWELL LEVEL SIGNAL DURING TESTING.
8	07/01/86	F	6.7	G	3				UNIT TRIP, REACTOR TRIP DUE TO LOW-LOW STEAM GENERATOR LEVEL IN MANUAL CONTROL.
9	07/24/86	S	66.5	B	3				UNIT TRIP, REACTOR TRIP DUE TO LOW-LOW STEAM GENERATOR LEVEL IN MANUAL CONTROL WHILE TAKING UNIT OFF-LINE TO REPAIR A STATOR COOLING WATER LEAK.

* SUMMARY *

WOLF CREEK INCURRED 3 SHUTDOWNS IN JULY AS DISCUSSED ABOVE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* WOLF CREEK 1 *

FACILITY DATA

Report Period JUL 1986

FACILITY DESCRIPTION

UTILITY & CONTRACTOR INFORMATION

LOCATION
STATE.....KANSAS
COUNTY.....COFFEY
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...3.5 MI NE OF
BURLINGTON, KAN
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...MAY 22, 1985
DATE ELEC ENER 1ST GENER...JUNE 12, 1985
DATE COMMERCIAL OPERATE...SEPTEMBER 3, 1985
CONDENSER COOLING METHOD...COOLING LAKE
CONDENSER COOLING WATER...COOLING LAKE
ELECTRIC RELIABILITY
COUNCIL.....SOUTHWEST POWER POOL

UTILITY
LICENSEE.....KANSAS GAS & ELECTRIC
CORPORATE ADDRESS.....P.O. BOX 208
WICHITA, KANSAS 67201
CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....DANIEL INTERNATIONAL
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....IV
IE RESIDENT INSPECTOR.....J. CUMMINS
LICENSING PROJ MGR.....P. OCONNOR
DOCKET NUMBER.....50-482
LICENSE & DATE ISSUANCE...NPF-42, JUNE 4, 1985
PUBLIC DOCUMENT ROOM.....WILLIAM ALLAN WHITE LIBRARY
GOVERNMENT DOCUMENTS DIVISION
EMPORIA STATE UNIVERSITY
1200 COMMERCIAL STREET
EMPORIA, KANSAS 66801

INSPECTION STATUS

INSPECTION SUMMARY

INSPECTION CONDUCTED APRIL 1-30, 1986 (86-08) ROUTINE, UNANNOUNCED INSPECTION INCLUDING FOLLOWUP ON A PREVIOUSLY IDENTIFIED NRC ITEM; OPERATIONAL SAFETY VERIFICATION; ENGINEERED SAFETY FEATURES SYSTEM WALKDOWN; ONSITE FOLLOWUP OF EVENTS; MONTHLY SURVEILLANCE OBSERVATION; MONTHLY MAINTENANCE OBSERVATION; AND PLANT TOURS. WITHIN THE SEVEN AREAS INSPECTED, THREE VIOLATIONS WERE IDENTIFIED.

INSPECTION CONDUCTED MAY 5-9, 1986 (86-12) ROUTINE, UNANNOUNCED INSPECTION OF THE PHYSICAL SECURITY PLAN (PSP) AND IMPLEMENTING PROCEDURES, MANAGEMENT EFFECTIVENESS, SECURITY ORGANIZATION MANAGEMENT, SECURITY PROGRAM AUDIT, AND RECORDS AND REPORTS. WITHIN THE AREAS INSPECTED, ONE APPARENT VIOLATION WAS IDENTIFIED.

INSPECTION CONDUCTED MAY 1-31, 1986 (86-13) ROUTINE, UNANNOUNCED INSPECTION INCLUDING PLANT STATUS; FOLLOWUP ON PREVIOUSLY IDENTIFIED NRC ITEMS; OPERATIONAL SAFETY VERIFICATION; MONTHLY SURVEILLANCE OBSERVATION; MONTHLY MAINTENANCE OBSERVATION; ENVIRONMENTAL QUALIFICATION OF ELECTRIC EQUIPMENT; AND SURVEY OF BIOFOULING DETECTION INSTRUMENTATION ON COOLING WATER HEAT EXCHANGERS. WITHIN THE SEVEN AREAS INSPECTED, THREE VIOLATIONS WERE IDENTIFIED.

INSPECTION CONDUCTED MAY 12-16, 1986 (86-14) SPECIAL, UNANNOUNCED INSPECTION TO DETERMINE WHAT WIRING IS INSTALLED IN LIMITORQUE OPERATORS AND TO REVIEW LICENSEE'S ENVIRONMENTAL DOCUMENTATION TO ENSURE THAT QUALIFICATION OF WIRING IS ADEQUATELY ESTABLISHED. THE INSPECTION ALSO INCLUDED A REVIEW OF THE LICENSEE'S ACTIONS RELATIVE TO INFORMATION NOTICES.

Report Period JUL 1986

I N S P E C T I O N S T A T U S - (CONTINUED)

* WOLF CREEK 1 *

INSPECTION SUMMARY

INSPECTION CONDUCTED JUNE 1 - JULY 5, 1986 (86-16) ROUTINE, UNANNOUNCED INSPECTION INCLUDING PLANT STATUS; FOLLOWUP ON PREVIOUSLY IDENTIFIED NRC ITEMS; OPERATIONAL SAFETY VERIFICATION; ENGINEERED SAFETY FEATURES SYSTEM WALKDOWN; ONSITE FOLLOWUP OF EVENTS; MONTHLY SURVEILLANCE OBSERVATION; MONTHLY MAINTENANCE OBSERVATION; PLANT SAFETY REVIEW COMMITTEE; AND NUCLEAR SAFETY REVIEW COMMITTEE. WITHIN THE NINE AREAS INSPECTED, ONE VIOLATION WAS IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

PLANT STATUS:

NONE

LAST IE SITE INSPECTION DATE: JULY 5, 1986

INSPECTION REPORT NO: 50-482/86-16

R E P O R T S F R O M L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
=====			
NONE			
=====			

1. Docket: 50-029 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/86 Outage + On-line Hrs: 744.0

3. Utility Contact: S. WHIPPLE (617) 872-8100

4. Licensed Thermal Power (MWh): 600

5. Nameplate Rating (Gross MWe): 185 X 1.0 = 185

6. Design Electrical Rating (Net MWe): 175

7. Maximum Dependable Capacity (Gross MWe): 180

8. Maximum Dependable Capacity (Net MWe): 167

9. If Changes Occur Above Since Last Report, Give Reasons:

NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,087.0</u>	<u>225,332.0</u>
13. Hours Reactor Critical	<u>685.4</u>	<u>4,701.0</u>	<u>180,222.2</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>679.6</u>	<u>4,690.8</u>	<u>175,349.2</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>396,445</u>	<u>2,759,025</u>	<u>95,439,642</u>
18. Gross Elec Ener (MWH)	<u>120,514</u>	<u>840,493</u>	<u>28,923,166</u>
19. Net Elec Ener (MWH)	<u>112,886</u>	<u>787,388</u>	<u>27,063,605</u>
20. Unit Service Factor	<u>91.3</u>	<u>92.2</u>	<u>77.8</u>
21. Unit Avail Factor	<u>91.3</u>	<u>92.2</u>	<u>77.8</u>
22. Unit Cap Factor (MDC Net)	<u>90.9</u>	<u>92.7</u>	<u>73.8*</u>
23. Unit Cap Factor (DER Net)	<u>86.7</u>	<u>88.4</u>	<u>70.3*</u>
24. Unit Forced Outage Rate	<u>8.7</u>	<u>7.8</u>	<u>5.3</u>
25. Forced Outage Hours	<u>64.4</u>	<u>396.2</u>	<u>8,722.3</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


NONE

27. If Currently Shutdown Estimated Startup Date: N/A

* YANKEE-ROWE 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

YANKEE-ROWE 1



JULY 1986

* Item calculated with a Weighted Average

Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

* YANKEE-ROWE 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
86-3	06/18/86	F	64.4	A	4				CONTINUATION OF SHUTDOWN TO REPAIR S/G BLOWDOWN LINE.

* SUMMARY *

YANKEE ROWE RETURNED TO POWER ON JULY 3 AFTER STEAM
GENERATOR BLOWDOWN LINE REPAIR.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* YANKEE-ROWE 1 *

F A C I L I T Y D A T A

Report Period JUL 1986

FACILITY DESCRIPTION

LOCATION
STATE.....MASSACHUSETTS
COUNTY.....FRANKLIN
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...25 MI NE OF
PITTSFIELD, MASS
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...AUGUST 19, 1960
DATE ELEC ENER 1ST GENER...NOVEMBER 10, 1960
DATE COMMERCIAL OPERATE....JULY 1, 1961
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...DEERFIELD RIVER
ELECTRIC RELIABILITY
COUNCIL.....NORTHEAST POWER
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....YANKEE ATOMIC ELECTRIC
CORPORATE ADDRESS.....1671 WORCESTER RD.
FRAMINGHAM, MASSACHUSETTS 01701
CONTRACTOR
ARCHITECT/ENGINEER.....STONE & WEBSTER
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....STONE & WEBSTER
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I
IE RESIDENT INSPECTOR.....H. EICHENHOLZ
LICENSING PROJ MANAGER.....E. MCKENNA
DOCKET NUMBER.....50-029
LICENSE & DATE ISSUANCE....DPR-3, DECEMBER 24, 1963
PUBLIC DOCUMENT ROOM.....GREENFIELD COMMUNITY COLLEGE
1 COLLEGE DRIVE
GREENFIELD, MASSACHUSETTS 01301

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

Report Period JUL 1986

I N S P E C T I O N S T A T U S - (CONTINUED)

* YANKEE-ROWE 1 *

OTHER ITEMS

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S F R O M L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
NO INPUT PROVIDED.			

=====

Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

* ZION 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System Component	Cause & Corrective Action to Prevent Recurrence
-----	------	------	-------	--------	--------	------------	------------------	---

NONE

***** ZION 1 OPERATED ROUTINELY DURING JULY.
* SUMMARY *

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

INSPECTION STATUS - (CONTINUED)

```

*****
*                ZION 1                *
*****

```

IN THREE AREAS; ONE VIOLATION WAS IDENTIFIED IN THE TWO REMAINING AREAS (INADEQUATE TEST CONTROL)

ENFORCEMENT SUMMARY

OTHER ITEMS

NONE

NONE

NONE

PLANT STATUS:

THE UNIT IS OPERATING NORMALLY

LAST IE SITE INSPECTION DATE: 01/01/86

INSPECTION REPORT NO: 86020

REPORTS FROM LICENSEE

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
86-25	06/16/86	07/16/86	CONTAINMENT SPRAY ADDITIVE TANK BELOW MINIMUM LEVEL
86-27	07/08/86	08/07/86	INOPERABLE FIRE BARRIER

1. Docket: 50-304 OPERATING STATUS
2. Reporting Period: 07/01/86 Outage + On-line Hrs: 744.0

3. Utility Contact: GERRI AUSTIN (312) 746-2084

5. Nameplate Rating (Gross MWe): 1220 X 0.9 = 1098

7. Maximum Dependable Capacity (Gross MWe): 1085

9. If Changes Occur Above Since Last Report, Give Reasons:

0. Power Level To Which Restricted, If Any (Net MWe): _____

NONE

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


27. If Currently Shutdown Estimated Startup Date: N/A

```

XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX
X                                     ZION 2                                     X
XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX

```

ZION 2



Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

* ZION 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
-----	------	------	-------	--------	--------	------------	--------	-----------	---

NONE

***** ZION 1 OPERATED ROUTINELY DURING JULY.
* SUMMARY *

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* ZION 1 *

FACILITY DATA

Report Period JUL 1986

FACILITY DESCRIPTION

LOCATION
STATE.....ILLINOIS
COUNTY.....LAKE
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...40 MI N OF
CHICAGO, ILL
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...JUNE 19, 1973
DATE ELEC ENER 1ST GENER...JUNE 28, 1973
DATE COMMERCIAL OPERATE...DECEMBER 31, 1973
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...LAKE MICHIGAN
ELECTRIC RELIABILITY
COUNCIL.....MID-AMERICA
INTERPOOL NETWORK

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....COMMONWEALTH EDISON
CORPORATE ADDRESS.....P.O. BOX 767
CHICAGO, ILLINOIS 60690
CONTRACTOR
ARCHITECT/ENGINEER.....SARGENT & LUNDY
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....COMMONWEALTH EDISON
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III
IE RESIDENT INSPECTOR.....M. HOLZMER
LICENSING PROJ MANAGER.....J. NORRIS
DOCKET NUMBER.....50-295
LICENSE & DATE ISSUANCE...DPR-39, OCTOBER 19, 1973
PUBLIC DOCUMENT ROOM.....ZION - BENTON PUBLIC LIBRARY
2400 GABRIEL AVENUE
ZION, ILLINOIS 60099

INSPECTION STATUS

INSPECTION SUMMARY

INSPECTION ON MARCH 12-13 (86008): ROUTINE, ANNOUNCED INSPECTION BY ONE REGIONAL INSPECTOR OF PLANT TRIPS - SAFETY SYSTEM CHALLENGES. IT WAS CONDUCTED IN ACCORDANCE WITH NRC INSPECTION PROCEDURE NO. 93702. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION ON APRIL 14 THROUGH JUNE 13 (86011; 86010): ROUTINE, UNANNOUNCED RESIDENT INSPECTION OF LICENSEE ACTION ON PREVIOUS INSPECTION FINDINGS; UNIT 1 TRIP ON LOSS OF EHC; LOSS OF ENGINEERED SAFETY FEATURES LOGIC DUE TO PULLED FUSES; FAILURE OF THE 1B MAIN STEAM CHECK VALVE; UNIT 1 UNUSUAL EVENT DUE TO EXCESSIVE REACTOR COOLANT SYSTEM LEAKAGE; UNIT 2 TRIP ON LOSS OF THE 2B MAIN FEEDWATER PUMP; MISSED SURVEILLANCE OF CONTROL ROOM MAKEUP CHARCOAL FILTER; OPERATIONAL SAFETY AND ENGINEERED SAFETY FEATURE (ESF) SYSTEM WALKDOWN; SURVEILLANCE; MAINTENANCE; LICENSEE EVENT REPORTS (LERS); TRAINING; IE BULLETIN FOLLOWUP; AND REGION III REQUESTS. IN ADDITION, THIS REPORT DOCUMENTS THE APRIL 29, 1986, MEETING BETWEEN THE LICENSEE SITE AND CORPORATE STAFFS AND THE NRC REGION III STAFF REGARDING OPERATION WITH INCORRECT NEGATIVE FLUX RATE REACTOR TRIP SETPOINTS AND REGARDING THE DECEMBER 14, 1985, LOSS OF RESIDUAL HEAT REMOVAL EVENT. OF THE 15 AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED IN 13 AREAS, AND TWO VIOLATIONS WERE IDENTIFIED IN THE REMAINING TWO AREAS (FAILURE TO FOLLOW OPERATING PROCEDURES AND FAILURE TO CONDUCT A TECHNICAL SPECIFICATION REQUIRED SURVEILLANCE ON THE CONTROL ROOM VENTILATION CHARCOAL FILTER).

INSPECTION ON MAY 5 THROUGH JUNE 5 AND JUNE 11 (86012; 86011): ROUTINE, ANNOUNCED INSPECTION OF LICENSEE ACTION ON PREVIOUS INSPECTION FINDINGS (92701), ERROR IN ZION UNITS 1 AND 2 TECHNICAL SPECIFICATION F Q NORMALIZED OPERATIONS ENVELOPE (92701), ISOTHERMAL/MODERATOR TEMPERATURE COEFFICIENT MEASUREMENTS (61708), CONTROL ROD WORTH MEASUREMENTS (61710), AND SHUTDOWN MARGIN/ESTIMATED CRITICAL CONDITION CALCULATION (61707). OF THE FIVE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED

INSPECTION STATUS - (CONTINUED)

PAGE 2-427

1. Docket: 50-304 OPERATING STATUS

2. Reporting Period: 07/01/86 Outage + On-line Hrs: 744.0

3. Utility Contact: GERRI AUSTIN (312) 746-2084

4. Licensed Thermal Power (MWt): 3250

5. Nameplate Rating (Gross MWe): 1220 X 0.9 = 1098

6. Design Electrical Rating (Net MWe): 1040

7. Maximum Dependable Capacity (Gross MWe): 1085

8. Maximum Dependable Capacity (Net MWe): 1040

9. If Changes Occur Above Since Last Report, Give Reasons:

NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,087.0</u>	<u>104,016.0</u>
13. Hours Reactor Critical	<u>501.7</u>	<u>4,110.5</u>	<u>75,529.9</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>226.1</u>
15. Hrs Generator On-Line	<u>411.1</u>	<u>3,764.9</u>	<u>73,372.7</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,292,922</u>	<u>11,411,157</u>	<u>217,080,662</u>
18. Gross Elec Ener (MWH)	<u>429,513</u>	<u>3,818,651</u>	<u>68,138,246</u>
19. Net Elec Ener (MWH)	<u>406,513</u>	<u>3,640,446</u>	<u>64,817,888</u>
20. Unit Service Factor	<u>55.3</u>	<u>74.0</u>	<u>70.5</u>
21. Unit Avail Factor	<u>55.3</u>	<u>74.0</u>	<u>70.5</u>
22. Unit Cap Factor (MDC Net)	<u>52.5</u>	<u>68.8</u>	<u>59.9</u>
23. Unit Cap Factor (DER Net)	<u>52.5</u>	<u>68.8</u>	<u>59.9</u>
24. Unit Forced Outage Rate	<u>44.7</u>	<u>10.8</u>	<u>15.6</u>
25. Forced Outage Hours	<u>332.9</u>	<u>458.0</u>	<u>13,596.1</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


NONE

27. If Currently Shutdown Estimated Startup Date: N/A

* ZION 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

ZION 2



JULY 1986

Report Period JUL 1986

UNIT SHUTDOWNS / REDUCTIONS

 * ZION 2 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
4	06/27/86	F	332.9	A	4				CONTINUATION REACTOR TRIP DUE TO HIGH OVER-TEMPERATURE DELTA "T" ON LOOPS B&D.

 * SUMMARY *

ZION 2 RETURNED ONLINE FROM REPAIRS ON JULY 14TH AND OPERATED ROUTINELY THE REMAINDER OF THE MONTH.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

 * ZION 2 *

FACILITY DATA

Report Period JUL 1986

FACILITY DESCRIPTION

LOCATION
 STATE.....ILLINOIS
 COUNTY.....LAKE
 DIST AND DIRECTION FROM
 NEAREST POPULATION CTR...40 MI N OF
 CHICAGO, ILL
 TYPE OF REACTOR.....PWR
 DATE INITIAL CRITICALITY...DECEMBER 24, 1973
 DATE ELEC ENER 1ST GENER...DECEMBER 26, 1973
 DATE COMMERCIAL OPERATE...SEPTEMBER 17, 1974
 CONDENSER COOLING METHOD...ONCE THRU
 CONDENSER COOLING WATER...LAKE MICHIGAN
 ELECTRIC RELIABILITY
 COUNCIL.....MID-AMERICA
 INTERPOOL NETWORK

UTILITY & CONTRACTOR INFORMATION

UTILITY
 LICENSEE.....COMMONWEALTH EDISON
 CORPORATE ADDRESS.....P.O. BOX 767
 CHICAGO, ILLINOIS 60690
 CONTRACTOR
 ARCHITECT/ENGINEER.....SARGENT & LUNDY
 NUC STEAM SYS SUPPLIER...WESTINGHOUSE
 CONSTRUCTOR.....COMMONWEALTH EDISON
 TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III
 IE RESIDENT INSPECTOR.....M. HOLZMER
 LICENSING PROJ MANAGER.....J. NORRIS
 DOCKET NUMBER.....50-304
 LICENSE & DATE ISSUANCE....DPR-48, NOVEMBER 14, 1973
 PUBLIC DOCUMENT ROOM.....ZION - BENTON PUBLIC LIBRARY
 2400 GABRIEL AVENUE
 ZION, ILLINOIS 60099

INSPECTION SUMMARY

INSPECTION STATUS

INSPECTION ON APRIL 14 THROUGH JUNE 13 (86011; 86010): ROUTINE, UNANNOUNCED RESIDENT INSPECTION OF LICENSEE ACTION ON PREVIOUS INSPECTION FINDINGS; UNIT 1 TRIP ON LOSS OF EHC; LOSS OF ENGINEERED SAFETY FEATURES LOGIC DUE TO PULLED FUSES; FAILURE OF THE 1B MAIN STEAM CHECK VALVE; UNIT 1 UNUSUAL EVENT DUE TO EXCESSIVE REACTOR COOLANT SYSTEM LEAKAGE; UNIT 2 TRIP ON LOSS OF THE 2B MAIN FEEDWATER PUMP; MISSED SURVEILLANCE OF CONTROL ROOM MAKEUP CHARCOAL FILTER; OPERATIONAL SAFETY AND ENGINEERED SAFETY FEATURE (ESF) SYSTEM WALKDOWN; SURVEILLANCE; MAINTENANCE; LICENSEE EVENT REPORTS (LERS); TRAINING; IE BULLETIN FOLLOWUP; AND REGION III REQUESTS. IN ADDITION, THIS REPORT DOCUMENTS THE APRIL 29, 1986, MEETING BETWEEN THE LICENSEE SITE AND CORPORATE STAFFS AND THE NRC REGION III STAFF REGARDING OPERATION WITH INCORRECT NEGATIVE FLUX RATE REACTOR TRIP SETPOINTS AND REGARDING THE DECEMBER 14, 1985, LOSS OF RESIDUAL HEAT REMOVAL EVENT. OF THE 15 AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED IN 13 AREAS, AND TWO VIOLATIONS WERE IDENTIFIED IN THE REMAINING TWO AREAS (FAILURE TO FOLLOW OPERATING PROCEDURES AND FAILURE TO CONDUCT A TECHNICAL SPECIFICATION REQUIRED SURVEILLANCE ON THE CONTROL ROOM VENTILATION CHARCOAL FILTER).

INSPECTION ON MAY 5 THROUGH JUNE 5 AND JUNE 11 (86012; 86011): ROUTINE, ANNOUNCED INSPECTION OF LICENSEE ACTION ON PREVIOUS INSPECTION FINDINGS (92701), ERROR IN ZION UNITS 1 AND 2 TECHNICAL SPECIFICATION F Q NORMALIZED OPERATIONS ENVELOPE (92701), ISOTHERMAL/MODERATOR TEMPERATURE COEFFICIENT MEASUREMENTS (61708), CONTROL ROD WORTH MEASUREMENTS (61710), AND SHUTDOWN MARGIN/ESTIMATED CRITICAL CONDITION CALCULATION (61707). OF THE FIVE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED IN THREE AREAS; ONE VIOLATION WAS IDENTIFIED IN THE TWO REMAINING AREAS (INADEQUATE TEST CONTROL)

INSPECTION ON JULY 2 (86015; 86014): ROUTINE UNANNOUNCED INSPECTION OF THE RESOLUTION OF AN IE BULLETIN. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

Report Period JUL 1986

INSPECTION STATUS - (CONTINUED)

* ZION 2 *

INSPECTION SUMMARY

ENFORCEMENT SUMMARY

10 CFR 50, APPENDIX B, CRITERION XI AS IMPLEMENTED BY THE COMMONWEALTH EDISON CORPORATE QUALITY ASSURANCE MANUAL, REQUIRES THAT TESTING BE PERFORMED IN ACCORDANCE WITH WRITTEN TEST PROCEDURES AND THAT TEST RESULTS BE DOCUMENTED AND EVALUATED TO ASSURE THAT TEST REQUIREMENTS HAVE BEEN SATISFIED. CONTRARY TO THE ABOVE: (A) THE LICENSEE PERFORMED AN INADEQUATE RESULTS EVALUATION FOR TECHNICAL STAFF SURVEILLANCE PROCEDURE TSS 15.6.51, "ZERO POWER PHYSICS MEASUREMENTS FOLLOWING REFUELING," PERFORMED FOR UNIT 2 CYCLE 9 ON JANUARY 27-29, 1986, IN THAT THE INDEPENDENT REVIEW OF THE CALCULATION OF THE CRITICAL OPERATIONS RESTRICTIONS TO ASSURE A NEGATIVE MODERATOR COEFFICIENT FAILED TO DETECT THAT THERE WERE TWO ERRORS PRESENT IN THE CALCULATION. THE FAILURE TO IDENTIFY AND CORRECT THE ERRORS HAD MINOR SAFETY SIGNIFICANCE; (B) TESTING WAS NOT PERFORMED IN ACCORDANCE WITH WRITTEN TEST PROCEDURES IN THAT: (1) PROCEDURE STEPS WERE SKIPPED (NOT SIGNED NOR PERFORMED BEFORE PROCEEDING TO THE NEXT STEP) DURING THE PERFORMANCE OF THE FOLLOWING TEST PROCEDURE: TSS 15.6.51, "ZERO POWER PHYSICS MEASUREMENTS FOLLOWING REFUELING," PERFORMED FOR UNIT 2 CYCLE 9 ON JANUARY 27-29, 1986: STEPS 7.7.B AND 7.9.B. (2) PROCEDURE STEPS AT THE END OF SURVEILLANCE PROCEDURES WERE NOT SIGNED OFF PRIOR TO PROCEEDING TO AN OPERATIONAL PHASE FOR WHICH THE SURVEILLANCES WERE REQUIRED TO BE PERFORMED: TSS 15.6.54, "ISOTHERMAL MODERATOR TEMPERATURE COEFFICIENT MEASUREMENTS," PERFORMED FOR UNIT 2 CYCLE 9 ON JANUARY 27-29, 1986: STEPS G.1, G.2 AND G.3.; TSS 15.6.55, "ROD AND BORON WORTH MEASUREMENTS," PERFORMED FOR UNIT 2 CYCLE 9 ON JANUARY 27, 1986: STEPS A.5.6, A.5.6.1 AND B.5.11. (3) THE STATION NUCLEAR ENGINEER SIGNED A STEP IN TSS 15.6.51 THAT STATED, "BASED ON ROD WORTH MEASUREMENTS ADEQUATE SHUTDOWN MARGIN EXISTS, "PRIOR TO THE TIME THAT THE PROCEDURE STEPS RELATED TO EVALUATING ROD WORTH MEASUREMENTS HAD BEEN SIGNED IN PROCEDURES TSS 15.6.53, "BORON ENDPOINT MEASUREMENT," TSS 15.6.55, "ROD AND BORON WORTH MEASUREMENTS," AND TSS 15.6.51, "ZERO POWER PHYSICS TESTING FOLLOWING REFUELING."
(8601 5)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

THE UNIT IS OPERATING NORMALLY

LAST IE SITE INSPECTION DATE: 09/08/86

INSPECTION REPORT NO: 86018

Report Period JUL 1986

REPORTS FROM LICENSEE

* ZION 2 *

```
=====
NUMBER    DATE OF    DATE OF    SUBJECT
          EVENT      REPORT
-----
86-16     06/27/86   07/28/86   REACTOR TRIP DUE TO LIGHTNING STRIKE
=====
```

SECTION 3

APPENDIX

 * PRESSURIZED*
 * WATER *
 * REACTORS *

STATUS OF SPENT FUEL STORAGE CAPABILITY

REACTORS * *****	(a) CORE SIZE (NO. OF ASSEMBLIES) *****	PRESENT AUTH. STORAGE POOL CAP. (FUEL ASSEMBLIES) *****	NO. OF ASSEMBLIES STORED *****	REMAINING CAPACITY (NO. OF ASSEMBLIES) *****	REMAINING CAPACITY IF PENDING REQUEST APPROVED (NO. OF ASSEMBLIES) *****	NEXT REFUEL SCHED. DATE *****	(b) WILL FILL PRESENT AUTH. CAPACITY *****
ARKANSAS 1	177	988	384	604		09-86	1998
ARKANSAS 2	177	988	289	699		N/S	2003
BEAVER VALLEY 1	157	833	284	549		N/S	1995
BYRON 1	193	1050	0	1050		10-86	1995
CALLAWAY 1	193	1340	64	1336		N/S	1993
CALVERT CLIFFS 1	217	1830(c)	1000(c)	830(c)(m)	1098	10-86	1991
CALVERT CLIFFS 2	217					03-87	1991
CATAWBA 1	193	1418	0	1418		08-86	2008
COOK 1	193	2050(c)	866(c)	1184(c)		N/S	1994
COOK 2	193					N/S	1994
CRYSTAL RIVER 3	177	1163	328	829		N/S	1994
DAVIS-BESSE 1	177	735	204	531		N/S	1997
DIABLO CANYON 1	193	1400	0	1400		03-87	1993
DIABLO CANYON 2						09-86	1993
FARLEY 1	157	1407	273	1134			
FARLEY 2	157	1407	240	1167		10-86	1991
FORT CALHOUN 1	133	729	348	381		N/S	1994
GINNA	121	1016	420	596		05-87	1996
HADDAM NECK	157	1168	597	571		N/S	1993
INDIAN POINT 1	0	288	160	128		07-87	1994
INDIAN POINT 2	193	980	460	520		N/S	
INDIAN POINT 3	193	840	292	548		N/S	1993
KEWAUNEE	121	990	376	614(m)		N/S	1993
MAINE YANKEE	217	1476	721	755		N/S	1993
MCGUIRE 1	193	1463	220	1243(n)		N/S	1987
MCGUIRE 2	193	1463	141	1266		N/S	2010
MILLSTONE 2	217	1112	663	449		05-86	2010
MILLSTONE 3	0	0	0	0		09-86	1994
NORTH ANNA 1	157	1737(c)	520(c)	1217		N/S	
NORTH ANNA 2	157					N/S	1993
OCONEE 1	177	1312(1)	956	356(1)(n)		07-87	1991
OCONEE 2	177					08-86	1991
OCONEE 3	177	875	469	406		02-87	1991
PALISADES	204	798	477	321		N/S	2002
PALO VERDE 1	241	1329	0	1329		03-87	1993
PALO VERDE 2	241	1329	0	1329		01-88	2003
POINT BEACH 1	121	1502(c)	875(c)	626(c)		N/S	1995
POINT BEACH 2	121					09-86	1995
PRAIRIE ISLAND 1	121	1586(c)	781(c)	805(c)(m)		N/S	1993
PRAIRIE ISLAND 2	121					N/S	1993
RANCHO SECO 1	177	1080	316	764		N/S	1993
ROBINSON 2	157	541	274	266(e)	379	03-87	2000
SALEM 1	193	1170	380	790		N/S	1988(g)
SALEM 2	193	1170	140	1030		09-87	2001
SAN ONOFRE 1	157	216	146	70		10-86	2004
SAN ONOFRE 2	217	800	160	640		03-88	1988
SAN ONOFRE 3	217	800	72	728		01-88	1997
						11-86	

Report Period JUL 1986

* PRESSURIZED* STATUS OF SPENT FUEL STORAGE CAPABILITY

* WATER *

* REACTORS *

FACILITY *****	(NO. OF ASSEMBLIES) *****	STORAGE POOL CAP. (FUEL ASSEMBLIES) *****	ASSEMBLIES REMAINING STORED (NO. OF ASSEMBLIES) *****	CAPACITY *****	APPROVED (NO. OF ASSEMBLIES) *****	NEXT REFUEL SCHED. DATE *****	WILL FILL PRESENT AUTH. CAPACITY *****
SEQUOYAH 1	193	1386	348		1033	N/S	1994
SEQUOYAH 2(d)	193					N/S	1994
ST LUCIE 1	217	728	372		356	N/S	1993
ST LUCIE 2	217	1076	152		924	N/S	1993
SUMMER 1	157	1276	96		1180	N/S	2008
SURRY 1	157	1044(c)	901(c)		143(c)	N/S	1987
SURRY 2	157					N/S	1987
THREE MILE ISLAND 1	177	752	208		544	11-86	1991
THREE MILE ISLAND 2	177	442	0		442	N/S	
TROJAN	193	1408	425		983	N/S	1993
TURKEY POINT 3	157	1404	445		959(m)	N/S	1993
TURKEY POINT 4	157	1404	482		922	N/S	1993
WATERFORD 3	217	1088	0		1088	N/S	1993
WOLF CREEK 1	193	1340	0		1340	N/S	
YANKEE-ROWE 1	76	721	325		396	N/S	1993
ZION 1	193	2112(c)	1008(c)		1104(c)	08-86	1995
ZION 2	193					02-87	1995

INDEPENDENT SPENT FUEL STORAGE INSTALLATIONS(h)

MORRIS OPERATIONS	750 MTU(j)	315	385 MTU(j)	1490 MTU(j)
NFS(i)	250 MTU	170 MTU	80 MTU	

- (a) At each refueling outage approximately 1/3 of a PWR core and 1/4 of a BWR core is off-loaded.
- (b) Some of these dates have been adjusted by staff assumptions.
- (c) This is the total for both units.
- (d) Plant not in commercial operation.
- (e) Some spent fuel stored at Brunswick.
- (f) Authorized a total 2772 BWR and 1232 PWR assemblies for both pools.
- (g) Robinson 2 assemblies being shipped to Brunswick for storage.
- (h) Capacity is in metric tons of uranium; 1 MTU = 2 PWR assemblies or 5 BWR assemblies.
- (i) No longer accepting spent fuel.
- (j) Racked for 700 MTU.
- (k) Reserved.
- (l) This is the station total.
- (m) Installed capacity is less than that authorized.
- (n) McGuire 1 authorized to accept Oconee fuel assemblies.

N/S = Not Scheduled

***** * BOILING * STATUS OF SPENT FUEL STORAGE CAPABILITY * WATER * * REACTORS * *****							
FACILITY *****	(a) CORE SIZE (NO. OF ASSEMBLIES) *****	PRESENT AUTH. STORAGE POOL CAP. (FUEL ASSEMBLIES) *****	NO. OF ASSEMBLIES STORED *****	REMAINING CAPACITY IF PENDING REQUEST APPROVED (NO. OF ASSEMBLIES) *****	REMAINING CAPACITY IF PENDING REQUEST APPROVED (NO. OF ASSEMBLIES) *****	NEXT REFUEL SCHED. DATE *****	(b) WILL FILL PRESENT AUTH. CAPACITY *****
	BIG ROCK POINT 1	34	441	192	249		N/S
BROWNS FERRY 1	764	3471	1288	2183		N/S	1993
BROWNS FERRY 2	764	3471	1161	2310(m)	1819	N/S	1993
BROWNS FERRY 3	764	3471	1004	2467(m)		N/S	1993
BRUNSWICK 1	560	(f)	160PWR+656BWR	123		N/S	1992
BRUNSWICK 2	560		144PWR+564BWR	107		N/S	1993
COOPER STATION	548	2366	790	1576		10-86	1996
DRESDEN 1	464	672	221	451		N/S	1990
DRESDEN 2	724	3537(c)	1413 (c)	2124(c)	(c)	12-86	1993
DRESDEN 3	724	3537	1271	2266		N/S	1993
DUANE ARNOLD	368	2050	696	1354		02-87	1998
FITZPATRICK	560	2244	1012	768		09-86	1992
GRAND GULF 1	800	1440	0	1440		09-86	1993
HATCH 1	560	6026	1580	4446		N/S	1999
HATCH 2	560			1325		09-86	1999
HUMBOLDT BAY	172	487	251	236		N/S	
LA CROSSE	72	440	261	179		N/S	1992
LASALLE 1	764	2162	191	1971		N/S	1988
LASALLE 2	764					N/S	1988
LIMERICK 1	764	2040	0	2040		N/S	1993
MILLSTONE 1	580	2184	1546	638		05-87	1991
MONTICELLO	484	2237	822	1415		N/S	1999
NINE MILE POINT 1	532	2776	1377	1399	1788	N/S	1996
OYSTER CREEK 1	560	2600	1902	698		N/S	1990

* BOILING * STATUS OF SPENT FUEL STORAGE CAPABILITY

* WATER *
* REACTORS *

*****		(a)					REMAINING CAPACITY			(b)
*****		CORE SIZE	PRESENT AUTH.	NO. OF	REMAINING CAPACITY	IF PENDING REQUEST	APPROVED	NEXT REFUEL	WILL FILL PRESENT	
*****		(NO. OF	STORAGE POOL CAP.	ASSEMBLIES	(NO. OF ASSEMBLIES)	(NO. OF ASSEMBLIES)	(NO. OF ASSEMBLIES)	SCHED. DATE	AUTH. CAPACITY	
*****		ASSEMBLIES)	(FUEL ASSEMBLIES)	STORED	(NO. OF ASSEMBLIES)	(NO. OF ASSEMBLIES)	(NO. OF ASSEMBLIES)	*****	*****	
*****		*****	*****	*****	*****	*****	*****	*****	*****	
PEACH BOTTOM 2	764	2816	1462	1354	2357	02-87	1995			
PEACH BOTTOM 3	764	2816	1496	1320	2323	09-87	1996			
PILGRIM 1	580	2320	1128	1192(m)		07-86	1990			
QUAD CITIES 1	724	3657	1896	1761		09-87	2003			
QUAD CITIES 2	724	3897	836	3061		10-86	2003			
RIVER BEND 1										
SUSQUEHANNA 1	764	2840	382	2458		N/S	1997			
SUSQUEHANNA 2	764	2840	0	2840		08-86	1997			
VERMONT YANKEE 1	368	2000	1296	704		N/S	1992			
WASHINGTON NUCLEAR*	764	2658	191	2467		N/S	1993			

INDEPENDENT SPENT FUEL STORAGE INSTALLATIONS(h)

MORRIS OPERATIONS	750 MTU(j)	315	385 MTU(j)	1490 MTU(j)
NFS(i)	250 MTU	170 MTU	80 MTU	

- (a) At each refueling outage approximately 1/3 of a PWR core and 1/4 of a BWR core is off-loaded.
- (b) Some of these dates have been adjusted by staff assumptions.
- (c) This is the total for both units.
- (d) Plant not in commercial operation.
- (e) Some spent fuel stored at Brunswick.
- (f) Authorized a total 2772 BWR and 1232 PWR assemblies for both pools.
- (g) Robinson 2 assemblies being shipped to Brunswick for storage.
- (h) Capacity is in metric tons of uranium; 1 MTU = 2 PWR assemblies or 5 BWR assemblies.
- (i) No longer accepting spent fuel.
- (j) Racked for 700 MTU.
- (k) Reserved.
- (l) This is the station total.
- (m) Installed capacity is less than that authorized.
- (n) McGuire 1 authorized to accept Oconee fuel assemblies.

N/S = Not Scheduled

(INCLUDES BOTH LICENSED
AND NON-LICENSED UNITS)

REACTOR YEARS OF EXPERIENCE

	YEARS	1ST ELEC GENERATE	UNIT

* LICENSED *	12.00	08/01/74	ARKANSAS 1
* OPERATING *	23.65	12/08/62	BIG ROCK POINT 1
* ELECTRICAL *	9.88	09/12/76	BROWNS FERRY 3
* PRODUCING *	1.42	03/01/85	BYRON 1
* UNITS *	9.65	12/07/76	CALVERT CLIFFS 2

	8.36	03/22/78	COOK 2
	8.93	08/28/77	DAVIS-BESSE 1
	16.30	04/13/70	DRESDEN 2
	8.95	08/18/77	FARLEY 1
	12.93	08/25/73	FORT CALHOUN 1
	1.78	10/20/84	GRAND GULF 1
	7.86	09/22/78	HATCH 2
	12.31	04/08/74	KEWAUNEE
	2.28	04/20/84	LASALLE 2
	5.09	06/30/81	MCGUIRE 1
	10.73	11/09/75	MILLSTONE 2
	16.73	11/09/69	NINE MILE POINT 1
	13.24	05/06/73	OCONEE 1
	16.85	09/23/69	OYSTER CREEK 1
	.20	05/20/86	PALO VERDE 2
	14.03	07/19/72	PILGRIM 1
	12.66	12/04/73	PRAIRIE ISLAND 1
	14.19	05/23/72	QUAD CITIES 2
	15.85	09/26/70	ROBINSON 2
	19.04	07/16/67	SAN ONOFRE 1
	6.03	07/22/80	SEQUOYAH 1
	3.13	06/13/83	ST LUCIE 2
	13.39	03/10/73	SURRY 2
	12.12	06/19/74	THREE MILE ISLAND 1
	13.11	06/21/73	TURKEY POINT 4
	1.37	03/18/85	WATERFORD 3
	13.09	06/28/73	ZION 1

TOTAL 934.01 YRS

YEARS	1ST ELEC GENERATE	UNIT
7.60	12/26/78	ARKANSAS 2
12.79	10/15/73	BROWNS FERRY 1
9.66	12/04/76	BRUNSWICK 1
1.77	10/24/84	CALLAWAY 1
1.52	01/22/85	CATAWBA 1
12.23	05/10/74	COOPER STATION
1.72	11/11/84	DIABLO CANYON 1
15.03	07/22/71	DRESDEN 3
5.19	05/25/81	FARLEY 2
9.64	12/11/76	FORT ST VRAIN
18.98	08/07/67	HADDAM NECK
13.10	06/26/73	INDIAN POINT 2
18.26	04/26/68	LA CROSSE
1.30	04/13/85	LIMERICK 1
3.19	05/23/83	MCGUIRE 2
.47	02/12/86	MILLSTONE 3
8.29	04/17/78	NORTH ANNA 1
12.65	12/05/73	OCONEE 2
14.58	12/31/71	PALISADES
12.45	02/18/74	PEACH BOTTOM 2
15.73	11/06/70	POINT BEACH 1
11.61	12/21/74	PRAIRIE ISLAND 2
11.80	10/13/74	RANCHO SECO 1
9.60	12/25/76	SALEM 1
3.86	09/20/82	SAN ONOFRE 2
4.61	12/23/81	SEQUOYAH 2
3.71	11/16/82	SUMMER 1
3.71	11/16/82	SUSQUEHANNA 1
10.61	12/23/75	TROJAN
13.86	09/20/72	VERMONT YANKEE 1
1.14	06/12/85	WOLF CREEK 1
12.60	12/26/73	ZION 2

YEARS	1ST ELEC GENERATE	UNIT
10.13	06/14/76	BEAVER VALLEY 1
11.93	08/28/74	BROWNS FERRY 2
11.26	04/29/75	BRUNSWICK 2
11.58	01/03/75	CALVERT CLIFFS 1
11.47	02/10/75	COOK 1
9.50	01/30/77	CRYSTAL RIVER 3
.78	10/20/85	DIABLO CANYON 2
12.20	05/19/74	DUANE ARNOLD
11.50	02/01/75	FITZPATRICK
16.66	12/02/69	GINNA
11.72	11/11/74	HATCH 1
10.26	04/27/76	INDIAN POINT 3
3.91	09/04/82	LASALLE 1
13.73	11/08/72	MAINE YANKEE
15.67	11/29/70	MILLSTONE 1
15.41	03/05/71	MONTICELLO
5.93	08/25/80	NORTH ANNA 2
11.92	09/01/74	OCONEE 3
1.14	06/10/85	PALO VERDE 1
11.92	09/01/74	PEACH BOTTOM 3
14.00	08/02/72	POINT BEACH 2
14.30	04/12/72	QUAD CITIES 1
.66	12/03/85	RIVER BEND 1
5.16	06/03/81	SALEM 2
2.85	09/25/83	SAN ONOFRE 3
10.23	05/07/76	ST LUCIE 1
14.08	07/04/72	SURRY 1
2.08	07/03/84	SUSQUEHANNA 2
13.74	11/02/72	TURKEY POINT 3
2.18	05/27/84	WASHINGTON NUCLEAR 2
25.72	11/10/60	YANKEE-ROWE 1

	YEARS	1ST ELEC GENERATE	SHUTDOWN DATE	UNIT

* PERMANENTLY *	3.80	08/14/64	06/01/68	BONUS
* OR *	18.54	04/15/60	10/31/78	DRESDEN 1
* INDEFINITELY *	6.32	08/05/66	11/29/72	FERMI 1
* SHUTDOWN *	13.21	04/18/63	07/02/76	HUMBOLDT BAY
* UNITS *	1.19	07/25/66	10/01/67	PATHFINDER

	2.16	11/04/63	01/01/66	PIQUA

TOTAL 74.77 YRS

YEARS	1ST ELEC GENERATE	SHUTDOWN DATE	UNIT
3.04	12/18/63	01/01/67	CVTR
4.44	08/24/63	02/01/68	ELK RIVER
1.26	05/29/63	09/01/64	HALLAM
12.12	09/16/62	10/31/74	INDIAN POINT 1
7.76	01/27/67	11/01/74	PEACH BOTTOM 1
.93	04/21/78	03/28/79	THREE MILE ISLAND 2

 * RESEARCH *
 * REACTORS *

NON-POWER REACTORS IN THE U. S.

STATE	CITY	LICENSEE	REACTOR TYPE	DOCKET	LICENSE NUMBER	DATE OF ISSUED	AUTHORIZED POWER LEVEL (KW)
ALABAMA	TUSKEGEE	TUSKEGEE INSTITUTE	AGN-201 #102	50-406	R-122	08-30-74	0.0001
ARIZONA	TUCSON	UNIVERSITY OF ARIZONA	TRIGA MARK I	50-113	R-52	12-05-58	100.0
CALIFORNIA	BERKELEY	UNIVERSITY OF CALIFORNIA, BERKELEY COLLEGE	TRIGA MK. III	50-224	R-101	08-10-66	1000.0
	CANOGA PARK	ROCKWELL INTERNATIONAL CORP.	L-85	50-375	R-188	01-05-72	0.003
	HAWTHORNE	NORTHROP CORP. LABORATORIES	TRIGA MARK F	50-187	R-90	03-04-63	1000.0
	IRVINE	UNIVERSITY OF CALIFORNIA, IRVINE	TRIGA MARK I	50-326	R-116	11-24-69	250.0
	LOS ANGELES	UNIVERSITY OF CALIFORNIA, L.A.	ARGONAUT	50-142	R-71	10-03-60	100.0
	SAN DIEGO	GENERAL ATOMIC COMPANY	TRIGA MARK F	50-163	R-67	07-01-60	1500.0
	SAN DIEGO	GENERAL ATOMIC COMPANY	TRIGA MARK I	50-089	R-38	05-03-58	250.0
	SAN JOSE	GENERAL ELECTRIC COMPANY	NTR	50-073	R-33	10-31-57	100.0
	SAN LUIS OBISPO	CALIFORNIA STATE POLYTECHNIC COLLEGE	AGN-201 #100	50-394	R-121	05-16-73	0.0001
	SAN RAMON	AEROTEST OPERATIONS, INC.	TRIGA (INDUS)	50-228	R-98	07-02-65	250.0
	SANTA BARBARA	UNIVERSITY OF CALIFORNIA, SANTA BARBARA	L-77	50-433	R-124	12-03-74	0.01
COLORADO	DENVER	U.S. GEOLOGICAL SURVEY DEPARTMENT	TRIGA MARK I	50-274	R-113	02-24-69	1000.0
DELAWARE	NEWARK	UNIVERSITY OF DELAWARE	AGN-201 #113	50-098	R-43	07-03-58	0.0001
DIST OF COLUMBIA	WASHINGTON	THE CATHOLIC UNIVERSITY OF AMERICA	AGN-201 #101	50-077	R-31	11-15-67	0.0001
FLORIDA	GAINESVILLE	UNIVERSITY OF FLORIDA	ARGONAUT	50-083	R-56	05-21-59	100.0
GEORGIA	ATLANTA	GEORGIA INSTITUTE OF TECHNOLOGY	AGN-201 #104	50-276	R-111	04-19-68	0.0001
	ATLANTA	GEORGIA INSTITUTE OF TECHNOLOGY	HEAVY WATER	50-160	R-97	12-29-64	5000.0
IDAHO	POCATELLO	IDAHO STATE UNIVERSITY	AGN-201 #103	50-284	R-110	10-11-67	0.0001
ILLINOIS	URBANA	UNIVERSITY OF ILLINOIS	LOPRA	50-356	R-117	12-27-71	10.0
	URBANA	UNIVERSITY OF ILLINOIS	TRIGA	50-151	R-115	07-22-69	1500.0
	ZION	WESTINGHOUSE ELECTRIC CORP.	NTR	50-087	R-119	01-28-72	10.0
INDIANA	LAFAYETTE	PURDUE UNIVERSITY	LOCKHEED	50-182	R-87	08-16-62	10.0
IOWA	AMES	IOWA STATE UNIVERSITY	UTR-10	50-116	R-59	10-16-59	10.0
KANSAS	LAWRENCE	UNIVERSITY OF KANSAS	LOCKHEED	50-148	R-78	06-23-61	250.0
	MANHATTAN	KANSAS STATE UNIVERSITY	TRIGA	50-188	R-88	10-16-62	250.0
MARYLAND	BETHESDA	ARMED FORCES RADIOBIOLOGY RESEARCH INSTITUTE	TRIGA	50-170	R-84	06-26-62	1000.0
	COLLEGE PARK	UNIVERSITY OF MARYLAND	TRIGA	50-166	R-70	10-14-60	250.0

 * RESEARCH *
 * REACTORS *

NON-POWER REACTORS IN THE U. S.

STATE	CITY	LICENSEE	REACTOR TYPE	DOCKET	LICENSE NUMBER	DATE OF ISSUED	AUTHORIZED POWER LEVEL (KW)
MASSACHUSETTS	CAMBRIDGE	MASSACHUSETTS INSTITUTE OF TECHNOLOGY	HWR REFLECTED	50-020	R-37	06-09-58	5000.0
	LOWELL	UNIVERSITY OF LOWELL	GE	50-223	R-125	12-24-74	1000.0
	WORCESTER	WORCESTER POLYTECHNIC INSTITUTE	GE	50-134	R-61	12-16-59	10.0
MICHIGAN	ANN ARBOR	UNIVERSITY OF MICHIGAN	POOL	50-002	R-28	09-13-57	2000.0
	EAST LANSING	MICHIGAN STATE UNIVERSITY	TRIGA MARK I	50-294	R-114	03-21-69	250.0
	MIDLAND	DOW CHEMICAL COMPANY	TRIGA	50-264	R-108	07-03-67	100.0
MISSOURI	COLUMBIA	UNIVERSITY OF MISSOURI, COLUMBIA	TANK	50-186	R-103	10-11-66	10000.0
	ROLIA	UNIVERSITY OF MISSOURI	POOL	50-123	R-79	11-21-61	200.0
NEBRASKA	OMAHA	THE VETERANS ADMINISTRATION HOSPITAL	TRIGA	50-131	R-57	06-26-59	18.0
NEW MEXICO	ALBUQUERQUE	UNIVERSITY OF NEW MEXICO	AGN-201M #112	50-252	R-102	09-17-66	0.005
NEW YORK	BRONX	MANHATTAN COLLEGE - PHYSICS DEPT.	TANK	50-199	R-94	03-24-64	0.0001
	BUFFALO	STATE UNIVERSITY OF NEW YORK	PULSTAR	50-057	R-77	03-24-61	2000.0
	ITHACA	CORNELL UNIVERSITY	TRIGA MARK II	50-157	R-80	01-11-62	500.0
	ITHACA	CORNELL UNIVERSITY	ZPR	50-097	R-89	12-11-62	0.1
	NEW YORK	COLUMBIA UNIVERSITY IN THE CITY OF NEW YORK	TRIGA MARK II	50-208	R-128	04-14-77	250.0
	TUXEDO	UNION CARBIDE CORP	POOL	50-054	R-81	09-07-61	5000.0
NORTH CAROLINA	RALEIGH	NORTH CAROLINA STATE UNIVERSITY AT RALEIGH	PULSTAR	50-297	R-120	08-25-74	1000.0
OHIO	COLUMBUS	OHIO STATE UNIVERSITY	POOL	50-150	R-75	02-24-61	10.0
OKLAHOMA	NORMAN	THE UNIVERSITY OF OKLAHOMA	AGN-211 #102	50-112	R-53	12-29-58	0.100
OREGON	CORVALLIS	OREGON STATE UNIVERSITY	TRIGA MARK II	50-243	R-106	03-07-67	1000.0
	PORTLAND	REED COLLEGE	TRIGA MARK I	50-288	R-112	07-02-68	250.0
PENNSYLVANIA	UNIVERSITY PARK	PENNSYLVANIA STATE UNIVERSITY	TRIGA MK. III	50-005	R-2	07-08-55	1000.0
RHODE ISLAND	NARRACANSETT	RHODE ISLAND NUCLEAR SCIENCE CENTER	GE POOL	50-193	R-95	07-21-64	2000.0
TENNESSEE	MEMPHIS	MEMPHIS STATE UNIVERSITY	AGN-201 #108	50-538	R-127	12-10-76	0.0001
TEXAS	AUSTIN	UNIVERSITY OF TEXAS	TRIGA MARK I	50-192	R-92	08-02-63	250.0
	COLLEGE STATION	TEXAS A&M UNIVERSITY	AGN-201M #106	50-059	R-23	08-26-57	0.005
	COLLEGE STATION	TEXAS A&M UNIVERSITY	TRIGA	50-128	R-83	12-07-61	1000.0
UTAH	PROVO	BRIGHAM YOUNG UNIVERSITY	L-77	50-262	R-109	09-07-67	0.01

 * RESEARCH *
 * REACTORS *

NON-POWER REACTORS IN THE U. S.

STATE	CITY	LICENSEE	REACTOR TYPE	DOCKET	LICENSE NUMBER	DATE OF ISSUED	AUTHORIZED POWER LEVEL (KW)
UTAH	SALT LAKE CITY	THE UNIVERSITY OF UTAH	TRIGA MARK I	50-407	R-126	09-30-75	100.0
	SALT LAKE CITY	UNIVERSITY OF UTAH	AGN-201M #107	50-072	R-25	09-12-57	0.005
VIRGINIA	BLACKSBURG	VIRGINIA POLYTECHNIC INSTITUTE	UTR-10	50-124	R-62	12-18-59	100.0
	CHARLOTTESVILLE	UNIVERSITY OF VIRGINIA	CAVALIER	50-396	R-123	09-24-74	0.1
	CHARLOTTESVILLE	UNIVERSITY OF VIRGINIA	POOL	50-062	R-66	06-27-60	2000.0
	LYNCHBURG	BABCOCK & WILCOX COMPANY	LPR	50-099	R-47	09-05-58	1000.0
WASHINGTON	PULLMAN	WASHINGTON STATE UNIVERSITY	TRIGA	50-027	R-76	03-06-61	1000.0
	SEATTLE	UNIVERSITY OF WASHINGTON	ARGONAUT	50-139	R-73	03-31-61	100.0
WISCONSIN	MADISON	UNIVERSITY OF WISCONSIN	TRIGA	50-156	R-74	11-23-60	1000.0

 * EXPERIMENTAL AND TEST REACTORS *

CALIFORNIA	SAN JOSE	GENERAL ELECTRIC COMPANY	GETR	50-070	TR-1	01-07-59	50,000.0
DIST OF COLUMBIA	WASHINGTON	NATIONAL BUREAU OF STANDARDS	TEST	50-184	TR-5	06-30-70	10,000.0

 * CRITICAL EXPERIMENT FACILITIES *

NEW YORK	TROY	RENSSELAER POLYTECHNIC INSTITUTE		50-225	CX-22	07-03-64	0.0
VIRGINIA	LYNCHBURG	BABCOCK & WILCOX COMPANY		50-013	CX-10	10-22-58	0.0
WASHINGTON	RICHLAND	BATTELLE MEMORIAL INSTITUTE		50-360	CX-26	11-29-71	0.0

NRC FORM 336 10-83		U.S. NUCLEAR REGULATORY COMMISSION		1. REPORT NUMBER (Assigned by NRC add Vol. No. if any)	
BIBLIOGRAPHIC DATA SHEET				NUREG-0020 Volume 10 Number 8	
				2. Leave blank	
3. TITLE AND SUBTITLE				4. RECIPIENT'S ACCESSION NUMBER	
Licensed Operating Reactors Status Summary Report				5. DATE REPORT COMPLETED	
6. AUTHOR(S)				MONTH	YEAR
				DECEMBER	1986
7. DATE REPORT ISSUED				MONTH	YEAR
				DECEMBER	1986
8. PERFORMING ORGANIZATION NAME AND MAILING ADDRESS (Include Zip Code)				9. PROJECT/TASK/WORK UNIT NUMBER	
Division of Computer and Telecommunications Services Office of Information Resources Management U. S. Nuclear Regulatory Commission Washington, DC 20555				10. PIN NUMBER	
11. SPONSORING ORGANIZATION NAME AND MAILING ADDRESS (Include Zip Code)				12a. TYPE OF REPORT	
Division of Computer and Telecommunications Services Office of Information Resources Management U. S. Nuclear Regulatory Commission Washington, DC 20555				12b. PERIOD COVERED (Inclusive dates)	
				JULY 1986	
13. SUPPLEMENTARY NOTES					
Status Summary Report					
14. ABSTRACT (200 words or less)					
<p>The OPERATING UNITS STATUS REPORT - LICENSED OPERATING REACTORS provides data on the operation of nuclear units as timely and accurately as possible. This information is collected by the Office of Resource Management from the Headquarters staff of NRC's Office of Inspection and Enforcement, from NRC's Regional Offices, and from utilities. The three sections of the report are: monthly highlights and statistics for commercial operating units, and errata from previously reported data; a compilation of detailed information on each unit, provided by NRC's Regional Offices, IE Headquarters and the utilities; and an appendix for miscellaneous information such as spent fuel storage capability, reactor-years of experience and non-power reactors in the U.S. It is hoped the report is helpful to all agencies and individuals interested in maintaining an awareness of the U.S. energy situation as a whole.</p>					
15a. KEY WORDS AND DOCUMENT ANALYSIS			15b. DESCRIPTORS		
16. AVAILABILITY STATEMENT			17. SECURITY CLASSIFICATION		18. NUMBER OF PAGES
Unlimited			(This report) Unclassified		
			19. SECURITY CLASSIFICATION		20. PRICE
			(This page) Unclassified		\$

DISTRIBUTION LIST - NRC

INTERNAL DISTRIBUTION

Office of the Commissioners	5
Atomic Safety and Licensing Appeal Panel	3
Advisory Committee on Reactor Safeguards	6
Office of Inspector and Auditor	1
Office of Policy Evaluation	1
Office of the General Counsel	1
Office of Public Affairs	21
Office of Congressional Affairs	3
Office of the Executive Director for Operations	7
Office of Administration	2
Office of the Executive Legal Director	2
Office of Analysis and Evaluation of Operational Data	2
Office of International Programs	3
Office of State Programs	1
Office of Information Resources Management	19
Office of Nuclear Material Safety and Safeguards	2
- Division of Fuel Cycle and Material Safety	3
- Division of Safeguards	2
Office of Nuclear Reactor Regulation	138
- Division of Engineering	
- Division of Safety Technology	
- Division of Licensing	
- Division of Systems Integration	
- Division of Human Factors Safety	
Office of Nuclear Regulatory Research	4
Office of Inspection and Enforcement	7
- Region I	11
- Region II	10
- Region III	10
- Region IV	10
- Region V	7
	<u>281</u>

EXTERNAL DISTRIBUTION

SPECIAL REQUESTS

Air Force	1
Congress	10
Department of Energy	32
Government Accounting Office	1
Environmental Protection Agency	1
Electric Power Research Institute	1
Argonne National Laboratory	3
Bureau of Mines	1
Department of Agriculture	1
Department of the Commerce	1
Department of the Interior	1
	<u>53</u>

OTHER

GPO Depository	440
GPO Stores	75
National Technical Information Service	25
Subscriptions (NTIS)	250
Colleges and Libraries (including Public Document Rooms)	128
Utilities and Other Requests	<u>227</u>
	1145

UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555

OFFICIAL BUSINESS
PENALTY FOR PRIVATE USE, \$300

FIRST CLASS MAIL
POSTAGE & FEES PAID
USNRC
WASH D C
PERMIT No. G-57

120555078877 1 1AN1NU
US NRC
ADM-DIV OF PUB SVCS
POLICY & PUB MGT RR-PDR NUREG
W-501
WASHINGTON DC 20555