

LICENSEE EVENT REPORT (LER)

FACILITY NAME (1) Dresden Nuclear Power Station - Unit 2										DOCKET NUMBER (2) 0 5 0 0 0 2 3 7										PAGE (3) 1 OF 0 2									
TITLE (4) Leakage in Excess of Technical Specification 3.7.A.2.b Limit Found on Main Steam Isolation Valve 2-203-2B Due to Packing Leak																													
EVENT DATE (5)			LER NUMBER (6)				REPORT DATE (7)			OTHER FACILITIES INVOLVED (8)																			
MONTH	DAY	YEAR	YEAR	SEQUENTIAL NUMBER	REVISION NUMBER	MONTH	DAY	YEAR	FACILITY NAMES						DOCKET NUMBER(S)														
									N/A						0 5 0 0 0														
1	2	1	4	8	6	8	6	0	3	0	0	0	1	0	6	8	7	N/A						0 5 0 0 0					
OPERATING MODE (9)		THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR § (Check one or more of the following) (11)																											
N		20.402(b)				20.406(c)				50.73(a)(2)(iv)				73.71(b)															
POWER LEVEL (10)		20.406(a)(1)(i)				30.38(c)(1)				50.73(a)(2)(v)				73.71(c)															
0 0 0		20.406(a)(1)(ii)				50.38(c)(2)				50.73(a)(2)(vii)				OTHER (Specify in Abstract below and in Text, NRC Form 366A)															
		20.406(a)(1)(iii)				X 50.73(a)(2)(i)				50.73(a)(2)(viii)(A)																			
		20.406(a)(1)(iv)				50.73(a)(2)(ii)				50.73(a)(2)(viii)(B)																			
		20.406(a)(1)(v)				50.73(a)(2)(iii)				50.73(a)(2)(ix)																			
LICENSEE CONTACT FOR THIS LER (12)																													
NAME Brian C. McCabe Technical Staff Engineer (X-483)										TELEPHONE NUMBER AREA CODE 8 1 5 9 4 2 - 2 9 2 0																			
COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13)																													
CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NRC	CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NRC	CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NRC	CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NRC	CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NRC					
X	S	B	I	S	N	C	6	6	5	Y																			
SUPPLEMENTAL REPORT EXPECTED (14)																													
YES (If yes, complete EXPECTED SUBMISSION DATE)										X NO										EXPECTED SUBMISSION DATE (15)		MONTH	DAY	YEAR					

ABSTRACT (Limit to 1400 spaces, i.e., approximately fifteen single-space typewritten lines) (16)

On December 14, 1986 with Unit 2 at 0% power and in a refueling outage, main steam isolation valve (MSIV) 2-203-2B was found to be leaking (25.553 SCFH) in excess of the Technical Specification 3.7.A.2.b limit of 11.5 SCFH during the performance of Dresden Technical Staff Surveillance Procedure DTS 250-1 "Main Steam Isolation Valve Local Leak Rate Test". An immediate investigation by the cognizant Technical Staff Engineer identified the leakage as coming from the packing on the 2-203-2B valve. An inspection of MSIV 2-203-2B by the Mechanical Maintenance Department found the packing in a slightly degraded condition due to wear experienced from unit operation during the previous fuel cycle. Therefore, on 12-19-86 the valve was repacked and on 12-21-86 an "as left" local leak rate test was successfully performed. The safety significance of this event was minimal because the calculated leakage remained significantly less than the Technical Specification limit for Type B and C leak rate testing which is 493.116 SCFH. Furthermore leakage from the in-line inboard MSIV 2-203-1B remained within Technical Specification limits indicating that the calculated "through" leakage using the "Minimum Pathway" methodology was minimal. The previous failure of an MSIV during an Appendix J local leak rate test is documented in Reportable Occurrence #83-05 on Docket #050237.

8701150266 870106
PDR ADOCK 05000237
S PDR

IE22
1/1

LICENSEE EVENT REPORT (LER) TEXT CONTINUATION

APPROVED OMB NO. 3150-0104

EXPIRES: 8/31/85

FACILITY NAME (1)	DOCKET NUMBER (2)	LER NUMBER (6)			PAGE (3)		
		YEAR	SEQUENTIAL NUMBER	REVISION NUMBER			
Dresden Nuclear Power Station, Unit 2	0 5 0 0 0 2 3 7	8 6	— 0 3 0	— 0 0	0 2	OF	0 2

TEXT (If more space is required, use additional NRC Form 366A's) (17)

On December 14, 1986 with Unit 2 at 0% power and in a refueling outage, main steam isolation valve (MSIV, EIIS Code SB) 2-203-2B was found to be leaking in excess of the Technical Specification 3.7.A.2.b limit of 11.5 SCFH during the performance of Dresden Technical Staff Surveillance Procedure (DTS) 250-1 "Main Steam Isolation Valve Local Leak Rate (Dry) Test". The calculated leak rate was determined to be 25.553 SCFH during the test. An immediate investigation by the cognizant Technical Staff Engineer identified the leakage as coming from the valve stem area indicating a packing leak on the 2-203-2B valve. The remaining seven MSIVs successfully completed the Appendix J local leak rate test. Work Request D60399 was initiated for the Mechanical Maintenance Department to inspect MSIV 2-203-2B and adjust the packing as necessary to correct the problem causing the leak.

An inspection of MSIV 2-203-2B (Crane Co. #DR34289-20" Y Pattern Globe Valve) by the Mechanical Maintenance Department found the packing (QP Packing Co.) in a slightly degraded condition due to wear experienced from unit operation during the previous fuel cycle. Therefore, on 12-19-86 the valve was repacked and on 12-21-86 an "as left" local leak rate test (LLRT) was successfully performed. The calculated "as left" leak rate was determined to be 6.578 SCFH. The safety significance of this event was minimal because the calculated leakage remained significantly less than the Technical Specification limit for Type B and C leak rate testing which is 493.116 SCFH. Furthermore leakage from the in-line inboard MSIV 2-203-1B (3.289 SCFH) remained within Technical Specification limits indicating that the calculated "through" leakage using the "Minimum Pathway" methodology was minimal. The previous failure of an MSIV during an Appendix J local leak rate test is documented in Reportable Occurrence #83-05 on Docket #050237.



Commonwealth Edison
Dresden Nuclear Power Station
R.R. #1
Morris, Illinois 60450
Telephone 815/942-2920

January 6, 1987

EDE LTR #87-009

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

Licensee Event Report #86-030-0, Docket #050237 is being submitted
as required by Technical Specification 6.6, NUREG 1022 and
10 CFR 50.73(a)(2)(i)(B).

RA. Elenberg for

E.D. Eenigenburg
Station Manager
Dresden Nuclear Power Station

EDE/jmt

Enclosure

cc: J.G. Keppler, Regional Administrator, Region III
File/NRC
File/Numerical

IE22
1/1