



UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION V

1450 MARIA LANE, SUITE 210
WALNUT CREEK, CALIFORNIA 94596


AUG 04 1982

MEMORANDUM FOR: F. J. Miraglia, Chief, Licensing Branch No. 3,
Division of Licensing, NRR

FROM: J. L. Crews, Director, Division of Resident, Reactor
Projects and Engineering Programs

SUBJECT: DIABLO CANYON MODIFICATIONS

In accordance with your request (memorandum from F. J. Miraglia to J. L. Crews of June 16, 1982) the attached summary of Diablo Canyon modifications is provided for your information. In the future, the summary of modifications will be provided to you on a monthly basis.


J. L. Crews, Director
Division of Resident, Reactor
Projects & Engineering Programs

cc: D. F. Kirsch

8703050170 870226
PDR FOIA
HOLMES86-151 PDR

Q/5

7/22/82

DIABLO CANYON MODIFICATIONS, STATUS OF:

1. 121 Large Bore Pipe Hangers

a. Status as of 7/1/82

Total Received from San Francisco 171

Total Issued to Pullman Power 158

Total Production Completed 127

b. Inspected by NRC as of 7/2/82 57

2. 67 Small Bore (2" and smaller) Pipe Hangers

a. Status as of 7/2/82

Total from G. C. Hng. Group

Rod 49

Annulus 23

Other 4

TOTAL 76

Total Production Completed

Rod 47

Annulus 22

Other 4

TOTAL 73

b. Inspected by NRC as of 7/2/82

Rod Hangers (Vertical Restraint) 38

Annulus Hangers 18

TOTAL 56

3. (Closed) Fan Cooler 1-3 Support #18 Weld Modifications

a. Inspected by NRC as of 2/12/82 and found acceptable.

4. (Closed) 2 Instrument Tubing Supports
 - a. Inspected by NRC as of 2/12/82 and found acceptable.
5. (Closed) ECCS Accumulator Level Transmitter Supports, 4 Large Bore and 3 Small Bore Supports
 - a. Inspected by NRC during week of 4/19/82 and found acceptable.
6. (Closed Electrical Raceway Supports, Detail S-221 (DCO-G-E-2593). 94 Supports in Containment.
 - a. Inspected by NRC during weeks of 3/29 and 4/19/82 and found acceptable.
7. (Closed) Electrical Raceway Supports Detail S-241 (DCO-G-E-2572). Add Brace to 13.
 - a. Inspected by NRC During week of 4/19/82 and found acceptable.
8. (Closed) Electrical, Add 6" W Beam in Annulus
 - a. Status as of 5/28/82. It has been determined following the reverification of raceway supports that this modification: will not be required.
9. (Closed) Electrical, Add S-6 Braces to Raceway Supports Detail S-415 (Unofficial)
 - a. Status as of 3/11/82: It has been determined following the reverification of raceway supports that modifications to support detail 415 will not be required.
10. Electrical Raceway Supports Detail S-102 (DCO-1-E-1278), Add Brace to 16 Supports
 - a. Construction commenced in May 82.
 - b. Inspected by NRC during week of 6/28/82 and found acceptable - 5
11. (Closed) Electrical Raceway Supports Details S-4B, S-226, S-318, S-319, S-235, and S-493 (DCO-1-E-1279), Modify 22 Supports
 - a. Construction commenced in May 82.
 - b. Inspected by NRC during week of 6/28/82 and found acceptable - 22