

# PACIFIC GAS AND ELECTRIC COMPANY

PG&E

77 BEALE STREET • SAN FRANCISCO, CALIFORNIA 94106 • (415) 781-4211 • TWX 910-372-6587

JAMES D. SHIFFER  
VICE PRESIDENT  
NUCLEAR POWER GENERATION

March 3, 1987

PGandE Letter No: DCL-87-040

U.S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, D.C. 20555

Re: Docket No. 50-275, OL-DPR-80  
Diablo Canyon Unit 1  
Licensee Event Report 1-85-014-02  
Reactor Trip and Safety Injection  
Due to Personnel Error


Gentlemen:

Pursuant to 10 CFR 50.73(a)(2)(i) and (iv), PGandE is submitting the enclosed Licensee Event Report revision concerning a reactor trip and safety injection. This revision is being submitted to report the discovery of an additional damaged snubber which resulted from the water hammer that followed the reactor trip addressed in this Licensee Event Report. Revision bars are used to indicate the changes.

This event has in no way affected the public's health and safety.

Kindly acknowledge receipt of this material on the enclosed copy of this letter and return it in the enclosed addressed envelope.

Sincerely,



Enclosure

cc: L. J. Chandler  
J. B. Martin  
M. M. Mendonca  
P. P. Narbut  
B. Norton  
H. E. Schierling  
CPUC  
Diablo Distribution  
INPO

1289S/0049K/RHM/1916

DC1-86-MM-N113

8703110087 870303  
PDR ADOCK 05000275  
S PDR

IE 22  
1/1

IE 22  
1/1