




UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

9 MAR 1987

Docket Nos.: 50-327
and 50-328

LICENSEE: Tennessee Valley Authority
FACILITY: Sequoyah Nuclear Plant
SUBJECT: MINUTES OF FEBRUARY 13, 1987 MEETING TO DISCUSS NUREG-1150

On February 13, 1987, members of the staff met with representatives from the Tennessee Valley Authority (TVA) and several other utilities. The purpose of the meeting was to provide TVA with a preliminary overview of NUREG-1150, "Reactor Risk Reference Document," and describe the Sequoyah results. Enclosure 1 is a list of attendees and Enclosure 2 is a copy of the staff's presentation.


Joseph J. Holonich, Project Manager
PWR Project Directorate #4
Division of PWR Licensing-A

Enclosures: As stated

cc: See next page

8703110300 870309
PDR ADOCK 05000327
P PDR

Docket Nos.: 50-327
and 50-328

9 MAR 1987

LICENSEE: Tennessee Valley Authority
FACILITY: Sequoyah Nuclear Plant
SUBJECT: MINUTES OF FEBRUARY 13, 1987 MEETING TO DISCUSS NUREG-1150

On February 13, 1987, members of the staff met with representatives from the Tennessee Valley Authority (TVA) and several other utilities. The purpose of the meeting was to provide TVA with a preliminary overview of NUREG-1150, "Reactor Risk Reference Document," and describe the Sequoyah results. Enclosure 1 is a list of attendees and Enclosure 2 is a copy of the staff's presentation.

151
Joseph J. Holonich, Project Manager
PWR Project Directorate #4
Division of PWR Licensing-A

Enclosures: As stated

cc: See next page

11/1
PWR#4/DPWR-A
JHolonich/rad
03/6/87

11/1
PWR#4/DPWR-A
BJYoungblood
03/6/87

Mr. S.A. White
Tennessee Valley Authority

Sequoyah Nuclear Plant

CC:
Tennessee Department of Public
Health
ATTN: Director, Bureau of
Environmental Health Services
Cordell Hull Building
Nashville, Tennessee 37219

Regional Administrator, Region II
U.S. Nuclear Regulatory Commission,
101 Marietta Street, N.W., Suite 2900
Atlanta, Georgia 30323

R. W. Cantrell
ATTN: D.L. Williams
Tennessee Valley Authority
400 West Summit Hill Drive, W12 A12
Knoxville, Tennessee 37902

Mr. Michael H. Mobley, Director
Division of Radiological Health
T.E.R.R.A. Building
150 9th Avenue North
Nashville, Tennessee 37203

Mr. Bob Faas
Westinghouse Electric Corp.
P.O. Box 355
Pittsburgh, Pennsylvania 15230

County Judge
Hamilton County Courthouse
Chattanooga, Tennessee 37402

R. L. Gridley
Tennessee Valley Authority
5N 157B Lookout Place
Chattanooga, Tennessee 37402-2801

M. R. Harding
Tennessee Valley Authority
Sequoyah Nuclear Plant
P.O. Box 2000
Soddy Daisy, Tennessee 37379

Resident Inspector/Sequoyah NPS
c/o U.S. Nuclear Regulatory Commission
2600 Igou Ferry Road
Soddy Daisy, Tennessee 37379

H.L. Abercrombie
Tennessee Valley Authority
Sequoyah Nuclear Plant
P.O. Box 2000
Soddy Daisy, Tennessee 37379

MEETING SUMMARY DISTRIBUTION

Docket File

NRC PDR
L PDR
NSIC
PRC System
PWR#4 Reading File
M. Duncan
OGC-Rethesda
J. Partlow
E. Jordan
B. Grimes
ACRS (10)
JZwolinski
SEbnetter
JKeppler

NRC Participants

J. Holonich
B.J. Youngblood
J. Austin
G. Bagchi
T. Novak
C. Tinkler
F. Eltawila
S. Newberry
S. Long
W. Lyon
C. Rossi
B. Morris

bcc: Licensee & Service List

Enclosure 1

ATTENDEES

<u>NAME</u>	<u>ORGANIZATION</u>
Joe Youngblood	NRC/Licensing
Joe Holonich	NRC/Licensing
John Austin	NRC/OCM
R. Gridley	TVA - Nuclear Safety & Licensing
Vince Noonan	NRC/Licensing
Milton Alexich	UP Nuclear OPS/Americal Elec. Power
Goutam Bagchi	NRC/NRR/Engineering Branch
D.R. Nichols	TVA/OGC
N.J. Liparulo	Westinghouse Electric
J.L. Milhoan	NRC/OCM
Mike Harding	TVA/Sequoyah
D.W. Wilson	TVA/Sequoyah Project Engineer
J.D. Smith	TVA/Sequoyah
Ken Keith	TVA/DNE/NEB
Robert Galante	TVA/DNE
T.M. Novak	NRC/PWR-A
C. Fox	TVA/ONP
C. Tinkler	NRC/NRR
Farouk Eltawila	NRC/DSRO/RIB
Frank Carson	TVA/Public Information
William Hannum	TVA - Chairman, NSRB
Scott Newberry	NRC/NRR
Steve Long	NRC/NRR
Warren Lyon	NRC/NRR/PWR-A
Wang Lau	TVA/Systems Engineering
C.E. Rossi	NRC/NRR/PWR-A
Allan S. Benjamin	Sandra National Labs
Bill Morris	NRC/RES/DRSS
Joe Murphy	NRC/RES/DRSS
R.O. Sharpe	Duke Power Company
T.A. Ippolito	TVA Licensing

ENCLOSURE 2

METHODOLOGY

- o ABBREVIATED ANALYSIS OF FREQUENCY OF SEVERE ACCIDENTS, EMPLOYING INSIGHTS FROM PREVIOUS STUDIES TO ALTER DEPTH OF ANALYSIS.
- o EXTREMELY DETAILED CONTAINMENT EVENT TREES,
- o ANALYSIS OF SEVERE ACCIDENT PHENOMENOLOGY USING STATE-OF-THE-ART TOOLS,
- o CONSEQUENCE ANALYSES EMPLOYING IMPROVED MODELING AND LATEST HEALTH EFFECTS MODELS,
- o RISK ESTIMATION WITH COMPREHENSIVE UNCERTAINTY ANALYSES

Table D.13 Ranges of Risk Parameters



Risk Measure	Lower Bound	Upper Bound
Early Fatalities (/r-yr)	3.5×10^{-6}	3.1×10^{-4}
Individual Risk of Early Fatalities (/r-yr)	1.4×10^{-8}	3.1×10^{-7}
Latent Cancer Fatalities (/r-yr)	4.3×10^{-2}	5.1×10^{-1}
Early Injuries (/r-yr)	3.6×10^{-5}	2.0×10^{-3}
Population Dose Within 50 miles (person-rem/ r-yr)	106.	906.
Offsite Costs (\$/r-yr)	4721.	155500.

(r-yr) = reactor year of operation

Table D.3 (Continued)

Issue	Description of Sensitivity Study ^a	Total Core Damage Frequency
10. Recovery from Small LOCAs	Assume that blowdown of the steam generator secondary is a viable recovery procedure for small LOCAs with failure of high pressure injection where AFW is available.	8.4 x 10 ⁻⁵
11. ECCS Operability Following Containment Failure	Assume that ECC systems fail following containment failure.	1.2 x 10 ⁻⁴
12. Common-Cause Failure Rates	Use alternative (more pessimistic) interpretation of beta factors for common-cause failure rates.	1.8 x 10 ⁻⁴
13. Common-Cause Failure Rates	Eliminate the use of beta factors in modeling common-cause failure rates.	5.4 x 10 ⁻⁵
14. Check Valve Failure Rates	Use a more optimistic distribution for failure rates of check valves in interfacing systems LOCA sequences.	1.2 x 10 ⁻⁴ (a)
15. Check Valve Failure Rates	Use a more pessimistic distribution for failure rates of check valves in interfacing systems LOCA sequences.	1.1 x 10 ⁻⁴

(a) The change in mean total core damage frequency in this sensitivity case is considered to represent expected variation with a statistical sampling code and is not indicative of the impact of the modified parameters.



PLANT
DAMAGE STATES

DESCRIPTION

S2NNNT

Loss of component cooling water system, causing ECCS, containment heat removal and spray failure.

S2NNNN

Small LOCA with failure of ECCS and containment systems due to failure of AC power.



S2YYYY

Reactor coolant pump seal LOCA with failure of ECCS in recirculation. Containment heat removal, sprays and AC power available.

TNNNN

Transient with loss of all AC power. All ECCS and containment systems unavailable.

Figure 7.12 Contributions of plant damage states to Sequoyah risk



BIN 1 Reactor vessel pressure intermediate to high. Fans and sprays not operating. Cavity dry at vessel breach and ice present.

BIN 7 Reactor vessel pressure intermediate to high. Fans operate, sprays do not. Cavity dry at vessel breach. Ice present at vessel breach.



BIN 13 Early containment failure. Reactor vessel pressure intermediate to high. Fans operate, sprays do not. Cavity flooded at vessel breach. Ice present at vessel breach. Core-concrete interactions delayed one day.

BIN 13 Containment failure several hours after vessel breach at high or intermediate pressure. Containment sprays failed, but fans working.

BIN 21 Late containment failure. Containment sprays continue to operate. No coolable debris bed.

Figure 7.13 Contributions of containment failure bins to Sequoyah risk

Relative Contribution of Isotope Groups to Early Fatality Consequences



Relative Contribution of Isotope Groups to Latent Fatality Consequences








Figure D.8 Relative Contribution of Isotope Groups to
Early and Latent Fatality Consequences

Large Release Probability



Individual Risk of Early Fatality



Early Containment Failure probability





Figure D.13 (Continued)



D-47




Figure D.11 Comparison of Costs and Averted Risk for Preventive Options




Figure D.12 Comparison of Costs and Averted Risk for Mitigative Options





Figure 7.11 NUREG-1150 complementary cumulative distribution function for Sequoyah plant




Figure 3.6 "Box-and-whisker" display of uncertainties for core damage frequency at Sequoyah





Figure 7.14 Comparison of Sequoyah internal event risk with safety goals

Sequoyah Probability of Large Release




Table D.3 Sensitivity Studies for Core Damage Frequency Analysis

Issue	Description of Sensitivity Study ^a	Total Core Damage Frequency
	BASE CASE	1.0×10^{-4}
1. RCP Seal LOCA	Decrease the probability of an RCP seal LOCA following station blackout sequences to 0.05. Also, increase the probability of recovery from a RCP seal LOCA during TCCW to 0.10.	7.5×10^{-5}
2. RCP Seal LOCA	Assume a seal LOCA occurs 1/2 hr after loss of all seal cooling and that recovery of AC power within 1 hr of the seal LOCA prevents core damage.	1.1×10^{-4}
3. RCP Seal LOCA	Assume the size of a RCP seal LOCA is 1/4 the size assumed in the base case. The time for recovery of HPI flow was increased from 1 hr to 2 hr.	1.0×10^{-4}
4. Recovery of AC Power	Use alternative (more optimistic) set of data for experience in recovery of offsite electric power.	1.0×10^{-4}
5. Steam Binding of Aux. Feedwater Pumps (AFW)	Assume an increased probability of common mode failure of all AFW pumps due to steam binding.	$1.5 \times 10^{-4(a)}$
6. Loss of Component Cooling Water (CCW)	Assume only one CCW pump is sufficient to service the cooling loads for both Sequoyah units, rather than one for each unit as in the base case.	5.8×10^{-5}
7. Recovery from Loss of CCW	Assume 70-95 percent of loss of CCW sequences are recoverable.	6.3×10^{-5}
8. Feed and Bleed Success Criteria	Assume one PORV is sufficient to provide cooling under loss of feedwater conditions.	1.0×10^{-4}
9. Requirement for Recirculation Cooling After an S ₂ Initiator	Assume that for 75 percent of S ₂ LOCAs, containment sprays are not actuated.	8.5×10^{-5}




Figure D.1 Ranges of Core Damage Frequency - Sequoyah

TOTAL CORE DAMAGE FREQUENCY




Figure 3.5 Principal contributors to core damage frequency at Sequoyah