

ORIGINAL

ACRST-3083

OFFICIAL TRANSCRIPT OF PROCEEDINGS
NUCLEAR REGULATORY COMMISSION
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

Title: MEETING: PLANT LICENSE
RENEWAL

TRO4 (ACRS)
RETURN ORIGINAL *only*
TO BJWHITE *Do not*
M/S T-2E26 *send*
415-7130 *copies!*
THANKS!

Docket No.:

Work Order No.: ASB-300-839

LOCATION: Rockville, MD

DATE: Wednesday, June 30, 1999

9907080372 990630
PDR ACRS
T-3083

PDR

PAGES: 1 - 197

070182

ANN RILEY & ASSOCIATES, LTD.

1025 Connecticut Avenue, NW, Suite 1014
Washington, D.C. 20036

ACRS Office Copy - Retain
for the Life of the Committee

ORIGINAL

ACRST-3083

OFFICIAL TRANSCRIPT OF PROCEEDINGS
NUCLEAR REGULATORY COMMISSION
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

Title: MEETING: PLANT LICENSE
RENEWAL

TRO4 (ACRS)
RETURN ORIGINAL *only*
TO BJWHITE *Do not*
M/S T-2E26 *send*
415-7130 *Copies!*
THANKS!

Docket No.:

Work Order No.: ASB-300-839

LOCATION: Rockville, MD

DATE: Wednesday, June 30, 1999

PAGES: 1 - 197

9907080372 990630

PDR ACRS

T-3083

PDR

070182

ANN RILEY & ASSOCIATES, LTD.

1025 Connecticut Ave., NW, Suite 1014

Washington, D.C. 20036

(202) 842-0034

ACRS Office Copy - Retain
for the Life of the Committee

DISCLAIMER

UNITED STATES NUCLEAR REGULATORY COMMISSION'S
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

JUNE 30, 1999

The contents of this transcript of the proceeding of the United States Nuclear Regulatory Commission Advisory Committee on Reactor Safeguards, taken on June 30, 1999, as reported herein, is a record of the discussions recorded at the meeting held on the above date.

This transcript had not been reviewed, corrected and edited and it may contain inaccuracies.

1 UNITED STATES OF AMERICA
2 NUCLEAR REGULATORY COMMISSION
3 ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

4 ***

5 MEETING: PLANT LICENSE RENEWAL

6
7 U.S. NRC

8 Two White Flint North

9 Room T2-B3

10 11545 Rockville Pike

11 Rockville, MD

12 Wednesday, June 30, 1999

13
14 The subcommittee met, pursuant to notice, at 8:30
15 a.m.

16 MEMBERS PRESENT:

17 MARIO BONACA, Chairman, ACRS

18 THOMAS S. KRESS, Member, ACRS

19 ROBERT SEALE, Member, ACRS

20 WILLIAM SHACK, Member, ACRS

21 ROBERT UHRIG, Member, ACRS

22
23
24
25
ANN RILEY & ASSOCIATES, LTD.
Court Reporters
1025 Connecticut Avenue, NW, Suite 1014
Washington, D.C. 20036
(202) 842-0034

P R O C E E D I N G S

[8:30 a.m.]

CHAIRMAN BONACA: Good morning.

The meeting will now come to order.

This is a meeting of the ACRS Subcommittee on Plant License Renewal.

I am Mario Bonaca, Chairman of the subcommittee.

ACRS members in attendance are Dr. George Apostolakis -- actually, he's on his way, I guess -- Thomas Kress, Robert Seale, Bill Shack, and Robert Uhrig.

The purpose of this meeting is for the subcommittee to review the NRC staff's Safety Evaluation Report related to the Oconee license renewal application, crediting of existing programs, and related matters.

The subcommittee will gather information, analyze relevant issues and facts, and formulate proposed positions and actions as appropriate for deliberation by the full committee.

Mr. Noel Dudley is the cognizant ACRS staff engineer for this meeting.

The rules for participation in today's meeting have been announced as part of the notice of this meeting previously published in the Federal Register on June 1, 1999.

A transcript of this meeting is being kept and

1 will be made available as stated in the Federal Register
2 notice.

3 It is requested that speakers first identify
4 themselves and speak with sufficient clarity and volume so
5 that they can be readily heard.

6 We have received no written comments or requests
7 for time to make oral statements from members of the public.

8 On June 16, 1999, the NRC staff completed the
9 Safety Evaluation Report for the Oconee license application.
10 This is the second Safety Evaluation Report for a license
11 renewal application.

12 The report identifies only three items that must
13 be resolved for the staff to complete the evaluation. The
14 open items include the basis for excluding specific
15 structures and components from an aging management review,
16 applicability of certain aging effects to structures and
17 components, and the need for additional periodic
18 inspections.

19 The Safety Evaluation Report also identifies six
20 confirmatory items that involve documentation of certain
21 information or commitments.

22 The ACRS plans to review and comment on the Safety
23 Evaluation Report at its September 1999 meeting.

24 On June 3, 1999, the staff issued a Commission
25 paper identifying options for crediting existing programs

1 for license renewal. ACRS plans to review and comment on
2 crediting existing programs at its July 1999 meeting.

3 This is just one example of the license renewal
4 policy issues that the staff is evaluating and that the
5 subcommittee plans on considering.

6 We will now proceed with the meeting, and I call
7 upon Mr. Christopher Grimes, Chief of the License Renewal
8 and Standardization Branch, to begin.

9 MR. GRIMES: Thank you, Dr. Bonaca.

10 We're very pleased to be here today.

11 The NRC staff is prepared to respond to the
12 committee's questions concerning both the basis for the
13 staff's review of the Oconee license renewal application,
14 and also, this is different from Calvert Cliffs to the
15 extent that Duke Energy refers to B&W topical reports that
16 establish generic bases for aging management programs, and
17 so, we're also -- we have also arranged on the agenda to
18 speak to the topical report reviews and to discuss the basis
19 for the staff's evaluation of those reports, as well, and as
20 you mentioned, we have designated time on the schedule after
21 we've discussed Oconee to discuss the staff's paper on the
22 generic issue associated with credit for existing programs,
23 and we'll cover that topic when we've finished with the
24 Oconee presentations.

25 Beyond that, we're here prepared to answer

1 questions, and we've arranged for specific members of the
2 NRC staff to make presentations on the material covered in
3 all three of those areas.

4 Thank you.

5 CHAIRMAN BONACA: Thank you.

6 The Duke staff -- we have a presentation on the
7 topical reports, actually the specific BAW-2251.

8 MR. ROBINSON: Good morning.

9 I am Greg Robinson. I am the Project Manager for
10 Oconee license renewal, and on behalf of Duke and our
11 Framatome Technology gentlemen here, I appreciate the
12 opportunity to come share this information with you.

13 I'm going to take just a few minutes and give you
14 an acclamation and overview of the project and how the
15 topical reports fit into the Duke application. Then I'll
16 turn it over to our Framatome colleagues, who will give you
17 the details of the reactor vessel report.

18 Also, this afternoon, in your hand-out package
19 that you have in front of you is the remainder of the
20 presentation materials for the afternoon session. It will
21 be a short session that we will cover, and we put all the
22 information in the one hand-out.

23 This morning, Mark Rinckel from Framatome will
24 take the lead on a bulk of the reactor vessel material.
25 Matt Devan is here, Ken Yoon is here, and Bob Gill will then

1 give us an overview of how the owners group topical
2 information fits into the application itself.

3 Paul Colaianni will cover the afternoon session
4 for us.

5 A little background on Oconee: Oconee Nuclear
6 Station began construction in the late 1960s and completed
7 construction in the early 1970s, a three-unit site, 2,538
8 mega-watts, initial capital cost around \$500 million.
9 Commercial operation began in 1973 for units one and two and
10 1974 for unit three. The initial licenses obviously expire
11 40 years later, in 2013 and '14, and about 1,300 people are
12 employed on-site.

13 Here is an aerial of the Oconee site. It's set in
14 northwestern South Carolina in the foothills of the
15 mountains, on a peninsula out in the lake, Lake Keowee. So,
16 you can see the three units there, and you're looking from
17 the discharge out over the plant -- or, excuse me, the
18 intake out over the plant.

19 Before Mark gets into the details of the owners
20 group work, I thought it would be fair to show you just how
21 long ago we began to work on the technical information that
22 ultimately ended up in the application.

23 You can see, back in the mid-'80s, there were a
24 number of technical reports, the lead plant work that you're
25 all familiar with, a scientific perspective on aging and

1 aging phenomena, a good bit of research going on both in the
2 industry and by the NRC.

3 The focus was on aging mechanisms at that point in
4 time.

5 The time-line here is meant to show you the
6 progression in thought over the last 15 years, where you can
7 see we've evolved from more of a scientific thought process
8 into more of a practical engineering end point that we were
9 ultimately able to use and put in the Oconee application,
10 and I hope you'll be able to see that today.

11 I won't go through each of the areas. I'm sure
12 you're very familiar with them.

13 I will point out that the Oconee efforts really
14 began back in the same time period, in the mid-'80s, where
15 we were a participant in the industry efforts and then,
16 later, in the owners group efforts and ultimately got to the
17 1998 submittal in July of last year.

18 Current project status, just to acclimate us again
19 here this morning -- I think you hit most of this in your
20 introduction this morning -- safety responses to RAI's were
21 completed, and the safety evaluation was issued just a few
22 weeks ago.

23 The environmental area, the Draft Oconee
24 Supplemental Environmental Impact Statement was issued the
25 end of May.

1 There is a public meeting on that in the
2 Clemson-Oconee area here next week, and then, in the
3 hearings area, the NRC commission has affirmed ASOB's
4 decision to deny the petition of our potential intervenor,
5 and that was done in April of this year.

6 I showed you the time-line, the progression of
7 thought over the last 15 years, and I thought it fair to
8 give you another little rule of thumb as we get into the
9 technical details of the vessel report.

10 One of the things that we began to notice when we
11 put together the initial B&W's owners group reports was we
12 were beginning to see a pattern emerge, and the pattern
13 ended up fitting into this equation, and the pattern was, if
14 we can define the component and its materials of
15 construction, we understand where it's located in the plant,
16 then we can understand the aging of that component,
17 material, environment, stress conditions.

18 Then we can look and see if we have programmatic
19 action that can manage that material/aging combination. If,
20 for example, those programs had been in existence for a good
21 long time, there ought to be demonstrable evidence that the
22 programs work or they don't work or they've self-corrected,
23 and all of that taken collectively gives us assurance that
24 we have something that will continue to serve us on into the
25 future.

1 That was written in many, many words in many, many
2 technical reports.

3 What we did for ourselves is boil it out into this
4 rule of thumb to give us the confidence that, each time, we
5 could measure back against the standard, making sure that we
6 had covered each of the aspects of this in our integrated
7 plant assessment.

8 The other area that Mark will touch on with the
9 vessel and that we certainly touched on completely in the
10 application was the time limit that aging analysis, the
11 boundary conditions on the initial design that we had to
12 investigate.

13 Begin to progress toward the owners group topicals
14 and how they fit into our application.

15 We divided the application work, the development
16 work, into five areas. We covered the reactor coolant
17 system, which is where the B&W owners group topicals fit, as
18 a separate area, for a couple of reasons.

19 One, it was an important area of focus for us. It
20 demanded a lot of additional attention, we felt, and also,
21 that is where the owners group work fit back in. So, when
22 the match line between the owners group work and the Duke
23 work -- we wanted to be very clear that we didn't miss
24 something. So, we delineated that area.

25 The reactor containment was another area that we

1 felt needed special attention.

2 Radiological line of defense -- we broke it out as
3 a separate area from the remainder of the structures, so
4 that we could study it. Then the other three areas were the
5 classical discipline areas -- mechanical, electrical, and
6 structural.

7 So, today, we're here to focus on the reactor
8 coolant system and, more specifically, on the reactor
9 vessel.

10 Here are the reactor coolant system components,
11 just to give you a feel for how they break down. You'll see
12 the piping, pressurizer vessel, and reactor internals and,
13 beside them, some small notation.

14 Those were the technical -- or, excuse me, topical
15 reports from the owners group that we submitted to the staff
16 for approval over time. They absolutely equal the
17 information that's over in our application for the piping
18 pressurizer vessel and internals.

19 We also developed through the owners group
20 additional information for the remainder of the components.
21 We did not submit that for approval, but we did use it in
22 the Oconee application.

23 You'll see there's a safety evaluation for piping,
24 the pressurizer, the reactor vessel, and a draft safety
25 evaluation recently issued for the reactor internals, and

1 today, we're here to give you the details of BAW-2251, and
2 with that, I'll turn it over to Mark Rinckel from Framatome,
3 who will give us the details.

4 MR. RINCKEL: Good morning.

5 My name is Mark Rinckel. I'm from Framatome
6 Technologies. I've been the project engineer, generic
7 license renewal project engineer since approximately 1993.
8 I have Matthew Devan here, who is an expert in our materials
9 area, on our surveillance program, and Ken Yoon to assist me
10 in the fracture mechanics area.

11 So, I will proceed to give you a summary of 2251,
12 and the topics I'd like to go over today are who the
13 participating plants were in the report, the contents of the
14 reactor vessel report, basically how it's divided into the
15 various chapters of our report, the scope, which tells about
16 the component, the aging effects, how we came upon the aging
17 effects for the reactor vessel, the demonstration of aging
18 management, which would be the programs that we credit for
19 those aging effects, and the time-limited aging analyses,
20 which in my mind are really the crux of the reactor vessel
21 report, because it deals with all the reactor vessel
22 embrittlement issues. We'll finish it up with the
23 conclusions.

24 Now, the participants in our program include ANO
25 unit one, Oconee units one, two, and three, and TMI unit

1 one. Crystal River unit three and Davis-Besse unit one were
2 not participants in our generic program in the reactor
3 vessel report.

4 All of our plants are similar in design. They're
5 177 fuel assembly lowered-loop plants, and all of the
6 operating licenses expire somewhere between 2013 and 2016.

7 So, because of the similarity in the design and
8 construction, it certainly lends itself to generic report
9 treatment.

10 Now, as Greg had mentioned before, the basic
11 formula that we follow in almost all of our report was
12 establishing an RCS piping report, and I saw Sam Lee here
13 earlier, and he was instrumental in helping in the iteration
14 process in developing how we go about doing these
15 evaluations, and basically, the first thing we do is the
16 first bullet, is we define the intended functions of the
17 component, and for the reactor vessel, there are two
18 intended functions, one of them being maintain RCS pressure
19 boundary and the other one being to support the internals.
20 We find that through going through our design specs,
21 equipment specs as the designer. So, we define those two
22 functions.

23 The next thing we do is to provide a description
24 of the component, including materials of construction, and
25 this was fun for me, because when most of these components

1 were fabricated, I was in elementary school. So, I had to
2 go back and understand the construction and see how all
3 these things were put together, and the objective there is
4 really to find -- you know, to define the component
5 materials of construction and really go through the
6 fabrication part, and that was a lot of fun for me, because
7 you know, we seem to have lost some of that technology as
8 time has gone on.

9 DR. KRESS: Did you have sufficient records that
10 you could find the material?

11 MR. RINCKEL: Yeah, we did. We had -- all the QA
12 data packages were in our records system, and then, when I
13 got stumped, I'd go downstairs to the component engineers,
14 who were in Mt. Vernon when these things were fabricated,
15 and I'd ask them, and I found that they were usually the
16 best source of information.

17 DR. KRESS: But QA is worth something.

18 MR. RINCKEL: Yes, it is, even back to the
19 1968-1970 timeframe.

20 So, that's really chapter two of our report, is
21 providing the description of a component.

22 Chapter three of four report is to define the
23 applicable aging effects, and again, we look at material
24 construction, we look at operating environment, and we look
25 at level A and B service conditions. Those are normal and

1 upset conditions.

2 Those are the normal aging stresses of the
3 component. We did not assume emergency and faulted
4 conditions, as that is not a normal aging stresser.

5 So, the assessment of aging effects is very much
6 qualitative in this whole process, and again, that whole
7 process was established through our first report, which was
8 the RCS piping report.

9 Once we've defined the aging effects for the
10 component and the various items, then we look at the
11 programs that manage those aging effects. One of the
12 primary programs is ASME Section XI. There are other
13 programs, forecast and wastage program, Matthew's
14 surveillance program for reduction of fracture toughness and
15 so forth. I will get into that in more detail a little bit
16 later.

17 The last item is to evaluate the time limited
18 again analyses, includes the upper shelf energy, lots of the
19 reduction of fracture toughness in the belt-line region.

20 So, that's the basic outline for the report.

21 DR. KRESS: Was Oconee one of the plants that was
22 used in the original pressurized thermal shocks?

23 MR. RINCKEL: I believe it was.

24 MR. YOON: Ken Yoon from Framatome Technologies.

25 In the initial 1980 period, one of three plants

1 was Oconee 1, Oconee unit one.

2 MR. RINCKEL: All of the vessels within the scope
3 of this report were designed in accordance with ASME Section
4 III, 1965 edition, 67 addenda.

5 We have found it very convenient in our report to
6 describe the various components in chapter two of our
7 report, really in accordance with the ASME Section XI
8 examination categories.

9 For instance, we would divide it into groups.

10 Examination category BA can include the reactor
11 vessel shell enclosure head.

12 Reactor vessel nozzles would be examination
13 category BD. That included the inlet-outlet nozzles, core
14 flood nozzles, in-core monitoring system nozzles, and CRDM
15 penetrations at the top of the vessel.

16 The reactor vessel interior attachments,
17 examination category BN-1 -- those are the core guide lugs,
18 and the last item would be pressure retaining closures,
19 which would be the closure head and the CRDM closure at the
20 top.

21 Now, the reactor vessel shell and closure head
22 I'll point out here. These are all fabricated from
23 low-alloy steel, either A508 class two forgings or they're
24 A533, was a grade B, plate or a 302 plate. The closure head
25 and the shell are about 14-foot inner diameter, 37-foot

1 high. They're shown here.

2 These are all clad on the interior surface with
3 Austin stainless steel. They were put in with a weld
4 deposit submerged arc process, usually a two-wire or a
5 six-wire process, which would be a high heat input process
6 was used for cladding the interior surface of the vessel
7 shell and the vessel head. That's the first item.

8 These shells were usually about six-foot sections
9 that were welded using an automatic submerged arc process,
10 using a Linde 80 flux weld wire that was coated with copper.

11 At the time of construction back in the late '60s,
12 the copper was put on the weld wire to preclude rusting of
13 the weld wire, and we didn't know at that time that it would
14 result in accelerated reduction of fracture toughness.

15 So, many of our welds, most of the welds in the
16 belt-line region, are Linde 80 welds that have some copper
17 in them, a little bit more than they probably would without
18 the coating, and therefore was the beginning of our
19 surveillance program that Matthew will talk about later.

20 So, that's the shell and the closure head.

21 DR. SHACK: It's clad with stainless steel.
22 There's 82-182 pads underneath the core guide lugs. Is that
23 the only place that you have the 82-182 on the shell?

24 MR. RINCKEL: Yeah, that's right. These are
25 alloy-600 guide lugs, and they're connected to the cladding

1 with 82-182 weld material. So, that's the only place in the
2 vessel where there's 82-182 weld material.

3 DR. SHACK: Now, are they welded to the cladding,
4 or there's an 82-182 deposit on the shell and then they're
5 welded to that?

6 MR. RINCKEL: I believe they're welded to the
7 cladding, to the stainless cladding, but there is a stress
8 evaluation done to show that -- I mean the purpose of those
9 guide logs is to catch the internals, should there be a
10 fracture of the core barrel up near the ledge, and so, it's
11 designed to accept about a quarter-inch drop, and it's
12 blended in with the cladding, but it is a structural weld
13 that's able to withstand that weight.

14 DR. SHACK: Okay. So, it's not sustaining load
15 most of the time.

16 MR. RINCKEL: There's nothing on it.

17 DR. SHACK: It's really just a catcher.

18 MR. RINCKEL: It's a catcher, and the purpose of
19 that is, if the internals should drop down, is to catch it
20 to prevent the internals from going down to the bottom of
21 the vessel and therefore taking some of the control rods out
22 of the active fuel region. That's the whole purpose of the
23 guide logs.

24 DR. SHACK: Then the only other alloy-600 and
25 82-182 weldments would be at the penetrations for the

1 instrumentation and the drives.

2 MR. RINCKEL: That's right. The nozzles up top,
3 which would be the control rod CRDM nozzles, which would be
4 these up here, are all alloy-600, and then the in-core
5 monitoring system nozzles down at the bottom are alloy-600.

6 So, that's the inconel or alloy-600 that you have
7 in the vessel.

8 DR. SHACK: Thank you.

9 DR. UHRIG: How thick is the wall, pressure
10 vessel?

11 MR. RINCKEL: The shell region is about 8 1/2
12 inches in the belt-line, and then it increases to
13 approximately 12 1/2 inches where the nozzles enter the
14 vessel, and the head, the flanges are approximately 24
15 inches.

16 The heads -- the bottom head and the top head are,
17 I think, about 4 1/2 to 5 inches thick, and those are made
18 from plate, both the top and the bottom head are plate.

19 DR. UHRIG: So, the head is about 7 inches.

20 MR. RINCKEL: About 7 inches, yeah.

21 We have two outlet nozzles, 36-inch diameter, all
22 clad with stainless steel. Those are forgings, 508
23 forgings.

24 We have four inlet nozzles that are 28-inch inner
25 diameter, again 508 forgings clad with stainless steel, two

1 core flood nozzles that are approximately 10-12 inch inner
2 diameter, again 508 forgings clad with stainless steel, and
3 then we just talked about the alloy-600 penetrations which
4 are at the top and bottom of the vessel.

5 Now, the alloy -- I don't have this in the packet,
6 but since you're interested in the alloy-600, we had
7 problems with the original configuration of the in-core
8 monitoring system pipes down at the bottom of the vessel.

9 They were three-quarter-inch Schedule 160 pipes
10 that extended through the bottom head and met up with the
11 internals package so that the in-core monitoring system
12 would go up and through there.

13 In hot functional testing in Oconee unit one,
14 those all broke off, and so, these pipes here, the pipe
15 through the bottom would extend all the way up, and those
16 all broke off right in that vicinity there, and what we had
17 to do was make a reinforcement to increase the strength of
18 this so that it would not break under the flow conditions at
19 the bottom of the vessel, and those were all done after the
20 -- again, after hot functional testing was completed at
21 Oconee unit one.

22 That made it bigger, made it stronger, but that's
23 really the only major problem that we have had with the
24 vessel to date. We've had, really, very little problems.

25 DR. SHACK: Do you have cracking in your

1 instrumentation nozzles?

2 MR. RINCKEL: Not that we know of, and they do a
3 visual inspection of those, VT-3, every interval, and to my
4 knowledge, they have not seen any, and we have not had any
5 leak at present, and of course, they are at the bottom of
6 the vessel, so they are at about 550 degrees, which is a
7 lower temperature and, therefore, less susceptible to PWSCC
8 than the penetrations, probably, at the top, since
9 temperature does play a factor in that, even though they
10 would be susceptible to cracking by PWSCC.

11 DR. SHACK: You do a VT-3 on those, but in the
12 license renewal application, you're going to do at least a
13 one-time VT-1 enhanced?

14 MR. RINCKEL: That was not discussed in there, no.
15 The only thing that we would -- that we committed to in our
16 report was to continue the inspections that we would commit
17 to as part of Generic Letter 97-01, and those included the
18 closure head penetrations and not the bottom head
19 penetrations, but the alloy-600 -- all of the alloy-600 in
20 the loop is within the Ocone alloy-600 program, and that
21 requires some additional looking for the most susceptible
22 components.

23 So, Ocone took an approach where they looked at
24 all of the alloy-600 items, and they said, okay, let's
25 catalog these and find out which are the most susceptible to

1 PWSCC and then we will look at the top five locations. To
2 my knowledge, that IMS nozzle did not come up as one of the
3 top five locations.

4 DR. SHACK: That's the way you do it; you look at
5 the limiting component --

6 MR. RINCKEL: That's right.

7 DR. SHACK: -- in the inspection.

8 MR. RINCKEL: Yes.

9 DR. SHACK: And what can you actually see with the
10 VT-3?

11 MR. RINCKEL: Well, you can see if there's
12 cracking there, not fine cracks, obviously, you'd have to
13 have pretty good size cracks. I think you can see if there
14 is any cladding missing, if there's any, perhaps, cracks big
15 enough to extend to the base metal where you can see some
16 rust or something there.

17 So, that is what you can see, and you only really
18 do a VT-3 of the reactor vessel internals and the interior
19 surfaces of the vessel itself.

20 Anyway, the other thing that we typically do is,
21 based on the functions -- and I'll put this back -- we
22 identify what items we will subject -- that will be subject
23 to aging management review based on the functions that they
24 -- whether they support an intended function, and there are
25 a couple items that were sent with the vessel to the Ocone

1 units that are not -- do not support an intended function,
2 that are not subject to review.

3 One of them would be the monitoring pipes, which
4 are there to detect leakage. These items don't support the
5 pressure boundary and are not subject to review.

6 The other item that's not subject to review is the
7 seal ledge on the outside. It does not support the pressure
8 boundary function.

9 And the other items that were -- are subject to
10 review that weren't in the scope of the report are the lower
11 CRDM service support structure and the lower portion of the
12 reactor vessel skirt.

13 Now, those items we simply chose not to include in
14 the scope of the report, because we, in general, were
15 consistent with the IWB inspection boundary. Those aren't
16 inspected in accordance with IWB, so we simply didn't
17 include them, and Oconee would then have to evaluate them in
18 the plant-specific application.

19 So, that's what's in the report, what's not in the
20 report, what's subject to review, what's not subject to
21 review.

22 Once we have the component, the materials of
23 construction, we look at the operating environment, the
24 operating stresses, which are service levels A and B, and we
25 determine the applicable aging effects, and again, it was

1 easy for us to group them.

2 Examination category BA, which are reactor vessel
3 shell enclosure head -- we looked cracking, where would
4 cracking occur at welded joints, why would that be the case,
5 growth of pre-service flaws, fatigue. Fatigue would be
6 time-limited aging analysis.

7 The external surfaces of the shell enclosure head
8 could be subject to loss of material, boric acid wastage,
9 could have leakage at the closures, bolted closures. So, we
10 looked at loss of material.

11 Reduction of fracture toughness in the belt-line
12 region.

13 The last one, growth of inter-granular
14 separations, and I'll get into growth of inter-granular
15 separations with -- the easiest to show is a figure of it
16 here.

17 That was a time-limited aging analysis. We found
18 this when we went back to the early 1970s, when the
19 components were fabricated and licensed. We found a
20 fracture mechanics analysis that was done for this, and so,
21 we had to evaluate it.

22 DR. SHACK: There's absolutely no consideration of
23 stress corrosion cracking of the low-alloy steel.

24 MR. RINCKEL: That's correct. We did not do that,
25 because there was no indication that that's occurred for any

1 of the primary system components, and you also have
2 cladding.

3 DR. SHACK: Okay. I guess that was my question.
4 Is that because you felt that, in this environment, the
5 material would -- the low-alloy steel, even if exposed,
6 would be resistant --

7 MR. RINCKEL: Yes.

8 DR. SHACK: -- or you're simply relying on in the
9 integrity of the cladding, that it will never get exposed?

10 MR. RINCKEL: I think both.

11 I mean, if you go back, the only aging effect that
12 we said would crack welded joints would be to the
13 pre-service flaws, and that is why you look at the joints
14 now, is that those things may be there and they may grow
15 over time, and so, we dismissed stress corrosion cracking of
16 the low-alloy steel cladding, and even if it were exposed to
17 borated water in this environment, we do not feel that
18 stress corrosion cracking would be a mechanism, and plus,
19 that's one thing I liked about the rule that changed, is
20 that you talk about cracking and the mechanisms, and you
21 know, we could argue a long time about those, but the fact
22 that we have said we would -- it's possible that we would
23 crack the welded joint, and what do you have there to look
24 for?

25 So, the aging effects we looked at, again for the

1 shell enclosure head, are listed there.

2 This figure shows the reactor vessel shell region
3 in the welded joints for Ocone unit two, again cracking at
4 the welded joints, but we had to look at reduction of
5 fracture toughness and where on this shell reduction of
6 fracture toughness would be applicable.

7 The traditional belt-line region -- and I'll show
8 it to you in just a second -- is primarily the regions of
9 the shell that are adjacent to the active fuel assemblies,
10 and I'll show you right here.

11 So, that portion of the shell is the traditional
12 belt-line region, and that includes the lower -- the
13 intermediate shell and the lower shell and the welds that
14 connect those shells together, the little portion of the
15 nozzle belt region, which is a forging on the top, and then
16 this region right down at the bottom here with the
17 transition forging.

18 DR. SEALE: Those are all ring castings?

19 MR. RINCKEL: Those are all ring forgings, not
20 castings.

21 DR. SEALE: I mean forgings.

22 MR. RINCKEL: Yes, sir.

23 Now, unit one is different from units two and
24 three. Unit one has a plate that's -- two plates to make
25 the cylinders, and that's 302 plate, and units two and three

1 have 508 forgings.

2 DR. UHRIG: There is some longitudinal welds on
3 unit one.

4 MR. RINCKEL: Unit one does have some axial welds,
5 yes, sir.

6 Now, the belt-line region, as I said, is
7 traditionally those regions that are just adjacent to the
8 active fuel assemblies, and then the question for license
9 renewal is would the belt-line region grow and would it, in
10 fact, grow up and include some of the weld that includes --
11 that connects the nozzles to the nozzle belt region, and the
12 nozzles are subjected to different loads than the shell,
13 because it basically supports the weight of the piping.

14 So, you have discontinuities where the nozzle
15 comes into the nozzle shell and also piping loads under
16 design basis conditions.

17 We looked at estimating what the fluence would be
18 up in that region, and it was above 1 times 10 to the 17th,
19 which is the number that says that you need to have that
20 type of material in the surveillance program. At present,
21 we don't have that material, that specific material in our
22 surveillance program.

23 So, what we did is we had Dr. Yoon do a fracture
24 mechanics analysis for that particular region to see if, in
25 fact, it was more limiting than the shell region of the

1 belt-line. It was not.

2 Therefore, we could dismiss that region as not
3 being limiting and therefore not within the belt-line
4 region, and the classical belt-line definition for -- that
5 we have used for 32 effective full-power years was also
6 applicable to 48.

7 So, we were able to narrow the region where a
8 reduction of fracture toughness was applicable to the
9 classical belt-line region, where we are irradiating all of
10 the materials up until fluences, well beyond what we would
11 expect at 48 NPY.

12 DR. SHACK: Let me just understand that screening
13 analysis.

14 You do the fracture mechanics analysis from a
15 purely fracture mechanics point of view to get the loads
16 regardless of the presumed toughness of the material, and
17 you're saying that the loads just aren't as high there, or
18 are you really making some assumption about toughnesses,
19 also?

20 MR. RINCKEL: Well, we included the toughness,
21 because we estimated what a fluence would be. The fluence
22 up in that region was about an order of magnitude lower than
23 the maximum in the belt-line region, and so, we did look at
24 material degradation, reduction of toughness.

25 DR. SHACK: Okay. So, you don't have that

1 material in your surveillance program, but you then make
2 some reasonably conservative assumption about its loss of
3 toughness.

4 MR. RINCKEL: Because it's really very similar to
5 the Linde-80 welds and very similar to the weld material
6 that was used in the belt-line region. I believe that's
7 right.

8 Now, the only portion of the reactor vessel, the
9 base metal, that would be subject to cracking would be the
10 508 forgings, class two forgings that were clad using the
11 high-heat input process such as the submerged arc two-wire
12 or six-wire, and all of the forgings in the scope of our
13 report were clad using a six-wire process, and what's shown
14 here in this figure are the two beads.

15 They had bead one, including the six wires, would
16 be the first pass, and this was all clad. They put the
17 forgings on a machine and turned them, and they had an
18 automatic submerged arc welding process where they would lay
19 down the cladding in six wires.

20 So, they'd roll the thing and make one pass, pick
21 it up and move it, and do another, and that's what these two
22 beads are shown here, bead one and bead two, and at the
23 region where they overlap, in the heat-affected zone
24 underneath, it subjected the forgings to some cracking.
25 This was discovered, I believe, in Germany sometime in the

1 late '60s or early '70s.

2 What we found at B&W was the largest crack that we
3 had seen when we did NDE.

4 It was about .1 inches deep and a half-inch long,
5 and what happened back in roughly 1970 was that a fracture
6 mechanics analysis was done to show that that flaw would not
7 grow and the reduction of toughness would be such that it
8 would not be -- it would not jeopardize the integrity of the
9 reactor vessel at the end of the 32 effective full-power
10 years.

11 So, this became an issue that we had to address
12 for license renewal, because it was an issue that was --
13 that resolved this at the beginning of operation of our
14 plants.

15 This will be the subject of Ken Yoon's discussion
16 about Appendix C of our document.

17 For the other items, we have just covered the
18 aging effects in the last slide on the record for the vessel
19 shell enclosure head.

20 The other items will be the reactor vessel nozzles
21 -- these are clad low-alloy steel nozzles, again cracking at
22 welded joints, cracking at the inside nozzle radius. There
23 are higher loads on some of our bigger nozzles that could be
24 subjected to stresses at the inside radius, and loss of
25 external material due to boric acid wastage. Again, the

1 closures could leak.

2 For the alloy-600 nozzles, which would be the CRDM
3 penetrations, the IMS nozzles down at the bottom, we have
4 cracking at or near the heat-affected zone. We have seen
5 cracking not of any of these nozzles but other alloy-600
6 items.

7 It typically occurs at or near the heat-affected
8 zone in the base metal, as opposed to the 82-182 weld. So,
9 that has been our experience, but that would be an
10 applicable aging effect for those nozzles.

11 The reactor vessel interior attachments are
12 alloy-600. Those are the items that catch the internals
13 should they fall. Cracking at or near the attachment welds.
14 And for the reactor vessel, pressure retaining Bolted
15 closures, loss of mechanical closure integrity.

16 We could have loss of material of the alloy steel
17 studs, cracking, or stress relaxation, but again, the aging
18 effect is loss of mechanical closure integrity that must be
19 managed.

20 Listed here are the generic aging management
21 programs that are credited for managing the aging effects of
22 the items that we discussed earlier. ASME Section XI,
23 subsection IWB, 1989 edition -- the staff has to have -- NRC
24 staff has to have something to pull off the shelf to look
25 at.

1 It's the 1989 edition, with appendices seven and
2 eight. Appendix seven and eight deal with qualification of
3 NDE for UT and performance demonstration for UT. These are
4 credited for managing cracking in welded joints, again the
5 fabrication flaws you're looking for.

6 B&W owners group for reactor vessel integrity
7 program is credited for managing reduction of fracture
8 toughness.

9 Those are NRC requirements for 10 CFR 50.60, which
10 is fracture toughness, and 50.61, which is pressurized
11 thermal shock, both of which are time-limited aging
12 analyses, and 50.60 gets into the surveillance program.

13 Technical specifications, the pressure temperature
14 limits, again tied to 50.60, RCS chemistry is credited as an
15 aging management program and RCS leakage limits, primarily
16 for bolted closures.

17 Commitments to NRC generic communications --
18 Generic Letter 88-05 is the boric acid wastage generic
19 letter that required all licensees to prepare a program to
20 address boric acid wastage.

21 Bulletin 82-02 is degradation of threaded
22 fasteners in RCS components, and most recently, Generic
23 Letter 97-01 concerning PWSCC of reactor vessel head
24 penetrations -- we made a commitment in our report that
25 inspections and activities that will be done in the current

1 term of operation will be carried forward to the period of
2 extended operation to manage this aging effect in the next
3 20 years.

4 DR. SHACK: The analysis that's used to identify
5 the most limiting components there is based on the EPRI
6 susceptibility model?

7 MR. RINCKEL: I believe it's -- Matthew, you may
8 be able to answer that.

9 I believe it is the EPRI susceptibility model that
10 is used to do that, and it considers the material, the
11 stress, the chemistry, and there is a time to crack
12 initiation probability and so forth.

13 So, I believe that is the EPRI model. Our expert
14 on that is not here today.

15 I wanted to get into now, really, the time-limited
16 aging analyses associated with the reactor vessel, and the
17 first one that we addressed in our report is thermal
18 fatigue. So, I'll give a summary of that, and then the next
19 item would be compliance with 10 CFR 50.60 and 50.61.

20 Again, that manages reduction of toughness of the
21 belt-line region. That includes pressurized thermal shock
22 to 480 FPY and the upper shelf energy evaluations.

23 Growth of inter-granular separations I referred to
24 earlier. We did a fracture mechanics analysis, and Ken Yoon
25 will be discussing that.

1 The last item would be flaw growth acceptance in
2 accordance with ASME Section XI. When NDE is performed on
3 structural welds in the vessel, if there are any indications
4 that exceed allowable, they become defects, and the options
5 are to repair or to evaluate.

6 We have found some flaws that have exceeded the
7 acceptance criteria in some of the vessels.

8 I think Oconee unit two has one. Not many, but
9 they've been evaluated, and there is a fatigue flaw growth
10 evaluation that's done to assess how big the flaw will get
11 at the end of the design life of the component. So, we've
12 had to revisit those.

13 We did not do that in our generic report. That
14 was a plant-specific evaluation. So, Oconee is handling
15 that through their application.

16 Our first time-limited aging analysis is thermal
17 fatigue, and when we started into this thermal fatigue area,
18 all of the RCS components have cumulative usage factors
19 calculated for them, and we found that a lot of the
20 transients that go into the calculation of that not only
21 apply to the vessel, they apply to the piping, they apply to
22 every component.

23 So, you can't really just look at cumulative usage
24 factors for one component; you need to look at all of the
25 components and really get a good basis of what your fatigue

1 design basis is.

2 So, what we did is we summarized -- Framatome
3 summarized the cumulative usage factors for all the class
4 one components, including the identification of what the
5 transients were that were the controlling factors for those
6 usage factors.

7 We determined that the current number of design
8 transients would be valid for the period of extended
9 operation, and we also were requested and required to assess
10 the impact of environmental-assisted fatigue. All of that
11 was done in our specimen of fatigue.

12 And what we started off doing was looking at
13 preparing matrices summarizing the usage factors and the
14 applicable normal and upset transients that contributed to
15 the usage, and for instance, you would have heat-ups and
16 cool-downs from 70 degrees up to 580 degrees. That would be
17 one transient that would have a contribution to usage
18 factor.

19 The Oconee is designed for 360 such cycles over
20 the 40-year design life. It's stated as such in the FSAR.
21 That's why it became a time-limited aging analysis. There's
22 nothing magical about 40 years; it was just stated that way.

23 Our job was to look at all of the transients that
24 went into those usage factors, the heat-ups and cool-downs,
25 reactor trips -- there are a number of them that go into the

1 calculation -- and really assess where they are now and
2 where they're going.

3 Are the original design cycles still okay for 60
4 years? That was our whole objective of doing this, and we
5 found that, yes, a lot of these plants come up and are
6 base-loaded, and they simply are not accruing cycles such
7 that would put them beyond their cycling at 60 years.

8 We found the controlling transients for almost all
9 of the RCS components to be listed here -- heat-ups and
10 cool-downs, reactor trips, HPI actuations, EFW, rapid
11 cool-downs, and natural-circulation cool-downs. So, those
12 are the controlling transients for the usage factors for
13 almost all of the RCS components.

14 For the controlling transients listed on the
15 previous slide, we made an assessment of the number of
16 transients accrued to date for each plant, and I had one for
17 Oconee. Let's see if I can find that. Here we go. This is
18 something that we did.

19 Oconee unit one is shown here, and these are the
20 heat-ups and cool-downs that they have accrued over time,
21 and you can see, up to 2001, they have accrued about 100.
22 We then did a conservative projection about -- for the next
23 20 years, up until the end of the period of extended
24 operation or close to it.

25 The line up above shows the number of design

1 cycles, 360 design cycles.

2 So, you can see that they are projected to be well
3 below that at the period of extended operation. Therefore,
4 there was no need to increase the number of design cycles
5 for any of the design basis transients.

6 And we did conclude that, for the reactor vessel
7 and really for all of the RCS components, that the current
8 design cycles are accepted for the period -- acceptable for
9 the period of extended operation.

10 DR. UHRIG: Do you also add in reactor trips --

11 MR. RINCKEL: Yes.

12 DR. UHRIG: -- rapid cool-downs? So, that would
13 make it a higher projection on there.

14 MR. RINCKEL: Well, each one of those transients
15 would have its own curve.

16 DR. UHRIG: Oh, okay.

17 MR. RINCKEL: If you have a usage factor of .9,
18 let's say .5 would be attributed to heat-ups and cool-downs,
19 perhaps .1 to reactor trips, and so forth. It's based on
20 each of those transients you consider, and oftentimes, the
21 heat-ups and cool-downs are bounding. They bound many of
22 the other transients because of the stresses applied and so
23 forth.

24 So, that's where we had it. We had a separate
25 curve for each one.

1 In our report, we had demonstrated that the
2 existing usage factors, with the exception of the Oconee ONS
3 reactor vessel studs, remain valid for the period of
4 extended operation, and the reactor vessel studs actually
5 have a usage factor of 1.04 now that I think has since been
6 revised due to -- and recalculated. So, I believe Oconee
7 has taken care of that.

8 There is a program in place at each of the
9 utilities to monitor these design transients, and we could
10 not go into the detail in our generic report of describing
11 the plant-specific programs.

12 So, that became a license renewal applicant action
13 item, to describe their thermal fatigue monitoring program.
14 As part of the license renewal application, Oconee has done
15 that, and I think Bob Gill will discuss that a little bit
16 later.

17 The last thing is, once we had a good handle on
18 the fatigue design basis, understood what the controlling
19 transients were, understood where they were today and where
20 they're going, we had to do an assessment of
21 environmental-assisted fatigue, and we did that for the
22 items, the reactor vessel items evaluated in NUREG-6260.

23 We used the ANO model described in NUREG-6335,
24 applied environmental factors for the faradic items, and
25 showed that the usage factor would be less than 1. So, we

1 did address environmental-assisted fatigue for the vessel
2 items again.

3 The factors are not as high for the faradic items
4 as they would be for stainless steel, and I think there is
5 some controversy as to the stainless steel, but we didn't
6 have that to deal with, because we were all faradic in the
7 vessel.

8 DR. SHACK: On the limiting items, is that on a
9 design basis, or that's actually going back and looking at
10 the actual transients and seeing -- and looking at those
11 usage factors?

1 MR. RINCKEL: It was a study that was done by, I
13 believe, ANO or the NRC on identifying the limiting items in
14 the vessel, and the items were the nozzles, inlet-outlet
15 nozzles. the core flood nozzle, the weld that connects the
16 lower shelf to the transition forging, I believe were the
17 specific items, and I think I saw John Fair here.

18 Is that right, John? Okay.

19 Yeah, John's nodding his head.

20 So, we looked at those specific items as the items
21 to apply the environmental factors to.

22 I'm not sure -- I think we also looked at the IMS
23 nozzles at the bottom and I believe the CRDM penetrations at
24 the top, of the alloy-600 items.

25 So, that was our assessment of thermal fatigue in

1 the reactor vessel report, and the next item is compliance
2 with 10 CFR 50.60 and 50.61, which addresses the reduction
3 of fracture toughness in the vessel, and I thought, really,
4 the best way is to have our expert on our surveillance
5 program give you kind of a history of our reactor vessel
6 integrity program.

7 It was formed, I think, about 20-some years ago to
8 address the problems with the Linde-80 welds that we have,
9 and it's really an outstanding program, and I was very
10 fortunate to have Matthew help out with this. So, I'm going
11 to turn it over to Matthew here.

12 I'll turn the slides for you, Matthew.

13 MR. DEVAN: I'm Matt Devan from Framatome. I'm a
14 metallurgical engineer, and as Mark indicated, I want to
15 give you a brief background of the master integrated
16 program, which I'll refer to as the MIRVP throughout this
17 presentation.

18 What I would like to do first is pretty much just
19 restate the NRC requirements for fracture toughness
20 requirements and material surveillance requirements.

21 As Mark indicated, 10 CFR 50.60 requires that all
22 light-water nuclear reactors must meet fracture toughness
23 requirements and material surveillance requirements, as
24 documented in Appendix G and Appendix H of the Code of
25 Federal Regulations.

1 Also, as part of fracture toughness, we have 10
2 CFR 50.61, which requires the protection against pressurized
3 thermal shock.

4 10 CFR Appendix G has requirements, again, for
5 fracture toughness requirements for reactor vessels. One of
6 the requirements is that the upper shelf energy shall not be
7 less than 50 foot-pounds. This was a problem for the
8 Linde-80 welds in that, during the life of the plant, these
9 welds had a low upper shelf energy value and would drop
10 below 50 foot-pounds.

11 Again, Appendix G allows an equivalent margins
12 analysis per ASME, Section XI, Appendix G, and this has been
13 performed through the end of life with an -- at the NRC with
14 an SER.

15 Also, in Appendix G, they have requirements for
16 pressure/temperature operating limits, and they utilize the
17 predicted shifts of the reference temperatures, which
18 utilize -- which you can utilize the Reg. Guide 199, Rev. 2,
19 methodology used to calculate the adjusted reference
20 temperature, which is then used to develop these
21 pressure/temperature operating limits.

22 10 CFR Appendix H is the material surveillance
23 requirements. It utilizes the ASTM E-185 standard, which is
24 basically the standard practice for conducting surveillance
25 tests for light-water nuclear power reactors.

1 It also states approved withdrawal schedules for
2 capsules for surveillance, for monitoring reactor vessel
3 embrittlement.

4 It also contains integrated program rules, rules
5 for integrated program, which, again, the MIRVP is an
6 integrated program. So, these are keys that we had to
7 develop when we created this program.

8 Some keys for the integrated program were for
9 similar design and operating features of reactor vessels,
10 and reactors must have an adequate dosimetry program and
11 also the data-sharing arrangement for these reactor vessels.

12 For the B&W fabricated reactor vessels, for the
13 PWRs, there were two NSS designers. One was B&W and one was
14 Westinghouse.

15 The materials that were used to fabricate these
16 vessels, as indicated by Mark earlier, were -- for the plate
17 vessels, they utilized SA-302B, modified, which was modified
18 by a code case, and those were the earlier plants, Oconee
19 one and TMI one.

20 Also, the later plants or the plants that were
21 fabricated at a later time were -- the SA-508 -- or, excuse
22 me, SA-533, grade B, class one, plate material, and the
23 Oconee three and Oconee two and Davis-Besse plants were
24 forgings, fabricated from A-508, class two.

25 The welds, again, were utilized for the plate

1 materials. They both contain circumferential welds and also
2 axial welds. For the forgings, they only had
3 circumferential welds, as indicated by the earlier drawing.

4 All the welds in the belt-line region were
5 automatic submerged arc welds. They utilized the Linde-80
6 flux, which had a low initial upper shelf energy, and again,
7 as Mark indicated earlier, they were fabricated using a
8 copper-coated wire, which, with the introduction of the
9 copper or the increased amount of copper, can accelerate the
10 reduction of fracture toughness.

11 For the welds used in the fabrication, each weld
12 wire heat and flux lot had a unique identifier which
13 basically went through a weld qualification for that
14 particular wire heat and flux lot. There were -- welds were
15 qualified both at the Mount Vernon facility and also in the
16 Barberton facility.

17 The welds, when you see -- for the B&W fabricated
18 vessels, you'll see a WF numeral. That indicates that that
19 weld qualification was performed at Mount Vernon, and SA
20 numerals were basically qualified at Barberton, and all the
21 weld seams in the belt-line region are traceable to either a
22 WF or an SA identifier.

23 Surrogate welds, just for information, is a --
24 weld-wire heat can be fabricated from a different flux lot,
25 but when -- as for a surrogate weld, the wire heat is the

1 key, and the flux lot can differ, and it would be a
2 surrogate weld of that.

3 But the wire-heat has got the unique equivalent
4 copper and -- the copper content, nickel content, and also
5 mechanical properties.

6 For the surveillance material or surveillance
7 capsules contained in these capsules, again, in accordance
8 with ASTM E-185, contains both base metal and weld metal.
9 The early capsules, which the B&W capsules fall into, they
10 may not have the same WF or SA weld in the vessel belt-line
11 as what's in the capsule.

12 This requirement was changed in later editions of
13 ASTM E-185, but they do contain both a plate or forging
14 material that is within the belt-line region and a Linde-80
15 weld associated with that program.

16 The test specimens that are contained in these
17 capsules -- they are charpy V-notch impact specimens,
18 tension test specimens, and at a later time, compact
19 fracture test specimens were included.

20 No compacts were included in the very early
21 plant-specific capsules. As time went on, half-T's were
22 included in some of the plant-specific for the B&W reactor
23 vessels, and once the integrated program was developed,
24 supplemental capsules were fabricated using actual 1-T
25 specimens.

1 Also included, neutron dosimetry wires to
2 calculate fluence and temperature monitors which were
3 low-eutectic alloys which would melt and show the actual
4 radiation temperature exposure that the specimens would
5 receive.

6 DR. UHRIG: Could you tell me what you mean by
7 compact fracture specimen here?

8 MR. DEVAN: Ken?

9 MR. YOON: Compact fracture specimen -- it is a
10 fracture specimen according to the ASME standard. There is
11 various size specimens with two holes in the specimen you
12 can pull under a test machine. You can perform fracture
13 test using these specimens.

14 DR. UHRIG: It's not impact loaded.

15 MR. YOON: No. It is just a slow pull.

16 DR. UHRIG: Okay. It's pre-cracked.

17 MR. YOON: Yes, pre-cracking is a requirement.

18 DR. UHRIG: You do mean impact on the tension
19 specimens.

20 MR. DEVAN: Oh, no. The tension specimens are
21 actual tension tests.

22 DR. UHRIG: Okay. There are tension impact tests,
23 also.

24 MR. DEVAN: Right. But what I'm classifying are
25 the slower, actual tension tests.

1 MR. YOON: In our program, to accommodate the
2 cylindrical shape of the capsule, we used the round compact
3 instead of square, which both are according to ASTM
4 standards.

5 DR. UHRIG: Okay. Thank you.

6 DR. SHACK: So, even the half-T are really round
7 geometry?

8 MR. YOON: No. The 1-T's are round. Actually,
9 it's .9-something.

10 MR. DEVAN: This is a slide summarizing the
11 reactor vessel integrity program. Again, it was established
12 in the late '70s.

13 The primary purpose of this program was to resolve
14 fracture toughness concerns with Linde-80 welds because of
15 the low upper shelf energies.

16 The original participants were the B&W design
17 reactor vessels, which included Arkansas Nuclear one,
18 Crystal River unit three, Davis-Besse, Oconee's unit one,
19 two, and three, Rancho Seco, and TMI one and two.

20 As time went on, some later participants with
21 B&W-fabricated vessels were included. These were
22 Westinghouse design reactors, which include R.E. Ginna,
23 Point Beach one and two, Surry unit one and two, Turkey
24 Point three and four, and Zion unit one and two.

25 The reactor vessel integrity program -- the goals

1 were to obtain materials and irradiation effects data,
2 develop test methods and analytical procedures to -- for
3 determination of fracture toughness, and also to provide an
4 effective communication among the owners themselves with
5 these materials, also effective communication with the NRC,
6 and also with the industry.

7 As I indicated earlier, the plant-specific
8 capsules had deficiencies in that the limiting materials
9 within those plant-specific capsules were not the actual
10 limiting materials within the vessels.

11 Also, fracture toughness specimens were not
12 included in the plant-specific.

13 So, the integrated program was developed, in
14 addition to the fact that there were some failures of the
15 capsule holders within the vessels.

16 So, the B&W owners group developed the integrated
17 program at that point, which established an integrated
18 program for the B&W-design reactors because of the failures
19 of the holders within a few of the reactor vessels.

20 What they would have would be host reactors, which
21 would host the actual plant-specific capsules themselves,
22 and the other ones would be just basically utilizing --
23 these host reactors would be obtaining the data because of
24 the similarities of the reactor vessels.

25 They would be able to pull and test their capsules

1 after being irradiated in these host capsules and provide
2 them the irradiation data that they needed.

3 The integrated program also added some additional
4 capsules which were classified as supplemental capsules,
5 which were providing additional data for other Linde-80
6 welds that weren't included in some of the plant-specific.

7 At the time, the master integrated program has 14
8 capsules, 14 different individual supplemental capsules, and
9 these were inserted all in power reactors.

10 DR. SHACK: What are the flux limits on these
11 things, and when you -- presumably, you accelerate these
12 somewhat, but what's the limit on the flux rate acceleration
13 you can give it?

14 MR. DEVAN: It's all limited on where the location
15 of the capsules themselves are within the reactor vessel.
16 They're based on -- again, their exposure is based on their
17 location, and we project the fluence that's going to be
18 received by these capsules and withdrawn per a withdrawal
19 schedule that is efficient for the participants to obtain
20 the data that's necessary to fill in the data that's
21 necessary for end of life and also for license renewal.

22 DR. SHACK: But when you add these supplemental
23 capsules, presumably in order for them to catch up, you have
24 to somehow put them in a location with a somewhat higher
25 flux?

1 MR. DEVAN: These are the same locations of the
2 plant-specific.

3 The plant specifics are inserted and also
4 withdrawn at different times to -- well, they're inserted,
5 and they get the exposure that is required per ASTM E-185,
6 and then, once they hit that limit or that window, the
7 capsules are actually withdrawn and then stored in our
8 Lynchburg Technology Center, and they are either tested or
9 they're actually stored.

10 MR. RINCKEL: What's the lead factor?

11 MR. DEVAN: Well, the lead factor for -- there's
12 two locations within the B&W reactors, and the lead factors
13 for the quarter thickness vessel thickness, which is one
14 quarter of 8 1/2 -- the two locations have lead factors of
15 around 7 and 9. So, they are accelerated.

16 DR. UHRIG: Do you have any of the weld material
17 among these samples, these capsules?

18 MR. DEVAN: Yes.

19 DR. UHRIG: Including the copper that was put into
20 the original welds.

21 MR. DEVAN: Yes. We have, I believe, eight
22 different weld wire heats, eight or nine, I can't remember,
23 but we have a large number of weld wire heats represented in
24 these capsules, so we have an idea of how each of these weld
25 wire heats is behaving with respect to irradiation and

1 embrittlement.

2 DR. UHRIG: They use essentially the same amount
3 of copper on the electrodes for the different vessels that
4 -- generally familiar with the Turkey Point situation.

5 MR. DEVAN: Uh-huh.

6 DR. UHRIG: Is this comparable to, say, the
7 vessels at Turkey Point?

8 MR. DEVAN: Yes. Yes.

9 DR. UHRIG: It was the same procedure, same
10 welding rod or welding wire.

11 MR. DEVAN: The same process was used to coat the
12 wires, but there was no requirement as to how much copper
13 was going to be put on the wire.

14 In other words, it went through a copper bath, and
15 then -- so, there are some areas where -- I mean there's no
16 set thickness of the copper coating. So, that's why there
17 are some variations within the copper contents within these
18 Linde-80 welds.

19 Some welds have, you know, copper contents of .3
20 weight percent. Others have copper contents of, say, .25
21 percent. So, there is variation, and again, all these are
22 measured based on a large number -- a very large database of
23 chemistry data that we have at hand right for Linde-80
24 welds.

25 DR. SEALE: Let me see if I understand some of the

1 code words you're using here. When you say you have a lead
2 factor of 9, does that mean that I have to essentially put a
3 capsule in for seven years in order to replicate a 60-year
4 anticipated irradiation?

5 MR. DEVAN: What that means is -- the lead factors
6 that I specified reflect the fluence that has attenuated
7 through the vessel at the quarter-T location, and what that
8 means is that the capsules will lead the vessel wall by
9 seven.

10 So, if the vessel sees a fluence of $1E18$, the
11 capsule exposed at the same period of time would receive, at
12 the quarter-T -- or equivalent to the quarter-T location of
13 $7E18$.

14 DR. SEALE: If that's your lead factor.

15 MR. DEVAN: Yes.

16 DR. SEALE: Okay.

17 MR. YOON: So, your question is correct.

18 DR. SEALE: My question was correct. Okay.

19 DR. UHRIG: Do you have thermal seals?

20 MR. DEVAN: Yes.

21 DR. UHRIG: So, therefore, there would be a
22 significant reduction.

23 MR. DEVAN: Yes.

24 DR. SHACK: Those pressurized thermal shock
25 calculations that you showed -- that was essentially with no

1 additional neutron management or neutron reduction. That's
2 sort of calculated as you're doing it now, so that they have
3 the option of going to a low leakage core or something?

4 MR. RINCKEL: Yes, that's correct. I think all of
5 our plants have gone to low leakage cores now. They're
6 already there.

7 DR. SHACK: Okay. So, you can't buy anymore that
8 way.

9 MR. RINCKEL: No, sir.

10 MR. DEVAN: B&W, when it generated this integrated
11 program, had a unique situation where they had with I would
12 classify as nozzle drop-outs. These are the areas within --
13 in the pressure vessel where they cut out to -- for the
14 nozzles themselves, the outlet and the inlet nozzles.

15 So, what we had was a unique situation in that we
16 had these large disks with an actual Linde-80 production
17 weld within that nozzle drop-out that we could utilize for
18 these supplemental capsules.

19 This -- again, it added additional data for weld
20 wires heats that were not included in the surveillance
21 program. So, this expanded the database that was necessary
22 to cover some of the belt-line welds that aren't -- were not
23 represented within the plant-specific capsules.

24 Again, the drop-out -- the welds that were in
25 these drop-outs were utilized in these 14 capsules,

1 supplemental capsules that are part of the master integrated
2 program.

3 The master integrated program is documented in
4 BAW-1543. The current rev is Rev. 4, and what we have is a
5 supplement document to that which provides the surveillance
6 capsule withdrawal schedules that the plants are scheduled
7 to withdraw the capsules and so whatever is required per
8 E185.

9 The SER that was issued for Rev. 3 indicated some
10 requests. In particular, we had to do a TMI-2 supplemental
11 capsule re-qualification because of the accident at TMI-2.

12 They also asked for an analysis of sub-size
13 tensile specimens, because we utilized a smaller specimen
14 than standard tensile specimen themselves, and also, we --
15 they requested an analysis of our reconstitution process,
16 because one of the capsules we had included reconstituted
17 specimens from previous irradiated capsules, charpy
18 specimens.

19 These requests were answered and had no further
20 comment from the NRC.

21 And I would like to conclude with my background by
22 indicating some of the current activities that we're
23 involved with and concluded with as of right now.

24 We had a post-irradiation testing of a capsule
25 called W-1, which was irradiated in a Westinghouse-design

1 plant, Surry unit two, and what this capsule's purpose was
2 was to document or provide irradiated data from exposure in
3 a Westinghouse reactor vessel, and we had the same material
4 from the same source included in B&W, in capsules that were
5 irradiated in a B&W reactor, and the intention is to compare
6 the irradiated data from a Westinghouse plant to the B&W
7 plants and see what differences, if any, are there, and this
8 is currently -- the evaluation is currently going on and
9 should be completed as part of the 1999 integrated program.

10 And lastly, the --

11 DR. UHRIG: What kind of difference would you
12 expect? A spectrum difference?

13 MR. DEVAN: The spectrum difference I don't think
14 is a problem.

15 Again, there are some questions of irradiation
16 temperature differences due to the fact that B&W's operate
17 at a higher -- their cold legs are a little bit higher than
18 the Westinghouse folks, and again, I don't know what kind of
19 conclusions we're going to be able to make, because this is
20 such a small database, but it provides a unique situation
21 where we've got the same welds irradiated in two different
22 reactor designs.

23 The B&W reactors have a cold leg temperature
24 roughly of about 550. The Westinghouse -- there are
25 differences within the Westinghouse. They range from anyway

1 -- 545 to 540, I believe, somewhere in that range.

2 Now, there was one reactor -- or reactor vessels,
3 I should say -- Zion unit one and unit two, which operated
4 at a much cooler temperature. They were around 530, but
5 they are no longer part of the program. So, the concern for
6 that is not there.

7 The last capsule, which was a unique capsule in
8 that it included a previously-irradiated charpy tested
9 charpy specimens that were reconstituted to form new charpy
10 specimens.

11 So, what this provided was specimens that already
12 had exposure to irradiation and already had the
13 embrittlement, and we could reconstitute those, further
14 irradiate those specimens to get a higher fluence exposure
15 and embrittlement on those specimens, and that testing has
16 just been completed, and the report has just been signed
17 off, and that concludes my presentation.

18 DR. UHRIG: You alluded earlier to some of the
19 specimens having an impact, a charpy impact value of less
20 than 50. How low was it?

21 MR. DEVAN: They were --

22 MR. YOON: Between 40 and 45.

23 DR. UHRIG: So, it was not a big difference.

24 MR. DEVAN: No.

25 DR. UHRIG: Okay.

1 MR. YOON: Depending on the fluence, but that's
2 about the number we've seen.

3 DR. UHRIG: Okay.

4 CHAIRMAN BONACA: Any other questions for the
5 presenter?

6 [No response.]

7 CHAIRMAN BONACA: What I would like to do -- we
8 are scheduled for a break, and this seems to be the right
9 time to take it. So, I would like to take a break now and
10 resume the meeting at five after 10.

11 [Recess.]

12 MR. RINCKEL: What we're concerned about is the
13 fluence at the inside surface of the vessel. The capsules,
14 the surveillance capsules that Matthew talked about are in
15 Crystal River unit three and Davis-Besse. They are not in
16 ANO and they're not in TMI and they're not in the Oconee
17 units.

18 Those units all rely on ex-vessel cavity
19 dosimetry, but basically, when we projected out to 48 EFPY,
20 the NRC asked us, well, that's a long ways away, that's
21 about, you know, 30 years from now, and how are you going to
22 ensure that those fluence values that you've used at 48 EFPY
23 are accurate and within uncertainty limits of the
24 correlations that are used for the embrittlement
25 evaluations?

1 Well, in so doing, that was certainly a valid
2 question.

3 During the same period of time of the NRC review
4 of our vessel, there was a separate effort going on with the
5 NRC in review of uncertainty and fluence calculations and so
6 forth, and that resulted in the approval of topical report
7 BAW-2241, which addresses the uncertainties of fluence and
8 projection of fluence and so forth, and basically, as a
9 condition of acceptance of the fluence vessels, our fluence
10 values used in our report, our owners have to monitor, using
11 ex-vessel cavity dosimetry, reactor -- the fluence, and
12 using the calculation-based method that's described in
13 BAW-2241, update those calculations on a periodic basis to
14 make sure that the fluence that we have used out to 48 EFPY
15 is still going to be valid.

16 So, we cannot just put our blinders on and not --
17 and ignore fluence. We're going to have to continue
18 monitoring.

19 We'll be using ex-vessel dosimetry to do that, and
20 we will be continually extrapolating out to 48 EFPY to make
21 sure that what we -- the values we've used in our report
22 remain valid.

23 If, all of a sudden, an extrapolation goes beyond
24 what we used in our calculation -- and our maximum fluence
25 projection was approximately 1.5 times 10 to the 19th -- if,

1 at a later time, it exceeds that, then we would have to
2 update these evaluations.

3 So, we have committed to a monitoring process that
4 will ensure that these values that we have used in here
5 remain valid.

6 Now, these values form the basis for the upper
7 shelf energy evaluation that Ken's going to talk about and
8 also the RTPTS evaluations that are performed in accordance
9 with 10 CFR 50.61, and that's the subject of the next slide
10 here.

11 The next bullet is compliance with 10 CFR 50.60
12 and 50.61, and the two items I'll talk about would be the
13 RTPTS to 48 EFPY, which is Appendix A of our BAW-2251
14 report.

15 Appendix B is a low upper shelf energy. Ken Yoon
16 will be talking about the fracture mechanics evaluation, and
17 then the last bullet is the growth of the inter-granular
18 separations. That's Appendix C of the BAW-2251.

19 Once we had the end of life or end of 48 EFPY
20 fluence estimates at the inside surface of the vessel for
21 all of the participating plants, we demonstrated that the
22 RTPTS values at 48 EFPY comply with the requirements of
23 50.61 using Reg. Guide 199, Revision 2.

24 The results of our calculations, RTPTS welds for
25 all of the participating units were calculated to be below

1 the PTS limits, with the exception of WF-25 in Oconee unit
2 two reactor vessel, which had a value of 300.1 -- screening
3 criterion is 300, so it was a tenth of a degree above -- and
4 one weld at another plant.

5 Oconee has subsequently done a plant-specific
6 analysis. That's reported in the application, and the RTPTS
7 value for WF-25 has been reduced to 296.8. They had updated
8 fluence, they had looked at surveillance data, and Bob Gill
9 will get into that a little bit later.

10 And at this time, I'm going to turn it over to Ken
11 Yoon, who will describe the Appendix B to our report, which
12 is the low upper shelf toughness fracture mechanics
13 analysis, and that's for the limiting belt-line welds that
14 are below 50 foot-pounds, you have to perform equivalent
15 margins analysis in accordance with 10 CFR 50, Appendix G,
16 and that's what Ken is going to describe here.

17 MR. YOON: Again, my name is Ken Yoon, and I work
18 in the fracture mechanics analysis area.

19 One of the two fracture mechanics analysis
20 included in the license renewal project -- first one is the
21 low upper shelf toughness issue.

22 That is really the driving force behind the first
23 creation of B&W owners group, and subsequently, we had all
24 the material testing program was under this program, and for
25 the analysis method and acceptance criteria, we didn't have

1 any in the beginning, but early '80s, NRC wrote a letter to
2 Section XI of ASME pressure vessel pipe boiler and pressure
3 vessel code to provide the acceptance criteria.

4 So, we started working on it, on this project. It
5 took only 12 years, but we finished it in early 1990s, and
6 the technical basis is well documented in the Welding
7 Research Council Bulletin 413. Additionally, there is a
8 regulatory guide, how to do low upper shelf analysis, is
9 also issued.

10 For the 40-year design life, all four owners
11 groups, including BWR owners group, completed the evaluation
12 and was approved for their justification for low upper shelf
13 issue.

14 B&W owners group also performed the analysis for
15 not only B&W-designed plant but our reactor vessel working
16 group members, which is some of the Westinghouse plants
17 having B&W-fabricated the vessels.

18 So, I'm going to go over the next slide,
19 acceptance criteria. There are three criteria. First one
20 is based on -- all three based on service levels.

21 First one, for levels A and B, there is a
22 requirement for the crack size, postulated crack size of
23 quarter-T, just like Appendix G, and the safety margin of
24 1.15, and crack extension of .1 inch was specified.

25 This J material is the crucial input to this

1 analysis, and B&W owners group performed J resistance curve
2 testing from day one and collected many JR curves for this
3 activity. Some are non-irradiated material and some are
4 irradiated material.

5 Also, B&W owners group donated weld material
6 specimens to the HSST program, namely 62-W through 67-W
7 series of the both un-irradiated and irradiated specimen
8 testing. That specimens were a B&W contribution to the
9 program.

10 We collected many specimens, and Ernie Eason took
11 the job of modeling it using the pattern recognition
12 program, and we have a B&W owners group J resistance model
13 as a function of temperature, fluence, copper content, and
14 specimen size. So, that's the basis of this critical
15 evaluation.

16 For the level C --

17 DR. SHACK: Now, how does Ernie's curve for the
18 owners group differ from Ernie's curve for the NRC?

19 MR. YOON: Slightly different, because he
20 exclusively used our database, and he has two or three
21 different welds to look at that data, but ours is exclusively
22 Linde-80 weld data but in a similar format.

23 For level C, the differences -- the postulated
24 flows depth should be one-tenth of a thickness instead of a
25 quarter-T, and a safety factor of one was given.

1 In level D, the same as level C, but in this case,
2 the best estimate mean curve was allowed instead of some
3 sort of low bounding materials curve, but those are the only
4 difference.

5 So, based on this, we used the B&W J material
6 model, and the next one shows some plots of -- because the J
7 material is the key information, I plotted that against the
8 fluence, and you can see that the dotted line is a mean
9 curve and solid line is a mean sigma curve, and this is for
10 high copper Linde-80 W-70 and 209 data points, were plotted
11 as in the illustration.

12 So, it's trying to show that the model is doing an
13 adequate job, and one thing to notice is B&W plants, design
14 plants, early on, went into low leakage fuel scheme.

15 So, at their extended life, 48 EFPY, fluence is a
16 lot less than some of the other plants' regular 40-year
17 design life.

18 So, the results of this evaluation is it is found
19 at all the plants under this program, was found acceptable
20 by the Appendix K. So, that was the conclusion of this
21 program.

22 DR. SEALE: I must make a comment. This sounds
23 like on-time code development, to mix the jargons of modern
24 management analysis with the codes and so on.

25 Fifteen years ago, a letter was written to suggest

1 that we needed to look at low upper shelf energies. It was
2 available three years ago, and now you're using it.

3 It's truly on-time development. I don't think you
4 could cut it any closer. I wrote myself a note here that
5 Demming would be proud.

6 MR. YOON: It made some of us a career in this
7 business.

8 [Laughter.]

9 DR. UHRIG: Could you define what you mean by
10 level A, B, C, D?

11 MR. YOON: That's the --

12 MR. RINCKEL: Level A and B are the normal and
13 upset events. Normal events would be like your heat-ups and
14 cool-downs. An upset event would be like a reactor trip.

15 Level C is an emergency event. For us, that's
16 defined as a stuck-open turbine bypass valve.

17 Level D is a faulted event, maybe a
18 loss-of-coolant accident, or a safe shutdown earthquake.

19 So, those are the various loadings that these
20 things are designed for.

21 DR. UHRIG: Thank you.

22 MR. RINCKEL: The next item Ken's going to talk
23 about is Appendix C to our report, which is the growth of
24 inter-granular separations. I had talked about those
25 earlier.

1 Those are the regions on the forgings where the
2 weld overlap is that there are some under-clad cracks, and
3 so, that's what he's going to talk about, is evaluation of
4 those under-clad cracks or inter-granular separations, as we
5 call them.

6 MR. YOON: Like Mark alluded to earlier, in the
7 early '70s, we found out these under-clad cracks. We have
8 an SER on it. So, that became one of the requirements on
9 this project.

10 So, we revisited that flow evaluation using
11 modern-day, better solution, as well as a lot more complex
12 loading tables we generated for this project.

13 So, the cracks we worry about is separation -- I'm
14 a fracture mechanics guy, so it's a flaw. The flaw has
15 maximum depths of .165 inches and lengths of .5 inches.
16 This diagram is not to scale.

17 So, we assumed, very conservative way, depth of
18 .353, including the cladding, and a length of 2.12. You
19 know, that was the basis for the input flow size, and used
20 this to go through all the particulate growth analysis using
21 all the load tables we created.

22 So, toughness curve -- so, we used code KONC, KONA
23 method of IW-3600 out of Reg. Guide 199 and particulate
24 growth out of Appendix A of the ASME Section XI code.

25 DR. SEALE: I'm curious. That looks more like a

1 separation on the lamination --

2 MR. YOON: Yes.

3 DR. SEALE: -- between the clad and the base
4 material.

5 MR. YOON: It's not really truly sharp crack.

6 DR. SEALE: It's not a crack, and you're not
7 saying that that kind of flaw would propagate in the same
8 way that a crack would propagate.

9 MR. YOON: It would not.

10 DR. SEALE: Okay.

11 MR. YOON: But there's no precise way of
12 predicting that.

13 DR. SEALE: Okay.

14 MR. YOON: So, we're attaching it all with very
15 conservative evaluations.

16 DR. SEALE: So, this is kind of a level of detail
17 in the modeling, even.

18 MR. YOON: Yeah. It's overkill, but it's a sure
19 way to get rid of the issue.

20 DR. SEALE: Well, as long as you can say it's a
21 conservative analysis.

22 MR. YOON: Yes, it is.

23 So, we had a normal and upset condition, 19
24 transients.

25 It's all reported in the Appendix C, and all the

1 design basis transients were used from functional spec, and
2 the stresses from various strategic locations -- we just
3 didn't take one location stress. We just went around,
4 sampled various locations, and we lumped all the fatigue
5 calculations into five groups, and we did thorough job, as
6 much as we can.

7 DR. SHACK: Five fatigue groups mean you had five
8 contributions to the CUF?

9 MR. YOON: This is a little different than CUF.

10 DR. SHACK: You're right. You're crack growth.
11 kay.

12 MR. YOON: So, the conclusion of this evaluation
13 is, for 48 EFDY, we'll be using all the base transient,
14 design base transient into the cycles. We can show that
15 this crack is no concern. Even though the assumption was
16 very conservative, even that we could show that this was
17 okay.

18 DR. SHACK: Now, in the crack growth analysis,
19 does it make a difference how you order the groups? Is that
20 what you do? You take the most conservative ordering?

21 MR. YOON: You mean for the crack stuff?

22 DR. SHACK: Yeah. When I do the fatigue crack
23 growth, it would be dependent on the order of the cycles,
24 wouldn't it?

25 MR. YOON: Yeah. So, what you do is you group

1 them and you somehow combine them per yield base, instead of
2 finishing one type of transient all the way through the
3 life, then attacking another one.

4 DR. SHACK: Okay. So, you bunch them by yield.

5 MR. YOON: Right. So, you take a portion of that
6 particular duty cycle as part of a per-yield base spectra.

7 That's my presentation.

8 MR. RINCKEL: Anymore questions for Ken?

9 CHAIRMAN BONACA: I have one.

10 You say that this crack -- you postulate it's a
11 conservative estimate. Why do you say that is a
12 conservative start for the analysis? Is it because, in
13 inspections, you have never seen a crack --

14 MR. RINCKEL: Yeah. The original size for the B&W
15 vessels was never bigger than 0.1-inch depth and a half-inch
16 in length, and we've started off with a larger depth than
17 that, which is the biggest that they saw in industry, and
18 so, that -- to start off with, and then I think the methods
19 that we used were just very conservative.

20 CHAIRMAN BONACA: I'm just trying to understand
21 what the words mean. That's because you have never
22 observations of cracks of that size. In fact, they are much
23 smaller than that.

24 MR. YOON: But the analysis assumed that that flaw
25 is breaking through the cladding.

1 CHAIRMAN BONACA: I understand that. I'm trying
2 to understand the context.

3 MR. RINCKEL: Did you have something, Barry?

4 MR. ELLIOT: This is Barry Elliot.

5 We addressed that issue in our SER. These are
6 under-clad cracks. Because they're under-clad, they have a
7 very, very slow growth rate. They're not surface-breaking.

8 As a result, they grow very, very slow, and the
9 assumption they make is that the clad goes entirely through
10 the clad, which is a very conservative assumption. We
11 addressed that in the SER, that issue.

12 MR. RINCKEL: Well, that really concludes our
13 presentation of the B&W owners group report, BAW-2251, and
14 then there are -- I think, certainly, you can see that we
15 demonstrate that aging of the reactor vessel will be
16 adequately managed to ensure the component-intended
17 functions during the period of extended operation in both
18 requirements for 5421A3 and 5421C, which are the aging
19 management review, and TLAA portions of the requirements in
20 the license renewal rule.

21 This report has been built on experience and
22 methodologies developed over the past 20 years and
23 outstanding reactor vessel integrity program, and the work
24 -- the fracture mechanics work are really the keys to show
25 that this vessel, the intended functions will be maintained

1 in the period of extended operation, and at this point, I'm
2 going to turn it over to Bob Gill, who will tell how Ocone
3 has used this report in their license renewal application,
4 unless there are further questions.

5 DR. SHACK: My question goes probably to Mr. Gill,
6 but when you do the plant-specific analysis for the Ocone
7 weld that didn't make the screening for PTS, the
8 plant-specific uses the surveillance data instead of Reg.
9 Guide 199 to estimate the shift?

10 MR. RINCKEL: Well, maybe Matthew is probably the
11 one to answer that, because we did re-do the fluence
12 evaluation, and it was somewhat -- a little bit lower than
13 what we had used in 2251.

14 What we used in 2251 for 48 EFPY was based on a
15 1994 estimate, and we have since revised all of that. There
16 had been a topical report that had been approved. So, the
17 fluence was a little bit lower, not a lot, I think within
18 about 3 to 5 percent, and there was some other chemistry
19 surveillance data.

20 MR. DEVAN: The evaluations were in accordance
21 with the regulations, which did -- you did have to consider
22 the surveillance data that was available. That was taken
23 into account in the evaluation. And based on all these
24 additional informations and reduced fluences, we came up
25 with a revised value of 296.8.

1 MR. GILL: This is Bob Gill.

2 Just a footnote on that. The original analyses
3 for the topical were done in the '94-'95 time period, and
4 you can see how robust the program is, that over time, as
5 more information is available, we had an even better
6 calculation at the time of application last year of 300.1,
7 and then subsequently we've done even more and gotten it
8 below 300.

9 So, it's just the evolution, and we'll continue
10 this program, the vessel integrity program, which I'll get
11 into briefly here.

12 So, it's just a natural process.

13 My name is Bob Gill. I'm with the Oconee license
14 renewal project. I was one of the members of the B&W owners
15 group vessel materials committee back in '77 at Duke, at the
16 very fledgling committee that we started out, and we had
17 serious concerns at that time of the licenseability of
18 Oconee and all the B&W vessels due to the upper shelf energy
19 concern.

20 So, a lot of effort was put forth at that time,
21 and thankfully, we've been able to continue that, and I
22 think this committee was also one of the main reasons why
23 the B&W owners group got involved in license renewal some
24 five or six years ago, and I appreciate the opportunity to
25 come back and speak to you all again. I think I was here

1 about 18 months ago.

2 I am going to talk to you about how Duke has taken
3 the generic owners group report and addressed the
4 plant-specific requirements that are identified there, and
5 in our application, we'll cover the overall Oconee
6 application where the report is covered, briefly go over the
7 process we use to incorporate it by reference in actually
8 all the reports that we are using, all four of them.

9 We'll address the plant-specific items, renewal
10 applicant action items. This is typical for any owners
11 group topical report that you saw, 95 or 98 percent of the
12 issues, but there are always going to be a handful of items
13 to be done on a plant-specific basis.

14 We consciously identified some of those. They
15 were just not mature at the time we put this report in in
16 '96.

17 And then I'll go over the Oconee-specific programs
18 and TLAA's that we addressed inside the application.

19 We organized the application so that the --
20 chapter two is primarily the scoping and screening results,
21 and 2.4 is the reactor coolant system, and 2.5 is the
22 vessel, and you'll see a parallel on the numbering scheme
23 that allows easier review.

24 All the vessel components that are subject to
25 aging management review, all the piece parts are discussed

1 and pointed to in section 2.4.5. All the aging effects
2 associated with the vessel are part of section 3.4.5.

3 The many programs that we credited are all
4 described in chapter four. We did not keep it similar to
5 the previous chapters because there are many programs that
6 cover components associated with other areas, like boric
7 acid wastage will be used in several areas, not just the
8 reactor coolant system.

9 Section 5.4 is our plant-specific time-limited
10 aging analyses, and the approved owners group reports are
11 referenced in each of these sections where applicable, if
12 you go through and review that.

13 We did that by conscious to make sure they are on
14 the public docket, they are on our docket at the time of
15 application.

16 In addressing the renewal applicant action items,
17 we created an item-by-item, two-column format table to
18 facilitate review by the staff, the public, the ASLB,
19 whoever.

20 In fact, we had some questions or potential issues
21 regarding that, because this report was still under review.
22 But we do have a two-column format, makes it very simple.
23 Here is the action item that's required; here is the
24 Oconee-specific response.

25 We provided to the staff in a May 10th letter, and

1 that was less than two weeks after the final SE was issued.
2 We knew pretty much what the issues were going to be,
3 because we had seen a Draft Safety Evaluation Report, and we
4 knew what the open items were. So, we were well prepared to
5 go ahead and address those.

6 For BAW-2251, there are 13 renewal applicant
7 action items, and we addressed all those in the report.

8 Just to summarize rather than belabor each one, we
9 had to verify that Oconee was bounded by the topical report,
10 and since we were intimately involved in the creation of the
11 report through the several years leading up to its submittal
12 and in the review, we were real confident about that, but we
13 went through another step to do that.

14 We actually created a process -- and Mark was
15 involved in that -- of going back and re-reviewing the
16 Oconee-specific information to make sure our chemistry was
17 the same, the materials are right, the Oconee-specific
18 documentation.

19 We have that in-house to verify that everything
20 that's said in a topical report does, in fact, bound the
21 design of Oconee, all three vessels.

22 We also verified that the programs and activities
23 that we credit in the topical report are, in fact, in place
24 at Oconee, and I'll go over those in more detail in a
25 moment.

1 We did have to perform the plant-specific
2 time-limited aging analysis, and we identified the fact that
3 the PTS value on unit two needed to be updated, and so,
4 we've actually done that twice now.

5 We did it at the time of application and then
6 again earlier this year.

7 So, we've gotten that down to below the 300
8 degrees, and another area was to provide summary
9 descriptions of all these programs and time-limited aging
10 analyses in the FSAR, and we, of course, did that as part of
11 the application.

12 This is a -- I believe a complete list of all the
13 aging management programs that we credit at Oconee, and the
14 number one item is a -- is our version of the reactor vessel
15 integrity program, and you can see here that we credit the
16 master integrated reactor vessel surveillance program that
17 Matthew talked about, the cavity dosimetry program -- we
18 have ex-vessel dosimetry on unit two that we periodically
19 remove.

20 That gives you a -- you know what the flux is at
21 the core, you have this ex-vessel dosimetry, you can then
22 project to see what the distribution is of the fluence, and
23 that helps validate your models.

24 We are updating the fluence and uncertainty
25 calculations. We're using the approved topical there,

1 keeping current on that.

2 We do pressure/temperature limit curves. We
3 currently have a set of curves, I guess, under staff review
4 for going out to 33 EFPY. We've already extrapolated that
5 out to 48 EFPY, so we know we're going to be able to operate
6 at that time.

7 This is an ongoing program, and another sub-part
8 of this overall program is counting the effect of full-power
9 years.

10 We have an engineer full-time in Charlotte that
11 monitors this, manages the program, attends the owners group
12 meetings that occur periodically, interfaces with the staff,
13 and this is his program to own and manage it, as well the
14 engineers at the site that actually help implement it.

15 So, we're pretty well vested in this area, and
16 it's a very important program. It's been around at Oconee
17 in one form or another for over 20 years.

18 DR. SHACK: Are the pressure/temperature limit
19 curves based on the new code case?

20 MR. GILL: Yes. Actually, they help give us a lot
21 more relief. There are several code cases, I understand,
22 that give us more relief on the MPSH and the minimum
23 temperatures we've got to have.

24 That's one of the reasons, even though that's
25 under review by the staff, that gives us confidence we'll be

1 able to have valid curves for 60 years.

2 Another major program that we have been involved
3 in -- and there's another engineer at Oconee -- at Charlotte
4 and Oconee that's involved -- is the control rod drive
5 mechanism, another vessel closure penetration inspection
6 program.

7 This is the CRDM vessel head. There's a generic
8 letter several years ago that came out -- I guess there was
9 European experience. We've had several inspections at
10 Oconee. We've been involved in the industry efforts. We
11 credit that as an existing program.

12 We have one more inspection scheduled this fall on
13 unit two, and we'll determine at that point in time what
14 additional inspections and how often and all. That is
15 really a living program.

16 That is probably the leading indicator of
17 alloy-600 activity in our alloy-600 program. This is the
18 leading indicator of what's going on due to the geometry,
19 the temperature, that type of situation.

20 Chemistry control -- our chemistry control program
21 is based on the EPRI water chemistry guidelines. It's an
22 industry standard. We continue to update that as new
23 chemistry guidelines come out. We keep current with it. I
24 don't believe the staff had any real questions or concerns
25 regarding this during the review.

1 We're real confident in that program in that
2 program, too. We have solid chemists and scientists and
3 engineers involved in monitoring, and this is a well-managed
4 program.

5 I mentioned the alloy-600 aging management
6 program. Alloy-600 is in several locations. We have
7 identified the most susceptible locations. In addition to
8 the control rod drive mechanisms, there are several
9 locations in the pressurizer which are leading indicators
10 because of the temperature there, and we will be inspecting
11 some of those locations in the future.

12 The in-service inspection plan is very
13 straightforward. That's your Section XI program. We are
14 currently using the '89 edition. We will continue to update
15 that every 10 years or whatever the regulatory requirements
16 are.

17 As time goes on, we've built into our commitment
18 either to continue using this or 50.55(a) or whatever
19 version of the code in the future. So, we've addressed
20 that.

21 That is definitely a living program.

22 Boric acid wastage surveillance program -- Duke
23 has had one of those for many years. There was a generic
24 letter several years ago.

25 This is an ongoing program. It covers not only

1 the reactor coolant system, the vessel, but other areas
2 inside containment, other systems, and in some cases, some
3 components in the auxiliary building that may be subject to
4 having boric acid wastage. It's primarily carbon steel-type
5 components.

6 We have a period monitoring program on that one,
7 also.

8 RCS operational leakage is a tech spec
9 requirement. It's monitored periodically for the tech
10 specs. This is a backup. We don't want to have leakage,
11 but if we do have it, I think the only place we credit it in
12 the vessel is the leakage between the head and the flange
13 area.

14 Certainly, we don't have any through-wall leakage
15 at all.

16 And the thermal fatigue management program, which
17 is becoming more and more formalized at Oconee, we credit
18 that through the reactor coolant system, monitoring fatigue
19 cycles.

20 We've had a lot of detailed discussion with the
21 staff on that, and we're working on improving the formality
22 of that program.

23 DR. SHACK: Just a question on your chemistry
24 control program. The units are running at different pH's
25 now, right? Some are higher and lower?

1 MR. GILL: I don't know off the top of my head on
2 that. They should all be about the same program, because
3 it's all one site.

4 CHAIRMAN BONACA: On the alloy-600 aging
5 management program, you said that you have the inspection
6 planned for the pressurizer?

7 MR. GILL: Yes. We have identified several
8 components in the pressurizer that -- pressurizer heater
9 sleeves on unit one, level taps and safe ends, spray nozzle
10 safe ends and the vent nozzles on unit three all seem to be
11 more susceptible than other locations.

12 CHAIRMAN BONACA: For those leading indicators,
13 what kind of frequency do you have for those inspections in
14 the program?

15 MR. GILL: We haven't identified a frequency yet.
16 We will be setting that up. We've committed to do at least
17 one inspection during the current 40-year term and also
18 looking at, you know, monitoring industry experience to see
19 what's going on.

20 We really need to look at the CRDM nozzles to see
21 what's happening there, how fast this is growing, and again,
22 I think it's the third inspection will be this fall, and
23 we'll see and let the materials engineers decide how often
24 is important enough to look at this.

25 CHAIRMAN BONACA: The question I have, I guess, is

1 regarding the program. Does the program include provisions
2 such that you could have indications --

3 MR. GILL: Yes, that's right. You'd set up a
4 frequency and come back every cycle, every two cycles,
5 whatever is important.

6 CHAIRMAN BONACA: So, you already have established
7 some criteria, some time tables and things of that kind.

8 MR. GILL: That's all described in our proposed
9 program on alloy-600, and that will be carried forth into
10 the FSAR supplement.

11 So, that commitment, then, becomes visible to the
12 operators to carry forth on. We make changes to it; it's
13 covered by the change process for the FSAR. All these
14 commitments end up being in the FSAR supplement, and that's
15 why that particular plant-specific action item was very
16 important, and it's something we're going to be discussing
17 with the staff over the next several months, is the right
18 level of detail there, make sure the right commitments get
19 carried forward and everybody understands how we go forward
20 here.

21 It's kind of new ground. We haven't had this kind
22 of detail previously in programs of this sort in the FSAR.

23 CHAIRMAN BONACA: So, all of these programs
24 essentially contains elements of further inspections and
25 frequency --

1 MR. GILL: Right.

2 CHAIRMAN BONACA: -- depending on the indications
3 you have, but what you're telling me is that you really
4 don't have yet experience in many of these programs.

5 MR. GILL: On the alloy-600, the commitment is to
6 do the inspection and, based on that, determine what
7 additional inspections are needed, does it need to be
8 broadened, do you need to come back a year or two later.
9 Those type of decisions are written into the program.

10 All of our programs have about 10 or 12 attributes
11 of things we need to do, what the effect is that you're
12 looking for, what the scope is, how often you're going to do
13 it, what's the first one, what's the technique or
14 methodology.

15 We decided that the best way to measure our
16 programs is to set these attributes up and then match up,
17 make sure all the corrective actions are done in accordance
18 with our existing problem investigation program, they're all
19 done pretty much by administrative controls which are
20 governed by the QA topical, and in some cases, there was a
21 regulatory standard that applies, in some cases not, and we
22 just put that down there.

23 So, the future works that have to look at this
24 understand that total history.

25 CHAIRMAN BONACA: Thank you.

1 DR. SEALE: I'm curious. You said that you had a
2 pressurizer sleeves, I think it was --

3 MR. GILL: Right.

4 DR. SEALE: -- that you were monitoring on unit
5 one, and there was something else on unit three and so on.
6 There is discernible differences between those two units
7 that tells you to focus on unit one in one case and unit
8 three in another?

9 MR. GILL: Actually, during the detailed review
10 that Mark did, we found out that the unit one pressurizer
11 heater bundles are actually different than units two and
12 three, have different design, different welding, and
13 actually have this alloy-182 weld in there, whereas units
14 two and three do not, and also, the design difference --
15 you'll have these as -- in the overall program, but what
16 we're saying is, even of this set of, say, the pressurizer
17 vent nozzles, the unit three nozzles are most susceptible of
18 all the vent nozzles, so we'll look at those. So, based on
19 the groupings, we'll actually look at the most leading
20 indicators of those.

21 DR. SEALE: That might suggest down the road that
22 you need to look at the unit two --

23 MR. GILL: Absolutely. If you start seeing
24 indications, the first thing you do is what about the
25 adjacent units, and you have to go in and look at them

1 perhaps at the next outage.

2 DR. SEALE: It would also appear that
3 communication between your experience and your cohorts in
4 the users group could very well suggest things both ways.

5 MR. GILL: And the industry, anybody doing
6 alloy-600 inspection.

7 DR. SEALE: Well, the users group, in particular.

8 MR. GILL: Absolutely. The communications is
9 extremely important as we start to see more and more
10 indications, more and more folks inspecting, rolling that
11 into the database, and certainly, the owners group will
12 continue on as long as they're owners, and you know, some of
13 the experiences come from ANO, some from TMI. Roll that in.
14 They talk periodically, make decisions on which ones to
15 inspect.

16 So, it's very important.

17 Now we're getting into owners group activities,
18 but yes, it's a very important thing.

19 That's one reason we're confident. It's not just
20 us working on this. We have this resource of everybody else
21 out there in the industry that's looking at the same thing.

22 The other owners, EPRI and any work they may be
23 doing to help us, European experience, if that comes into
24 play -- a lot of that helps drive -- that's why it's
25 difficult to say an exact frequency or when you're going to

1 do something, because you have a lot of factors from the
2 outside world that may say you need to do that next outage,
3 not -- you can't wait five or 10 years.

4 CHAIRMAN DONACA: Just one last question about
5 that overhead, the previous one.

6 Of these programs that you have, I guess all of
7 them will be still in place if you do not go to life
8 extension.

9 MR. GILL: That's correct. These are all existing
10 programs. Alloy-600 is -- we proposed as a new one, but in
11 fact, we do have activities underway today in that area.
12 But all these others are, in fact, existing programs that we
13 have in place today.

14 We're very fortunate that we've had such a robust
15 set-up on the reactor vessel and in the entire reactor
16 coolant system, very few new programs.

17 DR. SEALE: Are there commitments in these other
18 programs, however, that have been added to those programs as
19 a result of the aging analysis?

20 MR. RINCKEL: I can answer that, Bob. The CRDM,
21 another vessel closure penetration, is one example of that.
22 That is an ongoing existing program where there's a
23 requirement that they will have to do and continue the
24 inspections through the period of extended operation.

25 DR. SEALE: I mean have you added things?

1 MR. GILL: I'm trying to think on the adding. Not
2 on the vessel per se.

3 We've added some pressurizer -- based on the
4 pressurizer topical report that was reviewed, we've added
5 some examinations of the pressurizer, and in the piping, we
6 have added some examinations of small-bore piping, and so,
7 there have been some small areas outside the vessel. The
8 bulk of our new programs and activities have been outside
9 the reactor coolant system completely, and of course, the
10 vessel internals, which we may get to later.

11 Okay?

12 I should point out, for each one of these
13 programs, we have some lead engineers at Duke, either at the
14 site or in the corporate office, that monitor -- own up to
15 these programs, not just sitting up there in space.

16 The time-limited aging analyses for Oconee -- the
17 B&W topical, 2251, was the first topical we had actually on
18 the opportunity to identify what the TLAA's would be and
19 then take time to do the evaluation on a generic basis.

20 The previous topicals on pressurizer and piping
21 did not -- we had not identified what they would be, so we
22 could not evaluate them.

23 So, for Oconee, we actually -- you know, for
24 thermal fatigue that Mark talked about earlier -- that's
25 managed by our thermal fatigue management program.

1 For the flow growth analyses, we did review all
2 the previous in-service inspections handled on Oconee for
3 the previous 20 years, identified one indication at unit one
4 on the vessel.

5 We've identified others in other components, but
6 this is the one on the vessel, and that is being addressed
7 by our fatigue program.

8 For pressurized thermal shock -- and we've talked
9 about this several times now -- we've updated the chemistry,
10 updated the fluence, and now all three units are well within
11 the limits for 60 years.

12 For upper shelf energy and inter-granular
13 separation, we determined we were bounded by the generic
14 analysis, so no further review was required.

15 The beauty of these topical reports is, once we
16 work with the staff and work through it, then the subsequent
17 users of it need not go through that. Instead of reviewing
18 a whole document, you're down to 13 applicant action items
19 to look at.

20 DR. SHACK: That reactor vessel indication --
21 that's a fabrication flaw?

22 MR. GILL: I believe it was, yeah.

23 MR. RINCKEL: Yes.

24 MR. GILL: It was determined real early and was
25 analyzed and accepted at that time. We just went back and

1 re-looked at the analysis and updated it, and we found, you
2 know, several across the whole reactor coolant system we had
3 to do that, and it was, again, the QA records we had to go
4 back to. We had to go back to the ISI reports.

5 Duke's practice at the time was to send in the
6 actual calculations to the staff. So, it met all the six
7 criteria for being a time-limited aging analysis.

8 So, we had the opportunity to go ahead and look at
9 all those, but they all turned out okay.

10 Okay.

11 On the conclusions from an Oconee perspective, the
12 vessels are, in fact, bounded by the topical report, and it
13 was a well-worth effort for us to do.

14 The programs that we currently have will continue
15 to effectively manage all the aging effects of our vessels,
16 and the plant-specific time-limited aging analyses have been
17 evaluated for the 60-year operation, and we feel real
18 comfortable and confident that we know about the vessel.
19 Many of us -- some of us, I guess, have been working on this
20 thing for over 20 years.

21 Any questions about the Oconee perspective on the
22 vessel? We'll get into more about the application in the
23 review later this afternoon.

24 [No response.]

25 MR. GILL: Okay.

1 CHAIRMAN BONACA: Thank you for that presentation.
2 It was informative.

3 MR. GILL: We'll turn it over to Barry, I guess,
4 of the staff.

5 MR. ELLIOT: My name is Barry Elliot. I'm with
6 the Materials and Chemical Engineering Branch of NRR. Today
7 I'm going to give you our perspectives on our review of
8 BAW-2251 and also discuss some of the open issues, how
9 they've been resolved, plant-specific issues and how they've
10 been resolved for Oconee.

11 I had help on this review from the people over
12 here.

13 We've completed the review of 2251. There were no
14 open issues; there were no confirmatory issues. There were
15 aging management programs, which was discussed by the -- by
16 Duke and by Framatome. We're not going to repeat all that.

17 We will, though, tell you that the first three
18 programs are discussed in our SER, and they are common aging
19 programs, so they're discussed in more detail under section
20 3.2 of our SER.

21 The bulk of today's discussion will be thermal
22 fatigue and the B&W owners group reactor vessel integrity
23 program. As discussed by Duke, the integrity program
24 consists of surveillance data and analyses, and we'll be
25 discussing that in detail.

1 There were 13 identified plant-specific renewal
2 action items identified by the staff in its SER. Duke has
3 responded to all 13. At the moment, there is one open item.
4 The 13 items deal with scoping, aging management, and
5 TLAA's, time-limited aging analysis.

6 The one open item is related to the time-limited
7 aging analysis, and it deals with the question of flaw
8 growth, of the flaw in the unit one reactor vessel. We'd
9 like to look at that in a little more detail to make sure
10 it's being analyzed correctly.

11 That's the only open item at the moment.

12 DR. SHACK: That's the existing flaw that they
13 have, the fabrication flaw?

14 MR. ELLIOT: Yes.

15 DR. SEALE: That's strictly an analysis?

16 MR. ELLIOT: At the moment, it's an analysis. We
17 want to make sure that whatever inspections are going to be
18 done in the future, that they're going to be adequate for
19 the life of the plant.

20 DR. SEALE: Is that flaw of a kind that's
21 susceptible to inspection?

22 MR. ELLIOT: We haven't seen the analysis yet. We
23 haven't gotten that far. That's the open issue, to look at
24 the analysis, look at the inspection methods, and come to
25 the conclusion, you know, what we have to -- if there's

1 anything more than the ASME code required here.

2 Right now, they're only limited by the
3 requirements of the ASME code, and we have to decide for
4 ourselves whether additional requirements are necessary.

5 There are two significant -- very significant
6 license renewal issues. They are the vessel surveillance
7 program and the fatigue of the metal components.

8 Fatigue of metal components is concerned with the
9 impact of environmental fatigue on the usage factor. The
10 staff has completed its review of this issue. The licensee
11 has done an analysis.

12 It has looked at the impact of environmental
13 fatigue based on the models described in NUREG-6335, and the
14 staff has determined that the B&W owners group has
15 adequately addressed GSI-190 regarding environmental fatigue
16 of the reactor vessel components, and the fatigue of the
17 Oconee reactor vessel will be managed during the period of
18 extended operation.

19 Now we get to vessel surveillance, and this is a
20 little broader picture of the vessel surveillance.

21 Framatome described their program. Oconee is part
22 of an integrated surveillance program.

23 Participating in that program and having
24 plant-specific capsules in that program are from the three
25 Oconee units, TMI one and two, Crystal River, Arkansas

1 Nuclear one, Davis-Besse, and Midland, and in addition, it
2 has supplementary capsules.

3 The advantage of this program is that it provides
4 a vast amount of data, much more than would be normally
5 attributed to an in-vessel surveillance program.

6 In a normal in-vessel surveillance program, only
7 one heat of weld wire would be part of the program, and it
8 may not even be the limiting weld, and that would be the
9 requirement today for any in-vessel surveillance program.

10 The Oconee one belt-line, unit one has three
11 circumferential welds and six axial welds. There are six
12 heats of different weld materials in that belt-line.

13 Oconee unit two has three circumferential welds
14 but only two with significant amount of fluids, and they
15 have two heats of weld material.

16 Oconee unit three also has three circumferential
17 welds but only two with significant fluence, and they have
18 three heats of weld material in their belt-line.

19 So, in unit one, there are six heats of weld
20 material. Four of the heats of the weld material have
21 surveillance data, and if it was just a plant-specific
22 evaluation, we were lucky if we got one.

23 For Oconee unit two, both heats of weld material
24 in the belt-line have surveillance data, and for Oconee unit
25 three, all three heats in the belt-line have surveillance

1 data.

2 That's the advantage of an integrated surveillance
3 program. The disadvantage is that there's no way to monitor
4 embrittlement if something changes in the reactor vessel
5 design.

6 That is, if they change some core design
7 significantly or significant changes in the dimensions or
8 something, or cold leg temperature, let's say, we do not
9 have data by which to determine the effect of the
10 embrittlement.

11 So, what we've had Duke do is establish limits on
12 the critical nuclear environment conditions such as gamma
13 heating, radiation temperature, neutron flux, and neutron
14 fluence, and they are to monitor those conditions during the
15 license renewal term, and if they project that they are
16 going to go outside those limits, then they would have to
17 come back to us and propose an additional program.

18 The current surveillance program only applies as
19 long as they stay within those limits.

20 There are four TLAA's associated with the reactor
21 vessel. The fatigue of metal components. The staff
22 reviewed the TLAA evaluation, and the staff concluded that
23 the TLAA evaluation performed by the B&W Owners' Group on
24 fatigue of reactor vessel components was acceptable except
25 for the Oconee reactor vessel studs. They became a

1 plant-specific action item. Ocone has reviewed, has
2 reevaluated the studs and found them acceptable, and the
3 staff agrees. So that issue is closed.

4 There is an open issue on the fatigue part, and I
5 talked to you about that before. That was the floor
6 evaluation. We need to look into that a little more.

7 Pressurized thermal shock. The neutron fluence --
8 there are two parts to the pressurized thermal shock. There
9 is a neutron fluence part and the chemistry part, and the
10 surveillance data part. I'm going to talk a little bit more
11 about the chemistry and the surveillance data in a few
12 minutes, but on the next slide. The neutron fluence
13 methodology was reviewed by the staff and found acceptable.
14 There was a charpy upper-shelf energy evaluation --

15 DR. SEALE: Excuse me.

16 MR. ELLIOT: Yes.

17 DR. SEALE: It was a month and a half ago,
18 roughly, or maybe two and a half months ago --

19 MR. ELLIOT: Yes.

20 DR. SEALE: Time flies when you're having fun.

21 We heard from the people in Research about a look
22 at the whole question of pressurized thermal shock, and in
23 particular not only the chemistry that you indicated, but
24 also the distribution of the flaws.

25 MR. ELLIOT: Yes.

1 DR. SEALE: And they indicated that a systematic
2 look at that problem or that aspect of the problem was under
3 way. Is that in any way reflected in any of the materials
4 here?

5 MR. ELLIOT: No, it is not. That's a research
6 program?

7 DR. SEALE: Yes.

8 MR. ELLIOT: This is a regulatory program.

9 DR. SEALE: Okay.

10 MR. ELLIOT: And it's based -- a regulatory
11 program is based upon the analysis we did early when we
12 developed the PTS Rule, which is SECY-82-465, and the
13 reports that we did for Oconee -- I can't remember the other
14 plant.

15 DR. SEALE: So --

16 MR. ELLIOT: They were done in the eighties.

17 DR. SEALE: Yes.

18 MR. ELLIOT: And this criterion was developed from
19 those analyses. What Research is doing is they're taking
20 the more -- another look at those type of analyses using --

21 DR. SEALE: With hopefully a more realistic flaw
22 distribution.

23 MR. ELLIOT: With a more realistic flaw -- what
24 they say is more -- what we say is a more realistic flaw
25 distribution, and seeing what the impact is on the screening

1 criteria of the PTS rule. It may be that it goes up. In
2 that case, you know, maybe no one has a problem. Or, you
3 know, it might go down, depending on -- there are a whole
4 bunch of issues here that have to be evaluated, not only --

5 DR. SEALE: But the expectation is after that
6 you'll be able to say and how.

7 MR. ELLIOT: Right. And -- so there's more than
8 just --

9 DR. SEALE: Yes.

10 MR. ELLIOT: Flaw distribution here that's at
11 issue. There's --

12 DR. SEALE: Chemistry and --

13 MR. ELLIOT: A whole bunch of things. But this
14 rule -- what we're talking about today is what we
15 developed --

16 DR. SEALE: I got you.

17 MR. ELLIOT: More than 15 years ago. Okay?

18 The B&W Owners' Group did a charpy upper-shelf
19 evaluation, an upper-shelf energy evaluation, and it's
20 contained in a topical report. We reviewed the topical
21 report, and we concluded that it provided sufficient
22 fracture toughness data and analysis to demonstrate that all
23 the member plants could meet the requirements of Appendix G,
24 10 CFR 50, and the ASME code at the end of the license
25 extension period.

1 The upper-shelf energy evaluation was just an
2 extension of the previous evaluation. The previous
3 evaluation, which had been done in the mid-nineties, was for
4 40 years, and this evaluation just extended it to 60 years.

5 The next -- we also reviewed a Topical Report 2274
6 which had to deal with growth of intergranular separation
7 and low elasticity of forgings in the heat-affected zone of
8 stainless steel weld deposit cladding. Duke went into a lot
9 of detail on that. I would just like to add that the
10 previous analyses were done in the seventies. Since then
11 there has been a lot of changes in the fracture mechanics
12 analyses. This new submittal contains all those changes.
13 It is the most up-to-date analysis. It evaluates fatigue,
14 the growth of cracks, as well as embrittlement. And it
15 incorporates the latest technology we have in those areas.

16 We concluded the analysis demonstrates that the
17 underclad cracking will not be a problem. It will meet the
18 ASME Code fracture toughness requirements for fracture at
19 the end of 60 years.

20 There are two things I think are very significant
21 that I thought were of interest, and that was the integrated
22 surveillance program and the PTS analysis. I discussed the
23 integrated surveillance program. I'd like to discuss now
24 the PTS analysis in a little more detail as is written here.

25 Our original estimate when the B&W report -- BAW

1 2251 was given to us, we determined that Oconee Unit 2 upper
2 shelves and lower shelves circ weld would be over the
3 screening criteria at the prior to 60 years. So we made
4 this a plant-specific action item. Duke has responded and
5 they've revised the fluence, and in addition I just want to
6 say it revised the chemistry. This is an active program
7 that had been going on since 1992. It had nothing to do
8 with this submittal.

9 We had during the Palisades review discovered that
10 plants were not sharing data sometimes and they weren't
11 reviewing all the data, so we put out a generic letter in
12 which we requested everybody to evaluate their chemistry
13 data relative to all the other data existing in the industry
14 as well as the surveillance data. And it went on for about
15 three or four years, and as a result, there are some new
16 chemistries. In this case the chemistry went down slightly,
17 and that impacted their evaluation, where instead of having
18 a PTS -- RT PTS value of 304, it went down to 297.

19 We compared -- the methodology was the discussed
20 earlier, was that they used the chemistry to determine the
21 amount of embrittlement. We looked at that. We compared it
22 to the surveillance data that was available for this heat of
23 material, and that assumption is conservative for this heat.
24 So we feel that the value of 297 is applicable.

25 DR. KRESS: Would you have reached that same

1 conclusion if the value had stayed at 304?

2 MR. ELLIOT: It would have been even more
3 conservative. I mean --

4 DR. KRESS: Yes, it would have. That's right.

5 MR. ELLIOT: What we look at when we make the
6 judgment is the RT PTS value is the sum of three quantities.
7 It's the sum of the initial value --

8 DR. KRESS: Shift.

9 MR. ELLIOT: The shift, and margin. And we look
10 at what -- the surveillance data shifted. Is it accounted
11 for in the shift plus the margin? And in this case it was
12 accounted. The surveillance data is less -- the shift in
13 the surveillance data could be accounted for by those
14 quantities. Or actually those quantities were more than the
15 shift in the surveillance data, so they consider it's
16 conservative.

17 DR. SHACK: When those chemistries change, is that
18 because somebody else brought in -- I mean obviously the
19 chemistry changes from point to point in the weld when you
20 take the sample.

21 MR. ELLIOT: Yes.

22 DR. SHACK: You just have more data and you do a
23 statistical analysis and that gives you slightly different
24 numbers when you look at larger data sets?

25 MR. ELLIOT: Yes, that's what's happening. In the

1 past we had plants that had their own little data sets, and
2 no one ever put them -- no one had put them all together.
3 B&W had done a little bit of that, but it wasn't all
4 together. And when we put out the generic letter, different
5 owners' groups started putting all the data together. Don't
6 forget, B&W fabricated vessels for Westinghouse in
7 themselves, so we had to get all the Westinghouse data
8 together with the B&W data and put it all together to get
9 the most accurate values of chemistries.

10 DR. UHRIG: So what you're saying is that you have
11 more confidence in the large sample of data as opposed to
12 the individual plant --

13 MR. ELLIOT: Right. It's a more robust data base
14 now than we've ever had.

15 DR. SHACK: You mean nobody actually went off and
16 did more chemistry analyses. They basically just looked at
17 all the data that was really around and looked at it in
18 toto.

19 MR. ELLIOT: That's true.

20 That's all I have to say today. Thank you.

21 CHAIRMAN BONACA: Okay.

22 MR. GRIMES: If there are no other questions on
23 the staff's review of the B&W vessel topical and the related
24 topicals, the staff will proceed with a presentation on the
25 status of the license renewal activities. We would begin by

1 presenting a general picture of where we stand generically,
2 license renewal issues, and the overall program attributes.
3 And that's going to be presented by the license renewal
4 project manager for Oconee, Joe Sebrosky, who is being ably
5 assisted by Steve Hoffman, who's a senior project manager in
6 the License Renewal and Standardization Branch.

7 CHAIRMAN BONACA: Yes. And the fact, you know, we
8 are running ahead of time, and I think it would be
9 appropriate to continue with the presentation and maybe a
10 second one we have scheduled for the afternoon so we can
11 gain some time. So with that, let's proceed.

12 MR. SEBROSKY: Good morning. As Chris said, my
13 name is Joe Sebrosky. I'm project manager for Oconee
14 license renewal. And to my left is Steve Hoffman.

15 What I'd like to go over is in general the status
16 of license renewal activities, and also a broad overview of
17 the SER related to Oconee license renewal.

18 The way that we're going to present this
19 material -- you've already seen a foreshadowing of this this
20 morning -- we have lead presenters for each section that are
21 going to do the presenting, but we will also have the
22 principal reviewers in a panel-type discussion up here at
23 the front. And for the most part, that's what you'll see.
24 In some selected cases, you will see just one individual up
25 here giving the presentation.

1 That's the first couple of slides, just to let you
2 know for the particular sections who the lead presenters
3 are.

4 I guess I'd like to go to the status of license
5 renewal issues, which is slide number 5 in the package. And
6 for the first section, for license renewal issues, as the
7 subcommittee is aware, there's 108 license renewal issues
8 that the staff is currently tracking. Most of these issues
9 were given to us by NEI in the form of comments on the draft
10 standard review plan that we had issued. Out of these 108
11 issues, we've binned them into Priority 1, Priority 2, and
12 Priority 3.

13 Priority 1 items mean that the resolution of those
14 particular issues are needed or the staff felt it was needed
15 in order to resolve issues associated with either Calvert
16 Cliffs or the Oconee license renewal application.
17 license renewal which

18 DR. SEALE: Okay.

19 Priority 2 items are less important items but are
20 of a general nature and then Priority 3 are lower priority
21 than that. Out of the 108 issues, the Staff has written
22 proposed resolutions for nine, and the process in general
23 for resolving 108 issues is that the Staff after some
24 dialogue with NEI, the Staff writes a generic position for
25 that particular issue and that is what we have done in the

1 case of nine issues.

2 We expect then that NEI would write back to us and
3 either agree with the disposition or take some exceptions to
4 it. They have only written back to us on one issue, so out
5 of the nine issues that we have sent letters to NEI on, we
6 have gotten a response to one.

7 Down the line, once we have that response, once
8 the issue is settled, then the only activity that is left is
9 we have to determine the appropriate disposition for that
10 resolution, be it NEI 95-010, which is the industry guidance
11 or SRP or the draft Regulatory Guide.

12 DR. SEALE: You've got 108 initially and it looks
13 like you have got a pretty tall hill to climb, but I need a
14 little bit more information to decide how tall.

15 Of that nine, you have had comments on one. Have
16 you received any indication that you are going to get
17 comments on the other eight or that the other eight are
18 satisfactorily resolved?

19 MR. SEBROSKY: I will turn it over to Mr. Grimes.

20 MR. GRIMES: We have gotten some indications that
21 whenever we agree with NEI, we've gotten an indication they
22 are going to be satisfied with the answer.

23 DR. SEALE: Yes, but that still evades my
24 question.

25 MR. GRIMES: We are going to talk to you tomorrow

1 about this issue associated with credit for existing
2 programs, which really gets -- I think that is going to be
3 the watershed event that is going to help us start dealing
4 with these issues in a more expeditious way.

5 There were 17, I believe -- Steve, 17 Priority 1
6 issues?

7 MR. SEBROSKY: That is correct.

8 MR. GRIMES: And we have addressed all of those in
9 the safety evaluations for Calvert Cliffs and Oconee. We
10 have dealt with those issues in some shape or form. As a
11 matter of fact, the issue of credit for existing programs,
12 we have also addressed in the reviews for Calvert Cliffs and
13 Oconee because we have reviewed all the programs. We didn't
14 make any distinction about whether they existed or not, and
15 that formed the basis for our safety evaluation, but at this
16 point I think that once we get over a Commission decision
17 associated with the scope and depth of the Staff's review,
18 then the NEI Task Force and we will have a clearer
19 understanding of the expectation about the depth of the
20 safety evaluation basis for these issues, and so I think
21 that then we will start to see the dialogue pick up quicker
22 on these others, but at this point the indications are that
23 NEI is relatively satisfied. We haven't heard any
24 significant complaints.

25 DR. SEALE: Well, you basically have 99 or 100

1 rather than 108.

2 MR. HOFFMAN: And another point, too, is remember,
3 these came in as comments on the Standard Review Plan. They
4 are not all major issues.

5 DR. SEALE: I appreciate that.

6 MR. HOFFMAN: Some of them are just improvements,
7 comments where we can revise and make the SRP a little more
8 efficient.

9 DR. SEALE: Sure.

10 CHAIRMAN BONACA: You said that there were 17
11 Priority 1 issues, and also you said that they were
12 addressed in terms of Ocone and the BG&E application.
13 Okay. How come you only have nine proposed resolutions?
14 You seem to have 17 resolutions.

15 MR. GRIMES: Well, we just addressed the other
16 eight issues directly in the review, but we haven't got a
17 safety evaluation that addresses how we would propose to
18 deal with it on a generic basis like we do for these nine
19 issues.

20 CHAIRMAN BONACA: Okay.

21 MR. GRIMES: And so we just incorporated it into
22 the Staff's review. We dealt with the issue as it was
23 presented to us in these first two applications but there is
24 a lot more work that goes into developing a generic safety
25 evaluation that explains what the expectation is for all

1 plants.

2 DR. SHACK: But it is kind of a misnomer to say
3 the Priority 1s are the ones that have to be resolved in
4 order to do these, because you have essentially done that
5 part for the plant-specific.

6 MR. GRIMES: That is correct, but remember we
7 described these things as Priority 1 before we began the
8 review for the first two plants, and so you are correct, to
9 continue to call them Priority 1 must be resolved for the
10 first two applications is misleading to that extent.

11 We would have hoped that we would have had generic
12 resolutions on these issues but that process hasn't gone as
13 fast as we would have liked. As a matter of fact, it got
14 substantially derailed with this credit for existing
15 programs issue because almost all of our attention has been
16 devoted to developing the underlying policy issues to
17 present to the Commission.

18 CHAIRMAN BONACA: You seem to characterize the 108
19 issues as really centering regarding the depth of NRC
20 review. Is that a pretty good characterization of the
21 thrust of the dialogue you are having with NEI?

22 MR. GRIMES: Yes, because as Steve pointed out,
23 the vast majority of those came from specific comments that
24 we got from NEI on the Standard Review Plan.

25 Since the Standard Review Plan represents the tool

1 by which the Staff is directed to perform a review of
2 scoping, screening and aging management, and time-limited
3 aging analysis, it is fair to characterize those issues as
4 scope and depth of the Staff review.

5 MR. SEBROSKY: If there's no more questions about
6 the license renewal issues, I will go on to the standard
7 format for the application.

8 DR. SHACK: Let me just ask one question.
9 Obviously you are getting generic solutions. I mean you are
10 not going to be going over the pressure vessel report for
11 ANO-1. You have reviewed that. Do you have any feel for
12 what fraction of the work is being done generically, you
13 know, for the next B&W license renewal? Are you going to
14 say 15 percent of the effort, 20 percent?

15 MR. GRIMES: That is the second time that question
16 has come up. The CFO always asks that question when they
17 look at the budget numbers.

18 It is difficult to say because, for example, Barry
19 Elliot pointed out in his presentation that there is a
20 broader generic issue associated with how to treat the
21 vessel for all plants.

22 The B&W owners have a program, but then the CE
23 owners have a different program. The BWR Owners Groups have
24 two or three programs. Westinghouse has 51 varied units and
25 I don't know that I could find the Westinghouse program

1 simply because of its diversity, but at the same time we
2 need to put some clear guidance in the Standard Review Plan
3 that talks about treatment of the vessel program and so we
4 have got one piece of that generic answer with this B&W
5 evaluation, but that does not necessarily mean that what we
6 worked out in terms of the safety evaluation basis for
7 BAW-2251 constitutes "the answer" -- the generic answer that
8 could apply to all of the owners' groups.

9 Looking at it from that perspective, I think that
10 we made a substantial gain. Whether it is 15 percent or 20
11 percent is very difficult for us to measure. It will vary
12 according to the issue. It will vary according to the
13 extent to which there are generic features of these issues
14 that cut across all plants.

15 I think I could contrast the reactor vessel issue
16 with the containment issue. What is the appropriate
17 standard for maintenance and surveillance requirements for
18 containments? There are three different BWR containment
19 designs. There are dry -- there are three different kinds
20 of dry containments. There's subatmospheric containments.
21 Yet the industry's simple view is why don't you just say the
22 maintenance rule and IWL is satisfactory and leave me alone?
23 Maybe I said that in too pejorative a way, but it is
24 difficult for us to say that there's a simple explanation of
25 what constitutes the containment program that will manage

1 aging effects that are applicable to all containments for a
2 20-year period of extended operation that begins about 14-15
3 years from now, and then we'll extend 20 years beyond that.

4 I am not going to be here to make sure that I did
5 it right, even if I live that long, so that is a long-winded
6 answer to say no, I don't have a number for you.

7 MR. SEBROSKY: Continuing on, for the standard
8 format for applications, Steve is actually the lead for
9 this, but I'll go ahead and give you the highlights.

10 Back in March we transmitted to NEI, we
11 transmitted the formats for both the Calvert Cliffs and the
12 high level format for what the Oconee SER was going to look
13 like. That was given to NEI with the thought that when a
14 high level look at what we did for operating reactors the
15 SRP and the SERs along with the applications are one and the
16 same, as far as what is discussed in what chapters.

17 In order to try to come to a convergence on what
18 an application should look like, that is the main reason
19 that we transmitted the SER formats for Calvert and for
20 Oconee to NEI.

21 There was a public meeting on April 13th and NEI
22 has responded in a June 17th letter -- we just got the
23 response -- where they essentially provide us two different
24 formats. One format looks like the SERs. If you look at
25 the SER for Calvert and you look at the SER for Oconee you

1 will see on a high level that they are very similar.
2 There's of course some differences in the details, but as
3 far as what is discussed in what section, the SERs are
4 pretty close.

5 The one format that NEI provided in the June 17th
6 letter looks similar to that SER format. They also provided
7 us a format that is different, that's based on a commodity
8 group approach and Steve is trying to set up a meeting in
9 mid-July to discuss the two different formats with NEI. The
10 hope is that we will converge to one format and come to an
11 agreement.

12 MR. SEBROSKY: That's where we stand on the
13 standard format for the applications.

14 DR. SEALE: Does everybody know what the commodity
15 group program is?

16 MR. SEBROSKY: I have to admit to you that that's
17 one of the reasons for the meeting, is to try to understand
18 the commodity group approach and why it was chosen.

19 Going on to the next slide, the status of the
20 standard review plan and reg guide and NEI 95-010, I think
21 the subcommittee is aware that these documents are in a
22 draft form, the draft SRP and the draft reg guide.

23 As far as NEI 95-010 goes, that was issued in
24 March '96, and the draft reg guide proposes to endorse it.
25 As far as the SRP and reg guide update plan goes, Chris

1 alluded to the credit for existing program issue that goes
2 to the heart of the scope of the staff's review and also the
3 depth of the staff's review. And you'll hear some more
4 discussion about that tomorrow, but obviously we have to
5 figure out where we're going in those two broad areas before
6 we can come up with an update plan as to how that'll affect
7 the SRP and the reg guide.

8 That is basically the high-level status of the
9 license renewal activities. I guess I'd like to move on and
10 give you a broad overview of the Oconee license renewal
11 application.

12 This slide basically has the same information that
13 Greg Robinson provided earlier. I'll just touch on a high
14 level on some notes.

15 If you look at the schedule in general, we've met
16 all the milestone schedules. Both the staff and Duke have
17 met all the milestone schedules. The SER was actually
18 issued a day ahead of schedule. It was scheduled to be
19 issued June 17, and we issued that on June 16.

20 As far as the hearing status goes, Greg mentioned
21 that there was a potential intervenor, the Chattooga River
22 Watershed Coalition, and the only thing that I would have to
23 add to Greg's discussion was the Commission did affirm the
24 ASLB's decision to deny the petition in April. The deadline
25 to file an appeal by Chattooga has just recently passed, and

1 the staff has not seen any appeal filed by Chattooga River
2 Watershed Coalition.

3 As far as the comparison between the Oconee and
4 Calvert Cliffs license renewal reviews, there are some
5 obvious differences. One is a CE plant; the other's a B&W
6 plant. But if you look at the applications, you'll note
7 that Calvert was pretty much based on a vertical approach,
8 in that they for a particular system would list how they did
9 the scoping and screening process for that system, how they
10 identified the aging effects, the aging-management programs
11 and TLAA's. It was based on a system approach.

12 If you look at Duke's license renewal application,
13 it's more on a horizontal approach. Chapter 1 is the
14 introduction. Chapter 2 on a high level is how they did the
15 scoping and screening process broadly. Chapter 3 is the
16 aging effects. Chapter 4 is the aging management programs.
17 And Chapter 5 is the TLAA's.

18 When you look at the SER's for Calvert and for
19 Oconee, you'll note that the SER's actually look more like
20 the Oconee approach, in that chapter 1 is an introduction,
21 chapter 2 discusses the scoping and screening process for
22 particular systems, chapter 3 is actually a combination of
23 the aging effects and aging management programs, and then
24 chapter 4 is a discussion about the TLAA's. So although the
25 applications differ in their approach, the SER's look

1 similar.

2 Also, we've -- as you know, Duke relied on several
3 topical reports, and that's been discussed. Specifically
4 they relied on topical reports for RCS piping, pressurizer
5 reactor vessel internals, and fluence methodology. So
6 that's a difference between Calvert and the Oconee approach.

7 The only other thing that I'd like to mention as
8 far as differences go is when you actually look at the
9 plants themselves there are some differences, although we're
10 trying to come to convergence. With 103 plants out there,
11 you're going to come across unique differences. And when
12 you look at Oconee, some of the differences are that they
13 have a hydroelectric plant as an emergency power supply.
14 They also have a building called the standby shutdown
15 facility that doesn't exist at Calvert.

16 Anyway, I just give you that as a note that
17 generic resolution can only go so far.

18 Continuing on with the license renewal
19 application, regarding the license renewal inspections,
20 there's actually two inspections that are scheduled, and
21 there's a third inspection that's optional. The first
22 inspection was on the scoping and screening process, and
23 that was done in April. The finding out of the inspection
24 report or actually I'll read you a sentence from the
25 beginning of the inspection report.

1 It basically says with the exception of the items
2 identified in this report, your scoping and screening
3 process was generally successful in identifying those
4 systems, structures, and commodity groups required to be
5 considered for aging management. The issues that are
6 detailed in that inspection report you will also see crop up
7 this afternoon in Bob Latta's discussion. We do have an
8 open item in that area that Bob Latta will talk about. And
9 the inspection report alluded to that open item.

10 The second set of inspections are on the
11 aging-management review, and that's actually broken up.
12 It's a two-week inspection. The first part happens July --
13 is scheduled for July 12, and the second portion of that is
14 scheduled for July 26. The staff has actually -- because
15 one of the units will not be in an outage during that time
16 frame, the staff has already gone down there when Unit 1 was
17 in an outage to take a look at areas that are not going to
18 be accessible when they go down there in July.

19 And then the last inspection is a final
20 verification which is at the region's discretion, and that's
21 an optional inspection.

22 As far as the future for the Oconee schedule, if
23 you go back to the schedule dates, the next target date is
24 Duke is to respond to the open items by October 15. The
25 staff is scheduled to issue the SER in February. The ACRS

1 final meeting is scheduled for May. And then the license
2 renewal is scheduled for August 2000.

3 I'd like to move on on a high level and let you
4 know how we handled the Priority 1 license renewal issues
5 for Duke. The next two slides in the package basically tell
6 you what the issue is, a brief description, and then where
7 it's dispositioned in our SER. And the lead presenters will
8 talk about the issues when they come up here. There are,
9 however, four issues that will not have further discussion,
10 so I'd like to touch on those quickly.

11 The first of those would be 98-0003, which is
12 operating experience, and the note that we have is Duke
13 provided the information. If you look in their application
14 and also in our SER you'll see references to operating
15 experience. And in general the Priority 1 issue is how are
16 you going to use operating experience and to what extent are
17 you going to use it for your SER. We've done that. It's
18 not contained in one section in our SER, it's spread
19 throughout the SER.

20 The second issue I'd like to talk about just
21 briefly is 98-0009, which is the FSAR content. We have an
22 open item in our SER. The open item number is 3.0-1. We
23 have not settled with Duke what the FSAR supplement should
24 look like. In part of their application they gave us what
25 they believe is the necessary changes to their FSAR. The

1 staff has reviewed that as part of their application, but
2 there are several things that are intertwined with that
3 issue, and if you look at the open item in the SER, I'll
4 just read a quick sentence from it, it says therefore, the
5 resolution and the information that needs to be added to the
6 FSAR will be addressed after other open and confirmatory
7 items are resolved prior to issuance of a renewed license.
8 That will be one of the last open items that we'll take care
9 of.

10 Another issue that I just note is consumables.
11 It's 98-0012. It is actually not a Priority 1. The reason
12 that I mention it, though, is that there are several open
13 items that are in Section 2.2 of our SER that touch -- that
14 refer back to this consumable position that we just recently
15 issued. So that's just a piece of information for the
16 subcommittee.

17 And the last issue that will not be touched on by
18 a specific reviewer is 98-0068, which is the coded
19 additions. The note that we have on the slide is Duke
20 provided the information. The concern with this open item
21 was to what extent -- or the concern with this Priority 1
22 issue was to what extent are code additions going to be used
23 and how is the staff going to judge them to be acceptable or
24 not. And basically what you'll see throughout the SER and
25 the guidance that was provided to the staff is if Duke

1 references a code addition, you have to make sure that
2 they -- a code, they have to reference the addition. And
3 the staff has to agree with that addition. So you'll see
4 that throughout the SER. That's not contained in a
5 particular section.

6 And as far as the status of the Priority 1 issues,
7 those are the things that I wanted to note.

8 Unless there's any questions, I'm done with the
9 presentation.

10 CHAIRMAN BONACA: Okay. I think the next
11 presentation we have on the schedule is Duke's presentation.

12 So we adjourn now and then resume at one o'clock,
13 and give time also to the subcommittee to participate in
14 that meeting with BG&E.

15 MR. GRIMES: We're going to hold our monthly
16 management meeting at noon with BG&E and Duke and talk about
17 the status of both reviews, and we'd be pleased to have the
18 ACRS subcommittee join us.

19 CHAIRMAN BONACA: Okay. With that then we adjourn
20 this subcommittee meeting for the morning, and we'll resume
21 the formal presentations from Duke Engineering at 1 p.m.

22 [Whereupon, at 11:36 a.m., the meeting was
23 recessed, to reconvene at 1:00 p.m., this same day.]
24
25

A F T E R N O O N S E S S I O N

[1:01 p.m.]

CHAIRMAN BONACA: We are going to resume the meeting of the subcommittee, and I believe we are about 40 minutes ahead of time in our schedule and we have now the Duke Energy Corporation presentation. Hopefully, we will complete the scheduled SCR reviews on time. If we are ahead of time, I would like to possibly advance some SCRs from tomorrow morning into today.

MR. GRIMES: We will attempt to accommodate that. We will keep an eye on the clock and see where you are going and then we'll see whether or not the Staff that had planned on coming tomorrow is available.

CHAIRMAN BONACA: Okay, and in case we can, we will adjourn the schedule at 4:00 p.m. for the discussion of the ACRS, so with that in mind, let's start now with Duke Energy Corporation's presentation.

MR. COLAIANNI: I am Paul Colaianni. I will be doing the presentation this afternoon. Also I do have Mike Sumner up here, who is the mechanical lead. I am the electrical lead for the project, so if you have any questions, which I encourage, do ask as I go along.

First, I would like to put up the slide -- photograph again, and of course being mechanical Greg Robinson forgot to point out the most important feature of

1 the slide, which is the switchyards, which as an
2 electrical --

3 [Laughter.]

4 MR. COLAIANNI: -- engineer, I just wanted to
5 point that out. Electrical seems to be forgotten in many
6 things in license renewals.

7 VOICE: That is our loading dock.

8 MR. COLAIANNI: For the disciplines, as Greg
9 explained this morning, we split it up to the engineering
10 disciplines basically, and the basic rule of thumb we used
11 is that if it carries current it is electrical, if it
12 supports, protects or restrains the movement of a component,
13 it is civil structural, and pretty much everything else is
14 mechanical. There are maybe a few exceptions to that, but
15 that is kind of the basic rule that we took the whole plant
16 and split it along those lines to begin our reviews.

17 For the scoping of components, each discipline
18 used a slightly different approach. Structural relies on a
19 CLB definition that appears in the UFSAR, Mechanical went
20 straight from a functional review process and Electrical
21 uses an encompassing approach, so you will see these
22 differences play out as I describe them in the presentation.

23 All the reviews that are taking place, as Greg
24 described this morning, we had a separate review for the
25 reactor coolant system, separate review for the containment

1 structures, and then we had a systems, structures and
2 components review, mechanical components, and electrical
3 components. These three are what I will be covering this
4 afternoon, the three discipline reviews.

5 This gives a layout of the topics I will be
6 touching on during the presentation. The first one, the
7 IPA, Integrated Plant Assessment, scoping and screening for
8 each of the three disciplines, and then the aging management
9 review for all three disciplines, TLAA reviews for all three
10 disciplines, and the programs and activities that are
11 credited for license renewal. So that lays it out. The
12 first topic will be the scoping and screening.

13 We will take up each engineering discipline
14 separately. Next slide.

15 Now an overall look at the scoping and screening
16 for the three disciplines, the structural and mechanical
17 component methodologies are consistent with NEI 95-10. We
18 use that as the basic guide for going through the reviews.
19 The electrical component methodology follows the
20 requirements of Part 54 and also uses guidance in the
21 statement of considerations that was published with the rule
22 and is generally consistent with the guidance provided in
23 95-10, although there are some differences and exceptions to
24 that guidance.

25 The structural review, scoping and screening

1 methodology, the basic methodology was to identify the
2 structures and the structural components within the scope of
3 the rule, and their intended functions, and then from that
4 list to identify the structures and structural components
5 subject to an aging management review, there again applying
6 all the scoping/screening criteria.

7 This is laid out in a simple flow chart where all
8 the structures are identified, then the structures are
9 scoped and intended functions are identified for the scoping
10 process, then these in scope structures are broken down into
11 the structural components that make up those structures, and
12 the intended functions of those structural components are
13 scoped, so within each structure the structural components
14 are determined whether they meet an intended function or
15 not. From all that you get the structures and structural
16 components subject to an aging management review.

17 Here is an example of the scoping summary.
18 Basically all the structures are listed in the left-hand
19 column, and this would continue on for all the structures.
20 This is just a sampling of the first few. The
21 classification of structure is here, and that is either
22 Class 1, 2, or 3 as defined in the Oconee SR.

23 This defines whether it is within license renewal
24 or not, yes/no, and the function. Basically on these I
25 think there's 12 criteria that define all the intended

1 functions that a structure could have, so basically if it
2 meets any of these functions then it is within the scope of
3 license renewal.

4 Then the break-out of the detail for
5 safety-related and nonsafety-related and the regulated
6 events, those are broken out separately and each of those
7 criteria is answered yes or no as to whether parts of the
8 structure meet the license renewal intended functions, and
9 in documentation information on the right, so that is like a
10 first page.

11 I will give you an example of that process. The
12 results shown on a global scale are these are the structures
13 that were found to be within the scope of license renewal.
14 There are several structures that are outside normal
15 structures and equipment pads, and those are grouped down in
16 the last one called Yard Structures, which includes a lot of
17 outside things such as trenches and towers and elevated
18 tanks and transformer pads.

19 This is a complete list of all the structures that
20 were included in the scope of review.

21 Going from those, basically this shows a matrix
22 that was used for each of the structures that was listed in
23 the last table. We have got them listed here and then what
24 was broken out here was all the possible components,
25 structural components, that might be in any of these

1 structures. The list would go down further than this for a
2 complete list, and then for each of the structures an "x"
3 would indicate that there are some anchors, anchorages or
4 embedments in the auxiliary building, and the same
5 determination would be made about all the structures,
6 basically outlining all of the structural components, all
7 the piece parts within that structure that would pertain to
8 it.

9 That pretty much ends the structure scoping and
10 screening. The mechanical component scoping methodology
11 basically looks at -- splits it based on systems, splits up
12 the plant, and the systems are scoped using the criteria and
13 rule along with determining the intended functions to see
14 what intended functions they serve, and then the
15 identification of components within these in-scope systems
16 are determined along with their intended functions, so it is
17 broken down first into system, and then looking in those
18 systems for what components in those systems are in scope.

19 The mechanical scoping process for each criteria
20 look like this for 54.4(a)(1) and (a)(2), the safety and
21 nonsafety, a functional flow path identification using
22 event, mitigation and calculations. At the start of the
23 process, fluid pressure boundary determinations were made,
24 physical interface identification was made, and then other
25 designated item identifications, anything else that should

1 be included within the review, and this information was
2 documented not only in calculation but also onto mechanical
3 system flow diagrams where the diagrams were highlighted to
4 show the portions of those systems that were in the scope of
5 license renewal for any of the criteria.

6 This slide shows scoping events that were used
7 scoping calculations that were done in the mechanical
8 scoping process. This is basically all of the events that
9 we used to determine what components in the mechanical
10 systems need to be part of the scope of review.

11 CHAIRMAN BONACA: I understand there is some
12 difference with the Staff or some questions to resolve, and
13 I am trying to understand what is it. Let me ask a
14 question. For example, you have loss of main feedwater in
15 the scoping. Why didn't you have feedwater line break? I
16 am trying to understand what the issue is, okay?

17 MR. COLAIANNI: I know the Staff is going to go
18 into some of that explanation of the issue also, but Mike,
19 do you want to get that or --

20 MR. SUMNER: I think I need to refer that to Greg.

21 MR. COLAIANNI: Okay.

22 MR. ROBINSON: In that particular example, we did
23 not exclude looking at things like feedwater line break.
24 What we did is we focused on including the things that have
25 traditionally been part of the design and licencing basis of

1 the plant and make sure that we clearly defined what that
2 set of events was, and then focused on that.

3 We recognized that over the course of the last 25
4 years many other events and topics have come along and we
5 have looked at them and addressed them and made sure that we
6 understood their applicability to the plant, but we did not
7 see them as design basis events or events that we would use
8 for scoping.

9 CHAIRMAN BONACA: Okay. I tried to go through a
10 little exercise to see if I understood this issue, because I
11 think it's one that keeps going back and forth.

12 For example, I made the example that if you go to
13 line break because if you had to go to line break, you have
14 to have certain equipment to deal with it. In that case you
15 would want to have isolation of the lines.

16 My understanding is that Oconee doesn't have main
17 feedwater isolation valves but it has control valves used
18 for that function. Therefore the expectation from the rule
19 would be that the control valves, at least the passive
20 portions of that, would be addressed in the rule. Now if
21 you told me they are addressed in the rule because we are
22 including them by some other means, that would be
23 satisfactory to me, but I would like to know what the answer
24 is to that question.

25 MR. COLAIANNI: And there again we have tried to

1 go strictly from Oconee's definition of what we have
2 traditionally had as our design basis events, and from that,
3 that is basically where we got this list.

4 CHAIRMAN BONACA: So going back to the question,
5 then there would be passive components in the feedwater
6 control system or the piping. Are they included in the
7 scope of the application?

8 MR. SUMNER: My name is Mike Sumner. Yes, they
9 are. They are included.

10 CHAIRMAN BONACA: So they are by some other means.
11 Okay.

12 MR. ROBINSON: This is Greg Robinson. They were
13 classified on our documents set as being safety-related and
14 how they got to be tagged as safety-related we can debate
15 forever, but in that particular example the piping and the
16 valve bodies and things that were already identified, and
17 Paul mentioned on the highlighted flow diagrams we did go
18 through and highlight the schematics to point out the areas
19 that we have traditionally had labelled as safety-related in
20 the plant, and it does include those.

21 CHAIRMAN BONACA: All right.

22 DR. SHACK: But the answer is the process was
23 essentially done by tradition then?

24 MR. COLAIANNI: The process was to go by what we
25 understand, what Oconee understands as Oconee's design-basis

1 events, and that is the starting process.

2 DR. SHACK: What are the infamous additional 32
3 events for possible inclusion? Somehow you did seem to sort
4 through these things in some way. What was that process?
5 Was it again tradition? The 32 weren't traditionally
6 considered safety?

7 MR. ROBINSON: This is Greg Robinson. I will try
8 to answer that.

9 MR. COLAIANNI: I'll refer to Greg, yes.

10 MR. ROBINSON: What we did was somewhere around
11 the late '80s or early '90s with our design-basis
12 documentation program, we realized we needed to write down
13 some of our tribal knowledge in a history.

14 We had longstanding licensing and design engineers
15 who knew how the plant design evolved over time, but we did
16 not have that written down. In the process of writing that
17 down through the course of the 1990s, we got to a point
18 where we said it would be nice to step back from the
19 particulars of writing down each item as we think it applies
20 to Oconee and take a more global look.

21 When we did that, we said let's go look around the
22 industry, everything everyone has considered, and we came up
23 with about 58 -- I believe that was the number -- 58
24 different events that had been considered, some of which
25 were never considered on Oconee, but we wanted to include

1 them in the mix. From that, we sorted through the licensing
2 basis, essentially compiled the licensing basis of the plant
3 to find these numbers of events that you see up here on the
4 screen, and the other number, the 32, were the ones we found
5 not to be applicable, but the broad view didn't occur until
6 the early to mid-'90s.

7 We backed away from the problem and said let's
8 take a broad view of this and make sure we are in the right
9 ball park.

10 DR. KRESS: Did the PRA play any role in this at
11 all?

12 MR. ROBINSON: Not directly in establishing these
13 event sets, no, sir.

14 CHAIRMAN BONACA: I understood the licensing basis
15 for the plant, but we are looking here for aging of
16 components which play a significant safety role, so to me it
17 doesn't matter if they are safety-grade or control-grade at
18 this stage -- that was part of the original license and we
19 are not questioning that. We are questioning whether or not
20 we are capturing them in aging programs, and you gave me an
21 answer for the feedwater system that said yes, we do. Well,
22 that specific one.

23 The question is broader in general. It is are you
24 capturing them in any case?

25 MR. GRIMES: Dr. Bonaca, this is Chris Grimes. I

1 would like to clarify that we have concentrated on applying
2 the scoping criteria and 54.4 and the Staff will explain in
3 its presentation the open item, but when we apply those
4 criteria we apply them to identify those intended functions
5 that are associated with the design basis and so if we find,
6 as you pointed out before, if we find that we can think of
7 an event that they didn't include in their methodology, the
8 first thing we are going to do is go see whether or not it
9 matters in terms of whether or not that excludes an intended
10 event -- or system, structure or component.

11 But in the event that we find that they did not
12 consider an event and they don't have, as you pointed out,
13 they have got some design differences, if it ends up
14 excluding some system, structure or component, the first
15 question we have to ask is is that a deficiency in the
16 licensing basis that should be treated under Part 50 today,
17 rather than trying to solve it as part of license renewal,
18 so we are trying not to backfit the design basis in license
19 renewal.

20 We tried to be very careful about that in order to
21 make sure that license renewal wasn't doing something it was
22 not intended to do.

23 MR. ROBINSON: May I add, Chris -- Greg
24 Robinson -- in addition to the focus that both Duke and the
25 NRC had on meeting the regulations or working to meet the

1 regulations, we did on a plant-specific basis take a look a
2 the risk-significant results from the maintenance rule
3 efforts, and the results from the license renewal efforts,
4 and when you overlay them we have found that the
5 risk-significant mechanical systems that were determined
6 through other risk processes are included in the license
7 renewal scope and do receive aging management review, so I
8 can answer that part of your question.

9 CHAIRMAN BONACA: So also indirectly you are
10 answering Dr. Kress's question?

11 DR. KRESS: Yes, indirect answer to mine, too.

12 MR. NEWBERRY: Scott Newberry, Staff. Just by way
13 of example -- that is a good question and I remember back in
14 rulemaking we talked about risk significance, and one of the
15 reason the scope -- because of those questions, the scope
16 was expanded to explicitly include ATWS, station blackout,
17 and fire protection equipment and they are listed explicitly
18 in the scope.

19 CHAIRMAN BONACA: Okay.

20 MR. COLAIANNI: So using also in addition
21 54.4(a)(3), basically the mechanical systems that satisfy
22 the regulated event criteria were picked out of the
23 licensing commitments and design documents. They related to
24 those for each of those four -- those five events -- and
25 those components were pulled out and made sure that they

1 were included in the scope of review.

2 Now for the screening -- that was the scoping --
3 for the screening basically Mechanical used, put a menu up
4 of active versus passive components, and the mechanical
5 groups that were highlighted were run through that menu to
6 determine the passive components in the systems in the
7 in-scope systems that needed to be reviewed, and that is
8 basically what this slide is identifying.

9 The list of mechanical components subject to aging
10 management review, a list was provided in the application to
11 identify those components.

12 Here are the results of the scoping, all the
13 systems at Oconee that were included or that meet the
14 scoping criteria, and you have got Oconee systems that are
15 with the plant proper, the safe shutdown facility -- or
16 standby shutdown facility systems, and then the systems at
17 Keowee, which is the hydroelectric plant supplying emergency
18 power, but this is a list of all the systems that meet the
19 scoping criteria.

20 An example here is given next on how the
21 components were screened. You have got the systems listed
22 here and these are the different materials that might be
23 part of the system and this gives remarks on the materials
24 and where the information came from. This is what shows up
25 in the station calculation that identifies the components

1 within a system, the materials.

2 Now we are on to electrical. The electrical
3 scoping and screening methodology as basically laid out is a
4 little bit different from the mechanical approach. Except
5 for specific components that are scoped out or screened out,
6 all plant electrical components are included in the aging
7 management review. To explain that a different way and
8 contrast it to the mechanical approach, for mechanical the
9 systems were defined and everything was scoped to determine
10 exactly what was in-scope. In electrical it turned out to
11 be more efficient for Oconee to start with the whole plant
12 and only screen or scope out a few pieces of equipment for
13 particular reasons but leaving the rest of the components
14 in, thereby having an encompassing review of components that
15 are both in-scope and some that are not within scope but not
16 trying to differentiate exactly which ones meet which
17 criteria.

18 It does include everything that is in-scope but it
19 does also include components that do not really meet the
20 criteria.

21 So the way that breaks out in the scoping and
22 screening criteria, 54.4(a), the scoping, basically
23 everything is scoped in but a few specific commodity groups
24 of electrical components are scoped out. Evaluation is done
25 to scope them out. The screening criteria for the

1 active-passive components was actually applied to all
2 electrical component commodity groups, so this was done for
3 all of them.

4 The screening criteria for the replacement
5 criteria was only applied to a few groups of components but
6 was not applied to everything. The basic evaluations for
7 electrical did not break it down into systems to start out
8 with, it broke all the electrical components into components
9 in commodity groups to start out the review.

10 This chart shows the basic process -- identify
11 electrical component commodity groups installed at Oconee
12 along with their intended functions, and then applying the
13 scoping or screening criteria. These were not done as it
14 shows here really in a sequence. They were all done sort of
15 as independent steps, and then what came out of the scoping
16 and screening were a list of electrical components that were
17 included in the review.

18 Here we have a table that shows all the electrical
19 component commodity groups. This basically describes all
20 the electrical commodity groups that are installed at
21 Oconee.

22 Some of the commodity groups are broader than
23 others, but basically that includes everything in the plant.

24 This table gives the results of the application of
25 the screening criteria, the passive-active screening of

1 components. It was done to all the components. Most of the
2 determinations were made elsewhere or documented elsewhere
3 to start out with in the rule. You have the reference
4 documents. The rule says that these particular components
5 are subject to or do meet the criteria, the passive
6 criteria, and these particular components do not meet the
7 criteria.

8 The working draft of the SRP in NEI 95-10, which
9 has the same tables, say that these particular components do
10 not meet the criteria. There is a September 19 letter from
11 the NRC to NEI that particularly speaks to these particular
12 components as not meeting the criteria, and at the time this
13 table was made, what Ocone did in the application was
14 address these particular sets of components, some of which
15 did meet the criteria and some of which didn't.

16 Since then in particular there's been an NRC
17 letter which addressed fuses that probably should be added
18 to this table, but for Ocone really it's just these
19 determinations that really should be of discussion in the
20 application.

21 This gives the results of all the electrical
22 components that are included in the aging management review.
23 Here you have the component commodity groups that had
24 components that met the scoping and screening criteria, and
25 this describes in words the groups of components that meet

1 the criteria, giving exclusions where necessary, and this
2 lists the intended functions that were used for the
3 components, but that is the complete set.

4 Now I will go on to the integrated plant
5 assessment aging management review for structural,
6 mechanical and electrical components.

7 Although the scoping and screening was done
8 slightly differently for each discipline, when you get to
9 the aging management review it is done, really addressed the
10 same for all three disciplines.

11 The reason is that at a high level you have got
12 component materials and you add in component environments or
13 stressors that could affect those materials and also you
14 look at potential aging effects -- what sort of aging
15 effects can happen to those materials, and then basically
16 you are looking at determining whether those aging effects
17 are applicable to those materials in those environments, and
18 applicable also meaning having a time limit is going to
19 cause the loss of intended function if unmanaged for the
20 period of extended operation.

21 The TLAA reviews that were performed I will
22 discuss next. The TLAAs involved plant-specific design
23 analyses, focused on boundary conditions or assumptions
24 based on the 40-year operating term, and the action is to
25 assure that the analyses are valid for the extended period

1 of operation or that the effects of aging will be adequately
2 managed for 60 years.

3 Oconee-specific time limit aging analyses have
4 been identified by reviewing the Oconee UFSAR documented
5 correspondence and other topical reports. The resultant
6 list includes EQ fatigue, tension loss and pre-stress,
7 reactor vessel embrittlement, just as some examples, and no
8 Oconee exemptions were based on a time limit aging analysis.

9 The TLAA process is consistent with the guidance
10 provided in NEI 95-10, the process that was used by Duke,
11 and provides reasonable assurance that we found them all and
12 evaluated them.

13 The last area that I will cover is programs and
14 activities credit for license renewal.

15 This chart gives an overview of all the programs
16 that are credited for license renewal, a total of 50; 28 are
17 existing programs or activities that are going to require no
18 change at all. There are 11 existing programs or activities
19 that need to be enhanced in some way or other, and then
20 there are 11 new programs or activities that need to be
21 instituted at the station.

22 This is a list of the 28 existing programs that do
23 not require any changes for license renewal, this is the
24 list of the existing programs to be enhanced, programs and
25 activities, and a listing of the new programs and

1 activities. Most of these new programs, from here on down,
2 are inspections, one-time inspections.

3 CHAIRMAN BONACA: Before you change that --

4 MR. COLAIANNI: Yes?

5 CHAIRMAN BONACA: -- just could you give me an
6 example of an enhancement in one of them, just to get a
7 feeling for --

8 MR. COLAIANNI: Okay. Mike, can you give us an
9 example? Maybe the Keowee oil sampling?

10 MR. SUMNER: My name is Mike Sumner. The Keowee
11 oil sampling program at the hydro station has been there
12 since 1970 and they take oil samples on a periodic basis for
13 years and have them analyzed, but it wasn't formalized. The
14 results were very hard to come by. They just did it. It
15 was done by the fossil hydro department.

16 We enhanced that program by making it very
17 formalized and having a bonafide frequency and documenting
18 results and keeping track of stuff like that. That is a
19 particular enhancement.

20 CHAIRMAN BONACA: Okay, thank you.

21 MR. COLAIANNI: All right. Talking about the
22 safety evaluation report, it was recently issued. There are
23 43 open items and six confirmatory items; 28 of the 49 are
24 relatively straightforward to address. We don't see any
25 real complications coming in for those. Three of the 49

1 items are related to the UFSAR supplement. Eighteen of the
2 49 in five different topic areas will require meetings. The
3 topic areas are scoping process and results, complex
4 assembly boundaries, consumables, CASS components, and
5 reactor vessel internals.

6 To end up -- some observations on implementing the
7 license renewal rule. These are rather broad but basically
8 we saw a need to develop clear definitions of terms so that
9 we as an industry and the NRC can be always talking from the
10 same page. That would help streamline the process.

11 Document scoping and screening processes -- in a
12 lot of respects that is talking about the electrical process
13 which wasn't represented in the NRC guidance and/or in the
14 inspection plans, and just basically it would make the
15 process easier if that were included, to broaden the ability
16 of the utilities to use efficient means to get things done.

17 Also, develop a technically sound process for
18 handling emerging issues -- GSIs is an example. That sort of
19 thing. But these are just some broad topics, observations
20 that we have had that would help the process.

21 That ends my presentation, unless there are any
22 questions on any parts?

23 CHAIRMAN BONACA: Just looking at the programs you
24 had to institute, you have the 11 new programs and
25 activities. This seems to be a significant fraction of the

1 overall programs that you are talking about. I mean you had
2 28, 11 are enhanced and 11 are new, but --

3 MR. ROBINSON: This is Greg Robinson, if I may, a
4 little explanation of the programs.

5 If you will note, there are two new programs, and
6 both of them were discussed or mentioned, at least the Alloy
7 600 was mentioned in this morning's discussions. Those are
8 really the only true new programs. A point on the
9 inspections below that, the nine inspections below that. In
10 many cases when we could not characterize an aging
11 phenomena, we just did not feel comfortable technically to
12 say a phenomena was not occurring. We said why don't we go
13 look, and so the one-time inspections are aimed at doing
14 that aging characterization.

15 If there is aging present, we will continue on and
16 the process will allow us to implement some programmatic
17 action. If there is not any aging present or we cannot
18 determine that there is any, we will then be able to form a
19 better technical conclusion and those will drop off, and so
20 there's only two that we plan to carry forward, so the
21 percentages change when you look at it from that
22 perspective.

23 MR. TUCKMAN: Mike Tuckman. If you look at it
24 from the perspective of work hours expended in the year,
25 there is not a relationship to the number of programs. Most

1 of the programs that are in place are very heavy usage
2 programs. These one-time inspections are relatively small
3 in comparison.

4 DR. KRESS: When you look at the fact that you did
5 add a couple of new programs, and you may add more depending
6 on these inspections, is that a lessons learned for
7 operating plants that aren't yet thinking about license
8 renewal? Should those programs be there?

9 MR. GRIMES: This is Chris Grimes. I will tackle
10 that one.

11 We would not expect individual license renewal
12 applicants to reflect on the generic implications of these
13 findings. We have identified half a dozen to a dozen issues
14 that have come up as the guidance for license renewal has
15 formulated. We refer to the panel that reviews events and
16 determines what things warrant further action. Some of
17 these things have evolved in bizarre and unusual ways, but
18 they do get fed back into the operating reactor program.

19 DR. KRESS: That was basically my question.

20 MR. GRIMES: We feed back this experience into the
21 normal, into the regulatory process because license renewal
22 is predicated on the regulatory process carries forward
23 through the period of extended operation in order for us to
24 focus on just this small set, and I would like to provide a
25 different perspective on the statistics.

1 That is, irrespective of whether or not the
2 inspections are done every day or they are done once in a
3 60-year period, they lend to the public credibility of our
4 knowledge, understanding and ability to address whether or
5 not those aging effects will have an impact on the intended
6 function in the unlikely event that a design-basis accident
7 should ever occur, and so from our perspective on the
8 statistics, we essentially weigh things that occur routinely
9 almost the same way that things that we want to just verify
10 we never need to anything more about it.

11 CHAIRMAN BONACA: I had a question. These are
12 inspections -- the ones on the right side, my right side. I
13 see that pressurizer examinations, but this morning I asked
14 a question because I saw a program that covered that and I
15 was told that the program provides for examinations to be
16 stepped up in case you have in fact findings from those
17 inspections.

18 MR. GRIMES: Right.

19 CHAIRMAN BONACA: So these are not just one-time
20 inspections outside of some kind of programmatic
21 requirement. You have some programs under which you are
22 going to put those?

23 MR. GILL: This is Bob Gill. Let me clarify.
24 These are different pressurizer components than the ones we
25 talked about this morning. This is in fact the heater

1 bundle and actually the interior cladding and spray nozzle,
2 not the Alloy 600 parts.

3 CHAIRMAN BONACA: Okay.

4 MR. GILL: And in fact the pressurizer cladding
5 was a concern from an operating experience event about 10
6 years ago. We are going to go in and look to see if there
7 is any indication of iron oxides on the cladding and then go
8 further, the pressurizer heater bundles, the stress
9 corrosion cracking of a weld which might lead, and so that
10 is different than the Alloy 600 big program we were talking
11 about, which is up there at the top. There is overlap on
12 some of these. It's just the way they got binned and when
13 they were born and that type of thing.

14 DR. SHACK: A similar question on the small bore
15 piping in the sense that you have had problems with small
16 bore piping --

17 MR. GILL: Right.

18 DR. SHACK: -- and you are looking for now a
19 particular in this inspection.

20 MR. GILL: This would be different piping. If you
21 flip up the other overhead with the existing programs, let's
22 touch on that briefly.

23 The existing programs that we have had operating
24 experience on is the program to inspect the high pressure
25 injection connections throughout the cooling system. We had

1 the event a couple of years ago. Many years ago the B&W
2 Owners had an event, created a program. There was a generic
3 letter and all that. We had some problems on implementing
4 that program, but that is an existing program that covers
5 that specific location, its unique thermal phenomena, its
6 situation there. We do RT/UT, all kinds of examinations on
7 that. Many inspections are done on those nozzles. Those
8 are HPI makeup nozzles.

9 To flip back to the small bore piping, that is
10 different. That's events in drains and impulse lines and
11 other things that are less than four inches, not the HPI
12 nozzles per se.

13 CHAIRMAN BONACA: All right. We would like to get
14 a sense from the Staff when we have a presentation of how
15 this compares with the BG&E application.

16 MR. GRIMES: We are going to cover that during the
17 separate discussion tomorrow on the credit for existing
18 programs.

19 CHAIRMAN BONACA: Okay.

20 MR. GRIMES: In a general way -- and we will try
21 to show you the contrast.

22 CHAIRMAN BONACA: From our perspective it is very
23 hard to compare. It seems almost apples and oranges in that
24 BG&E have approximately 400 programs and here we are talking
25 about 50. They are different things, I understand that, but

1 I would like to put them in the same context so we
2 understand.

3 MR. GRIMES: We are going to cover that during
4 tomorrow's session.

5 MR. TUCKMAN: Dr. Bonaca and Dr. Shack, this is
6 Mike Tuckman.

7 It is interesting to note, since you asked the
8 question about small bore piping, that is not a program that
9 we had identified as something needed to be done. We
10 believe the ASME code was sufficient to and does require
11 various visuals, et cetera, of small bore piping. This was
12 something that came out in the NRC's SER on reactor coolant
13 system piping and when you talk later about credit for
14 existing programs, one of the concerns of the industry has
15 been the accretion of requirements from existing programs,
16 and that would be an example of one that we added as a
17 result of the review process from the NRC but I don't know
18 that we would necessarily agree it should have been added.

19 Did I do that right, Chris?

20 MR. GRIMES: Yes, sir. We twisted his arm. It's
21 just a question of whether we twisted it fairly.

22 [Laughter.]

23 DR. SHACK: Would that be true also of the reactor
24 vessel internals aging management program?

25 MR. TUCKMAN: I don't think so.

1 DR. KRESS: Does Ocone deal with design basis
2 hydrogen by using recombiners?

3 MR. TUCKMAN: Yes.

4 DR. KRESS: Is there not a program associated with
5 those that -- I didn't see it on your existing programs. It
6 seems like it is a component needed to mitigate the
7 design-basis event.

8 MR. COLAIANNI: And it is included in the review.

9 DR. KRESS: It is part of the review?

10 MR. TUCKMAN: Yes.

11 DR. KRESS: Gets screened out for some reason?

12 MR. SUMNER: This is Mike Sumner again. We
13 evaluated and it had no aging effects because it is stored
14 in the warehouse. It is a portable piece of equipment.

15 DR. KRESS: Oh, I see. It's not in there --

16 MR. SUMNER: It is not in the reactor building,
17 no, sir.

18 DR. KRESS: I see, I see, so there wouldn't be any
19 aging --

20 MR. SUMNER: Right. We keep it out in the
21 warehouse and keep it warm.

22 DR. KRESS: -- because it is in a controlled
23 environment.

24 MR. SUMNER: Yes, sir.

25 MR. COLAIANNI: It has a heater that we keep it up

1 at about 200 degrees to keep it warm and dry.

2 DR. KRESS: Okay.

3 MR. COLAIANNI: Any other questions on any aspect
4 of it?

5 [No response.]

6 CHAIRMAN BONACA: If none, I want to thank you for
7 a really informative presentation. Thank you.

8 MR. COLAIANNI: Okay. Thanks for the chance.

9 CHAIRMAN BONACA: Now we are moving to Staff
10 presentations.

11 MR. LATTA: Good afternoon, gentlemen. My name is
12 Robert Latta. I work in the Quality Assurance, Vendor
13 Inspection, and Maintenance Branch within NRR. My function
14 was to review the aspects -- the application related to
15 scoping and screening.

16 Section 2.2 of Exhibit A of the application
17 described the methodology used by Duke to identify the
18 mechanical systems and components to meet the requirements
19 of 54.4(a)(1) and (a)(2), that being safety-related and
20 non-safety-related components. These requirements state in
21 part that the plant systems -- excuse me, the plant -- I'd
22 better have that light on, I can't read -- these
23 requirements state in part that the plant systems,
24 structures, and components that are within the scope of this
25 part are safety-related SSE's that are those relied upon to

1 maintain functional during and following design basis events
2 as described in 50.49(b)(1).

3 However, as described in the application, the
4 design criteria to which Oconee Nuclear Station was
5 originally built did not include all of the systems,
6 structures, or components that needed to be included under
7 the safety-related criteria defined under 54.4(a)(1) or the
8 non-safety-related criteria defined under 54.4(a)(2).

9 Therefore, Duke relied on the results of a design study that
10 identified the systems and components that are needed to
11 fulfill the safety-related criteria defined in 54.4(a)(1).

12 Since the design study conducted by Duke only
13 validated those functions required for the successful
14 mitigation of Oconee design basis events identified in
15 chapter 15 of the FSAR, it was unclear to us whether or not
16 all of the functions required for the successful mitigation
17 of these DBE's set forth in the Oconee current licensing
18 basis have been identified as required under the rule.
19 Further, since Duke's methodology had not identified all of
20 the SSC's required under 54.4(a)(1), the potential existed
21 that these conditions also existed for components addressed
22 under 54.4(a)(2), non-safety-related SSC's.

23 During the staff's most recent meeting with Duke
24 representatives on May 11, 1999, involving Oconee's license
25 renewal application scoping issues, RAI 2.2-6, the staff

1 identified two action items that needed to be resolved
2 within the confines of the SER. And those are described on
3 my first slide here, that is, that the applicant is to
4 review their response to RAI 2.2-6 to include a description
5 of the processes used to identify the events for Oconee
6 Nuclear Station's license renewal scoping and expansion as
7 to how these -- and an explanation as to how these 26 events
8 identified during the May 11 meeting are sufficient to
9 satisfy the requirements of 54.4(a)(1) and (a)(2).

10 Subsequent to the development of these slides, we
11 did receive the letter from Duke that was dated June 22
12 which provided their revised response to the RAI. This
13 included a description of the 26 events used for mechanical
14 license renewal scoping relative to the second bullet there
15 where we were evaluating subsequent to the receipt the need
16 for future inspection efforts that is an ongoing effort
17 within our organization.

18 Questions related to the open item or --

19 MR. GRIMES: Is that all for 2.1, Bob?

20 MR. LATTA: Yes, sir.

21 MR. GRIMES: This is the way that the scoping
22 issue that you referred to, Mr. Bonaca, this is the way it's
23 characterized in the safety evaluation, and we have received
24 a response from Duke concerning how they identified the 26
25 events, and as I mentioned before, our objective in this

1 review is to make sure that we're satisfied that all of the
2 intended functions associated with the current licensing
3 basis have been identified and that the associated systems,
4 structures, and components that are relied upon to perform
5 those functions have been properly screened or have been
6 subject to an aging-management review. And so we're going
7 to, as Bob mentioned, we're going to proceed to pursue the
8 information supplied in the letter from Duke. Copies of
9 that should have been provided to the ACRS, but I'll make
10 sure that Noel --

11 DR. SHACK: We have it.

12 MR. GRIMES: Okay.

13 CHAIRMAN BONACA: Okay. So right now this remains
14 an open item.

15 MR. GRIMES: Yes, that's correct.

16 DR. KRESS: Does the staff have any plans to use
17 something like a risk-importance measure, components that
18 end up -- to see if the design basis actually captures all
19 of the ones that you might -- risk important?

20 MR. GRIMES: We used risk-importance measures in
21 order to focus the scope of our inspection activities. As I
22 mentioned before, we're consciously avoiding trying to
23 challenge the adequacy of the current licensing basis to --

24 DR. KRESS: I recognized that was your marching
25 orders.

1 MR. GRIMES: But that doesn't -- as I also
2 mentioned before also, the process provides that we try and
3 do smart samples that we look at things that have risk
4 importance in terms of the processes, the methodology, and
5 the aging-management program. So we're going to look in
6 areas that if there are questions, you know, concerning
7 whether or not the intended functions are really doing the
8 right things relative to plant risk, we find something and
9 we'll pass it on back to folks to think about in terms of
10 the current licensing basis.

11 DR. KRESS: So you really don't -- oh, you think
12 that might ought to be incorporated into the licensing
13 basis?

14 MR. GRIMES: If we find something that's
15 risk-significant for which there is some question about
16 whether or not the current licensing basis is the right
17 current licensing basis.

18 DR. KRESS: Would that have to be subject to a
19 backfit?

20 MR. GRIMES: Yes, it would. We put it into the
21 appropriate process for making decisions about changing the
22 current licensing basis.

23 MR. NEWBERRY: Dr. Kress, let me follow up. A
24 week before last we got our staff requirements memo from the
25 Commission on risk-informing Part 50, and in that SRM they

1 tasked us to go look at the definitions of "safety related"
2 and "important to safety." And, you know, Bob just
3 mentioned (a)(1) of the rule in terms of scope of license
4 renewal used the term "safety related."

5 So even though the SRM is directed at Part 50,
6 we've talked about it with the industry at our first kickoff
7 meeting, and I think we're trying to figure out to what
8 extent that project is going to draw in Part 54. And I
9 think we're going to end up tackling that issue that you
10 just raised in the context of that effort.

11 DR. KRESS: Once you approve a license renewal
12 like this, though, what's going to come, particularly for
13 Oconee, before you ever get to that.

14 MR. NEWBERRY: Yes, that's true.

15 DR. KRESS: You wouldn't go back and grandfather.

16 MR. NEWBERRY: Mike's going to shake his head no
17 on that. I don't think so.

18 MR. GRIMES: Like I said, we're trying to proceed
19 along this, you know, walking that very careful line,
20 recognizing that the state of the art will continue to
21 evolve, and we don't necessarily like being on the cutting
22 edge of technology in terms of fixing the regulatory
23 process, but we keep being driven there for, you know, a
24 variety of things.

25 But in this case, we're just going to try and --

1 we need to satisfy ourselves that the suite of events -- as
2 a matter of fact, we ought to define the term, what is a
3 design basis event. We'll clarify what we understand the
4 current licensing basis to be, and then we'll proceed from
5 there to make sure that we've got all the functions.

6 DR. KRESS: The nature of my question was that
7 clearly design basis events incorporate risk-significant or
8 else we wouldn't do them. But my question was are you
9 really limiting yourself to that or are you making some
10 other sort of overall risk evaluation so that you assure
11 yourself that you're not really missing something that might
12 be risk-significant, and in my mind even if it were not
13 captured by the design basis event, you might want to make
14 it part of the license renewal. If it's really
15 risk-significant you want to capture it in the scope of an
16 aging-management program, only to be sure you weren't
17 limiting yourself.

18 MR. GRIMES: On the 14th when you talk about
19 policy issues you can consider that, because we specifically
20 took the language in the statements of consideration to be
21 an admonition that we should -- the current licensing basis
22 carries over. But, like I said, if we find something we
23 think is important, whether it's a plant-specific question
24 related to the current licensing basis and the state of the
25 current licensing basis, or whether there's a generic

1 implication, you know, we'll refer those to the appropriate
2 processes.

3 MR. TUCKMAN: Dr. Kress, this is Mike Tuckman.
4 I'm from Duke.

5 One of the interesting things about this rule is
6 that it is not a risk-informed rule, it is a very
7 prescriptive rule. I think in reality we are covering
8 everything, and if an improvement were to be made in the
9 rule sometime in the future, the scope of things that you
10 look at in the license renewal would be greatly reduced.

11 DR. KRESS: You're probably right. I looked at a
12 lot of things in here that might not have to be in the scope
13 if you did it really risk-informed. It would probably go
14 that direction.

15 MR. TUCKMAN: As Greg talked about, we use the
16 maintenance rule as a kind of a tool to look and see how it
17 matched up with license renewal, and of course in the
18 maintenance rule we do look at risk-significant systems and
19 pay more attention to those as we do in license renewal. But
20 as far as the actual rule went thus far, it was very
21 prescriptive and you treat everything the same.

22 DR. KRESS: I recognize it's strictly a design
23 basis concept.

24 MR. TUCKMAN: Yes, sir. I think it's very
25 unlikely that we will have missed it.

1 CHAIRMAN BONACA: Although everything is captured
2 in the discussion, but does it mean that you have to do
3 something about it? All you have to do is to address the
4 need. And so even within the context of a prescriptive
5 rule, I think that it is a way to soften the blow, I mean,
6 you can say hey, this is justification for not doing further
7 inspection. And I think that it's only fair to say that
8 that should be allowed by the rule.

9 But I think the only place where it is important
10 is where, you know, you may have a component out there
11 because of some insights and it may be from looking at a
12 broader set of initiators, either through PRA or through
13 deterministic approach, or by one component there is
14 important and we may have missed it. And that was the
15 thrust of I guess my question, and I'm sure that that's
16 really what the staff is doing and will bring to closure.
17 And I don't expect to see surprises, I mean, to the question
18 I had on the feedwater system, I got an answer that said we
19 already included it. That's the answer. So -- okay, with
20 that, any other questions?

21 DR. SHACK: Well, just on a general, I mean, does
22 the license renewal give you a way around backfitting in the
23 sense that you get a chance to look at the degradation of a
24 passive component and have it addressed whether it's
25 safety-significant or not?

1 MR. GRIMES: We had one example that was just
2 mentioned in terms of twisting the applicant's arm to
3 address the lack of an inspection activity associated with
4 small bore piping, and, you know, we get into at least do
5 one inspection, check and see whether or not the QA program
6 needs to pick something up. And in the course of resolving
7 questions and comments on the standard review plan, there
8 are other areas like that that have come up where the
9 utilities have said they don't think that it's worth it, and
10 we've said prove it, and we've, you know, we'll march
11 through those. Those are the 108, you know, things to do
12 when we have spare time.

13 If we can embarrass the industry enough into going
14 out and checking some of these gaps, then eventually we will
15 have a full program, but even then by the time we get that
16 cleaned up then operating experience will say there is
17 something else we ought to go check -- you just have to
18 follow up there, getting back to Dr. Shack's comment. These
19 inspections and programs are solely focused on 40 to 60
20 years, so the licensee is not obligated unless there is a
21 relationship there to go look today. The focus is on aging
22 from 40 to 60, so we are not talking -- remember Chris's
23 comment, to feed it back in -- that is another process.

24 DR. KRESS: After 60 years has gone by, can we
25 expect license renewal renewal?

1 MR. GRIMES: I'm sorry, what was the question?

2 DR. KRESS: Can we expect a license renewal
3 renewal after 60 years?

4 MR. GRIMES: I would want to answer that question
5 in two ways. The first way is that in this question of
6 credit for existing programs, we were reminded to point out
7 that we have not even completed the first two applications
8 yet, and so it may be expected that the license renewal rule
9 needs to be renewed here in the very near future based on
10 the experience from the first few applications, and we'll
11 constantly revisit whether or not this is the right thing at
12 the right job associated with license renewal, but then the
13 second part of the answer is we specifically point out that
14 20 years from now Ocone can come back and apply to renew
15 the renewed license for another 20 years on a presumption
16 that the maintenance activities are going to take sufficient
17 care of the plant so that they could justify continuing
18 operation, so long as it is economically viable.

19 MR. TUCKMAN: This is Mike Tuckman. I am going to
20 let somebody else worry about that problem.

21 [Laughter.]

22 DR. KRESS: You are going to be retired by then.

23 MR. GRIMES: Thank you, Bob. Mr. Gratton and Mr.
24 Shemanski are going to start with the next section, but I do
25 want to ask this. The Staff's presentation was set up on a

1 streamlined format based on some feedback we got from you on
2 the Calvert Cliffs presentation. We are going through each
3 chapter and we are going talk about the open items, the
4 confirmatory items and anything the Staff thought
5 constituted a particularly important or noteworthy thing to
6 pass on to the Committee, but at the same time, we are here
7 to answer any questions that you might have about the
8 Staff's evaluation basis, so don't hesitate to take us in a
9 different direction if you need to.

10 CHAIRMAN BONACA: Before we start the
11 presentation, the discussion we just had, one thing that I
12 would like to state is that it is impressive to see how many
13 programs exist already in the units and also the insights
14 provided by the maintenance rule, and the existence of
15 corrective action programs.

16 I mean on the positive side of it, there has been
17 tremendous progress in the industry in the past 10 years and
18 it is pretty impressive to see how ready the industry is to
19 move to license renewal. I mean there is a lot of stuff in
20 place there that is pretty impressive.

21 MR. GRIMES: Mr. Bonaca, I would like to emphasize
22 that although we talk about disputes over what is necessary
23 for license renewal, we agree that almost all or nearly all
24 of the existing programs deserve the credit that we are
25 going to give them for managing aging effects and the area

1 where these disputes probably should continue is a struggle
2 between the plant operators and the regulators to constantly
3 challenge these areas where there are programs that don't
4 get a whole lot of visibility, that don't get challenged
5 often enough in order to be readily understood as being an
6 effective aging management program.

7 But we are only talking about out of those 49 open
8 and confirmatory items there are like five areas of
9 controversy, and regardless of whether or not you count
10 individual procedures and come up with a number between 400
11 and 500, or whole programs and come up with a number that is
12 like 50, having five things to argue about in order to come
13 to a conclusion about granting a 20-year license I think is
14 remarkable in terms of credit to the regulatory process that
15 we have set up over the last, what? -- four years.

16 CHAIRMAN BONACA: With that, are we ready?

17 MR. GRATTON: Thank you very much and good
18 afternoon. My name is Chris Gratton and I am the Divisional
19 Coordinator from the Division of System Safety Analysis for
20 the License Renewal Activities, and what I am going to be
21 discussing today are the scoping and screening activities
22 performed by the Staff.

23 Since Chris already took my thunder, this is a
24 streamlined presentation that will not focus on the process
25 that we use but rather the results of those activities.

1 What I am going to cover today are the open items
2 that the Staff identified during the review, the
3 confirmatory items -- which is actually only one, so
4 confirmatory item. We will discuss how the Staff addressed
5 license renewal issues, the Priority 1 issues that were in
6 our area of concern, and I will discuss one item of
7 interest, the difference between the BG&E review and the
8 Oconee review that we have just completed.

9 As you can see on the slide, the first two open
10 items have to do with systems that the Staff considered were
11 within the scope of license renewal yet the licensee did not
12 determine to be within the scope of license renewal so
13 questions were asked of the licensee to justify the
14 exclusion of the recirculated cooling water system and the
15 chilled water system.

16 The RCW system is a closed cooling water system
17 that removes decay heat from the spent fuel pool cooling
18 system and transfers it to the CCW system. The chilled
19 water system provides air conditioning or cooling air to the
20 control room. Both of these systems we felt met the
21 regulations to be within the scope of license renewal and we
22 are pursuing justification for their exclusion.

23 The third open item is identified here as
24 skid-mounted equipment. The real clarification is that for
25 an emergency diesel generator supporting the SSF, the

1 licensee identified the skid as being within the scope of
2 license renewal but excluded the components on the skid as
3 being subject to an aging management review under a
4 provision in Part 54.21 and the Staff believes that it was
5 inappropriately applied in that certain components on the
6 skid were excluded without consideration for aging
7 management review. It was just sort of a blank exclusion,
8 so there are clarifications in NEI 95-10 that we believe
9 they should have applied and reviewed those components on
10 the skid and we are pursuing that also.

11 DR. KRESS: What sort of components are they?
12 Starting the diesel or --

13 MR. GRATTON: There are some components associated
14 with the fuel oil system. This is piping up to the diesel
15 generator, cooling water to the cylinder cooling jackets,
16 and portions of the air starting system.

17 The fourth open item has to do with structural
18 sealants in general. The issue came about in questions
19 regarding water stops that were cast in place for the
20 auxiliary building. The Staff identified them as not being
21 identified as within scope of license renewal at all. When
22 the question was brought up the Applicant stated that they
23 did not meet any intended functions that would require them
24 per 54.4.

25 When that was brought up there is a Staff position

1 on consumables. We consider these to be consumables, and
2 they should have been addressed as such, but because they
3 are passive and long-lived, we felt that they did meet some
4 scoping requirements to maintain the integrity of the
5 auxiliary building, protecting safety-related equipment that
6 may be in the spaces from either flooding or intrusion of
7 water, so we believe they should be within scope and we are
8 still discussing their inclusion within the scope of license
9 renewal.

10 The fifth open item has to do with staged
11 equipment, and this is Appendix R equipment. It includes
12 items such as pumps and switchgear and cables that would
13 normally not be considered within the scope of license
14 renewal but because this equipment is staged in a warehouse
15 and not continually in operation, the Staff believes that
16 some provision should be made to monitor its again because
17 the rule assumes that active equipment such as pumps and
18 switchgear are continually in use, monitored and tested, and
19 this equipment is available in the event that there is a
20 design basis fire and as such it is not being used.

21 The last three open items are similar in nature in
22 that the Applicant identified them as being within the scope
23 of license renewal but did not provide justification for its
24 exclusion from an aging management review. They provided a
25 condition monitoring or performance monitoring as the reason

1 why they are not subject to aging management review, but the
2 rule requires that -- or maybe the statements of
3 consideration identify that a site-specific justification
4 that the condition monitoring program that they are
5 referring to should be described in adequate detail, and
6 those provisions were not included.

7 The three systems that we are talking about or the
8 three components that we are talking about are the Keowee
9 and turbine building roof structures. These were identified
10 as being monitored by the Applicant and replaced based on
11 their condition. Ventilation sealants, which includes
12 sealing material like tapes for the ventilation ducting for
13 the control room pressurization and filtration system, that
14 again would be monitored but replaced on the basis of their
15 condition.

16 The final one was some fire detection cabling.
17 The Staff feels that more information about how the
18 performance or condition monitoring is taking place is
19 needed so that we will be assured that the components will
20 be replaced prior to their failure.

21 Those were the open items. The one confirmatory
22 item that we had involved piping segments that provide
23 structural support in particular for boundary points. In
24 the BG&E review, there was a specific section that was
25 written on the identification of these piping segments and

1 the anchors that are included with them.

2 There was some confusion over the Oconee
3 application identifying these segments and the Staff got
4 together with the licensee and the issue was resolved. We
5 are just waiting for written confirmation that -- and
6 docketed information that will close this item.

7 As far as license renewal issues, three issues
8 came within the area of the DSSA review for scoping and
9 screening. I have mentioned some of the consumables that we
10 had issue with, specifically the structural sealants. There
11 was a letter issued by the Staff that identified our
12 position on structural sealants, and they mostly include
13 areas such as packing and O-rings, which are excluded from
14 license renewal, structural sealants -- which the Staff
15 considers included because they are long-lived and passive,
16 oils and greases were excluded and filters, fire
17 extinguishers and hoses and other fire protection equipment
18 were excluded but they are subject to certain justifications
19 that are required by the licensee to ensure that their
20 exclusion is appropriate, and the Staff addressed those as
21 they were performing their review.

22 Cascading -- there were a few issues identified
23 for cascading in the BG&E review, but they did not seem to
24 carry forward in the Oconee. There were not as many
25 instances where hypothetical failures had brought systems

1 that we felt or components that we felt should be within the
2 scope, and it just was a matter of site-specific, so there
3 were no good cascading examples that we could think of for
4 the Oconee review.

5 As far as the heat exchanger function, the heat
6 exchangers that perform safety-related intended functions
7 for license renewal were identified as having an intended
8 function that included the transfer of heat. I believe in
9 the BG&E review that was not identified, so the industry
10 picked up on that and they did include that intended
11 function for this review.

12 As far as items of interest, the one that I did
13 want to identify was the difference in the methodology that
14 the Applicant used for identifying the systems, structures
15 and components that were in the scope of license renewal.
16 Two different methods were used -- two different approaches,
17 I should say, were used.

18 The BG&E used simplified diagrams to identify the
19 bounds of the review, where Oconee provided a voluminous
20 number of flow diagrams that were computer-generated and
21 they were very robust with respect to identifying the ends
22 of -- the boundaries of license renewal. They were very
23 helpful to the Staff because they provided a lot of
24 information about and beyond what BG&E had provided, but
25 BG&E, because they provided simplified diagrams, they tended

1 to have more emphasis on the written text, so there was a
2 lot more description of where the bounds were and tables and
3 charts associated with a number of components, which was
4 helpful in their review.

5 In the Oconee review, they were sort of sparse,
6 and they provided a lot of flow diagrams and then the final
7 result of the components and structures that were subject to
8 aging management review, but our review is a two-step
9 process, which structures and components are within the
10 scope of license renewal, and of those which ones are
11 subject to aging management review.

12 We didn't have that first group. We had to pull
13 them off of sometimes as many as 28 diagrams to try and
14 figure out which ones were subject to aging management
15 review.

16 Neither of them were wrong or in my own personal
17 opinion, since I did a number of these, I felt the Oconee
18 was easier because I could read the diagrams and see them,
19 but that was a large difference, and I believe that I had
20 more success reviewing the latter ones, so I just wanted to
21 highlight that and maybe give Oconee some kudos in choosing
22 that methodology for the Staff to review.

23 That is the end of my presentation. Paul
24 Shemanski is sitting next to me. The majority of the review
25 was done in DSSA but the electrical portion was done in the

1 Division of Engineering and Paul up here is from DE, and if
2 there were any questions on how that was done, he could also
3 answer those questions.

4 CHAIRMAN BONACA: Questions?

5 DR. KRESS: Would you prefer a combination of the
6 Ocone and the BG&E?

7 MR. GRATTON: I would prefer a combination of the
8 two. The written text tended to eliminate some of the
9 questions. I had an example of areas where we became sort
10 of tube-locked in our trying to find answers. The seismic
11 anchoring I think was one of the areas of concern. If there
12 was a written text on how they approached that, the
13 questions wouldn't have come out when you looked at the
14 boundaries. They went up to the safety-related,
15 nonsafety-related interface and stopped.

16 They called that a boundary position when in fact
17 the boundary went beyond that and included the pipe segment
18 and a seismic anchor. That was one example.

19 Another one was the method that they used to
20 identify components. They used almost like commodity groups
21 to say, for an example, in the intake structure, they used
22 steel beams, columns, plates and supports, and since there
23 weren't any that really fit in there, the trash rack rails,
24 the rails that the trash rack rolls on, was considered a
25 steel column.

1 DR. KRESS: That is confusing.

2 MR. GRATTON: It is. When you read that, you
3 are -- you know, there's no steel column there, but when in
4 fact it was made of the same material, it ages the same way,
5 you know, it really belongs in there, but there was no
6 explanation that went with that. It was just, you know, say
7 a diagram and a table, so maybe a little bit more text would
8 have helped.

9 DR. KRESS: Is this a message that might be
10 transmitted to, say, ANO?

11 MR. GRATTON: Well, to tell you the truth, Mr.
12 Grimes -- we are currently working that.

13 MR. GRIMES: We are trying to gather this
14 experience and then fold it back through the process as we
15 settle on a standard content.

16 DR. KRESS: That makes your job easier.

17 MR. GRIMES: Yes, and the delicate balance is we
18 want to make our job easier but one of our four principles
19 is that we also want to reduce unnecessary burdens, so we
20 are going to try and find a nice middle ground and then fold
21 that back into either a revision to 95.10 on the contents of
22 the application, or review guidance in the Standard Review
23 Plan.

24 DR. KRESS: Is 95-10 still a living document that
25 is going to be changed?

1 MR. GRIMES: Yes. They haven't talked about
2 changing it, but we have said that some of this experience
3 is more appropriate there.

4 MR. TUCKMAN: Mr. Kress, this is Mike Tuckman. I
5 have the distinction of chairing the NEI Working Group on
6 this also, and our intent is to take the lessons learned
7 from both BG&E as well as Duke, as well as the various
8 issues that we are getting resolution papers from the NRC
9 on, fold those into a revised NEI 95-10.

10 DR. KRESS: That would be a great way to handle
11 it.

12 MR. TUCKMAN: Yes, and also just to provide
13 further assurance to you that the industry is working
14 together, Gary Young is here from Entergy and they have been
15 very actively involved in this process too, so they are
16 getting lessons learned to make theirs work a little better
17 than ours.

18 DR. KRESS: Great. I am glad to hear that.

19 DR. SHACK: Since they are going to get charged
20 for it.

21 [Laughter.]

22 CHAIRMAN BONACA: With that, let's take a 15-plus
23 minute break. We'll start again at a quarter of three.

24 [Recess.]

25 CHAIRMAN BONACA: Okay. Let's resume the meeting

1 with presentations by the NRC staff.

2 MR. GEORGIEV: Good afternoon. My name is George
3 Georgiev. I am with materials engineering in Chemical
4 Engineering Branch, Division of Engineering.

5 I am here to make a presentation on aging effects.
6 What is different for this application as compared to the
7 BG&E application is that Duke has grouped various systems
8 and identified common mechanisms which cause certain aging
9 effects and have evaluated them in section 3.52 of the
10 application. And section 3.1 is the result of our review of
11 this application.

12 Basically the section involves only identification
13 of aging effects, and our review consisted of what are the
14 identified materials in the applications, what are the aging
15 effects, and what is the environment. And we tried to find
16 out whether we can identify over and above what the
17 applicant has done. And with all fairness, after we did our
18 review, we didn't find anything different than what they
19 have found. So consequently Duke has done a good job about
20 it.

21 However, we do have two open items, and all this
22 question is, if Duke did such a good job, how do you have
23 two open items? And I will attempt to answer that.

24 [Laughter.]

25 Okay. The answer is that those are imported open

1 items from other sections of our review, because when you do
2 this general lumped together review that is not so much
3 system-specific. It is conceivable that something could be
4 missed when you do a system review. And we ran it through
5 our individual system reviewers, and doing so we came up
6 with the first open item, which is the aging effects
7 discussed and accepted by the staff are not consistently
8 applied by the applicant of the system, specific discussion
9 of aging effects. And we list in section 3.1 which systems
10 these open items relate to.

11 The second open items relate to buried components,
12 and basically in our review we couldn't get a feel how much
13 buried piping is involved in these facilities. And with all
14 fairness again, the applicant has provided flow diagrams.
15 We went and reviewed the flow diagrams, we took out what was
16 buried, identified, and we more or less we can say what is
17 involved. But then one of that piping is a very large
18 diameter piping. It's 137 inches. And the aging program
19 that they proposed to manage the effects on this buried pipe
20 is such that it is really responsive to this large pipe. It
21 doesn't address the small pipe because the examination would
22 be done from the ID of the pipe. And if it is a
23 smaller-diameter pipe, it cannot do it. So that is the
24 background information of this open item.

25 DR. KRESS: Are these pipes buried in concrete?

1 MR. GEORGIEV: They're buried in soil, in soil,
2 yes. They too address buried in concrete. Today is no
3 problem with the buried in concrete.

4 DR. UHRIG: What are they, discharge pipes, 137
5 inches?

6 MR. GEORGIEV: I think intake pipes.

7 MR. ROBINSON: This is Greg Robinson. The intake
8 piping is 11-foot diameter coming in from the lake, and I
9 believe it's a 9-foot diameter discharge piping. And the
10 piping is coated and wrapped, and was buried at the initial
11 construction.

12 MR. GEORGIEV: Basically so what these open items
13 is intended to do is seek information, find out what other
14 piping is involved. And another problem was like they do
15 have notes in the flow diagrams which allow that anything,
16 treat waters of an inch up to 6 inch, you can put -- you
17 could use stainless steel. But it is a maze, not shell. So
18 we really don't know what is stainless, what is carbon, what
19 is cast iron. And that is the purpose of this open item, so
20 when we get this information, we can evaluate it and
21 determine, you know, what are the problems.

22 DR. SEALE: You say that the QA records were not
23 such that you could ascertain what these particular pipes
24 were?

25 MR. GEORGIEV: We don't have the QA records.

1 Those are side documents. But we do have with the
2 application the flow diagrams, and with all fairness, those
3 are very good flow diagrams. They have more information
4 than typical flow diagrams, construction flow diagrams,
5 because they were made for license renewal. But it is not
6 that detailed for us to really determine how much is exempt,
7 so to speak, by what they are proposing to do. Maybe very
8 small, but maybe miles-long piping. We don't know. And
9 that is the purpose of that.

10 Other than that, we have an item of interest. The
11 applicant has performed an extensive review of aging effects
12 and an exhaustive identification of aging effects, which is
13 a compliment that they did a good job identifying the aging
14 effects.

15 That concludes my presentation and that of panel
16 member Miss Stephanie Coffin, and she did detailed system
17 reviews. So if you have some question concerning the open
18 items, she will be more than happy to give you the
19 specifics.

20 CHAIRMAN BONACA: Any questions?

21 DR. SEALE: This is an item that's still to be
22 resolved in the --

23 MR. GEORGIEV: Yes, sir. We'll receive the
24 information, and when we receive it, we'll have a fuller
25 picture as to determining whether what has been proposed is

1 adequate.

2 CHAIRMAN BONACA: Okay.

3 MR. ROBINSON: This is Greg Robinson. If I might
4 add just a thought here, I think one of the things that
5 you're seeing is not availability of QA records, but it's
6 the level of detail we provided in the application to
7 address the problem at hand versus say the piping drawings
8 or construction drawings that we certainly have on site, but
9 we can go and measure off the miles of piping or what not,
10 and we will be providing that information. So I think we're
11 just seeing the comparing and contrasting of the available
12 information set with that provided in the application.

13 DR. SEALE: Sometimes they're curioser than they
14 are other times.

15 MR. HOU: My name is Shou-Nien Hou, Material and
16 Chemical Engineering Branch, Division of Engineering.

17 Now, the common aging management program consists
18 of 13 individual programs. So to make a long story short, I
19 will just go to the open items, unless you have specific
20 questions so I can explain to you.

21 Now the first open item is related to the Duke
22 quality control program. That program set the requirements
23 of the corrective actions, document controls, confirmation
24 process. Especially it sets the control process and
25 responsibility and activities for initiating the corrective

1 actions for responding to the nonconforming conditions. And
2 the program generally is in conformance with 10 CFR Part 50,
3 Appendix B. So it is quite acceptable, except that it's
4 only covered safety-related components. But we know in the
5 license renewal review it covers safety and nonsafety both.

6 So after interaction with the licensee, we come
7 out with an agreement that they're going to expand a similar
8 requirement to the nonsafety-related components. But we do
9 need an official commitment either in the updated FSAR or
10 toward the quality assurance program, like documents of
11 Duke-18. And that's our open item.

12 Any questions?

13 [No response.]

14 The next open item relates to the exchanger
15 performance testing activities. You know, the heat
16 exchanger contains a lot of tubings and small pipes, and
17 it's subject to the corrossions that reduce the efficiency of
18 the heat transfer.

19 So performance testing activity actually is
20 performed, periodic testing of its heat-transfer capability
21 by measuring the flow rate and also the temperature
22 difference across the heat exchanger. But in the standby
23 shutdown facility heat exchangers they only do the flow rate
24 measurement. You know, that's not enough, because that heat
25 exchanger includes air-cooled coiling, also water-cooled

1 condenser.

2 And they also have the fins. If the fins fail,
3 now even the flow rate's maintained the same, but because of
4 fin failure the flow patterns change and the heat transfer
5 function changes, and that is going to degrade heat-transfer
6 capability. So we feel that across the heat exchanger the
7 temperature difference measurement is essential. And that's
8 our question.

9 Another is about the decay heat removal coolers,
10 building cooling units, and standby shutdown facility heat
11 exchangers. We would like to know what is acceptance
12 criteria for the performance testing and what are the bases.
13 And also we know that heat transfer function is needed for
14 the normal operating conditions and also for the accident
15 conditions. Can they do that? And we'd like to know the
16 story.

17 Also, in what condition do we consider that we
18 should initiate corrective action? On some occasions you
19 mentioned that it's 4 percent above the previous performance
20 testing results, or it's below certain limits. But we'd
21 like to know the limits for all these three, the heat
22 exchangers. And this is another open item.

23 The third one is about surface model piping
24 corrosion programs. Now we know that certain piping
25 consists of a lot of tubings and pipes. The material is

1 made out of copper, brass, and cast iron, and also the
2 carbon steels. And also the environment, it's raw waters.
3 Now, oh, the makeup of others, degradation mechanism. What,
4 your inspection, what you did, what the licensee did, is try
5 to use the carbon steel components sort of as leading
6 indicators.

7 Now, that immediately raised some questions. How
8 do you justify to use the carbon steel as a leading
9 indicator and as a result will bounding or the material
10 conditions and/or the degradation mechanisms.

11 And also one question we'd like to ask is another
12 technical use. It's ultrasonic testing. Now, ultrasonic
13 testing may not be suitable for tests as you test the
14 localized corrosion and microbiologically induced
15 corrosions, and those things may happen to some standard
16 steel, and you may not be able to detect that from the
17 carbon steel testing results.

18 And most of all, that program does not cover the
19 inspection of the Keowee systems. It's only to the Oconee
20 plants, but not Keowee. Now how to program up all the
21 results from Oconee can bond the Keowee condition. So
22 that's our question.

23 We have no license renewal issues.

24 That concludes my presentation.

25 CHAIRMAN BONACA: Thank you. Any questions?

1 DR. SHACK: What's different about the treated
2 water system stainless steel inspection and this MIC
3 question you're asking. Are they the same?

4 MS. COFFIN: That's talking to the service water
5 inspection, which is raw water environment.

6 DR. KRESS: Okay.

7 MS. COFFIN: And the treated water is, well,
8 treated water.

9 DR. SEALE: In these systems that have mixed
10 piping, have you had problems with them so far with
11 corrosion?

12 MR. ROBINSON: This is Greg Robinson. When you
13 say mixed piping, are you talking about stainless and carbon
14 and --

15 DR. SEALE: Yes, stainless and carbon and copper
16 especially, or brass.

17 MR. ROBINSON: The short answer is no. We've had
18 carbon steel issues and we've used stainless steel as a
19 replacement material, and the periodicity of corrosion
20 problems on that stainless is going to be decades --

21 DR. SEALE: Yes.

22 MR. ROBINSON: And so we don't expect to see
23 anything for a long, long time, if ever.

24 DR. SEALE: Yes.

25 MR. ROBINSON: But, no, we've had no problems --

1 we have had carbon steel problems, but no problems with the
2 other materials.

3 MR. GRIMES: This is Chris Grimes. The nature of
4 the open issue isn't -- wasn't driven so much by a question
5 but that we know there have been problems with corrosion of
6 copper or cast iron. It's a reliance on an indicator from
7 findings of carbon steel inspections as --

8 DR. SEALE: Yes.

9 MR. GRIMES: Since you're not going to see
10 anything for a decade, are you going to remember that that's
11 the only thing you're measuring in order to make sure that
12 you take appropriate corrective action for these other
13 materials?

14 DR. SEALE: If it's going to leak, you want to
15 know by how much.

16 MR. GRIMES: Right. And where.

17 DR. SEALE: Yes.

18 MR. GRIMES: And where.

19 DR. SHACK: Well, I thought it was more the fact
20 that, you know, I mean if it's general corrosion, it's true,
21 I mean stainless and carbon steel are, you know, grossly,
22 but there's nothing that says you can't pit or have MIC
23 attack on the carbon steel, and it has no relation to the
24 general corrosion of the carbon.

25 MS. COFFIN: It's for the other mechanisms.

1 That's why the question's there.

2 DR. UHRIG: Have you had any significant problems
3 with the microbiological induced corrosion?

4 MR. ROBINSON: No, we have not. This is Greg
5 Robinson. In fact, to my knowledge we have had no
6 indication of problems with MIC at all. We're in the
7 foothills of the Appalachian Mountains, and the water
8 quality is pretty high.

9 DR. UHRIG: Usually, at least my limited
10 experience has been in water -- in stagnant water in pipes.

11 MR. ROBINSON: Yes, that would produce a conducive
12 environment for that to occur.

13 DR. SEALE: Everything grows fast in the water in
14 Florida.

15 [Laughter.]

16 DR. UHRIG: This is a Tennessee plant, Bob.

17 DR. KRESS: South Carolina.

18 DR. UHRIG: The one that had the MIC.

19 DR. KRESS: Oh, I'm sorry. I thought you were
20 talking about Ocone.

21 DR. UHRIG: No, no, it was at the Tennessee plant.

22 DR. KRESS: Fungus really grows fast.

23 CHAIRMAN BONACA: Okay. If there are no further
24 questions, I think we exhausted that agenda for today, and I
25 wonder if you have any presenters for tomorrow's items that

1 we can continue.

2 MR. SEBROSKY: The short answer is yes, we have
3 people for 3.3 and 3.4 that we can move from tomorrow to
4 this evening. As a matter of fact, they're here. So we can
5 go ahead and if you want go ahead and talk about 3.3 next.

6 CHAIRMAN BONACA: I think we should, items 3.3 and
7 3.4. Yes, 3.3 being containment structures.

8 MR. SEBROSKY: We don't have -- after we do the
9 presentation on 3.4, we haven't made any arrangements to
10 bring other people up.

11 CHAIRMAN BONACA: So we will resume tomorrow after
12 that. Okay.

13 MR. ASHAR: I am Hansraj Ashar from Division of
14 Engineering and I will be making a short presentation on
15 containment structures as to what the licensee has provided
16 to us in license renewal application. Yes?

17 DR. SHACK: I think the answer is if you can read
18 it, we can read it.

19 [Laughter.]

20 MR. ASHAR: I can read from here. You can read
21 from there.

22 Before I jump to the open items, I think I would
23 like to say something about what the applicant has provided
24 in the LRA and how the Staff has reviewed it in a very brief
25 manner.

1 For containment structures at Oconee, the
2 Applicant has grouped components of the containment
3 structure in three groups, the concrete components, the
4 steel components, and the post-tensioning tendon components.
5 In concrete components it includes the dome and cylindrical
6 wall, the basemat and the floor. Steel components includes
7 the liner plate and penetrations including equipment hedge,
8 the access openings, and the other process, the piping, and
9 post-tensioning tendons that includes the wires, the
10 tendons, the anchorage components.

11 Now for all these components, the applicant has
12 identified the aging effects and based on those aging
13 effects it has provided aging management programs.

14 There are three programs which the applicant is
15 counting on for managing the aging of containment
16 structures. Containment ISI plan, which is inservice
17 inspection plan for containment, containment program, and
18 the containment leak rate testing program. All these three
19 programs has been evaluated by the Staff in accordance with
20 the 10 elements for evaluating any of the plants or programs
21 which are something like a scope of the program, the
22 preventative actions, parameters monitored, et cetera.
23 There are 10 elements against which we evaluate these types
24 of programs.

25 One open item -- we believe the application has

1 fulfilled their requirement for aging management of the
2 containment structure components.

3 Now I will explore a little bit on the open item.
4 It talks about the lack of A&P to manage the aging effects
5 on tendon galleries. Now tendon galleries, I do not know
6 whether all of you are aware of it, where they are and what
7 they are, but the tendon galleries are the bottom of the
8 basemat of the containment structure. They are mainly used
9 for access to the tendon anchorages, so that during the
10 installation also they don't need it and during the
11 inservice inspection they need to go in that area to make
12 sure that they can inspect the grease caps and the anchorage
13 components in the tendon galleries.

14 Now what we see in the application is that the
15 applicant is not telling us how the tendon galleries will
16 be -- the effect of the degradation on tendon galleries will
17 be managed, and the reason we are not asking for this,
18 because we consider tendon galleries as pressure boundary
19 for containment. We consider it is a nonpressure boundary,
20 however the environment in the tendon galleries does give
21 aging effects on the tendon anchorage components, and we
22 have seen that in a number of plants that the bearing place
23 of some of the anchorages had corroded. We have seen quite
24 an infiltration of water at a number of tendon galleries,
25 and the high humidity in the tendon galleries, and that is

1 why we believe that the most cost-effective way of ensuring
2 that the tendon anchorages degradations are managed well,
3 the basic thing that the applicant has to do is to manage
4 the aging effects on tendon galleries and make sure the
5 environment in the tendon galleries is not conducive to
6 corrosion and degradation of the anchorage components. That
7 is the open item I am talking about.

8 The license renewal issues -- the license renewal
9 issues on tendons, this is mainly a discussion of
10 temperature effect on tendons. Our experience has shown
11 that the pre-stressing tendon forces in containments have
12 seen more losses than what were estimated at the time the
13 construction was -- when the design was performed, and that
14 is the reason this particular issue came as one of the
15 license renewal issues.

16 Now the Staff feels that the applicant's ISI plan,
17 which I mentioned earlier, plus an adequate TLAA for
18 tendons, which the applicant has performed to some extent --
19 we have some problems but that will come under the topic on
20 TLAA, but we believe that the ISI plan and the adequate TLAA
21 would take care of this particular license renewal issue.

22 The second issue on 98-0049, inaccessible areas,
23 10 CFR 50.55(a) has a requirement to look for the
24 degradation in the inaccessible area if there are symptoms
25 that indicates that there would be some problems in the

1 inaccessible areas. The basic concern in 98-0049 I believe
2 is related to the other areas which are not being indicated
3 by the accessible areas. Mainly there's the groundwater
4 chemistry that might affect the degradation and aging of the
5 below-grade containment structures.

6 The applicant response to some of the questions
7 that we asked has provided us with chemical composition of
8 some of the contaminants in the groundwater and it amounts
9 to something like less than 10 ppm of chlorides and close to
10 about 500 ppm or less of sulfates, which are the basic
11 contaminants we think are detrimental to the concrete
12 structures, so we believe that that particular issue for
13 containment has been addressed.

14 The next license renewal issue is 98-052, which is
15 related operating experience. The applicant has provided
16 data on what has happened to pre-stressing tendons and the
17 liner plate corrosion and the junction of the cylindrical
18 wall and the basemat, that they have seen some corrosion and
19 they have taken corrective actions on that, so the vital
20 things that are necessary for operating experience has been
21 provided in the license renewal application, so we believe
22 it has been very well covered in that.

23 The next one, in 98-0057, relation to maintenance
24 rule. I have not seen much discussion of this particular
25 issue in application itself, but the way we perceive, the

1 Staff perceives it is that for maintenance rule, as a matter
2 I had been to a couple of inspections on maintenance rule
3 baseline inspections, in which the licensees in general, not
4 this particular applicant but the licensee in general have
5 taken credit for the ISI plan, which is an implementation of
6 subsection IWE/IWL of ASME Section 11.

7 They have taken credit for preventive maintenance
8 for the maintenance rule, so I think it applies to this
9 particular application too.

10 On the subject of the next license renewal issue,
11 98-0087, which is related to the temperature, actually
12 shield water temperature should go into Section 3.8 but I'll
13 talk only about the containment temperature here.

14 The applicant has addressed this issue under
15 environmental assessment and its effect on various parts of
16 the containment structures, so the Staff believes that it
17 has been addressed well in the application and we don't have
18 any issue related to that particular license renewal issue.

19 Now items of interest, as I mentioned before about
20 the TLAA for post-tensioning tendon forces, will be
21 discussed probably tomorrow, in Section 4.22 of this SE.

22 TLAA for liner and penetration fatigue analysis,
23 that will be discussed in 4.21 of the SE, probably tomorrow.
24 That ends my presentation.

25 DR. SEALE: You mentioned that the experience with

1 tendons has been less positive than expected, that you have
2 had some relaxations of tendon tension which were more than
3 you would have anticipated?

4 MR. ASHAR: Yes. The experience does show that at
5 a number of plants the pre-stressing tendons were losing
6 their pre-stressing forces more than what was anticipated or
7 what was estimated during the design of the plant.

8 At Ginna, the licensee for Ginna had gone through
9 extensive investigation of why that happened and what they
10 found, they sent out the specimen of the wires and tendons
11 to Lehigh University for testing as to why it happened, and
12 the conclusion was that the steel that is being used for
13 pre-stressing tendons is going through much higher
14 relaxation at higher temperatures. In tighter temperatures
15 we are not talking about very high temperatures, we are
16 talking about in the range of 95 degrees instead of 72
17 degrees -- 95 degrees and 100 degree temperatures.

18 It was clearly indicated in some of the research
19 that has been done at Lehigh that relaxation losses are
20 occurring at a higher rate than would occur at 72 degrees
21 temperature, for example.

22 DR. KRESS: How did they determine? Did they
23 retorque the volts or they got crane gauges on it or --

24 MR. ASHAR: No. What they did was they took the
25 pre-stressing wires from the plant --

1 DR. KRESS: Oh, they took it out.

2 MR. ASHAR: They took it out because they had to
3 take it out as part of inspection and part of investigation.
4 They took out the pre-stressing wires. Because they are
5 greased you can take them out if you want, and as a matter
6 of fact, as part of the inservice inspection they have to
7 take one wire out of it in order to inspect the material
8 properties and condition of simple wire. It is part of the
9 inspection requirement.

10 So they took those wires out and stressed to
11 various levels of pre-stressing force and then they left it
12 for 1000 hours and 10,000 hours kind of timing to see how
13 much it relaxes under various temperature conditions.

14 DR. KRESS: I see what you are saying. They did
15 it in a lab.

16 MR. ASHAR: They did it in a lab, yes.

17 MR. GILL: Bob Gill, Duke. Just a footnote on
18 this. The original tech spec requirements for testing our
19 tendons required us to look at the same tendons periodically
20 specified in the tech specs. Several years ago Staff was
21 reviewing a report that we had made on that tendon testing
22 and strongly suggested we convert to Reg Guide 135, just a
23 random testing sample, and that was about concurrent with
24 the imposition of IWL, the rulemaking that occurred three or
25 four years ago, I forget, so have just recently shifted

1 from specified tendons to random tendons, and so we really
2 only have one datapoint with the random testing results, and
3 as we get more data obviously we can do extrapolations in
4 the future.

5 We have the projected loss based on the data we do
6 have. We projected that out and it is well above the
7 prescribed minimum limit at 60 years. That is in a document
8 called Selected Licensee Commitments, which are a part of
9 our FSAR. We will do the periodic testing and confirm that
10 our actual datapoints are above that. That is part of the
11 application. In fact, the FSAR supplement contains those
12 curves in there and again we are in a transition mode at
13 Ocone from what we had had for 20 some years to the new
14 random selection process, and which tendons do you select,
15 do you select some near main steam pipes which might be a
16 little warmer than others? All that is in the process of
17 evolution as a Part 50 type issue.

18 We tried to capture that in the renewal
19 application but the target is still evolving in some
20 respects.

21 DR. SEALE: Thank you.

22 DR. KRESS: What does containment leak testing
23 tell you about aging of containment? Anything?

24 MR. ASHAR: Containment leak testing regarding the
25 prestressing force, you mean?

1 DR. KRESS: No, about aging in general.

2 MR. ASHAR: Aging in general. Well, Type A test
3 generally tells us the overall leak rate into the
4 containment from the containment structure.

5 DR. KRESS: Tell you some of the elastomers
6 have --

7 MR. ASHAR: Elastomers, yes, but that would be
8 more seen in Type B type of test. Type B tests are the
9 ones --

10 DR. KRESS: Where you go right to the --

11 MR. ASHAR: Where you locally --

12 DR. KRESS: Locally go to the --

13 MR. ASHAR: Pressurize the particular
14 penetrations.

15 DR. KRESS: Yes.

16 MR. ASHAR: And try to find out the leakage rates.
17 And there are limits on leakage rates. So when they exceed
18 that leakage rate, then they ought to do something about it,
19 why it's happening. And many times the seals and gaskets
20 might come off it.

21 MR. GRIMES: This is Chris Grimes. I'd like to
22 add that Appendix J also has requirements in it that speak
23 to performing visual inspections. You basically want to
24 check the condition of the containment before you pump it up
25 so that you don't, you know, inadvertently blow a seal out

1 or something or break light bulbs. So to the extent that
2 Appendix J also provides for a visual inspection and just
3 the setup and performance of the test causes you to have to
4 go check on the condition of the structures, it provides you
5 with an inspection activity that constitutes an opportunity
6 to look for nonconforming conditions.

7 CHAIRMAN BONACA: Any other questions on
8 containment structures?

9 [No response.]

10 If not, I think we have one more presentation on
11 reactor coolant systems.

12 MS. BANIC: Good afternoon, ladies and gentlemen.
13 My name is Lee Banic, and it's a pleasure for me to be here
14 to discuss our safety evaluation of the reactor coolant
15 system. As coordinator of the review for the Division of
16 Engineering, I'll be making the presentation. Assisting me
17 is Barry Elliot, who had most of the open issues --

18 [Laughter.]

19 And generic license renewal issues.

20 There were ten reviewers who contributed to this
21 section, and many of them are here with me to answer any
22 questions you may have.

23 Duke described its aging management review of the
24 reactor coolant system in 17 sections of its application.
25 We reviewed these sections to determine whether the effects

1 of aging on the reactor coolant system components will be
2 adequately managed. The components are piping, pressurizer,
3 reactor vessel and internals, steam generators, reactor
4 coolant pumps, control rod drive, tube motor housings, and
5 letdown coolers.

6 The programs we reviewed were the Alloy 600
7 program, inspections for the pressurizer, reactor vessel
8 internals, small-bore piping, control rod drive mechanism,
9 nozzle and other vessel closure head penetrations,
10 high-pressure injection connections, reactor vessel
11 integrity, and steam generator tube surveillance.

12 Duke earlier described its aging management
13 programs for the reactor coolant system in four Babcock &
14 Wilcox owners' group topical reports. These reports were on
15 the reactor coolant system piping, pressurizer, reactor
16 vessel, and reactor vessel internals. We previously
17 approved reports on the piping and pressurizer. We had a
18 few open and action items in our safety evaluation for those
19 reports, and we found that Duke addressed them in its
20 application. We reviewed the reports on the reactor vessel
21 and internals concurrently with Duke's application. We had
22 no open items regarding the reactor vessel. We did have
23 open items for the internals, which we list in our safety
24 evaluation for the application.

25 We found that except for the open items shown on

1 the slides that Duke has shown that the effects of aging on
2 the reactor coolant system will be adequately managed so
3 that we can make our reasonable assurance finding.

4 And now for the open items. We had two open items
5 about Duke's identification of aging effects. They're shown
6 on the slide. Duke is to identify that the aging effects
7 for pressurizer spray head are cracking and reduction in
8 fracture toughness due to the thermal aging of cast
9 stainless steel and to provide the basis that void swelling
10 is not an issue for reactor vessel internals or provide an
11 aging management program for it. The staff is concerned
12 that void swelling could change the dimensions of a
13 component and thus its ability to perform its intended
14 function.

15 We had a number of open items about aging
16 management programs. This first open item relating to
17 inspection of pressurizer components exists because they are
18 made of Alloy 600, an alloy susceptible to primary water
19 stress corrosion cracking.

20 The next item is open --

21 DR. SHACK: Is the pressurizer spray head the only
22 internal component that's cast stainless?

23 MR. ELLIOT: That's the only one identified, yes,
24 so far, on the pressurizer. We have cast -- on the
25 internals there is cast stainless steel.

1 DR. SHACK: Okay.

2 MR. ELLIOT: But on the pressurizer -- this is the
3 only one they've identified.

4 MR. RINCKEL: This is Mark Rinckel from Framatome.
5 That's correct. It's the only cast item in the pressurizer.

6 MR. ELLIOT: The internals have cast stainless.
7 That's a separate item here.

8 DR. SHACK: What would be the internals component
9 that would see high enough fluence that you'd worry about
10 the dimensional changes from void swelling?

11 MR. ELLIOT: It would be -- what's the name of it,
12 whatever's nearest the core.

13 MR. RINCKEL: It would probably be the baffle
14 plates or baffle bolts. Those receive the highest fluence,
15 some around 10 to the 22, 10 to the 23.

16 DR. SHACK: I can see them getting stressed
17 perhaps by swelling, but, I mean, what --

18 MR. RINCKEL: I --

19 DR. SHACK: Requirement?

20 MR. RINCKEL: Well, I guess there are questions
21 with that type of fluence. The NRC said that the swelling
22 could be between 4 and 14 percent. I think this is very
23 much a research issue, and, you know, we're certainly
24 looking at responding to that and looking into it. But my
25 understanding is that any dimensional changes would really

1 impact the baffle bolts, and we have a program to look at
2 the baffle bolts, so that's really going to be the focus of
3 our response.

4 MR. ELLIOT: That you're inspecting the baffle --

5 MR. RINCKEL: We will at some time. Right now we
6 just do visual of those.

7 MR. ELLIOT: The intent of this question is to
8 make sure they have a reactor vessel internals program,
9 which you've heard discussed before. We want to make sure
10 that part of that program that they address void swelling.

11 MS. BANIC: The next item is open because Duke did
12 not identify thermal fatigue as an aging mechanism for the
13 letdown coolers. However, Duke had thermal fatigue damage
14 on four coolers due to operating them in an improper manner.
15 Duke repaired them, but we're asking Duke for information to
16 convince us that the four coolers will not fail again due to
17 thermal fatigue. We had open items about stainless steel
18 components. The first one applies to managing thermal aging
19 of reactor vessel internals, valve bodies, the pressurizer
20 spray head.

21 The next item applies to reactor vessel internals.
22 Duke is to identify and include limiting wrought stainless
23 steel nonbolting components and welds in internals in its
24 ISI program. This action is necessary to manage the effect
25 of neutron irradiation embrittlement in these components.

1 The next item is to manage the effects of
2 irradiation-assisted stress corrosion cracking, IASCC, of
3 stainless steel bolting of reactor vessel internals.

4 The next open item addresses synergistic effects
5 of thermal and neutron embrittlement on the fracture
6 toughness of cast stainless steel internal components.

7 DR. SHACK: On that one, you seem to have a
8 criterion for the fluence on the cast stainless. Has that
9 really ever been looked at independently or do you just
10 assume that if you've got enough ferrite in it to embrittle
11 it thermally, it's going to embrittle when you irradiate it
12 too?

13 MR. ELLIOT: Our approach on -- Barry Elliot --
14 our approach on the cast stainless steel internals is to
15 look at both mechanisms simultaneously. Failure to satisfy
16 either mechanism, whether it be embrittlement or cast --
17 whether it be neutron embrittlement or thermal
18 embrittlement, if you cannot satisfy the criteria we've
19 written into the safety evaluation, then an augmented or
20 supplementary inspection would be required. So in this case
21 you have to satisfy both criteria. Satisfying one is
22 insufficient.

23 We've established two criteria. We have a thermal
24 embrittlement criterion in the SER. We have a neutron
25 embrittlement criterion in the SER. And if they can satisfy

1 both those criteria, then they don't need to do any
2 supplementary inspection. If they can't satisfy both
3 criteria, then they would have to do some kind of
4 supplementary inspection.

5 DR. SHACK: But the neutron embrittlement criteria
6 is basically a fluence level --

7 MR. ELLIOT: Yes.

8 DR. SHACK: And then a ferrite level that's
9 essentially equivalent to what you use for the thermal
10 aging. Is that --

11 MR. ELLIOT: Right. And also we're allowing as
12 part of the neutron embrittlement and thermal embrittlement,
13 if the stresses are very low, if they can show the stresses
14 are very low, then we would --

15 DR. SHACK: You don't really care.

16 MR. ELLIOT: We don't really care. That may be
17 one way the spray head can be removed from inspection, for
18 instance, is there's probably very little stresses on the
19 spray head. You know, that would be something they have to
20 look at. We just established a criterion. It's up to them
21 to, once we established a criterion, to convince us that
22 nothing -- no supplementary inspection is required.

23 MR. RINCKEL: I had one question. In the B&W
24 owners' group RCS piping report, BAW 2043(a), that was
25 approved by the NRC in 1996, you had accepted a different

1 position for the evaluation of CASS valve bodies, and I
2 guess three years have elapsed and things have happened.
3 But the position that you have here is different than what
4 was accepted before. And I wonder if you might just tell us
5 what your thinking is here and what's transpired in three
6 years to lead to this.

7 MR. ELLIOT: In the last three years, in fact in
8 the last year, the industry has come up with a criterion for
9 evaluating CASS stainless steel. We didn't have that
10 criterion three years ago. We've reviewed that criterion
11 now. We've adopted it as well as provided additional
12 criteria we think should be added to it, and we think that
13 Duke should implement the industrywide criteria at this
14 time.

15 MR. GRIMES: That raises a good point in terms of
16 all of the topical report approvals are subject to
17 verification to make sure that they're still current, and so
18 before we complete the final safety evaluation we'll make
19 sure that the evaluation basis for all the B&W topicals is
20 current.

21 MR. RINCKEL: I think that's the only one so far
22 that I've seen that there's been a, you know, something -- a
23 different position. So I just wanted to get clarification.

24 MS. BANIC: This last open item concerns vent
25 valve and retaining rings, which are precipitation-hardened

1 stainless steel being subject to supplemental examination
2 unless Duke can show that loss of fracture toughness from
3 thermal embrittlement and neutron irradiation embrittlement
4 is not significant.

5 We had no confirmatory items. There were three
6 license renewal issues. As shown on the slide, they are
7 thermal aging of cast stainless steel, vessel surveillance,
8 and internals embrittlement. We cover all of these issues
9 in our safety evaluation. As you have heard, Duke's
10 treatment of the thermal aging of cast stainless steel and
11 internals embrittlement resulted in open issues. We had no
12 issues with the vessel surveillance program. And we had no
13 items of interest.

14 MR. GRIMES: As they're leaving the table, I'll
15 say are there any questions on section 35?

16 [Laughter.]

17 DR. SEALE: We noticed they were pretty slick.

18 CHAIRMAN BONACA: It was quite a fast move.

19 Any other questions from any Members here?

20 [No response.]

21 There are none, so we thank the staff for the
22 presentations they've given to this point, and we have
23 gained some time for tomorrow morning. We will resume the
24 presentations tomorrow morning with I guess SER Section 3.5,
25 Engineered Safety Features, and also because we gained some

1 time, we will have time for the subcommittee for our
2 deliberation and decisions on what we need to bring to the
3 full committee in September, as well as some topics for the
4 ACRS interim letter.

5 So with that, we thank the presenters both from
6 Duke and from the staff, and we'll move on to -- we have one
7 hour here right now for us to have some brief discussion c-
8 what we heard, and again we have time tomorrow again at
9 midday.

10 Chris, could you stick around?

11 MR. GRIMES: Certainly.

12 CHAIRMAN BONACA: I think for the following
13 discussion we will go off the record.

14 [Whereupon, at 3:40 p.m., the meeting was recessed
15 to reconvene at 8:30 a.m., Thursday, July 1, 1999.]
16
17
18
19
20
21
22
23
24
25

REPORTER'S CERTIFICATE


This is to certify that the attached proceedings before the United States Nuclear Regulatory Commission in the matter of:

NAME OF PROCEEDING: MEETING: PLANT LICENSE RENEWAL

CASE NUMBER:

PLACE OF PROCEEDING: Rockville, MD

were held as herein appears, and that this is the original transcript thereof for the file of the United States Nuclear Regulatory Commission taken by me and thereafter reduced to typewriting by me or under the direction of the court reporting company, and that the transcript is a true and accurate record of the foregoing proceedings.

A handwritten signature in dark ink, appearing to read "Jon Hundley", is written over a horizontal line.

Jon Hundley

Official Reporter

Ann Riley & Associates, Ltd.

INTRODUCTORY STATEMENT BY THE CHAIRMAN OF THE
PLANT LICENSE RENEWAL SUBCOMMITTEE
11545 ROCKVILLE PIKE, ROOM T-2B3
ROCKVILLE, MARYLAND
JUNE 30-JULY 1, 1999

The meeting will now come to order. This is a meeting of the ACRS Subcommittee on Plant License Renewal. I am Mr. Mario Bonaca, Chairman of the Subcommittee.

ACRS Members in attendance are: Drs. George Apostolakis, Thomas Kress, Robert Seale, William Shack, and Robert Uhrig.

The purpose of this meeting is for the Subcommittee to review the NRC staff's safety evaluation report related to the Oconee license renewal application, crediting of existing programs, and related matters. The Subcommittee will gather information, analyze relevant issues and facts, and formulate proposed positions and actions, as appropriate, for deliberation by the full Committee. Mr. Noel Dudley is the Cognizant ACRS Staff Engineer for this meeting.

The rules for participation in today's meeting have been announced as part of the notice of this meeting previously published in the *Federal Register* on June 1, 1999.

A transcript of this meeting is being kept, and will be made available as stated in the Federal Register Notice. It is requested that speakers first identify themselves and speak with sufficient clarity and volume so that they can be readily heard.

We have received no written comments or requests for time to make oral statements from members of the public.

On June 16, 1999, the NRC staff completed the safety evaluation report for the Oconee license application. This is the second safety evaluation report for a license renewal application. The report identifies 43 open items that must be resolved for the staff to complete the evaluation. The open items include the basis for excluding specific structures

and components from an aging management review; applicability of certain aging effects to structures and components; and the need for additional periodic inspections. The safety evaluation report also identifies six confirmatory items that involve documentation of certain information or commitments. The ACRS plans to review and comment on this safety evaluation report at its September 1999 meeting.

On June 3, 1999, the staff issued a Commission paper identifying options for crediting existing programs for license renewal. The ACRS plans to review and comment on crediting existing programs at its July 1999 meeting. This is one just example of the license renewal policy issues that the staff is evaluating and that the Subcommittee plans on considering.

We will now proceed with the meeting and I call upon Mr. Christopher Grimes, Chief of the License Renewal and Standardization Branch to begin.

JUNE 30, 1999
AGENDA ITEM III

51-1234566-02

Figure D1 - OC-1 Heatup/Cooldown Cycles per Year




Figure D2 - OC-1 Heatup/Cooldown Cycles Projected for 60 Years





Figure 2-10 Incore Instrumentation System Nozzle





ACRS LICENSE RENEWAL SUBCOMMITTEE

JUNE 30 - JULY 1, 1999

**NRC SAFETY EVALUATION
RELATED TO BAW-2251**

**Barry Elliot
DE/EMCB**

FINAL SAFETY EVALUATION RELATED TO BAW-2251

"Demonstration of the Management of Aging Effects for the Reactor Vessel"

OPEN and CONFIRMATORY ITEMS

- NONE

AGING MANAGEMENT PROGRAMS

- ASME Code, Section XI, Inservice Inspection Program
- Boric Acid Wastage Surveillance Program
- Technical Specification Leakage Limits
- B&WOG Reactor Vessel (RV) Integrity Program

FINAL SAFETY EVALUATION RELATED TO BAW-2251 (CONT.)

RENEWAL APPLICANT ACTION ITEMS

- Thirteen plant-specific renewal applicant action items identified

License Renewal Issues

- 98-0085 - Vessel surveillance
- 98-0028 - Fatigue of metal components

FINAL SAFETY EVALUATION RELATED TO BAW-2251 (CONT.)

TLAAs

- Fatigue of metal components
- Pressurized Thermal Shock (PTS) analysis to 10 CFR 50.61 - Neutron fluence analysis contained in Topical Report BAW-2241P
- Charpy Upper Shelf Energy (USE) analysis to Appendix G, 10 CFR Part 50 - Analysis contained in Topical Report BAW-2275
- Growth of intergranular separations in low alloy steel forgings heat-affected zones under stainless steel weld deposit cladding - Analysis contained in Topical Report BAW-2274

FINAL SAFETY EVALUATION RELATED TO BAW-2251 (CONT.)

ITEMS OF INTEREST

- Master Integrated Reactor Vessel Material Surveillance Program contained in Topical Report BAW-1543, Revision 4, Supplement 2
- PTS analyses:

Initially the Oconee 2 upper shell to lower shell circumferential weld RT_{PTS} value was calculated as 304°F, 4°F above the PTS Screening Criteria at the end of the license renewal term.

As a result of analysis of chemistry data and Charpy impact data (in response to Generic Letter 92-01, Rev. 1, Supplement 1) and revision to the RV neutron fluence, the RT_{PTS} value was reduced to 297°F.

Additional analyses will be performed as surveillance material is irradiated and tested.



ACRS LICENSE RENEWAL SUBCOMMITTEE

JUNE 30 - JULY 1, 1999

**OCONEE LICENSE RENEWAL
APPLICATION**

**OCONEE LICENSE RENEWAL APPLICATION
NRC PRESENTERS**

GENERAL TOPICS

PRESENTER

Status of License Renewal Activities

**Joseph Sebrosky
DRIP/RSLB**

**Overview of Safety Evaluation Report (SER)
Related to Oconee License Renewal**

**Joseph Sebrosky
DRIP/RSLB**

SER SECTION AND TOPIC

PRESENTER

**2.1 Methodology for Identifying Structures
and Components Subject to Aging
Management Review (AMR)**

**Bob Latta
DIPM/IQMB**

**2.2 Identification of Structures and Components
Subject to Aging Management Review**

**Chris Gratton
DSSA/SPLB**

NRC PRESENTERS (CONT.)

<u>SER SECTION AND TOPIC</u>	<u>PRESENTER</u>
3.1 Applicable Aging Effects for Mechanical Components	George Georgiev DE/EMCB
3.2 Common Aging Management Programs	Shou-Nien Hou DE/EMCB
3.3 Containment Structures	Hansraj Ashar DE/EMEB
3.4 Reactor Coolant System (RCS)	Lee Banic DE/EMCB
3.5 Engineered Safety Features	Stephanie Coffin DE/EMCB

NRC PRESENTERS (CONT.)

SER SECTION AND TOPIC

PRESENTER

3.6 Auxiliary Systems

Stephanie Coffin
DE/EMCB

3.7 Steam and Power Conversion Systems

Kris Parczewski
DE/EMCB

3.8 Structures and Component Supports

David Jeng
DE/EMEB

3.9 Electrical Components

Paul Shemanski
DE/EELB

4.0 Time-Limited Aging Analyses (TLAA)

Paul Shemanski
DE/EELB

STATUS OF LICENSE RENEWAL ISSUES

A. License Renewal Issues

- 108 license renewal issues - mostly NEI comments on the draft Standard Review Plan (SRP)
- Staff proposed resolutions - 9
- Continuing interactions with NEI to clarify issues & develop resolutions

B. Standard Format for Applications

- NRC letter to NEI - Mar. 15, 1999, transmitted Calvert Cliffs and Oconee Safety Evaluation Report Table of Contents
- Public meeting with NEI - Apr. 13, 1999
- NEI response June 17, 1999

STATUS OF LICENSE RENEWAL ISSUES (CONT.)

C. Standard Review Plan, Regulatory Guide (RG), and NEI 95-10

- Draft SRP: Placed in Public Document Room - Sept. 1997
- Draft RG: Published DG-1047 for public comment - Aug. 1996
- NEI 95-10: Issued Mar. 1996. Draft RG proposes to endorse it
- SRP & RG update plan

OVERVIEW OF OCONEE LICENSE RENEWAL APPLICATION

- Application dated - July 6, 1998
- Staff completed requests for additional information (RAIs) - Dec. 4, 1998
- Duke completed RAI responses - Feb. 17, 1999
- Public meetings, letters, telephone calls, & site visits used to resolve staff questions
- SER issued June 16, 1999 (43 Open Items and 6 Confirmatory Items)
- Hearing status - petition denied
- Comparison - Oconee and Calvert Cliffs renewal reviews

OVERVIEW OF OCONEE LICENSE RENEWAL APPLICATION (CONT.)

LICENSE RENEWAL INSPECTIONS

- Scoping and screening process Apr. 26-30, 1999
- Aging management review July 12-16 and 26-30, 1999
- Final verification (optional) 30 days prior to final licensing action

OCONEE SCHEDULE

- Duke complete response to open items Oct. 15, 1999
- Staff issue Safety Evaluation Report Feb. 12, 2000
- ACRS Final Meeting May 2000
- Decision on Oconee renewal license Aug. 2000

PRIORITY 1 LICENSE RENEWAL ISSUES

ISSUE #	DESCRIPTION	DUKE REVIEW CONSIDERATION
98-0003	Operating experience	DUKE provided information
98-0009	FSAR content	Will follow 10 CFR 50.71(e) guidance
98-0012	Consumables (Not Priority 1)	Section 2.2 of SER
98-0014	EQ TLAA	Section 4.2 of SER
98-0016	Fuses	Section 3.9 of SER
98-0028	Fatigue (Not Priority 1)	Section 4.2 of SER
98-0030	Thermal aging of CASS	Section 3.4 of SER
98-0048	IWE/IWL: Tendons	Sections 3.3 & 4.2 of SER
98-0049	IWE/IWL: Inaccessible	Section 3.3 of SER
98-0052	IWE/IWL: Op. exp.	Section 3.3 of SER

PRIORITY 1 LICENSE RENEWAL ISSUES (cont.)

ISSUE #	DESCRIPTION	DUKE REVIEW CONSIDERATION
98-0057	Maintenance rule/struct.	Sections 3.3 & 3.8 of SER
98-0068	Code editions	Duke provided information
98-0082	Cascading support Sys.	Section 2.2 of SER
98-0085	Vessel surveillance	Sections 3.4 & 4.2 of SER
98-0087	Shield wall temp.	Section 3.3 of SER
98-0100	FERC dams	Section 3.8 of SER
98-0103	Internals embrittlement	Section 3.4 of SER
98-0105	Heat exchanger function	Section 2.2 of SER

2.1 METHODOLOGY FOR IDENTIFYING STRUCTURES AND COMPONENTS SUBJECT TO AGING MANAGEMENT REVIEW

Open Items

- Applicant to revise response to RAI 2.2-6, to include a description of the process used to identify events for Oconee license renewal scoping and an explanation as to how the 26 events identified during the May 11, 1999, meeting are sufficient to satisfy the requirements of 10 CFR 54.4(a)(1) and 54.4(a)(2).
- Subsequent to the receipt of the above information the staff will determine whether additional inspection activities will be needed to verify the adequacy of the applicants process for identifying structures and components that are within the scope of the rule.

Confirmatory Items

- None

2.1 METHODOLOGY FOR IDENTIFYING STRUCTURES AND COMPONENTS SUBJECT TO AGING MANAGEMENT REVIEW (CONT.)

License Renewal Issues

- None

Items of Interest

- Evaluation of the scoping and screening methodology for Oconee was challenging for the staff because as stated, in part, in the application "..... a list of the Oconee safety-related systems, structures and components, in and of itself, will not meet the intent of 10 CFR 54.4(a)(1)."

2.2 IDENTIFICATION OF STRUCTURES AND COMPONENTS SUBJECT TO AGING MANAGEMENT REVIEW

Open Items

- Basis for the recirculated cooling water system not being included within the scope of license renewal.
- Basis for the chilled water system not being included within the scope of license renewal.
- Passive, long-lived skid-mounted equipment are excluded from an AMR.
- Structural sealants, water stops, and expansion joints are excluded from an AMR.
- Staged pumps, electrical cable, and switchgear have been excluded from an AMR.

2.2 IDENTIFICATION OF STRUCTURES AND COMPONENTS SUBJECT TO AGING MANAGEMENT REVIEW (CONT.)

Open Items (Cont.)

- Provide a plant-specific justification for excluding the Keowee and Turbine Building roofs from an AMR.
- Provide a plant-specific basis for excluding the ventilation sealant material from an AMR.
- Provide a plant-specific justification for excluding fire detector cables from an AMR.

Confirmatory Items

- The applicant should docket information provided during two conference calls regarding pipe segments that provide structural support.

2.2 IDENTIFICATION OF STRUCTURES AND COMPONENTS SUBJECT TO AGING MANAGEMENT REVIEW (CONT.)

Licence Renewal Issues

- 98-0012 - Consumables
- 98-0082 - Cascading
- 98-0105 - Heat exchanger function

Items of Interest

- System flow diagrams

3.1 APPLICABLE AGING EFFECTS FOR MECHANICAL COMPONENTS

Open Items

- The aging effects discussed and accepted by the staff were not consistently applied by the applicant in the system specific discussions of aging effects.
- The full scope of buried piping and applicable aging management programs could not be identified and evaluated by the staff.

Confirmatory Items / License Renewal Issues

- None

Items of Interest

- The applicant has performed a comprehensive review of aging effects and exhaustive identification of aging effects.

3.2 COMMON AGING MANAGEMENT PROGRAMS

- Boric Acid Wastage Surveillance Program
- Chemistry Control Program
- Duke Quality Assurance Program

Open Item

Commitment needed in either Quality Assurance Program or Updated Final Safety Analysis Report Supplement to apply requirements for corrective actions, confirmation processes, and document control to non-safety related structures and components subject to aging management review.

- Fire Protection Program
- Inservice Inspection Plan

3.2 COMMON AGING MANAGEMENT PROGRAMS (CONT.)

- **Inspection Program for Civil Engineering Structures & Components**
- **Reactor Coolant System Operational Leakage Monitoring**
- **Cast Iron Selective Leaching Inspection**
- **Galvanic Susceptibility Inspection**
- **Preventive Maintenance Activity Assessment**
- **Treated Water Systems Stainless Steel Inspection**

3.2 COMMON AGING MANAGEMENT PROGRAMS (CONT.)

- Heat Exchanger Performance Testing Activities

Open Items

Justify why the temperature difference across the standby shutdown facility (SSF) heat exchanger (HX) is not measured.

For decay heat removal coolers, reactor building cooling units, and SSF HXs, provide the acceptance criteria for performance testing, provide the basis for such criteria to meet heat transfer demand on normal and accident conditions, and provide/justify criteria to initiate corrective action.

3.2 COMMON AGING MANAGEMENT PROGRAMS (CONT.)

- **Service Water Piping Corrosion Program**

Open Items

Explain how loss of material is managed for components other than carbon steel (e.g., copper, brass, ductile iron).

Basis for inspections of carbon steel components to serve as leading indicator for conditions of other materials susceptible to different corrosive mechanisms such as pitting and microbiologically influenced corrosion (MIC).

Program does not include inspection of Keowee systems. Justify how components in the Keowee systems are bounded by overall program results.

Justify the use of ultrasonic testing for detecting and sizing localized corrosion in stainless steel.

3.2 COMMON AGING MANAGEMENT PROGRAMS (CONT.)

License Renewal Issues

- None

Items of Interest

- None

3.3 CONTAINMENT STRUCTURES

Open Items

- Lack of aging management program to manage the aging effects on tendon galleries.

Confirmatory Items

- None

License Renewal Issues

- 98-0048 - Tendons
- 98-0049 - Inaccessible Areas
- 98-0052 - Operating Experience (IWE/IWL)
- 98-0057 - Maintenance Rule/Structure
- 98-0087 - Shield Wall Temperature

3.3 CONTAINMENT STRUCTURES (CONT.)

Items of interest

- TLAA for liner and penetration fatigue
- TLAA for post-tensioning tendon forces

3.4 REACTOR COOLANT SYSTEM

Use of B&WOG Topicals.

Aging Effects - Open Items

- Identify that aging effects for pressurizer spray head are cracking and reduction in fracture toughness due to thermal aging of cast stainless steel (CASS).
- Provide basis that void swelling is not an issue or provide an aging management program.

Aging Management Programs - Open Items

- Expand scope of inspection of Unit 1 pressurizer to include Alloy 600 heater sheath-to-sleeve plate and heater sleeve-to-bundle diaphragm plate. State when heater bundle will be removed for examination and basis for scheduling.

3.4 REACTOR COOLANT SYSTEM (CONT.)

Aging Management Programs - Open Items (Cont.)

- Provide assessment to ensure repaired letdown coolers are operating to preclude failure from thermal fatigue.
- Evaluate CASS components to criteria in EPRI TR-106092 and additional criteria in SER.
- Identify and include limiting wrought stainless steel non-bolting components and welds in internals in ISI program.
- Provide plan to manage aging of baffle-former bolts.
- For loss of fracture toughness from synergistic thermal and neutron embrittlement, perform supplemental examinations/evaluations of CASS internals. Provide estimates of fluence for each CASS component at end of license renewal term, method of determining, justification.

3.4 REACTOR COOLANT SYSTEM (CONT.)

Aging Management Programs - Open Items (Cont.)

- Applicant to submit Pump & Valve In-Service Test Program for staff to determine whether supplemental examination is necessary for vent valve bodies and retaining rings.

Confirmatory Items

- None

License Renewal Issues

- 98-CC30 - Thermal aging of CASS
- 98-0085 - Vessel surveillance
- 98-0103 - Internals embrittlement

Items of Interest

- None

3.5 ENGINEERED SAFETY FEATURES SYSTEMS

Open Items

- None

Confirmatory Items

- Requested documentation that provides the bases for considering the results of the reactor building spray system inspection applicable to the nitrogen purge and blanketing system.

License Renewal Issues

- None

Items of Interest

- One-time inspection of the reactor building spray system planned before the end of the current operating license.

3.6 AUXILIARY SYSTEMS

Open Items

- No identification of vibrational loading as causing aging effects for the HVAC system (e.g., cracking and loosening of fasteners).
- Basis for the acceptability of the scope of the reactor coolant pump motor oil collection system inspection.
- Basis for the acceptability of the frequency of sampling for the Keowee oil sampling program.

Confirmatory Items

- Documentation of operating experience relative to system performance testing.
- Documentation of bases for acceptance criteria for the Keowee oil sampling program.

3.6 AUXILIARY SYSTEMS (CONT.)

License Renewal Issues

- None

Items of Interest

- Two one-time inspections planned before the end of the current operating license (reactor coolant pump motor oil collection system and Keowee air and gas systems inspections).

3.7 STEAM AND POWER CONVERSION SYSTEMS

Open Items

- None

Confirmatory Items

- None

License Renewal Issues

- None

Items of Interest

- Piping Erosion/Corrosion Program

3.8 STRUCTURES AND COMPONENT SUPPORTS

Scope of review

- **Auxiliary Building**
- **Earthen Embankments**
- **Intake Structure**
- **Keowee structures**
- **Reactor Building internal structure & vent stack**
- **Turbine Buildings**
- **Yard structures**
- **Class 1 component supports**

3.8 STRUCTURES AND COMPONENT SUPPORTS (CONT.)

Open Items

- Aging effects of 183°F temperature on spent fuel pool concrete (cracking and change in properties).
- Identification of applicable aging effects should consider results of Oconee baseline inspection and instances of the reported unusual events (e.g., spent fuel pool liner water leakage).
- Secondary shield wall tendon forces should be monitored for the extended period of operation.
- Inconsistent treatment of aging effect (loss of material) for cable trays and conduits located inside and outside the Oconee containment.

3.8 STRUCTURES AND COMPONENT SUPPORTS (CONT.)

Confirmatory Items

- None

License Renewal Issues

- 98-0057 - Maintenance Rule/Structure
- 98-0100 - FERC Dams

Items of Interest

- None

3.9 ELECTRICAL COMPONENTS

Open Items

- None

Confirmatory Items

- None

License Renewal Issues

- 98-0016 - Fuses

Items of Interest

- None

4.0 TIME-LIMITED AGING ANALYSES

Duke identified the following as TLAAAs:

- Fatigue analyses for the containment liner plate and penetration
- The loss of prestress in the containment post-tensioning system
- Fatigue and fracture mechanics analyses for ISI reportable indications in the reactor coolant system and Class 1 components
- Neutron embrittlement of the beltline region of the reactor pressure vessel (RPV), including analyses for pressurized thermal shock and Charpy upper-shelf energy reduction. Also, intergranular separation in the heat-affected-zone (HAZ) of low alloy steel under austenitic stainless steel cladding.
- Flow-induced vibration, transient cycle count assumptions, and ductility reduction of fracture toughness for the reactor vessel internals

4.0 TIME-LIMITED AGING ANALYSES (CONT.)

Duke identified the following as TLAAAs (Cont.):

- **Fatigue analysis of the reactor coolant pump flywheel**
- **Fatigue analyses for mechanical components**
- **Environmental qualification of electrical equipment**
- **Fatigue analysis of the polar crane**
- **Aging evaluation of Boraflex in the spent fuel rack**

4.0 TIME-LIMITED AGING ANALYSES (CONT.)

4.2.1 Containment Liner Plate And Penetrations

Open Items

- Provide discussion of the cumulative effects of all possible cycles in the fatigue analysis

Confirmatory Items

- Applicant should note that the performance-based Option B allows the 10-year frequency if previous leak rate tests had no problems. Additional leak rate tests may have to be performed after any major modifications (e.g. steam generation replacement).

License Renewal Issues

- None

4.0 TIME-LIMITED AGING ANALYSES (CONT.)

4.2.1 Containment Liner Plate And Penetrations (Cont.)

Items of Interest

- Containment leakage testing program
- Containment ISI Plan

4.0 TIME-LIMITED AGING ANALYSES (CONT.)

4.2.2 Containment Post Tensioning System

Open Items

- The trend lines that would demonstrate the adequacy of the existing prestressing forces in the containment tendons have not been shown by the applicant for the period of extended operation.

Confirmatory Items

- None

License Renewal Issues

- 98-0048 - IWE/IWL: Tendons

Items of Interest

- Containment ISI plan

4.0 TIME-LIMITED AGING ANALYSES (CONT.)

4.2.3 Fatigue Analysis of Reactor Coolant System (RCS)

Open Items

- TLAA of RCS is not adequate to address fatigue concerns for operation beyond 40-years (GSI-190).
- Corrective actions regarding the Section XI flaw evaluation.

Confirmatory Items

- Completion of (1) emergency feedwater nozzle analysis; (2) Class I analysis of the attached piping to the first isolation valve; (3) revised response to NRC Bulletin 88-08 by July 1, 2000.

License Renewal Issues

- 98-0028 - Fatigue of Metal Components

4.0 TIME-LIMITED AGING ANALYSES (CONT.)

4.2.3 Fatigue Analysis of Reactor Coolant System (Cont.)

Items of Interest

- None

4.0 TIME-LIMITED AGING ANALYSES (CONT.)

4.2.4 Reactor Neutron Embrittlement and Underclad Cracking

Open Items

- None

Confirmatory Items

- None

License Renewal Issues

- 98-0085 - Vessel Surveillance

4.0 TIME-LIMITED AGING ANALYSES (CONT.)

4.2.4 Reactor Neutron Embrittlement and Underclad Cracking (Cont.)

Items of Interest

- Pressurized Thermal Shock
- Charpy Upper Shelf Energy
- Underclad Cracking
- Pressure-Temperature Limits

4.0 TIME-LIMITED AGING ANALYSES (CONT.)

4.2.5 Reactor Vessel Internals

Open Items

- Plan to develop data to demonstrate that the internals will meet the deformation limits.
- Applicant did not address the applicability of flaw growth acceptance in accordance with the ASME B&PV code, Section XI ISI requirements.

Confirmatory Items

- None

License Renewal Issues/Items of Interest

- None

4.0 TIME-LIMITED AGING ANALYSES (CONT.)

4.2.6 Fatigue of Reactor Coolant Pump Flywheel

Open Items

- None

Confirmatory Items

- None

License Renewal Issues

- None

Items of Interest

- None

4.0 TIME-LIMITED AGING ANALYSES (CONT.)

4.2.7 Fatigue Analysis of Class II and Class III Components

Open Items

- None

Confirmatory Items

- None

License Renewal Issues

- None

Items of Interest

- None

4.0 TIME-LIMITED AGING ANALYSES (CONT.)

4.2.8 Environmental Qualification of Electrical Equipment

Open Items

- None

Confirmatory Items

- None

License Renewal Issues

- 98-0014 - Environmental Qualification (EQ) TLAA

Items of Interest

- Oconee evaluated the EQ TLAA while Calvert Cliffs provided a process description of the EQ TLAA.

4.0 TIME-LIMITED AGING ANALYSES (CONT.)

4.2.9 Fatigue of Polar Crane

Open Items

- None

Confirmatory Items

- None

License Renewal Issues

- None

Items of Interest

- None

4.0 TIME-LIMITED AGING ANALYSES (CONT.)

4.2.10 Aging of Boraflex in Spent Fuel Racks

Open Items

- None

Confirmatory Items

- None

License Renewal Issues

- None

4.0 TIME-LIMITED AGING ANALYSES (CONT.)


4.2.10 Aging of Boraflex in Spent Fuel Racks (Cont.)

Items of Interest

- **Boraflex Monitoring Program:**
 - Visually inspects Boraflex coupons.
 - Monitors gap formation in Boraflex panels by blackness testing.
 - Monitors future performance of Boraflex by measuring silica in the spent fuel pool and using the RACKLIFE computer code.



Oconee License Renewal Project




Presentation to:
Advisory Committee on
Reactor Safeguards –
Plant License Renewal
Subcommittee

June 30, 1999



Oconee License Renewal Project



Presentation to:

Advisory Committee on
Reactor Safeguards -
Plant License Renewal
Subcommittee

June 30, 1999



Presentation Overview

■ Morning Session

- ♦ Introduction
- ♦ Reactor Vessel Topical Report BAW-2251 Overview

■ Afternoon Session

- ♦ Application Integrated Plant Assessment and Time Limited Aging Analysis Overview

June 30, 1999

Oconee License Renewal Project

2



Presentation Participants

■ Morning Session

- ♦ Greg Robison (Duke Energy)
- ♦ Mark Rinckel (FTI)
- ♦ Matthew Devan (FTI)
- ♦ Ken Yoon (FTI)
- ♦ Bob Gill (Duke Energy)

■ Afternoon Session

- ♦ Paul Colianni (Duke Energy)

June 30, 1999

Oconee License Renewal Project

3



Current Project Status

■ Safety

- Responses to 324 RAIs completed 2/17/99
- Safety Evaluation Report issued 6/16/99

■ Environmental

- Responses to 39 RAIs completed 3/3/99
- Draft Oconee Supplemental Environmental Impact Statement issued 5/20/99

■ Hearings

- The Chattooga River Watershed Coalition petitioned to intervene in 8/98
- The Atomic Safety and Licensing Board denied petition in 12/98
- The Chattooga River Watershed Coalition appealed the Atomic Safety and Licensing Board decision to the NRC Commission in 1/99
- The NRC Commission affirmed the Board decision to deny the petition on 4/15/99

June 30, 1999

Oconee License Renewal Project

7



License Renewal Technical Information

■ Integrated Plant Assessment Process

$$C + A + P + D = R.A.$$

C = Component
A = Aging Effects
P = Program
D = Demonstration
R.A. = Reasonable Assurance

■ Time-limited Aging Analysis and Exemption Reviews

- 40 year boundary conditions established in the licensing basis of the plant

June 30, 1999

Oconee License Renewal Project

8



License Renewal Technical Information

■ The Integrated Plant Assessment (IPA) and Time-limited aging analysis (TLAA) activities associated with plant components are divided along discipline function lines:

- Reactor Coolant System (B&WOG Reports fit here)
- Reactor Building Containment
- Mechanical
- Electrical
- Structural

June 30, 1999

Oconee License Renewal Project

9



Plant Description

- Oconee Nuclear Station is a 3 Unit Site - 2538 MW total
- Construction finished in early 1970's
- Initial capital cost was approximately \$500 million
- Commercial operation began in
 - ♦ 1973 - Units 1 & 2
 - ♦ 1974 - Unit 3
- Initial licenses expire in 2013 and 2014
- About 1300 people are employed at Oconee


June 30, 1999

Oconee License Renewal Project

4



Oconee Nuclear Station Photograph



June 30, 1999

Oconee License Renewal Project

5



Oconee License Renewal Background

	1985	1990	1995	Today
Industry	<ul style="list-style-type: none">• Technical Reports• Lead plant reviews• Scientific perspective• Aging mechanisms	<ul style="list-style-type: none">• Owners Groups• RGAE• 10 CFR 54 and GEIS issued by NRC	<ul style="list-style-type: none">• Application guide• NRC/Utility Demos• Engineering perspective• Aging effects	
Duke	<ul style="list-style-type: none">• Industry Participant• Leader in Technical Report development	<ul style="list-style-type: none">Oconee License Renewal Team<ul style="list-style-type: none">• Formed - 1992• Designed Oconee LR Solution• Active in Owners Groups and Industry efforts• July 6, 1998 Application Submittal		

June 30, 1999

Oconee License Renewal Project

6



Reactor Coolant System Components

- Reactor Coolant System Piping (Safety Evaluation 3/21/96)
- Pressurizer (Safety Evaluation 8/18/97)
- Reactor Vessel (Safety Evaluation 4/26/99) → BAW-2251
- Reactor Vessel Internals (Draft Safety Evaluation 5/26/99)
- Once Through Steam Generator
- Class 1 Component Supports
- Reactor Coolant Pumps
- CRDM Pressure Boundary

June 30, 1999

Oconee License Renewal Project

10



Reactor Vessel Topical Report BAW-2251 Overview



B&WOG Reactor Vessel Topical Report (BAW-2251)

Topics

- Participating Plants
- Contents of RV Report
 - ◆ Scope
 - ◆ Aging Effects
 - ◆ Demonstration of Aging Management
 - ◆ Time Limited Aging Analyses
- Conclusions

June 30, 1999

Oconee License Renewal Project

12



B&W Owners Group Participating Plants

- ANO-1; Oconee 1, 2, and 3; and TMI-1
- All plants similar in design and age
- B&W designed 177 FA lowered loop plants
- Operating licenses expire between 2013 to 2016

June 30, 1999

Oconee License Renewal Project

13



Reactor Vessel Report Contents

- Define component intended function(s) that must be protected for period of extended operation (pressure boundary and support of reactor vessel internals)
- Provide description of component including materials of construction
- Define applicable aging effects for material, environment, and stress (Level A and B Service Conditions)
- Determination that aging effects are managed—Credit regulated program: (e.g., ASME Section XI)
- Evaluate applicable Time Limited Aging Analyses (e.g., Fatigue, and Irradiation Embrittlement)

June 30, 1999

Oconee License Renewal Project

14




Reactor Vessel Report Scope

- Vessel designed in accordance with ASME Section III, 1965 Edition, Addenda through Summer 1967
- Describe RV items in accordance with ASME Section XI, Subsection IWB, Examination Categories
 - ◆ RV Shell and Closure Head
 - ◆ RV Nozzles – Inlet/Outlet, Core Flood, IMS, and CRDM
 - ◆ RV Interior Attachments – Core Guide Lugs
 - ◆ RV Pressure – Retaining Bolted Closures (Closure Studs, CRDM Housing Flange Bolting)


June 30, 1999

Oconee License Renewal Project

15




Reactor Vessel Shell and Closure Head



June 30, 1999

Oconee License Renewal Project

16



Reactor Vessel (RV) Aging Effects


RV Shell and Closure Head

- Cracking at Welded Joints (Growth Pre-Service Flaws and Fatigue-TLAA)
- Loss of External Material Near Bolted Closures Owing to Boric Acid Wastage
- Reduction Fracture Toughness Beltline Region (TLAA)
- Growth of Intergranular Separations (A508 Class 2 forgings-TLAA)


June 30, 1999

Oconee License Renewal Project

17



Reactor Vessel Shell Unit 2




June 30, 1999

Oconee License Renewal Project

18

Intergranular Separations



June 30, 1999

Oconee License Renewal Project

19

Reactor Vessel (RV) Aging Effects (continued)

■ RV Nozzles

- ◆ Clad Low-Alloy Steel—Cracking at welded joints, cracking at inside nozzle radius, and loss of external material
- ◆ Alloy 600 (CRDM and IMS)—cracking at or near the HAZ

■ RV Interior Attachments

- ◆ Alloy 600 Guide Lugs—cracking at or near the attachment welds

■ RV Pressure-Retaining Bolted Closures

- ◆ Loss of Mechanical Closure Integrity (loss of material, cracking, stress relaxation)

June 30, 1999

Oconee License Renewal Project

20

Generic Aging Management Programs

- ASME Section XI, Subsection IWB, 1989 Edition (Appendices VII and VIII)
- BWOG Reactor Vessel Integrity Program (Compliance with 10 CFR 50.60 and 10 CFR 50.61)
- Technical Specifications (P-T Limits, Chemistry, Leakage Limits)
- Commitments to NRC Generic Communications (GL88-05, BL82-02)
- GL 97-01 Concerning Vessel Head Penetrations--Alloy 600

June 30, 1999

Oconee License Renewal Project

21



Generic Time-Limited Aging Analyses

- Thermal Fatigue
- Compliance with 10 CFR 50.60 and 10 CFR 50.61 (MIRVP)
 - ◆ RT_{PTS} to 48 EFPY (10 CFR 50.61)
 - ◆ Upper-Shell Energy (10 CFR 50.60)
- Growth of Intergranular Separations
- Flaw growth acceptance in accordance with ASME Section XI ISI (plant-specific)

June 30, 1999

Oconee License Renewal Project

22



Thermal Fatigue

- Approach for License Renewal
 - ◆ Summarize cumulative usage factors for all Class 1 components—including applicable design transients (e.g., heatups and cooldowns)
 - ◆ Determine if current number of design transients valid for the period of extended operation
 - ◆ Assess impact of environmental-assisted fatigue—if required

June 30, 1999

Oconee License Renewal Project

23



Summary of Fatigue Design Basis

- Matrices prepared summarizing usage factors and applicable Level A and B transients for all R&W designed Class 1 components
- Controlling transients identified as:
 - ◆ Heatups and Cooldowns
 - ◆ Reactor Trips
 - ◆ HPI Actuations
 - ◆ EFW Actuations
 - ◆ Rapid Cooldowns
 - ◆ NC Cooldowns

June 30, 1999

Oconee License Renewal Project

24



Projection of Accrued Cycles

- For controlling transients, assessment made as to number of transients accrued to date for each plant
- Information sources included plant-specific transient logs, transient data, TAP reports, etc
- Projection of controlling transients made to end of period extended operation
- For RV--current design cycles acceptable for period of extended operation

June 30, 1999

Oconee License Renewal Project

25



Thermal Fatigue

- Demonstrated that existing usage factors, w/exception of ONS studs, remain valid for period of extended operation. ONS studs (CUF=1.04) to be addressed by ONS at time of application.
- Demonstration performed by identification of controlling design transients and projection to end of period of extended operation.
- Program in place at utilities to monitor occurrences of design transients.
- NRC position that environmental assisted fatigue (EAF) should be evaluated for license renewal--not a current day issue.
- EAF evaluated for limiting RV items (CUF < 1.0)

June 30, 1999

Oconee License Renewal Project

26



Generic Time-Limited Aging Analyses

- Thermal Fatigue
- Compliance with 10 CFR 50.60 and 10 CFR 50.61 (MIRVP)
 - ◆ Upper Shelf Energy (10 CFR 50.60)
 - ◆ RT_{PT5} to 48 EFPY (10 CFR 50.61)
- Growth of Intergranular Separations

June 30, 1999

Oconee License Renewal Project

27



Master Integrated Reactor Vessel Surveillance Program (MIRVP) – NRC Requirements

- 10 CFR 50.60 Acceptance Criteria for Fracture Prevention Measures for Lightwater Nuclear Power Reactors for Normal Operation
 - ◆ 10 CFR 50 Appendix G Fracture Toughness Requirements
 - ◆ 10 CFR 50 Appendix H RV Material Surveillance Program
- 10 CFR 50.61 Fracture Toughness Requirements for Protection Against Pressurized Thermal Shock Events

June 30, 1999

Oconee License Renewal Project

28



MIRVP – NRC Requirements

- 10 CFR 50 Appendix G
 - ◆ CVUSE not less than 50 ft-lbs (unless equivalent margin of safety per Section XI, Appendix G)
 - ◆ Pressure-temperature limits
 - ΔRT_{MDT} (Regulatory Guide 1.90, Revision 2)
- 10 CFR 50 Appendix H
 - ◆ ASTM E185
 - ◆ Approved withdrawal schedule
 - ◆ Integrated program rules
 - similar design and operating features
 - adequate dosimetry program
 - data sharing arrangement

June 30, 1999

Oconee License Renewal Project

29



B&W Fabricated Vessels

- Vessels designed by B&W and Westinghouse
- Material: Mn-Mo-Ni steels
 - ◆ Plate SA-302B (early)
 - ◆ Plate SA-533B (later)
 - ◆ Forgings A 506, Class 2
- Welds
 - ◆ Plate: axial and circumferential
 - ◆ Forgings: circumferential only
 - ◆ Automatic submerged arc (ASA)
 - ◆ Linde 80 flux: Low initial CVUSE
 - ◆ Copper-coated weld wire: Accelerated reduction of fracture toughness

June 30, 1999

Oconee License Renewal Project

30



B&W Fabricated Vessels

■ Weld Identification

- ◆ Each combination of wire heat and flux lot uniquely identified and qualified
- ◆ Welds identified by WF-numeral (qualified in Mount Vernon) or SA-numeral (qualified in Barberton)
- ◆ All weld seams traceable to a WF- or SA- identifier

■ Surrogate Welds

- ◆ Welds fabricated from the same wire heat, even if flux lots are different, have equivalent copper content and properties

June 30, 1999

Oconee License Renewal Project

31



Surveillance Capsules

■ Material

- ◆ Base and weld metal
- ◆ Early capsules: Weld metal not same WF/SA as in vessel beltline (requirement changed to same as limiting weld metal in later ASTM E185 Standard Editions)

■ Test Specimens

- ◆ Charpy V-notch impact, Tension Test, and Compact Fracture
 - No compacts in very early plant-specific capsules
 - 0.5T in some plant-specific capsules
 - 1T (round) in later B&W Owners Group capsules

■ Neutron Dosimeter Wires

■ Temperature Monitors—Fusible alloy wires

June 30, 1999

Oconee License Renewal Project

32



Reactor Vessel Integrity Program

- Established in 1977
- Resolve fracture toughness concerns with Linde 80 ASA weld metal
- Original participant plants (B&W-designed): ANO-1; Crystal River-3; Davis-Besse; Oconee-1, -2, and -3; Rancho Seco; TMI-1 and -2
- Later participant plants (Westinghouse-designed): R. E. Ginna; Point Beach-1 and -2; Surry-1 and -2; Turkey Point-3 and -4; and Zion-1 and -2

June 30, 1999

Oconee License Renewal Project

33



Reactor Vessel Integrity Program

- Obtain materials and irradiation effects data
- Develop test methods and analytical procedures for determination of fracture toughness
- Provide effective communication
 - ◆ Among all owners
 - ◆ With NRC
 - ◆ With industry groups

June 30, 1990

Oconee License Renewal Project

34



Master Integrated Reactor Vessel Surveillance Program (MIRVP)

- Plant-specific capsules had deficiencies:
 - ◆ Limiting materials not in plant-specific capsules
 - ◆ Fracture toughness specimens not in plant-specific capsules
- Adding to the plant-specific RVSP irradiation capsules, 14 capsules were fabricated and inserted in power reactors

June 30, 1990

Oconee License Renewal Project

35



Master Integrated Reactor Vessel Surveillance Program (MIRVP)

- B&W kept nozzle dropouts which contain a weld seam. This was the only remaining source of many beltline weld materials. These nozzle dropout weld materials were used to fabricate specimens for irradiation in the 14 capsules.
- Report BAW-1543 describes the MIRVP and is revised regularly to reflect program changes. NRC issued SER accepting the program. Requests for information in the SER were answered with no further NRC comment.

June 30, 1990

Oconee License Renewal Project

36



MIRVP Current Activities

- Post-irradiation testing of the W1 Capsule has been completed. The W1 Capsule provides Linde 80 weld metal data irradiated in a Westinghouse-designed reactor. Evaluation of the irradiated data for Capsule W1 and the other MIRVP capsules containing the same weld materials is currently being performed as part of the 1999 B&WOG Reactor Vessel Integrity Program.
- Post-irradiation testing and evaluation of the A5 Capsule has been completed. The A5 Capsule contained previously irradiated/reconstituted Charpy impact specimens to acquire high-fluence information.

June 30, 1999

Oconee License Renewal Project

37



Reactor Vessel Beltline Fluence

- Fluence of RV Beltline Region at 48 EFPY used to calculate RT_{PTS} and USE
- Fluence monitoring using calculational-based methodology and cavity dosimetry
- Uncertainties in fluence estimates addressed through BAW-2241
- Plant-specific monitoring and updates to ensure evaluations in BAW-2251 remain valid

June 30, 1999

Oconee License Renewal Project

38



General Time-Limited Aging Analyses

- Thermal Fatigue
- Compliance with 10 CFR 50.60 and 10 CFR 50.61 (MIRVP)
 - ♦ RT_{PTS} to 48 EFPY (10 CFR 50.61)
 - ♦ Upper-Shelf Energy (10 CFR 50.60)
- Growth of Intergranular Separations

June 30, 1999

Oconee License Renewal Project

39



RT_{PTS} to 48 EFPY (10 CFR 50.61)
Appendix A to BAW-2251

- Demonstrated that RT_{PTS} values at 48 EFPY comply with requirements of 10 CFR 50.61 using Regulatory Guide 1.99 Revision 2
- RT_{PTS} welds all participating units were calculated to be below PTS limits, with exception of weld WF-25 in Oconee Unit 2 RV and one weld at another plant
- Subsequent plant-specific analyses performed for Oconee Unit 2 result in RT_{PTS} of 296.8 °F

June 30, 1999

Oconee License Renewal Project

40



Low Upper-shelf Toughness
Fracture Mechanics Analysis

- Analysis Methods and Acceptance Criteria
 - ◆ Appendix K, Section XI
 - ASME Boiler & Pressure Vessel Code
 - ◆ Technical Basis
 - Welding Research Council Bulletin 413, July 1996
 - "Development of Criteria for Assessment of Reactor Vessels with Low Upper Shelf Fracture Toughness"

June 30, 1999

Oconee License Renewal Project

41



Low Upper-shelf Toughness
Fracture Mechanics Analysis

- All four Owners Groups completed this analysis for all reactor vessels for 40 year design life
- B&W Owners Group Report BAW-2275 addresses low upper-shelf toughness fracture mechanics analysis of B&W designed reactor vessels for 48 EFPY

June 30, 1999

Oconee License Renewal Project

42



Low Upper-shelf Toughness Fracture Mechanics Analysis

■ Acceptance Criteria

◆ Service Levels A and B:

- Flaw depth $a = 1/4$ interior semi-elliptical surface flaw
- Applied J for pressure equals 1.15 times P_a and thermal load:
 $< J$ material at $da = 0.1$ inch

- Flaw extension at J for pressure equals 1.25 times P_a and thermal load shall be ductile and stable
- J material shall be conservative representation for the vessel material under evaluation

June 30, 1990

Oconee License Renewal Project

43



Low Upper-shelf Toughness Fracture Mechanics Analysis

◆ Service Level C:

- Flaw depth $a = 1/10$ interior semi-elliptical flaw
- Applied $J < J$ material at $da = 0.1$ inch
- Flaw extensions shall be ductile and stable using $SF = 1.0$
- J material shall be conservative representation for the vessel material

◆ Service Level D:

- Same as Level C above except J material shall be a best estimate representation of the vessel material


June 30, 1989

Oconee License Renewal Project

44



Low Upper-shelf Toughness Fracture Mechanics Analysis



June 30, 1989

Oconee License Renewal Project

45



Low Upper-shelf Toughness Fracture Mechanics Analysis

■ Analysis Results

- ◆ All participating B&W Owners Group Reactor Vessels were found acceptable by the acceptance criteria of ASME Section XI, Appendix K

June 30, 1999

Oconee License Renewal Project

46



Generic Time-Limited Aging Analyses

- Thermal Fatigue
- Compliance with 10 CFR 50.60 and 10 CFR 50.61 (MIRVP)
 - ◆ Upper-Shelf Energy (10 CFR 50.60)
 - ◆ RT_{PTS} to 48 EFPY (10 CFR 50.61)
- Growth of Intergranular Separations

June 30, 1999

Oconee License Renewal Project

47



Intergranular Separations-- Appendix C to BAW-2251

- Demonstrated acceptability growth of postulated flaws to 48 EFPY using ASME Section XI (1989 Edition), IWB-3612, acceptance criteria
- Linear elastic fracture mechanics
- For Service Levels A through D, the analytical results demonstrate sufficient margin beyond that required by the acceptance criteria of IWB-3612

June 30, 1999


Oconee License Renewal Project

48

Duke Power.
A Duke Energy Company

Fracture Mechanics Analysis of Underclad Cracks
Postulated Cracks

- Postulated Cracks in SA-508 Class 2 Materials in Reactor Vessels



June 30, 1999 Oconee License Renewal Project 49

Duke Power.
A Duke Energy Company

Fracture Mechanics Analysis of Underclad Cracks
Section XI Flaw Evaluation

- ASME B & PV Code K_{Ic} and K_{Ia}
- Regulatory Guide 1.99 RT_{NDT}
- ASME Section XI, Appendix A Fatigue Crack Growth
- Raju Newman K_I Equations

June 30, 1999 Oconee License Renewal Project 50

Duke Power.
A Duke Energy Company

Fracture Mechanics Analysis of Underclad Cracks
Postulated Cracks

- Normal and Upset Condition – 19 Transients
- Design Basis Transients from Functional Specification
- Stresses in Selected Regions (Figure 3-3 in Appendix C of BAW-2251)
- 5 Fatigue Groups

June 30, 1999 Oconee License Renewal Project 51



Fracture Mechanics Analysis of Undercired Cracks
Conclusions

- Postulated flaws are found acceptable per Section XI Flaw Evaluation Procedures for:
 - ◆ 48 EFPY fluence
 - ◆ Design base transients and duty cycles

June 30, 1990

Oconee License Renewal Project

52



**Overall BAW-2251
Conclusions**

- Demonstrated that aging of the RV will be adequately managed to ensure component intended function(s) during the period of extended operation (40 to 60 years) — AMR and TLAA
- The RV report has been built on experience and methodologies developed over past 20 years in responding to RV issues as well as aging management review experience gained on RCS piping and pressurizer reports
- License renewal applicants must comply with LR applicant action items when referencing the reports

June 30, 1990

Oconee License Renewal Project

53



Incorporation of BAW-2251
into the
Oconee Application for
Renewed Operating Licenses



Incorporation of BAW-2251 into the Oconee Application

Topics

- Oconee Application for Renewed Operating Licenses
- Process to Incorporate All Approved B&WOG Topicals into the Application
- BAW-2251 Renewal Applicant Action Items and Oconee-specific responses
- Aging Management Programs for the Oconee Reactor Vessels
- Time-Limited Aging Analyses for the Oconee Reactor Vessels

June 30, 1999

Oconee License Renewal Project

55



Oconee Application for Renewed Operating Licenses

- Section 2.4.5 describes the Reactor Vessel Components that are Subject to Aging Management Review
- Section 3.4.5 Identifies the Applicable Aging Effects for these Components
- Aging Management Programs are described in Chapter 4
- Section 5.4 Identifies and Provides the Evaluations of the RCS Time-Limited Aging Analysis
- Approved B&WOG Topical Reports are referenced in each of these locations of the Application

June 30, 1999

Oconee License Renewal Project

56



Renewal Applicant Action Items for BAW-2251

- Presented Item-by-Item in a two-column format
- Oconee-specific response to BAW-2251 Items were provided by letter dated May 10, 1999
- For BAW-2251, there are 13 Renewal Applicant Action Items

June 30, 1999

Oconee License Renewal Project

57



Summary of Renewal Applicant Action Items for BAW-2251

- Verify that Oconee is bounded by the Topical Report
- Verify that Oconee programs and activities are the same as those credited within the Topical Report
- Perform the plant-specific TLAA identified
- Provide summary descriptions in the UFSAR Supplement

June 30, 1999

Oconee License Renewal Project

38



Aging Management Programs for the Oconee Reactor Vessels

- Reactor Vessel Integrity Program
 - Master Integrated Reactor Vessel Surveillance Program
 - Cavity Dosimetry Program
 - Fluence and Uncertainty Calculations
 - Pressure-Temperature Limit Curves
 - Effective Full Power Years
- CRDM and Other Vessel Closure Penetration Inspection Program
- Chemistry Control Program
- Alloy 600 Aging Management Program
- Inservice Inspection Plan
- Boric Acid Wastage Surveillance Program
- RCS Operational Leakage Monitoring
- Thermal Fatigue Management Program

June 30, 1999

Oconee License Renewal Project

59



Time-Limited Aging Analyses for the Oconee Reactor Vessels

- Thermal Fatigue
 - Managed by Thermal Fatigue Management Program
- Flaw Growth Analyses
 - One Oconee Unit 1 RV indication is being addressed
- Pressurized Thermal Shock
 - Fluence projection updated using BAW-2241P methods
 - Chemistry data updated using BAW-2325
 - RT PTS of all three Oconee vessels are less than screening criteria
- Charpy Upper Shelf Energy
 - Bounded by BAW-2751
- Intergranular Separation in HAZ
 - Bounded by BAW-2251

June 30, 1999

Oconee License Renewal Project

60



Oconee Reactor Vessel Conclusions

- Oconee Reactor Vessels are bounded by Topical Report BAW-2251
- Oconee programs will continue to effectively manage aging of the Reactor Vessels
- Plant-specific time-limited aging analyses have been evaluated for 60 years of operation

June 30, 1999

Oconee License Renewal Project

61



End of the Morning Session

June 30, 1999

Oconee License Renewal Project

62



Integrated Plant Assessment (IPA)
and
Time-Limited Aging Analysis (TLAA)
Overview



Oconee Integrated Plant Assessment (IPA)

■ Rule of Thumb:

- ♦ The discipline boundaries, with few exceptions, are as follows: if a component or parts of it carry electrical current, it is Electrical; if it supports, protects or restrains the movement of a component, it is Structural; everything else is Mechanical. Exceptions to this are noted where applicable.

■ Scoping components in each discipline:

- ♦ Structural - relies on Oconee CLB definition
- ♦ Mechanical - works through a functional review process
- ♦ Electrical - uses an encompassing approach

June 30, 1999

Oconee License Renewal Project

54



Oconee IPA & TLAA Reviews

- Reactor Coolant System Components
- Reactor Building Containment Components
- Structures & Structural Components
- Mechanical Components
- Electrical Components

June 30, 1999

Oconee License Renewal Project

55



Oconee IPA & TLAA Reviews

- IPA Scoping and Screening
 - ♦ Structures and Structural Components
 - ♦ Mechanical Systems and Components
 - ♦ Electrical Components
- IFA Aging Management Review
 - ♦ Structural/Mechanical/Electrical Components
- TLAA Reviews
- Programs and Activities Credited for License Renewal

June 30, 1999

Oconee License Renewal Project

56



Oconee Scoping & Screening Methodology

- Structural component and mechanical component methodologies are consistent with the guidance provided in NEI 95-10 Rev. 0.
- Electrical component methodology follows the §54 requirements and the guidance provided in the Statement of Considerations (SOC) published with the Final License Renewal Rule and is generally consistent with the guidance provided in NEI 95-10 Rev. 0.

June 30, 1999

Oconee License Renewal Project

67



Structure Scoping & Screening Methodology

- Structural scoping and screening Includes:
 - ◆ Identification of structures and structural components within the scope of the Rule and their intended functions
 - ◆ Identification of structures and structural components subject to an aging management review


June 30, 1999

Oconee License Renewal Project

68



Structure Scoping & Screening Process



June 30, 1999

Oconee License Renewal Project

69

Structure Scoping Summary (Example)

[illegible]

June 30, 1990

Oodoo License Renewal Project

70



Structure Scoping Results

- **Auxiliary Buildings** (Includes Spent Fuel Pools)
- **Earthen Embankments** (Includes Intake Canal Dike, Keowee Dam, Little River Dam and Dikes)
- **Intake Structure**
- **Keowee Structures** (Includes Breaker Vault, Intake Structure, Penstock, Power House, Service Bay Structure, and Spillway)
- **Reactor Buildings** (Includes Internal Structures and Unit Vents)
- **Standby Shutdown Facility**
- **Turbine Buildings** (Includes Switchgear Enclosures)
- **Yard Structures** (Includes 230 kV Relay House, Switchyard Structures, Trenches, Towers, Elevated Water Storage Tank, Transformer Pads)

June 30, 1999

Courtesy License Renewal Project

21



Structure / Component Matrix (Example)

[illegible]

June 30, 1929

Oocyte License Renewal Project

72



Mechanical Component Scoping Methodology

- Mechanical scoping and screening process includes:
 - ◆ Identification of systems within the scope of the Rule and their system intended functions
 - ◆ Identification of components subject to an aging management review and their component intended functions

June 30, 1999

Oconee License Renewal Project

73



Mechanical System §54.4(a)(1) and (a)(2) Scoping

- Mechanical §54.4(a)(1) and (a)(2) scoping was performed using a four-step process:
 1. Functional flow path identification using event mitigation calculations
 2. Fluid pressure boundary determination
 3. Physical interference identification
 4. Other designated item identification
- Evaluation boundaries are highlighted on mechanical system flow diagrams

June 30, 1999

Oconee License Renewal Project

74



Oconee License Renewal Mechanical Scoping Events Set

- | | |
|--------------------------------------------------------|--------------------------------------------------------------------------------------|
| ■ Loss of Main Feedwater (Scoping) | ■ Startup Accident (DBE) |
| ■ Loss of Offsite Power (LOOP) (DBE) | ■ Small Break Loss of Coolant Accident (DBE) |
| ■ Turbine Trip (DBE) | ■ Maximum Hypothetical Accident (DBE) |
| ■ Loss of Electric Power (DBE) | ■ Rod Ejection Accident (DBE) |
| ■ Large Break Loss of Coolant Accident with LOOP (DBE) | ■ Uncompensated Transient Reactivity Change (DBE) |
| ■ Steam Generator Tube Rupture (DBE) | ■ Waste Gas Tank Rupture (DBE) |
| ■ Main Steam Line Break (DBE) | ■ Rod Withdrawal Accident (DBE) |
| ■ Fuel Handling Accident (DBE) | ■ SSF Event Turbine Building Flood (Scoping) |
| ■ Moderator Dilution Accident (DBE) | ■ Natural Phenomena: Tornado, Wind & Hurricane (includes Tornado Missiles) (Scoping) |
| ■ Post Accident Hydrogen Control (DBE) | ■ Natural Phenomena: Seismic (Scoping) |
| ■ Control Rod Misalignment (DBE) | ■ Natural Phenomena: External Floods & Ground Water (Scoping) |
| ■ Cold Water Accident (DBE) | ■ Natural Phenomena: Snow & Ice (Scoping) |
| ■ Locked Rotor / Sheared Shaft (DBE) | |
| ■ Loss of Coolant Flow (DBE) | |

June 30, 1999

Oconee License Renewal Project

75



Mechanical System §54.4(a)(3) Scoping

- Mechanical systems which satisfy §54.4(a)(3) criteria were identified through review of licensing commitments for the regulated events.
 - ◆ Fire Protection
 - ◆ Environmental Qualification
 - ◆ Pressurized Thermal Shock
 - ◆ Anticipated Transient without Scram
 - ◆ Station Blackout

June 30, 1999

Oconee License Renewal Project

76



Mechanical Component Screening Process

- A menu of mechanical component commodity groups installed in the plant was developed, which included components identified in NEI 95-10 and components not listed in NEI 95-10.
- Using the "passive" and "long-lived" definitions and guidance, mechanical components meeting these screening criteria that are within the highlighted portions of the license renewal flow diagrams are identified and listed.
- This list identifies the mechanical components subject to aging management review.

June 30, 1999

Oconee License Renewal Project

77



Mechanical System Scoping Results

Oconee Systems

• Auxiliary Building Ventilation
• Auxiliary Service Water
• Breathing Air
• Chemical Addition
• Component Cooling
• Condensate
• Condenser Circulating Water
• Containment Hydrogen Control
• Control Room Pressurization and Filtration
• Coolant Storage
• Core Flood
• Demineralized Water
• Electro-Hydraulic Control
• Emergency Feedwater
• Feedwater
• Filtered Water
• Gaseous Waste Disposal
• High Pressure Injection
• High Pressure Service Water
• Instrument Air

• Leak Rate Test
• Liquid Waste Disposal
• Low Pressure Injection
• Low Pressure Service Water
• Lubrication
• Main Steam
• Nitrogen Purge and Blanket
• Penetration Room Ventilation
• Post Accident Monitoring
• Reactor Building Cooling
• Reactor Building Purge
• Reactor Building Spray
• Reactor Coolant
• Spent Fuel Cooling
• Turbine Building Sump
• Vacuum
SSE Systems
• Air Intake and Exhaust
• BSB Auxiliary Service Water
• Diesel Engine
• Diesel Jacket Water Cooling
• BSB Drinking Water

• BSB Fuel Oil
• Governor
• BSB HVAC
• Diesel Lube Oil
• Reactor Coolant Makeup
• BSB Sanitary Lift
• Starting Air
Kaurem Systems
• Carbon Dioxide
• Fire Protection/Detection
• Drying Air
• Drain
• Emergency Power
• Generator
• Generator High Pressure Oil
• Governor Air
• Governor Oil
• Main Turbine
• Service Water
• Turbine Generator Cooling Water
• Turbine Guide Bearing Oil
• Turbine Sump Pump

June 30, 1999

Oconee License Renewal Project

78



Identification of Electrical Component Commodity Groups

Alarm Units	Fuses	Motors	Relay/Control Operators
Analyses	Generators	Motor Control Centers	Solid-State Devices
Antennas	Heat Treating	Motors	Surge Arresters
Batteries	Insulators	Nonenergized Phase Bus	Switches
Chargers	Indicators	Power Distribution Panels	Switchgear
Circuit Breakers	Insulated Cables and	Power Supplies	Switchpoint Bus
Connectors	Connections	Relay/Control Modules	Thermocouples
Communication Equipment	Isolators	Recorders	Transformers
Electrical Controls and	Isolators	Regulators	Transmitters
Panel Interiors	Isolators Phase Bus	Relays	Transmission Conductors
Component Assemblies	Isolators	RTDs	Transmitters
Electrical Penetration	Light Bulbs	Segregated Phase Bus	Uninsulated Ground
Antennas	Load Centers	Sensors	Conductors
Elements	Long Conductors	Signal Conditioners	

June 30, 1999

Oconee License Renewal Project

82



Application of §54.21(a)(1)(i) Screening Criteria to Electrical Components

Reference Document	§54.21(a)(1)(i) Criteria are met	Electrical Component Commodity Groups
§54.21(a)(1)(i)	Yes	electrical cables and conductors (i.e., insulated cables and noninsulated conductors, unarmored ground conductors, electrical penetration assemblies, isolators, chargers (e.g., battery chargers), circuit breakers and transformers (i.e., solid state devices, loadable (i.e., circuit breaker) equipment (e.g., direct power transfer), indicators (e.g., pressure indicators, water level indicators), meters (e.g., power meters), motors, power supplies, relays, switches, switchgear, transformers (e.g., power transformers).
§54.21(a)(1)(i) Table 2.3.2 (applicable to §§ 54.21(a)(1)(i) and 54.21(a)(1)(i) respectively)	No	alarm units, analyses, antennas, connectors (e.g., relay/terminal), communication equipment, electrical controls and panel interior component assemblies, elements (e.g., conductivity elements, flow elements, meters, load centers, load controllers (e.g., differential pressure indicating controllers, flow indicating controllers, temperature controllers, speed controllers), motors (e.g., ammeters), motor control centers, power distribution panels, radiation monitors, recorders, RTDs, sensors (e.g., temperature sensors, radiation sensors), signal conditioners, solid-state operators, thermocouples, transmitters (e.g., cell transmitters).
September 15, 1987 (NRC letter to DOE)	No	heat treating, isolators, indicating lights (i.e., light bulbs), transformers.
Oconee License Renewal Application	Yes	insulators, isolated phase bus, nonenergized phase bus, segregated phase bus, switchgear, bus.
	No	communication equipment, buses, regulators, surge arresters.

*No in the second column indicates that the identified electrical component commodity groups are screened-out.

June 30, 1999

Oconee License Renewal Project

83



Listing Electrical Components Included in the AMR

Electrical Component Commodity Group	Included in the AMR	Intended Functions
Isolated Cables and Connections	An encompassing group of all isolated cables and connections except those (1) associated with the 500KV Ballyvaughan, Ballyvaughan Facility, or Oconee Reactor installation; (2) included in the (1) program; or (3) used for test detection is included in the AMR.	To electrically connect two portions of an electrical circuit.
Isolators	An encompassing group of all isolators except those associated with the (1) 500KV Ballyvaughan, (2) Oconee Cablebus, Oconee and Oconee 200KV Transmission Lines, or (3) Oconee Reactor installation is included in the AMR.	To isolate and support an electrical conductor.
Isolated Phase Bus	An encompassing group of all isolated phase bus is included in the AMR.	To electrically connect two portions of an electrical circuit.
Nonenergized Phase Bus	An encompassing group of all nonenergized phase bus is included in the AMR.	To electrically connect two portions of an electrical circuit.
Segregated Phase Bus	An encompassing group of all "group" phase bus is included in the AMR.	To electrically connect two portions of an electrical circuit.
Switchgear	An encompassing group of all switchgear except those associated with the (1) 500KV Ballyvaughan, (2) Oconee Cablebus, Oconee and Oconee 200KV Transmission Lines, or (3) the Oconee Reactor installation is included in the AMR.	To electrically connect two portions of an electrical circuit.
Transmission Conductors	An encompassing group of all transmission conductors except those associated with the (1) 500KV Ballyvaughan, (2) Oconee Cablebus, Oconee and Oconee 200KV Transmission Lines, or (3) the Oconee Reactor installation is included in the AMR.	To electrically connect two portions of an electrical circuit.

June 30, 1999

Oconee License Renewal Project

84



Oconee IPA & TLAA Reviews

- IPA Scoping and Screening
 - ◆ Structures and Structural Components
 - ◆ Mechanical Systems and Components
 - ◆ Electrical Components
- IPA Aging Management Review
 - ◆ Structural/Mechanical/Electrical Components
- TLAA Reviews
- Programs and Activities Credited for License Renewal

June 30, 1990

Oconee License Renewal Project

85



Oconee Aging Management Review Process

- Identify Component Materials
 - + Identify Component Environments
 - + Identify Potential Aging Effects
-
- = Determine Applicable Aging Effects
(those aging effects that if left unmanaged would cause a loss of intended function before the end of the extended period of operation)

June 30, 1990

Oconee License Renewal Project

86



Oconee IPA & TLAA Reviews

- IPA Scoping and Screening
 - ◆ Structures and Structural Components
 - ◆ Mechanical Systems and Components
 - ◆ Electrical Components
- IPA Aging Management Review
 - ◆ Structural/Mechanical/Electrical Components
- TLAA Reviews
- Programs and Activities Credited for License Renewal

June 30, 1990

Oconee License Renewal Project

87



Time-Limited Aging Analyses

- Involve plant-specific design analyses
- Focus on boundary conditions or assumptions based on 40-year operating term
- Action: Assure analyses are valid for the extended period of operation or that the effects of aging will be adequately managed for 60 years

June 30, 1999

Oconee License Renewal Project

86



Time-Limited Aging Analyses

- Oconee specific TLAA have been identified by reviewing the Oconee UFSAR, docketed correspondence and NSSS Topical Reports
- The resultant list includes EQ, fatigue, tendon loss of prestress, reactor vessel embrittlement, etc.
- No Oconee exemptions were based on TLAA
- The TLAA process is consistent with the guidance of NEI 95-10 and provides reasonable assurance that Oconee specific TLAA have been identified and evaluated

June 30, 1999

Oconee License Renewal Project

87




Oconee IPA & TLAA Reviews


- IPA Scoping and Screening
 - ◆ Structures and Structural Components
 - ◆ Mechanical Systems and Components
 - ◆ Electrical Components
- IPA Aging Management Review
 - ◆ Structural/Mechanical/Electrical Components
- TLAA Reviews
- Programs and Activities Credited for License Renewal


June 30, 1999

Oconee License Renewal Project

88









Oconee Safety Evaluation Report Open & Confirmatory Items

- 43 Open Items and 6 Confirmatory Items
- 28 of the 49 items are relatively straightforward to address
- 3 of the 49 items are related to the UFSAR Supplement
- 18 of the 49 items (5 topic areas) will require meetings:
 - ♦ Scoping Process and Results
 - ♦ Complex Assembly Boundaries
 - ♦ Consumables
 - ♦ CASS Components
 - ♦ RV Internals

June 30, 1999

Oconee License Renewal Project

84



Observations on Implementing the License Renewal Rule

- Develop clear definitions of terms
- Document alternate scoping and screening processes
- Develop a technically sound process for handling emerging issues

June 30, 1999

Oconee License Renewal Project

85
