

July 15, 1986

Radioisotope Licensing Branch  
USNRC - Region III  
799 Roosevelt Road  
Glen Elyn, Illinois

RE: Amendment to NRC License No. 24-24331-01

To Whom It May Concern:

We would like to amend our teletherapy license as follows:

Add Lily Ann Hanes, M.D. as an authorized user. Dr. Hanes was previously named on our license.

Move the Picker Co-60 unit to a new location within the current room. See the supporting documentation for details.

Please find enclosed a check in the amount of \$230.00 as specified in CFR part 170.31 category 7A.

Sincerely,

*David J. Keys, Ph.D.*

David J. Keys, Ph.D.  
Radiation Safety Officer

DJK:sjk

8702040541 B61022  
REG3 LIC30  
24-24331-01 PDR

Log	July 26
Remitted	3485
Check No.	3485
Amount	\$230
Fee Category	7A
Type of Fee	and
Date Check Rec'd.	
Date Completed	3/25/86
By:	

86 JUL 25 10:12

RECEIVED

RECEIVED

JUL 21 1986

REGION III

JUL 21 1986

NORTHWEST RADIATION ONCOLOGY  
CO-60 SHIELDING CALCULATIONS

Comment: Please see the accompanying drawing depicting the Co-60 Rx room. This room originally was designed to house a 20 MV linear accelerator. All walls unless otherwise specified are built of concrete.

Assumptions: The following assumptions apply to our calculations:  
Workload - 40000 R/wk at one meter (as recommended by NCRP Report 49, page 64)  
Max. Source Strength - 9000 RHM (max allowed by the manufacturer)  
Max. Field Size - 40 x 40 @ 80 cm  
Concrete Density - 147 lbs/ft<sup>3</sup>

Definitions:

- $d_{pri}$  = distance from the source to the point of interest
- $d_s$  = distance from the scatterer to the point of interest
- $d_l$  =  $d_{pri}$
- SSD = source to surface distance
- $t_c$  = thickness of concrete (cm)
- $T_x$  = transmission through the shielding; this value is determined from NCRP 49, page 102 or alternatively, by using a TVL of 20.6 cm of concrete
- $\dot{R}$  = exposure rate in mR/hr
- $\dot{R}_w$  = weekly exposure in mR/hr
- $a$  = ratio of the primary to scattered component within a patient
- $w$  = workload
- RHM = roentgen per hour at 1 meter
- $A$  = area of max field size = 1600 cm<sup>2</sup>
- $L$  = leakage radiation = 0.1% of RHM

Allowed Beam Directions: 30° in, 90° out  
30° CW, 30° CCW

Primary Walls: Walls along pts. B and C

## Equations:

## Primary Radiation

$$\dot{R} = RHM/(d_{pri})^2 \times T_x \times 1000 \text{ mR/R}$$

$$\dot{R}_w = w/(d_{pri})^2 \times T_x \times 2000 \text{ mR/R} = \dot{R} w/RHM$$

## Scattered Radiation

$$\dot{R} = RHM/(SSD)^2 \times a \times 1/(d_s)^2 \times T_x \times 1600/400 \times 1000 \text{ mR/R}$$

$$\dot{R}_w = \dot{R} w/RHM$$

## Leakage Radiation

$$\dot{R} = RHM/(d_l)^2 \times L \times T_x \times 1000 \text{ mR/R}$$

$$\dot{R}_w = \dot{R} w/RHM$$

LOCATION A - PHYSICS OFFICE

$$\begin{aligned}d_s &= 7.7 \text{ m} \\t_c &= 0.76 \text{ m} \\T_x &= 2.0 \times 10^{-4}\end{aligned}$$

Scatter

$$\begin{aligned}\dot{R} &= 9000/(0.8)^2 \times 0.001 \times 1/(7.7)^2 \times 2.0 \times 10^{-4} \times 1600/400 \times 1000 \text{ mR/R} \\&= 0.19 \text{ mR/hr}\end{aligned}$$

$$\dot{R}_w = 0.19 \times 40000/9000 = 0.84 \text{ mR/wk}$$

Leakage

$$\begin{aligned}\dot{R} &= 9000/(7.7)^2 \times 0.001 \times 2.0 \times 10^{-4} \times 1000 \text{ mR/R} \\&= 0.03 \text{ mR/hr}\end{aligned}$$

$$\dot{R}_w = 0.03 \times 40000/9000 = 0.13 \text{ mR/wk}$$

$$\text{Net } \dot{R} = 0.19 + 0.03 = 0.22 \text{ mR/hr}$$

$$\text{Net } \dot{R}_w = 0.84 + 0.13 = 0.97 \text{ mR/wk}$$

LOCATION B - CONSOLE AREA - CONTROLLED AREA

$$\begin{aligned}d_{\text{pri}} &= 7.32 \text{ m} \\t_c &= 122 \text{ cm} \\T_x &= 3 \times 10^{-6} \\ \dot{R} &= 9000/(7.32)^2 \times 3 \times 10^{-6} \times 1000 \text{ mR/R} = 0.5 \text{ mR/hr} \\ \dot{R}_w &= 2.0 \times 40000/9000 = 2.2 \text{ mR/wk}\end{aligned}$$

Because primary dominates scatter or leakage components by about 3 orders of magnitude, no scatter or leakage calculations are necessary.

LOCATION C - CLINAC 6 AREA

$$\begin{aligned}d_{\text{pri}} &= 6.7 \text{ m} \\t_c &= 6^1 = 1.83 \text{ m} \\T_x &= 8.88 \text{ TVL} = 1.32 \times 10^{-9} \\ \dot{R} &= 9000/(6.7)^2 \times 1.32 \times 10^{-9} \times 1000 \text{ mR/R} \\&= 0.0 \text{ mR/hr} \\ \dot{R}_w &= 0.0 \text{ mR/wk}\end{aligned}$$

LOCATION D - PARKING LOT

No primary beam will be allowed. The primary beam is restricted via an electrical interlock which will limit motion to  $30^{\circ}$  CCW from vertical down. CW is defined viewing the unit from in front of the stand.

$$\begin{aligned}d_s &= 3.0 \text{ m} \\SSD &= 0.8 \text{ m} \\a &= 0.001 \\t_c &= 0.91 \text{ m} \\T_x &= 2.2 \times 10^{-5}\end{aligned}$$

Scatter

$$\begin{aligned}\dot{R} &= 9000/(0.8)^2 \times 0.001 \times 1/(3.0)^2 \times 2.2 \times 10^{-5} \times 1600/400 \times 1000 \text{ mR/R} \\&= 0.13 \text{ mR/hr}\end{aligned}$$

$$\dot{R}_w = 36.13 \times 40000/9000 = 0.6 \text{ mR/wk}$$

Leakage

$$\begin{aligned}\dot{R} &= 9000/(3.0)^2 \times 0.001 \times 2.2 \times 10^{-5} \times 1000 \text{ mR/R} \\&= 0.02 \text{ mR/hr}\end{aligned}$$

$$\text{Net } \dot{R} = 0.13 + 0.02 = 0.15 \text{ mR/hr}$$

$$\text{Net } \dot{R}_w = 0.6 + 0.1 = 0.7 \text{ mR/wk}$$

LOCATION E - OUTSIDE WALL

$$\begin{aligned}d_s &= 3.0 \text{ m} \\t_c &= 1.22 \text{ m}\end{aligned}$$

Since this wall has the same distances as point E, but substantially thicker walls, there will be less radiation than for point D.

LOCATION F - CLINAC 6/100 ROOM, BACK CORNER

$$\begin{aligned}d_s &= 6.1 \text{ m} \\t_c &= 0.91 \text{ m}\end{aligned}$$

Since the distances are much greater than for location D, the exposure rates will be much less.

LOCATION - UNDER CO-60 ROOM

Comment: There is ground under the unit; therefore, there is no occupancy, no exposure.

LOCATION - ROOM ABOVE THE CO-60 UNIT

Comment: Directly above the unit the thickness is equivalent to greater than 4 feet of concrete. Off center from the unit the thickness is a minimum of 3 feet thick. No primary is allowed due to mechanical limitations (90° out - max) and electrical (90 CW from vertical down - max)

$$\text{SSD} = 0.8 \text{ m}$$

$$d_s = 3.05 \text{ m}$$

$$d_1 = 2.25 \text{ m}$$

$$a = 0.001$$

$$t_c = 91.4 \text{ cm}$$

$$T_x = 4.5 \times 10^{-5}$$

Scatter

$$\begin{aligned} \dot{R} &= 9000/(0.8)^2 \times 0.001 \times 1/(3.05)^2 \times 4.5 \times 10^{-5} \times 1600/400 \times 1000 \text{ mR/R} \\ &= 0.27 \text{ mR/hr} \end{aligned}$$

$$\dot{R}_w = 0.27 \times 40000/9000 = 1.21 \text{ mR/wk}$$

Leakage

$$\begin{aligned} \dot{R} &= 9000/(2.25)^2 \times 0.001 \times 4.5 \times 10^{-5} \times 1000 \text{ mR/R} \\ &= 0.08 \text{ mR/hr} \end{aligned}$$

$$\dot{R}_w = 0.35 \text{ mR/wk}$$

$$\begin{aligned} \text{Total } \dot{R} &= 0.27 + 0.08 = 0.35 \text{ mR/hr} \\ \dot{R}_w &= 1.21 + 0.35 = 1.56 \text{ mR/wk} \end{aligned}$$

Summary


Calculations have been made which show that, using the beam limitations requested (30 CW, -30 CCW from vertical down; 90° out, 30° in), there will be no unrestricted areas where exposure rates of greater than 2.0 mR/hr or 100 mR in a week can occur. In addition we are assured because of the low weekly exposures that no one in the area surrounding the Co-60 unit, even if continually present, will receive 500 mR in one years time.

Note: Because of the shielding involved, it is not necessary to calculate the added weekly exposure due to 2 mR/hr leakage at 1 meter with the beam in the OFF position.

David J. Keys, Ph.D.  
David J. Keys, Ph.D.  
7/14/86

DJK:sjk

CONTROL NO. 81741



NRO

7/15/86

CONTROL NO. 81741

*Dr. Callan*