

DISTRIBUTION:
Docket File 50-275
Docket File 50-275 (w/enc1)
NOTE: Docket Files
NOTE: Docket File
V.Bernero
W.P. Gammill
H. Schierling
F. Witt
C. Willis
C.R. Nichols

JAN 31 1985

Docket Nos. 50-275/323

MEMORANDUM FOR: George W. Knighton, Chief
Licensing Branch No. 3, DL

FROM: William P. Gammill, Chief
Meteorology and Effluent Treatment Branch, DSI

SUBJECT: DIABLO CANYON ALLEGATIONS

PLANT NAME: Diablo Canyon Power Plant, Unit Nos. 1 and 2
LICENSING STAGE: GR/OL
DOCKET NUMBER(S): 50-275/323
RESPONSIBLE BRANCH: LB#3; H. Schierling, PM
REVIEW STATUS: Continuing

As requested in your memorandum of January 23, 1985, we have reviewed and evaluated Allegations 1228 and 1232, in accordance with your November 30, 1984 memorandum. Our evaluations are enclosed using the forms you provided.

If you have any questions, contact Charles R. Nichols (427034).

Original signed by:
William P. Gammill

William P. Gammill, Chief
Meteorology & Effluent Treatment Branch
Division of Systems Integration

Enclosures:
As stated

cc: R. Bernero
T. Novak
D. Muller

8502070255XA
3pp.

~~XXXXXXXXXX~~
B/25
~~XXXXXXXXXX~~

ccw
TO : DSI:RP:METB : DSI:RP:METB : DSI:RP:METB :
FROM : C.R. Nichols:dj : C.A. Willis : W.P. Gammill :
DATE : 01/31/85 : 01/31/85 : 01/31/85 :

Topic: Allegation of Concern No. 1228

ATS No:

BN No:

Characterization

From the public record available at the PDR, the degree to which the 1986-0737, Item 11.B.3 requirement has been sacrificed remains indeterminate.

Class D

Limited Significance to Plant Design, Construction, or Operation

Pertains to the ability to obtain certain information that could be used in determining mitigating actions to be taken during an accident.

Assessment of Safety Significance

This is not a safety system. In e.g. 1.87, Rev. 2, this is a "Detect and diagnose" that is "diagnostic and backup;" and it monitors "Type B" variables, the least critical category. Therefore, deficiencies in this function do not have a critical impact on public health and safety.

Functionally, the deficiencies have been corrected as shown in the next section.

Staff Position

The public record, developed after the allegation was made, describes how the requirement has been met.

Action Required

Identify the following documents available from the public records: letters from F. A. Kanskiwski, NRC, to PHE, dated 07/19/84, 07/24/84, 11/13/84, 11/23/84, and 01/03/85.

Issue: Allegation or Concern No. 1232

ATS No:

BN No:

Characterization

A review of publicly available documents/records has not revealed a PRAE submittal of the NUREG-0737, Item III.D.1.1 required program or the NRC approval of the same.

Code D

Implied Significance to Plant Design, Construction, or Operation

Pertains to the ability of plant personnel to safely access restricted areas of the plant in order to take mitigating actions during an accident.