

GPU Nuclear, Inc. U.S. Route #9 South Post Office Box 388 Forked River, NJ 08731-0388 Tel 609-971-4000

July 9, 1999 1940-99-20377

U. S. Nuclear Regulatory Commission Attention: Document Control Desk Washington, DC 20555-0001

Dear Sir:

Subject:

Oyster Creek Nuclear Generating Station

Docket No. 50-219

GPUN Emergency Plan for Oyster Creek Nuclear Generating Station

Enclosed is one copy of the GPUN Emergency Plan for Oyster Creek Nuclear Generating Station, 2000-PLN-1300.01, Revision 1.

The changes in Revision 1, which became effective July 2, 1999, are briefly summarized in Attachment 1 of this letter. GPU Nuclear has determined that the changes in this revision do not decrease the effectiveness of the Emergency Plan and continue to meet the standards of 10 CFR 50.47(b) and 10 CFR 50.54(q).

If you have any questions, please contact Ms. Brenda S. DeMerchant, Oyster Creek Licensing Engineer, at 609-971-4642.

Sincerely,

Michael B. Roche

Vice President and Director

Thirland & Roche

Oyster Creek

Attachment

cc:

Region I Administrator
Oyster Creek Project Manager
Ovster Creek Senior Resident Inspector

0045

9907190045 990709 PDR ADDCK 05000219 FDR 110025

Attachment 1

Revised Public Information Process for Emergencies - Alert or Higher

PURPOSE:

In an effort to strengthen Oyster Creek's emergency public information efforts at the Joint Information Center (JIC) in Lakewood N.J., GPUN Emergency Preparedness and Communications conducted a review of the Public Information process. As an result of this review, changes were made which will streamline the current procedures to provide for a simpler, stronger central line of communications.

The new Public Information process assures that all of the positions within the Emergency Communications Plan are fully utilized and team members are actively engaged at all times. The plan calls for the implementation of new roles at the JIC and relocation of two existing roles. It is expected that these moves will provide a smoother flow of information, fewer communication disconnects and a more fully engaged staff.

The following plan defines the positions and their responsibilities and outlines the process that would be followed by Public Information (PI) staffers in the event of a plant emergency.

EMERGENCY COMMUNICATIONS ROLES

Public Information (PI) Technical Representative/ Emergency Operations Facility (EOF):

The PI Technical Representative/EOF serves as the technical advisor from the EOF and will be responsible for gathering all approved and final information regarding the plant event. This position will interact with the PI Technical Representative in the JIC and provide that person with the most up to date information, as it becomes available. The PI Technical Representative in the EOF will be responsible for attending all Emergency Support Director (ESD) briefings at the EOF. This position will also be responsible for calling the JIC in advance of all briefings so JIC staff knows that new information could be developing.

This position will be staffed by the individuals that were filling the "209" PI Tech Rep position in the TSC, that position has been eliminated.

PI Technical Representative/JIC:

This new position is to be filled using the individuals currently in the "612" position in the EOF and is responsible for serving as the focal point in the JIC for all technical information associated with the plant event. This single point of reference will assure that those writing the press releases and presiding over the briefings have a full and consistent understanding of the events happening at the plant. Because this position would be retrieving information for both written and verbal communications, all information that goes out to the public would be coordinated and correct. The PI Technical Representative at the JIC would be in constant contact with the PI Technical Representative at the EOF.

This new position would also help with the staffing needs of the JIC by assuring that the communication lines in the JIC are constantly manned.

Media Center Lead:

This new position is a spin-off of the Media Center Advisor/Communications position. The Media Center Lead will:

- have command and control over the center's activities
- assure that all procedures are being followed by others in the center
- approve press releases prior to their review by the ESD.

The Media Center Lead will be the individual in the JIC with the responsibility to interface with and coordinate the activities of the State and Local Government communications personnel responding to the JIC. It is important that this position frequently meet with these individuals for the purpose of coordinating the information used in media briefings and when briefings are to be held.

Another responsibility of the Media Center Lead would be to serve as a moderator during press briefings. During these briefings, he or she would provide a brief synopsis of the emergency and its classification; give an overview of JIC logistics; introduce representatives on the panel; as well as field questions and direct them to the proper representative. He or she may also answer non-technical questions from the media regarding the event.

Media Center Advisor:

This position has previously been a technical advisor, media briefer and moderator. Under its new description, the Media Center Advisor will serve as the technical spokesperson on the panel during press conferences. Following press conferences, the Media Center Advisor will stay in the auditorium for a short time to answer technical questions from the media about plant systems, components, etc. He or she will not answer questions outside the formal media briefings that discuss actions taken regarding the event.

Press Release Writer:

This position was formerly located at the EOF. This position will serve essentially as the news release writer. The PI Representative will receive information from the PI Technical Representative in the JIC, which will coincide with the information given to the Media Center Adviror and the Media Center Lead. Movement of the position from the EOF to the JIC will streamline the process in a number of ways:

- The press release must be reviewed for grammar, writing style and communications elements by the Media Center Lead in the JIC prior to its release to the public.
- Information for the news release will be better coordinated because the same approved information that is being disseminated by Technical Representatives for use in media briefings will be used for press releases as well.

JIC Admin/Com:

This position stays the same.

NEW PROCESS

The following is the new process that would be used to disseminate information in the event of a plan emergency- Alert or greater.

- Event is declared.
 - All emergency response personnel respond to their assigned locations at the JIC and the EOF.
- Responders arrive at JIC
 - Press Release Writer begins writing press release, based on information received from the PI Technical Representative at the JIC or EOF, or information received from the Control Room (i.e.: 126 notification and/or the initial notifications form), depending on whom is first available.
 - Media Center Lead assesses plant event and estate a staffing plan and watchbill for 24-hour coverage. Retains essential emergency staff and sends others home for later shifts if necessary.
 - JIC Admin/Com assures auditorium setup, work room equipment e perability, etc. This is confirmed by Media Center Lead.
 - PI Technical Representative/IIC contacts PI Technical Representative/EOF to obtain plant status.
- 3. Upon arrival at the EGF, PI Technical Representative obtains plant status and notifies PI Technical Representative at the JIC. This information would be acquired from the Leads in the EOF and/or through the engineering communications line to the ECC and TSC. Any conflicting or incomplete information should be resolved prior to communicating it to the JIC.
- PI Technical Representative/JIC briefs Media Center Lead and Media Center Advisor of plant status.
- 5. Press Release Writer completes first press release, which is reviewed by Media Center Lead. If release is written from boilerplate material, no further approval is needed. If new information is part of the release, release must be approved by ESD following Media Center Lead review.

- Approved press release is fax distributed by JIC Admin/Com and placed in the back of the JIC auditorium.
- Concurrent with press release writing, Media Center Lead and Media Center Advisor review plant events with PI Technical Representative/JIC to prepare for media briefing.
- Media Center Lead holds pre-brief meeting with Media Center Advisor and state, county and federal Public Information Representatives. The group shares information and plans what each organization will discuss during briefing.
- 9. Media Briefing is held moderated by Media Center Lead. Media Center Lead introduces panel, provides brief overview of plant event and, one-by-one, turns over to others on panel who will also provide brief information. Following panel encapsulations, Media Center Lead fields questions from the media and refers them to the proper panel representative.
- 10. At the conclusion of the media briefing, all leave the auditorium with the exception of the Media Center Advisor who stays back to take questions from the media on plant-related questions only.
- 11. During the briefing, PI Technical Representative/JIC continues to gather new information in coordination with PI Technical Representative/EOF.
- 12. Process recycles at #4



Applicability/Scope

Safety Reviews Required

Station

Number GPUN Emergency Plan 2000-PLN-1300.01 Revision No. GPU Nuclear Emergency Plan for Oyster Creek Nuclear 1 Responsible Office Emergency Preparedness This Plan has Oyster Creek Applicability

This document is within QA plan scope X Yes No

Prior Revision 0 incorporated the This Revision 1 incorporates the following Temporary Changes: following Temporary Changes:

Effective Date

(06/22/99) 07/02/99

N/A

N/A

List of Pages (all pages rev'd to Rev. 0)

X Yes_No

1.0 to 172.0		
E1-1	E14-1 to E14-2	
E2-1 to E2-4	E15-1 to E15-2	
E3-1	E16-1	
E4-1 to E4-2	E17-1	
E5-1 to E5-3	E18-1	
E6-1 to E6-2	E19-1	
E7-1 to E7-2	E20-1	
E8-1 to E8-2	E21-1	NON-CONTROLLED
E9-1	E22-1	
E10-1	E23-1	This Document Will Not
E11-1	E24-1	Be Kept Up To Date
E12-1	E25-1	DCC Oyster Creek
E13-1		DCC Cyster Creek

THIS PROCEDURE REPLACES 1000-PLN-1300.01

ANALYSIS (1997)	Signature	Concurring Organization Element	Date
Originator	DU Joseph	Emergency Planner	5/21/99
Concurred By	/5/	Director, Human & Adm. Services	
	/s/	Comptroller, Financial & Planning Services	
	/s/	Director, Communications	
	/s/	Director, Nuclear Safety Assessment	,
	/s/	Director, Engineering	
	/s/	Director, Radiological Health & Safety	
		Director, Oyster Creek	
Approved By	Jose Justin	Office of the President	6/8/99



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

SECT	ION	PAGE	
1.0	1.0 <u>GLOSSARY</u>		
	1.1 Definitions	8.0	
	1.2 Abbreviations	17.0	
2.0	APPLICABILITY AND SCOPE	20.0	
	2.1 General Demographic and Geographic Information	20.0	
	2.1.1 General Information and Site Description	20.0	
	2.1.2 Owner Controlled Area, Exclusion Area, and Low Population Zone	22.0	
	2.1.3 Population and Population Distribution	22.0	
	2.1.4 Local Industrial and Military Facilities	23.0	
	2.1.5 Emergency Planning Zones	23.0	
	2.2 Scope of the Emergency Plan	24.0	
	2.2.1 Emergency Plan Implementing Document	25.0	
	2.2.2 Related Plans, Programs and Procedures	26.0	
	2.2.3 Related County and State Plans	27.0	
3.0	SUMMARY OF EMERGENCY PREPAREDNESS PROGRAM	29.0	
	3.1 The GPUN Emergency Plan	29.0	
	3.2 The Implementing Documents	30.0	
4.0	EMERGENCY CONDITIONS	32.0	
	4.1 Emergency Classification System	32.0	
	4.1.1 Unusual Event	35.0	
	4.1.2 Alert	36.0	
	4.1.3 Site Area Emergency	37.0	
	4.1.4 General Emergency	39.0	
	4.2 State, County and Local Classification System	40.0	
	4.3 Spectrum of Postulated Accidents	40.0	
	4.3.1 Classification of Hypothetical Accidents	41.0	
	4.4 Instrumentation Capability for Detection	41.0	



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

SECTI	ON		PAGE
5.0	GPUN	EMERGENCY ORGANIZATION	42.0
	5.1	Mobilization	42.0
		5.1.1 Transition from Normal Shift Organization to	
		Emergency Shift Organization	43.0
		5.1.2 On-Shift Emergency Organization	46.0
		5.1.3 Initial Response Emergency Organizati	49.0
		5.1.4 Emergency Support Organization	72.0
	5.2	Long-Term Recovery Organization	79.0
	5.3	Additional Support	81.0
		5.3.1 Medical Support Organizations and Personnel	82.0
		5.3.2 Firefighting Organizations	82.0
		5.3.3 Law Enforcement Agencies	82.0
		5.3.4 Other Government Agencies	83.0
		5.3.5 Miscellaneous Organizations	83.0
	5.4	Government Agencies	85.0
		5.4.1 Federal Radiological Emergency Response Plan	85.0
		5.4.2 State Agencies	90.0
		5.4.3 County Agencies	92.0
6.0	EMER	GENCY MEASURES	93.0
	6.1	Emergency Notification of Offsite Agencies	93.0
	6.2	Corrective Actions	94.0
	6.3	Onsite Protective Action	95.0
		6.3.1 Sheltering, Evacuation, Personnel Accountability	95.0
		6.3.2 First Aid and Decontamination	101.0
		6.3.3 Medical Transportation	104.0
		6.3.4 Medical Treatment	105.0
	6.4	Environmental Assessment	105.0
		6.4.1 Radiological Assessment and Offsite Monitoring	105.0
	6.5	Offsite Protective Actions	109.0
		6.5.1 General Public	109.0
	6.6	Offsite Agency Response	112.0
		6.6.1 Ocean County	112.0
		6.6.2 State Emergency Management Agency (NJ State Police OEM)	112.0
		6.6.3 Bureau of Nuclear Engineering	113.0
	6.7	Prompt Notification System	113.0
		Evacuation Time Estimates	116.0
		Emergency Public Information	116.0



Number

2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

SECTI	ON				PAGE
7.0	EMER	GENCY RES	PONSE FACIL	ITIES AND EQUIPMENT	118.0
	7.1	Onsite E	mergency Re	sponse Facilities	119.0
				Control Center	119.0
				Support Center	119.0
				Support Center	120.0
	7.2			ncy Response Facilities	120.0
		7.2.1		Operations Facility	120.0
	7.3			ederal Emergency Operations Centers	121.0
				ergency Operations Centers	121.0
				gency Operations Center	121.0
				rield Office	121.0
	7.4			tions Systems	122.0
				Communications	123.0
				NRC Emergency Notification System (ENS)	123.0
				Health Physics Network	123.0
				Telephone System	124.0
				Transmission (Voice)	124.0
				Automatic Dialing Equipment	124.0
				Emergency Response Facility Communications	
				System	124.0
				Telephone System Emergency Power Supplies	126.0
				Radio Communications	127.0
		7.4.2		rning System	127.0
			7.4.2.1		127.0
				Plant Paging System	128.0
				Call Out Telecommunication Equipment (Teleclerk)	128.0
	7.5	Assessme	nt Faciliti	es	129.0
		7.5.1	Onsite Sys	tems and Equipment	129.0
				Radiation Monitoring System	129.0
				Radiation Monitoring	130.0
				Atmospheric Radiation Monitoring	131.0
				Liquid Radiation Monitoring	133.0
				Main Steam Line Radiation Monitoring System	134.0
			7.5.1.6	Augmented Off-Gas Building Ventilation	
				Exhaust Monitoring System	135.0
			7.5.1.7	Containment Radiation Monitors	135.0
			7.5.1.8	Post Accident Sampling System	135.0
		7.5.2		ection Devices	136.0
		7.5.3	Seismic Mo		137.0
		7.5.4		eorological Monitors	137.0
		7.5.5	Process Mo		139.0
		7.5.6	Laboratory		139.0
		7.5.7		nd Equipment Required by NUREG	139.0
			4		



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Dyster Creek Nuclear Station

Revision No.

1

SECTI	ION			PAGE
		7.5.8	Facilities and Equipment for Offsite Monitoring	139.0
			7.5.8.1 Reuter Stokes Sentri System	139.0
			7.5.8.2 Radiological Environmental Monitoring Program	
			(REMP)	140.0
		7.5.9	National Weather Service (NWS)	143.0
		7.5.10	Federal Radiological Monitoring and Assessment Plan	
			(FRMAP)	143.0
		7.5.11	State Department of Environmental Protection	144.0
		7.5.12	Offsite Emergency Radiologial Assistance	145.0
	7.6		al Support Facilities	145.0
		7.6.1	Joint Information Center	146.0
		7.6.2	Environmental Assessment Command Center (EACC)	147.0
		7.6.3	Remote Assembly Area (RAA)	147.0
			Control Room/Shift Supervisor's Office	148.0
		7.6.5	Processing Center	149.0
			Emergency Assembly Areas	149.0
			d and Medical Facilities	149.0
			Control Equipment	150.0
			rical Controls Equipment	150.0
	7.3.0	Emergenc	y Equipment Readiness	151.0
8.0	MAIN	TAINING E	MERGENCY PREPAREDNESS	152.0
	8.1	Responsi	bilities	152.0
	8.2		tional Preparedness	157.0
		8.2.1	Training	157.0
		8.2.2	Drills and Exercises	159.0
		8.2.3	Emergency Preparedness Department	164.0
	8.3	Reviewin	g and Updating of the Emergency Plan and Implementing	
		Document		165.0
	8.4	Maintena	nce and Inventory of Emergency Equipment and Supplies	166.0
9.0	RECO	VERY		168.0
10.0	REFE	RENCES		170.0



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

TABLES

TABLE	1	Percent of Land Use by County
TABLE	2	OCNGS Emergency Action Summary
TABLE	3	Emergency Classification of Postulated Accidents
TABLE	4	Plant Instrumentation for Accident Detection
TABLE	5	On-Shift Emergency Organization Staffing
TABLE	6	Initial Response Emergency Organization Staffing
TABLE	7	Emergency Support Organization Staffing
TABLE	8	Inventory of Oyster Creek Emergency Kits by General Category
TABLE	9	Typical Environmental/Radiological Monitors
TABLE	10	GPUN Emergency Response/Additional Support Facilities
TABLE	11	County, and State Federal Emergency Operations Centers
TABLE	12	OCNGS Emergency Communications Network
TABLE	13	Department Commitments to Provide Instructors
TABLE	14	Periodic Training for GPUN Emergency Response Personnel
TABLE	15	Emergency Response Organization Staffing Responsibilities



Number 2000-PLN-1300.01

Title


GPU Muclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

**

FIGURES

FIGURE 1	OCNGS Site Arrangement
FIGURE 2	OCNGS Site Relative Location
FIGURE 3	OCNGS Site Exclusion Area and Low Population Zone
FIGURE 4	OCNGS Site Plume Exposure Pathway (10 mile) Emergency Planning Zone
FIGURE 5	OCNGS Site Ingestion Pathway (50 mile) Emergency Planning Zone
FIGURE 6	OCNGS Normal Shift Organization
FIGURE 7	GPUN On-Shift Emergency Organization
FIGURE 8	GPUN Initial Response Emergency Organization
FIGURE 9	GPUN Emergency Support Organization
FIGURE 10	OCNGS Notification Network



Number 2000-PLN-1300.01



Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

1.0 GLOSSARY

1.1 Definitions

The following is a list of terms and their definitions which are used in the Emergency Plan and Implementing Documents:

- 1.1.1 Access Control Point An access control point serves as the boundary line between the "clean" and radiologically controlled areas of the plant and serves as a processing station for access to the RWP required areas. The two main access control points at OCNGS are located on the north side of the Reactor Building. One is located at the Northeast corner and the other at the Northwest corner and both are at ground elevation.
- 1.1.2 Accident Mu unintentional event which may result in an emergency.
- 1.1.3 <u>Adverse Meteorology</u> For OCNGS as defined in Reg. Guide 1.3, Figure 1A.
- 1.1.4 Affected Persons Persons who, as the result of an accident, have been or may be radiologically exposed or physically injured to a degree requiring special attention (e.g., evacuation, decontamination, first aid or medical services, etc.).
- 1.1.5 Alert An emergency classification where events are in progress or have occurred which involve an actual or potential substantial degradation of the level of safety of the plant. Any release is expected to be limited to small fractions of the EPA Protection Action Guide exposure levels.
- 1.1.6 Annually Once each calendar year.



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear
Station

Revision No.

1.0 GLOSSARY

1.1 Definitions

The following is a list of terms and their definitions which are used in the Emergency Plan and Implementing Documents:

- 1.1.1 Access Control Point An access control point serves as the boundary line between the "clean" and radiologically controlled areas of the plant and serves as a processing station for access to the RWP required areas. The two main access control points at OCNGS are located on the north side of the Reactor Building. One is located at the Northeast corner and the other at the Northwest corner and both are at ground elevation.
- 1.1.2 <u>Accident</u> An unintentional event which may result in an emergency.
- 1.1.3 <u>Adverse Meteorology</u> For OCNGS as defined in Reg. Guide 1.3, Figure 1A.
- 1.1.4 Affected Persons Persons who, as the result of an accident, have been or may be radiologically exposed or physically injured to a degree requiring special attention (e.g., evacuation, decontamination, first aid or medical services, etc.).
- 1.1.5 Alert An emergency classification where events are in progress or have occurred which involve an actual or potential substantial degradation of the level of safety of the plant. Any release is expected to be limited to small fractions of the EPA Protection Action Guide exposure levels.
- 1.1.6 Annually Once each calendar year.



Number 2000-PLN-1300.01

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station Revision No.

- 1.1.7 <u>Assessment Actions</u> Those actions taken during or after an accident which are collectively necessary to make decisions to implement specific emergency actions.
- 1.1.8 Biennial Once every two calendar years.
- 1.1.9 <u>Clean Area</u> The allowable levels of loose surface contamination for a clean area are less than 1000 dpm/100 cm² beta-gamma and 20 dpm/100 cm² alpha.
- 1.1.10 <u>Contaminated Area</u> An area where contamination levels are in excess of those specified for a clean area.
- 1.1.11 Control Room The legation from which the reactor and its auxiliary systems are controlled. The OCNGS Control Room is located on the 46' elevation of the turbine building.
- 1.1.12 <u>Corrective Actions</u> Those emergency actions taken to mitigate or terminate an emergency situation.
- 1.1.13 <u>Dose</u> The energy imparted to matter by ionizing radiation per unit mass of irradiated material.
- 1.1.14 <u>Dose Commitment</u> The dose that will be accumulated by a specific organ over a 50 year period following intake.
- 1.1.15 <u>Effluent Monitor</u> An on-line or off-line instrument monitoring radiological conditions of a designed pathway to the environment (e.g., station ventilation exhaust).
- 1.1.16 <u>Emergency</u> That situation or condition which may result in damage to property and/or may lead to undue risk to the health and safety of the general public and/or site personnel.

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

- 1.1.17 Emergency Actions Those measures or steps taken to ensure that an emergency situation is assessed (assessment actions) and that the proper corrective and/or protective actions are taken.
- 1.1.18 Emergency Action Levels (EAL) Predetermined conditions or values, including radiation and integrated dose; events such as natural disasters or fires; or specific instrument indications which, when reached or exceeded, require implementation of the Emergency Plan.
- 1.1.19 Emergency Classifications The characterization of several classes of emergency situations consisting of mutually exclusive groupings including the entire spectrum of possible radiological emergencies. The four classes of emergencies are (1) Unusual Event, (2) Alert, (3) Site Area Emergency, and (4) General Emergency.
- 1.1.20 Emergency Control Center (ECC) The location from which control and coordination of emergency actions are effected.

 The designated area encompasses the Shift Supervisor's Office and Control Room at OCNGS. Once the entire emergency response organization is activated, the Emergency Director retains command and control of all on-site activities from the TSC.
- 1.1.21 Emergency Core Cooling System System of pumps, piping, valves, etc., used to deliver emergency cooling water to the reactor core. At OCNGS, the ECCS includes the pertinent pumps, piping, valves, etc. of the Isolation Condenser, Core Spray and Automatic Depressurization Systems.

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station.

Revision No.

- 1.1.22 Emergency Director (ED) Designated onsite individual having the responsibility and authority to implement the Emergency Plan, and who will coordinate efforts to limit consequences of, and bring under control, the emergency.
- 1.1.23 Emergency Operations Center (EOC) Designated State, county, and Municipal Emergency Management Agency locations especially designed and equipped for the purpose of exercising effective coordination and control over disaster operations within their jurisdiction.
- 1.1.24 Emergency Operations Facility (EOF) Designated location from which the Emergency Support Organization conducts the companies overall emergency response.
- 1.1.25 Emergency Operations Procedures Specific plant procedures
 that provide step-by-step instructions to guide plant
 operations during potential or real emergency situations.
- 1.1.26 Emergency Plan GPU Nuclear Oyster Creek plan for dealing with emergencies at the Oyster Creek reactor site.
- 1.1.27 <u>Emergency Plan Implementing Procedures</u> Specific procedures in the Implementing Document which include emergency action levels and provide step-by-step emergency actions.
- 1.1.28 Emergency Planning Zone (EPZ) There are two Emergency

 Planning Zones. The first is an area, approximately 10 miles
 in radius around the site, for which emergency planning

 consideration of the plume exposure pathway has been given in

 order to assure that prompt and effective actions can be
 taken to protect the public and property in the event of an
 accident. This is called the Plume Exposure Pathway EPZ.

Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

The second is an area 50 miles in radius around the site, for which emergency planning consideration of the ingestion exposure pathway has been given. This is called the Ingestion Exposure Pathway (EPZ).

- 1.1.29 Emergency Support Director (ESD) Designated individual offsite having the overall responsibility for the management of the response to an accident and recovery operations.
- 1.1.30 Exclusion Area As defined in 10 CFR 100.3; "that area surrounding the reactor, in which the reactor licensee has the authority to determine all activities including exclusion or removal of personnel and property from the area". The OCN3S exclusion area is the 1358 ft. radial area surrounding the OCNGS site, as measured from the centerline of the reactor building.
- 1.1.31 General Emergency Events are in progress or have occurred which involve actual or imminent substantial core degradation or melting with potential for large releases of radioactive material and/or loss of reactor building (containment) integrity, and other accidents that have large radioactive release potential such as fuel handling and waste gas system accidents. Releases can be reasonably expected to exceed EPA Protective Action Guide Exposure levels off-site for more than the immediate site area.
- 1.1.32 Implementing Document A document containing a description of the concept of emergency operations, emergency communication system, Emergency Plan Implementing Procedures and administrative procedures.



Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

- 1.1.33 Ingestion Exposure Pathway EPZ The 50 mile Emergency

 Planning Zone in which a radioactive plume can cause the

 exposure of the population-at-risk and/or onsite personnel to

 internal contamination resulting from ingestion of

 contaminated water or foods, such as milk or fresh

 vegetables.
- 1.1.34 <u>Joint Information Center (JIC)</u> Center of release of information to the news media, and the public, and for coordination of information releases with Federal, State and local agencies.
- 1.1.35 Low Population Zone (LPZ) As defined in 10 CFR 100.3, the area immediately surrounding the exclusion area which contains residents, the total number and density of which are such that there is a reasonable probability that appropriate protective measures could be taken in their behalf in the event of a serious accident.
- 1.1.36 Off-site Any area outside the owner controlled area.
- 1.1.37 Operable A component or system is defined as operable when it is capable of performing its intended function within the required range.
- 1.1.38 Operations Support Center (OSC) Designated location from which accident mitigation personnel are dispatched.
- 1.1.39 Owner Controlled Area That area located outside of the protected area fence surrounding the OCNGS.
- 1.1.40 Parent County County in which the site is located i.e.,
 Ocean County for the Oyster Creek site.



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

- 1.1.41 <u>Personnel Monitoring Equipment</u> As defined in 10 CFR 20.1003, devices designed to be worn or carried by an individual for the purpose of measuring the dose received (e.g., pocket dosimeters, thermoluminescent dosimeters, etc.).
- 1.1.42 Plume Exposure Pathway EPZ The approximate 10 mile

 Emergency Planning Zone in which a radioactive plume can
 expose the population-at-risk and/or onsite personnel to
 radiation. The principal modes of exposure in the EPZ are:

 (1) whole body external exposure to gamma radiation from the
 plume, and (2) dose commitments from inhalation of the
 radioactive material within the plume.
- 1.1.43 Population-At-Risk Those persons for whom protective actions are being or would be taken.
- 1.1.44 <u>Population Center Distance</u> The distance from the reactor to the nearest boundary of a densely populated center containing more than about 25,000 residents.
- 1.1.45 Projected Dose A calculated estimate of dose which the population-at-risk may receive as a result of a radiological emergency in the absence of protective action.
- 1.1.46 Properly Relieved Qualified individual/fit for duty.
- 1.1.47 Protected Area As defined in 10 CFR 73.2, an area encompassed by physical barriers and to which access is controlled. This area includes all areas within the security fence that immediately surrounds the major site structures (i.e. Reactor, Warehouse, Turbine, New Radwaste, Diesel Generator Bldg., and Other Office Buildings).



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear
Station

Revision No.

- 1.1.48 Protective Actions Those actions taken during or after an emergency situation that are intended to minimize or eliminate the hazard to the health and safety of the general public and/or on-site personnel.
- 1.1.49 Protective Action Guides Projected radiological dose or dose commitment values to individuals in the general population and to emergency workers that warrant protective action before or after a release of radioactive material. Protective actions would be warranted provided the reduction in individual dose expected to be achieved by carrying out the protective action is not offset by excessive risks to individual safety in taking the protective action. The protective action guide does not include the dose that has unavoidably occurred prior to the assessment.
- 1.1.50 RAC Model Computer model used by the radiological assessment personnel to estimate radiological release source terms and make off-site dose projections. This model has been verified by comparison of results to those from the MIDAS Model.
- 1.1.51 Radiologically Controlled Area All plant areas where radiation, contamination, or airborne radioactivity have a potential for existing in amounts above the limits set forth for an uncontrolled area as defined in 10CFR20; includes Radiation Area, High Radiation Area, Airborne Radioactivity Area, Radioactive Material Area, Contaminated Area or any other posting established for Radiological Controls purposes.



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

- 1.1.52 <u>Recovery Actions</u> Those actions taken after the emergency to restore the plant as nearly as possible to its pre-emergency condition.
- 1.1.53 Restricted Area As defined in 10 CFR 20.3, any area access to which is controlled by the licensee for purposes of protection of individuals from exposure to radiation and radioactive materials. A restricted area shall not include any areas used as residential quarters, although a separate room or rooms in a residential building may be set apart as a restricted area.
- 1.1.54 Risk County Any County which is within (in whole or in part) the Plume Exposure Pathway (i.e., approximate 10 mile)

 Emergency Planning Zone.
- 1.1.55 Semi-Annually -Twice within a calendar year.
- 1.1.56 Site Area Emergency An emergency classification where events are in progress or have occurred which involve actual or likely major failures of plant functions needed for protection of the public. This emergency class includes accidents which have a significant radiation release potential. Any releases are not expected to exceed EPA Protective Action Guide exposure levels except near the site boundary.
- 1.1.57 <u>State</u> A term used for convenience to indicate the State of New Jersey.
- 1.1.58 State Plan State developed and maintained radiological emergency response plan (RERP) which coordinates off-site response by state, county and municipal agencies.



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

- 1.1.59 <u>Technical Support Center (TSC)</u> Emergency response facility utilized by engineering personnel to provide engineering support for emergency operations. The facility is also used by the Emergency Director and his staff.
- 1.1.60 <u>Tornado Warning</u> Meteorological conditions imminent for a tornado or a tornado sighted in the area.
- 1.1.61 Unrestricted Area As defined in 10 CFR 20.1003, any area to which access is not controlled by the licensee for the purposes of protection of individuals from exposure to radiation and radioactive materials, and any area used for residential quarters.
- 1.1.62 Unusual Event An emergency classification where events are in progress or have occurred which indicate or allow recognition of a potential degradation of the level of safety of the plant, including contaminated injuries of plant personnel which require offsite emergency treatment. No releases of radioactive material requiring off-site response or monitoring are expected unless further degradation of safety systems occurs.

1.2 Abbreviations

- 1.2.1 BNE Bureau of Nuclear Engineering (New Jersey)
- 1.2.2 CDE Committed Dose Equivalent
- 1.2.3 CFR Code of Federal Regulations
- 1.2.4 cpm counts per minute
- 1.2.5 CRO Control Room Operator
- 1.2.6 CRT Cathode Ray Tube
- 1.2.7 DEP New Jersey Department of Environmental Protection



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

-	NAME AND ADDRESS OF THE OWNER, THE PARTY OF	THE RESIDENCE PROPERTY AND ADDRESS OF THE PARTY OF THE PA	
	1.2.8	DFO -	Disaster Field Office
	1.2.9	DGI -	Digital Graphics Incorporated
	1.2.10	DOE -	US Department of Energy
	1.2.11	dpm -	disintegrations per minute
	1.2.12	EAA	Emergency Assembly Area (on-site)
	1.2.13	EAC -	Environmental Assessment Coordinator
	1.2.14	EAAC -	Emergency Assembly Area Coordinator
	1.2.15	EACC -	Environmental Assessment Command Center
	1.2.16	EAL -	Emergency Action Level
	1.2.17	EAS-	Emergency Alert System
	1.2.18	ECC -	Emergency Control Center
	1.2.19	ED -	Emergency Director
	1.2.20	EMA -	Emergency Management Agency
	1.2.21	ENS -	NRC Emergency Notification System
	1.2.22	EOC -	Emergency Operations Center
	1.2.23	EOF -	Emergency Operations Facility
	1.2.24	EPA -	US Environmental Protection Agency
	1.2.25	EPI -	Emergency Public Information
	1.2.26	EPIP -	Emergency Plan Implementing Procedure
	1.2.27	EPZ -	Emergency Planning Zone
	1.2.28	ESD -	Emergency Support Director
	1.2.29	FEMA -	Federal Emergency Management Agency
	1.2.30	FRAA -	Forked River Assembly Area
	1.2.31	FRERP -	Federal Radiological Emergency Response Plan
	1.2.32	FRMAC -	Federal Radiological Monitoring and Assessment Center
	1.2.33	FRMPP -	Federal Radiological Monitoring and Assessment Plan
	1.2.34	FSAR -	Final Safety Analysis Report
	1.2.35	GM -	Geiger Mueller (radiation detection tube)
	1.2.36	GPUN -	GPU Nuclear, Inc.



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1.2.37	GOS -	Group Operating Supervisor
1.2.38	HPN -	NRC Health Physics Network Line
1.2.39	JIC -	Joint Information Center
1.2.40	LPZ -	Low Population Zone
1.2.41	NRC -	US Nuclear Regulatory Commission
1.2.42	NRR -	US Nuclear Regulatory Commission, Nuclear Reactor Regulation
1.2.43	NWS -	US National Weather Service
1.2.44	NUREG -	Nuclear Regulatory Guide
1.2.45	OCNGS -	Oyster Creek Nuclear Generating Station
1.2.46	OEM -	New Jersey State Police, Office of Emergency Management
1.2.47	<u>O/P</u> -	Office of the President (GPUN)
1.2.48	osc -	Operations Support Center
1.2.49	PAG -	Protective Action Guides
1.2.50	PAR -	Protective Action Recommendation
1.2.51	RAA -	Remote Assembly Area (off-site)
1.2.52	RAC -	Radiological Assessment Coordinator
1.2.53	RAGEMS -	Radioactive Gas Effluent Monitoring Systems
1.2.54	RCC -	Radiological Controls Coordinator
1.2.55	RERP -	Radiological Emergency Response Plan
1.2.56	RMS -	Radiation Monitoring System
1.2.57	SDD -	System Design Description
1.2.58	SRO -	Senior Reactor Operator
1.2.59	SSM	Site Shift Manager
1.2.60	TEDE -	Total Effective Dose Equivalent
1.2.61	TLD -	Thermoluminescent Dosimeter
1.2.62	TSC -	Technical Support Center
1.2.63	χ/Q-	Atmospheric Dispersion Factor (Chi/Q)



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

2.0 APPLICABILITY AND SCOPE

The prime objectives of emergency planning are to: (1) develop a plan and implementing procedures that will provide the means for mitigating the consequences of emergencies (including very low probability events) in order to protect the health and safety of the general public and site personnel and to prevent damage to property and (2) ensure operational readiness of emergency preparedness capabilities.

This Emergency Plan has been developed in accordance with the provision of 10 CFR 50, Appendix E and 10 CFR 50.47, and is consistent with the guidelines given in (1) Regulatory Guide 1.70, "Standard Content and Format of Safety Analysis Reports for Nuclear Power Plants", Revision 3 and (2) "Criteria for Preparation and Evaluation of Radiological Emergency Response Plans and Preparedness in Support of Nuclear Power Plants", NUREG 0654/FEMA-REP-1, dated November, 1980. Additional references used in the development of this Emergency Plan are listed in Section 10.

2.1 General Demographic and Geographic Information

In addition to the following information, specific details concerning

Oyster Creek site is included in the Final Safety Analysis Report

(FSAR).

2.1.1 General Information and Site Description

The Oyster Creek Nuclear Generating Station (OCNGS) is operated by GPU Nuclear (GPUN). OCNGS has a General Electric 670 Mw Boiling Water Reactor steam supply system. Control rods and recirculation flow are used for reactivity control. Steam generated within the reactor housing is utilized to drive a turbine coupled to the main generator. The



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

arrangement of the major OCNGS facilities is shown in Figure 1.

The OCNGS site is located near the Atlantic Ocean within the State of New Jersey. The site, approximately 152 acres, is part of a 860 acre site owned by Jersey Central Power and Light Company and lies, in part, in Lacey and Ocean Townships, Ocean County. OCNGS is about two miles inland from the shore of Barnegat Bay and seven miles west-northwest of Barnegat Light on the Atlantic shorefront. The site is approximately nine miles south of Toms River, New Jersey, about fifty miles east of Philadelphia, Pennsylvania, and sixty miles south of Newark, New Jersey.

The major transportation routes include the Garden State
Parkway and U.S. Highway 9, running north and south; U.S.
Highway 72, State Highways 37 and 70, New Jersey Routes 532,
530, 554 and Lacey Road running east and west, which serve
primarily as feeder routes to the Garden State Parkway and
U.S. Route 9. U.S. Highway 9 provides the eastern most
boundary with 708 acres lying east of the highway. U.S.
Highway 9 provides the only access routes to the site by land.
Water access to the site is provided by the Intracoastal
Waterway, which runs through Barnegat Bay. A general area map
showing the relative location of the OCNGS site is shown as
Figure 2.



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

2.1.2 Owner Controlled Area, Exclusion Area and Low Population Zone
The Owner Controlled Area for the OCNGS includes all areas
within the site perimeter security fence. At Oyster Creek,
the minimum distance from the center line of the OCNGS Reactor
Building to the eastern OCA fence is approximately 800 feet.
The Exclusion Area for the OCNGS is a 1358 ft. radius as
measured from the center line of the Reactor Building. The
licensee retains complete authority to determine and maintain
sufficient control of all activities including the authority
to exclude or remove personnel and property for land areas
within the exclusion area.

The OCNGS low population zone is shown in Figure 3.

2.1.3 Population and Population Distribution

The nearest population center is Toms River in Dover Township, 9.5 miles north of the site. Specific information regarding population densities within the Plume Exposure Pathway EPZ, (e.g., residential areas, typical school enrollment and typical hospital capacities) can be found in the Oyster Creek Evacuation Time Estimate Study.

An appreciable variance in population density occurs during June, July and August due to seasonal transient vacationers. The Oyster Creek area, particularly the bay and seashores, is a summer vacation area for the mid-Atlantic states. This seasonal population fluctuation occurs primarily in the eastern sectors.



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

2.1.4 Local Industrial and Military Facilities

A brief summary of land use in Ocean County is included in Table 1. Typical industries within 10 miles of the OCNGS site are found in the Oyster Creek FSAR.

The area within 40 miles of the site is comprised primarily of forest, vacant, or farm land. Only about 25 percent of the land is developed. No major industry exists within a ten mile radius of the site, although several small industrial concerns exist in the Toms River area.

The nearest military installations are Fort Dix, New Jersey (approximately 35 miles northwest), McGuire Air Force Base (on the Fort Dix Military Reserve), and Lakehurst Naval Air Station (14 miles north). There is also a military reserve approximately 12 miles west along U.S. Route 72, utilized as a practice bombing range.

There is one general aviation airport within the 10 mile radius; Robert J. Miller Airpark County Airport, approximately 9 miles northwest.

2.1.5 Emergency Planning Zones

GPU Nuclear has taken into consideration the information and data presented above, guidance provided by the Environmental Protection Agency, Nuclear Regulatory Commission, and the New Jersey Office of Emergency Management, as well as other important factors such as organizational capabilities, availability of emergency facilities and equipment, and the methods for implementing the GPUN Emergency Plan in defining the Emergency Planning Zones (EPZs) for the Oyster Creek site.



Number 2000-PLN-1300.01

71+10

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Stat on

Revision No.

1

As a result, an EPZ having an approximate radial distance of 10 miles from the sites has been defined as the Plume Exposure Pathway EPZ. An EPZ having a radial distance of 50 miles from the sites has been defined as the Ingestion Exposure Pathway EPZ. Figures 4 and 5 illustrate the respective boundaries of these EFZs.

2.2 Scope of the Emergency Plan

In the event of an accident, a radioactive release may pose the principal threat to the workforce and population-at-large in the area around the plant site. Emergency preparedness planning accordingly then focuses on response to this release potential. Prime objectives include development of plans and procedures that provide the basis for efficient and effective radiological emergency response, ensure and maintain operational readiness and emergency preparedness and mitigate environmental impact.

The GPUN Emergency Plan describes the methods and procedures to be used by GPU Nuclear in satisfying its onsite responsibilities. The Emergency Plan describes: (a) the organizations and facilities to be relied upon in responding to emergencies, (b) the means to be used for initial accident assessment and notification, (c) the resources available for cont; onitoring, assessment and dissemination of information about the agency, (d) the emergency measures to be taken, including onsite protective and corrective actions, and (e) the procedures to be followed for maintaining emergency preparedness.



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

To ensure that the response to emergencies is initiated in a timely manner and effectively controlled, the Emergency Plan is coordinated with other plans, programs, and procedures, as follows:

2.2.1 Emergency Plan Implementing Document

The GPUN Emergency Plan has separate Implementing Documents which are distributed to those individuals, agencies, organizations, and facilities where immediate availability of such information would be required in an emergency. The Implementing Documents are organized to provide:

- Detailed Emergency Plan Administrative Procedures which
 define all necessary actions that must be performed on a
 periodic basis in order to ensure readiness of the
 emergency preparedness program. These procedures cover
 such topics as training, drills, emergency equipment and
 administration of emergency duty rosters.
- Detailed Emergency Plan Implementing Procedures that

 define specific emergency action levels, requirements for

 implementation of the procedures, persons responsible for

 implementing each procedure and the detailed emergency

 actions (i.e., step by step instructions) necessary to

 implement the procedure. These procedures give detailed

 instructions to be used during an emergency including:

 emergency assessment, classification, notification,

 protective and corrective actions.



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

The Emergency Plan Implementing Procedures have a direct relationship to the Emergency Plan and are coordinated with other site-specific plans, programs, and procedures.

2.2.2 Related Plans, Programs, and Procedures

- Plan and Implementing Procedures have been coordinated to ensure that appropriate emergency actions can be taken.

 For example, the Security Plan and procedures will make provision for emergency response personnel and vehicle access when required by Emergency Plan Implementing Procedures.
- The GPU Nuclear Radiation Protection Plan sets forth the philosophies, basic policies and object. es of the Radiological Controls Program at the Oyster Creek Nuclear Generating Station. The objectives of the radiological controls programs are to control radiation hazards to avoid accidental radiation exposures, to maintain exposures within the regulatory requirements and to maintain exposures to workers and the general population as low as is reasonably achievable. In addition, Radiological Controls Procedures provide adequate guidance and specify appropriate methods or techniques to ensure that the performance of each activity is in accordance with sound radiological controls principles, and is in compliance with applicable regulatory provisions. The pertinent information and details provided in these



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

documents either have been incorporated into the Emergency Plan, Implementing Procedures or appropriately referenced.

- The GPU Nuclear Environmental Control Plan provides for systematic control of plant systems and materials to avoid accidental environmental discharges and thereby minimize the environmental impact of plant operation.
- A comprehensive set of Emergency Operations Procedures

 that are used to control plant operations during emergency
 and abnormal conditions have been prepared. Since there
 is a direct relationship between emergency operations and
 emergency planning, these procedures and the Emergency
 Plan Implementing Procedures are coordinated and
 complementary. As a result, specific Emergency Operations
 Procedures will, when appropriate, direct the onshift
 operations personnel to the applicable Emergency Plan
 Implementing Procedure(s).
- GPU Nuclear has developed the Emergency Public Information
 Implementing Document for the Oyster Creek site. This
 implementing document describes the methods by which GPU
 Nuclear will disseminate information to the media and the public.

2.2.3 Related County and State Plans

The development of the State of New Jersey Emergency Plan and the GPUN Emergency Plan were closely coordinated. In addition, specific State requirements for reporting of emergencies, providing information and data, and recommending protective actions, have been integrated directly into the



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

Emergency Plan Implementing Procedures. In considering the Plume Exposure Pathway EPZ, there are also county plans that have been considered in the development of the GPUN Emergency Plan. The State Plan designates the New Jersey State Police, Office of Emergency Management (OEM) as the lead state agency for radiological emergency response planning and the state agency through which the Governor will exercise coordination and control during emergency. The State Plan is an integrated document setting forth the resources and responsibilities of all relevant state agencies. Significant plans from the State Departments of Agriculture, Environmental Resources, Bureau of Nuclear Engineering, NJ and Health are included in the State Plans.



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

3.0 SUMMARY OF EMERGENCY PREPAREDNESS PROGRAM

The Emergency Preparedness Program, as defined by GPU Nuclear, consists of separate, coordinated, documents. The Emergency Plan provides the means for performing advance planning and defining specific requirements and commitments that will be implemented by other documents and procedures (e.g., Administrative Procedures, Surveillance Procedures, and Emergency Plan Implementing Procedures). The Emergency Plan Implementing Documents provide the detailed information and procedures that will be required to implement the Emergency Plan, in the event of an emergency at the GPU Nuclear reactor site and to ensure a high state of emergency readiness.

3.1 The GPUN Emergency Plan

The GPUN Emergency Plan ensures that all emergency situations, including those which involve radiation or radioactive material are handled logically and efficiently. It covers the entire spectrum of emergencies from minor, localized emergencies to major emergencies involving action by offsite emergency response agencies and organizations. The GPUN Emergency Plan includes schemes for classifying emergencies consistent with the guidance provided by the Nuclear Regulatory Commission (NRC) in NUREG-0654. This classification system is described in detail in Section 4.0 with site specific information in the applicable Emergency Plan Implementing Procedures (EPIPs). A summary of each classification, its description, purpose and a list of the actions to be taken by GPUN site personnel and offsite authorities is included in Table 2. Furthermore, this Plan incorporates response criteria (emergency action levels) which will be used in the assessment of emergency situations.



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

In summary, the GPUN Emergency Plan provides:

- · Guidance for classifying emergency conditions.
- Guidance for reclassifying such emergency conditions should the severity increase or decrease.
- Details of emergency response organizations.
- General guidelines, as well as specific details, as to which state, county and federal authorities and agencies, and other outside organizations are available for assistance.
- Information pertaining to the emergency facilities and equipment available both on-site and off-site.
- Emergency Preparedness direction necessary for the development of
 Emergency Plan Implementing Procedures.
- Commitments to training, drills, reviews and audits, which will ensure a high degree of emergency preparedness and operational readiness on a continuous basis.
- Figures and tables which display detailed information and data such as organization charts, maps, etc.
- · Emergency Public Information Implementing Procedure.
- Site-specific of as and agreements pertaining to participating off-site organizations and agencies.

3.2 The Implementing Documents

The Emergency Plan Implementing Documents provide & "single source" of pertinent information and the procedures required by or useful to various emergency response organizations. The Implementing Documents, therefore, consolidate and integrate specific material described in such documents as the Emergency Plan, the State Plans, and the various County Plans.



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

The OCNGS Emergency Plan Implementing Documents provide:

- Administrative Procedures necessary to ensure a high state of readiness.
- Implementing Procedures which detail the emergency actions to be taken by appropriate plant personnel.



Number 2000-PLN-1300.01

Title
GPU Nuclear Emergency Plan for Oyster Creek Nuclear
Station

Revision No.

4.0 EMERGENCY CONDITIONS

4.1 Emergency Classification System

This Emergency Plan characterizes four classes of emergency situations which consist of mutually exclusive groupings covering the entire spectrum of possible emergency situations. Each class is associated with a particular set of immediate actions to be taken to perform: (1) accident classification, (2) notification of offsite agencies and support groups, and (3) mobilization of the applicable portion of the emergency organizations to cope with the situation and continue accident assessment functions. The various classes of emergencies represent a hierarchy of events based on potential or actual hazards presented to the general public. Emergencies may be classified in a lower category at first and then escalate to another, higher class if the situation deteriorates, as well as de-escalate as the situation improves.

Although mobilization of GPU personnel is generally keyed to a specific formal classification of emergency, declaration of an emergency is not a prerequisite for activation of GPUN emergency response organizations and facilities. However, activation and mobilization must occur if a prescribed emergency level is declared. Each of the four emergency classes are characterized by emergency action levels. These levels consist of specific sets of plant parameters (e.g., instrument indications, system status) that will be used to initiate emergency response including (1) emergency class designation, (2) notification, and (3) emergency organization mobilization. These emergency action levels are used to facilitate rapid assessment and accident classification and to attain rapid



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

readiness status on the part of emergency response persons and organizations. These levels have not been selected so as to infer any immediate need to implement protective actions but rather to ensure a reasonable amount of time is available to confirm in-plant readings by implementing assessment measures onsite and offsite. Once declaration of an emergency class requiring possible protective action occurs, dose assessments will be made by measurement and/or projection methods. The dose assessment values, along with other plant status assessments, will be reported to offsite agency officials as inputs for their decision on whether or not protective actions should be implemented for the blic. The relationship of these dose assessment values to the Environmental Protection Agency (EPA) Protective Action Guides (PAGs), as well as the possibility of approaching or exceeding the PAGs, will be reported. A specific methodology was used to relate Total Effective Dose Equivalent (TEDE), hereafter referred to as Total Whole Body Dose, and thyroid dose (CDE) emergency action levels of the Alert, Site Area and General Emergency classes to the EPA PAGs. The radiation

levels used in the Emergency Action Levels (EALs) were chosen such

that an individual exposed to these levels would receive a dose

NUREG-0654 Fraction of PAG

Alert \geq 0.01 Site Area Emergency \geq 0.05 General Emergency \geq 1.00

equivalent to the following fraction of the EPA PAGs:



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

The applicable PAG(s) for Oyster Creek Emergency Action Levels are 1 Rem total whole body dose (total effective dose equivalent) and 5 Rem thyroid dose (CDE).

The philosophy used to classify an emergency is to promptly declare the highest class for which an emergency action level is indicated, based on plant status or projected dose. For example, a Site Area Emergency would be declared directly if a Site Area Emergency action level is exceeded, even if the lower Alert class had not been previously declared. The classification system is designed to permit rapid evaluation of plant conditions based on comparison to established emergency action levels to facilitate prompt recognition and declaration of emergencies (typically within 15 minutes of the onset of an event).

Emergency action levels and corresponding indications requiring emergency declaration are found in the site's Emergency Plan Implementing Procedures (EPIP's). The intent of the stated values is to provide absolute values which, if exceeded, will initiate the required action for the given emergency classification.

Each of the four emergency classes, and the related emergency action levels requiring declaration of each class, are described in the following subsections.



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.


1

4.1.1 Unusual Event

The least severe of the four emergency classes defined by this Plan is called an Unusual Event. For the purposes of this Plan, an Unusual Event shall be defined as the occurrence of an event or events that indicate or allow recognition of a potential degradation of the level of safety of the plant.

The incident shall be classified as an Unusual Event only if the event is a minor one and no releases of radioactive material requiring offsite response or monitoring are expected. Events in this class are selected based upon a potential to degrade to a more severe situation rather than an actual public hazard.

In addition the Emergency Director shall also declare an Unusual Event any time that in his judgement plant conditions exist that warrant the activation of emergency centers and precautionary public notification. The Unusual Event class may be referenced by an action statement in a specific Emergency Operating Procedure, Abnormal Transient Procedure or Abnormal Operating Procedure. Steps in these procedures state that an Unusual Event has occurred or is occurring and require that an Unusual Event class of emergency be declared in accordance with the Emergency Plan Implementing Procedures. All Emergency Plan related actions (notification, etc.) will be carried out in parallel with the remainder of the Operating Procedures.



Number 2000-PLN-1300.01



Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

In exercising the judgement as to the need for declaring an Unusual Event, uncertainty concerning the safety status of the plant, the length of time the uncertainty exists and the prospects for resolution of ambiguities in a reasonable time period is sufficient basis for declaring an Unusual Event.

4.1.2 Alert

The next level of emergency class designated in this Plan is called an Alert. An Alert is the occurrence of an event or series of events that indicate and allow recognition of an actual or potentially substantial degradation of the level of safety of the plant. As in the case of an Unusual Event, the Alert class includes emergency situations that are expected to be minor in nature but where it has been deemed prudent to notify more of the off-site emergency response agencies and mobilize a larger portion of the emergency organization. In addition, because of the nature of the Alext class (releases of radioactive material possible), broader assessment actions will be started. Events that will initiate an Alert shall be those with the potential of limited releases of radioactive material to the environment or events that indicate a decrease in plant safety with potentially severe consequences. As before, a situation will only be classified at the Alert level if none of the emergency action levels for a higher class have been exceeded or are expected to be exceeded in the near term. The values specified are absolute action levels requiring declaration of the Alert emergency class.



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

In addition, the Emergency Director shall also declare an Alert any time that in his judgement plant conditions exist that warrant the activation of emergency centers and precautionary public notification.

This class of emergency may also be referenced by arrival at an action statement in specific Emergency Operating, Abnormal Operating or Abnormal Transient Procedures. Steps in these procedures state that an Alert has occurred or is occurring and require that an Alert class of emergency be declared in accordance with Emergency Plan Implementing Procedures.

All Emergency Plan related actions (notification, etc.) will be carried out in parallel with the remainder of the Operating Procedure (s).

In exercising the judgement as to the need for declaring an Alert, uncertainty concerning the safety status of the plant, the length of time the uncertainty exists the prospects for resolution of ambiguities beyond a reasonable time period and the potential of the level of safety of the plant is sufficient basis for declaring an Alert.

4.1.3 Site Area Emergency

The next level of emergency class designated is the Site Area Emergency. The Site Area Emergency class includes accidents in which actual or likely major failures of plant functions needed for protection of the public have occurred. Although immediate protective actions are not automatically required, declaration of a Site Area Emergency will set into motion all personnel on-site and off-site that would be required to



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

perform actions in preparation for a potential evacuation to off-site areas. Monitoring teams will be dispatched to make continuing assessments and provide officials with information necessary to make decisions concerning protective actions. The Site Area Emergency class includes accidents which have a significant radiation release potential. In addition, the Emergency Director shall also declare a Site Area Emergency any time that in his judgement plant conditions exist that warrant the activation of emergency centers and precautionary public notification. In exercising the judgement as to the need for declaring a Site Area Emergency, uncertainty concerning the status of the plant functions needed for protection of the public, the length of time the uncertainty exists, the prospects for resolution of ambiguities beyond a reasonable time and the potential degradation of the plant functions needed for protection of the public is sufficient basis for declaring a Site Area Emergency.

This class of emergency may also be referenced by arrival at an action statement in specific Emergency Operating, Abnormal Operating or Abnormal Transient Procedures. Steps in these procedures state that a Site Area Emergency has occurred or is occurring and requires that a Site Area Emergency be declared in accordance with Emergency Plan Implementing Procedures as a minimum.

All Emergency Plan related actions (notification, etc.) will be carried out in parallel with the remainder of the Operating Procedure (s).



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

It should be noted that, unlike the two previously described classes of emergency, the Site Area Emergency class may likely involve some radiation exposure to the public. Many of the accidents included in the class have the potential for degradation to the General Emergency class. Although the emergency action levels for this class have been selected at values which would result in off-site exposures below the protective action guides, off-site monitoring team reports and continuing assessment may lead to a decision warranting a recommendation for protective actions. If such a decision is necessary, a General Emergency shall be declared prior to issuing the protective action recommendation.

4.1.4 General Emergency

The most severe class of emergency defined by this Emergency Plan is the General Emergency. The General Emergency class includes accidents which involve actual or imminent substantial core degradation or melting with potential for loss of Reactor Building (containment) integrity (e.g. loss of two of three fission product boundaries with potential loss of the third), and other accidents that have large radioactive release potential such as fuel handling and waste gas system accidents.

In keeping with the philosophy adopted throughout this Plan, the emergency action levels are based on the EPA protective action guides and are used to (1) declare the emergency, (2) notify the appropriate authorities and support groups, and (3) mobilize the applicable portions of the emergency



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

organizations. However, this class of emergency is somewhat different in that protective actions are typically recommended within 15 minutes of declaration of the General Emergency since the lower limits of the protective action guides may be exceeded. The emergency action levels have been selected to be consistent with the site specific EAL methodology guidance. Confirmatory measurements in the field should be made prior to any expansion of the protective actions beyond the initial recommendation.

This emergency class may arise from an action statement in specific Emergency Operating, Abnormal Operating or Abnormal Transient Procedures.

4.2 State, County and Local Classification System

State, county and local emergency plans incorporate the same emergency classification system as that utilized by GPUN in this Plan. Since both the State and GPU Nuclear classification schemes include events which have significant potential for radioactive releases, it is imperative that specific guidance for initiating protective actions be available to the "decision-making" personnel in emergency response organizations and agencies. The State of New Jersey has, for planning purposes, adopted the Environmental Protection Agency (EPA) protective action guides (PAG's).

4.3 Spectrum of Postulated Accidents

Each of the discrete accidents that have been hypothesized for OCNGS is encompassed within the aforementioned emergency classification scheme.



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

4.3.1 Classification of Hypothetical Accidents

All of the design basis accidents hypothesized in Chapter 15 of the updated Oyster Creek FSAR fall into one of the four emergency classes. Table 3 lists each of these design basis accidents and the related emergency classification. A complete discussion of any of these hypothetical events may be found in the FSAR.

4.4 Instrumentation Capability for Detection

The plant instrumentation that will be used to promptly detect accidents at Oyster Creek is discussed in detail in the FSAR.

Table 4 lists each hypothetical accident and the important instrumentation that would be expected to detect each. Only major installed equipment is listed.



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

5.0 GPUN EMERGENCY ORGANIZATION

5.1 Mobilization

GPU Nuclear operates and provides technical support for the Oyster Creek site. A complete description of the corporate organization is contained in the GPU Nuclear Organization Plan. GPUN Emergency Response capabilities include On-Shift, Initial Response and Emergency Support Organizations. The On-Shift Emergency Organization includes members of the normal operating shift which assume an emergency posture to immediately respond to the emergency. The Initial Response Emergency Organization at OCNGS is comprised of rotating duty roster positions which maintain a one-hour response time, 24 hours a day, to relieve and or augment the On-shift organization as needed. The Emergency Support Organization is comprised of duty roster positions which maintain four hour and selected one hour response time, 24 hours per day, to augment the Initial Response Organization, as needed. Emergency manpower staffing for the GPUN site is presented in Tables 5, 6 and 7. The tables include: Emergency position; minimum number of personnel required; shift position, title or expertise; emergency duties and location and person to which each emergency position reports. The Initial Response Emergency Organization shall report to the duty station within 1 hour of notification of declaration of an Alert, Site Area or General Emergency. The Emergency Support Organization shall be fully manned within 4 hours of notification of declaration of a Site Area or General Emergency; however, the Emergency Support Director and designated members of the EOF staff will respond within one (1) hour as noted in Table 7.



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

5.1.1 Transition from Normal Shift Organization to Emergency Shift Organization

The OCNGS Normal Shift Organization is shown as Figure 6.

Requirements for minimum shift crews are specified in the OCNGS Technical Specifications. Licensed operators are provided on-site on a rotating shift basis to ensure the safe and proper operation of the plant 24 hours per day. In addition, personnel from other departments are assigned to shifts to provide additional capabilities. The Normal Shift Organization can be augmented, in an emergency, with designated/additional personnel within 60 minutes of notification.

NOTE

The Shift Supervisor position as described throughout this Plan includes the <u>Site Shift Manager</u>. The Shift Foreman position includes the Group Operating Supervisor.

The normal operating shift organization is generally described as follows:

Shift Supervisor is on duty at all times at OCNGS. The Shift Supervisor is the immediate position of authority and responsible for the safe and proper operation of the plant. The Shift Supervisor will be responsible for the initial evaluation of any abnormal or emergency situation and for directing the appropriate response. If it is determined that an emergency exists, those responsibilities assigned to the Emergency Director will be assumed by the Shift Supervisor.



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

The Shift Supervisor (or Senior Plant Representative) may request and direct activation of any or all emergency response organizations, or any portions there of, as he may deem appropriate, based on non-emergency plant conditions for which he perceives a need for additional support.

The Emergency Director will initiate appropriate actions, implement proper procedures, notify appropriate offsite emergency response organizations and agencies (e.g., risk county, OEM, NRC) and retain such responsibilities until relieved by the Initial Response Emergency Organization Emergency Director. During normal and emergency operations, the Shift Supervisor shall retain responsibility for the plant safety and shall maintain control over the conduct of operations and personnel in the Control Room unless relieved by a senior reactor operator (SRO) licensed management representative.

- The Group Operating Supervisor (GOS) assists the Emergency
 Director. In the absence of the Shift Supervisor, the GOS
 will assume his responsibilities.
- The Control Room Operators are responsible for the manipulation of controls as necessary to perform plant operations as directed by the GOS or Shift Supervisor.

 They are responsible to the GOS.
- The Equipment Operators are responsible for performing component and/or system operations outside the Control Room. They are responsible to the GOS.



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

- In addition to the operations personnel assigned to each shift, a Shift Technical Advisor will be assigned to each shift. He will serve as an advisor on plant safety to the Shift Supervisor. He shall have no duties or responsibilities for manipulation of controls or for command of operations.
- Radiological Controls Technicians will be assigned to each
 shift. These technicians are qualified to determine doses
 received by workers during the performance of their duties
 and will be available during emergencies on a
 24-hour-per-day basis to perform related functions.
- To provide for round-the-clock maintenance coverage, a
 maintenance crew is assigned to each shift. This crew
 typically consists of a foreman and several craft
 personnel providing capability in the mechanical,
 electrical, and instrumentation and controls disciplines.
- The Site Security Force provides round-the-clock security services in accordance with the Security Plan and procedures.



Number 2000-PLN-1300.01

Title
GPU Nuclear Emergency Plan for Oyster Creek Nuclear
Station

Revision No.

5.1.2 On-Shift Emergency Organization

An On-Shift Emergency Organization will be maintained for the site. Upon declaration of an emergency, members of the Normal On-Shift Organization gain additional responsibilities by assuming roles as the On-Shift Emergency Organization. This transition is shown in Figure 7. These roles are retained until these personnel are relieved by members of the Initial Response Emergency Organization or other qualified personnel. The On-Shift Emergency Organization is described as follows:

Emergency Director - The senior licensed individual in the Control Room (i.e., Site Shift Manager) assumes the duties of the Emergency Director. The individual assigned to the duties of Emergency Director, will assume overall charge of the plant emergency, ensure that the GPUN Emergency Plan is properly implemented and notify senior plant management. He shall retain his normal plant responsibilities in addition to these emergency responsibilities until properly relieved. When relieved, this individual may assume the Operations Coordinator position.

Due to the numerous responsibilities assigned to the Shift Supervisor at the onset of an emergency, he shall prioritize his actions to (1) ensure the safe operation of the plant, (2) ensure that immediate notification requirements are met, (3) obtain an operational and radiological assessment of the emergency, and (4) perform



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

additional emergency actions as designated in the plant procedures as time and conditions permit.

- GOS The next senior licensed individual in the control room, (i.e., Group Operating Supervisor) is responsible for directing the actions of the control room operators to return the plant to a safe condition. He may assume the responsibilities of the Operations Coordinator. When relieved, he again reports to the senior licensed individual, i.e., Shift Supervisor, etc., and continues to direct plant operations through the control room operators.
- Shift Technical Advisor The Shift Technical Advisor retains his normal duties to advise and assist the Emergency Director on plant conditions.
- assumes the role of ECC Communications Coordinator. This position is responsible to make notifications to offsite agencies until properly relieved. The remaining control room, equipment and auxiliary operators continue to support emergency plant operations. Call outs are made by Security.



Number 2000-PLN-1360.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

Radiological Assessment Coordinator - The Group

Radiological Controls Supervisor (GRCS) assumes the role

of Radiological Assessment Coordinator (RAC) and becomes

overall in charge of the radiological assessment effort.

This position reports to and advises the Emergency

Director in regards to in-plant, onsite and offsite

radiological conditions. As the RAC, he/she performs dose

projections, directs onsite and offsite

radiological/environmental survey teams and formulates

Protective Action Recommendations which are then relayed

to the Emergency Director. He/she also directs the

dispatch of Radiological Controls Technicians from the

OSC. The Group Radiological Controls Supervisor will turn

over the duties of the RAC when relieved.

· Operations Support Center Coordinator -

Operations/Maintenance Supervisor fills the Operations
Support Center (OSC) Coordinator position. His
responsibilities include chemistry, maintenance and
operations support. This position reports to the
Emergency Director until properly relieved. He may assume
the position of Emergency Maintenance Coordinator and
oversees emergency maintenance activities until properly
relieved.



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

- Chemistry Coordinator Senior Chemistry technician

 assumes the position of Chemistry Coordinator. This

 position reports to the OSC Coordinator and is responsible

 for sample procurement and analysis. When relieved, he

 returns to his normal duties of chemistry support.
- Security Coordinator The Security Coordinator position is filled by the Site Protection Shift

 Supervisor/designated Senior Site Protection Officer and is responsible for directing the security force, accountability, access control and interfaces with the local law enforcement agencies/EOD.

5.1.3 Initial Response Emergency Organization

Personnel are assigned to positions on the Initial Response Emergency Organization by the Director of the applicable Division or their designees. The Initial Response Emergency Organizations is illustrated on Figure 8. The duty roster assignments will be published to ensure that full coverage is provided. As a minimum, this organization will be manned at the Alert level.



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

5.1.3.1 Direction and Coordination

As previously stated, the Shift Supervisor will initially assume the responsibilities of the Emergency Director in the event of an emergency. Until personnel can be recalled to staff the Initial Response Emergency Organization, the Shift Supervisor will assign members of the on-shift organization to carry out the appropriate prioritized actions. In addition, he will ensure notification of the duty roster Emergency Director, who will relieve the Shift Supervisor of Emergency Director responsibilities upon his arrival in the TSC. If the Shift Supervisor is unavailable or becomes incapacitated for any reason, the GOS has the authority to assume the position of Emergency Director until properly relieved by a designated Emergency Director. The Operations Coordinator may assume the ED Role, if necessary, until properly relieved.

The Emergency Director has the authority and the responsibility to immediately and unilaterally initiate any emergency action, including providing protective action recommendations to authorities responsible for implementing offsite emergency measures.

Following notification of an existing or potential emergency, the Emergency Director will be



Number 2000-PLN-1300.01

Title

GPU Nuclear Energency Plan for Oyster Creek Nuclear Station

Revision No.

1

responsible for the assessment of emergency situations, especially where the emergency presents a real or potential hazard to offsite persons or property. The Emergency Director will implement the Emergency Plan through the use of specific Emergency Plan Implementing Procedures, activate necessary and/or required portions of the emergency organizations and, as appropriate:

- Establish the necessary communications to ensure that all emergency organizations are kept informed of the status of the emergency.
- Provide direction and support in the plant emergency mitigation process.
- Ensure that notification and reports to County,
 State, and Federal governments, are made in a timely manner.
- Interpret radiological data in terms of real-time measurements and projected radiological doses in order to evaluate the need to recommend offsite protective actions.
- Ensure adequate protective measures for the safety of personnel involved in emergency response efforts.



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

The Emergency Director is vested with certain authority and responsibility that shall not be delegated to a subordinate. Included are:

- Approving and directing official notifications to offsite agencies.
- Approving information for release to the news media. ED/ESD approval is not required for public announcement of formal emergency declarations and changes of emergency classifications.
- Approving and, if possible, personally conveying appropriate Protective Action Recommendations to the State (e.g., OEM-NJ)
- 4. Brief the NRC Site Team Leader and serve as principle "point of contact" for receiving NRC directives. However, NRC will interface with other GPUN emergency response personnel in mitigating the consequences of the emergency.
- 5. Classification of an emergency event.
- Directing onsite evacuation at the Alert or lower level emergency classification based on potential hazard to non-essential personnel.
- Authorizing emergency workers to exceed 10 CFR 20
 Radiation Exposure Limits.



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

8. Approving and directing deviation from
established procedures during plant emergencies
or during a declared National Security Emergency.
Procedures shall be followed unless the situation
dictates a valid need to deviate and in all cases
the deviation shall be documented. Emergency
Operating Procedures are written to address
emergency conditions and generally should be
followed with no deviations.

NOTE

For National Security Emergencies the following conditions must be met: 1) When this action is immediately needed to implement National Security Objectives as designated by the National Command Authority through the NRC, and 2) No action consistent with license conditions and technical specifications that can meet National Security objectives is immediately apparent.

No one other than a licensed SRO individual or
Senior Kanagement can make the decision to depart
from the Technical Specifications, the license or
license conditions (required by 10 CFR 50.54).

However, if a more senior manager is present
(i.e., Emergency Director) even though he does not
possess an SRO License the decision authority would
be passed to him as a higher authority in the chain
of command. The licensed SRO shall provide his best
judgement to the ED for consideration. Beyond that,
the SRO shall follow the orders of his supervision.



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

For emergencies at Oyster Creek the Emergency
Director shall consult the SRO and the technical
staff to the fullest extent practicable in arriving
at a decision to deviate from the Technical
Specifications, the license or license conditions
(required by 10 CFR 50.54).

If the decision is made to depart from technical specifications, license or license conditions (required by 10 CFR 50.54), notify the NRC before taking such actions, if time permits or if time does not permit, then within one hour. Deviations from Technical Specifications, the license and license conditions (required by 10 CFR 50.54) should only be authorized in extreme cases. However, only the specific portions of those GPUN Plans and Programs that implement the requirements of 10 CFR 50.54 need be considered when reporting deviations to the NRC. As an example, this Emergency Plan is a license condition required by 10 CFR 50.54. However a deviation from this plan does not necessarily require invoking 10 CFR 50.54(x). This emergency plan is required by 10 CFR 50.54 to meet the standards in 10 CFR 50.47(b) and the requirements of 10 CFR 50 Appendix E. Only the items in these two parts are the ones that need be considered when deciding the applicability of 10 CFR 50.54(x). Specific instructions on the applicable parts of the



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

GPUN Plans and programs required by the license and 10 CFR 50.54 will be contained in the implementing procedures.

NOTE

10 CFR 50.54(x) must be invoked when deviating from the Technical Specifications, License, license conditions (required by 10 CFR 50.54) or safeguards measures. This should only be done when such action is immediately needed for public health and safety and no other alternatives are apparent.

If the decision is made to depart from license conditions or technical specifications, notify the NRC before taking such actions, if time permits or if time does not permit, then within one hour. When the designated Emergency Support Director (ESD) arrives at the Emergency Operations Facility (EOF) and declares himself to be ready to assume that role, he will assume overall responsibility for management of the response to the accident and recovery operations. With activation of the ESD function, the ESD specifically will assume decision authority for Items 2, 3 and 4, above and may assume Item 1 if requested by the ED. Decision authority for Items 5, 6, 7 and 8 above will be retained by the Emergency Director (ED). Decisions on all of the listed actions normally will result from close and continuous consultation between the ESD and the ED and it is the responsibility of the ED to ensure the ESD is provided with the necessary information

55.0



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

to arrive at timely and appropriate decisions. In the special case of event classification, the ESD shall retain the prerogative to overrule the ED if, in the judgment of the ESD, uncertainty or other considerations exist to the extent warranting classification of a higher level of emergency than that classified by the ED. Directives from the NRC must come from the Director of the executive team (typically, the NRC Chairman) or the Director of Site Operations (typically, the NRC Regional Administrator). Such advice or directive can only be communicated to the Emergency Director (the Emergency Support Director when the EOF is activated). If a directive is issued by the NRC Director or Director of Site Operations, the ED/ESD should request written confirmation which spells out the specific nature of the directive. While the ED/ESD may challenge the advice of the NRC, the ED/ESD must comply with all directives. With respect to protective action recommendations for the public, the NRC may either endorse the GPUN recommendation or opt to recommend a different one. The ED/ESD is encouraged to include the NRC and State representatives in the protective action recommendation discussions in order to arrive at a mutually agreeable recommendation. In the event that the NRC opts to recommend a different



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

recommendation, they will communicate directly with the State. Their recommendation, like the utility recommendation, will be considered by the State in the development of a Governor directive.

Upon arrival of the NRC personnel, the ED/ESD should:

- Verify who is the senior NRC person in charge (Site Team Leader)
- Ask the Site Team Leader to inform the ED/ESD once he assumes the role of Director Site Operations and whether this designation also includes the responsibility to issue directives.
- Request that the NRC keep GPUN informed of all substantive information exchanges between the NRC and the State.
- Request that the NRC provide all directives in writing.

As a matter of policy, when a judgement is made by the senior person in the Control Room to declare an emergency based on a discretionary emergency action level, senior management will honor this decision unless it is in error.

To ensure that proper offsite authorities are kept fully informed of the emergency status and actions in progress, the Emergency Director will ensure that follow-up messages containing the following



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

information, if it is known and appropriate, are transmitted in a timely manner:

- Location of incident and name and telephone number (or communications channel identification) of caller
- Date/time of incident
- Class of emergency, nature of emergency, and plant status
- Type of actual or projected release and
 identification of potentially affected areas
- Estimate of quantity of radioactive material
 released or being released and height of release
- Isotopic and physical form of released material, including estimates of the relative quantities and concentration of noble gases, iodines and particulates
- Prevailing weather conditions (e.g., wind velocity, direction, temperature, atmospheric stability data)
- Actual or projected dose rates and integrated dose at exclusion area boundary and at about 2,
 5 and 10 mile radius, including sectors affected
- Surface radioactive contamination levels
- · Emergency response actions underway
- Recommended actions, including protective measures



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

- Request for on-site support from off-site organizations
- Prognosis for future course of event based on current plant information

5.1.3.2 Plant Staff Emergency Assignments

a. Assistance

The <u>RD Assistant</u> provides direct interface with the <u>ECC</u> Communications Coordinator, Emergency Assembly Area Coordinator, Security Coordinator and Public Information Representative. He then advises and assists the Emergency Director in matters pertaining to these areas.

b. Communications

The ECC Communications Coordinator will report to the ED Assistant. He will function as liaison between the ECC and GPUN Initial Response and Emergency Support Organizations, governmental agencies and other off-site support organizations (e.g. Technical support Center, Technical Support Representative, NRC headquarters,). The ECC Communications Coordinator will provide reliable and accurate communications in accordance with the appropriate Emergency Plan Implementing Procedures. In addition, he is responsible for maintaining records of outgoing and incoming communications. The ECC Communicators will



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

report to the ECC Communications Coordinator and be responsible for maintaining communications with the NRC as well as assisting in the notification process and receiving incoming calls.

c. Technical Support

The Technical Support Center Coordinator will report to the Emergency Director. The Technical Support Center engineers will assist the Technical Support Center Coordinator in analyzing current and projected plant status and, in close communications with the Emergency Director, provide technical support and recommendations regarding emergency actions. In addition, the Technical Support Center Coordinator will provide a direct intermediate with the Technical Support Representative and state at the EOF. Specifically, the Technical Support Center Center Coordinator and his staff will:

- Assume the position of technical advisor for the emergency.
- Provide technical support, analysis, and guidance in matters concerning specific plant request, equipment response, exceeding normal equipment operating limits and technical specifications, varying from normal and emergency operating procedures.



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

- Analyze reactor core, mechanical, electrical, and instrument and control problems; develop solutions; design and assist in the coordination of the installation of short-term modifications.
- Provide recommendations to the plant that would mitigate the consequences of the emergency.
- Assess the implications of actions taken and provide recommendations that would minimize damage to plant equipment, loss of plant assessment/monitoring capabilities, and reduce plant radiation and contamination levels.
- Analyze general plant conditions and develop guidance for the Emergency Director,
 Emergency Support Director and operations personnel.
- Analyze thermohydraulic and thermodynamic problems and develop solutions.
- Assist in the development of Emergency Procedures and Operating Procedures necessary for conducting emergency response operations, and resolve questions concerning Operating License requirements.



Number 2000-PLN-1300.01

ritle

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

 Provide technical support concerning plant operating procedures, emergency operating procedures and normal plant specific concerns.

d. Plant Operations

- (1) The Operations Coordinator is responsible for coordinating operations and maintenance activities through the Shift Supervisor and the Operations Support Center Coordinator.

 The Operations Coordinator may not relieve the Shift Supervisor or specifically direct plant operations unless he is a licensed Serior Reactor Operator. The Operations Coordinator will report to the Emergency Director.
- initially assumes the duties of the Emergency

 Director. Once relieved by the Emergency

 Director, he may assume the Operations

 Coordinator position and will be responsible for maintaining control over plant operations.

 He shall have the GOS, Shift Technical Advisor and the Operations shift personnel to assist him.
- (3) The <u>Shift Technical Advisors</u> will advise their respective Shift Supervisors on activities that impact the safe and proper operation of the plant.



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

- i.e., directing control room operators and assisting the Shift Supervisor. He reports directly to the Shift Supervisor and has the operations shift personnel report to him. He may assume the responsibilities of Operations Coordinator. When relieved, he again reports to the senior licensed individual, i.e., Shift Supervisor, etc. and continues to direct plant operations through the control room operators.
- (5) The Operations Shift under the direction of the Shift Supervisor, is responsible for the safe and proper operation of the plant at all times. Therefore, the operations shift will respond to all abnormal and emergency situations and take action as necessary to mitigate the emergency.

The shift organization will be self-reliant for a sufficient period of time to allow for initial emergency response, notification of required personnel, and the assembly and integration of response personnel into the emergency organization.



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

The station personnel are familiar with the operation of plant systems and the location and use of emergency equipment. Some members of each shift are trained in firefighting, first aid, and the use of radiation monitoring equipment. The duties of the operations shift during an emergency includes operating both primary and secondary plant systems, making initial notifications to off-site authorities and operational support to the emergency.

- is responsible for support Center (OSC) Coordinator
 is responsible for supporting operations in the
 areas of maintenance, first aid, search and
 rescue, chemistry and radiological controls. He
 reports to the Operations Coordinator. The
 Emergency Maintenance Coordinator, Chemistry
 Coordinator, and Medical Representative report
 directly to him.
- (7) The <u>Emergency Maintenance Coordinator</u> is responsible for directing the activities of maintenance personnel involved in emergency maintenance repair and corrective actions.



Station

GPUN Emergency Plan

Number 2000-PLN-1300.01

itle
GPU Nuclear Emergency Plan for Oyster Creek Nuclear

Revision No.

1

- (8) Shift maintenance personnel serve as the

 Emergency Repair Teams and shall report

 directly to the Emergency Maintenance

 Coordinator. They shall be used for emergency repair, search and rescue, drivers for radiation monitoring teams and fire brigade members (if qualified).
- (9) The Radiological Assessment Coordinator (RAC) is responsible for all on-site radiological assessment activities. The RAC reports to the Group Leader - R&EC after the Emergency Support Organization is activated. Initially, the Radiological Assessment Coordinator is responsible for directing the on-site and off-site Radiological/Environmental Survey Teams (after they are dispatched), Radiological Engineering Support, and the Radiological Controls Coordinator. He/she shall coordinate initial on-site and off-site radiological assessment activities, review results, report findings and make recommendations to the Emergency Director. In addition, he/she shall interface with the Environmental Assessment Coordinator to keep him/her current as to plant conditions and radiological source terms. The RAC will independently review dose projections from the



Number 2000-PLN-1300.01

ritle

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

computer based dose assessment program. The EAC will perform these dose projections independently. Redundant power supplies, hardware and software exist for RAC code utilization.

The Radiological Controls Coordinator will (10) report to the Radiological Assessment Coordinator (RAC) and will have the Radiological Controls Technicians report to him/her. He/she will be responsible for coordinating the in-plant radiological controls activities from the OSC and initially dispatching the Radiological/Environmental survey teams until they have established communications with the RAC. His/her functions include supervising the radiological controls technicians in the areas of radiological access control; radiological control coverage for emergency repair, corrective actions, search and rescue, first-aid, assembly area monitors, firefighting, and personnel monitoring. He/she will be responsible for prioritizing the immediate radiological controls response in-plant. The Radiological Controls Coordinator must keep the OSC Coordinator advised of the jobs he/she is covering in



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

order to effectively coordinate the in-plant radiological control needs with plant operational needs.

- report directly to the Radiological Controls

 Coordinator. In addition to the

 aforementioned functions, the technicians will

 also be responsible to assist the Radiological

 Controls Coordinator in the call out of

 additional technicians, and for performing as

 radiological/environmental survey team

 members. Additional technicians may be

 obtained by calling in off-duty technicians.
- (12) The <u>Chemistry Coordinator</u> will report directly to the OSC Coordinator. He shall be responsible for obtaining and analyzing all post-accident samples in accordance with procedures.
- (13) <u>Chemistry Technicians</u> will report directly to the Chemistry Coordinator at the OSC. They will perform all post-accident chemistry samples and analyses.



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

- (14) Radiological Engineering Support shall assist
 the RAC in performing dose projection
 calculations, source term calculations, and
 other calculations or determinations necessary
 to assess radiological hazards and to minimize
 personnel exposure.
- direct the muster of non-essential site

 personnel at the Emergency Assembly Areas.

 The Emergency Assembly Area Coordinators

 Report to the ED Assistant in the ECC.
- The Public Information Representative At the onset of an emergency, the duty Public Information representative is notified after the New Jersey State Police and implements the Emergency Public Information (EPI)

 Implementing Document. Another Public Information Representative is dispatched to the control room for information gathering.

 This representative will remain at the TSC during the emergency to provide technically accurate information to public information personnel who will be preparing information for release to the public. This information will be approved by the Emergency Director.
- (17) The <u>Medical Representative</u> is responsible for coordination of emergency medical support.



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

- (18) The <u>Security Coordinator</u> is responsible for the overall security response during an emergency. Coordinates the activities of the Site Protection Shift Supervisor and local law enforcement agencies/EOD.
- (19) The following functions will be performed by trained members of the normal shift complement:

a. Firefighting

Specific personnel on each shift (Site Fire Brigade) are trained in firefighting to ensure such capability will be available 24 hours per day. The Fire Brigade, under the direction of the Fire Brigade Team Leader or another individual designated by him, shall respond to all confirmed fire alarms or as directed by the Control Room and report to the location of the fire with assigned equipment. During the normal work week, additional qualified firefighting personnel will, as necessary, be obtained from the normal on-site organization. Assistance will be requested from local fire departments through the county dispatcher/appropriate local dispatch



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

system if deemed necessary by the Emergency Director.

b. First Aid and Search and Rescue

Medical emergencies and search and rescue operations will be the responsibility of the First Aid and Search and Rescue Teams. Specific personnel on each shift are trained in first aid techniques to ensure such assistance will be available 24 hours per day. Assistance will be requested from outside medical support personnel or organizations as deemed necessary by the Emergency Director.

c. Radiological Monitoring

Prior to the activation of the entire
Initial Response Organization, the
Radiological Assessment Coordinator (RAC)
may dispatch offsite and/or on-site
Radiological/ Environmental Survey Teams
to perform radiological monitoring
functions. Initially, the off-site and
on-site Radiological/Environmental Survey
Teams report directly to the Radiological
Assessment Coordinator. The Environmental
Assessment Coordinator (EAC) will assume
command of off-site radiological and
environmental assessment upon activation



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

Radiological/Environmental Survey Teams will either report directly to the EAC or return to the plant as instructed. The onsite Radiological/Environmental Survey Teams will continue to report to the RAC. The various survey teams are responsible for performing radiation/contamination surveys, other radiological monitoring as directed, and for assisting in assigned decontamination activities. A complete discussion of monitoring teams and dose assessment is contained in Section 6.4.1.

d. Security and Personnel Accountability

The site Security Force will operate in accordance with the established Security

Plan and Procedures. During emergencies, the Site Protection Shift Supervisor assumes the duties of the Security

Coordinator. The site Security Force will report to the Security Coordinator in emergency situations. The Security

Coordinator, in turn, shall report to the ED Assistant. The security force will respond and provide assistance as required for security controls. The security force will assume responsibility for personnel



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

accountability. In addition, provisions have been made in the Security Plan for admitting off-site emergency vehicles when Security is notified by the Shift Supervisor or Emergency Director and for escorting these vehicles to the proper location.

5.1.4 Emergency Support Organization

The Emergency Support Organization will provide technical and logistic support in the event of a serious or potentially serious emergency. An illustration of the GPUN Emergency Support Organization is included as Figure 9. This organization will be staffed by personnel from the normal station organization, the normal technical support organization, and consultants.

In general, the responsibilities of the Emergency Support Organization are to:

- Provide liaison and communications with the Nuclear Regulatory Commission and the appropriate State and county agencies.
- Provide for public relations activities and disseminate information to the public.
- Provide for environmental monitoring and assessment in support of the Initial Response Organization.
- · Provide security support.
- Support the Initial Response Organization in engineering and technical matters.



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

- Coordinate the restoration and/or operation of all generation, transmission and distribution facilities.
- · Procure and dispatch transportation equipment and services.
- Purchase materials, equipment, and services necessitated by the emergency.
- Provide assistance for re-entry operations and post-accident planning.
- Assign post-accident investigation and review responsibilities.
 - 1. The Emergency Suprort Director will be responsible for activating and directing the Emergency Support Organization and for ensuring that the functional groups provide a coordinated response in support of the Initial Response Organization. The Emergency Support Director shall report to the EOF within one hour of notification of declaration of a Site Area or General Emergency or when directed and will serve as the senior corporate management representative at or in the vicinity of the site. As such, during emergency operations, the Emergency Support Director will provide overall direction and policy guidance for the emergency response; the Emergency Director will retain primary responsibility for the operation and control of the plant. As emergency situations stabilize, the Emergency Support Director may expand his involvement in the technical direction of in-plant accident management. This will provide a controlled means of



Number 2000-PLN-1300.01

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station Revision No.

1

shifting to a recovery organization should that type of organizational arrangement be deemed appropriate. The Initial Response Emergency Organization shall report to the Emergency Support Director through the Emergency Director.

2. The ESD Assistant located at the EOF will assist the Emergency Support Director by interfacing with senior representatives of the Emergency Support Organization and providing status reports to the Emergency Support Director. The ESD Assistant assists and advises the ESD in matters pertaining to communications, technical support, implementation of the Emergency Plan and public information. In the absence of the Emergency Support Director, the ESD Assistant will not assume his emergency responsibilities. Rather, it will be the most senior (ESD qualified) operations person (e.g., Director OCNGS). Until the designated Emergency Support Director (ESD) arrives at the EOF, the person designated to coordinate the activities of the EOF is the ESD Assistant. His responsibilities are specifically limited to the activation of the EOF, coordination of activities prior to the arrival of the ESD, and communications with the Emergency Director (ED) located onsite. The ED retains decision-making authority as the senior corporate representative until the arrival of the ESD.



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

- 3. The Group Leader-Radiological and Environmental Controls

 (R&EC) also located at the EOF, functions as the "point of contact" for radiological and environmental information for the Emergency Support Director. The Group Leader R&EC collects information from the RAC and EAC and presents that information to the ESD. This position is overall-in-charge of the radiological and environmental controls effort. This position also maintains industrial health and safety responsibilities.
- 4. The <u>BOF Communications Coordinator</u> and <u>BOF Communicators</u>
 will be responsible for the operation of the communications
 systems at the Emergency Operations Facility and the
 coordination of requests for outside assistance. The EOF
 Communicators report to the EOF Communications Coordinator
 who, in turn reports to the ESD Assistant.
 - The setup and operation of primary communications systems.

Their duties include, but are not limited to:

- The setup and operation of backup communications systems.
- Maintaining records of communications.
- · Maintaining the status boards at the EOF.
- Coordinating the procurement of outside resources
 (e.g., technical assistance, manpower, equipment,
 etc.) with the Group Leader-Administrative Support.



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

5. The <u>Public Information Technical Representative/Emergency</u> Operations Facility (EOF)

Once the EOF is activated, the PI Tech Rep/EOF shall report to the EOF in a staff capacity and is responsible for gathering all approved and final information regarding the plant event and for providing the PI Tech Rep in the Joint Information Center with the most up-to-date information.

6. The <u>Public Information Technical Representative/Joint</u> Information Center (JIC)

Once the JIC is activated, the PI Tech Rep/JIC shall report to the JIC in a staff capacity and is responsible for retrieving information from the PI Tech Rep/EOF and being a single point of reference for those writing press releases and presiding over briefings.

7. The Media Center Lead/JIC

Once the JIC is activated, the Media Center Lead/JIC shall report to the JIC and is responsible for the command and control over the center's activities and moderator along press briefings and to interface with State and Local government communications personnel.

8. The Media Center Advisor/JIC

Once the JIC is activated, the Media Center Advisor/JIC shall report to the JIC and will serve as the technical spokesperson on the panel during press conferences.



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

9. The Press Release Writer/JIC

Once the JIC is activated, the Press Release Writer/JIC shall report to the JIC and will serve as the news release writer.

- 10. The Emergency Preparedness Representative, located at the EOF, will provide advice and information to the ESD Assistant relating to on-site, off-site and state emergency facilities, communication capabilities, personnel and resource availabilities and procedural requirements.
- 11. The <u>Technical Support Representative</u>, located at the EOF, shall provide technical assistance and long term planning to the Emergency Support Director and TSC, and shall assist in the review of news releases to ensure technical accuracy.
- 12. The <u>Group Leader-Administrative Support</u> and his staff will be responsible for administrative and logistic functions required to support the Initial Response and Emergency Support Organizations. The types of support services that might be required include, but are not limited to:
 - · General Administration
 - * Word processing
 - * Typing pool
 - * Reproduction
 - · Personnel Administration and Accommodations
 - * Personnel processing (Registration,

 Indoctrination and Training, Security badging)
 - * Lodging, food
 - * Transportation



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

- · Outside Plant Support
 - * Trailer set-up
 - * Janitorial service
 - * Telephones
- · Commissary
 - * Temporary facilities
 - * Meal delivery
- · Human Resources
 - * Manpower
 - * Labor relations
 - * Payroll
 - * Badging
- 13. The Environmental Assessment Coordinator (EAC) and staff will assume responsibility for all offsite radiological and environmental monitoring. The EAC and staff will respond within one hour upon notification of an Alert, Site Area or General Emergency. The Environmental Assessment Coordinator will be located in the Environmental Assessment Command Center and will initially report directly to the Emergency Director. Following activation of the EOF, the EAC will report to the Group Leader R&EC. He/she shall direct the staff's assignments which shall include, but are not limited to:
 - Determine real time meteorology data and input into the Dose Assessment System Code.
 - · Track and plot release plume direction and speed.



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

- In coordination with the RAC, support and/or conduct total whole body dose (TEDE) projection, thyroid dose (CDE) and bone dose commitment, as appropriate, at all Emergency Planning Zone boundaries and other locations as needed.
- Transfer vital information on plume travel and dose projections to the Group Leader R&EC and update the Radiological Assessment Coordinator.
- Serve as primary advisor to the Group Leader R&EC on matters concerning Protective Action Recommendations.
- In coordination with the RAC assess the impact of liquid and gaseous effluents with respect to
 Technical specifications and EPA protective action guides.
- Deploy and direct off-site Radiological/Environmental
 Monitoring Teams.
- Maintain communications with BNE regarding dose projection/assessment matters.
- Maintain an emergency and routine Radiological Environmental Monitoring Program (REMP) which includes off-site radiological/environmental monitoring.



Number

2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

5.2 Long-Term Recovery Organization

In those cases where post-accident conditions indicate that recovery operations will be either complicated or will extend over a relatively long period of time, GPT Nuclear will shift from the emergency response organizations (e.g., Initial Response and Emergency Support) to a long-term recovery organization. The functioning of the recovery organization will be dependent on the nature of the accident, post-accident conditions (e.g., plant conditions, radiation/contamination levels, etc.) and other factors to be determined at the time. Prior to initiating recovery operations, a specific long-term recovery organization will be defined based on the normal GPUN organization. A detailed discussion of recovery operations is provided in Section 9.



Number 2000-PLN-1300.01

Title
GPU Nuclear Emergency Plan for Oyster Creek Nuclear
Station

Revision No.

1

A typical long-term recovery organization is described as follows:

- The Office of the President, GPU Nuclear is responsible for overall recovery operations. This includes overseeing the operations of the various functional groups and ensuring that all activities, proposed courses of action, and contingency plans are subjected to proper analysis and coordination. Selection of senior personnel to fill the key positions in the long-term recovery organization will be based on the particular conditions. Specific functions internal to the Office of the President include Communications and Nuclear Safety Assessment.
- The <u>Comptroller</u>, <u>Financial</u> and <u>Planning Services</u> is responsible for financial reporting, accounting, budgets and material management support.
- The <u>Director</u>, <u>Communications</u> is responsible for the overall guidance and direction of the public relations and communications program to ensure distribution of information about the nuclear facilities to public officials, industry representatives, media, customers, employees and the general public.
- The <u>Director</u>, <u>Human and Adm</u>. <u>Services Division</u> is responsible for nuclear security, medical, human resources and information resources management.
- The <u>Director</u>, <u>Engineering Division</u> is responsible to provide engineering support, nuclear analyses, chemistry and materials, equipment reliability and configuration control procedures.



Number 2000-PLN-1300.01

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station Revision No.

1

• The <u>Plant Director</u> is responsible for ensuring the safe and efficient clean up of all radioactive waste and required decontamination of buildings for either return of the unit to full operation or decommissioning of the unit as a nuclear generating station in accordance with corporate policies, all applicable laws, regulations, licenses and technical requirements. In addition, they provide liaisons with the NRC. Manpower and commissary requirements will be coordinated with the appropriate division. The Plant Director is responsible for radiological health and safety, environmental affairs, emergency preparedness and training and education.

5.3 Additional Support

The nature of an emergency may require augmenting the GPUN emergency organizations with assistance from additional personnel and organizations. In order to ensure that support from local law enforcement, fire departments, hospitals, ambulance services and other organizations will be available on relatively short notice, agreements have been established with personnel and organizations. Agreements from offsite individuals, groups and agencies that support Oyster Creek may take one of the following forms:

- · Contracts
- · Letters of Agreement
- · Memoranda of Understanding
- · Formal Emergency Plans



Number 2000-PLN-1300.01

mi+1-

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

These typical support organizations include:

NOTE

While this list reflects letters of agreement currently in effect, it is possible that the list may change for a number of reasons. The EP Department will consider the impact that a loss of an agency will have on the emergency response process.

5.3.1 Medical Support Organizations and Personnel

- Community Medical Center
- · Southern Ocean County Hospital
- · Oak Ridge
- · Lacey Township First Aid Squad
- · Lanoka Harbor First Aid Squad
- · Waretown First Aid Squad

5.3.2 Firefighting Organizations

NOTE

These are supplemented by Mutual Aid agreements with other firefighting as organizations.

- · Lanoka Harbor Fire Department
- · Forked River Volunteer Fire Company
- · Waretown Fire Department
- · Bayville Fire Department

5.3.3 Law Enforcement Agencies

- · New Jersey State Police/Office of Emergency Management
- · Others as specified in the State Plans
- · Lacey Township Police Department



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

5.3.4 Other Government Agencies

- Nuclear Regulatory Commission
- Dept. of Commerce/NOAA
- · Dept. of Energy
- · Federal Aviation Administration
- . U.S. Coast Guard
- Dept. of the Army
- · Dept. of the Navy (Lakehurst NJ)
- · Others as specified in the State Plans
- · National Weather Service

5.3.5 Miscellaneous Organizations

- GPU Subsidiaries
- · Other utilities
- . The Institute for Nuclear Power Operations (INPO)
- · American Nuclear Insurers
- · General Electric
- · Aviation services

5.3.5.1 NEI/EPRI/INPO Coordination Agreement

In order to provide efficient and timely transfer of technical and public information regarding formal emergencies at nuclear power stations and maximize their assistance to their utility members and the industry, the Nuclear Energy Institute (NEI), the Electric Power Research Institute (EPRI), the Institute of Nuclear Power Operations (INPO) have



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

agreed to coordinate their actions and activities.

In general, support will be provided as follows:

- NEI Technical & Regulatory Division will maintain an emergency response capability for consultation on regulatory issues.
- NEI Industry Communications and Publications

 Division will develop and issue, in coordination

 with the affected utility, appropriate public

 statements to the news media, as necessary.
- INPO will provide the Nuclear Network electronic communications system to its members, NEI and EPRI to facilitate the flow of media and technical information about the emergency to other INPO members and participants and coordinate the flow of technical information amon, the parties to the agreement.
 - capability and be available for consultation and to conduct in-depth analysis of the emergency as appropriate. Both EPRI and INPO will be available to assist the affected utility through their analysis capabilities. EPRI and INPO will coordinate such efforts with each other.

 Specific details can be obtained by consulting the NEI/EPRI/INPO Coordination Agreement which is maintained on file by the Emergency

 Preparedness Department.



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

5.4 Government Agencies

GPU Nuclear has and will continue to work closely with Federal, State and County agencies in coordinating emergency preparedness activities for the Emergency Planning Zones to ensure the health and safety of the general public. As a part of this coordination, each participating agency has been assigned specific responsibilities and authority for both emergency planning and emergency response. Also as a part of this combined effort, specific emergency-related notification and information reporting requirements have been defined between GPU-Nuclear and the various participating agencies. Information pertaining to emergency-related offsite notification requirements that activate the emergency response organizations and the subsequent information reporting requirements is provided in Section 6.1. Additional reporting requirements, contained in 10 CFR 50.72, 10 CFR 50.73, and plant (safety) Technical Specifications, will also be met. A brief description of the key elements of the role of each of the participating Federal, State and County agencies is provided in the following subsections.

5.4.1 Federal Radiological Emergency Response Plan

The Federal Radiological Emergency Response Plan (FRERP) is to be used by Federal agencies in peacetime radiological emergencies. It primarily concerns the offsite Federal response in support of State and local governments with jurisdiction for the emergency. The FRERP: (1) Provides the Federal government's concept of operations based on specific authorities for responding to radiological emergencies; (2) outlines Federal policies and planning assumptions that



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

underlie this concept of operations and on which Federal agency response plans (in addition to their agency-specific policies) were based; and (3) specifies authorities and responsibilities of each Federal agency that may have a significant role in such emergencies. The FRERP includes the Federal Radiological Monitoring and Assessment Plan (FRMAP) for use by Federal agencies with radiological monitoring and assessment capabilities.

5.4.1.1 Nuclear Regulatory Commission

When the licensee notifies the NRC of an incident, the initial NRC response is to ascertain the status of the plant and monitor licensee activities. The purpose of this monitoring role is to assure that the public and the environment are fully protected. The NRC (and other organizations) will measure offsite radiological effects and will develop a projection of on-site and off-site effects for use by other Federal State and local agen _s. If and when the NRC determines that there is a potential threat to the public or the environment, it will begin to monitor more intensively to develop an NRC assessment of the problems. The NRC will offer specific advice to the licensee to help solve or limit the consequences of the problem. In addition to monitoring and advisory activities, in some unusual and very rare situations, the NRC could find it necessary to intervene in a limited



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

fashion to direct the licensee's onsite response; however, it is not expected that NRC will be required to assume this role. In such an unlikely event, the NRC would issue formal orders to the licensee to take certain measures and then monitor implementation of the actions ordered. In this role, the licensee continues to make other key operational decisions and to operate and manage the facility with licensee personnel Directives from the NRC must come from the Director of the Executive Team (typically, the NRC chairman) or the Director of Site Operations (typically), the NRC Regional Administrator). NRC directives would be channeled to licensee management; (ED until the ESD is available).

To ensure reports can always be made, the NRC

Headquarters Operations will be called. The

Headquarters Operations Officer will record the call

and bridge it to the Region I Duty Officer and

Manager on call.

The NRC in conjunction with FEMA whenever possible, will present any Federal recommendations to the State or other appropriate offsite authority with jurisdiction for implementing or relaxing protective actions. In the case of a fixed nuclear facility licensed by the NRC, the licensee is responsible for developing appropriate protective action



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

recommendations and promptly providing those recommendations to State and local authorities with or without NRC's concurrence. NRC will evaluate the licensee's protective action recommendation as time permits and will either concur in them or suggest modifications, as appropriate. In the event NRC opts to recommend a different recommendation, they will communicate directly with the State. Their recommendation, like the utility recommendation, will be considered by the State in the development of the Governor's directive. FEMA is then responsible for promoting coordination among Federal agencies providing assistance to the State in implementing those recommendations if such assistance is requested by the State, and for communicating those recommendations to the responding Federal agencies.



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

5.4.1.2 Department of Energy

The Department of Energy (DOE), during the initial phases of the emergency, and the EPA thereafter, will work with the appropriate State and local agencies to coordinate offsite radiological monitoring and assessment activities. DOE or EPA will assess monitoring data and present them to the NRC and appropriate State agencies. The NRC will use this information, together with its assessment of the current condition and prognosis of the emergency on site, to develop or evaluate public protective action recommendations.

5.4.1.3 U.S. Coast Guard

During a radiation emergency at OCNGS which could involve exposure to offsite personnel, the U.S.

Coast Guard and NJ Marine Law Enforcement Bureau will provide assistance by notifying mariners, maintaining water traffic control, and implementing protective and parallel actions as directed. The N.J. State OEM will coordinate the emergency response activities of these agencies in support of OCNGS.

5.4.1.4 Department of the Army

The local Ordinance Detachment, Department of the Army, will provide an Explosive Ordinance Disposal capability in response to requests for assistance in the event of a bomb threat.



Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

5.4.1.5 Taderal Aviation Administration

The Federal Aviation Administration will ensure air traffic is diverted in the event of an emergency situation with a potential for radioactive release.

5.4.1.6 National Weather Service

The National Weather Service will provide backup meteorological information upon request.

5.4.2 State Agencies

The planning for, and response to a radiological emergency at the GPUN site is the joint responsibility of GPU Nuclear and the state/county/local governmental agencies. GPU Nuclear is responsible for onsite emergency response. In order to fulfill this responsibility, GPU Nuclear relies on various offsite agencies, both governmental and private, to provide assistance beyond that available onsite. The state of New Jersey, through the various state, county and local agencies, is responsible for offsite emergency response. In order to fulfill this responsibility, the state relies on GPU Nuclear to provide necessary information on plant status and radiation releases. Recognizing the joint nature of their responsibilities, GPU Nuclear and the relevant governmental agencies have coordinated their emergency planning and have provided for adequate and redundant communication systems to coordinate their response during an emergency event. The New Jersey State Police, Office of Emergency Management, is responsible to coordinate emergency services in the State of New Jersey.



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

5.4.2.1 New Jersey Office of Emergency Management

The New Jersey Office of Emergency Management (OEM) has been assigned the responsibility for developing a statewide radiation emergency response plan. Annex B to the State of New Jersey Radiological Emergency Response Plan serves as a reference document incorporating the policy, the concept of operation, the rationale for chosen guidelines, and the relevant statutory documents. The OEM is the lead agency and coordinates the efforts of all state support agencies.

The Office of Emergency Management coordinates actions and operations involving public response and furnishes resources required to support decisions affecting exposure control.

This agency initiates communications with county and municipal authorities through the County Emergency

Management Coordinator. Ocean County and each municipality has contingency plans indicating actions to be taken upon notification of an emergency condition by the Office of Emergency Management.

Primary contact with state authorities is through the

New Jersey State Police Office of Emergency Management

and the Headquarters Communications Bureau. This office
is responsible for notifying other State and federal
agencies and for providing assistance to state and local
authorities in implementing emergency actions.



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

5.4.2.2 New Jersey Department of Environmental Protection, Bureau of Nuclear Engineering

The Bureau of Nuclear Engineering is responsible for responding to a radiation incident within state boundaries. They will assess the radiological hazard and provide technical guidance and recommendations concerning the execution of protective actions for the general public.

5.4.3 County Agencies

The Ocean County Office of Emergency Management (OEM) is the established emergency response organization that will serve each affected municipal OEM in a coordination and support capacity. It will assume the coordination of all intermunicipality communications and emergency operations. Upon receipt of notification of a radiological emergency at OCNGS which requires a County response, the Ocean County Emergency Operations Center (EOC) will be activated. The Ocean County EOC will serve as the focal point for County emergency operations and protective actions for the duration of the emergency. Personnel and resources of the County agencies employed in local emergency operations will be under the operational control of the Director of the Ocean County Board of Chosen Freeholders and will be coordinated by the Ocean County Emergency Management Coordinator in accordance with direction received from the State Office of Emergency Management.



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

6.0 EMERGENCY MEASURES

This Section describes the notifications and specific actions that will be taken for each class of emergency and is used as the basis for detailed Emergency Plan Implementing Procedures. Emergency measures all begin with (1) the recognition and declaration of an emergency class, (2) notification of the applicable agencies, and (3) mobilization of the appropriate portions of the emergency organization. Implementation of these measures are organized into emergency notification of offsite agencies, corrective actions, on-site protective actions, offsite protective actions, environmental assessment, offsite agency response and emergency public information.

6.1 Emergency Notification of Offsite Agencies

Parameters that establish emergency situations have been predetermined and specified as emergency action levels and included in procedures contained in the site Emergency Plan Implementing Documents. When conditions or criteria specified in one of these procedures are met or exceeded, an emergency classification (i.e., Unusual Event, Alert, Site Area Emergency or General Emergency) must be declared. The senior management person must classify and declare the emergency and ensure that all required notifications are made. Messages, developed in conjunction with State and local agencies, have been specified in Emergency Plan Implementing Procedures and will be used to provide information relative to the emergency class, (i.e., type and magnitude of any actual or potential release, affected populace and areas, and any recommendations to take protective actions). The NJ State Police provide verification of initial notification at OCNGS. For initial notification/escalation of an Unusual Event, Alert or a Site Area



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

Emergency OCNGS will notify NJ State Police (OEM) and the NRC. For General Emergencies OCNGS notifies NJ State Police (OEM), Ocean County, Lacey and Ocean Townships directly and the NRC. In addition to the initial notification and verification, communication channels will be maintained between the facility and offsite emergency response organizations to allow for any further dissemination and update of information concerning the emergency. The communications network that has been established at OCNGS for notification requirements, information reporting, and decision making is presented as Figures 10 and 7.

Offsite emergency support from Federal, State and local agencies will be coordinated by the State of NJ in accordance with their (state)

Radiological Emergency Response Plan.

6.2 Corrective Actions

Detailed operating procedures are available to the operators for use during emergencies as well as normal operations. Specific Emergency Procedures are provided to assist the operators in placing the plant in a safe condition and taking the necessary supplemental corrective actions. In addition, operations personnel are trained in the operation of plant systems and their associated procedures and will be capable of taking appropriate corrective actions.

Selected staff personnel, including operations, radiological controls, and maintenance personnel, are trained and assigned to emergency teams. These teams will be able to respond as set forth in the Emergency Plan Implementing Procedures in order to assess conditions and take any available corrective actions. Maintenance personnel will provide the



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

necessary crafts expertise to affect repair and damage control functions.

Corrective actions will normally be planned events that are taken to ameliorate or terminate the emergency situation. Planned radioactive releases or corrective actions that may result in a radioactive release will be evaluated by the Emergency Director and/or Emergency Support Director and staff as far in advance of the event as possible. Such events and data pertaining to the release will be reported to the appropriate offsite emergency response organizations and agencies.

6.3 Onsite Protective Action

Protective actions are emergency measures taken during or after an emergency situation which are intended to minimize or eliminate the hazard to the health and safety of the general public and/or Site personnel. Such actions taken onsite are the responsibility of GPU Nuclear while those taken offsite fall under the jurisdiction of the State and other offsite response agencies.

6.3.1 Sheltering, Evacuation, Personnel Accountability

During an emergency, personnel may be required to temporarily relocate to prevent or minimize exposure to radiation and radioactive materials. The following subsections discuss the policies applying to sheltering, evacuation and personnel accountability during emergencies at the Oyster Creek site.

6.3.1.1 Station Personnel

At the time an emergency is declared, an announcement is made on the site public address system to all personnel within the Owner Controlled area. The announcement will include the



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

classifications of the event, a brief description of the event, and actions taken by site personnel.

Shift personnel will proceed to their emergency assignments.

The primary protective measures for onsite personnel during an emergency is prompt evacuation from areas which are affected by significant radiation, contamination, airborne radioactivity or other personnel hazards. All persons onsite at the time an emergency is declared shall be notified by means of the plant page supplemented by designated personnel providing notification in areas that the page does not cover. Upon declaration of a Site Area Emergency or General Emergency and/or at the discretion of the Emergency Director, all essential personnel within the Protected Area will be individually accounted for at the ECC, TSC and OSC unless other factors (e.g., security events) advise against it. When directed, all non-essential personnel report to an Emergency Assembly Area. This process allows for personnel mustering, monitoring and evacuation as needed. This procedure provides the ability to initially account for all essential personnel and identify all missing persons within the Protected Area within 30 minutes. If by 60 minutes full accountability is not achieved, search and rescue should be initiated.



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

Non-essential personnel shall be evacuated from the site based upon:

- · Declaration of a General Emergency, or
- The discretion of the ED, if emergency conditions
 warrant evacuation unless other factors (e.g.,
 tornadoes, security events) advise against it.
 Consideration of protective actions (e.g.,
 relocation, respiratory protection) for essential
 personnel should be done on the same basis.

Evacuation routes will be determined by the

Emergency Director based on the prevailing

radiological conditions. This evacuation will be
accomplished using private vehicles to relocate to
the Remote Assembly Areas.

Upon declaration of a General Emergency, or at the discretion of the Emergency Director, all non-essential personnel will be directed to proceed to their vehicles directly and to evacuate to the Remote Assembly Areas.

In support of these operations, a sweep of buildings, trailers, and other areas of the Owner Controlled area will commence to ensure that all persons have assembled and/or evacuated the site.

Search and rescue operations will be implemented to locate any missing persons.

At the Remote Assembly Area, personnel and vehicles will be monitored for radioactive contamination.



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

Individuals found to be contaminated will be decontaminated in accordance with applicable Radiological Controls Procedures. Vehicles found to be contaminated will be impounded until they can be decontaminated. Inclement weather will not affect the direction of the traffic flow, but may increase evacuation times.

The licensee retains complete authority to determine and maintain sufficient control of all activities including the authority to exclude or remove personnel and property for land areas within the exclusion area and contamination will, thereby, be controlled. In addition, there are no areas for producing agricultural products within the exclusion area. In-plant contamination control will be in accordance with approved Radiological Controls procedures.

6.3.1.2 Emergency Personnel Exposure

Emergency personnel, including those involved in removal of injured persons, undertaking corrective actions, performing assessment actions, providing first aid, performing personnel decontamination, providing ambulance service, and providing medical treatment services, will have their dose minimized. This is accomplished through normal Radiological Controls Practices onsite. When offsite emergency personnel are called to respond to Oyster Creek,



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

qualified Radiological Controls technicians are provided to support these teams. For example, a Radiological Controls technician is assigned to the offsite fire teams to monitor and control radiation exposures and evaluate radiological hazards.

Emergency measures may warrant the acceptance of greater than normal radiation exposure (doses). Lifesaving, measures to prevent substantial radiation exposure to the population or preservation of vital equipment may be sufficient cause for greater than normal exposures. The following are the exposure guidelines for these emergency activities:

Life saving action - No pre-established limit

Corrective action - 10 Rem total whole body dose

(TEDE), 30 Rem to the lenses of the eye, or 100 Rem total organ dose to any organ.

The Emergency Director is the designated individual who can authorize emergency workers to receive doses as defined in excess of 10 CFR 20 limits. These workers must be volunteers and will be required to closely adhere to the controls specified in applicable procedures. In authorizing onsite volunteers to receive radiation exposure in the course of carrying out lifesaving activities, the Emergency Director shall balance the risks from such exposures against the benefits to be received from



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear

Revision No.

1

the lifesaving activities. Risks are determined and decisions are made to expedite lifesaving activities based upon advance radiation surveys done at the affected areas to determine stay times, shielding requirements, or the possibility of dispatching a "scouting" team to assess actual conditions.

Measures will be utilized to aid in exposure reduction and the Emergency Director, in consideration of advice from the Radiological Assessment Coordinator, shall assure that all possible measurements are taken to minimize other exposures (such as internal exposures) during the activities.

All personnel who are members of the emergency response teams and who have emergency duties consite are issued dosimetry including self-reading dosimeters. Additional provisions have been made for dosimetry issue at the site entrance gates or other locations, if required. This dosimetry will be periodically read and recorded in accordance with approved site Radiological Control Procedures.



Number 2000-PLN-1300.01

Title
GPU Nuclear Emergency Plan for Oyster Creek Nuclear

Revision No.

6.3.2 First Aid and Decontamination

· First Aid

Emergency first aid and medical treatment will be given to injured personnel who may or may not be contaminated. Shift personnel, trained in first aid, will be available onsite on a 24-hour per day basis and will assist contaminated personnel at the scene of the accident. Provisions have been made, through agreements, to ensure contaminated and injured personnel will receive specialized medical treatment, if necessary. Local hospitals in the vicinity of the Oyster Creek site have agreed to accept contaminated patients for emergency medical and surgical treatment and/or observation. A comprehensive program of radiological control for injured/contaminated personnel has been developed and will be instituted when necessary during an emergency. The primary emphasis will be to initially address traumatic or life-threatening injuries since radiation injuries may not be immediately life threatening. Detailed instructions for treatment and transportation of

Detailed instructions for treatment and transportation of contaminated and imjured individuals are specified in appropriate procedures.



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

· Decontamination

accomplished at the Radiological Controls Access Control Point where specialized equipment and supplies are available. Procedures are written with specific details for decontamination. For personnel within the Protected Area, emergency situations which require decontamination will be handled in accordance with these procedures and the Emergency Plan Implementing Document. All personnel leaving a Radiologically Controlled Area will be monitored for contamination. Any individual found to have contamination levels in excess of 100 net cpm (above background as measured by a pancake probe at 1/2 inch) at the site will be considered contaminated. Personnel found to be contaminated will undergo decontamination by radiological controls personnel (or other designated personnel as specified in Radiological Controls or Emergency Plan Implementing Procedures). Measures will be taken to prevent the spread of contamination. Such measures may include isolating affected areas, placing contaminated personnel in "clean" protective clothing before moving, and decontaminating affected personnel, their clothing and equipment prior to release, in accordance with applicable station Radiological Controls Procedures. In the event that a release of contaminants has occurred

Personnel and equipment decontamination will be initially

or is occurring, in-plant potable water systems will be



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

secured to prevent possible contamination. If food and water supplies are brought in for emergency personnel who remain on-site these supplies will be packaged in sealed containers and will be monitored by Radiological Controls personnel (using standard Rad Con practices and procedures) prior to use or consumption and on a normal routine basis. Any food or water supplies discovered to be contaminated will immediately be disposed of as waste and will not be used.

Upon receipt of information that the emergency has entered recovery phase, in-plant facilities and areas will be surveyed, sampled, and cleared for use, or controlled as necessary, in accordance with applicable Radiological Controls practices.

If it becomes necessary to declare an onsite evacuation, personnel from outside the Protected Area will be directed to proceed to the Remote Assembly Area. Upon arrival at the Remote Assembly Area, personnel will be monitored for contamination. If anyone is found to be contaminated, showers, sinks and decontaminating supplies are available in close proximity to the plant site. Equipment for decontamination personnel will be stored in Emergency Supply Lockers. Portable survey instruments are available and routinely calibrated for use in decontamination operations. All skin contamination problems will be treated using accepted Radiological Controls practices.



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Cyster Creek Nuclear Station

Revision No.

1

For contaminated personnel inside the Protected Area, the preferred decontamination facility will be the onsite Monitor and Control Station if accessible, otherwise offsite facilities will be used.

6.3.3 Medical Transportation

Agreements have been made with local medical support organizations to provide ambulance services to the GPUN site. Ambulance personnel will be certified in accordance with State regulations. GPU Nuclear will offer training to the squad members in the treatment and transportation of contaminated injured individuals. GPU Nuclear will provide radiological control technicians if available to assist the squads enroute to the hospital. Ambulance service for the facility is provided by GPU Nuclear or local first aid squads. When affected personnel must be transported, measures will be taken to prevent the spread of contamination. Such measures will include placing affected personnel in "clean" protective clothing or wrapping in blankets. The Emergency Director will insure that the organizations who will provide the transportation and treatment are alerted. Detailed instructions for treatment and transportation of contaminated and injured individuals are specified in appropriate procedures.



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

6.3.4 Medical Treatment

Arrangements for hospital and medical services for injured or contaminated/overexposed personnel are provided for by letters of agreement.

The first level of treatment can be given on-site. On-site emergency medical services will be rendered by qualified site personnel. If the severity of the injury requires more extensive or prolonged treatment, the patient will be transported for the second level of assistance. For conventional injuries (that is, non-radiation injuries), the patient will be transported to any of the local hospitals. Arrangements for hospital and medical services for injured and/or contaminated/overexposed personnel are provided by Community Medical Center, and Southern Ocean County Hospital, NJ. These hospitals have agreed to accept contaminated patients for emergency medical and surgical treatment or observation. Detailed plans and procedures are in place for decontamination and treatment of contaminated patients.

6.4 Environmental Assessment

6.4.1 Radiological Assessment and Offsite Monitoring

Prior to the activation of the entire Initial Response

Organization, offsite radiological/environmental survey teams

may be dispatched. These teams will consist of one to two

persons per team, trained in the use of portable radiation

monitoring equipment. When dispatched, the teams will pick up

portable radios, and emergency kits containing portable

monitoring equipment. Emergency kit inventory lists are



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear

Revision No.

1

included as Tables 8. After an operational check of the equipment, including a radio operability check, they will proceed in an emergency vehicle to their first monitoring location. They will be controlled by the Radiological Assessment Coordinator and will report directly to him/her. The site has the capability to dispatch up to two radiation monitoring teams within one-half hour of the emergency declaration, if necessary.

Procedures are in place which enable monitoring teams to detect airborne radioiodine and particulates under field conditions in the presence of noble gases and background radiation.

For gaseous releases, the first step in the initial assessment process is to estimate the radioactive source terms in microcuries per second. To do this, the radiation monitoring system readings for each monitored effluent release path are converted to a source term by applying the appropriate ventilation flow rates, meter conversion factors, containment building design leak rate, etc. using a computer program developed by GPUN known as the RAC Model. The RAC Model prompts the user for specific entries, e.g., meter readings and release type, to estimate the radiological source terms by isotope. This model, using real time meteorological data directly from the on-site monitoring system, performs off-site dose calculations of the total whole body dose (TEDE) and thyroid dose (CDE) based on the expected or a default duration.



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

These integrated doses are examined in the context of the EPA PAGS and an estimate of time to reach the PAGS, assuming constant release rate and source terms. After the projections are made, the radiation monitoring teams can be directed to the location of interest to take readings and confirm the projection. Radiation Monitoring team lata lend credence to the dose projection process, better quantify ground receptor dose rates and alert plant personnel of any unmonitored release pathways or potential problems in the dose projection process. Dose calculations and projections are relayed to the BNE in NJ.

If the instrumentation used for radiological assessment is off-scale or inoperative, the Radiological Assessment Coordinator may utilize in-plant sample data from the affected ventilation pathway. In lieu of instrumentation or in-plant sample data, the RAC must utilize contingency calculations. The contingency calculations are based on plant conditions. Concurrently, radiological/environmental survey teams are sent to these locations of interest to take actual field measurements in order to verify the projections and to correlate projected versus actual results. These detailed calculational techniques are included in the Emergency Dose Calculation Manual (EDCM) and incorporated as part of the RAC Model.

For liquid releases, the radionuclide concentration at any downstream location is determined by taking liquid effluent concentrations and applying the effluent flow rate and



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

volumetric flow rate of the receiving water. Downstream users will be notified to curtail intake if the projected concentration is above the level specified in the procedures. When the Environmental Assessment Coordinator (EAC) is ready (typically within one hour of the declaration of an Alert or higher classification), the responsibility for offsite radiological and environmental monitoring will be transferred to the Environmental Assessment Coordinator. (NOTE: The Radiological Assessment Coordinator will maintain control of the onsite radiological/environmental survey team(s) and onsite radiological controls assessment. The EAC will assume offsite radiological and environmental monitoring but the RAC will retain the duty of performing dose projections. The EAC will perform these dose projections independently. In addition, the BNE liaison in the EOF makes independent assessments and maintain contact with BRP/BNE headquarters. Two field monitoring teams can be dispatched at each site during an emergency situation. This can be backed-up with two additional teams, should it become necessary. The Environmental Assessment Command Center generally communicates with the field teams using two-way radios. Field data can be relayed to both the ECC and Emergency Operations Facility using separate dedicated phone lines from the Environmental Assessment Command Center. Verification of the model projections will be accomplished by comparisons with field monitoring team results.



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

-

The Environmental Assessment Coordinator and his staff, located at the EACC, have the following capabilities:

- Obtain additional monitoring teams from the OCNGS and
 other Nuclear sites
- Obtain and evaluate meteorological forecast information and evaluate effects of atmospheric releases.
- Obtain additional expertise in the areas of meteorology and dose projections from OCNGS and other Nuclear sites
 Typical environmental/radiological monitoring equipment is listed in Table 9.

6.5 Offsite Protective Actions

6.5.1 General Public

The Emergency Support Director/Emergency Director shall be prepared to provide protective action recommendations, as appropriate. Initially, the Emergency Director is responsible to develop recommendations, however, this function is assumed by the Emergency Support Director in coordination with the Emergency Director after the EOF is activated.

Recommendations are developed when it is apparent that a release is possible or underway and dose projections indicate protective actions may be required for the public and within approximately 15 minutes of the declaration of a General Emergency.

The responsibility for actions to protect persons in offsite areas rests with the State and is described in detail in the State Emergency Plan and implemented in conjunction with the county emergency plans.



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

The State Bureau of Nuclear Engineering is the specific agency responsible for evaluating information from the GPUN staff and all other sources and recommending to NJ OEM that protective actions be taken. The BNE has sheltering and evacuation as protective action options. The most appropriate protective action for a particular situation will depend on the magnitude of the release, duration of the release, wind speed, wind direction, time of day and transportation constraints. In the case of a General Emergency, circumstances may indicate the immediate need to initiate some precautionary protective action. This judgment is the responsibility of the BNE and should be based on an evaluation of the current plant conditions, dose projections relative to the PAG's and expected subsequent plant operations/evaluations. GPU Nuclear, through the Emergency Director (Emergency Support Director when the EOF is activated), shall remain ready throughout an emergency to provide Protective Action Recommendations to State officials. General Protective Action Recommendation methodology is shown in the respective site implementing procedures.

Off-site it is the responsibility of the State Department of Agriculture, in conjunction with the Departments of Environmental Resources/Protection and Health, to issue guidance and coordinate actions to control contaminated agricultural products.

The means to warn or advise involved persons is a responsibility of the risk county. The risk county, in



Number 2000-PLN-1300.01

Title
GPU Nuclear Emergency Plan for Oyster Creek Nuclear
Station

Revision No.

1

coordination with the State, is also responsible for the preparation and dissemination of information material for the general public on protective actions including necessary information (evacuation routes, maps, etc.) for the implementation of protective measures in the Plume Exposure Pathway.

The principal off-site local coordinating agency for providing response to radiological emergencies in the vicinity of OCNGS is the Ocean County Office of Emergency Management. The population and land area within the Plume Exposure Pathway EPZ is wholly within Ocean County. Upon notification of a situation which may require protective actions by the offsite population, the Ocean County Emergency Management Coordinator will initiate appropriate actions in accordance with the Ocean County Radiological Emergency Response Plan and in coordination with the New Jersey OEM.

The Ocean County Office of Emergency Management and NJ OEM have prepared detailed plans for implementing protective actions including:

- Prompt notification of the population within a 10-mile radius of OCNGS.
- Transmitting specific instructions to potentially affected populations.
- Providing assistance for evacuation of all specific segments of the population within the 10-mile Emergency
 Planning Zone.



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

 Providing reception and mass care centers for evacuated individuals.

The population within the 10-mile Emergency Planning Zone will be provided, on a periodic basis, information describing the methods by which they will be notified of an emergency and specific instructions that should be followed upon receipt of such notification.

6.6 Offsite Agencies Response

6.6.1 Ocean County

- The dispatcher at Ocean County shall notify the County Emergency Management Coordinator or his designated alternate.
- The County Office of Emergency Management shall notify county and municipal personnel, as appropriate.

6.6.2 State Emergency Management Agency (NJ State Police OEM)

- Upon receiving notification of an emergency from the site,
 the Duty Officer at the Office of Emergency Management
 shall immediately notify the State Bureau of Nuclear
 Engineering.
- The office of Emergency Management Agency shall, notify the following personnel, organizations, and agencies as appropriate in accordance with their standard operating procedures:
 - a. Ocean County
 - b. Other affected County Emergency Management Agencies
 - c. Other affected states
 - d. Selected State agencies
 - e. Selected Federal agencies



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

6.6.3 Bureau of Nuclear Engineering

The person at the Bureau of Nuclear Engineering (i.e.,

Incident Manager) who receives the notification from the State

Emergency Management Agency shall:

- Call the site Emergency Control Center to:
 - Verify actual origin of the emergency message.
 - · Determine the classification of the emergency.
 - Obtain and assess information and data pertaining to the emergency.
- Initiate activation of the BNE emergency response organization, if appropriate.
- Advise the State EMA Duty Officer or Operations Officer of the BNE initial assessment of the emergency.
- · Notify selected Federal agencies, as appropriate.

6.7 Prompt Notification System

Prompt notification and instructions to the population at risk are accomplished by the OEM-NJ and the affected county emergency management organizations. Prompt notification is the vital first link in this process. Sirens are used for prompt notification throughout the Plume Exposure Pathway EPZ.

After state authorities have been notified, the Prompt Notification (siren) System and the Emergency Alert System (EAS) are the primary means of notifying the population within the Plume Exposure Pathway EPZ. The risk county can activate the sirens located in their portion of the county that falls within the same Plume Exposure Pathway EPZ. This signal is a three to five minute steady tone which alerts the population to tune their radio or television to the local EAS station.



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyater Creek Nuclear Station

Revision No.

1

The OEM-NJ and the risk county has the capability to broadcast emergency information messages advising the population of what actions should be taken, if any. These EAS messages will be repeated at frequent intervals to ensure proper dissemination. In addition to the Prompt Notification System and the EAS message, state and/or municipal police and fire departments will act to supplement emergency notification through the use of route alerting procedures, as necessary.

The Oyster Creek Prompt Notification Systems meet the guidelines of Appendix 3 to NUREG-0654-FEMA-Rep. 1 Rev-1 Criteria for Preparation and Evaluation of Radiological Emergency Response Plans and Preparedness in Support of Nuclear Power Plants as identified in each site specific siren acoustical evaluation.

The Prompt Notification System is comprised of 42 sirens throughout portions of Ocean County that fall within the OCNGS Plume Exposure Pathway EPZ. A complete description of the siren system to include siren ratings, siren coverage, and location is located with the Emergency Preparedness Department.

The Prompt Notification System will be activated by the Ocean County Sheriff's department upon receipt of notification of an emergency situation which would require the dissemination of pertinent information to the public. The emergency situation that could require the sounding of the warning systems may be a natural catastrophe, industrial accident, as fixed nuclear facility emergency which may require protective. tion. The siren sounding is intended as an alerting mechanism to have the public monitor a designated Emergency Alert System radio station for emergency information. If an incident



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear
Station

Revision No.

1

at the plant warrants the activation of the Prompt Notification

System, the initial notification will be made to NJ OEM. NJ OEM will

in turn notify the BNE and the risk county. BNE will assess the

severity of the emergency and notify the PEMA/NJ OEM of any protective

actions required.

These signals are transmitted to the individual sirens where they are received and translated causing the siren to sound. The system deactivates in a manner analogous to that of the activation signals. Protection and selectivity is afforded to the system through an individual carrier frequency and/or series of dedicated activation signals for each county. Varying combinations of activation signals will minimize the probability of inadvertent siren activations and permit the sounding of several different signals.

The preventive maintenance program for the system insures a high degree of reliability. The sirens are inspected and tested in accordance with NUREG 0654 guidance on a continuous schedule.

In Ocean County, sirens are sounded quarterly for short durations and annually for three minutes by GPU. GPUN retains system ownership and maintenance responsibility.



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

6.8 Evacuation Time Estimates

The OCNGS Evacuation Time Estimates meet the guidelines of Appendix 4 of NUREG-0654-FEMA-Rep. 1 Rev. 1, Criteria for Preparation and Evaluation of Radiological Emergency Response Plans and Preparedness in Support of Nuclear Power Plants. The analyses used various assumptions in estimating populations, automobile occupancy factors and roadway capacities. The Evacuation Time Estimates take into consideration the population within the Plume Exposure Pathway (EPZs). Population information is contained in the site updated FSAR. However the complete set of information for evacuation planning is contained in the site Evacuation Time Estimate Study.

The complete OCNGS Evacuation Time Estimate Report is maintained on file by the Site Emergency Preparedness department.

6.9 Emergency Public Information

Communications is assigned primary responsibility for providing information promptly and accurately to the media, public officials, employees and members of the public through news releases, media briefings and public official notification.

To achieve this goal, GPUN makes the following commitment:

• Implementing guidelines establish a communications organization and enumerate responsibilities for performing organization functions. Statements are prepared by qualified communications professionals working closely with emergency response team members. The guidelines allow for quick dissemination to the news media as well as opportunities for media representatives to ask questions and gain further details on plant status during an emergency.



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear
Station

Revision No.

1

- The Emergency Public Information Implementing Document provides for quick notification and update of emergency information to local, county and State public officials.
- Joint Information Center has been established for Oyster Creek. The center is equipped with dedicated phone lines, commercial phone lines, telecopiers, radios, television monitors and necessary charts and maps to adequately provide media support. The Joint Information Center will be the focal point for the Utility, Local, State and Federal Public Information Officials to interact with the media and each other. As a minimum these centers will be activated at the Alert or higher emergency classification.
- On an annual basis, provide the news media with information the acquaints them with the dissemination of news information and the points of contact during times of plant emergencies.
- Annually in conjunction with OEM-NJ and Ocean County, emergency-related information containing educational information on radiation, contact points for additional information and protective measures is disseminated to all residents, business establishments, hotels, motels and parks within the Plume Exposure Pathway EPZ. In addition, a means is provided for individuals requiring special assistance to be identified and accommodated.
- The company will designate a chief spokesperson with support from technical personnel to facilitate the flow of accurate and timely information to the media and ultimately to the public.
- Rumor Control at Oyster Creek is handled by the NJ State Police, Office of Emergency Management.
- Members of the Public Information emergency response teams from Oyster
 Creek will be trained annually on their roles in responding to an emergency at the station.



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

7.0 EMERGENCY RESPONSE FACILITIES AND EQUIPMENT

Emergency response facilities and equipment described in this section are provided to ensure the capability for prompt, efficient assessment and control of situations over the entire spectrum of probable and postulated emergency conditions. Personnel are assigned to staff the emergency response facilities on a rotating duty roster schedule to assure a proper and timely response.

This section describes the equipment and facilities that are utilized to:

- Assess the extent of accident hazards.
- Mobilize the resources required to mitigate the consequences of an accident.
- Provide protection to plant personnel.
- Support the accident mitigation process.
- Provide immediate care for injured personnel.
- Effect damage control.
- Provide information concerning potential environmental impact offsite to appropriate governmental agencies.
- Provide information to the news media and the general public.

Many of the GPU Nuclear facilities and much of the equipment are normally used for routine plant operations. Other items are reserved for use only on an "as needed" basis.

Site specific details pertaining to onsite and offsite emergency response facilities as well as the OCNGS related county, state and federal Emergency Operations Centers are included in Tables 10 and 11.



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

7.1 GPUN Onsite Emergency Response Facilities

7.1.1 Emergency Control Center (ECC)

The Emergency Control Center is the primary location for the initial assessment and coordination of corrective actions for all emergency conditions. The ECC is located in the Control Room and Shift Supervisor's Office areas. This Center is equipped with meteorological, radiological and plant system parameter readouts integrated with assessment aids for all critical plants systems and provide access to all station communication systems.

Command and control of all initial emergency response activities originate from the ECC. When the entire emergency response organization is activated, the Emergency Director retains command and control of all onsite activities from the TSC and responsibility for offsite emergency management is transferred to the Emergency Support Director at the Emergency Operations Facility (EOF). The ECC is activated for all emergency levels.

7.1.2 Technical Support Center (TSC)

The Technical Support Center accommodates engineering personnel that provide in-depth diagnostic and corrective engineering assistance to the Emergency Director command and control functions. The TSC is activated during an Alert, Site Area Emergency, General Emergency or when directed by the Emergency Director. Records and drawings which describe conditions and layout of structures, systems, and components are contained in filing cabinets inside the TSC.



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

7.1.3 Operations Support Center (OSC)

The Operations Support Center serves as muster areas for shift personnel and as locations to organize and dispatch emergency response teams (i.e., onsite radiological monitoring, fire brigade, rescue operations, damage control, and maintenance). Emergency equipment and supplies, including portable radios, portable lighting, protective clothing, and respirators, are maintained in emergency lockers located in the Operations Support Center. Additional emergency equipment, such as gamma and air monitoring equipment can be promptly available to the OSC if needed. The OSC is activated during an Alert, Site Area Emergency, General Emergency or when directed by the Emergency Director.

7.2 GPUN Offsite Emergency Response Facility

7.2.1 Emergency Operations Facility (EOF)

The Emergency Operations Facility serves as the primary location for management of the Corporation's overall emergency response. This facility is equipped for and staffed by the Emergency Support Organization to coordinate emergency response with offsite support agencies and assessment to the environmental impact of the emergency. When activated, the EOF participates in accident assessment and transmits appropriate data and recommended protective actions to Federal, State and local agencies. The facility is equipped with data transmission links with the plant, status boards and dedicated communication links with the ECC,



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

TSC, OSC, NRC, State Bureau of Nuclear Engineering, and the JIC. Drawings which describe the as-built conditions and layout of the structures, systems, and components and applicable operating procedures are available of the plant.

7.3 County, State and Federal Emergency Operations Centers

7.3.1 County Emergency Operations Centers

Emergencies at the OCNGS site could impact the risk counties.

Each of these risk counties, therefore, has an Emergency

Operations Center (EOC) that meets or exceeds the maximum

federal criteria for sufficient space, communications,

warning systems, self sufficiency in supplies and

accommodations. All counties maintain a full time employee

to coordinate emergency planning.

7.3.2 State Emergency Operations Center

The State Emergency Operations Center contains provisions and accommodations to support State emergency operations. A communications system ties all area and county emergency operations centers into this center. During an energency, representatives from the State agencies assemble in the State EOC to manage and coordinate response activities.

7.3.3 Disaster Field Office (DFO)

<u>Disaster Field Office</u> - The office will be established by FEMA at a location identified in conjunction with the State that serves as a focal point for Federal response team interactions with the State. The DFO will more than likely be established at Miller Airpark in Berkeley Township, N.J.



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

7.4 Emergency Communications Systems

The emergency communications systems are designed to ensure the reliable, timely flow of information between all parties having an emergency response role. Reliability is provided through (1) redundancy, (2) alternate communications methods, (3) dedicated communication equipment, and (4) routine use of many of the systems which reduces the probability of undetected system failures.

Timeliness of information flow is achieved by (1) prompt notification, (2) predefined lines of communication, (3) predefined emergency action levels, and (4) predefined levels of authority and responsibility, and (5) diversity.

The Control Room is the primary source of plant information.

Information originating in the Control Room can be classified into two major categories: operational data and radiological data. The emergency communications networks are formulated around this basic concept and designed to channel information directly to the key parties having closely related functions. By providing well-defined and dedicated communication links, efficient and effective accident management can be achieved albeit key personnel operate from physically separated facilities. The following circuits have been installed at the OCNGS. The specific details of these circuits and description of additional emergency communications available at the site are also included in Table 12.



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

7.4.1 Emergency Communications

7.4.1.1 NRC Emergency Notification System (ENS)

The NRC Emergency Notification System lines are part of the dedicated telephone system that connects Emergency Response Facilities at the OCNGS site with NRC Operations Center. The ENS is used primarily to report emergencies. Commercial telephone lines are used as backup communications. Transmittal of operational data to the NRC should be accomplished using this circuit. The Emergency Director/Emergency Support Director and the Technical Support Center Coordinator will appoint a communicator from the appropriate functional group to act as an ENS line communicator.

7.4.1.2 Health Physics Network (HPN)

In the event of a radiological emergency, the HPN will be activated. These lines are circuits used to relay information to the NRC Regional and Headquarters offices. The HPN can be used for NRC notification when the ENS is out of service. This system is dedicated to transmission of radiological information to the NRC.



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Cyster Creek Nuclear Station

Revision No.

1

7.4.1.3 Telephone System

The Oyster Creek site is served by the Private

Phone System and direct commercial lines. These
systems are expected to function during emergencies
as they do during normal plant operations.

7.4.1.4 Transmission (Voice)

The Oyster Creek site maintains telephone communication throughout the entire GPU system using a company-owned microwave and fiber optics links (i.e., tie-lines) system. Access to this system is through the plant telephone system which bypasses potentially congested public-use circuits. Backup to these routes are commercial business lines.

7.4.1.5 Automatic Dialing Equipment

Automatic dialing equipment provides automatic dialing of pre-selected telephone numbers, reducing callout/notification time and dialing errors.

7.4.1.6 Emergency Response Facility Communications System

• The phone system used by the OCNGS Emergency

Response Organization includes a dedicated system

with the normal site phone system as a back-up.

The dedicated system allows communications

between the ERF's and is not normally connected

with outside circuits. The system has its own

uninterruptible power supply (rated at 8 hours)



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

which is powered by one of the Station's Emergency Diesel Generator backed busses.

- The State Emergency Director's Hot Line
 The State Emergency Director's Hot Line provides
 automatic communication between the Emergency
 Director in the ECC or the Emergency Support
 Director in the EOF to the State Emergency
 Director at the state EOC.
- New Jersey State Police Notification and
 Verification Lines

The New Jersey State Police Notification and

Verification Lines are two separate circuits that

connect the Emergency Director/Emergency Support

Director or his designee in the ECC, the

Technical Support Center and the Emergency

Operations Facility with the State Police

Communicator at the Division Headquarters

Communications Center, West Trenton, N.J. The

purpose of these lines is to provide a reliable

means of prompt notification and verification of

an emergency at OCNGS.

• Ocean County Notification and Verification Lines
The Ocean County Notification and Verification
Lines are separate and dedicated automatic ring
circuits that directly connect the Emergency
Director or his designee in the Control Room;
the Technical Support Center and the Emergency



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

Operations Facility with the Sheriff's representatives in the Ocean County

Communications Center, Toms River, N.J. The purpose of these lines is to provide a reliable means of prompt notification and verification.

7.4.1.7 Telephone System Emergency Power Supplies

- USNRC telephones on the FS 2000 system and select telephones are powered by telephone company equipment at an off site location.
- · OCNGS has direct offsite Commercial Phone system lines in each ERF and are supplied by phone company backup power. In plant lines in each ERF are supported by GPU's PBX power supplies as follows: 12.5KV offsite power, 19.9KV backup offsite power and backup battery power for 8 hours. In plant emergency circuits are also on the PBX and have an additional 8 hour battery backup. Offsite emergency circuits are carried by both Commercial Phone system and Company owned microwave. The Commercial Phone system circuits have the same backup power as other such circuits. The company microwave has 8 hour hattery backup at each connecting node. Emergency diesel generator power is available for the onsite circuits. Portable gasoline generators are available for the microwave nodes.



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

7.4.1.8 Radio Communications

Radio communication equipment used during normal plant operations will be used in an emergency to communicate with mobile units and to provide backup to the telephone system.

• OCNGS, base stations are located in the

Emergency Control Center and the Emergency

Operations Facility. The EOF has the capability

of transmitting and receiving on the State

Emergency Radio (EMRAD) Network which provides a

communication path with the N.J. State and Ocean

County Emergency Management Centers.

7.4.2 Station Warning System

7.4.2.1 Alarms

Audible alarms are a quick and effective means of communicating emergency warnings on the site.

Alarms currently installed at Oyster Creek include:

- Station Emergency Alarm
- · Fire Alarm
- Reactor Building Evacuation Alarm

 Each alarm provides a distinctive sound that all site personnel and contractors are trained to recognize and respond to. The Station Emergency Alarm will be followed by an announcement that provides emergency information such as class of emergency declared, accountability directions, radiological precautions, etc. The Reactor



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

Building evacuation alarm is supplemented with flashing lights at specific locations in the Reactor Building to provide both audible and visual warnings.

The Control Room alarm systems consist of overhead annunciators, panel annunciators and computer alarms. The overhead and panel annunciators consist of flashing translucent tiles and audible indicators (i.e., buzzer or horn). The computer alarms use annunciators and also provide specific data using the alarm printer.

7.4.2.2 Plant Paging System

The Plant Paging System provides plant-wide paging from the Control Room and all remote stations plus private communications during normal operating conditions.

The plant paging system provides immediate warning and instructions to onsite personnel in the event of an emergency. Phone stations and speakers of this subsystem are located in vital plant areas.

7.4.2.3 Call Out Telecommunication Equipment (Teleclerk)

The Call Out telecommunication equipment enables

personnel to determine who has responded to the

call-out of emergency personnel. Emergency

personnel notified by pocket pager during the call
out will call a number, listen to the message,

enter a position identifier using a touch tone



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

phone causing the individual's response to be documented. It will also contact personnel (e.g., alternates for unfilled positions).

7.5 Assessment Facilities

7.5.1 Onsite Systems and Equipment

7.5.1.1 Radiation Monitoring System

The onsite Radiation Monitoring System contributes to personnel protection, equipment monitoring, data gathering, and accident assessment by measuring and recording radiation levels and concentrations of radioactive material at selected locations within the plant. The Radiation Monitoring System alarms and initiates required emergency actions when radiation levels or radionuclide concentrations exceed predetermined levels. Area, liquid, and atmospheric monitoring subsystems are required to perform these functions. Specific details regarding radiation monitoring and effluent monitoring systems can be found in system design descriptions (SDDs) and Final Safety Analysis Report.

The data from these subsystems are displayed by readout in the Control Room. Selected channels are recorded by recorders and/or the plant process computer which are also located in the Control Room.



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

In general the radiation monitoring equipment is designed in accordance with the following:

- Each monitoring station has adjustable alarm,
 alert, and power supply failure alarms.
- Solid-state circuitry is used except for primary detectors.
- Most AC operated radiation monitoring equipment, except for the pump assemblies, is provided with power from the battery-backed, inverter-fed vital power supply bus.
- Each radiation monitor is capable of being checked periodically with solenoid actuated check sources.
- A pulse generator or solid sources are used for electrically checking each monitor or subsystem.
- The modules are designed so that an alarm and/or indication is initiated when failure occurs anywhere in the channel.

7.5.1.2 Radiation Monitoring

Plant areas are provided with area radiation monitors in the AOG, Turbine, Reactor, old Radwaste and new Radwaste buildings. In-plant ARMs (turbine, reactor and old radwaste buildings) are the Geiger-Mueller type. The Augmented Off-Gas (AOG) building and the new Radwaste building utilize ionization chambers.



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Cyster Creek Nuclear Station

Revision No.

1

Each in-plant monitor has a remote indicator, an alarm and is recorded on one of two multi-channel recorders in the Control Room. The monitors are provided with an upscale alarm which is set using past plant operating experience and warns of an abnormally high radiation level and each monitor is provided with a downscale alarm which warns of instrument channel failure. The individual detectors and associated instrumentation for the AOG and the new Radwaste buildings are provided with local indication and alarm, range indication on the respective AOG and new Radwaste control panels, high and high high alarm for concerned level and limit level respectively.

7.5.1.3 Atmospheric Radiation Monitoring

Atmospheric Radiation Monitoring is provided by
Reactor Building RAGEMS, Turbine Building RAGEMS,
Air Ejector Off-Gas Monitoring, Reactor Building
Ventilation Monitoring, and AOG Building
monitoring.

RAGEMS (Radioactive Gas Effluent Monitoring System)
has been installed to comply with NUREG 0737.

These systems will provide for a continuous
monitoring of noble gas releases, continuous
particulate and iodine samplers are included in the
RAGEMS. The systems are designed to detect noble
gas. Iodine and particulate samples from both



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

systems must be manually analyzed to provide isotopic concentrations of halogens and particulates. RAGEMS data is accessible from recorders in the control room and/or by accessing the RAGEMS system computers, or the plant computer system.

The Air Ejector Off-Gas Monitoring Subsystem draws a sample of the condenser off-gas downstream of the steam jet air ejectors, Here, a 2 minute delay line is provided to allow for the decay of N-16 and 0-19 before passing through the sample chamber. The sample chamber is provided with two detectors. Output is recorded on a recorder located in the Control Room. The count-rate meters have adjustable downscale trip and upscale trips. The upscale trips are set at four times the maximum allowable stack gas release rate, while the downscale trip is set to indicate instrument failure. Any combination of either two "Hi Hi" upscale trips or one "Hi Hi" upscale and one downscale trip will initiate a 15 minute timed closure of the off-gas exhaust valve at the stack or isolate the augmented Off-Gas system if in operation. The recorders have an adjustable upscale "Hi" alarm set at a valve equivalent to the maximum allowable stack gas release rate.



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Ravision No.

1

The Reactor Building Ventilation Monitoring
Subsystem provides continuous monitoring of the
gaseous discharges from the Reactor Building
ventilation systems through the use of two GeigerMueller detectors located upstream of the
ventilation outlet isolation valves. The downscale
alarm indicates instrument failure, while the
upscale trip is set at an acceptable radiation
concentration. The activation of the upscale trip
will close the Reactor Building ventilation inlet
and outlet isolation valves, trip the ventilation
fans and energize the standby gas treatment system.
However its usefulness is limited due to its
sensitivity to other external radiation sources.

7.5.1.4 Liquid Radiation Monitoring

The Process Liquid Monitoring Subsystem provides the continuous monitoring of three process liquid streams; the radwaste discharge, the reactor building closed cooling-water system, and the reactor service-water discharge. The radwaste monitor is located in the radwaste discharge line external to the radwaste building, downstream of the flow control valves. The reactor building closed cooling-water probe is located a the discharge header of the cooling water pumps.



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Flan for Oyster Creek Nuclear Station

Revision No.

1

The reactor service-water monitor is located in the service water discharge of the closed cooling-water heat exchanger.

7.5.1.5 Main Steam Line Radiation Monitoring System

The Main Steam Line Radiation Mcnitoring Subsystem utilizes detectors mounted next to each of the primary steam lines. This subsystem provides continuous monitoring of the primary steam lines which gives an immediate indication of a gross release of fission products from the fuel to the reactor coolant and subsequently to the turbine. The detectors located immediately upstream of the outer isolation valves at the drywell penetration provide an output to a meter and a recorder located in the Control Room.

Each monitor has a downscale alarm and an adjustable upscale alarm set at less than or equal to five times normal. If the indicated value on two or more monitors reach ten times normal, station procedures direct the scramming of the reactor and the closure of all four main steam isolation valves.



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

7.5.1.6 Augmented Off-Gas Building Ventilation Exhaust Monitoring System

The AOG Exhaust Monitoring System is designed to monitor and sample the effluent for iodine, gas, and particulates. The data from these subsystems are displayed by local readouts on the AOG control panel and are recorded by strip chart recorders displayed locally.

7.5.1.7 Containment Radiation Monitors

High range containment radiation monitors have been installed at OCNGS to monitor containment radiation levels.

7.5.1.8 Post Accident Sampling System

The Post-Accident Sampling System (PASS) at Orster Creek Nuclear Generating Station was designed to sample five separate post-accident media from eight separate sampling points.

Liquid samples may be taken of the reactor water from "A" recirc loop, the liquid poison system or the shutdown cooling system and of torus water from the core spray system.

Gaseous samples may be taken of the drywell atmosphere from the hydrogen monitoring system and from the ring header. Gaseous samples may be taken of torus atmosphere and secondary containment from the TIP room.



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

7.5.2 Fire Protection Devices

Site specific details regarding Fire Protection at the OCNGS site are as follows:

Fire Protection at CCNGS is provided by the Fire Service Water System, the Halogenated Fire Suppression Systems, the CO₂ Fire Extinguishing System, and the Fire Detection/Alarm System.

The Fire Service Water System is a full-loop, piped system that supplies water for sprinklers, deluge water spray, fire hydrants and hose connections that are located to provide fire protection for all major areas of the plant. A man-made pond containing approximately 7 million gallons of water supplies a water source for this system. This system is maintained in a pressurized condition by an electric drive pond pump. In the event a fire occurs, and either an automatic or manual system is initiated, the Fire Service Water System piping pressure will decrease which will sequentially start two diesel fire pumps to meet system flow requirements. The backup supply of Fire Service water consists of a 350,000 gallon tank and electric pump which may manually be initiated to supply the loop should the primary source of water be inoperable.

Automated Halogenated Fire Suppression Systems are provided in the Control Room panels, the station battery A and B room and the 480 volt switchgear room to quickly suppress any fires that may occur.



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

The ${\rm CO}_2$ Fire Extinguishing System provides fire protection for the 4160 Switchgear Vault. When a manual pushbutton is depressed, the ${\rm CO}_2$ is discharged into the 4160 Switchgear Vault after a time delay.

7.5.3 Seismic Monitoring

Specific details regarding the seismic monitoring systems at the Oyster Creek site are included as follows:

Although OCNGS currently does not have seismic or hydrologic instrumentation installed onsite, offsite hydrologic information can be obtained from the Hydrologic Division of the United States Geological Survey and offsite seismic information can be obtained from the LaMont Dougherty Geological Observatory, the New Jersey State Geological Survey or the United States Geological Survey.

7.5.4 Onsite Meteorological Monitors

Specific details regarding the onsite meteorological monitoring system at the ONCGS site are included as follows:

Meteorological data have been collected onsite since February of 1966. The current meteorological tower is 400 ft. high and located 2529 feet (0.48 miles) west-northwest of the OCNGS stack. The tower is instrumented with complete redundant sensors at 33 feet and 380 feet. Single sensors are located at 150 feet. A back-up electrical power supply is available, if necessary.



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

The instrumentation and meteorological variables measured at each level are as follows:

Approximate Height Above Tower Base (ft.)	Parameter
380	wind speed*, wind direction*, temperature*, ΔT 380-33 ft.*
150	wind speed, wind direction, temperature, ΔT 150-33 ft.
33	wind speed*, wind direction*, and temperature*
Ground Level	rainfall

* redundant system available.

The variables are measured every 10 seconds and are averaged for 15-minute periods before being archived using a computer. There are redundant wind speed, wind direction, and temperature sensors at the 33- and 380- ft. levels to insure efficient data recovery and to comply with U.S. Nuclear Regulatory Commission Regulatory Guide 1.23 requirements. In addition, a processor calculates vertical temperature differentials between the 150- and 33-ft. and the 380- and 33-ft. levels. All readings are continuously recorded on strip chart recorders at the base of the tower. The meteorological tower sensors, chart recorders, and processors are calibrated at least semi-annually as per Regulatory Guide 1.23. Periodic tower inspections are made to insure maximum data integrity. A full description of the Onsite Meteorological Measurement Program is included in the FSAR.



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

Meteorological data can be remotely interrogated by telephone by the NRC and New Jersey State agencies.

7.5.5 Process Monitors

Process monitors measure appropriate parameters that are indicative of the status of various plant systems and the reactors. These parameters are displayed and recorded in the Control Room, or at local panels in the plant.

7.5.6 Laboratory Facility

The Oyster Creek laboratory facility is equipped to provide the water chemistry and radiochemical analysis support required during normal plant operations and emergencies.

7.5.7 Systems and Equipment Required by NUREG

Onsite capability and resources to provide initial values and continuing assessment throughout the course of any accident include post-accident sampling capability, radiation and effluent monitors, in-plant iodine instrumentation and containment radiation monitoring in accordance with NUREG-0737.

7.5.8 Facilities and Equipment for Offsite Monitoring

7.5.8.1 Reuter Stokes Sentri System

The Reuter Stokes Sentri System at OCNGS consists of radially located monitoring stations hard-wired into a central processing center (CPC). The OCNGS system was installed in 1982 and upgraded in 1993. The OCNGS system is owned by the State of New Jersey.

Each monitoring station measures and records ambient radiation levels every five seconds. The



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

monitoring station at regular, specified time intervals. Average ambient radiation levels, station status and diagnostic information are then transmitted by telephone line to the print-out locations. The OCNGS system monitoring stations can measure from 0 to 500 micro R/hr and 0.5 to 100 mR/hr. and 10R/hr.

Alarm setpoints for each station are set at the CPC. When a setpoint is exceeded, the CPC automatically increases print-out frequently and indicates which station(s) have exceeded the setpoint.

7.5.8.2 Radiological Environmental Monitoring Program (REMP)

Complete Radiological Environment Monitoring

Program (REMP) for the OCNGS site has been established by GPU Nuclear.

The objectives of the REMP are:

- To fulfill the obligations of the radiological environmental surveillance sections of the Environmental Technical Specifications of the respective plant.
- To determine whether any statistically significant increase occurs in the concentration of radionuclides in critical pathways.



Number 2000-PLN-1300.01

Title
GPU Nuclear Emergency Plan for Oyster Creek Nuclear
Station

Revision No.

1

- To detect any buildup of long-lived radionuclides in the environment.
- To detect any change in the ambient gamma radiation levels.
- To verify that radioactive releases are within allowable limits and that plant operations have no detrimental effect on the health and safety of the public or the environment.

· To obtain a post accident historical assessment

of accumulated dose for the affected area.

Samples for the REMP are taken from the aquatic, atmospheric, and terrestrial environments. Sample types are based on: 1) established critical pathways for the transfer of radionuclides through the environment to man, and 2) experience gained during the preoperational and initial operational phases of the REMP. Sampling locations were determined from site meteorology, hydrology, local demography, and land uses.

Sampling locations are divided into two classes: indicator and control. Indicator stations are those which are expected to monitor plant effects, if any exist; control samples are collected at locations which are believed to be unaffected by plant operations. Fluctuations in the levels of radionuclides and direct radiation at indicator stations are evaluated with respect to analogous



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

fluctuations at control stations. Indicator station data is also evaluated relative to background characteristics established prior to station operation.

The following samples are obtained: air iodine, green leafy vegetables, air particulates, immersion dose (TLD), fish, aquatic plants, precipitation, sediment, surface water, drinking water, ground water, scil, fodder crops, fruit and milk.

The TLD program used by GPU Nuclear meets the requirements set forth in the OCNGS Technical Specifications. Locations of Environmental TLDs can be found in the most recent Radiological Environmental Monitoring Report for Oyster Creek. The report is submitted annually to the NRC in accordance with Technical Specifications.

Additional information regarding the site specific TLD program follows:

The TLD program used by GPU Nuclear at OCNGS
exceeds the requirements of the Oyster Creek
Technical Specifications, as do other aspects of
the REMP. Radiological and Environmental
Monitoring Report contains a detailed description
of the number and locations. During normal
operations, accurate measurements of the
environmental gamma dose are made. Following an



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

accident, a cumulative dose estimate will be available.

7.5.9 National Weather Service (NWS)

The NWS can provide backup meteorological information (e.g., wind speed, temperature, wind direction) from several locations in the vicinity of the Oyster Creek site. The information for various locations is available through the Mt. Holly, NJ, NWS office.

The NWS will also perform emergency balloon runs to collect data upon request. Air stability determinations are also provided, with information received from weather stations in Pittsburgh; Washington, D.C.; Binghamton, NY; and Mt. Holly, NJ.

Back-up meteorological information from the National Weather Service is also available indirectly from other sources that collect National Weather Service data.

The Federal Radiological Monitoring and Assessment Plan (FRMAP)

The Federal Radiological Monitoring and Assessment Plan was developed to coordinate Federal radiological assistance. The FRMAP establishes: (a) A means of requesting and providing Federal radiological assistance from existing Federal resources and (b) an operational framework for coordinating the radiological monitoring and assessment activities of Federal agencies during radiological emergencies occurring within the United States and its territories.

To the extent that assistance under this plan is needed, GPUN

requests for Federal assistance will be coordinated through



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

the NRC. Requests for this assistance will be initiated by the Emergency Director, Radiological Assessment Coordinator or Emergency Support Director. When notified of an emergency, the Federal agencies will respond with equipment and personnel, as required, to assist in the performance of assessment actions. The resources available consists of, but are not limited to:

- · Portable radiation survey instrumentation
- · Mobile laboratory facilities
- · Personnel for supporting functions
- Special transportation activities
- · Environmental monitoring teams

7.5.11 State Departments of Environmental Protection

The NJ Dept. of Environmental Protection. BNE, is responsible for responding to radiological incidents within their respective state boundaries. The BNE maintains personnel, facilities and equipment to assist in assessing the hazard and provide technical guidance and recommendations regarding the implementation of protective actions for the general public. The BNE perform both routine and emergency environmental monitoring.



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear
Station

Revision No.

1

7.5.12 Offsite Emergency Radiological Assistance

Backup radiological monitors, including rate meters, sampling devices, dosimeters and laboratory facilities will be obtained through GPU Nuclear. Equipment, facilities and personnel from the GPU System will be used to support the emergency site during emergency situations.

Additional radiological emergency assistance available to the OCNGS site from companies, utilities and governmental

agencies is included in the INPO Emergency Resources Manual.

7.6 Additional Support Facilities

Personnel protective action is a function of the nature of the hazard (e.g., preparing for a hurricane is somewhat different from preparing for radiological hazards). Preplanned responses to basic hazards, high wind, flooding, earthquakes, and radiation exposure, are an integral part of the Emergency Plan. A fundamental concept in personnel protection is the evacuation of all individuals not essential to the operation, safety, security, and damage control of the plant. Obviously some hazards can occur before significant protective action can be applied (e.g., earthquake). When the situation permits positive action, the appropriate alarms are sounded and all personnel on the site either assume assigned emergency responsibilities or prepare for evacuation.

Provision has been made for adequate supplies and protective equipment for all personnel who may be required to perform emergency activities. Specific quantities of each type are detailed in station procedures and include equipment for personnel monitoring, determining the magnitude and continuously assessing the impact of the release of



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

radioactive material, decontaminating personnel and providing emergency first aid. Additionally, a current prescription and adequate supplies of potassium iodide are maintained by the site Medical Department for issue to personnel exposed or suspected of exposure to radioactive iodine.

Onsite locations have been designated as emergency assembly points or areas where emergency teams will be assembled in accordance with the Emergency Plan Implementing Procedures or as directed by the Emergency Director. Major locations for onsite protective equipment and supplies are the Control Room, access control point, and processing center. Additional information regarding protective facilities can be obtained by consulting the FSAR.

7.6.1 Joint Information Center

The Joint Information Center has been established to provide for the dissemination of accurate and timely news information. Equipment and facilities are designed to support timely communications and information dissemination on plant conditions and emergency operations to the news media.



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

7.6.2 Environmental Assessment Command Center (EACC)

The Environmental Assessment Command Center is co-located in the Emergency Operations Facility. The EACC provides for the analysis of field monitoring data and the coordination of the offsite radiological and environmental monitoring. In addition, the EACC performs offsite release dispersion modeling. Computer terminals are available to display real-time meteorological data and facilitate dispersion modeling and dose projections. The EACC performs independent dose projections.

7.6.3 Remote Assembly Areas (RAA)

An Offsite Remote Assembly Area has been designated at the OCNGS site for assembly of personnel following muster and accountability at the onsite emergency assembly areas.

Personnel and vehicles arriving at the RAA are monitored by qualified personnel in accordance with approved Radiological Controls Procedure. Personnel arriving at the RAA as a result of site evacuation will be mustered, monitored and given further instructions.



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

7.6.4 Control Room/Shift Supervisor's Office

The Control Room and Shift Supervisor's Office are designed to be habitable under accident conditions and will serve as the primary onsite Emergency Control Center (ECC).

These areas are located in seismically-rated structures and have adequate shielding to permit safe occupation for extended periods of time.

The OCNGS control room ventilation system can be operated in an emergency mode with 100 percent outside air to prevent recirculation of smoke in the control room and to clear the areas of smoke and fumes. This system has been modified to prevent smoke from other areas from entering the control room.

Emergency lighting, power, ventilation system, and shielding walls enable operators to remain in the Control Room to ensure that the reactor will be maintained in a safe condition. In addition, the operators will be able to evaluate plant conditions and relay pertinent information to appropriate onsite and offsite personnel, organizations, and agencies during emergencies. To ensure the operations shift and other personnel assembled at the location can remain self-sufficient, emergency equipment and supplies will be stored in or near the Control Room. The exact location, type and quantity of emergency equipment and supplies available is specified in the Emergency Plan Implementing Documents.



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

7.6.5 Processing Center

The Processing Center will be continuously manned by Site Security Force personnel, unless otherwise directed.

Emergency equipment and supplies will be maintained in this facility to support such tanks as reentry efforts, performing onsite and offsite radiation surveys or collecting samples.

The exact location and the type and quantity of emergency equipment and supplies are specified in the Emergency Plan Implementing Document.

7.6.6 Emergency Assembly Areas

At OCNGS non-essential personnel will be directed to the site designated assembly areas, based on the radiological conditions. If ordered to evacuate the site, personnel will be given instructions to report to a pre-designated remote offsite assembly area. (See Table 10)

7.7 First Aid and Medical Facilities

First aid facilities are designed to support a wide range of immediate care requirements ranging from simple first aid to procedures requiring a physician. The most readily available first aid is provided by small kits placed throughout the plant. These kits contain items typically needed to care for minor injuries. Typical contents can be referenced in Table 8. The next level of first aid equipment is found at first aid stations. The medical staff can also provide Advanced Life Support and routine trauma care.



Number

2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

7.8 Damage Control Equipment

The site is extensively equipped to conduct preventive maintenance and repairs on mechanical, structural, electrical, and instrumentation and controls equipment found in the plant. Operational policy requires that a minimum maintenance crew be assigned to the onsite shift organization at all times. Each individual assigned to the maintenance crew is qualified and certified to perform the tasks associated with his craft in the working environment of a nuclear plant.

In addition to the equipment and materials required for normal maintenance, other items are available to handle extraordinary maintenance jobs that might arise in damage control. Selection of damage control equipment inventory is based upon (a) mitigating the consequences of flooding, (b) personnel rescue, (c) checking the uncontrolled flow of fluids from process systems, and (d) elimination of electrical hazards. Typical equipment available for damage control can be found in Table 8.

7.9 Radiological Controls Equipment

The site maintains an inventory of protective clothing, respiratory equipment, survey instruments and supplies to provide adequate contamination control for all personnel expected to be onsite who might be affected in the event of an emergency.

The supplies are maintained, updated, inventoried and calibrated, as appropriate, on a regular basis in accordance with applicable procedures. Storage locations of emergency supplies can be found in the site implementing documents. Typical equipment available can be found in Tables 8.



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

7.10 Emergency Equipment Readiness

To insure that the necessary emergency equipment is maintained and available for use during emergency situations, readiness checklists have been developed and incorporated in Administrative Procedures.

These checklists facilitate detailed inventory and calibration/functional checks of equipment contained in the emergency kits/lockers. The inventory checklists will be performed on a quarterly basis and to insure interim readiness, all kits/lockers are sealed or locked as appropriate.



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

8.0 MAINTAINING EMERGENCY PREPAREDNESS

Although this plan is considered to be part of the Final Safety Analysis
Report (FSAR), GPU Nuclear will maintain, as separate documents, this
Emergency Plan and the Oyster Creek site-specific Emergency Plan
Implementing Documents.

Efforts will be made to assure continuous emergency preparedness and operational readiness among GPU Nuclear personnel and the offsite response agencies and organizations. The Vice President and Director of Oyster Creek has been assigned overall responsibility and accountability for providing the human and material resources to carry out the provisions of this plan and implementing procedures, to accomplish training and qualification of the Emergency Response Organization, and to meet performance expectations for emergency preparedness at their respective sites. Specific responsibilities of this Director are delineated in section 8.1.3 of this plan.

8.1 Responsibilities

- 8.1.1 All Division Directors In accordance with the requirements of the Emergency Plan and Implementing Procedures shall:
 - 8.1.1.1 Designate essential personnel to be assigned to positions within the On-Shift, Initial Response Emergency, and Emergency Support Organizations as specified in Table 15.
 - 8.1.1.2 Ensure that personnel designated for assignment to emergency response organizations satisfy the prescribed prerequisites as identified in the OC Administrative Procedures.



Number 2000-PLN-1300.01

Title
GPU Nuclear Emergency Plan for Oyster Creek Nuclear
Station

Revision No.

- 8.1.1.3 Ensure that assigned responsibilities for maintaining emergency preparedness are accomplished in a timely and effective manner in accordance with relevant procedures and that required documentation is prepared and maintained to reflect accomplishment of such activities, i.e., surveillance, audit, inventory, calibration and corrective actions, as appropriate.
- 8.1.1.4 Provide technically qualified personnel to support the Emergency Preparedness department in the development of drill/exercise scenarios and review of scenarios for technical accuracy and content.
- 8.1.1.5 Provide technically qualified observer/controller personnel to assist in the conduct and evaluation of drills and exercises.
- 8.1.2 Director, Engineering Division In addition to the requirements specified in Paragraph 8.1.1 above, shall:
 - 8.1.2.1 Provide technically qualified personnel to participate in the development and conduct of appropriate portions of the specified training courses.
- 8.1.3 Director, Oyster Creek Division In addition to the requirements specified in Paragraph 8.1.1 above, shall:
 - 8.1.3.1 Ensure development and implementation of a GPU

 Nuclear Emergency Preparedness Training Program

 which is in accordance with the requirements of the

 Emergency Plan.



Number 2000-PLN-1300.01

Title
GPU Nuclear Emergency Plan for Oyster Creek Nuclear
Station

Revision No.

- 8.1.3.2 Provide technically qualified personnel to participate in the development and/or conduct of specified training courses as listed in Table 13.
- 8.1.3.3 Provide for the review/concurrence of all Emergency
 Plan Implementing Procedures and training courses.
- 8.1.3.4 Provide for proper and timely development,
 implementation and maintenance of dose projection
 methodology including computer software with
 concurrence from the Emergency Preparedness
 Department and review for concurrence proposed
 changes to the methodology.
- 8.1.3.5 Provide and maintain the necessary portable radiation survey instruments, assigned vehicles and radio for use by both on site and offsite survey teams and computer equipment used to run dose projection software.
- 8.1.4 Director, Communications In addition to the requirements specified in Paragraph 8.1.1 above, shall:
 - 8.1.4.1 Provide an Emergency Public Information Implementing

 Procedure, and a staff to handle all public

 information aspects (media inquiries, news releases

 and briefings, public official notifications, of an

 emergency at OCNGS.
 - 8.1.4.2 Provide and maintain in readiness, a Joint

 Information Center to handle, as necessary, the

 public information aspects of an emergency at OCNGS.



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear
Station

Revision No.

- 8.1.5 Training and Education Director Shall assume overall responsibility for the development, implementation, and administration of the Emergency Preparedness Training Program.

 Specific responsibilities shall include:
 - 8.1.5.1 The development, scheduling, presentation,
 documentation and administration of training,
 consistent with the training scope referenced in the
 Emergency Preparedness Training Program, the
 instructor responsibility assignments of Table 13
 and the periodic training requirements of Table 14
 of this plan.
 - 8.1.5.2 The review by the cognizant Radiological and
 Environmental Affairs Department, for concurrence,
 of emergency preparedness training content records
 dealing with radiological or environmental controls,
 procedures and concerns.
 - 8.1.5.3 The review by the Emergency Preparedness Department, for concurrence, of emergency preparedness training content records.
 - 8.1.5.4 The development, coordination and publication of training schedules of supporting training facilities to satisfy program requirements.
 - 8.1.5.5 Documentation of training, to include, as a minimum, attendance records and the status of training related to emergency preparedness. Emergency Preparedness training conducted by other than the Training Department shall be documented to the



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

Training Department by the organizations conducting that training, in accordance with Training Department processes.

- 8.1.5.6 Providing qualified instructor personnel to conduct specified training consistent with Table 14.
- 8.1.6 The Director Radiological Health and Safety Shall assume overall responsibility for the development, administration, and maintenance of the GPU Nuclear Emergency Preparedness program including the preparation of the Emergency Plan, establishment of performance standards for the Emergency Response Organization, and coordination of emergency response with off site agencies. Specific responsibilities shall include:
 - 8.1.6.1 Development, implementation and maintenance of the Emergency Plan and Implementing Documents.
 - 8.1.6.2 Development, implementation and coordination of the Emergency Preparedness Surveillance Program.
 - 8.1.6.3 Determining, in coordination with affected departments, which categories of personnel are to receive what emergency preparedness training. This includes reviewing, for concurrence, the emergency preparedness Training Content Records to ensure (1) compliance with regulatory requirements and with the provisions of the Emergency Plan, and (2) that the emergency plan-related technical content is current, correct and appropriate.



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear

Revision No.

1

8.1.6.4 Providing technically qualified personnel to conduct specified training in accordance with Table 13.

8.2 Organizational Preparedness

8.2.1 Training

All personnel at the Oyster Creek site take part in a formal training program under the direction of the Manager Plant Training, Oyster Creek. In general, this training program provides for the indoctrination of GPU Nuclear employees and contractors in addition to providing specialized training for licensed operators, health physics/radiation protection personnel, and personnel assigned specific responsibilities in the emergency organization.

The Manager Plant Training Oyster Creek is responsible to ensure that personnel in each department receive the appropriate training. The Manager may delegate specialty training responsibilities to personnel qualified to perform such training.

The training program for OCNGS includes the following:

- All staff personnel are required to attend the General Employee Training Program annually. With regard to emergency planning, the objectives of these programs are to:
 - a. Familiarize personnel with the scope, applicability, and the concept of implementation of the Emergency Plan.
 - b. Familiarize all personnel with the station alarms and appropriate personnel response.



Number 2000-PLN-1300.01

Title
GPU Nuclear Emergency Plan for Oyster Creek Nuclear
Station

Revision No.

1

- c. Familiarize those personnel who do not have pre-assigned emergency response duties (i.e., non-essential personnel) with their required actions during emergencies which include paying attention to instructions, responding to alarms, assembly, accountability, and evacuation.
- OCNGS and station support organization personnel assigned to the emergency organization with specific Emergency Plan duties and responsibilities (i.e., essential personnel) are required to attend specific emergency preparedness training. The training is designed to prepare these essential personnel to perform their assigned duties in accordance with the Emergency Plan and Implementing Documents.
 - a. The scope of training for essential personnel is delineated in Table 14.
 - b. Essential personnel shall reverify their assigned emergency preparedness training preferably every 12 months but at least every 15 months.
- In addition to state and county sponsored training, GPU

 Nuclear will invite the emergency management organizations

 listed below on an annual basis, to participate in a

 training program.

The program will also include a review of recent changes to the OCNGS Emergency Plan and Implementing Documents with particular emphasis given to the classification of emergencies; reporting requirements; assessment,



Number 2000-PLN-1300.01

Title
GPU Nuclear Emergency Plan for Oyster Creek Nuclear

Revision No.

1

protective, and corrective actions; and communications networks that may affect interface with offsite agencies.

Oyster Creek

- · NJ Office of Emergency Management
- · State Bureau of Nuclear Engineering

NOTE

Training for the Risk County is provided by the NJ Office of Emergency Management (OEM).

e GPU Nuclear will offer training for hospital personnel, ambulance and rescue, police and fire departments. This training shall include the procedures for notification, basic radiation protection and their expected roles. For those support organizations that must enter the site, training shall also include site access procedures and the identity (by title) of the individual in the site emergency organization who will control the organizations' support activities. While it is expected that offsite support organizations would take advantage of the training, an organization that habitually fails to participate in training programs will be dropped from the list of relied upon offsite support agencies.

8.2.2 Drills and Exercises

Periodic drills and exercises will be conducted in order to test the state of emergency preparedness. The prime objective of this form of training is to verify the emergency preparedness of all participating personnel, organizations, and agencies. Each drill or exercise will be conducted to:



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

(1) ensure that the participants are familiar with their respective duties and responsibilities, (2) verify the adequacy of the Emergency Plan and the methods used in the Emergency Plan Implementing Documents, (3) test communications networks and systems, (4) check the availability of emergency supplies and equipment, and (5) verify the operability of emergency equipment. In addition, repair and damage control shall be included in one major drill/exercise on an annual basis.

The site Emergency Preparedness (EP) Manager is responsible for the planning, scheduling, and coordinating of all emergency planning related drills and exercises. The site EP Manager in consultation with site management, will approve all drills and exercises. The site Manager Plant Training will assist the Emergency Preparedness Manager in carrying out these responsibilities.

Annually a major drill or exercise will be conducted. The Emergency Preparedness Manager will:

- Coordinate the assignment of personnel to prepare a scenario.
- Coordinate efforts with other participating emergency personnel, organizations, and agencies.
- Obtain required approvals (refer to applicable

 Administrative Procedures).
- Coordinate a date for drill execution and arrange for qualified observers.
- · Critique the results of the drill.



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

- · Assign personnel to correct any deficiencies.
- · Ensure that deficiencies are corrected.
- Ensure that proper documentation is retained.

 Scheduled drills and exercises will be held involving

scheduled drills and exercises will be held involving appropriate offsite as well as onsite emergency personnel, organizations, and agencies. These drills and exercises will be conducted to simulate as closely as possible actual emergency conditions and may be scheduled such that one or more drills or exercises can be conducted simultaneously. Drill scenarios will be prepared that involve participation of several emergency teams and all or specific parts of the onsite and offsite emergency organizations including varying degrees of participation of Federal, State and County agencies and organizations and local services support personnel and organizations.

The Emergency Preparedness Manager will notify the offsite emergency response organizations and agencies in advance of the scheduled date of the drill or exercise.

A critique shall be scheduled and held as soon as practical after completing a drill or exercise. Observer and participant comments will be given to the Emergency Preparedness Manager for evaluation and/or resolution by assignment to appropriate individuals. A formal report will be prepared from each drill or exercise. Appropriate action items will be generated and tracked to completion. A file will be maintained on each drill listed below.



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

Medical Emergency Drill

At least one drill shall be conducted annually for the OCNGS site. The drill will involve the participation of local medical support personnel and organizations (e.g., physician, ambulance service, hospital), and will involve simulated (injured) contaminated personnel.

· Fire Emergency Drill

Fire drills shall be conducted in accordance with the site Fire Protection Plan.

· Communications Links Test

- a. The communication links with state and county governments within the Plume Ex_ sure Pathway EPZ shall be exercised at least once per month for the OCNGS site.
- b. The communication links with Federal emergency response organizations and states within the Ingestion Pathway EPZ shall be exercised in accordance with State procedures.
- c. The communication links between the nuclear facility, State and local emergency operations centers and field assessment teams shall be exercised at least annually for the OCNGS site.
 - In addition, emergency phone numbers shall be verified and updated on a quarterly basis.
- d. The communications link between the nuclear facility and the NRC shall be exercised at least once per month for the OCNGS site.

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

Radiological Monitoring Drill

At least one drill shall be conducted annually for the OCNGS site. The drill shall include collection and analysis of all appropriate sample media for both onsite and offsite locations.

· Radiological Controls Drill

At least one drill shall be conducted semi-annually. The drill will involve response to, and analysis of, simulated elevated airborne and liquid samples and direct radiation measurements. The drill shall include analysis of inplant liquid samples with simulated elevated activity levels.

· Hazardous Material Spill Drill

Hazardous Material Spill Drills shall be conducted as required by the GPUN Environmental Control Plan.

· Biennial Site Exercises

a. The OCNGS Emergency Plan shall be tested

biennially at the OCNGS site to include a

scenario appropriate to a Site Area or General

Emergency. State and local government emergency

plans will be included biennially with full or

partial participation by state and local

governments within the Plume Exposure Pathway

EPZ as required by federal regulations.



Number 2000-PLN-1300.01

Title
GPU Nuclear Emergency Plan for Oyster Creek Nuclear

Revision No.

1

b. Conduct of the exercise shall include

mobilization of onsite and offsite emergency

response personnel and resources in order to

verify their capability to respond to an

emergency. Communications with State and County

agencies will be included. The scenario will be

varied from year to year such that all major

elements of these plans and preparedness

organizations are tested within a six year

period. Once within each six year period an

annual exercise will be conducted in accordance

with NRC and FEMA objectives.

8.2.3 Emergency Preparedness Department

The responsibilities of the Emergency Preparedness Department shal include, but are not necessarily limited to:

- Ensuring the coordination of the OCNGS Emergency Plan with State, County and local emergency plans, the site Security Plan and the site Emergency Public Information Implementing Procedure.
- Ensuring that the information, data, and procedures
 detailed in the Emergency Plan Implementing Document are
 consistent with the guidance provided in the Emergency
 Plan.
- Ensuring that the Emergency Plan Implementing Documents are coordinated and interfaced properly with other procedures (e.g., Administrative Procedures, Emergency Operating Procedures).



Number 2000-PLN-1300.01

Title
GPU Nuclear Emergency Plan for Oyster Creek Nuclear

Revision No.

1

- Assisting the Training and Education Department in coordinating and/or providing emergency preparedness related specialty training.
- Coordinating emergency planning drills and exercises as previously described.
- Coordinating the review and updating of the Emergency Plan and Implementing Document.
- Ensuring the maintenance and inventory of emergency equipment and supplies.
- Maintaining current with respect to changes in federal regulations and guidance that impact emergency planning activities.
- 8.3 Review and Updating of the Emergency Plan and Implementing Document

 The Emergency Plan and Implementing Documents will be reviewed on an annual basis.

The Nuclear Safety Assessment Department is responsible for auditing, in accordance with 10 CFR 50.54 (t) at least once every twelve (12) months, the Emergency Plan and Implementing Document to verify compliance with the Operational Quality Assurance Plan, the Fire Protection Program Plan, internal rules and procedures, federal regulations, and operating license provisions. This audit will be conducted pursuant to the procedures and methods set forth in the Operational Quality Assurance Plan. This audit will focus on the state of emergency readiness (i.e., review of emergency drills, exercises, capabilities and adequacy of interfaces). In addition, the Emergency Preparedness Manager will, by virtue of his involvement with the Emergency Preparedness Program, provide an ongoing review.



Number 2000-PLN-1300.01



Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

This Emergency Plan is considered a part of the Oyster Creek SAR.

Revisions to the Plan shall be administratively controlled consistent with Administrative Procedures 1000-ADM-1218.01, GPU Nuclear Policies,

Plans and Procedures, 1000-ADM-1291.01, GPU Nuclear Safety Review and Approval Procedure, and Emergency Preparedness Dept. Surveillance Procedures.

The site Emergency Plan Implementing Document will be incorporated into the Emergency Preparedness procedures program. As such, the Implementing Document will be prepared, reviewed, approved, controlled, distributed, and revised in accordance with applicable corporate and division procedures. Document holders (e.g., GPU Nuclear, Federal, State and County agencies) will receive revisions to the Emergency Plan Implementing Document in a controlled manner as they are issued.

The Site Emergency Preparedness Manager is responsible for coordinating the periodic reviews and audits of the Emergency Plans and Implementing Documents. In addition, he shall, through letters, meetings, seminars, or other means available, ensure that all elements of the total emergency organization (e.g. GPU Nuclear, Federal, State and County) are informed of the Emergency Plans, the Implementing Documents and revisions thereto.

Maintenance and Inventory of Emergency Equipment and Supplies

Designated emergency equipment and supplies and their storage

locations will be listed in the Emergency Plan Implementing Documents.

Such equipment and supplies will be maintained, inventoried, inspected and calibrated in accordance with approved site procedures.



Number 2000-PI 1-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

Equipment, supplies, and parts having shelf-lives will be checked and replaced as necessary.

Any deficiencies found during the inventory and inspection will be either cleared immediately or documented for corrective action. A report of each inventory and inspection, including documented deficiencies, will be prepared and submitted to the site Emergency Preparedness Manager. He will ensure that cognizant department heads assign personnel to correct deficiencies and shall ensure that identified deficiencies are corrected in a reasonable period of time.



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

9.0 RECOVERY

The Emergency Director and Emergency Support Director have the joint responsibility for determining and declaring when an emergency situation is stable and has entered the recovery phase. They will evaluate the status of the emergency by observing monitoring instrumentation and reviewing all current and pertinent data available from emergency response and/or monitoring teams. They shall consider the emergency under control and in the recovery phase only when the following general guidelines are met:

- Radiation levels in all in-plant areas are stable or are decreasing with time.
- Releases of radioactive materials to the environment from the plant are under control or have ceased.
- Containment pressure is at normal levels.
- Reactor plant is stable and in a long term safe shutdown condition.
- Any fire, flooding, or similar emergency conditions are controlled or have ceased.

If the above conditions are met, the Emergency Director/Emergency Support Director (ED/ESD) may establish the long term Recovery Organization or close out the emergency. Information pertaining to emergency close-out is typically discussed with the State and NRC.

If all of the above criteria are <u>not</u> met but the plant is proceeding in an orderly fashion towards meeting the above criteria, the ESD/ED may implement a two or three section watchbill, and maintain the emergency response capability at the fully-staffed level; or implement a reduced staffing of the emergency organizations commensurate with plant conditions until recovery or close-out is appropriate. As a minimum, for an Alert all of the onsite emergency response facilities (i.e., ECC, TSC, and OSC) and EACC must



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

remain staffed. As a minimum, for a Site Area or General Emergency all the onsite and offsite emergency response facilities must remain staffed.

Although planning for recovery will vary according to the specific nature of the emergency situation, a long-term recovery organization that is general in nature has been defined based on the normal GPUN organization.

During recovery operations, the radiation exposure limits of 10 CFR 20 shall apply. Compliance with those limits shall be the responsibility of the Director, Oyster Creek Division.

At the time of declaring that an emergency has entered the recovery phase, the ED/ESD shall be responsible for providing notification to all applicable agencies (e.g., Federal, State, and County agencies) that the emergency has shifted to a recovery phase.

Recovery actions that plan for, or may result in, radioactive release will be evaluated by the Director, Oyster Creek Division and his staff as far in advance of the event as possible. Such events and data pertaining to the release will be reported to the appropriate offsite emergency response organization and agencies.

Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

10.0 REFERENCES

- 10.1 Title 10, Code of Federal Regulations
 - 10.1.1 Part 20, Standards for Protection Against Radiation
 - 10.1.2 Part 50, Licensing of Production and Utilization Facilities
 - 10.1.3 Part 50, Appendix E, Emergency Plans for Production and Utilization Facilities.
 - 10.1.4 Part 73, Physical Protection of Plants and Materials
 - 10.1.5 Part 100, Reactor Site Criteria
- 10.2 US NRC Order and Notice of Hearing, Docket No. 50-289, dated August 9, 1979
- 10.3 Section 13.3, Emergency Planning, of Regulatory Guide 1.70, Revision 3, Standard Format and Content of Safety Analysis Reports for Nuclear Power Plants
- 10.4 NUREG-75/087, Revision 1, US NRC Standard Review Plan
 - 10.4.1 Section 9.5.1, Fire Protection Program
 - 10.4.2 Section 13.3, Emergency Planning
- 10.5 Regulatory Guide 1.97, Revision 1 dated August 1977, Instrumentation for Light-Water-Cooled Nuclear Power Plants to Assess Plant Conditions During and Following an Accident
- 10.6 US Environmental Protection Agency Manual EPA-400-R-92-001, October 1991, Manual of Protective Action Guides and Protective Actions for Nuclear Incidents
- 10.7 NUREG-0396, EPA 520/1-78-016, November 1978, Planning Basis for the Development of State and Local Government Radiological Emergency Response Plans in Support of Light Water Nuclear Power Plants
- 10.8 Federal Radiation Council Report No. 7, May 1965, Background Material for the Development of Radiation Protection Standards
- 10.9 National Council on Radiation Protection Report No. 39, January 15, 1971, Basic Radiation Protection Criteria
- 10.10 ANS-3.2/ANSI N18.7-1976, Administrative Controls and Quality Assurance for the Operations Phase of Nuclear Power Plants
- 10.11 Regulatory Guide 1.120 Revision 1 dated November 1977, Fire Protection Guidelines for Nuclear Power Plants
- 10.12 Regulatory Guide 1.16, Revision 4 dated August 1975, Reporting of Operating Information Appendix A, Technical Specifications

(130001)



Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

- 10.13 US NRC Information Report SECY-79-450, dated July 23, 1979, Action Plan for Promptly Improving Emergency Preparedness
- 10.14 NRC Emergency Planning Review Guideline Number One Revision One Emergency Planning Acceptance Criteria for Licensed Nuclear Power Plants, dated September 7, 1979
- 10.15 Emergency Operations Plan for Ocean County, October 1, 1988
- 10.16 NUREG-0728, NRC Incident Response Plan, Revision 1, April 1, 1983.
- 10.17 Oyster Creek Nuclear Station Procedures
 - 10.17.1 Administrative Procedures
 - 10.17.2 Radiological Controls Procedures
 - 10.17.3 Emergency Procedures
 - 10.17.4 Security Procedures
 - 10.17.5 Alarm Response Procedures
- 10.18 NUREG-0654/FEMA-REP-1, Criteria for Preparation and Evaluation of Radiological Emergency Response Plans and Preparedness in Support of Nuclear Power Plants, dated November 1980
- 10.19 Jersey Central Power and Light Company Operating License DPR-16 (Docket No. 50-219), including Technical Specifications
- 10.20 State of New Jersey Radiological Emergency Operations Standard Operating Procedures
- 10.21 State of New Jersey Radiological Emergency Response Plan for Nuclear Power Plants Annex B Oyster Creek, Rev. 4, dated August 1987
- 10.22 Evacuation Time Estimates for the Plume Exposure Pathway EPZ at the Oyster Creek Nuclear Generating Station, dated December, 1991
- 10.23 Oyster Creek Nuclear Generating Station Final Safety Analysis Report
- 10.24 GPU Nuclear Organization Plan, 1000-PLN-1000.01
- 10.25 GPUN Operational Quality Assurance Plan, 1000-PLN-7200.01
- 10.26 AIF National Environmental Studies Project Document No. AIF/NESP 022, Atmospheric Dispersion Modelling For Emergency Preparedness. October 1981
- 10.27 1000-POL-1319.01, Emergency Preparedness Policy
- 10.28 NUREG-0737, TMI Lessons Learned





Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

TABLE 1

PERCENT OF LAND USE BY COUNTY

USE	OCEAN	
Forest & Woodland	55.53	
Crops	0.83	
Livestock	0.27	
Pasture	***	
Urban	7.27	
Business	0.89	
Industrial	2.72	
Public	17.8	
Other	17.8	
The second secon	Commence of the commence of th	

References: 1977 Survey for Ocean County, Ocean County Planning and Zoning Department



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear

Revision No.

1

TABLE 2

OCNGS EMERGENCY ACTION SUMMARY

CLASS	DESCRIPTION	INITIAL NOTIFICATIONS	
		ONSITE	OFFSITE
EVENT or indeed sail No race research	Events are in process or have occurred which indicate a potential degradation of level of safety of the plant. No releases of radioactive material requiring offsite response or monitoring are expected unless further degradation of safety occurs.	 Fire Brigade Damage Control Teams Surveillance Watches Search & Rescue Teams Monitoring Teams Security Force Appropriate Station Personnel 	* Fire Units * Rescue Assistance * Ambulance Service * Medical Service * NRC * State Police (1)(2)
		INITIAL	ACTIONS
	ONSITE PERSONNEL	OFFSITE PERSONNEL	
		• Fight Fire • Perform Emergency Repairs • Designate Surveillance • Administer First Aid • Conduct Rescue Operations • Perform Onsite Monitoring • Suitable Security Measures • Perform Continuing Assessment • Effect Prompt Offsite Notifications	* Provide Firefighting Assistance * Assist in Rescue Operations * Provide Medical Transportation * Provide Hospital Medical Treatment

Notification is required within 15 minutes from declaration of the event.
 State Police will make notification to BNE.



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

TABLE 2 (continued)

OCNGS EMERGENCY ACTION SUMMARY

		INITIAL NOTIFICATIONS				
CLASS	DESCRIPTION	ONSITE	OFFSITE			
ALERT	Events are in process or have occurred which involve an actual or potential substantial degradation of the level of safety of the plant. Any releases expected to be limited to small fractions of the EPA Protective Action Guideline exposure levels.	• Fire Brigade • Damage Control Teams • Monitoring Teams • Dose Projection Personnel • Appropriate Station Personnel	* Fire Units * NRC * State Police (1) (2)			
		INITIAL AC	TIONS			
		ONSITE PERSONNEL	OFFSITE PERSONNEL			
		* Fight Fire * Perform Emergency Repairs * Onsite and Offsite Monitoring * Offsite Dose Projections * Suitable Security Measures * Effect Prompt Offsite Notifications * Mobilize Onsite Emergency Organization * Perform Continuing Assessment * Activate TSC and OSC	Provide Onsite Assistance as Necessary Activate Primary Response Centers Alert Key Personnel to Standby Maintain Emergency Communications			

- (1) Notification is required within 15 minutes from declaration of the event.
- (2) State Police will make notification to BNE.



Number 2000-PLN-1300.01

Title
GPU Nuclear Emergency Plan for Oyster Creek Nuclear

Revision No.

1

TABLE 2 (continued)

OCNGS EMERGENCY ACTION SUMMARY

		INITIAL NOTIFICATIONS			
CLASS	DESCRIPTION	ONSITE	OFFSITE		
SITE AREA EMERGENCY	Events are in process or have occurred which involve actual or likely major failures of plant functions needed for protection of the public. Any releases are not expected to exceed EPA Protective Action Guideline exposure levels except near the site boundary.	Appropriate Emergency Teams Security Force All Other Station Personnel	* Appropriate Assistance * NRC * State Police (1)(2)		
		INITIA	LACTIONS		
		ONSITE PERSONNEL	OFFSITE PERSONNEL		
		* Appropriate Corrective and Protection Actions Onsite and Offsite Monitoring Offsite Dose Projections Suitable Security Measures Effect Prompt Offsite Notifications Activate TSC, OSC & EOF Personnel Evacuation as Necessary Mobilize Appropriate Portions of Offsite Emergency Organizations Perform Continuing Assessment Recommend Offsite Protection Actions	* Provide Onsite as Necessary * Activate and Man Response Centers * Mobilize Emergency Response Personnel * Continuously Evaluate Dose Projections * Place Public Notification Systems and Procedures Standby Status * Implement Appropriate Nearsite Emergency Protective Measures * Maintain Continuous Emergency Communications		

(1) Notification is required within 15 minutes from declaration of the event.

(2) State Police will make notification to BNE.



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear

Revision No.

1

TABLE 2 (continued)

OCNGS EMERGENCY ACTION SUMMARY

		INITIAL MOTIFICATIONS				
CLASS	DESCRIPTION	ONSITE	OFFSITE			
GENERAL EMERGENCY	Events are in process or have occurred which involve actual or imminent substantial core degradation or melting with potential for loss of containment integrity. Releases can be reasonably expected to exceed EPA Protective Action Guideline exposure levels offsite for more than the immediate site area.	Appropriate Emergency Teams Security Force All Other Station Personnel	* Appropriate Local Assistance * NRC * State Police (1)(2) * Ocean County (1) * Ocean Twp. (1) * Lacey Twp. (1)			
		INITIAL ACTIONS				
		ONSITE PERSONNEL	OFFSITE PERSONNEL			
GENERAL EMERGENCY (Cont'd)		* Appropriate Corrective and Protective Actions * Onsite and Offsite Monitoring * Offsite Dose Projections * Suitable Security Measures * Effect Prompt Offsite Notifications * Activate TSC, OSC & EOF * Personnel Evacuation as Necessary * Mobilize Total Emergency Organization * Perform Continuing Assessment * Recommend Offsite Protective Actions	• Provide Onsite Assistance as Necessary • Fully Staff All Response Centers • Mobilize Emergency Response Personnel • Continuously Evaluate Dose Projections • Implement Public Notification Procedure • Implement Appropriate Offsite Emergency Protectiv Measures • Maintain Continuous Emergency Communications			

- Notification is required within 15 minutes from declaration of the event.
 State Police will make notification to BNE.

Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclean Station

Revision No.

1

TABLE 3 EMERGENCY CLASSIFICATION OF POSTULATED ACCIDENTS

	ACCIDENT*	EMERGENCY CLASS OCNGS
1)	Decrease in Heat Removal by the Secondary System	Unusual Event
	* Turbine Trip w/o Bypass Valves	
2)	Decrease in Reactor Coolant System Flow Rate	Unusual Event
	* Trip of All (Simultaneous) Recirc. Pumps	
3)	Power Distribution Anomalies	
	Control Rod Maloperation (System Malfunction or Operator Error)	Unusual Event
	 Inadvertent Loading and Operation of a Fuel Assembly in an Improper Position 	Unusual Event
	Control Rod Drop	Unusual Event
4)	Increase in Heat Removal by the Secondary System	Site Area Emergency
	Steam System Piping Failure Outside Containment	
5)	Radioactive Release from a Subsystem or Component	
	Waste Gas System Rupture Accident	Site Area Emergency Site Area Emergency
	Radioactive Liquid Waste System Leak or Failure	Site Area Emergency
	Radioactive Liquid Tank Failure	Site Area Emergency
	Design Basis Fuel Handling Accident in Containment	
6)	Decrease in Reactor Coolant Inventory	General Emergency
	Loss of Coclant	

^{(*} Postulated Accidents for Given Conditions from OCNGS FSAR, 1985 Updated Version)



Number 2000-PIN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

3

TABLE 4

PLANT INSTRUMENTATION FOR ACCIDENT DETECTION

	ACCIDENT	INSTRUMENTATION
II	. OCNGS	
1.	Turbine Trip w/o Bypass Valves	• Reactor Pressure Indicator • Reactor Level Indicator • Turbine Supervisory • Steam Flow Indicator • Power Range Monitor
2.	Trip of All Recirculating Pumps	 Recirc. Flow Indicators Power Range Monitors Reactor Level Indicator Steam Flow Indicator Reactor Pressure Indicators
3.	Control Rod Maloperation Control Rod Drop	• Stack Gas Monitors • Steam Line Radiation Monitors • Off-Gas Monitors • Power Range Monitors • Pactor Level Indicators • Reactor Pressure Indicators • Feed Water Flow Indicators • Steam Flow Indicator • MSIV Position Indicators
4.	Inadvertent Loading & Operation of a Fuel Assembly in an Improper Position	 Area Radiation Monitors Reactor Building Ventilation Rad Monitors Standby Gas Treatment System Instrumentation Stack Gas Monitor
5.	Steam System Piping Failure Outside Containment	 Stack Radiation Monitors Area Radiation Monitors MSIV Position Indicators D_ywell Pressure/Containment Pressure Indicators ECCS Instrumentation Reactor Water Level Indicator System Pressure Indicators
6.	Radioactive Release from a Subsystem or Component	 Area Radiation Monitors Turbine Building Ventilation Radiation Monitors Stack Gas Monitor Standby Gas Treatment System Instrumentation



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

TABLE 4 (continued)

PLANT INSTRUMENTATION FOR ACCIDENT DETECTION

ACCIDENT	INSTRUMENTATION					
II. OCNGS						
7. Loss of Coolant	Stack Gas Monitors Area Radiation Monitors Reactor Building Ventilation Monitors Standby Gas Treatment Inst. Reactor Water Level ECCS Instrumentation Drywell Humidity Indicator Drywell Pressure/Containment Pressure Indicator Torus Water Level Indicator Drywell Monitors (CHRRMS) Containment Hydrogen Monitors					



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear

Revision No.


1

TABLE 5

ON-SHIFT EMERGENCY ORGANIZATION STAFFING (Available Immediately)

SHIFT POSITION	MIN NO.	ASSUMES DUTIES OF	EMERGENCY DUTIES	REPORT TO LOCATION/PERSON
Shift Supervisor	1	Emergency Director	Initially assumes the duties of the Emergency Director which includes the initial assessment and evaluation of any abnormal or emergency situation and for directing appropriate response in accordance with the emergency plan implementing procedures.	ECC/Plant Management
Group Operating Supervisor	1	Operations Coordinator	Retains his normal duties of directing the Control Room Operators in maintaining control over the plant.	ECC/ED (ECC/Shift Supervisor upon relief)
*Shift Technical Advisor	1	Shift Technical Advisor	Retains his normal duties of advising and assisting the Emergency Director on plant conditions.	ECC/ED
Control Room Operator (CRO)	2	Control Room Operator	Retains his normal duties of operating and controlling the Plant as directed.	ECC/Operations Coordinator
CRO	1	ECC Communications Coord'nator	Assumes the duties of the ECC Communications Coordinator. This position is responsible to make notification to off-site agencies. Once properly relieved, he will be used to support the emergency.	ECC/Emergency Director (CRO-ECC/Ops Coordinator upon relief) (EO-OSC/OSC Coordinator upon relief)
Security Personnel				Main Gate/ED (OCNGS)
Equipment Operators	1	Equipment Operators	Will be used to support the emergency.	ECC/GOS Coordination through OSC upon activation
Group Radiological Controls	1	Radiological Assessment Coordinator (RAC)	Initially assumes the duties of the RAC. This includes providing all radiological assessment (onsite and offsite) to the Emergency Director. This also includes supervising the Radiological Controls Technicians and coordinating the in-plant radiological controls support for access control, emergency repair, search and rescue, fire fighting, personnel monitoring and dosimetry. The Group Radiological Controls Supervisor will turn over the duties of the RAC when relieved.	ECC/Emergency Director (OSC/RAC - upon relief)

Required in accordance with Sites' Tech Specs. These personnel may be assigned other functions.



Number 2000-PLN-1300.01



Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear


Revision No.

1

TABLE 5 ON-SHIFT EMERGENCY ORGANIZATION STAFFING (Available Immediately)

SHIFT POSITION	MIN. NO.	ASSUMES DUTIES OF	EMERGENCY DUTIES	REPORT TO LOCATION/PERSON
Radiological Controls Technicians	2	Radiological Controls Technicians	Retain their duties for radiological controls support in the areas of access control, emergency repair, search and rescue, first aid, firefighting, personnel monitoring and radiological monitoring as directed.	OSC/RAC
Chemistry Technician	1	Chemistry	Responsible for providing chemistry sampling and analysis to support the existing plant conditions and if appropriate to initiate activities to obtain and analyze post accident samples. Assumes the duties of Chemistry Coordinator until properly relieved.	OSC/OSC Coordinator (OSC/Chemistry Coordinator - upon relief)
Operations/ Maintenance Supervisor	1	Operations Support Center (OSC) Coordinator	Initially assumes the duties of the OSC Coordinator which includes supporting emergency operations in the areas of emergency repair, search and rescue, chemistry, firefighting and maintenance. Once properly relieved, he may assume the duties of the Emergency Maintenance Coordinator and direct the maintenance technicians in plant repair and corrective actions.	OSC/Operations Coordinator (OSC/OSC Coordinator - upon relief)
Senior Maintenance Technician	1	Senior Maintenance Person	Assumes the duties of the Senior Maintenance Person. Provides support to the OSC Coordinator for emergency maintenance repair and corrective actions.	OSC/OSC Coordinator
Maintenance Personnel or Equipment Operator	1	Emergency Maintenance Team	Retain their duties of performing all emergency maintenance repair and corrective actions. May be called on for search and rescue and as drivers for Radiation Monitoring teams.	OSC/Emergency Maintenance Coordinator
Site Protection Shift Supervisor/Designated Senior site Protection Officer	1	Security Coordinator	Assumes the duties of the Security Coordinator which includes directing the security force accountability, access control and interfaces with the Local Law Enforcement Agencies/EOD.	Processing Center (Main Gate /Operations Coordinator.

Required in accordance with Sites' Tech Specs. These personnel may be assigned other functions.



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear

Revision No.

1

TABLE 5 (continued)

ON-SHIFT EMERGENCY ORGANIZATION STAFFING (Available Immediately)

SHIPT POSITION	MIN. NO.	ASSUMES DUTIES OF	EMEPGENCY DUTIES	REPORT TO LOCATION/PERSON
Site Security Force	Per Sec. Plan	Security Personnel	Retain their duties of maintaining site security and implementing accountability, site evacuation and support search and rescue functions. At OCNGS, are responsible for mobilizing GPUN emergency response personnel.	As Directed/Security Coordinator
**Fire Brigade	Fire Prot Plan (OC)		Respond to all fire alarms and report to fire locations with assigned equipment to combat the fire and assess the need for offsite firefighting support.	Fire Scene/Fire Brigade Leader
**First Aid and Rescue Team	2		Provide emergency first aid and assist in rescue operations.	OSC/OSC Coordinator
**Emergency Maintenance Team			(As stated Above)	
**Radiological/ Environmental Survey Teams	2		Obtain emergency equipment and vehicle and proceed to areas designated by the RAC/EAC to perform radiological and environmental surveys.	Onsite - OSC/RAC Offsite - EACC/EAC



Required in accordance with Sites' Tech Specs. These personnel may be assigned other functions.



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

TABLE 6

INITIAL RESPONSE EMERGENCY ORGANIZATION STAFFING (Available Within One Hour)

EMERGENCY POSITION	MIN. NO.	MINIMUM LEVEL OF EXPERTISE	EMERGENCY DUTIES	REPORT TO LOCATION/PERSON
Emergency Director	1	Senior Management Personnel	Responsible for initial assessment and evaluation of any abnormal or emergency situation and for directing appropriate response in accordance with the Emergency Plan Implementing Procedures.	TSC/Emergency Support Director
ED Assistant	1	Engineer or individual with equivalent combination experience/education.	Advises and assists the Emergency Director in matters pertaining to communications, onsite personnel assembly, security and pubic information.	TSC/Emergency Director
Operations Coordinator	1	Current or previously qualified Senior Reactor Operator	Coordinates plant operations, maintenance and chemistry through the Shift Supervisor and Operations Support Center Coordinator.	ECC/Emergency Director
Technical Support Center Coordinator	1	Engineer or individual with equivalent combination engineering experience/ education.	Directs the TSC engineers in plant technical assistance and acts as liaison to the Emergency Director.	TSC/Emergency Director
Radiological Assessment Coordinator	1	Senior Radiological Controls experienced person.	Coordinates and directs all RED Con support and operations.	TSC/Emergency Director
Radiological Engineering Support	1	Radiological Controls Experienced Personnel	Assist the Radiological Assessment Coordinator in performing his duties. Insure communications with the BNE until the EOF staff assumes that function.	TSC/RAC
ECC Communications Coordinator	1	Site Personnel	Provides current information and direction to the ECC Communicators; ensures proper records and logs are maintained.	ECC/ED Assistant
ECC Communicators	2	Site Personnel	Responsible for maintaining communications with the NRC on the ENS line; makes follow-up notifications to offsite agencies; maintains primary emergency communications using the Operations Line; monitors other emergency circuits as directed by the ECC Communications Coordinator.	ECC/ ECC Communications Coordinator



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

TABLE 6 (continued)

INITIAL RESPONSE EMERGENCY ORGANIZATION STAFFING (Available Within One Hour)

EMERGENCY POSITION	MIN. NO.	MINIMUM LEVEL OF EXPERTISE	EMERGENCY DUTIES	REPORT TO LOCATION/PERSON
Technical Support Center Engineer	3	Assorted Discipline Engineer or equivalent engineering experience/ education (e.g., I&C, Mechanical, Electrical)	Activate TSC, assess plant status, recommend mitigation actions, and provide technical support in the areas of core, electrical, mechanical, and I&C.	TSC/TSC Coordinator
Operations Support Center Coordinator	1	Senior Maintenance or Operations Experienced Person.	Coordinates and directs emergency logistic activities to support Operations in the area of Chemistry, Rad Con and Maintenance.	OSC/Operations Coordinator
Emergency Maintenance Coordinator	1	Senior Maintenance Tech. Maint. Supv./Foreman (OCNGS)	Assigns personnel and directs emergency maintenance repair and corrective actions.	OSC/OSC Coordinator
Radiological Controls Coordinator	1	Radiological Controls Technician	Responsible for supervising Radiological Controls Technicians and coordinating the on-site and in-plant radiological controls support for activities such as access control, emergency repair, search and rescue.	OSC/RAC
Chemistry Coordinator	1	Chemistry Technician	Responsible for coordinating chemistry activities to support the existing plant conditions, and, if appropriate, for ensuring that all post-accident samples are obtained and analyzed.	OSC/OSC Coordinator
Emergency Assembly Area Coordinator	1	Site Personnel	Directs assembly and sign-in of site personnel at the onsite emergency assembly area.	Emergency Assembly Area (EAA)/ED Assistant
Security Coordinator	1	Site Protection Shift Supervisor/design ated Senior Site Protection Officer	Responsible for the overall security response during an emergency. Coordinates the activities of the Site Protection Shift Supervisor and Local Law Enforcement Agencies/EOD.	Processing Center (Main Gate)/ED Assistant
Medical Representative	1	Medical Personnel/EMT	Responsible for providing first aid support.	OSC/OSC Coordinator







Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear

Revision No.

1

TABLE 7 EMERGENCY SUPPORT ORGANIZATION STAFFING

	EMERGENCY POSITION	MIN. NO.	MINIMUM LEVEL OF EXPERTISE	EMERGENCY DUTIES	REPORT TO LOCATION/PERSON
+	Emergency Support Director (ESD)	1	Senior Management Representative	Responsible for overall management of emergency response and directs the response of the offsite organization functional groups in support of the onsite emergency organization.	EOF/Office of President
+	ESD Assistant	1	Management or Senior Staff Personnel	Advises and assists the Emergency Support Director in matters pertaining to communications, technical support, implementation of the Emergency Plan and public information.	EOF/ESD
+	Group Leader- Radiological and Environmental Controls (R&EC)	1	Radiological and Environmental Controls Management Personnel	Functions as the "point of contact" for radiological and environmental controls information for the ESD; collects information from the RAC and EAC and, presents that information to ESD; overall-in-charge of R&EC effort.	EOF/ESD
	Group Leader Administrative opport	1	Management Personnel	Responsible for administrative and logistic functions required to support the emergency organization. These services include: General Administration, Communications, Security, Accommodations, Commissary, Safety and Human Resources.	EOF/ESD
+	Emergency Preparedness Representative	1	Management or Staff Personnel	Provides ESD with information relating to onsite, offsite and state emergency facilities, communications, personnel and resources availabilities and procedure requirements.	EOF/ESD Assistant
+	EOF Communications Coordinator	1	Site Personnel	Responsible for the operation of the communications systems at the EOF and the coordination of requests for outside assistance. Ensure that the primary and back-up communications systems are activated and operational. Maintains records of communication and status boards.	EOF/ESD Assistant
	EOF Communicators	2	Site Personnel	Responsible to maintain communications with the site and offsite agencies, as needed, make additional notifications, as necessary and receive incoming calls.	EOF/EOF Communications Coordinator

This position will report to the EOF within one (1) hour upon notification of a Site Area or General

Emergency or when requested.

This position will report to the EOF/EACC within (1) hour upon notification of an Alert, Site Area or General Emergency.

Note: Staff and group members will be assigned by their respective Group Leaders/Coordinators who will also assign their training and ensure their availability during an emergency.



TABLE 7

GPUN Emergency Plan

Number

2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

TABLE 7 (continued)

EMERGENCY SUPPORT ORGANIZATION STAFFING

	EMERGENCY POSITION	MIN.	MINIMUM LEVEL OF EXPERTISE	EMERGENCY DUTIES	REPORT TO LOCATION/PERSON
	Public Information Tech Representative/ EOF	1	Media Trained Personnel	Responsible for gathering all approved and final information regarding the plant event. Providing the PI Tech Rep in the JIC with up-to-date information	EOF ESD Assistant
	Public Information Tech Representative/ JIC	1	Media Trained Personnel	Responsible for retrieving information from the PI Tech Rep in the EOF and being a single point of reference for those writing press releases and presiding over briefings	Media Center Lead JIC
	Media Center Lead/JIC	1	Media Trained Personnel	Responsible for the command and control over the centers activities and moderator during press briefings. Also interface with State and Local Government Communications personnel.	JIC/ESD
	Media Center Advisor/JIC	1	Media Trained Personnel	Serves as the technical spokesperson on the panel during press conferences	Media Center Lead JIC
+	Press Release Writer/JIC	1	Media Trained Personnel	Serves as the news release writer	Media Center Lead JIC
+	Technical Support Representative	1	Operations or Engineering Experienced Person	Provides technical liaison to the ESD and the onsite Technical Support Center Coordinator. Monitors the Operations Line and/or Technical Functions Line in order to obtain real time operational status from the ECC Communicator and relays this information to the ESD.	EOF/ESD
**	Environmental Assessment Coordinator (EAC)	1	Environmental Controls Manager or Scientist/Managem ent Person with Radiological Controls Experience	Responsible for the Radiological Environmental Monitoring Program. When the EACC is activated, assumes control of the offsite radiological monitoring and environmental assessment from the Radiological Assessment Coordinator. Communicates with monitoring teams and the Radiological Assessment Coordinator and reports findings and projections to the Group Leader-R&EC at the EOF.	EOF/Group Leader-R&EC
++	Met/Dose Coordinator	1	Environmental Controls Scientist/Managem ent Person with Radiological Controls Experience	Coordination collection of meteorological data for use in developing dose projections and/or weather forecast, and advises EAC regarding implications these may have on protective action recommendations.	EOF/EAC

⁺ This position will report to the EOF within one (1) hour upon notification of a Site Area or General Emergency or when requested.

Note: Staff and group members will be assigned by their respective Group Leaders/Coordinators who will also assign their training and ensure their availability during an emergency.



This position will report to the EOF/EACC within (1) hour upon notification of an Alert, Site Area or General Emergency.



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

TABLE 8

INVENTORY OF OYSTER CREEK EMERGENCY KITS BY GENERAL CATEGORY

I. EMERGENCY RAD CON EQUIPMENT

A. Typical Contents

- 1. Full Face Respirators with Canisters
- 2. Survey Instruments Radiation Survey Meters, Counter Scalers
- 3 Dosimetry Equipment Dosimeters/Chargers
- 4. Protective Clothing
- 5. Air Sampler and Cartridges
- 6. Support Materials Maps and Procedures, Etc.

II. EMERGENCY MONITORING EQUIPMENT

A. Typical Contents

- 1. Full Face Respirators with Canisters
- 2. Survey Instruments Radiation Survey Meters, Counter Scalers
- 3. Dosimetry Equipment Dosimeters/Chargers
- 4. Protective Clothing
- 5. Air Sampler and Cartridges
- 6. Support Materials Maps and Procedures, Etc.

III. EMERGENCY CHEMISTRY EQUIPMENT

- 1. Remote Handling Tool
- 2. Sample Vials
- 3. Particulate Filter Cask
- 4. Iodine Cartridge Cask
- 5. Noble Gas Sample Cask



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

TABLE 8 (continued)

INVENTORY OF OYSTER CREEK EMERGENCY KITS BY GENERAL CATEGORY

IV. DAMAGE CONTROL

A. Typical Equipment Available

- 1. Hand tools
- 2. Cutting/Welding equipment
- 3. Patching materials
- 4. Submersible pumps
- 5. Electrical equipment
- 6. Rigging equipment

V. EMERGENCY FIRST AID AND RESCUE EQUIPMENT

- 1. Splints
- 2. Bandages
- 3. Stretchers



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

TABLE 9

TYPICAL ENVIRONMENTAL/RADIOLOGICAL MONITORS

INSTRUMENTATION	PURPOSE
a. Meteorological Tower	Wind Speed and Direction, Temperature
b. Air Samplers	Analysis for Airborne Radioiodine and Particulates
c. Environmental Sampling Equipment	Environmental Media Sampling
d. Pressurized Ionization Chamber (PIC)	Gamma Radiation
e. Thermoluminescent Dosimeters (TLD)	Beta, Gamma Radiation
f. Geiger Mueller Detectors	Beta, Gamma Radiation



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

TABLE 10

GPUN EMERGENCY RESPONSE/ADDITIONAL SUPPORT FACILITIES

FACILITY	LOCATION	SPECIAL FRATURES
ECC	Turbine Building 46'	
TSC	Site Emergency Bldg.	HEPA and Charcoal Filtered Ventilation System and continuous air monitors and radiation monitor.
osc	Drywell Processing Center	
FAA	Site designated areas (e.g., Materials Management Warehouse, OCAB Cafeteria)	
EOF	Lakewood, N.J.	Located in the Pine Land Division Office approximately 18 miles from the site; location for BNE and NRC liaison representatives.
Media Center/ JIC	Lakewood, N.J.	Co-located with EOF.
RAA	Berkley Line Station	
EACC	Co-located in the Emergency Operations Facility at both sites.	



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

TABLE 11

COUNTY, AND STATE EMERGENCY OPERATIONS CENTERS

SITE	ROC LOCATION
OCNGS	Ocean County - Miller Air Park, Berkeley Township
OCNGS	State Police - State Police Division Headquarters, West Trenton



Number 2000-PLN-1300.01

Title
GPU Nuclear Emergency Plan for Oyster Creek Nuclear
Station

Revision No.

1

TABLE 12 OCNGS EMERGENCY COMMUNICATIONS NETWORK

CIRCUIT	CIRCUIT	*COMMUNICATOR	INFORMATION TRANSMITTED	ALTERNATE COMMUNICATIONS
ERF	Touch Tone Or Head Set	a)ECC b)TSC c)OSC d)EOF e)GPUN HQ f)Main Gate g)RAA h)JIC	ED/Ops Coordinator inplant response and status reports	Conventional Telephones
NRC Emergency Notifications System (ENS)	Touch Tone	a)ECC b)TSC c)EOF d)Onsite NRC e)NRC Operations Center	In-Plant radiological conditions and concerns	Conventional Telephones
NRC Haalth Physics 'letwork (HPN)	Touch Tone	a)TSC b)EOF c)Onsite NRC d)NRC Operations Center e)NRC Region I	Technical Engineering discussions	Conventional Telephones
Radio Communications	Touch Tone	a)Certain Onsite Locations b)Mobile Units	Plant Status information	Conventional Telephones
Bur. of Nuclear Engineering Information Line	Auto-Ring	a)ECC b)EOF c)TSC	Plant status and radiological information	Conventional Telephones
Emergency Director's Hotline	Auto-Ring	a)ECC b)TSC c)EOF	ED/ESD communications and consultation	Emergency Management line, conventional telephones
Notification Lines (NJSP/Ocean County)	Auto Ring	a)ECC b)TSC c)EOF	Official notifications (e.g., initial notifications, reclassifications, termination of the event)	Conventional Telephones
NJ State Emergency Director Hotline	Auto-Ring	a)ECC b)EOF c)TSC	Dedicated communication link between ED/ESD and State Emergency Director	Conventional Telephones
Environmental Assessment Direct Line	Auto-Ring	a)ECC b)TSC c)EOF	Dedicated link between RAC and EAC	Conventional Telephones, Radiological line, Environmental Assessment line

^{*} Communications are assigned duty roster personnel and facility staff designated by the Facility Coordinator/Group Leader



Number 2000-PLN-1300.01

Title
GPU Nuclear Emergency Plan for Oyster Creek Nuclear

Revision No.

1

TABLE 13

DEPARTMENT COMMITMENTS TO PROVIDE INSTRUCTORS

	TRAINING DEPARTMENT	EMERGENCY PREPAREDNESS
TRAINING		
Cyclic Training Positions		
Shift Supervisor/Site Shift Manager Group Operating Supervisor CRO's Equipment Operators Maintenance Foreman Maintenance Workers Rad Con Foreman Rad Con Technicians Chemistry Technicians Site Protection Force	X X X X X X X	x x
Training Focus		
Emergency Management ERF-ECC ERF-OSC ERF-TSC ERF-EOF Dose Projection Assessment Onsite/Offsite Radiological Survey Site Protection/Assembly/Accountability Emergency Radiological Controls Emergency Chemistry Emergency Teams Contaminated Injured and Decontamination Emergency Notification and Callouts	X X X X X X X X X X	х



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

TABLE 14

PERIODIC TRAINING FOR GPUNC EMERGENCY RESPONSE PERSONNEL

NOTE: This table identifies the broad subject areas to be included in Emergency Plan Training for personnel assigned to the Emergency Response Organization. Emergency Plan Training does not include training in the skills that are prerequisite for assignment to these positions.

	Position/Title	Scope of Training
: : : : : : : : : : : : : : : : : : : :	Emergency Director Operations Coordinator Shift Supervisor Shift Foreman ED Assistant Emergency Support Director ESD Assistant Emergency Preparedness Representative Group Leader R&EC Site Shift Manager Group Operating Supervisor	Emergency Organization, Emergency Facilities, Emergency Action Levels, Emergency Classifications, Concept of Operations, Emergency Communications, Dose Projection and Assessment Methodology, Protective Actions, and procedural responsibilities. The depth of training provided is a variable of the position held by the responsible member.
•	Control Room Operators	Techniques and methodology in operating communications equipment, proper log keeping and formal communication.
:	Radiological Assessment Coordinator Radiological Engineering Support Environmental Assessment Coordinator Met-Dose Coordinator	Plant Systems affecting dose assessment, EACC operations, RAC operations, RAC/EAC responsibilities and interfaces, dose projection and assessment, protective action.
	Radiological Controls Coordinator	Emergency organization, emergency classification, communications, facilities, relevant EPIPs, radiological controls during emergencies and interfacing with hospital, safety, security and rad con personnel.
	Group Radiological Controls Supervisor	Radiological controls during emergencies, dose projection and assessment, relevant EPIPs, post-accident sampling systems, emergency organization, facilities, communications and interfacing with hospital, safety, security and operations personnel.
:	Public Information Representative JIC/Presiding Media Briefer Communications Personnel	Emergency plan overview, media center activities and lessons learned.
•	Radiological Controls Technician	Emergency organization, facilities, emergency classification, communications, emergency ait instrument use, relevant EPIPs, radiological controls during emergencies and interfacing with hospital, safety, security and operations personnel concerning injuries and decontamination of personnel and vehicles.
	Radiological/Environmental Survey Teams	Emergency kit instrument use, relevant EPIPs, formal radio communications, proper sampling techniques and practical exercises.



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

TABLE 14 (continued)

PERIODIC TRAINING FOR GPUNC EMERGENCY RESPONSE PERSONNEL

NOTE: This table identifies the broad subject areas to be included in Emergency Plan Training for personnel assigned to the Emergency Response Organization. Emergency Plan Training does not include training in the skills that are prerequisite for assignment to these positions.

Position/Title	Scope of Training
 TSC Coordinator TSC Engineers Technical Support Representative (EOF) OSC Coordinator Group Leader - Administrative Support 	Emergency organization, emergency response facilities, emergency classification and communications, facility activation, relevant EPIPs, and concept of operations of the respective facilities.
Emergency Maintenance Coordinator	Emergency organization, facilities, communications, concept of operations, relevant EPIPs, and post-accident radiological controls.
Maintenance Technician	Emergency organization, facilities, emergency classification, communication, concept of OSC operations, and relevant EPIPs.
Equipment Operators	This training will include concept of operations and radiological controls in a post-accident environment, relevant EPIPs, emergency organization, facilities and emergency radio communications.
Chemistry Technician Chemistry Coordinator	Emergency organization, facilities, and communications equipment. Procedural guidance for gathering and analysis of chemistry samples.
• ECC Communications Coordinator • ECC Communicators • EOF Communications Coordinator • EOF Communicators	Techniques and methodology in operating communications equipment, proper logkeeping, formal communications, and offsite notifications.
• Security • Security Coordinator • Emergency Assembly Area Coordinator	Emergency organization, facilities, concept and methodology for accountability and operation of the Emergency Assembly Area, relevant EPIPs.
Medical Representative	Emergency organization, facilities, classification and communications, interfacing with hospital, safety, security, and rad con personnel for action concerning injuries.

Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

TABLE 15

EMERGENCY RESPONSE ORGANIZATION STAFFING RESPONSIBILITIES

EMERGENCY RESPONSE ORGANIZATION POSITION	RESPONSIBILITY FOR STAFFING DESIGNATED FOSITION(S)
ALL POSITIONS	Division Director, Responsible for each discipline.
	INITIAL RESPONSE EMERGENCY ORGANIZATION
Emergency Director, (ED) Operations Coordinator ED Assistant Radiological Assessment Coordinator/Staff Radiological Engineering Support ECC Communications Coordinator/Communicators TSC Coordinator TSC Engineers Chemistry Coordinator OSC Coordinator Radiological Controls Coordinator Radiological/Environmental Survey Teams Emergency Maintenance Coordinator Medical Representative Security Coordinator ** Emergency Assembly Area Coordinator Public Information Representative	Director, Plant Division Director, Engineering Division Director, Engineering Division Director, Plant Division Director, Human & Admin. Services Division Director, Human & Admin. Services Division Director, Human & Admin. Services Division Director, Communications
	EMERGENCY SUPPORT ORGANIZATION
Emergency Support Director (ESD) ESD Assistant Group Leader - Rad. & Env. Controls Emergency Preparedness Representative Technical Support Representative	Director, Plant Division Director, Engineering Division

- ** This position does not require respiratory/radiation worker training (Level II) qualification or active participation in the dosimetry system (i.e., TLD assigned and current WBC on record).
- ECC Emergency Control Center
- TSC Technical Support Center
- OSC Operations Support Facility
- EOF Emergency Operations Facility
- RAC Radiological Assessment Coordinator



Number 2000-PLN-1300.01

Title

GPU Nuclear Emergency Plan for Oyster Creek Nuclear Station

Revision No.

1

TABLE 15 (continued)

EMERGENCY RESPONSE ORGANIZATION STAFFING RESPONSIBILITIES

EMERGENCY RESPONSE ORGANIZATION POSITION	RESPONSIBILITY FOR STAFFING DESIGNATED POSITION(S)
	EMERGENCY SUPPORT ORGANIZATION
Technical Support Staff	Director, Engineering Division
Public Information Representative	Director, Communications
EOF Communications Coordinator	Director, Plant Division
EOF Communicators	Director, Plant Division
Group Leader - Administrative Support/Staff	Director, Plant Division
JIC/Media Center Briefers	Director, Communications
Environmental Assessment Coordinator/Staff	Director, Plant Division
Met/Dose Coordinator	Director, Plant Division

Note:

Staff and group members will be assigned by their respective group leaders/coordinators who will also assign their training and ensure their availability during an emergency.

- ** This position does not require respiratory/radiation worker training (Level II) qualification or active participation in the dosimetry system (i.e., TLD assigned and current WBC on record).
- ECC Emergency Control Center
- TSC Technical Support Center
- OSC Operations Support Facility
- EOF Emergency Operations Facility
- RAC Radiological Assessment Coordinator

FIGURE 1




FIGURE 2
OCNGS SITE RELATIVE LOCATION




FIGURE 3

OCNGS SITE EXCLUSION AREA AND LOW POPULATION ZONE




FIGURE 4




FIGURE 5

OCNGS SITE INJESTION PATHWAY (50 MILE) EMERGENCY PLANNING ZONE





FIGURE 6 OCNGS NORMAL SHIFT ORGANIZATION




Lisison/Communications

These positions are not in the normal shift complement. They merely Indicate the reporting scheme for certain shift positions. * Note:

These positions may be filled by another qualified Operations/Maintenance Supervisor.

:

GPUN ON-SHIFT EMERGENCY ORGANIZATION OCNGS




Fire Brigade, Search and Rescue, First Aid and Emergency Maintenance Teams will be staffed with On-Shift personnel that may be assigned other functions and will report to the OSC Coordinator. For security based events, the Security Coordinator has the capability of direct communications with the Emergency Director. NOTE:

Normal Shift Position

Direction/Reporting Limiton/Communications Required in accordance with Site's Tech Space

FIGURE 8

GPUN INITIAL RESPONSE ORGANIZATION OCNGS



- (1) Reports to Group Leader R&EC when Emergency Support Organization is activated.
- (2) Position may be filled SSM or GOS.

Direction/Reporting
---- Liaison/Communications

FIGURE 9

GPUN EMERGENCY SUPPORT ORGANIZATION





FIGURE 10

OCNGS NOTIFICATION NETWORK



- NOTES: (A) Notifications are sequenced as shown, with the initial notification designated by "1st."
 - (B) If initial event is a General Emergency, a description of the event and PAE is given to the State and Ocean County.
 - (C) Initial notification of the event on dedicated line must be made within 15 minutes of declaration.