# ATTACHMENT 2

Commonwealth Edison Co's NDE Procedure NDT-C-38, for UT Examination of Cast Stainless Steel Components.

# COMMONWEALTH EDISON COMPANY NONDESTRUCTIVE TESTING PROCEDURE FOR ULTRASONIC EXAMINATION OF FULL PENETRATION BUTT WELDS IN CAST STAINLESS STEEL COMPONENTS BYRON AND BRAIDWOOD STATIONS

### A. Scope

- A.1 The ultrasonic methods described in this procedure are for the examination of full penetration butt welds in statically cast stainless steel material, SA-351 Grades CF8A and CF8M in PWR Reactor Coolant systems. The cast stainless steel (CSS) welds are of different types such as: forged pipe-to-cast elbows, pumps or valves and cast elbows-to-cast pumps or valves.
- \*\*Dest effort\* to meet ASME code requirements as provided by IWA-2240, and is specifically designed for detection of planar indications in the lower 25% to 50% of the component wall thickness for materials from approximately 2.0° to 4.0° thick.
- A.3 This procedure utilizes straight beam (0°) and angle beam (approx. 40°) refracted longitudinal wave techniques.

## B. Applicable Documents and Codes

B.1 The following codes and standards form a part of this examination procedure to the extent specified herein.

MDT-C-38 Rev 0 June, 1986 Page 2 of 23

- B.2 American Society of Mechanical Engineers (ASME) Boiler and Pressure Vessel Code, section XI, Rules for Inservice

  Inspection of Nuclear Power Plant Components, and section V. Nondestructive Examination, 1977 Edition, Summer of 1978 addenda.
- B.3 American Society for Nondestructive Testing (ASNT)

  Recommended Practice for Nondestructive Testing Personnel

  Qualification and Certification SNT-TC-1A, Supplement C,

  1975 or 1980 Edition.
- B.4 Electric Power Research Institute (EPRI) Report, <u>Ultrasonic</u>

  Examination of Cast Stainless Steel Components In Main

  Coolant Piping Systems At Byron Nuclear Power Plant,

  December 18, 1985.

### C. Application

- C.1 The objectives of the methods given herein is the detection and recording of indications within the weld, the heat affected zone, and the base material adjacent to the weld. The indications that are located from 25% to 50% through wall depth are to be evaluated and identified by the inspector.
- C.2 The examination shall be performed from the outside of the component by means of contact ultrasonic testing.

- C.3 Examination areas shall include the entire circumference of the weld, the heat-affected zone and the cast stainless steel base material, to the extent possible, adjacent to the weld. When the afore mentioned volume cannot be examined due to surface contours and other restrictions (valves and pumps etc.) the maximum possible area shall be examined. The area examined and type of restrictions shall be documented on the report form.
- C.4 Reflectors parallel to the weld shall be detected by angle beam scanning from the cast side/sides with the beam directed toward and perpendicular to the weld, to extent possible.
- C.5 Reflectors transverse to the weld shall be detected by angle beam scanning on the weld surface and the cast base material side/sides with the beam directed parallel to the weld, in two directions, 180° to each other, where possible.
- C.6 A straight beam examination shall be performed on each weld for angle beam interference, for attenuation measurements, to obtain exact component wall thickness measurements at the counterbore area. Further more, straight beam examination is required to profile and plot I.D. geometry and to assist in determining examination coverage and signal evaluation.

### D. Requirements

### D.1 Personnel

- D.1.1 All personnel performing and evaluating this ultrasonic examination(s) shall be certified to at least Level II in accordance with SNT-TC-1A.

  Supplement C. 1975 or 1980 Edition.
- D.1.2 All personnel shall familiarize themselves with the objectives of this procedures by practicing on a mock-up or cracked specimens before performing an actual examination.

### D.2 Equipment

- D.2.1 Ultrasonic instruments shall be used with contact search units. The ultrasonic instrument shall be equipped with a dB calibrated gain control, accurate over its range to ± 20 percent or ± 2dB.
- D.2.2 The ultrasonic instrument and specified angle beam search unit combination shall be capable of resolving the 10% deep I.D. notch on the calibration block with a minimum 2:1 signal noise ratio. It may be necessary to adjust the instrument to a lower or different frequency setting, than the transducer in

MDT-C-38 Rev 0 June, 1986 Page 5 of 23

order to obtain satisfactory resolution.

Documentation of certification for the ultrasonic instruments and transducers used shall be supplied when requested.

- D.2.3 The modern digital microprocessor controlled ultrasonic instrument, such as the EPOCH 2002 is recommended to be used when doing this cast stainless steel component examination for the following reasons; good low frequency resolution, multiple calibration memory, material velocity readout and direct printer hookup.
- MHZ and .750" to 1.0" in diameter. The following specific set of angle beam search units, designed for optimum results on the 10% and 25% deep I.D. notches in the calibration blocks, were used in developing this procedure: KBA, Alpha type, .5 and 1.0 MHZ x 1.0" diameter transducers, mounted on axial and circumferential contoured wedges that produce an approximate 40° dual focused refracted longitudinal wave mode. Other search unit frequencies, sizes and angles may be used, for performing and assisting evaluations or accommodating geometry problems, if

MDT-C-38 Rev 0 June, 1986 Page 6 of 23

equal or better results are obtained on the calibration standard.

- D.2.5 The search unit cable shall be of the coaxial type and shall not exceed 12 feet in length.
- D.2.6 Glycerine or ultragel II are normally used as a couplant but other couplants may also be used if comparable results are obtained. All couplants used must have a certified analysis of halogen content of less than 300 ppm.

## D.3 Calibration blocks

- D.3.1 There are two calibration blocks (one thinner for 29° I.D. pipe and one thicker for 31° I.D. pipe)

  for each station that meet the recommended design and requirements of ASME Section V Article 5. The blocks have additional notches machined in them.
- D.3.2 The calibration blocks have the same material specification, cast structure type, similar diameter and wall thickness and a representative surface finish as the components being examined.
- D.3.3 There shall be documentation certifying the calibration block material.
- D.3.4 Additional calibration blocks shall meet the same above requirements of this procedure.

- D.3.5 Other reference blocks (IIW-2 DSC, Rompas, Etc) may be used for calibration verification checks.
- D.3.6 Calibration Block Holes and Notches

The calibration blocks contain both axial and circumferential side drilled holes (S.D.H.) and I.D. notches. The S.D.H.'s are 3/16" dia. x 3" long, located at depths of 1/4, 1/2 and 3/4 wall thickness and are primarily used for sweep range (F.3.2) calibration. The I.D. notches are 2" long and machined to 10%, 25% and 50% depths and are primarily used for sensitivity (F.3.3) calibration. Other holes and notches may be present and used for aiding calibration if they don't interfere.

### E. Surface Preparation

- E.1 The examination surface shall be free of irregularities, loose material or coatings which interfere with ultrasonic wave transmission.
- E.2 The component surface temperature shall be within ± 25°F of the calibration block temperature.
- B.3 Surface preparation shall include the weld and component surface either side of the weld, where possible, for a sufficient distance to allow examining the required volume.

# P. Calibration of Equipment

# F.1 Instrument Linearity Verification

# P.1.1 Screen Height Linearity

The ultrasonic instrument shall provide screen height linearity within 5% of full range for at least 80% of the full screen height (FSH) (base line to maximum calibrated screen points). The screen height linearity check shall be made in accordance with Attachment #1 of this procedure and the results recorded on Form NDT-CF-2.

# F.1.2 Amplitude Control Linearity

The ultrasonic instrument shall utilize an amplitude control, accurate over its useful range to  $\pm$  20%

of the nominal amplitude ratio, to allow measurement of indications beyond the linear range of the vertical display on the screen. The amplitude control linearity check shall be made in accordance with Attachment #1 of this procedure and the results recorded on Form NDT-CF-2.

P.1.3 Instrument calibrations for screen height and amplitude control linearity shall be performed at the beginning of each period of extended use or every 3 months, whichever is less.

### F.2 Calibration General

F.2.1 Calibration shall include the complete ultrasonic examination system. Any change in search units, wedges, couplants, cables, ultrasonic instruments, recording devices, or any parts of the examination system shall be cause for recalibration, except when using a digital microprocessor controlled instrument (EPOCH 2002) several calibrations may be made at one time and recorded. These digital calibrations may be recalled or reprogrammed at any time within four hours of the original calibration or recalibration, that day. The initial calibration shall be made on the proper designated calibration block. The calibration verification shall be made on either the proper designated calibration block or the reference blocks listed in D.3.5. The calibration block and data shall be recorded on the calibration form.

F.2.2 Calibration shall be performed at the beginning of each day of examinations. A calibration verification shall be made at least every four hours during examinations, at the finish of each shift and whenever a change in examination personnel occurs.

# F.2.2.1 Recalibration, Amplitude Only

If the amplitude on the CRT screen has changed by more than 20% of its original amplitude when a check is made on the calibration standard, all data forms since the last positive calibration check shall be marked void and destroyed. A new calibration shall be made and recorded and the voided examination areas shall be re-examined.

# F.2.2.2 Recalibration, Sweep Only

If there is any indication that the sweep position has moved on the sweep line more than ten percent of the calibration sweep, correct the sweep range calibration and note the correction in the examination record. If recordable reflectors are noted on the data sheets, those data sheets shall be voided and destroyed. A new calibration shall be completed and recorded, and the voided examination shall be repeated.

### F.3 Calibration, Specific

- F.3.1 Calibration Block Selection: The 29° I.D. calibration block shall be used when calibrating for examination of the 27 1/2" and 29" I.D. components and the 31" I.D. calibration block for examining the 31" I.D. components.
- F.3.2 Sweep Range Calibration: A 5.0" depth full screen range, using the 1/4, 1/2 and 3/4 T S.D.H.'s shall be established for both the straight beam and angle beam calibrations. Measure the depth of each S.D.H. from the calibration block O.D. surface, and with the search unit positioned for maximum hole signal response, from each hole, adjust the signal to it's corresponding 5.0" screen position. Repeat this process on each hole until the screen range is linear. The back reflection and the signals from the bottom of the notches may also be used for the straight beam calibration. If an accurate corner reflection signal is obtained from the 10% deep I.D. notch, it should also be used when calibrating the angle beam screen range. Use the staggered holes for the straight beam calibration and the in line holes for the angle beam calibration. A separate (Axial and Circumferential) calibration shall be performed

for each angle beam scan. If the hole signals do not line up exactly as stated, adjust them as best as possible with the greatest accuracy at the lower 50% block wall thickness.

F.3.3 Reference Sensitivity: The straight beam reference sensitivity shall be established by adjusting the minimum and maximum amplitude, 1st back reflections of the calibration block to 80% F.S.H. and recording both gain settings on the calibration form. During actual examination and scanning, the 1st back reflection shall be maintained at approximately 80% F.S.H. by readjusting the gain setting. The angle beam reference sensitivity, shall be established by maximizing the tip signal response of the 50%, 25% and 10% deep I.D. notches Adjust the maximum peak signal to 80% F.S.H. and mark on UT screen. At this gain setting mark the maximum amplitudes of the other two notches. Draw a DAC curve by connecting the three marked peaks and on the calibration form record their amplitudes and sweep positions. It should be noted that the notch depths do not always compare

exactly with their corresponding hole depth. Also, at reference sensitivity record the screen height noise level. During actual angle beam examination and scanning, a desired noise level (10 to 30% FSH) shall be maintained by raising or lowering the calibration gain setting.

# F.4 Calibration Data Record

- P.4.1 The following data shall be recorded on the calibration data Form.
  - Calibration sheet identification and date of calibration;
  - b. Names of examination personnel;
  - c. Examination procedure number and revision;
  - Basic calibration block identification and temperature;
  - e. Ultrasonic instrument identification and serial number;
  - Beam angle, couplant, and mode of wave propagation in the material;
  - g. Orientation of search unit with respect to the pipe (longitudinal or circumferential)
  - Search unit identification frequency, size and Manufacturer's serial number;
  - Special search units, wedges, shoe type, or saddle's identification, if used;
  - Search unit cable type and length;
  - k. Times of initial calibration, subsequent calibration checks and final calibration.
  - Amplitudes and sweep readings obtained form the calibration reflectors.

### G. Examination Procedure

### G.1 Scanning

- G.1.1 Scanning Coverage: Scan the examination volume with the sound beam path overlapping each scan by at least 10% of the transducer dimension measured perpendicular to the scan path.
- G.1.2 Scanning Speed: The rate of search unit movement shall not exceed six inches per second.
- G.1.3 Scanning Sensitivity: When performing straight beam examinations per paragraph C.6 it is recommended to maintain a 80% F.S.H. first back reflection. Angle beam scanning shall be performed at the relative reference amplitude (Para. F.3.3.) to the extent possible. Different cast material properties may require raising or lowering the gain to maintain a 10% to 30% F.S.H. noise level which is necessary to ensure a good examination. The scanning sensitivity (gain) used on each weld shall be recorded on the examination data form.
  - G.1.4 Scanning Motion: When straight beam examining per paragraph C.6, the search unit shall be moved progressively along and around the weld. For angle

beam axial and circumferential scanning for coverage per paragraphs C.3, C.4 and C.5 the search unit shall be moved towards and away from the weld and progressively around the diameter, where possible. The angle beam search unit should be oscillated slightly (as much as the curved wedge allows) during scanning.

### H. Recording

- H.1 Straight beam thickness measurements, and I.D./O.D.

  profiling shall be made every 90° (0°, 90°, 180°

  and 270°) around the component diameter and the results recorded on the data sheets with profile plots attached.
  - when using the straight beam examination for the detection of indications which might effect the angle beam examination, the noted indication, other than noise, that have an amplitude equal to or greater than 50% of the initial back reflection and accompanied by a 50% reduction of the initial back reflection shall be recorded. Also, record the minimum and maximum gain settings needed to maintain an 80% FSH initial back reflection. If there are areas, due to high noise and attenuation, that preclude resolution of the initial back reflection these areas shall be noted in the data report.

NDT-C-38 Rev 0 June, 1986 Page 16 of 23

- H.3 For angle beam examination, all indications other than material noise, that equal or exceed 50% reference (DAC) level shall be recorded. Also, any indication of any amplitude that the operator believes to be a planar flaw shall be recorded.
- H.4 For the purpose of establishing sound beam penetration and coverage, I.D. geometry indications that are detected below recording level shall be noted on the data report as a general comment.

### I. Examination Data Record


- I.1 The following data shall be recorded on the examination data sheet:
  - a. Data sheet identification and date of examination;
  - b. Names and level of examination personnel;
  - c. Examination procedure and revision;
  - d. Applicable calibration sheet identification;
  - e. Identification and location of weld or volume scanned (for example, marked up drawings or sketches);
  - f. Surface from which examination is conducted;
  - g. Record of indications or of volume free of indications;
  - Type of examination performed and orientation of search unit with respect to the pipe;
  - Couplant identification;
  - j. Pipe size, schedule and material type;
  - k. Unit and/or pipe system identification;
  - Pipe temperature.


NDT-C-38 Rev 0 June, 1986 Page 17 of 23

- I.1.1 For each recordable indication, the following information shall be recorded on the examination data sheet:
  - a. Give the indication a number and identify the scan in which detected.
  - b. For each recordable indication, the recording points for the minimum and maximum sweep distances, linear extent and surface distances will be 50% of the maximum signal amplitude at reference sensitivity
  - DAC curve at reference sensitivity. With the search unit still positioned at this maximum amplitude point, record the sweep distance to the reflector and surface distance (in inches) from the designated reference point (possibly, weld center line) to the search unit exit point. Again, at this location, record the sweep distance to the reflector and the surface distance from the designated reference point to the search unit exit point, when the signal drops of its maximum amplitude as the search unit is moved toward and away from the reflector.

NDT-C-38 Rev 0 June, 1986 Page 18 of 23

- d. The search unit locations (possibly, distance around the pipe from top dead center) parallel to the reflector at its maximum and start and end points, when the signal amplitude drops to 50% of its maximum amplitude. This will establish the location and linear extent of the reflector.
- The examiner shall evaluate, to the best of his ability, what's causing the recordable reflectors and try to determine their linear extent. Reflectors, such as possible I.D. geometry, root bead and weld grain boundaries, that are continuous or intermittent (proven by raising or lowering the gain) for a given length, shall be recorded as a single indication, with comments. The examiner shall supply any additional data obtained on indications that are evaluated as planar flaws.
- 1.3 The reference points (usually two) used for locating and plotting indications shall be designated by the station and the examiner shall identify these points on the data sheet.
- I.4 The examiner or agency performing ultrasonic examinations in accordance with this procedure, shall be responsible for filling out the calibration and data sheets correctly and submitting them to the station ISI/PSI coordinator, within his designated time period.





## SCREEN HEIGHT LINEARITY

To verify the ability of the ultrasonic instrument to meet the linearity requirement of F.1.1, position an angle beam search unit as shown in Fig. I-1 so that indications can be observed from both the 1/2 and 3/4 T holes in a basic calibration block. Adjust the search unit position to give a 2 to 1 ratio of amplitudes between the two indications, with the larger set at 80% of full screen height. Without moving the search unit, adjust sensitivity (gain) to successively set the larger indication from 100% to 20% of full screen height, in 10% increments (or 2 dB steps if a fine control is not available), and read the smaller indication at each setting. The reading must be 50% of the larger amplitude, within 5% of full acreen height. The settings and readings aust be estimated to the mearest 1% of full screen. Alternatively, a straight beam search unit may be used on any calibration block which will provide amplitude differences.

### AMPLITUDE CONTROL LINEARITY

To verify the accuracy of the amplitude control of the ultrasonic instrument, as required in F.1.2, position an angle beam search unit as shown in Fig. I-1 so that the indication from the 1/2 T hole in a basic calibration block is peaked on the screen. With the increases and decreases in attenuation shown in the following table, the indication must fall within the specified limits. Other convenient reflectors from any calibration block may be used with angle or straight beam search units.

Indication Set at I of Full Screen	dB Control	Indication Limits I Full Screen
802	- 6dB	32 to 48%
80%	-12 dB	16 to 24%
40%	+ 6 dB	64 to 962
20%	+12 dB	64 to 962

The settings and readings must be estimated to the nearest 1% of full screen

This calibration	on form	was ,use	d with	procedu	re NUT			rage 20
Date	_Unit_	Ins	pect10	n		Calibra	tion Sheet	No
Examiner			Level	c	alibra	tion Stan	dard No	
(Lot #):								lard combination
	100	Z DAC	50%	DAC-T	50%	DAC-A	]	
Hole Depth	W	Sweep	W	Sweep	W	Sweep		
1/4 T -		1	1/				T = Mov	ing toward refle
1/2 T		1	YF					ing away from
3/4 T		1					1	lector tance, on the
	100	OZ DAC	50%	DAC-T	50%	DVC-V	] sur	face, between the nsducer index po the center line
Hole Depth	17	Sweep	W	Sweep	W	Sweep	of	the holes '
1/4 T		A	11	h				
1/2 T		1	1//	4				
3/4 T	1		1				]	
AMPLITUDE LIN	FARITY	CHECK			_	CONTROL	LINEARITY	CHECK
1002 FSII			FSH_	XFS	н			(32-48)
90% FSH	<b>Z</b> F	SH 40%	FSH_	ZFS	н	1		(16-24)
80% FSH								(64-96)
707 FSH		'SII 202	FSII_	%FS	11	20% F	SII +12dB	(64-96)
60% FSH		FSH						

Reviewed by:

NDT-C-38 Rev 0 June, 1986 Page 21

This calibration fo	C gerateht	Beam	Angle Bea	a: Axia	1	_ Circ			
oteOpit No.				alibrat	ion Sh	eet No	•	-	_
caminerUpit No.	e mayaccam,	Lamal	Calibrat	on Stan	dard N	lo			_
caniner		rever		.d Thick	2220				
ouplant (Lot #):		Calibrati	lon Standa		diam'r.				
LAW DETECTION UNIT	TR	ANSDUCER		DAC GRI					_
anufacturer	Size		- 10			$\perp$	-	H	_
ode1	Freq.		- 8		$\perp$	$\perp$	-	H	-
erial No	Seria	1 No	7	$\dashv$	+	-	-	+	-
			6		-	-	+	-	-
ble: Type			5		+	-	+	+	1
Length			4		-	H	$\vdash$	+	十
CALIBRATION DATA		-	7 3	-H	+	$\vdash\vdash$	1	+	t
Reflector		-		HH	+	H	++	+	t
Node/Back Rf			1	$\vdash \vdash \vdash$	+	$\vdash$		+	T
Sweep/Depth			0		3	7 -	6 7	8	9
Amplitude .				Cal Time	Ibrati	on Che	mesb CKeq:	Ope	r.
"A" Distance			INT		1			-	
		A Dist.	PIN					Ļ.	
		A Disc.	Point of	Block U				Weld	40
INSTRUMENT CONTROLS start f			Incidence	•	_	Sheet B	1	R&TO	.30
DAC CURVE .			CALIB	CHECKS	-  -		$\dashv$	MATERIAL PROPERTY.	
Sucep		O Reflector	r		1		-		
	Att	enuation			J L		_		
SEMSITIVITY		-			1				
GAIM	COLUMN TO SERVICE AND ADDRESS OF THE PERSON NAMED IN COLUMN TO SERVICE AND ADDRESS OF			1	11				
Damping .	THE RESIDENCE OF THE PERSON NAMED IN COLUMN TWO IS NOT THE PERSON NAMED IN COLUMN TWO IS NAMED IN C	ise Level	-	+	11				
Reject	%FS	SH	-	-	11				
Filter					- L	October 1980 In the Indian			

### NDT-C-38 Rev 0 June, 1986 Page 22

## ULTRASONIC TESTING DATA SHEET!

	it No. & Inspection				
System	Weld Type		Weld No		_
Pipe Size	Schedule	Material			-
Examiner	Level	Couplant (	Lot #)		_
•	Nos: L-Wave		rial		
			performed	lindi	eation
EXAMINATION SCANS			yes no		no
1) Base Hetal L-W	lave .	PLON			
2) Angle Beam-Nor	mal	1			
3) Angle Beam-Nor	mal ZZZZZ	77			
4) Angle Beam-Alo	ng Weld	7			
5) Angle Beam-Alo	-			1	1
6) L-Wave of Weld	-			+-	$\vdash$
	ss Weld & Base Metal			-	7545
/) Thickness Acto	se werd a perso imper				
				str	ec:
Comments:					
_	*				
	•				_
	* . ?				
*	*		Marie Sergel Adelle of Heady		
				The second name of the second	-

ULTRASONIC DATA SHEET

REV. PROCEDURE USED REFERENCE POINT LOCATIONS: DATA SHEET NO.

END TOWARD MAX ASIAN			Sig	SWEEP	LINEA	LINEAR EXTENT FROM REFERENCE	F 22	FORE	FORE AND AFT SURFACE DISTANCE	10 N		
	SECTION AND PERSONS ASSESSED.		MINISTER OF THE PARTY.	MA.	START	F A	eg .	TOWARD	K A	AHAY	EVALUATION	1
	-	-										
	1	-							•			
	+	+										
	+	+										
	+	+										
	+	+										
	+	+										
EXAMINER: DATE	MER:	1				ASNT	LEVEL:			DA.	21	1

# PROCEDURE CERTIFICATION

Procedure Number: _	NDT-C-38	Revision: 0	Date: June, 198
Procedure Title:	Ultrasonic Exa	mination of Full Per	netration
procedure Trailer		Cast Stainless Comp	
	Byron and Brai	dwood Stations	
This is to certify	that the above titl	led procedure is in comp	liance with the
		ressure Vessel Code, 19	
Summer 1978	_ Addenda, Section (	(s) <u>V &amp; XI</u>	
Walter Authorize	Stewski Med QA Department Sign	III  A A hature	6-17-86 Date 6-19-86 Date
I, the undersigned	d, of the		
holding a valid co	ertificate issued by	the National Board of	Boiler and Pressure
Vessel Inspectors	and/or the State of	Illinois, have reviewe	d the above
procedure and fine			
Signature			Date

# ATTACHMENT 3

Byron Unit-2 and Braidwood Unit-1 UT Inspection Results Summery Report.

# BYRON UNIT #2 U.T. EXAMINATION RESULTS OF R.C. CAST FITTINGS

					2	LOOP A						
			Straig	Straight Beam Examination			An	gle B	Angle Beam Examination	minati	uc	
Line	Weld	Weld	Atten.		Indic	Indication	Refl	ector	Reflectors Recorded	pep.		Additional
No.	No.	Configur- ation	Measur.	Comments	Circ	Circ Axial	Count	Root	Count Root Inclu-Other Bore sion	Other	Comments	Comments
2BC01AA 29"	33	pipe to valve	Base Metal (valve) 52-61 Weld 42-47	1*	×		×				2*	Circ scan limited due to weld config- uration
2RC01AA 29"	40	valve to elbow	valve side 55-62 elbow side 52-61	1* valve side	×		×			ID	**	Weld configuration limited circ scan
2RC01AA 29"	F2	elbow to st. gen	53-64		×		×				2*	Circ. scan some- times restricted due to weld config- uration
2RC02AA 31"	FI	st. gen to elbow	weld 59- 70 elbow side 57-63	1* elbow side	×		×		×		2*, 4* C. Bore	No circ scan on weld crown due to configuration

No circ scan on crown of weld due to configuration

2×

×

×

1\* elbow side

elbow

11

2RC02AA 31"

side 51-56 elbow

to

Weld side

48-58

56-72

32

2RC02AA 31"

pipe to elbow

4\* Radiograph Reviewed

3\* No restrictions

2\* 3600 Intermittent or continuous

1\* High Noise Level

3\*

2×

×

×

			Strai	Straight Beam Examination			Angle E	Angle Beam Examination	minati	uo	
Line	Weld	Weld	Atten.		Indication		flector	Reflectors Recorded	pep		Additional
No.	No.	Configur- ation	Measur.	Comments	Circ Axial	THE RESERVE TO THE PERSON NAMED IN	t Root	Count Root Inclu-Other Bore sion	Other	Comments	Comments
2RC02AA 31"	33	elbow to pipe	58-70		×	×				2*	*
2BC02AA 31"	37	pipe to elbow	56-73		×	×				2*	3*
2RC02AA 31"	38	elbow to pump	weld 52-61	1* elbow & pump side	×	×	×			2*, C.Bore	No circ scan on weld crown due to configuration
2RC03AA 27 1/2	F.	pump to pipe	49-65	*	×				I.D.	2* 1.D.	Limited circ scan due to configur- ation
2RC03AA 27 1/2	35	pipe to valve	45-62	1×	×		×			2* Root or I.D.	Circ scan limited due to weld config- uration
2RC03AA 27 1/2	36	valve to pipe	45-60	**	×	×				2*	Configuration limited circ. scan
2RC03AA 27 1/2	1117	pipe to elbow	weld 38-46 base metal 55-61	1*	×	×				2*	3*
							-				

	_		Straight	ht Beam Examination	_		Angle	Angle Beam Examination	minati	uo	
Line	Weld	Weld	Atten.		Indication		flecto	Reflectors Recorded	pep		Additional
<b>N</b> 0.	0	Configuration	Measur.	Comments	Circ Axial	-	t Root	Count Root Inclu- Other Bore sion	Other	Comments	Comments
2RC03AA 27 1/2	312	elbow to RPV S.End	elbow side 62-68 weld 48-60	1* elbow side							Limited circ. scan due to configur- ation No axial scan performed due to AS-CAST transition located near weld
	1* High	1* High Noise Level	2*	360° Intermittent or c	or continuous		3* No re	restrictions	suc	4* Radios	4* Radiograph Reviewed

# BYRON UNIT #2 U.T. EXAMINATION RESULTS OF R.C. CAST FITTINGS LOOP B

١
l
ſ
ı
l
1
1
1
1
ı
1
1
1
1
1
1
1
1
1
1
1
1
1

			Straight	ht Beam Examination		An	Angle Beam Examination	xaminati	uo	
Line	Weld	Weld	Atten.		Indication	_	Reflectors Rec	Recorded		Additional
No.	No.	Configur- ation	Measur.	Comments	Circ Axial	_	Count Root Inclu-	- Other	Comments	Comments
2RC01AB 29"	13	pipe to elbow	weld 49-69 valve side 51-60	1*	×	×			2*	No circ scan on weld due to config- uration
2RC01AB 29"	47	valve to elbow	valve side 57-64 elbow side 58-67	1* elbow side	×	×			2×	No circ scan on weld due to O.D. geometry
2RC01AB 29"	F2	elbow to st. gen	elbow side 62-70 weld 52-59	1* elbow side	×	×			2*	No circ scan on weld due to configuration
2RC02AB 31"	E	st. gen. to elbow	weld 59-68 elbow side 60-64	1* elbow side	×	×			2×	No circ on weld due to weld config- uration
2RC02AB 31"	II.	elbow to pipe	elbow side 52-59 weld 47-57	1* elbow side	×	×		I.D.	2*	Circ scan limited 55"-63" and axial scan limited 3" to 6" due to concavity in base metal
2RC02AB 31"	32	pipe to elbow	48-67		×	×	×		2*	3*
	1* High	Noise Level	2*	3600 Intermittent or c	or continuous	3*	3* No restrictions	tions	4* Radiog	4* Radiograph Reviewed

	_		Straigh	Straight Beam Examination			Angle	Angle Beam Examination	aminati	uo.	
Line	Weld	Weld	Atten.		Indication		Reflectors	ors Recorded	rded		Additional
<b>N</b> 0.	No.	Contiguration	dB	Comments	Circ Axial	-	nt Roo	Count Root Inclu-Other Bore sion	Other	Comments	Comments
2RC02AB 31"	33	elbow to pipe	48-71		×	×	×			5*	*8
2RC02AB 31"	37	pipe to elbow	48-67		×	×	×			2×	3*
2RC02AB 31"	87	elbow to pump	elbow side 45-60 pump side- see comments	1* pump side	×	×				**	No circ scan on weld crown due to configuration
2RC03AB 27 1/2	L.	pump to pipe	44-65	1* pump side	×	×	*	×	I.D.	2*	Circ scan limited due to config- uration
2RC03AB 27 1/2	35	pipe to valve	46-60	1* valve side	×		×			2*	Limited circ scan due to configu- ration. Axial scan limited 3% due to permanent support
2RC03AB 27 1/2	36	valve to pipe	47-62	1* valve side	×		×			2*	Circ scan limited due to config- uration
2RC03AB 27 1/2	111	pipe to elbow	53-76		×		×			5*	3*
	1* High	1* High Noise Level	2*	360° Intermittent or o	continuous	+	3* No 1	restrictions	lons	4* Radios	4* Radiograph Reviewed

	_		Straight	nt Beam Examination		Angl	Angle Beam Ex	Examination	uo	
Line	Weld	Weld	Atten.		Indication	Reflectors	tors Recorded	rded		Additional
No.	0	Configur- ation	dB dB	Comments	Circ Axial	Count Ro	Count Root Inclu-	Other	Comments	Comments
2RC03AB 27 1/2	312	elbow to RVP	50-72							Limited circ scan due to config- uration. No axial exam was performed due to as-cast transition located near weld.
		Noise Level	2*	360° Intermittent or	or continuous	3* 80	No restrictions	ions	4* Radlog	4* Radiograph Reviewed

# BYRON UNTI #2 U.T. EXAMINATION RESULTS OF R.C. CAST FITTINGS LOOP C

			Straig	Straight Beam Examination	_		An	gle Be	Angle Beam Examination	minati	uo	
Line	Weld	Weld	Atten.		Indic	Indication	Refl	ectors	Reflectors Recorded	pep		Additional
No.	No.	Configur- ation	Measur.	Comments	Circ	Circ Axial	Count	Root	Count Root Inclu- Other Bore sion	Other	Comments	Comments
2RC01AC 29"	53	pipe to valve	48-68		×	×		×		ID	2*, 4*	Circ. scan limited due to configur- ation
2RC01AC 29"	34	valve to elbow	49-71		×		×			e e	5*	Limited circ. scan due to configur- ation
2RC01AC 29"	F2	elbow to st. gen	59-71		×		×		×		2*, 4* C. Bore	Weld configuration limited circ. scan
2RC02AC 31"	R	st. gen to elbow	48-71		×		×				2*	Limited scan due to weld configuration
2RC02AC 31"	5	elbow to pipe	48-74		×		×				2×	3*
2RC02AC 31"	32	pipe to elbow	42-58	1*	×		×				2×	3*
2RC02AC 31"	33	elbow to pipe	43-64	1*	×		×				2*	No circ. scan on weld due to config- uration
2RC02AC 31"	37	pipe to elbow	45-69		×		×	×			2*	3*
1*1	High Noi	1* High Noise Level	2* 3	3600 Intermittent or C	Continuous	sn	3* No	Restr	3* No Restrictions	S	4* Radiogra	Radiograph Reviewed

	_		Straig	Straight Beam Examination			Angle	Angle Beam Examination	aminati	uo	
Line	Weld	Weld	Atten.		Indication	tion	Reflectors	cors Recorded	pepa		Additional
NO.	0	Configuration	Measur.	Comments	Circ Axial	THE PERSON NAMED IN	Count Roc Bore	Count Root Inclu- Other Bore sion	Other	Comments	Comments
2BC02AC 31"	82	elbow to pump	48-70	1* pumpside	×				ID	2*	Limited circ scan due to configura- tion of weld
2RC03AC 27 1/2	5	pump to pipe	43-64	1*	×				ΙD	4*	Circ. scan limited due to weld config- uration
2RC03AC 27 1/2	35	pipe to valve	45-63	1*	×		×			5*	Limited circ. scan due to weld config- uration
2RC03AC 27 1/2	36	valve to pipe	49-63	1*	×				QI	2*	Weld configuration limits circ. scan
2RC03AC 27 1/2	312	pipe to elbow	57-70		×		×			2*	3*
2RC03AC 27 1/2	313	elbow to RPV	58-73	Scan restricted due to as-cast transition	0						Limited circ. scan due to weld config- uration. No axial exam performed due to as-cast transi- tion near weld
	-										

# BYRON UNTI #2 U.T. EXAMINATION RESULTS OF R.C. CAST FITTINGS LOOP D

LOOP D

Angle Beam Examination

Straight Beam Examination

									Section and Section 1	The state of the s	
Line	Weld	Weld	Atten.		Indication	-	lector	Reflectors Recorded	pep		Additional
O	NO.	configur- ation	dB	Comments	Circ Axial	-	Root	Count Root Inclu-Other Bore sion	Other	Comments	Comments
2RC01AD 29"	45	pipe to valve	51-71		×		×		OI	2*	Limited circ. scan due to OD contour
2RC01AD 29"	55	valve to elbow	valve side 49-74 elbow side 51-72		×		×		ID	2*	3*
2RC01AD 29"	F2	elbow to st. gen	58-78		×			×	QI	2*, 4* ID	Limited scan due to weld OD contour
2BC02AD 31"	12	st. gen to elbow	weld 58-69 elbow 62-67	1*	×	×				2*	No circ. scan on weld due to config- uration
2RC02AD 31"	5	elbow to pipe	elbow 54-60 weld 46-55	1*	×	×				2*	**
2RC02AD 31"	32	pipe to elbow	89-05	1*	×	×		×		2*, 4* C.Bore	3*
2RC02AD 31"	55	elbow to pipe	20-68	1*	×		×			2*	3*

4\* Radiograph Reviewed

3\* No Restrictions

2\* 3600 Intermittent or Continuous

1\* High Noise Level

	_		Straight	ght Beam Examination			Angle	Angle Beam Examination	aminati	uo	
Line	Weld	Weld	Atten.		Indication		eflecto	Reflectors Recorded	pepu		Additional
<b>N</b> o.	No.	Configur- ation	Measur.	Comments	Circ Axial	Marie Control of the	nt Root	Count Root Inclu- Other Bore sion	Other	Comments	Comments
2RC02AD 31"	37	pipe to elbow	47-69		×	×				2*	3,*
2RC02AD 31"	80	elbow to pump	47-69	Backwall not resolved on pump side due to OD geometry	×		н		ID	2*	Scan limited on weld due to OD contour
2RC03AD 27 1/2	r,	pump to pipe	not ob- tainable	Attenuation was not measured due to OD geometry	×			×	QI	*	Circ. scan limited due to OD contour
2RC03AD 27 1/2	35	pipe to valve	48-70		×		×		QI	5*	Limited circ. scan due to OD contour
2RC03AD 27 1/2	36	valve to pipe	47-70		×				QI	2*	Scan limited due to OD contour
2RC03AD 27 1/2	111	pipe to elbow	57-70		×	×			QI	2×	* 6
2RC03AD 27 1/2	312	elbow to %PV	53-70	Scan restricted due to as-cast transition							Circ. scan limited to weld crown due to as-cast condition. No axial exam performed due to as-cast transition near weld
	1* High	1* High Noise Level		2* 360° Intermittent or C	or Continuous	7	No Res	3* No Restrictions		4* Radiograph Reviewed	h Reviewed

## OF R.C. CAST FITTINGS

LOOP #1

		_	Straig	Straight Beam Examination			Angl	Angle Beam Examination	kaminati	uo	
Line	Weld		Atten.		Indication	ion	Reflec	Reflectors Recorded	pepao		Additional
No.	No.	Configur- ation	Measur. dB	Comments	Circ Axial		Count Ro	Count Root Inclu- Other Bore sion	- Other	Comments	Collination
1RC-01-29"	е	pipe to valve	49-65	Obtained a good back wall reflection	×		×			1*	2*
1RC-01-29"	4	valve to elbow	valve side 36-58 elbow side 42-50	A loss of backwall was noted when approching either side of toe weld	×	×	×			*1	2* Axial is in parent material of valve
1RC-01-31"	00	elbow to nozzle	6.4	Backwall not always resolved due to OD geometry, or non- parallel sides	×		×	×		1*	2*
1RC-01-31"	0	nozzle to elbow	59		×		×			1*	2*
1RC-01-31"	10	elbow to pipe	50-58	A loss of backwall was noted on either side of weld toe due to OD geometry	M		×		GI CI	1*	2*
1RC-01-31"	n	pipe to elbow	55-70	Unable to obtain a backwall (appr. 50% of the time) due to cast structure	×		× .			1*	2*
	1* 360	1* 360° Intermittent	ent	2* No Restrictions		3* Rad	iograpl	3* Radiograph Reviewed	P		

			Straight	ght Beam Examination			Angl	Angle Beam Examination	aminati	uo	
Line	Weld	Weld	Atten.		Indication		Reflec	Reflectors Recorded	pepa		Additional
0	No.	configur- ation	dB	Comments	Circ Axial	-	Count Ro	Count Root Inclu-Other Bore sion	Other	Comments	Comments
1RC-01-31"	12	elbow to pipe	45-65	Unable to obtain a backwall (appr. 50% of the time) due to cast structure	н		×			1*	2*
1RC-01-31"	16	pipe to elbow	elbow side 56 weld 57		H		×		qı	1*	2* Loss of back re- flection on elbow side from weld center line due to possible ramp on CB
1RC-01-31"	11	elbow to circ pipe	46-65	Backwall not always resolved on pipe side due to high noise level	×	×	×			* m	No axial or circ scans were per- formed when ap- proaching either side of weld toe due to OD geometry
1RC-01-27 1/2	18	pump to pipe	60-63		×				g	1*	2*
1RC-01-27 1/2	22	pipe to valve	60.8-64		×		×			1*	2*
1RC-01-27 1/2	23	valve to pipe	40-50	Backwall not always resolved due to OD geometry	н		×		QI .	1*	Scans #4 & 5 had a slight restrition over the weld. The transducer edge could only be moved to the weld center line
-	1* 360°	Intermittent	int	2* No Restrictions	3*		Radiograph	Reviewed			

			Strai	Straight Beam Examination		A	ngle E	Angle Beam Examination	minati	uo	
Line	Weld	Weld	Atten.		Indication		lector	Reflectors Recorded	pep		Additional
No.	No.	Configur- ation	Measur. dB	Comments	Circ Axial	THE RESERVE OF THE PERSON.	Root	Count Root Inclu-	Other	Comments	Comments
1RC-01-27 1/2	30	pipe to elbow	51-64	Loss of backwall was noted due to material grain structure noise	н		×	×	QI .	*1	when approaching weld toe, scans 1, 2,4,65 have a tendency to lose coupling due to base metal-to-weld transition
18C-01-27 1/2	31	elbow to safe-end	46-66	Backwall difficult to resolve due to excessive noise	×		×		gı		No axial scans per- formed due to OD configurations. Scan #1 limited due to elbow prep transition.
	1* 360°	360° Intermittent	nt	2* No Restrictions	3*	Radiograph Reviewed	aph Re	viewed			

### OF R.C. CAST FITTINGS

### LOOP #2

			Strei	Streight Beam Examination			An	gle B	Angle Beam Examination	ninati	uo	
Line	Weld	Weld	Atten.		Indication	ation	Refl	ector	Reflectors Recorded	led		Additional
No.	No.	Configur- ation	Measur.	Comments	Circ	Circ Axial	Count	Root	Count Root Inclu-	Other	Comments	Comments
1RC-02-27 1/2	7	pump to pipe	55-70	Backwall difficult to resolve due to non- parallel sides	×			×			*1	Slight Restriction on axial and circ. scans due to (hump/dip) at toe of weld on pump side.
1RC-02-27 1/2	2	pipe to valve	45-55	Backwall resolved most of the time	×			×		a	*1	Approx. 1 ft. at TDC, both axial & circ. scans could not be performed due to a beam in the way. Also (dip) at toe weld.
1RC-02-27 1/2	9	valve to pipe	51-64		×		×			gı		Scans 3,4,& 5 were sometimes restricted due to surface contact at the toe of the weld on valve side.
1RC-02-27 1/2	2 12	pipe to elbow	62-65	Loss of backwall occurred at the elbow- to-weld transition due to poor transducer-to- surface contact	×	×	×	×		a	**	While performing scans 2,4,6 5 the transducer did not make good contact with the surface at the elbow-to-weld transition
						1	The second secon	100	- French			

1\* 360º Intermittent

2\* No Restrictions

3\* Radiograph Reviewed

			Straig	Straight Beam Examination		4	ngle B	Angle Beam Examination	minati	uc	
Line	Weld	Weld	Atten.		Indication	_	lector	Reflectors Recorded	pep		Additional
No.	No.	Configur- ation	Measur.	Comments	Circ Axial	-	Root	Count Root Inclu- Other Bore sion	Other	Comments	Comments
1RC-02-27 1/2	13	elbow to safe-end	63-65								The following restrictions were due to transducer-to-surface contact. Scan #3 restricted due to taper of elbow. Scans 4 & 5 restricted to weld only. Scans 1 & 7 "best effort" exam elbow side
1RC-02-29"	11	pipe to valve	67		×	×			QI .		Scans 4 & 5 restricted 45 to 90 degrees and from 180 to 225 degrees due to weld crown narrows. Scans 1, 2,4,5,& 7 restrict- ed due to no trans- ducer contact.
1RC-02-29"	18	valve to elbow	valve side 51.9-61 elbow side 54-68	Loss of backwall noted on elbow side due to high noise level	×	×	×		QI .	*1	Scans 1,2,3,4 &5 are limited when approaching either side of weld toe due to OD geometry
1RC-02-31"	19	elbow to nozzle	63		×	×			ID	1*	2*
1	1× 360°	360° Intermittent	int	2* No Restrictions	3* 1	3* Radiograph Reviewed	aph Re	viewed			

			Strai	Straight Beam Examination			Ang	ele Be	Angle Beam Examination	ninati	uo	
Line	Weld	Weld	Atten.		Indication	tion	Refle	Reflectors	Recorded	pep		Additional
No.	No.	Configur- ation	Measur.	Comments	Circ Axial	NAME AND ADDRESS OF TAXABLE PARTY.	Count Bore	Root I	Count Root Inclu-Other Bore sion	Other	Comments	Comments
1RC-02-31"	23	nozzle to elbow	42-56	Loss of backwall was noted on either side of weld toe due to OD geometry	×		×	×		OI .	1*	Scans 4 & 5 restricted on weld and weld toe due to OD geometry
1RC-02-31"	24	elbow to pipe	52.9		×		×	×		ID	1*	2*
1RC-02-31"	25	pipe to elbow	66-72		×	×	×	×		QI .	*I	2* Scan 4-probable mid wall noise indications
1RC-02-31"	26	elbow to pipe	43-65	Backwall resolved most of the time	×	×	×				*1	2* Scan 4 appears as ID roll or noise signal
1RC-02-31"	30	pipe to elbow	58.5		×		×	×		ID	1*	2*
1RC-02-31"	31	elbow to pump	57.8		×		×	×		GI .	1*	Scans 4 & 5 restricted 1 inch on either side of weld center line due to OD geometry
	1* 3600	Intermittent	I	2* No Restrictions		3* Radiograph Reviewed	iograp	oh Rev	iewed			

## OF R.C. CAST FITTINGS

LOOP #3

			Strai	Straight Beam Examination			An	gle B	Angle Beam Examination	minat	no.	
Line	Weld	Weld	Atten.		Indication	ation	Refl	ector	Reflectors Recorded	pep		Additional
No.	No.	Configur- ation	Measur.	Comments	Circ Axial	the second second	Count	Root	Count   Root   Inclu-   Other Bore   sion	Other	Comments	Comments
1RC-03-29"	m	pipe to valve	50-58		×	м	×	×	×		3* possible base metal inclusion verified on radiograph	Scans 4 & 5 had loss of coupling due to OD geometry Scans 1 & 2 limited at weld toe due to OD geometry
1RC-03-29"	4	valve to elbow	valve side 40-54 elbow side 38-56	A loss of backwall was noted when approaching either side of weld toe due of OD geometry	×	×	×	×		a	Scans 4 & 5 possible ID geometry	scans 4 & 5 limited when approaching either side of weld toe due to OD geometry
1RC-03-31"	œ	elbow to nozzle	06		×		×	×			1*	2*
1RC-03-31"	•	nozzle to elbow	91		×		*	×			1*	2*
1RC-03-31"	10	elbow to pipe	91		×		×	×			1*	2*
1RC-03-31"	11	pipe to elbow	53-64		×		×	×		g g	1*	Scans 4 & 5 loose coupling for approx 50% of the scan due to 0D geometry
	1* 3600	Intermittent	ent	2* No Restrictions		3* Ra	diogra	ph Re	3* Radiograph Reviewed			

	-		Straight	8ht Beam Examination		A	ngle F	Angle Beam Examination	minati	uc	
Line	Weld	-	Atten.		Indication		lector	Reflectors Recorded	pep		Additional
No.	No.	Configuration	Measur. dB	Comments	Circ Axial	-	Root	Count Root Inclu-Other Bore sion	Other	Comments	Comments
1RC-03-31"	12	elbow to pipe	54		×	×	×		QI .	1*	2*
1RC-03-31"	16	pipe to elbow	48-65	Straight beam exam scanned at .5 MHz to 1.0 MHz to resolve backwell	×	×	×			1*	2*
1RC-03-31"	7	to to pump	20-65	Backwall could not be resolved on pump side most of the time	×	×				1*	Circ and axial scans limited due to surface contour at toe of weld. Also a partial scan was obtained over the weld center line
1RC-03-27 1/	1/2 18	pump to pipe	50-75	Backwall difficult to resolve on pump side due to noise	м	×	×		QI	*1	Poor contact was noted on circ and axial scans at junction between weld toe and pump
18C-03-27 1	1/2 22	pipe to valve	4	Loss of backwall occurred at the toe of the weld on the pipe side & valve side from 0 to 90 degrees	×		×	×		3* Scans 4 & 5 revealed a small base metal inclusion.	2*
1RC-03-27 1/2	/2 23	valve to pipe	55-58		×	M	×		a	1*	2*
	1* 360	1* 360° Intermittent	ent	2* No Restrictions	3* 1	Radiogr	aph R	3* Radiograph Reviewed			

			Straight	ght Beam Examination		Ar	gle B	Angle Beam Examination	minati	uo	
Line	Weld	Weld	Atten.		Indication	Refl	Reflectors	s Recorded	pep	j	Additional
No.	No.	Configur- ation	Measur. dB	Comments	Circ Axial	COLUMN TO SERVICE DE LA CONTRACTOR DE LA	Root	Count Root Inclu-Other Bore sion	Other	Comments	Comments
1BC-03-27 1/2	31	pipe to elbow	62	A loss of back reflextion occurred at the weld-to-base metal transition on elbow side due to transducer lift off	×	×	н			1*	Transducer lift off occurred on scans 2,4, &5 primarily from 180 to 0 degrees
18C-03-27 1/2	32	elbow to safe-end	r.	Scan #1 was performed where best transducer- to-surface could be obtained							Scans 4 & 5 Were performed on the weld only. No scan 3 could be performed due to lack of transducer-to-surface contact.
	1* 3600	Intermittent	ant	2* No Restrictions	3* R	3* Radiograph Reviewed	iph Re	Viewed			

## OF R.C. CAST FITTINGS

### LOOP #4

			Strai	Straight Beam Examination			Ang	le Be	Angle Beam Examination	minati	uo	
Line	Weld	Weld	Atten.		Indication	ion	Refle	sctors	Reflectors Recorded	pep		Additional
Ö	ġ	ation	dB	Comments	Circ Axial	ASSESSMENT OF THE OWNER, THE OWNE	Count Bore	Root 1	Count Root Inclu- Other Bore sion	Other	Comments	Comments
1RC-04-29"	q	pipe to valve	62	Backwall difficult to resolve 50% of the time due to unparallel surfaces or waviness of the OD	ж	×	×	×	×		1*, 3* Possible base metal inclusion verified on radiograph	Loss of surface contact was noted on scans 4 & 5 approx. 1 foot on either side of 180 degrees
1RC-04-29"	un .	valve to elbow	51.3 -	Excessive noise is present on scan #1 due to grain structure	×	н	н			8	* 6	Scans 1,4, & 5 restricted either side of weld toe due to base metal and weld transition Scans 2 & 3 lose coupling due to OD
1RC-04-31"	σ	elbow to nozzle	28-60		н	×	×		×	I.b.	1* Scan 4 &	2*
1RC-04-31"	10	nozzle to elbow	61.7		×		×	×		9	1*	2*
1RC-04-31"	п	elbow to pipe	68		н	1	×	м		10	1*	2*
1RC-04-31"	12	pipe to elbow	53.9		×		×	×		9	1*	2*
	1* 3600	Intermittent	ant	2* No Restrictions		3* Rad	Radiograph	h Rev	Reviewed	1		

	_	_	Strai	Straight Beam Examination		Z	ngle B	Angle Beam Examination	minati	uc	
Line	Weld		Atten.		Indication		lector	Reflectors Recorded	pep		Additional
No.	No.	Configuration	Measur	Comments	Circ Axial		Root	Count Root Inclu-	Other	Comments	Comments
18C-04-31"	13	elbow to pipe	53.7-		н	н				1*	Scans 3,4,45 re- stricted when ap- proaching weld toe due to OD geometry
1RC-04-31"	11	pipe to elbow	85-60		м	×	×			**	2*
1RC-04-31"	18	elbow to pump	66.5	No back reflection could be detected on pump side due to noise	н	×	×			**	Scans 4 & 5 were restricted .5" on either side of weld center line due to OD geometry
18C-04-27 1/2	/2 19	pump to pipe	60-64	A reduction of back reflection was noted on pump side due to ID geometry	м	×	×			1*	Scans 1,3,4,65 limited on either side of weld toe due to OD geometry
18C-04-27 1	1/2 23	pipe to valve	40-65		×	×	×				2*
1RC-04-27 1/2	/2 24	valve to pipe	69		н	×	×		QI	1*	2*
1RC-04-27 1	1/2 31	to to elbow	55-66	Backwall difficult to resolve on elbow side due to high noise level	×	×	×				Scan #2 had a tendency to lose coupling when the crystal approached weld toe.
	1* 36	1* 360° Intermittent	ent	2* No Restrictions	3*	3* Radiograph Reviewed	aph Re	viewed			

			Straight	ht Beam Examination		Ang	Angle Beam Examination	aminati	uc	
Line	Weld	Meld	Atten.		Indication	Refle	Reflectors Recorded	pepa		Additional
NO.	No.	Configur- ation	Measur. dB	Comments	Circ Axial	Count R	Count Root Inclu-	Other	Comments	Comments
18C-04-27 1/2	32	to safe-end	47-59							No axial scans per- formed from elbow side due to OD con- figuration. Scan #1 limited due to transition on elbow side. Straight beam limited to weld material and approx. 1-1/2" from center line on elbow side. Scans #4 & 5 performed on weld material
				Sub-taged on the	* K	o i o	3* Radiograph Reviewed			
	7 200	TULBIMITE	ent							

### ATTACHMENT B

### BYRON UNIT 2 RELIEF REQUESTS:

NR-1

Limited ultrasonic examinations were performed on cast stainless steel elbow-to-cast pump or valve welds.

NR-2

Limited ultrasonic examinations were performed on cast staionless steel elbow-to-reactor vessel nozzle safe-end welds.

NR-3

Limited ultrasonic examinations were performed on cast stainless steel elbow-to steam generator nozzle welds.

NR-12

Limited ultrasonic examinations were performed on cast stainless steel; elbow, pump or valve-to-pipe welds.

### RELIEF REQUEST NR-1

1. SYSTEM: Reactor Coolant

2. NUMBER OF ITEMS: 8

Cast Stainless Steel SA-351-CF8A (Elbow) to
Cast Stainless Steel SA-351-CF8 (Pump)

Line Number	Weld Number	Attachment Numbers	1
2RC02AA-31"	J-8	1 & 2	
2RC02AB-31"	J-8	1 & 2	
2RC02AC-31	J-8	1 & 2	
2RC02AD-31	J-8	1 & 2	

Cast Stainless Steel SA-351-CF8A (Elbow) to

Cast Stainless Steel SA-351-CF8M (Valve)


Line Number	Weld Number	Attachment	Numbers
2RC01AA-29"	J-4	1 &	3
2RC01AB-29"	J-4	1 &	3
2RC01AC-29"	J-4	1 &	3
2RC01AD-29"	J-5	1 &	3


- 3. ASME CODE CLASS: 1
- 4. ASME CODE SECTION XI REQUIREMENTS: Table IWB-2500-1, Examination Category B-J, Item B9.11 requires a surface and volumetric examination of the regions described in Figure IWB-2500-8 for piping 4 in. nominal pipe size and greater. In addition, Examination Category B-P, Item B15.50 requires a system leakage test in accordance with IWB-5221 each refueling outage for all pressure retaining components. Article IWB-2200, "Preservice Examination" states that:
  - a. Examinations required by this Article shall be completed prior to initial plant startup. In addition, the preservice examinations shall be extended to include essentially 100% of the pressure retaining welds in all Class 1 components except in those components exempted from examination by IWB-1220 (a), (b), or (c).
  - b. Shop and field examinations may serve in lieu of the on-site preservice examination provided:
    - In the case of vessels only, the examination is performed after the hydrostatic test required by Section III has been completed;
    - 2) such examinations are conducted under conditions and with equipment and techniques equivalent to those that are expected to be employed for subsequent inservice inspections;

- 3) the shop and field examinations records are, or can be, documented and identified in a form consistent with those required in IWA-6000.
- 5. BASIS FOR RELIEF: All of the welds listed above are cast austenitic stainless steel to cast austenitic stainless steel. Acceptable radiographic examinations of these welds have been completed to meet the preservice volumetric inspection requirement. However, we do not intend to use radiography as the inservice volumetric examination method.


A "best effort" ultrasonic examination, consisting of the code required axial 1/2 V-path scan from both sides of the weld and circumferential 1/2 V-path scan along the weld, was completed for each of the above listed welds. However, the code required sensitivity was not attainable due to the attenuation characteristics of cast austenitic stainless steel. In addition, the unwieldy characteristics of the contoured wedge search unit and the valve body contour on the 0.D. surface presented some limitations during the axial scans (except weld J5 on line 2RC01AD-29" which had no examination restrictions). Circumferential scans were limited a short distance from the edge of the weld crown for both the valve and pump welds because of the search unit dimensions and the physical shape of these castings. These restrictions precluded the 100% examination coverage as required by the procedure.

- 6. ALTERNATE TEST METHOD: None.
- JUSTIFICATION: The examinations performed on the above listed welds represent the state-of-the-art, best effort, technique available for the inspection of cast austenitic stainless steel. The ultrasonic inspection technique utilizes two 1.0 inch diameter x 1.0 MHz transducers, mounted on a contoured wedge search unit, that produce an approximate 41 degree, dual, refracted longitudinal wave focused near the calibration block I.D. surface. The calibration standards were machined from a representative cast stainless steel elbow. The ultrasonic examination technique was proven capable of penetrating ultrasound to the weld I.D. and detecting large flaws (25% or greater through wall dimension) in the cast material. Despite the reported limitations, both axial and circumferential scans were capable of locating flaws within the counterbore region as verified by the identification of root and counterbore signals. This counterbore region (See Attachments) closely resembles the ASME Code required examination volume and thus is the primary area of interest for volumetric flaw detection. The combination of acceptable radiographic examinations and these state-of-the-art ultrasonic examinations assures an acceptably high level of structural integrity for these welds.






ELBOW TO PUMP




WELD DETAIL

ATTACHMENT 2 NR-1



ELBOW TO VALVE



WELD DETAIL

### RELIEF REQUEST NR-2

1. SYSTEM: Reactor Coolant

2. NUMBER OF ITEMS: 4

Cast Stainless Steel SA-351-CF8A (Elbow)

to

Stainless Steel SA-182 GR-F316 (Safe-end)

Line Number	Weld Number	Attachment	Number
2RC03AA-27.5"	J-12	1 &	2
2RC03AB-27.5"	J-12	1 &	2
2RC03AC-27.5"	J-13	1 &	2
2RC03AD-27.5"	J-12	1 &	2

3. ASME CODE CLASS: 1

4. ASME CODE SECTION XI REQUIREMENTS: Table IW3-2500-1, Examination Category B-J, Item B9.11 requires surface and volumetric examination of the regions described in Figure IWB-2500-8 for piping 4 in. nominal pipe size and greater. In addition, Examination Category B-P, Item B15.50 requires a leakage test in accordance with IWB-5221 each refueling outage for all pressure retaining components.

Article IWB-2200 "Preservice Examination" states that:

- a. Examinations required by this Article shall be completed prior to initial plant startup. In addition, the preservice examinations shall be extended to include essentially 100% of the pressure retaining welds in all Class 1 components except in those components exempted from examination by IWB-1220 (a), (b) or (c).
- b. Shop and field examinations may serve in lieu of on-site preservice examination provided:
  - In the case of vessels only, the examination is performed after the hydrostatic test required by Section III has been completed;
  - 2) such examinations are conducted under conditions and with equipment and techniques equivalent to those that are expected to be employed for subsequent inservice inspections;
  - 3) the shop and field examination records are, or can be, documented and identified in a form consistent with those required in IWA-6000.


Ultrasonic examination requirements from Mandatory Appendix III, Article III-4000, require examination for:


a. reflectors parallel to the weld seam. The angle beam examination for reflectors parallel to the weld seam shall be performed by a full V path from one side or a one-half V path from two sides of the weld, where practicable.

- b. reflectors transverse to the weld seam.
  - The angle beam examination for reflectors transverse to the weld seam shall be performed on the weld crown on a single scan path to examine the weld root by one-half V path in two directions along the weld.
  - For inservice examination, only those welds showing reportable preservice indications need be examined for transverse reflectors.
- 5. BASIS FOR RELIEF: The welds listed above are all cast austenitic stainless steel to Reactor Vessel nozzle safe-ends. These welds have received radiographic and surface examinations to meet the preservice volumetric and surface examination requirements. However, we do not intend to use radiography as the inservice volumetric examination method.


Ultrasonic examinations were performed circumferentially in both directions for transverse reflectors, and axially for parallel reflectors, from the safe-end side only, on each of the above listed welds. In addition, a "best effort" ultrasonic examination, consisting of circumferential 1/2 V-path scans of the elbow side base metal, was performed. The unwieldy characteristics of the contoured wedge search unit and the as-cast transition on the elbow O.D. surface prevented performance of an axial scan from the elbow side. The elbow side circumferential scans were limited a short distance from the edge of the weld crown due to the inability of the search unit to maintain sufficient coupling while scanning over the weld to base metal transition. The code required sensitivity was, also, not attainable on the elbow side due to the attenuation characteristics of cast austenitic stainless steel. These restrictions precluded the 100% examination coverage as required by the procedure.

- 6. ALTERNATE TEST METHOD: None.
- 7. JUSTIFICATION: The examinations performed from the cast (elbow) side of the above listed welds represent the state-of-the-art, best effort, technique available for the inspection of cast austenitic stainless steel. The ultrasonic inspection technique utilizes two 1.0 inch diameter x 1.0 MHz transducers, mounted on a contoured wedge search unit, that produce an approximate 41 degree, dual, refracted longitudinal wave focused near the calibration block I.D. surface. The calibration standards were machined from a representative cast stainless steel elbow. The ultrasonic examination technique was proven capable of penetrating ultrasound to the weld I.D. and detecting large flaws (25% or greater through wall dimension) in the cast material. The circumferential scans were capable of locating flaws in the volume of metal adjacent to the weld, near the I.D. surface. Having performed acceptable radiographic and one-sided ultrasonic (from the safe-end side) examinations as well as the state-of-the-art ultrasonic examination (from the elbow side), an acceptably high level of structural integrity for these welds is assured.





ELBOW TO SAFE END



WELD DETAIL

ATTACHMENT 2 NR-2

### RELIEF REQUEST NR-3

1. SYSTEM: Reactor Coolant

2. NUMBER OF ITEMS: 8

Cast Stainless Steel SA-351-CF8A (Elbow)

to

Cast Carbon Steel SA-216 GR-WCC (Nozzle)

Line Number	Weld Number	Attachment Numbers
2RC01AA-29"	F-2	1 & 2
2RC02AA-31"	F-1	1 & 2
2RC01AB-29"	F-2	1 & 2
2RC02AB-31"	F-1	1 & 2
2RC01AC-29"	F-2	1 & 2
2RC02AC-31"	F-1	1 & 2
2RC01AD-29"	F-2	1 & 2
2RC02AD-31"	F-1	1 & 2

- 3. ASME CODE CLASS: 1
- 4. ASME CODE SECTION XI REQUIREMENTS: Table IWB-2500-1, Examination Category B-F, Item B5.30 requires surface and volumetric examination of the regions described in Figure IWB-2500-8 for all Steam Generator nozzle-to-safe end welds. In addition, Examination Category B-P, Item B15.30 requires a system leakage test in accordance with IWB-5221 each refueling outage for the steam generator pressure retaining boundary.

Article IWB-2200, "Preservice Examination", states that:

- a. Examinations required by this Article shall be completed prior to initial plant startup. In addition, the preservice examinations shall be extended to include essentially 100% of the pressure retaining welds in all Class 1 components except in those components exempted from examination by IWB-1220 (a), (b) or (c).
- b. Shop and field examinations may serve in lieu of on-site preservice examinations provided:
  - In the case of vessels only, the examination is performed after the hydrostatic test required by Section III has been completed;
  - such examinations are conducted under conditions and with equipment and techniques equivalent to those that are to be employed for subsequent inservice inspections;
  - 3) the shop and field examination records are, or can be, documented and identified in a form consistent with those required in IWA-6000.


Ultrasonic examination requirements from Mandatory Appendix III, Article III-4000, require examination for:


- a. Reflectors parallel to the weld seam. The angle beam examination for reflectors parallel to the weld seam shall be performed by a full V path from one side or a one-half V path from two sides of the weld, where practicable.
- b. Reflectors transverse to the weld seam.
  - The angle beam examination for reflectors transverse to the weld seam shall be performed on the weld crown on a single scan path to examine the weld root by one-half V path in two directions along the weld.
  - For inservice examination, only those welds showing reportable preservice indications need be examined for transverse reflectors.
- 5. BASIS FOR RELIEF: The welds listed above are cast austenitic stainless steel SA-351-CF8A to cast carbon steel SA-216 GR-WCC with austenitic stainless steel cladding. Acceptable radiographic examinations of these welds have been completed to meet the preservice volumetric inspection requirement. However, we do not intend to use radiography as the inservice volumetric examination method.

Ultrasonic examinations were performed circumferentially in both directions for transverse reflectors, and axially for parallel reflectors, from the steam generator nozzle side with a 1/2 V-path scan. In addition, a "best effort" ultrasonic examination, consisting of the code required axial 1/2 V-path scan from the elbow side and circumferential 1/2 V-path scans along the weld, was completed for each of the above listed welds. However, the code required sensitivity was not attainable on the elbow side due to the attenuation characteristics of cast austenitic stainless steel. The elbow side circumferential scans were limited a short distance from the edge of the weld crown due to the inability of the search unit to maintain sufficient coupling while scanning over the weld to base metal transition. These restrictions precluded the 100% examination coverage as required by the procedure.


ALTERNATE TEST METHOD: None.

7. JUSTIFICATION: The examinations performed from the elbow side of the above listed welds represent the state-of-the-art, best effort, technique available for the inspection of cast austenitic stainless steel. The ultrasonic inspection technique utilizes two 1.0 inch diameter x 1.0 MHz transducers, mounted on a contoured wedge search unit, that produce an approximate 41 degree, dual, refracted longitudinal wave focused near the calibration block I.D. surface. The calibration standards were machined from a representative cast stainless steel elbow. The ultrasonic examination technique was proven capable of penetrating ultrasound to the weld I.D. and detecting large flaws (25% or greater through wall dimension) in the cast material. Despite the reported limitations, both axial and circumferential scans were capable of locating any flaws within the counterbore region as verified by the identification of root and counterbore signals. This counterbore region (See Attachments) closely resembles the ASME Code required examination volume and thus is the primary area of interest for volumetric flaw detection. The combination of acceptable radiographic examinations, acceptable ultrasonic examinations from the steam generator side, and these state-of-the-art ultrasonic examinations from the elbow side assures an acceptably high level of structural integrity for these welds.





ELBOW TO NOZZLE



WELD DETAIL

ATTACHMENT 2 NR-3

### RELIEF REQUEST NR-12

1. SYSTEM: Reactor Coolant

2. NUMBER OF ITEMS: 36

Cast Stainless Steel SA-351-CF8A (Elbow)

to

Stainless Steel SA-376 Type 304N (Pipe)

Line Number	Weld Numbers	Attachments Numbers
2RC02AA-31"	J-1, J-2, J-3, J-7	1 & 2
2RC02AB-31"	J-1, J-2, J-3, J-7	1 & 2
2RC02AC-31"	J-1, J-2, J-3, J-7	1 & 2
2RC02AD-31"	J-1, J-2, J-3, J-7	1 & 2
2RC03AA-27.5"	J-11	1 & 2
2RC03AB-27.5"	J-11	1 & 2
2RC03AC-27.5"	J-12	1 & 2
2RC03AD-27.5"	J-11	1 & 2

Cast Stainless Steel SA-351-CF8 (Pump)

to

Stainless Steel SA-376 Type 304N (Pipe)

Line Number	Weld Numbers	Attachment Numbers
2RC03AA-27.5	J-1	1 & 3
2RC03AB-27.5	J-1	1 & 3
2RC03AC-27.5	J-1	1 & 3
2RC03AD-27.5	J-1	1 & 3

Cast Stainless Steel SA-351-CF8M (Valve)

to

Stainless Steel SA-376 Type 304N (Pipe)

Line Number	Weld Number	Attachment Number
2RC01AA-29"	J-3	1 & 4
2RC01AB-29"	J-3	1 & 4
2RC01AC-29"	J-3	1 & 4
2RC01AD-29"	J-4	1 & 4
2RC03AA-27.5"	J-5, J-6	1 & 4
2RC03AB-27.5"	J-5, J-6	1 & 4
2RC03AC-27.5"	J-5, J-6	1 & 4
2RC03AD-27.5	J-4, J-5	1 & 4

3 ASME CODE CLASS: 1

4. ASME CODE SECTION XI REQUIREMENTS: Table IWB-2500-1, Examination Category B-J, Items B9.11 and B9.12 require surface and volumetric examination of the regions described in Figure IWB-2500-8 for piping 4 in. nominal pipe size and greater. In addition, Examination Category B-P, Item B15.50 requires a system leakage test, IWB-5221, each refueling outage for all pressure retaining components.

Article IWB-2200, "Preservice Examination" states that:

- a. Examinations required by this Article shall be completed prior to initial plant startup. In addition, the preservice examination shall be extended to include essentially 100% of the pressure retaining welds in all Class 1 components except in those components exempted from examination by IWB-1220 (a), (b), or (c).
- b. Shop and field examinations may serve in lieu of on-site preservice examinations provided:
  - In the case of vessels only, the examination is performed after the hydrostatic test required by Section III has been completed;
  - 2) such examinations are conducted under conditions and with equipment and techniques equivalent to those that are expected to be employed for subsequent inservice inspections;
  - 3) the shop and field examination records are, or can be, documented and identified in a form consistent with those required in IWA-6000.

Ultrasonic examination requirements from Mandatory Appendix III, Article III-4000 require examination for:

a. Reflectors parallel to the weld seam.

The angle beam examination for reflectors parallel to the weld seam shall be performed by a full V-path from one side or a one-half /-path from two sides of the weld, where practicable.


- b. Reflectors transverse to the weld seam
  - The angle beam examination for reflectors transverse to the weld seam shall be performed on the weld crown on a single scan path to examine the weld root by one-half V-path in two direction along the weld.
  - For inservice examination, only those welds showing reportable preservice indications need be examined for transverse reflectors.


5. BASIS FOR RELIEF: The welds listed above are all cast austenitic stainless steel to stainless steel pipe. We have completed acceptable radiographic and surface examinations to meet the preservice volumetric and surface requirements. However, we do not intend to use radiography as the inservice volumetric examination method.

Ultrasonic examinations were performed circumferentially in both directions for transverse reflectors, and axially for parallel reflectors, from the pipe side with a 1/2 V-path scan. In addition, a "best effort" ultrasonic examination, consisting of the code required axial 1/2 V-path scan from the component (elbow, pump, or valve) side and circumferential 1/2 V-path scans along the weld, was completed for each of the above listed welds. However, the code required sensitivity was not attainable on the component side due to the attenuation characteristics of cast austenitic stainless steel. The axial scans of welds Jl and J5, on lines 2RC02AB-31" and 2RC03AB-27.5" respectively, were limited by 3% due to base metal concavity (J1) and a permanent support (J5). The unwieldy characteristics of the contoured wedge search unit and the valve body contour on the O.D. surface presented some limitations during the axial scans of the pipe-to-valve welds. Circumferential scans were limited a short distance from the edge of the weld crown for all the pipe-to-valve welds, all the pipe-to-pump welds, and three of the pipe-to-elbow welds (2RC02AA-31"/J1, 2RC02AB-31"/J1, and 2RC02AC-31"/J3) because of the inability of the search unit to maintain sufficient coupling while scanning over the weld to base metal transition. These restrictions precluded the 100% examination coverage as required by the procedure.


### 6. ALTERNATE TEST METHOD: None

7. JUSTIFICATION: The examinations performed from the component side of the above listed welds represent the state-of-the-art, best effort, technique available for the inspection of cast austenitic stainless steel. The ultrasonic inspection technique utilizes two 1.0 inch diameter x 1.0 MHz transducers, mounted on a contoured wedge search unit, that produce an approximate 41 degree, dual, refracted longitudinal wave focused near the calibration block I.D. surface. The calibration standards were machined from a representative cast stainless steel elbow. The ultrasonic examination technique was proven capable of penetrating ultasound to the weld I.D. and detecting large flaws (25% or greater through wall dimension) in the cast material. Despite the reported limitations, both axial and circumferential scans were capable of locating flaws within the counterbore region as verified by the identification of root and counterbore signals. This counterbore region (Sec Attachments) closely resembles the ASME Code required examination volume and thus is the primary area of interest for volumetric flaw detection. The combination of acceptable radiographic examinations, acceptable ultrasonic examinations from the pipe side, and these state-of-the-art ultrasonic examinations from the component side assures an acceptably high level of structural integrity for these welds.







PIPE TO ELBOW




ATTACHMENT 2 NR-12






WELD DETAIL

ATTACHMENT 3. NR-12



PIPE' TO VALVE



ATTACHMENT 4 NR-12

### ATTACHMENT C

### BRAIDWOOD UNIT 1 RELIEF REQUESTS:

1NR-2	Limited ultrasonic	
	examinations were performed	
	on cast stainless steel	

elbow-to-cast pump or valve

welds.

1NR-5 Limited ultrasonic examinations were performed

on cast stainless steel elbow-to-steam generator

nozzle welds.

1NR-6 Limited ultrasonic

examinations were performed on cast stainless steel

elbow, pump or valve-to-pipe welds.

1NR-7
Limited ultrasonic
examinations were performed
on cast stainless steel
elbow-to-reactor vessel

nozzle safe-end welds.

- 1. SYSTEM: Reactor Coolant
- 2. NUMBER OF ITEMS: 8

Line Number	Weld Number
1RC02AA-31	IRC-01-17
1RC02AB-31	1RC-02-31
1RC02AC-31	1RC-03-17
1RC02AD-31	1RC-04-18
1RC01AA-29	1RC-01-4
1RC01AB-29	1RC-02-18
1RC01AC-29	1RC-03-4
1RC01AD-29	1RC-04-5

- 3. A.S.M.E. CODE CLASS: 1
- 4. A.S.M.E. CODE SECTION XI REQUIREMENTS: Table IWB-2500-1, Examination Category B-J, Item B.9.11 requires surface and volumetric examination of the regions described in Figure IWB-2500-8 for piping 4 in. nominal pipe size and greater, this examination includes essentially 100% of the weld length. In addition, Appendix III, Supplement 7, requires that ultrasonic examination sensitivity be established using I.D. notches with a depth of 10% wall thickness.
- 5. BASIS FOR RELIEF: The above listed welds are cast stainless elbows to either cast pumps or cast valves.

  The optimized ultrasonic technique used for the statically cast stainless steel welds will detect large flaws (25% or greater through the wall) therefore this sensitivity is less than that required by code.

In addition, due to the unwieldly characteristics of the contoured wedge search units and variations in the machined surfaces, the welds listed above experienced axial and circumferential scanning limitations.

- 6. ALTERNATE TEST METHOD: None.
- 7. <u>JUSTIFICATION</u>: The structural integrity of these welds has been assured by:
  - a. Having performed a best effort ultrasonic exam, based on state of the art techniques, of the cast stainless welds.
  - b. Having performed acceptable radiographic and surface examinations.

- 1. SYSTEM: Reactor Coolant
- 2. NUMBER OF ITEMS: 8

Cast Stainless Steel SA 351-CF8A (Elbow) to
Cast Carbon Steel SA-216 GR-WCC (Nozzle)

Line Number	Weld Number
1RC01AA-29"	1RC-01-8
1RC02AA-31"	1RC-01-9
1RC01AB-29"	1RC-02-19
1RC02AB-31"	1RC-02-23
1RC01AC-29"	1RC-03-8
1RC02AC-31"	1RC-03-9
1RC01AD-29"	1RC-04-9
1RC02AD-31"	1RC-04-10

- 3. ASME CODE CLASS: 1
- 4. ASME CODE SECTION XI REQUIREMENTS: Table IWB-2500-1, Examination Category B-F, Item B5.30 requires surface and volumetric examination of the regions described in Figure IWB-2500-8 for all Steam Generator nozzle-to-safe end welds. This examination includes essentially 100% of the weld length. In addition, Appendix III Supplement 7, requires that ultrasonic examination sensitivity be established using I.D. notches with a depth of 10% wall thickness.
- 5. BASIS FOR RELIEF: The welds listed above are cast austenitic stainless steel SA-351-CF8A to cast carbon steel SA-216 GR-WCC with austenitic stainless steel cladding. The techniques used to examine the cast stainless side of these welds will detect large flaws (25% or greater through the wall) therefore this sensitivity is less than that required by code. In addition, Weld 1RC-02-23 had limited circumferential scans near the weld toe area. This limitation is due to the transducer system's inability to maintain coupling while scanning over the weld-base metal transition.
- 6. ALTERNATE TEST METHOD: None.
- 7. <u>JUSTIFICATION</u>: The structural integrity of these welds has been assured by:
  - a. Having performed a best effort ultrasonic exam, based on state of the art techniques, from the cast stainless side.
  - b. Having performed an acceptable ultrasonic exam from the carbon steel side.
  - c. Having performed acceptable radiographic and surface examinations.

- 1. SYSTEM: Reactor Coolant
- 2. NUMBER OF ITEMS: 36

Cast Stainless Steel SA-351-CF8A (Elbow) to Stainless Steel SA-376 Type 304N (Pipe)

Line Number	Weld Number	
1RC02AA-31"	1RC-01-10, 11, 12, 16	
1RC02AB-31"	1RC-02-24, 25, 26, 30	
1RC02AC-31"	1RC-03-10, 11*, 12, 1	5
1RC02AD-31"	1RC-04-11, 12, 13*, 1	7
1RC03AA-27.5"	1RC-01-30	
1RC03AB-27.5"	1RC-02-12	
1RC03AC-27.5"	1RC-03-31	
1RC03AD-27.5"	1RC-04-31	

Cast Stainless Steel SA-351-CF8 (Pump) to Stainless Steel SA-376 Type 304N (Pipe)

Line Number	Weld Number
1RC03AA-27.5	1RC-01-18*
1RC03AB-27.5	1RC-02-1*
1RC03AC-27.5	1RC-03-18*
1RC03AD-27.5	1RC-04-19*

Cast Stainless Steel SA-351-CF8M (Valve) to Stainless Steel SA-376 Type 304N (Pipe)

Line Number	Weld Number
1RC01AA-29"	1RC-01-3
1RC01AB-29"	1RC-02-17*
1RC01AC-29"	1RC-03-3*
1RC01AD-29"	1RC-04-4*
1RC03AA-27.5"	1RC-01-22, 23*
1RC03AB-27.5"	1RC-02-5*, 6*
1RC03AC-27.5"	1RC-03-22, 23
1RC03AD-27.5"	1RC-04-23, 24

3. ASME CODE CLASS: 1

- 4. ASME CODE SECTION XI REQUIREMENTS: Table IWB-2500-1, Examination Category B-J, Item B9.11 requires surface and volumetric examination of the regions described in Figure IWB-2500-8 for piping 4 in. nominal pipe size and greater, this examination includes essentially 100% of the weld length. In addition, Appendix III, Supplement 7, requires that ultrasonic examination sensitivity be established using I.D. notches with a depth of 10% wall thickness.
- 5. BASIS FOR RELIEF: The above listed welds are cast stainless steel to wrought stainless pipe. The optimized ultrasonic technique used for the statically cast stainless steel welds will detect large flaws (25% or greater through the wall) therefore this sensitivity is less than that required by code. In addition, due to the unwieldly characteristics of the contoured wedge search units and variations in the machined surfaces those welds listed with a asterik, experienced axial and circumferential scanning limitations.
- 6. ALTERNATE TEST METHOD: None.
- 7. JUSTIFICATION: The structural integrity of these welds has been assured by:
  - a. Having performed a best effort ultrasonic exam, based on state of the art techniques, from the cast stainless side.
  - b. Having performed an acceptable ultrasonic exam from the non cast side.
  - c. Having performed acceptable radiographic and surface examinations.

1. SYSTEM: Reactor Coolant

2. NUMBER OF ITEMS: 4

Cast Stainless Steel SA-351-CF8A (Elbow) to Stainless Steel SA-182 GR-F316 (Safe-end)

Line Number	Weld Number
1RC03AA-27.5"	1RC-01-31
1RC03AB-27.5"	1RC-02-13
1RC03AC-27.5"	1RC-03-32
1RC03AD-27.5"	1RC-04-32

- 3. ASME CODE CLASS: 1
- 4. ASME CODE SECTION XI REQUIREMENTS: Table IWB-2500-1, Examination Category B-J, Item B9.11 requires surface and volumetric examination of the regions described in Figure IWB-2500-8 for piping 4 in. nominal pipe size and greater, this examination includes essentially 100% of the weld length. In addition, Appendix III, Supplemental 7, requires that ultrasonic examination sensitivity be established using I.D. notches with a depth of 10% wall thickness..
- 5. BASIS FOR RELIEF: The above listed welds are all cast austenitic stainless steel to Reactor Vessel nozzle safe-ends. The optimized ultasonic technique used for the statically cast side of these welds will detect large flaws (25% or greater through the wall) therefore this sensitivity is less than that required by code. In addition, due to the unwieldly characteristics of the contoured wedge search units and variations in the machined surfaces, the welds listed above experienced axial and circumferential scanning limitations.
- 6. ALTERNATE TEST METHOD: None.
- 7. JUSTIFICATION: The structual integrity of these welds has been assured by:
  - a. Having performed a best effort ultrasonic exam, based on state of the art techniques, from the cast stainless side.
  - b. Having performed an acceptable ultrasonic exam from the non-cast steel side.
  - c. Having performed acceptable radiographic and surface examinations.