

Official

NOV 5 1985

✓ Duke Power Company
ATTN: Mr. H. B. Tucker, Vice President
Nuclear Production Department
422 South Church Street
Charlotte, NC 28242

Gentlemen:

SUBJECT: CONFIRMATION OF ACTION - MCGUIRE NUCLEAR STATION
UNITS 1 AND 2 DOCKET NOS. 50-369 AND 50-370

This letter refers to the telephone conversation on November 1, 1985, between Mr. H. C. Dance of this office and Mr. R. L. Gill of Duke Power Company concerning control room ventilation system filter testing.

With regard to the matters discussed, it is our understanding that you will conduct an air-aerosol mixing uniformity test for the control room area ventilation filter systems by November 8, 1985. The tests will be conducted in accordance with ANSI 510-1975.

If your understanding of our discussion is different from that stated above, please inform this office immediately.

Sincerely,

151 g. Olshinski
for J. Nelson Grace
Regional Administrator

CAL No. 50-369, 50-370/85-02

cc: ✓ T. L. McConnell, Station Manager

bcc: ✓ NRC Resident Inspector
✓ D. Hood, NRR
State of North Carolina
Document Control Desk

RII
for GKuzo
11/4/85

RII
[Signature]
WCline
11/4/85

RII
emc
DCollins
11/4/85

RII
[Signature]
JPS/ohr
11/4/85

RII
HCB/Sr
VBrownlee
11/4/85

RII
[Signature]
WRWalker
11/3/85

RII
[Signature]
JA Olshinski
11/4/85

RII
[Signature]
GJenkins
11/4/85

8511110279 851105
PDR ADOCK 05000369
F PDR

1/0 IE01