

Duquesne Light Company

Beaver Valley Power Station
P.O. Box 4
Shippingport, PA 15071-0004

SUSHIL C. JAIN
Senior Vice President
Nuclear Services
Nuclear Power Division

July 15, 1999
L-99-305

(412) 393-5512
Fax (412) 643-8069

U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, DC 20555-0001

Subject: Beaver Valley Power Station, Unit No. 1 and No. 2
BV-1 Docket No. 50-334, License No. DPR-66
BV-2 Docket No. 50-412, License No. NPF-73
License Amendment Request Nos. 270 and 146


Pursuant to 10 CFR 50.90, Duquesne Light Company requests an amendment to the above licenses in the form of changes to the technical specifications (TS). The license amendment request (LAR) proposes to revise the TS surveillance frequency for the Quench and Recirculation Spray Systems nozzle air flow test from 5 years to 10 years consistent with the guidance provided in Generic Letter 93-05.

This LAR also includes a revision to correct the terminology used in an action requirement in TS 3/4.2.1, Axial Flux Difference. In addition, this LAR contains miscellaneous editorial and format changes.

The proposed TS changes for Unit No. 1 and Unit No. 2 are presented in Attachments A-1 and A-2, respectively. The safety analysis (including the no significant hazards evaluation) is presented in Attachment B.

These changes have been reviewed by the Beaver Valley review committees. The changes were determined to be safe and do not involve a significant hazard consideration as defined in 10 CFR 50.92 based on the attached safety analysis. An implementation period of up to 60 days is requested following the effective date of this amendment.

Sincerely,



Sushil C. Jain

c: Mr. D. S. Collins, Project Manager
Mr. D. M. Kern, Sr. Resident Inspector
Mr. H. J. Miller, NRC Region I Administrator
Mr. W. P. Dornsife, Director BRP/DEP
Mr. M. P. Murphy (BRP/DEP)

9907230245 990715
PDR ADDCV 05000334
P PDR



