

Docket Nos. 50-334  
and 50-412

April 30, 1987

DECL 016

Mr. J. J. Carey, Senior Vice President  
Duquesne Light Company  
Nuclear Group  
Post Office Box 4  
Shippingport, PA 15077

Dear Mr. Carey:

Subject: BEAVER VALLEY UNIT 2-REQUEST FOR ADDITIONAL INFORMATION  
ON SEVERAL ISSUES (TACS 62933, 62935, 63184)

Enclosed please find two documents which delineate our information needed to complete review of several issues:

- (1) Confirmatory issue 48, fire protection deviations
- (2) Confirmatory issue 46, control room isolations on high radiation signal - this issue is also tied into the Unit 1 amendment request on control room wall removal.

These two documents are transmitted to provide background information for conference calls with your staff. No written response is needed from you. This letter also serves to make the subject documents available to the public.

Sincerely,

/S/

Peter S. Tam, Project Manager  
Project Directorate I-4  
Division of Reactor Projects I/II

Enclosures:  
As stated

cc w/enclosures:  
See next page

Docket File  
NRC & Local PDRs  
PD #I-4 Files  
SVarga  
SNorris  
OGC-Bethesda  
J. Partlow

BRoger  
PTam  
E. Jordan  
ACRS (10)

LAPDI-4  
SNorris  
4/13/87

PDI-4  
PTam;ehf  
4/13/87

PDI-4  
JStolz  
4/30/87

8705060155 870430  
PDR ADOCK 05000412  
E PDR

Mr. J. D. Sieber  
Duquesne Light Company

cc:

Mr. W. S. Lacey  
Station Superintendent  
Duquesne Light Company  
Beaver Valley Power Station  
Post Office Box 4  
Shippingport, Pennsylvania 15007

Mr. S. Sovick, Acting Supervisor  
of Licensing  
Duquesne Light Company  
Post Office Box 4  
Shippingport, Pennsylvania 15077

Mr. John A. Levin  
Public Utility Commission  
Post Office Box 3265  
Harrisburg, Pennsylvania 17120

Gerald Charnoff, Esquire  
Jay E. Silberg, Esquire  
Shaw, Pittman, Potts and Trowbridge  
2300 N Street, N.W.  
Washington, DC 20037

Charles E. Thomas, Esquire  
Thomas and Thomas  
212 Locust Street  
Box 999  
Harrisburg, Pennsylvania 17108

Marvin Fein  
Utility Counsel  
City of Pittsburgh  
313 City-County Building  
Pittsburg, Pennsylvania 15219

Resident Inspector  
U.S. Nuclear Regulatory Commission  
Post Office Box 298  
Shippingport, Pennsylvania 15077

Beaver Valley 1 Power Station

Pennsylvania Power Company  
James R. Edgerly  
Post Office Box 891  
New Castle, Pennsylvania 16103

Mr. Jess T. Shumate, Commissioner  
State of West Virginia Department  
of Labor  
1800 Washington Street, East  
Charleston, West Virginia 25305

David K. Heydinger, M.D.  
State Director of Health  
State Department of Health  
1800 Washington Street, East  
Charleston, West Virginia 25305

Regional Administrator, Region I  
U.S. Nuclear Regulatory Commission  
631 Park Avenue  
King of Prussia, Pennsylvania 19406

Mr. R. Janati  
Bureau of Radiation Protection  
Pennsylvania Department of  
Environmental Resources  
P.O. Box 2063  
Harrisburg, Pennsylvania 17120

John D. Burrows, P.E.  
Director of Utilities  
State of Ohio  
Public Utilities Commission  
180 East Broad Street  
Columbus, Ohio 43266-0573

Pennsylvania Office of Consumer  
Advocate  
ATTN: Michael Bardee  
1425 Strawberry Square  
Harrisburg, Pennsylvania 17120

Mr. J. J. Carey  
Duquesne Light Company

cc:

Gerald Charnoff, Esq.  
Jay E. Silberg, Esq.  
Shaw, Pittman, Potts & Trowbridge  
2300 N Street, N.W.  
Washington, DC 20037

Mr. C. W. Ewing, Quality Assurance  
Manager  
Quality Assurance Department  
Duquesne Light Company  
P. O. Box 186  
Shippingport, Pennsylvania 15077

Director, Pennsylvania Emergency  
Management Agency  
Room B-151  
Transportation & Safety Building  
Harrisburg, Pennsylvania 17120

Mr. T. J. Lex  
Westinghouse Electric Corporation  
Power Systems  
P. O. Box 355  
Pittsburgh, Pennsylvania 15230

Mr. P. RaySircar  
Stone & Webster Engineering Corporation  
P. O. Box 2325  
Boston, Massachusetts 02107

Mr. J. Beall  
U. S. NRC  
P. O. 181  
Shippingport, Pennsylvania 15077

Regional Administrator, Region I  
U.S. Nuclear Regulatory Commission  
631 Park Avenue  
King of Prussia, Pennsylvania 19406

Beaver Valley 2 Power Station

Mr. R. E. Martin, Manager  
Regulatory Affairs  
Duquesne Light Company  
Beaver Valley Two Project  
P. O. Box 328  
Shippingport, Pennsylvania 15077

Pennsylvania Office of Consumer  
Advocate  
ATTN: Michael Bardee  
1425 Strawberry Square  
Harrisburg, Pennsylvania 17120

John D. Burrows, P.E.  
Director of Utilities  
State of Ohio  
Public Utilities Commission  
180 East Broad Street  
Columbus, Ohio 43266-0573

Bureau of Radiation Protection  
PA Department of Environmental  
Resources  
ATTN: R. Janati  
P.O. Box 2063  
Harrisburg, Pennsylvania 17120

BVPS-2 Records Management Supervisor  
Duquesne Light Company  
Post Office Box 4  
Shippingport, Pennsylvania 15077

John A. Lee, Esq.  
Duquesne Light Company  
1 Oxford Centre  
301 Grant Street  
Pittsburgh, Pennsylvania 15279



POSITION PAPER

Unresolved Issue Beaver Valley Unit 2

During a site visit on December 5, 1984, the staff expressed concern that portions of the fire alarm system may not be in compliance with NFPA 72D regarding the listing of equipment and that circuits may not be electrically supervised in accordance with BTP CMEB 9.5-1 Section C.6.a which specifies that "Fire detection systems should comply with the requirements of Class A systems as defined in NFPA 72D.....". In addition, Sections 6.c, d and e which provide guidelines for the installation of Sprinkler, Halon and Carbon Dioxide Systems respectively, refer to the guidelines as provided in NFPA 13, 12A and 12. Each of these guidelines refers back to NFPA 72D for alarm installation.

In Generic Letter 86-10, in response to an industry question concerning conformance with NFPA codes, the staff affirmed that fire protection systems should comply with applicable codes. Where deviations from these codes-exist, the utility is obligated to identify and justify nonconformances. The applicant has not formally identified any deviation from NFPA 72D.

The Applicant responded to the December 5, 1984 concerns by letter dated May 24, 1985. In this letter the Applicant stated that the early warning smoke detection system was completely Class A per NFPA 72D and that portions of the

Halon and Carbon Dioxide System alarm circuitry were Class A and supervision was provided for the remaining portion. No mention was made of NFPA 72D compliance for the sprinkler system alarms.

It was interpreted by the staff and stated in SEP Supplement 3 that "the Applicant verified that all circuits of the fire-detection system are Class A."

During the site audit of January 27-30, 1987, additional concerns were raised about the adequacy of the fire alarm system and its compliance with NFPA 72D per Section C.6 of BTP CMEB 9.5-1. Specifically, the control room annunciator circuits appeared not to be properly supervised. If a single break or ground fault condition occurred, a fire alarm would not be able to be transmitted to the control room, with resulting delays in fire alarm notification and fire brigade response. In addition, the trouble condition on these circuits would not be annunciated as is required by NFPA 72D.

The applicant should be required to modify the existing alarm system to assure that all circuits are supervised per the referenced NFPA standard.

--

BEAVER VALLEY 1 & 2 - CONTROL ROOM ISOLATION

INSTRUMENTATION & CONTROL ISSUES

1. Numerous interposing/isolating relays are used in the BV-1/BV-2 design. Testability/single failure design requirements may not be met. This issue is related to the inadequacy of the technical specifications proposed for control room isolation instrumentation.

Applicant must provide:

- Identification of technical specifications for operability and surveillance of chlorine and radiation instrumentation channels, actuation logic, master relays and slave relays associated with automatic control room isolation on high chlorine and radiation signals.
- Complete, final design electrical schematics encompassing control room isolation on CIB/chlorine/radiation signals from sensors to final actuated devices (solenoid valves, motor-operated dampers, etc.)
- Complete control room ventilation system functional diagrams showing control signals and component identification for each fan, damper, etc. receiving automatic isolation signals and fail-open/fail-closed information for each damper.
- Discussion of procedures related to pulling fuses to effect disabling of equipment (such as ESF actuation relays) and of compliance with R.G. 1.47 when fuses are pulled. Relate this to at power testing of the relays used for control room isolation.

2. BV-2 SER Section 7.3.3.8 was closed based on a commitment that control room isolation dampers would be shut when an associated unit enters Mode 5 or 6 to ensure the dampers would be in their safety position in the event that electrical power is not available. Proposed BV-1/BV-2 technical specifications do not contain this commitment which may re-open our issue related to GDC-5.

Applicant must provide a discussion of how the proposed BV-1/BV-2 technical specifications for control room habitability systems comply with the commitment contained in the September 9, 1984, letter responding to Draft SER Section 7.3.3.8 and ensure that the design for control room habitability systems continues to meet GDC-5.

3. For multi-unit stations, bypassing of a protective function of a shared system (such as the BV-1/BV-2 control room habitability system) should be indicated in each control room per R.G. 1.47, "Bypassed and Inoperable Status Indication for Nuclear Power Plant Safety Systems."

Applicant must provide:

- Discussion of bypassed/inoperable status indications provided in the BV-1 control room and BV-2 control room for components (instrument channels, automatic actuation logic trains, power sources, etc.) which are required for the control room habitability systems to be operable, may be deliberately bypassed or rendered inoperable more frequently than once per year, and are shared by both units.