

ENCLOSURE 1

PROPOSED BRUNSWICK-1 TS PAGE
86TSB12

B609180429 B60912
PDR ADECK 05000324
P PDR

SUMMARY LIST OF REVISIONS

Page No.

Description of Change

3/4 6-15

Revised the isolation time for the RCIC Steam Line
Isolation Valves from 20 seconds to 30 seconds

TABLE 3.6.3-1 (Continued)

PRIMARY CONTAINMENT ISOLATION VALVES

VALVE FUNCTION	VALVE GROUP ^{1/}	ISOLATION TIME (Seconds)
EPOL steam line isolation valves E41-F002 E41-F003	4	50
HPCI torus section isolation valves E41-F042 E41-F041	4	80
RCIC steam line isolation valves E51-F007 E51-F008	5	30
Drywell purge exhaust backup valve CAC-V10	6	15
Containment air purge isolation valve CAC-V15	6	15
Suppression chamber vent valve CAC-V22	6	15
Drywell purge exhaust valve CAC-V23	6	15
Nitrogen makeup and inerting inlet valve CAC-V4	6	15
Suppression chamber inerting inlet valve CAC-V5	6	15

ENCLOSURE 2

Propose Brunswick-2 TS Page
86TSB12

SUMMARY LIST OF REVISIONS

Page No.

Description of Change

3/4 6-15

Revised the isolation time for the RCIC Steam Line
Isolation Valves from 20 seconds to 30 seconds

Removed temporary footnote extending isolation time

TABLE 3.6.3-1 (Continued)

PRIMARY CONTAINMENT ISOLATION VALVES

<u>VALVE FUNCTION</u>	<u>VALVE GROUP^{1/}</u>	<u>ISOLATION TIME (Seconds)</u>
HPCI steam line isolation valves E41-F002 E41-F003	4	50
HPCI torus suction isolation valves E41-F042 E41-F041	4	80
RCIC steam line isolation valves E51-F007 E51-F008	5	30
Drywell purge exhaust backup valve CAC-V10	6	15
Containment air purge isolation valve CAC-V15	6	15
Suppression chamber vent valve CAC-V22	6	15
Drywell purge exhaust valve CAC-V23	6	15

BRUNSWICK - UNIT 2

3/4 6-15

Amendment No.