NRC Form (9-83)	366									L	IC	ENS	EE	EV	ENT	RE	POR	T	LER				U.	S. N	APP	AR RI ROVE	EGULA D OM B/31/8	BNC	1Y CONN 0. 3150-0	415510N
FACILITY	NAME (1	1		-								-						-			Do	CKE	NUR	ABER	(2)			T	PAC	SE (3)
		NO	RTI	ŧΔ	NNA	PO	- Tu	RS	TAT	FTO	N	IIN	TT	2							0	15	10	10	10	13	1319	9 [1 OF	0 13
TITLE (4)		HI	GH	LI	FT S	SET	PO	INT	S (ON 1	MA	IN S	STE	EAM	SA	FET	VA	LV	ES						-			-		
EVENT DATE (5) LER NUMBER (6)								REPORT DATE (7) OTHE								ER F	R FACILITIES INVOLVED (8)													
MONTH DAY YEAR			R	YEA	R SEQUENTIAL REVISION				MONTH DAY YEAR			EAR		-	FAC	LITY	NAME	5			DOCKET NUMBER(S)									
			-			NUMBER		NUMBER		ic n		$^{+}$		+	-					0 15 0 0			0	10111						
0 2	2 1	8	6	8	6 -	0	0	1	-	0	0	0	3 2		1 8	6										0 15 10 10 10 1 1				
OPE	RATING			THIS	REPOR	IT IS	SUBA	AITTE	D PUP	RSUAP	NT T	O THE	REO	UIRE	MENT	S OF 10	CFR §	: 10	heck on	or m	ore of	the fo	llawi	ng) (1	(1)					
POWER LEVEL (10)	MODE (9) 3 POWER LEVEL (10) 0 1 01 0				20.402(b) 20.405(a)(1)(i) 20.405(a)(1)(ii)					20.405(c) 50.36(c)(1) 50.36(c)(2)				50.73(a)(2)(iv) 50.73(a)(2)(v) 50.73(a)(2)(vii)					73.71(b) 73.71(c) OTHER (Specify in Abstract											
			20.405(a)(1)(iii) 20.405(a)(1)(iv) 20.405(a)(1)(v)					50,73(a) (2)(i) 50,73(a) (2)(ii) 50,73(a) (2)(iii) 50,73(a) (2)(iii)				50.73(a)(2)(viii)(A) 50.73(a)(2)(viii)(B) 50.73(a)(2)(x)						385A)												
											L	CENSE	E CO	INTAC	T FO	R THIS	LER (12	2)							1.					
NAME E. Wayne Harrell, Station							on	Manager							AR	EAC	00E	819141-1511151			15 11									
						C	OMP	LETE	ONE	LINE	FOR	EACH	COM	PONE	NT F	ILURE	DESCR	BE	D IN TH	IS RE	PORT	(13)	-	-		-		-	-	
CAUSE	E SYSTEM COMP		OMPO	PONENT MANUFAC TURER		REPORTABLE TO NPROS						CAUSE		SYSTEM		COMPONE		it	MANUFAC TURER		R	REPORTABLE TO NPRDS								
X	SIB	R	V	1	(517	1	10		Y							1		1	1		1	1	1						
	1		_	1		1	1	1											1	1		1	1	1						
							SUPP	LEME	NTAL	REPO	DAT	EXPEC	TED	(14)				_			_		EXP	ECT	ED		MONT	TH	DAY	YEAR
X YES	s lit yes, c	ompie	te E)	PECT	TED SU	BM/SS	ion	DATE	9				-	NO									SU9 DA	MISS TE II	10N 15)		0.15	5	310	816

At 0355 hours on February 21, 1986, eight Main Steam Line Code Safety Valves on Unit 2 were declared inoperable after failing functional testing. The Unit was in Mode 3 (Hot Standby) with RC3 temperature at 539 degrees F and pressure at 1800 PSIG. The valves were determined to be inoperable while performing Periodic Testing in accordance with Section XI of the ASME Boiler and Pressure Vessel Code. With such a large number of valves found inoperable, Wyle Labs was selected to perform offsite testing on the Safety Valves. Discrepancies existed between the lift set pressures that station personnel found and those determined by Wyle Labs. All valves have been reset by Wyle Labs and will be operable upon installation. The cause of failure for the large percentage of Safety Valves has not been determined at this time. Results of Wyle Labs' investigation into the failures and the results of a Safety Analysis on the consequences of the failures will be included in a supplemental report. This event is reportable pursuant to 10 CFR 50.73(a)(2)(ii)(A).

PDR ADOCK 05000339

8603260159 860321

PDR

NRC Form 366A (9-83)	LICENSEE EVEN	NT REPORT (LER) TEXT CON	TINUATION	U.S. NUCLEAR REGUL APPROVED OME EXPIRES: 8/31/88	LATCRY COMMISSION 8 NO 3150-0104 8
FACILITY NAME (1)		DOCKET NUMBER (2)	LEA NU	MBER (6)	PAGE (3)
			YEAR SEQU	ENTIAL REVISION MBER NUMBER	

NORTH ANNA POWER STATION, UNIT 2

TEXT (If more space is required, use additional NRC Form 366A's) (17)

0 5 0 0 3 3 9 8 6 - 0 0 1 - 0 0 0 2 OF 0 3

At 0355 hours on February 21, 1986, eight Main Steam Line (EIIS System Identifier SB) Code Safety Valves (EIIS Component Identifier RV) on Unit 2 were declared inoperable after failing functional testing. The Unit was in Mode 3 (Hot Standby) with RCS temperature at 539 degrees F and pressure at 1800 PSIG. An initial sample of five of the fifteen Main Steam Safety Valves were selected in accordance with Section XI of the ASME Boiler and Pressure Vessel Code so that Periodic Testing could be performed. The test used a pneumatic assist test device in addition to the pressure in the Main Steam Lines. The pneumatic assist test device was used in accordance with instructions supplied by the valve manufacturer Crosby Valve & Gage Company (EIIS Vendor Identifier C710). Out of this initial sample, two valves would not lift at the maximum pressure available, two were declared operable after adjustment, and one was found within its setpoint range. Due to the failures, additional testing was performed in accordance with ASME Section XI. Testing of the second sample of five yielded two more Safety Valves that would not lift, two declared operable after adjustment, and one found operable. The remaining valves were tested as a result of the additional failures. Testing of the last set of five valves determined that four valves would not lift and one valve was adjusted within its setpoint range.

With such a high percentage of Safety Valves inoperable, a decision was made to have the valves retested with an all steam pressure system. Wyle Labs was selected to perform the offsite testing and refurbishing on the Safety Valves. On February 28, 1986, Wyle Labs was shipped a total of ten Safety Valves. Included in this shipment were the eight Safety Valves that did not lift, one valve that was initially found operable, and one valve that was determined operable after adjustment. Discrepancies existed between lift set pressures that station personnel found and those determined by Wyle Labs. The eight valves that would not lift on site were found to lift at or above the maximum pressure available at the station test. The valve which passed the station test after adjustment lifted at Wyle Labs within 0.8% of the station's "as left pressure". The valve which passed the station test without adjustment lifted above the station's "as left" pressure by 0.9% to 4.0% after multiple testing. Nine out of the ten valves retested by Wyle labs needed adjustment because they were out of their setpoint ranges. The remaining five Safety Valves were sent to Wyle Labs on March 10, 1986, after the report on the first shipment of valves showed that the originally thought operable valves were actually set high. A list of the Main Steam Safety Valve 1986 test results follows in the Appendix.

Testing of the Safety Valves during the previous outage of September 1984 was performed offsite by ITT Henze. All fifteen valves were sent to ITT Henze to be tested, reworked and adjusted as necessary to meet setpoint requirements.

The cause of the failure of such a large percentage of Safety Valves has not been determined at this time. Wyle Labs is preparing a technical report on the Safety Valve failures. Results of that report and any planned corrective actions will be included in a supplemental report. A Safety Analysis on the consequences of the as-found lift pressures is presently being performed. Results of that analysis will also be included in the supplemental report. This event is reportable pursuant to 10 CFR 50.73(a)(2)(ii)(A).

NRC Form 366A (9-83)	LICENSEE EVENT RE	PORT (LER) TE	XT CONTINU	ATION A B	CLEAR REGULATORY COMMISSION PPROVED OMB NO. 3150-0104 KPIRES: 8/21/88
FACILITY NAME (1)		DOCKET NUMBE	R (2)	LER NUMBER (6)	PAGE (3)
				YEAR SEQUENTIAL NUMBER	REVISION
NORTH ANNA POWER	STATION, UNIT 2	0 5 0 0	0 3 3 9	8 6 - 0 0 1 -	- 0 0 0 3 OF 0 3
TEXT (If more spece is required, use add	monel NRC Form 3664's/ (17)			APPENDI	X
		VIRGINIA	POWER	WYLE	LABS
VALVE	SET PRESSURE (PSIG)	AS FOUND (PSIG)	AS LEFT (PSIG)	AS FOUND (PSIG)	AS LEFT (PSIG)
2-MS-SV-201A	1085 (±11)	1109	1094	1105	1093
2-MS-SV-201B	1085 (±11)	1133	1077	1168	1091
2-MS-SV-201C	1085 (±11)	1149*		1133	1084
2-MS-SV-202A	1095 (±11)	1096	1098	1123	1100
2-MS-SV-202B	1095 (±11)	1156*		1166	1088
2-MS-SV-202C	1095 (±11)	1147*		1147	1097
2-MS-SV-203A	1110 (±11)	1124	1111	1111	1111
2-MS-SV-203B	1110 (±11)	1125	1106	1196	1116
2-MS-SV-203C	1110 (±11)	1131	1112	1105	1105
2-MS-SV-204A	1120 (±11)	1127	1128	1155	1118
2-MS-SV-204B	1120 (±11)	1159*		1182	1117
2-MS-SV-204C	1120 (±11)	1149*		1223	1127
2-MS-SV-205A	1135 (±11)	1161*		1168	1136
2-MS-SV-205B	1135 (±11)	1160*		1196	1132
2-MS-SV-205C	1135 (±11)	1149*		1164	1126

Values are averages *Failed to lift at this pressue



VIRGINIA ELECTRIC AND POWER COMPANY NORTH ANNA POWER STATION P. O. BOX 402 MINERAL, VIRGINIA 23117

March 21, 1986

U. S. Nuclear Regulatory Commission Document Control Desk Ol6 Phillips Building Washington, D.C. 20555 Serial No. N-86-008 NO/TRM: nih Docket No. 50-339

License No. NPF-7

Dear Sirs:

The Virginia Electric and Fower Company hereby submits the following Licensee Event Report applicable to North Anna Unit 2.

Report No. LER 86-001-00

This report has been reviewed by the Station Nuclear Safety and Operating Committee and will be forwarded to Safety Evaluation and Control for their review.

Very Truly You E. Wayne Man

Station Manager

Enclosures (3 copies)

cc: Dr. J. Nelson Grace, Regional Administrator U. S. Nuclear Regulatory Commission Region II 101 Marietta Street, Suite 2900 Atlanta, Georgia 30323

1522