DUKE POWER COMPANY P.O. BON 33160 GLARLOTTE, N.C. 28842

HAL B. TUCKER
VICE PROSIDENT
VUCLEAR PRODUCTION

TELEPHONE (704) 373-4531

September 9, 1986

Mr. Harold R. Denton, Director Office of Nuclear Reactor Regulation V. S. Nuclear Regulatory Commission Washington, D. C. 20555

Actention: Mr. B. J. Youngblood, Project Director PUR Project Directorate No. 4

Re: Catawba Muclear Station, Units 1 and 2 Docket Nos. 50-413 and 50-414 Technical Specification Amendment

Dear Mr. Danton:

Attached is a clarification to my letter dated June 6, 1986 concerning the addition of the Boron Dilution Mitigation System (RDMS) for Catawba Unit 1. The enclosed Technical Specification addition is necessary to ensure that all actuated components are tested at least once per 18 months to verify their operability.

Also enclosed are new FSAR pages for Section 7.6 which describe the EDMS. These FSAR pages will be incorporated into the next FSAR revision package.

Also, a review has been conducted and it has seen concluded that actuation of the BDMS will not disable any equipment which would be needed to mitigate the consequences of any accident identified in the accident analysis.

Very truly yours,

H.B. Tuchnoffel

Hal B. Tucker

RWO/23/sib

Attachments

8609190050 860909 PDR ADDCK 05000413 PDR PDR Mr. Harold R. Denton, Director September 9, 1986 Page Two

re: Dr. J. Welson Grace, Regional Administrator U. S. Nuclear Regulatory Commission Region II 101 Marietta Street, NW, Suite 2900 Atlanta, Ceorgia 30323

> Mr. Heyward Shealy, Chief Bureau of Radiological Health South Carolina Department of Health & Environmental Control 2600 Bull Street Columbia, South Carolina 29201

INPO Records Center Suite 1500 1100 Circle 75 Parkway Atlanta, Georgia 30339

American Nuclear Insurers c/o Dottie Sherman, ANI Library The Exchange, Suite 245 270 Farmington Avenue Farmington, CT 06032

M&M Nuclear Consultants 1221 Avenue of the Americas New York, New York 10020

Mr. P. H. Skinner NRC Resident Inspector Catawba Nuclear Station