



GeorgiaPower

the southern electric system

D. O. Foster
Vice President
Vogtle Project

SEP 12 11:58

September 5, 1986

United States Nuclear Regulatory Commission
Region II
Suite 2900
101 Marietta Street, Northwest
Atlanta, Georgia 30323

File: X7BG03-M123
Log: GN-1069

Reference: Vogtle Electric Generating Plant-Units 1 and 2; 50-424, 50-425;
Diesel Generator Control Panel Relays

Attention: Mr. J. Nelson Grace

On August 6, 1986, Mr. R. E. Folker, Vogtle Project Quality Assurance Engineer, informed Mr. E. F. Christnot of the USNRC Region II of a potentially reportable condition concerning General Electric Type NGA15AG3 relays used in Transamerica Delaval diesel generator control panels. The problem associated with these relays was initially reported by Transamerica Delaval and Delta Controls pursuant to 10 CFR 21.

Georgia Power Company is currently evaluating this condition and expects to inform the NRC of the evaluation results by November 21, 1986.

This response contains no proprietary information and may be placed in the NRC Public Document Room.

Yours truly,

D. O. Foster
D. O. Foster

REF/DOF/tdm

xc: U. S. Nuclear Regulatory Commission
Document Control Desk
Washington, D. C. 20555

J. H. Miller	R. A. Thomas	L. T. Gucwa
J. P. O'Reilly	D. R. Altman	C. W. Hayes
G. F. Head	P. R. Bemis	G. A. McCarley
R. E. Conway	J. A. Bailey	D. S. Read
J. T. Beckham	O. Batum	Sr. Resident (NRC)
R. H. Pinson	G. Bockhold	C. S. McCall (OPC)
P. D. Rice	C. E. Belflower	J. E. Joiner (TSLA)
B. M. Guthrie	J. F. D'Amico	D. Feig (GANE)
D. E. Dutton	E. D. Groover	NORMS

8609220063 860905
PDR ADOCK 05000424
S PDR

1/6

1119