

EVALUATION RESEARCH CORPORAT

COMANCHE PEAK RESPONSE TEAM

QUALITY INSTRUCTION FOR ISSUE-SPECIFIC ACTION PLAN VII.c

NOTICE OF CANCELLATION

INSTRUCTION NO.: QI-009

REVISION: 3

EFFECTIVE DATE: 12/04/86

UNCONTROLLED COPY

DOCUMENT REVIEW OF CONDUIT/R-E-CDUT

The QI identified above is hereby cancelled.
See page 2 for reasoning.

Prepared by: R. K. Chapman Date: 12-2-86

Approved by: D. Bailey for A. Patterson Date: 12/3/86
Issue Coordinator

Approved by: P. J. [Signature] Date: 12-3-86
On-Site QA Representative

Approved by: J. L. Hanel Date: 12/3/86
QA/QC Review Team Leader

8702110054 870126
PDR ADOCK 05000445
A PDR

All safety-related attributes for conduit, except conduit fabrication, are inspected in QI-008. The attribute for conduit fabrication would have been examined in QI-009; except that the inspection of conduit fabrication is done on a surveillance basis, which is common industry practice, and the IR's associated with these inspections are written to document only that the surveillance was performed. The conduit numbers are not recorded on these IR's and, therefore, the identification of the conduits which were inspected during fabrication cannot be determined.

However, the adequacy of conduit fabrication will be evaluated in the conduit report based on data from the cable damage attribute of the cable population.

Because document reviews do not obtain information that can be used relative to the adequacy of conduit fabrication, QI-009, all references and information relating to QI-009, and all packages inspected to this document review QI are hereby cancelled.

: