

GPU Nuclear Corporation

Post Office Box 388
Route 9 South
Forked River, New Jersey 08731-0388
609 971-4000
Writer's Direct Dial Number:

September 11, 1986

Mr. John A. Zwolinski, Director
BWR Project Directorate #1
Division of BWR Licensing
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Dear Mr. Zwolinski:

Subject: Oyster Creek Nuclear Generating Station
Docket No. 50-219
Technical Specification Change Request (TSCR) No. 147

Pursuant to 10CFR50.90, GPU Nuclear Corporation, operator of the Oyster Creek Nuclear Generating Station (OCNGS), Provisional Operating License No. DPR-16, requests a change to Appendix A of that license.

The subject Technical Specification (TS) Change Request provides the technical basis for revising: (1) the OCNGS TS limit for high drywell pressure from 2.4 psig to 3.5 psig, and (2) for bypassing the isolation condenser high flow trip function upon initiation of the alternate shutdown panel. We are requesting that TSCR No. 147 be issued no later than October 17, 1986, in order to support Cycle 11 operation. Implementing procedures will be drafted and ready for final approval at that time.

This change request has been reviewed in accordance with Section 6.5 of the Oyster Creek Technical Specifications. We have concluded that this proposed change does not constitute a significant hazard consideration.

Pursuant to 10CFR50.91(b)(1), a copy of this change request has been sent to the State of New Jersey Department of Environmental Protection. In addition, a check for \$150.00 pursuant to 10CFR170.12 is enclosed.

Very truly yours,

Peter B. Friedler
Vice President and Director
Oyster Creek

PBF/GB/dam
3329f:0002t
Attachment
ccs: on page 2

8609250297 860911
PDR ADOCK 05000219
P PDR

Handwritten notes:
A001 w/chuck
\$150
238699

cc: Dr. Thomas E. Murley, Administrator
Region I
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA. 19406

NRC Resident Inspector
Oyster Creek Nuclear Generating Station
Forked River, N.J. 08731

Mr. Jack N. Donohew, Jr.
U.S. Nuclear Regulatory Commission
7920 Norfolk Avenue
Bethesda, Maryland 20014


GPU NUCLEAR CORPORATION
OYSTER CREEK NUCLEAR GENERATING STATION

Provisional Operating
License No. DPR-16


Technical Specification
Change Request No. 147
Docket No. 50-219

Applicant submits, by this Technical Specification Change Request No. 147 to the Oyster Creek Nuclear Generating Station Technical Specifications, a change to Section 3.1, 3.1 Bases and Table 3.1.1.

By:


Peter B. Fiedler
Vice President and Director
Oyster Creek

Sworn and Subscribed to before me this 11th day of Sept. 1986.


A Notary Public of NJ
Exp. 6-5-91

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

In the matter of)
GPU Nuclear Corporation)


Docket No. 50-219


CERTIFICATE OF SERVICE

This is to certify that a copy of Technical Specification Change Request No. 147 for Oyster Creek Nuclear Generating Station Technical Specifications, filed with the U.S. Nuclear Regulatory Commission on September 11, 1986, has this day of September 11, 1986, been served on the Mayor of Lacey Township, Ocean County, New Jersey by deposit in the United States mail, addressed as follows:

The Honorable Christopher Connors
Mayor of Lacey Township
818 West Lacey Road
Forked River, NJ 08731

By:


Peter B. Fiedler
Vice President and Director
Oyster Creek



GPU Nuclear Corporation

Post Office Box 388

Route 9 South

Forked River, New Jersey 08731-0388

609 971-4000

Writer's Direct Dial Number:

September 11, 1986

The Honorable Christopher Connors
Mayor of Lacey Township
818 West Lacey Road
Forked River, New Jersey 08731

Dear Mayor Connors:

Subject: Oyster Creek Nuclear Generating Station
Docket No. 50-219

Enclosed herewith is one copy of Technical Specification Change Request No. 147 for the Oyster Creek Nuclear Generating Station Operating License.

This document was filed with the United States Nuclear Regulatory Commission on September 11, 1986.

Very truly yours,

A handwritten signature in dark ink, appearing to read 'Peter B. Friedler', written over the printed name.

Peter B. Friedler
Vice President and Director
Oyster Creek

PBF/GB/dam
3496f:0002t
Attachment