



Log # TXX-6272
File # 10130

William G. Council
Executive Vice President

February 10, 1987

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555

SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION (CPSES)
DOCKET NOS. 50-445 AND 50-446
REQUEST FOR INFORMATION REGARDING INSPECTION REPORTS:
50-445/85-07, 50-446/85-05; 50-445/85-14, 50-446/85-11;
50-445/85-16, 50-446/85-13; 50-445/86-06, 50-446/86-04

Gentlemen:

We have reviewed your letter dated February 5, 1987, requesting additional information on the subject inspection reports. We hereby respond to the request for additional information in the attachment to this letter.

Very truly yours,

A handwritten signature in cursive script that reads 'W. G. Council'.

W. G. Council

By:

A handwritten signature in cursive script that reads 'G. S. Keeley'.

G. S. Keeley
Manager, Nuclear Licensing

RSB:lw
Attachment
Enclosures

c - Mr. E. H. Johnson, Region IV
Mr. D. L. Kelley, RI - Region IV
Mr. H. S. Phillips, RI - Region IV

8702110255 870210
PDR ADOCK 05000445
Q PDR

400 North Olive Street L.B. 81 Dallas, Texas 75201

TEO
11

SUPPLEMENTAL REQUEST FOR INFORMATION REGARDING
INSPECTION REPORTS
50-445/85-07, 50-446/85-05; 50-445/85-14, 50-446/85-11;
50-445/85-16, 50-446/85-13; 50-445/86-06, 50-446/86-04

1. Provide TU Electric's evaluations and, as appropriate, proposed or corrective actions (including procedures generated) to unresolved items or open items addressed in inspection reports 50-445/85-07, 50-446/85-05; 50-445/85-14, 50-446/85-11; 50-445/85-16, 50-446/85-13; 50-445/86-06, 50-446/86-04.

RESPONSE TO ITEM 1

Based on discussions with the NRC staff on February 9, 1987, TU Electric will respond to this question by Thursday, February 12, 1987.

2. With reference to inspection report 50-445/85-07, 50-446/85-05, unresolved item 446/8505-06, when Westinghouse accepted the deviation in tolerance for centering and leveling of the Unit 2 reactor vessel from their recommended design criteria, did Westinghouse perform an engineering evaluation (e.g., to confirm the stress report is still valid)? Did TU Electric review the Westinghouse engineering evaluation? Please provide the engineering evaluation.

RESPONSE TO ITEM 2

At the time of the inspection finding (1985), no evaluation by Westinghouse was available which substantiated acceptance of the tolerance deviation on the 1979 construction operational traveler. However, as a result of the inspection item, Westinghouse, the NSSS design organization, documented acceptance of the tolerance by letter WPT-8148, dated January 10, 1986. Westinghouse has recently indicated an evaluation exists for accepting the tolerances; however, the evaluation has not been received at the jobsite. Westinghouse has also indicated that the final as-built stress reports (which will incorporate deviations encountered during the construction phase) will be issued after completion of construction. Currently, only design stress reports have been issued by Westinghouse.

SUPPLEMENTAL REQUEST FOR INFORMATION REGARDING
INSPECTION REPORTS

50-445/85-07, 50-446/85-05; 50-445/85-14, 50-446/85-11;
50-445/85-16, 50-446/85-13; 50-445/86-06, 50-446/86-04 - CONT'D

3. With reference to inspection report 50-445/85-07, 50-446/85-05, unresolved item 446/8505-07, does TU Electric audit plan require an audit be performed of surveillances of the Unit 2 reactor pressure vessel specifications, procedures, and installations?

RESPONSE TO ITEM 3

TU Electric's audit plan did not and does not require an audit of surveillances of the Unit 2 reactor pressure vessel specifications, procedures, and installations. The objective of the TU Electric audit plan is to determine that a quality assurance program has been developed and documented in accordance with specified requirements. TU Electric accomplishes that objective by performing audits on selected activities, not on all activities.

4. With reference to inspection report 50-445/85-07, 500-446/85-05, and NOV 445/8507-04, 446/8505-02, although no records exist that concrete mixing blades had been inspected quarterly since trucks were placed in service in 1977, it is our understanding that there are consistent concrete strength and uniformity tests.
 - a. Does TU Electric have a concrete strength statistical distribution for this period?
 - b. Provide three (3) results reports spaced over this period (i.e., 1977, 1980 and 1984).

RESPONSE TO ITEM 4.a

Enclosure 1 is a statistical evaluation of a series of concrete tests run during 1978. This is one of several statistical evaluations run during the 1973 to 1979 time frame.

RESPONSE TO ITEM 4.b

Enclosures 2, 3 and 4 are sample strength tests run during this period. Enclosure 5 is a sample uniformity test. Uniformity tests were run and documented during the 1977 to 1979 time frame, and strength tests were run and documented during the entire 1977 to 1984 time frame.

SUPPLEMENTAL REQUEST FOR INFORMATION REGARDING
INSPECTION REPORTS

50-445/85-07, 50-446/85-05; 50-445/85-14, 50-446/85-11;
50-445/85-16, 50-446/85-13; 50-445/86-06, 50-446/86-04 - CONT'D

5. What are the marking and traceability requirements for pipe spools and weld rods? With regard to weld rods, what are the consequences of using an unidentified weld rod to perform welding?

RESPONSE TO ITEM 5

MARKING AND TRACEABILITY REQUIREMENTS FOR PIPE SPOOLS:

The site marking and traceability requirements of pipe spools in the ASME Code Section III, Division I, Subsection NA, Paragraph NA-4442.1 and NA-3776.6(a) are identified within CP-CPM-6.9, General Piping Procedure, as specified by Specification MS-100, Piping Specification for Nuclear Piping.

CP-CPM-6.9, General Piping Procedure, states, "This procedure and the appendices have been prepared to delineate requirements for the fabrication, installation, BOP inspection, and the documentation for piping..."

CP-CPM-6.9, Appendix C, Material Identification, contains the requirements for the control and identification of components and material using unique markings, color coding, etc. It outlines the material identification procedure, QC receipt inspection of materials and color coding and tagging of material by warehouse personnel. It also requires that the color code be maintained until the pipe and/or fitting is fabricated into, or becomes a pipe spool. This appendix also requires that material requisition documentation should contain: a) Piping Materials - quantity, description, heat no., pipe category, specification, color code or stock no., code class, or for field use, the applicable drawing(s) for which the material is to be used, b) Piping Subassemblies - subassembly number ... and, d) Valves - quantity, size, generic no., serial no. and drawing(s) on which valve(s) are shown ... f) In addition to the above information, the applicable heat/log/serial number and code class shall be marked on the Material Requisition form adjacent to the appropriate item for all "Q" material ..."

CP-CPM-6.9, Appendix D, Welding and Related Processes, requires that QCI verify items or material to be installed or used in fabrication be accepted for construction activities or other wise released. This appendix also identifies controls for material traceability control, marking transfers and prefabrication checks for proper markings.

CP-CPM-6.9, Appendix E, Pipe Fabrication and Installation, delineates the requirements for piping fabrication and installation at CPSES. It

SUPPLEMENTAL REQUEST FOR INFORMATION REGARDING
INSPECTION REPORTS

50-445/85-07, 50-446/85-05; 50-445/85-14, 50-446/85-11;
50-445/85-16, 50-446/85-13; 50-445/86-06, 50-446/86-04 - CONT'D

specifies such elements as marking technique and requirements, QC verification and marking location. Specifically, the procedure requires, "Each spool shall be identified where practical by a name tag attached by banding and in addition, in all cases, by marking the spool number into the spool approximately 4 inches from the upstream field weld end." The procedure also provides marking requirements for piping prior to cutting for fabrication as follows: "Q" Pipe Heat number, piece number, spool number, ASME grade number and schedule. The procedure also states, "Care should be used when marking short pieces of pipe to ensure the markings are not inadvertently removed during the cleaning/fabrication process prior to being recorded on the weld documentation."

CP-CPM-6.9, Appendix G, Documentation for ASME Welding, Fabrication, and Installation Activities, provides the documentation requirements of ASME Section III for welding, fabrication, and installation activities. It describes the requirements for using Weld Data Cards, Multiple Weld Data Cards and Manufacturing Records Sheets. These records ensure traceability of material through onsite fabrication to final installation and documentation transmittal for review approval, certification and records vault for retention.

MARKING AND TRACEABILITY REQUIREMENTS FOR WELD RODS:

The site marking and traceability requirements for weld rods specified in the ASME Code Section III, Division I, Subsection NA, Paragraphs NA-4442.1 and NA-3766.6(b), are identified within CP-CPM-6.9, General Piping Procedure.

CP-CPM-6.9, Appendix B, Weld Filler Material, delineates requirements for the procurement and control of all welding filler material. It includes controls for procurement, identification, material distribution and storage, prevention of contamination during handling, and issuance control. The procedure is specific in requirements for identification of weld filler material that is removed from its original container:

- "...2) Each 18-inch length of straight bare wire shall be flag tagged on one end. Each 36-inch length of straight bare wire shall be flag tagged on both ends. Marking shall include the material classification, heat/lot, and size.
- 3) Low hydrogen electrodes shall be segregated to maintain traceability by the classification, size, and heat/lot number when placed in a heated stationary or portable oven..."

SUPPLEMENTAL REQUEST FOR INFORMATION REGARDING
INSPECTION REPORTS

50-445/85-07, 50-446/85-05; 50-445/85-14, 50-446/85-11;
50-445/85-16, 50-446/85-13; 50-445/86-06, 50-446/86-04 - CONT'D

The procedure gives requirements for the completion of the Weld Filler Material Log (WFML) as to Weld Procedure Specification (WPS), material size and class, welder's symbol, date and weld numbers, entry of the heat number and quantity of material issued and current revision/ICN number to the WPS. The return of weld filler material to the Material Distribution Station (MDS) shall be dispositioned as follows:

- "...2) Straight-length bare wire -
- a) Material not used may be reissued
 - b) Used material shall be considered NCWFM [Nonconforming WFM]
 - c) Flag tag identification must be affixed to all reissued bare wire.

Flag tagging shall not be done if material traceability is unclear. Material returned without the original flag tag shall be handled as NCWFM...

- 4) Low-hydrogen electrodes -
- a) Material issued in portable oven that was energized (no notation on WFML). Return to stationary oven, reissue as required.
 - b) Material issued in portable oven discovered not energized and has exceeded exposure limits (notation on WFML) disposition as NCWFM, store for transit to WQTC [Welder Qualification Training Center].

- 5) Other covered electrodes -

Identify and protect, reissue as required...."

CONSEQUENCES OF USING UNIDENTIFIED WELD RODS:

Unidentified weld rod is required to be treated as nonconforming and documented on Nonconformance Reports using CP-CPM-6.9, Appendix B.

If the weld rod could not positively be identified, the subject weld joint would be removed and replaced.

If the identification of the weld rod could be established using supplemental documentation, the subject weld could be accepted "as-is" contingent on approval of Engineering and QA/QC. This approval use would include appropriate technical justification for acceptance.

CONCRETE TESTING DATA MANAGEMENT

CP244-

8700

REVISION A

RUN DATE: 03-15-79

PROJECT: COMANCHE PEAK

JOB NUMBER: 35-1195

CONCRETE MIX: A-132

7 DAY TESTS TO: 12-29-78


28 DAY TESTS TO: 12-29-78



BROWN & ROOT, INC.
POWER ENGINEERING DIVISION
HOUSTON, TEXAS

FOR INFORMATION ONLY


COMANCHE PEAK	CONCRETE MIX: A-132	RUN DATE: 03-16-79	PLOT 1
CP-244			



COMANCHE PEAK	CONCRETE MIX: A-132	RLN DATE: 09-15-78	PLOT 2
---------------	---------------------	--------------------	--------


CP-244

FOR INFORMATION ONLY



CONCRETE PEEK	CONCRETE MIX: A-132	RUN DATE: 03-15-79	PL: JF 3
---------------	---------------------	--------------------	----------


CP-244



FOR INFORMATION ONLY


CONCRETE PIER	CONCRETE MIX: A-132	RUN DATE: 03-15-75	PLOT: 5
---------------	---------------------	--------------------	---------

CP-244




FOR INFORMATION ONLY

CONCRETE MIX: A-122 6.2N DATE: 03-15-9



CONCRETE MIXTURE A-132 P.N. 03-15-79



COMANCHE PEAK CONCRETE MIX: R-132 RUN DATE: 03-15-78 PLOT 8
CP-244


100.00
80.00
60.00
40.00
20.00
00.00
10'
PRICE
FOR INFORMATION ONLY




00 10 20 30 40 50 60 63
TEST NUMBER
MOVING AVERAGE OF PREVIOUS TEN. 7 DAY RANGE (PSI)

COMANCHE PEAK	CONCRETE MIX: A-132	RUN DATE: 03-15-79	PLOT 9
---------------	---------------------	--------------------	--------

CP-244




COMANCHE PEAK	CONCRETE MIX: A-132	RUN DATE: 03-15-79	PLOT: 10
CP-244			




COMANCHE PEAK	CONCRETE MIX: A-132	RUN DATE: 03-15-79	PLOT 11
---------------	---------------------	--------------------	---------

CP-244




COMANCHE PEAK	CONCRETE MIX: A-132	RUN DATE: 09-15-70	PLOT 12
---------------	---------------------	--------------------	---------

CP-244




COMANCHE PEAK	CONCRETE MIX: A-192	RUN DATE: 03-16-79	PLOT 13
---------------	---------------------	--------------------	---------

CP-244



COMANCHE PEAK	CONCRETE MIX: A-132	RUN DATE: 03-15-79	PLOT - 14
---------------	---------------------	--------------------	-----------


CP-244



COMANCHE PEAK	CONCRETE MIX: A-132	RUN DATE: 09-15-79	PLOT 15
---------------	---------------------	--------------------	---------

CP-244

FOR INFORMATION ONLY



.....
 * CLIENT NAME -TEXAS UTILITIES SERVICES INC.
 *
 * LOCATION -GLEN ROSE, TEXAS
 *
 * PLANT NAME -COMANCHE PEAK NUCLEAR PROJECT
 *
 * UNIT NUMBER -1 & 2
 *
 * BROWN AND ROOT JOB NUMBER - 35-1195
 *
 * CALCULATIONS BY - DUKE POINTER

CONCRETE TEST. DATA MGT.
 CP-244 REVISION A
 IBH 370-155/168
 J/15/79
 TIME=13:48:31

RUN NUMBER _____
 CALCULATION NUMBER _____
 REVISION NUMBER _____

.....
 * END OF FIRST ANALYSIS FOR MIX A-120
 * SECOND ANALYSIS FOR MIX A-120
 * END OF FIRST ANALYSIS FOR MIX A-132
 * SECOND ANALYSIS FOR MIX A-132
 * SECOND ANALYSIS FOR MIX A-133
 * UNIT WEIGHT PLOTS NOT EXECUTED AS A RESULT OF ONLY ONE TAKEN PER DAY

FOR INFORMATION ONLY

CHECKED BY _____ DATE _____
 APPROVED BY _____ DATE _____
 APPROVED BY _____ DATE _____

CONCRETE CLASS A-132										DATE 03-15-79			NO. OF SAMPLES TO DATE			46		
TEST NUMBER	TEMP	SLUMP	COEFF	UNIT	WGT	C OF V	7 DAY RESULTS	AVERAGE STRENGTH	RANGE	C OF V	28 DAY RESULTS	AVERAGE STRENGTH	RANGE	C OF V				
DATE CAST	AVG TEMP	AVG SLUMP	AVG COEFF	AVG WGT	AVG WGT	OF UNIT	CYL 1 CYL 2 CYL 3	AVG STRENGTHS	AVG RANGE	ST DEV OVERALL	CYL 1 CYL 2 CYL 3	AVG STRENGTHS	AVG RANGE	ST DEV OVERALL				
LAB NUMBER	MOVING	MOVING	MOVING	MOVING	MOVING	MOVING	MOV AVG OF 3	MOV AVG OF 3	MOV AVG OF 10	MOV AVG OF 10	MOV AVG OF 3	MOV AVG OF 3	MOV AVG OF 10	MOV AVG OF 10				
110178	61	3.50	4.7	143.6	6.0	0.46	4080	3920	170	3.85	5020	5030	10	0.18				
0	61	3.56	4.7	143.6	0.0	0.0	3830	3920	170	0.0	5030	5030	10	0.0				
0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0				
116775	58	3.16	4.4	144.9	0.46	0.46	4200	4270	140	3.36	5480	5550	130	1.17				
0	60	3.25	4.5	144.3	0.0	0.0	4340	4090	155	177.50	5610	5290	70	260.00				
0	0	0	0	0	0	0	0	0	0	0	0	0	0	4.92				
111378	64	3.10	4.9	144.6	0.38	0.38	3740	3780	80	2.89	5150	5170	30	0.96				
0	61	3.17	4.7	144.4	0.0	0.0	3620	3990	130	206.65	5180	5250	57	219.70				
0	61	3.17	4.7	144.4	0.0	0.0	3990	3990	5.18	5.18	0	5250	0	4.19				
111378	64	4.00	4.3	0.0	0.38	0.38	3600	3620	30	2.39	5220	5330	220	1.64				
0	61	3.38	4.6	144.4	0.0	0.0	3630	3900	105	241.17	5440	5270	98	193.79				
0	61	3.33	4.6	144.8	0.0	0.0	3890	3890	6.19	6.19	0	5350	0	3.68				
111378	64	4.00	4.3	0.0	0.38	0.38	4030	4040	20	1.99	5700	5640	130	1.73				
0	61	3.50	4.5	144.4	0.0	0.0	4050	3920	88	223.37	5570	5340	104	227.60				
0	62	1.83	4.3	144.6	0.0	0.0	3810	3810	5.69	5.69	0	5380	0	4.26				
111378	61	3.50	4.4	0.0	0.38	0.38	3750	3810	110	2.08	5470	5400	140	1.82				
0	62	1.83	4.3	144.4	0.0	0.0	3860	3900	92	208.67	5330	5350	110	208.97				
0	0	0	0	0	0	0	0	0	0	0	0	0	0	3.91				
111378	61	4.00	4.6	0.0	0.38	0.38	3680	3610	140	2.26	5330	5170	330	2.36				
0	62	3.43	4.3	144.4	0.0	0.0	3540	3860	99	218.91	5000	5320	141	204.01				
0	0	0	0	0	0	0	0	0	0	0	0	0	0	3.83				
111378	61	4.00	4.4	0.0	0.38	0.38	3750	3760	20	2.04	5450	5490	70	2.20				
0	61	3.63	4.5	144.4	0.0	0.0	3770	3850	89	207.54	5520	5340	133	198.16				
0	61	3.63	4.5	144.4	0.0	0.0	3730	3730	5.39	5.39	0	5350	0	3.71				
111378	64	4.60	4.3	0.0	0.38	0.38	4210	4230	30	1.87	5340	5600	520	2.90				
0	62	3.67	4.5	144.4	0.0	0.0	4240	3890	82	228.52	5860	5370	176	203.44				
0	0	0	0	0	0	0	0	0	0	0	0	0	0	3.79				
111378	60	3.50	5.2	143.2	0.49	0.49	3730	3730	10	1.72	5010	4950	130	2.84				
0	61	3.65	4.5	144.1	0.0	0.0	3720	3870	75	222.45	4880	5330	171	231.68				
0	62	3.63	4.6	143.2	0.0	0.0	3980	3980	75	5.74	0	5340	171	4.35				
111378	50	4.60	4.7	144.2	0.44	0.44	3950	3940	20	1.68	5450	5450	10	2.60				
0	60	3.64	4.6	144.1	0.0	0.0	3930	3880	70	212.93	5440	5340	156	223.38				
0	58	3.83	4.7	143.7	0.0	0.0	3760	3760	68	5.49	0	5330	171	4.18				
111678	54	4.00	4.0	145.0	0.46	0.46	4090	4020	150	1.75	5030	5280	410	2.95				
0	60	3.71	4.5	144.2	0.0	0.0	3940	3890	77	207.23	5440	5330	176	215.83				
0	55	3.83	4.6	144.1	0.0	0.0	3890	3890	61	5.32	0	5210	199	4.05				
112178	16	3.50	4.1	144.3	0.50	0.50	4270	4320	66	1.70	5400	5260	280	3.04				
0	60	3.60	4.5	144.4	0.0	0.0	4350	3920	75	229.49	5120	5350	185	208.23				

FOR INFORMATION ONLY

29	62.	2.50	4.4	145.4	0.5	3400.	3470.	130.	2.73	5060.	5040.	40.	3.01
121278	59.	3.57	4.7	144.5		3530.	3980.	123.	273.39	5020.	5310.	180.	192.17
0	61.	3.33	4.9	144.4		0.	3630.	189.	6.86	0.	5280.	134.	3.62
30	56.	2.25	5.0	145.4	0.5	3750.	3620.	270.	2.85	4770.	4930.	320.	3.10
121278	57.	3.52	4.7	144.5		3480.	3970.	128.	276.87	5090.	5300.	185.	200.80
0	57.	2.83	4.8	144.4		0.	3570.	212.	6.97	0.	5130.	149.	3.79
31	62.	3.50	5.2	0.0	0.5	3690.	3650.	40.	2.83	5710.	5570.	290.	3.15
121378	59.	3.57	4.7	144.5		3600.	3960.	126.	278.45	5420.	5300.	188.	203.17
0	59.	2.75	4.9	145.4		0.	3580.	220.	7.03	0.	5180.	162.	3.83
32	62.	3.00	4.2	146.2	0.6	3740.	3650.	180.	2.87	5500.	5410.	180.	3.14
121378	59.	3.51	4.7	144.6		3560.	3950.	126.	279.39	5320.	5310.	188.	200.80
0	60.	2.92	4.8	145.6		0.	3640.	187.	7.07	0.	5300.	176.	3.78
33	58.	2.75	4.6	144.7	0.61	3890.	3880.	20.	2.80	5680.	5620.	130.	3.11
121478	59.	3.48	4.7	144.6		3870.	3950.	125.	275.40	5550.	5320.	186.	204.61
0	61.	3.08	4.7	145.5		0.	3730.	175.	6.97	0.	5530.	181.	3.85
34	64.	3.25	4.6	144.6	0.54	3610.	3590.	50.	2.76	5700.	5580.	240.	3.13
121878	59.	3.48	4.7	144.6		3560.	3940.	123.	278.24	5460.	5330.	188.	206.41
0	61.	3.00	4.5	145.2		0.	3710.	161.	7.06	0.	5540.	189.	3.88
35	60.	3.25	4.7	144.5	0.57	3450.	3400.	110.	2.76	5070.	5090.	30.	3.06
121978	60.	3.47	4.7	144.6		3340.	3920.	122.	288.84	5100.	5320.	183.	207.33
0	63.	3.08	4.6	144.8		0.	3620.	134.	7.36	0.	5430.	174.	3.90
36	64.	3.50	5.2	0.0	0.57	3570.	3550.	50.	2.72	5350.	5330.	50.	3.00
121978	60.	3.47	4.7	144.6		3520.	3910.	120.	291.52	5300.	5320.	180.	204.44
0	65.	3.33	4.8	144.8		0.	3510.	131.	7.45	0.	5330.	168.	3.84
37	69.	3.25	5.1	0.0	0.57	3370.	3430.	120.	2.73	5090.	5150.	110.	2.97
121978	60.	3.47	4.7	144.6		3490.	3900.	120.	298.04	5200.	5310.	178.	203.01
0	62.	3.33	5.0	144.8		0.	3460.	104.	7.64	0.	5190.	170.	3.83
38	66.	3.50	5.4	0.0	0.57	3270.	3350.	160.	2.77	5070.	5090.	30.	2.91
121978	60.	3.47	4.7	144.6		3430.	3890.	121.	306.99	5100.	5310.	174.	204.22
0	66.	3.42	5.2	0.0		0.	3440.	118.	7.90	0.	5190.	142.	3.85
39	62.	3.00	4.3	145.0	0.58	4030.	4020.	30.	2.71	5760.	5890.	260.	2.93
122078	60.	3.46	4.7	144.7		4000.	3690.	119.	303.72	6020.	5320.	176.	221.60
0	66.	3.25	4.9	145.0		0.	3600.	108.	7.81	0.	5370.	164.	4.16
40	62.	3.25	5.2	143.5	0.57	3820.	3800.	40.	2.67	5540.	5330.	420.	3.04
12678	60.	3.45	4.7	144.6		3780.	3890.	117.	300.22	5120.	5320.	182.	216.81
0	63.	3.25	5.0	144.3		0.	3720.	85.	7.72	0.	5440.	174.	4.11
41	61.	3.75	5.9	142.7	0.62	3530.	3520.	30.	2.63	4990.	4980.	30.	2.98
12778	60.	3.46	4.8	144.5		3500.	3880.	115.	302.03	4960.	5310.	179.	222.69
0	62.	3.33	5.1	143.6		0.	3780.	79.	7.79	0.	5400.	148.	4.19
42	64.	3.25	4.1	0.0	0.62	3760.	3690.	140.	2.64	5420.	5510.	170.	2.97
12978	60.	3.45	4.8	144.5		3620.	3870.	115.	299.78	5590.	5320.	178.	221.94
0	62.	3.42	5.1	143.1		0.	3670.	75.	7.74	0.	5270.	147.	4.17
43	63.	3.75	4.4	0.0	0.62	3500.	3610.	10.	2.59	5840.	5720.	250.	2.99
122778	60.	3.46	4.7	144.5		3610.	3870.	113.	299.02	5590.	5330.	180.	227.32
0	61.	3.5	4.8	142.7		0.	3600.	74.	7.73	0.	5400.	159.	4.27

FOR INFORMATION ONLY

44	60.	4.00	4.7	0.0	0.62	3650.	360.	50.	2.56	5520.	5520.	10.	.93
122978	60.	3.47	4.7	144.5		3700.	3860.	112.	296.98	5510.	5330.	176.	226.44
0	63.	3.67	4.4	0.0		0.	3660.	74.	7.69	0.	5580.	136.	4.25
45	67.	4.00	5.2	0.0	0.62	3480.	3440.	90.	2.56	5370.	5260.	220.	2.95
122978	61.	3.48	4.8	144.5		3390.	3850.	111.	300.35	5150.	5330.	177.	224.16
0	64.	3.92	4.8	0.0		0.	3570.	72.	7.80	0.	5500.	155.	4.21
46	70.	3.25	4.6	0.0	0.62	3680.	3690.	10.	2.51	5730.	5600.	270.	2.98
122978	61.	3.46	4.8	144.5		3630.	3650.	109.	298.08	5460.	5340.	179.	225.04
0	60.	3.75	4.6	0.0		0.	3600.	68.	7.74	0.	5460.	177.	4.22

DESIGN STRENGTH=

4000.

REQUIRED OVERDESIGN STRENGTH=

4400.

FOR INFORMATION ONLY

ENCLOSURE 1
Page 19 of 19



File 3777-6
Order 13-C-9927

Date: 7-29-77

Brown & Root, Inc.
P.O. Box 1001
Clen Rose, Texas 76043

Subject: Texas Utilities Services, Inc.
Comanche Peak Steam Electric Station
1980-1982 Units 1 & 2
Job No. 35-1195
B & R Subcontract No. 35-1195-0225
Hunt Project No. 513

Re: B & R/TUSI retention time
for the attached documents
Lifetime years after plant
begins operation.

Gentlemen:

Please acknowledge receipt of the following item by signing and returning a copy of this letter.

HCP # 28351 To 28353 COMPRESSION TEST ON CONCRETE CYLINDERS
CONCRETE MIX # 126
CONCRETE POUR # 002-5810-001

BROWN & ROOT, INC.

RECEIVED

JUL 29 1977

FILES NOTED

ROBERT W. HUNT COMPANY

Rec. by Brown & Root, Inc.
by [Signature]

QUALITY ASSURANCE

[Signature]
Level II

Title

[Signature]

Date

7-29-77

Form HCP-9

QA RECORD ROUTING

RTN	QA REVIEW
L	[Signature]
FILE NO.	
	CCT-21
SUBFILE NO.	
	002-5810-001

1. _____
2. _____
3. _____
4. _____
5. _____

FOR INFORMATION ONLY

FILE NO. 3777-6
 ORDER 13-C-9927

Date: 7-29-77

Brown & Root, Inc.
 P. O. Box 1001
 Glen Rose, Texas 76043

RE: Texas Utilities Services, Inc.
 Comanche Peak Steam Electric Station
 1980-1982 Units 1 & 2
 Job No. 35-1195
 B & R Subcontract No. 35-1195-0225
 Hunt Project No. 513

Gentlemen:

We report results of Concrete Compression Tests, ASTM C-39 (Hunt E1001)

Pour No. 002-5810-001 Slump Inches 3 1/4"
 Ticket No. 32887 Temperature °F 620
 Date Made 7-22-77 Air Content % 4.3%
 Date Tested 7-29-77 Concrete Mix 126
 Age Days 7 Unit Weight 145.28

	STANDARD CURED		FIELD CURED (JOB)	
Cylinder No.	C4375	C4376	N/A	N/A
Strength lbs. PSI.	3450	3651	N/A	N/A
Max. Load - lbs.	97500	103500	N/A	N/A
Type of Fracture	Reg	Reg	N/A	N/A
Date Received	7-23-77	7-23-77	N/A	N/A
Area	28.26	28.35	N/A	N/A

Tested by: SD
 Checked by: 200

Respectfully submitted,
 ROBERT W. HUNT COMPANY

Jerry Sautter
 LEVEL II

FILE NO. 3777-6
HUNT NO. 13-C-9927

Date: 7-24-77

ENCLOSURE 2
Page 3 of 7
HUNT NO. 28352
PAGE

Brown & Root, Inc.
P. O. Box 1001
Glen Rose, Texas 76043

RE: Texas Utilities Services, Inc.
Comanche Peak Steam Electric Station
1980-1982 Units 1 & 2
Job No. 35-1195
B & R Subcontract No. 35-1195-0225
Hunt Project No. 513

Gentlemen:

We report results of Concrete Compression Tests, ASTM C-39 (Hunt E1001)

Pour No. 002-5810-001 Slump Inches 3 1/2"
Ticket No. 32919 Temperature °F 64°
Date Made 7-22-77 Air Content % 4.8%
Date Tested 7-29-77 Concrete Mix 126
Age Days 7 Unit Weight 145.58

	STANDARD CURED		FIELD CURED (JOB)	
Cylinder No.	<u>C4344</u>	<u>C4345</u>	<u>N/A</u>	<u>N/A</u>
Strength lbs. PSI.	<u>3633</u>	<u>3767</u>	<u>N/A</u>	<u>N/A</u>
Max. Load - lbs.	<u>103000</u>	<u>106500</u>	<u>N/A</u>	<u>N/A</u>
Type of Fracture	<u>Reg</u>	<u>Reg</u>	<u>N/A</u>	<u>N/A</u>
Date Received	<u>7-23-77</u>	<u>7-23-77</u>	<u>N/A</u>	<u>N/A</u>
Area	<u>28.35</u>	<u>28.27</u>	<u>N/A</u>	<u>N/A</u>

Tested by: SD
Checked by: SD

Respectfully submitted,
ROBERT W. HUNT COMPANY

Jimmy Sartin
Leach II

FILE NO. 3777-6
ORDER 13-C-9927

Date: 7-29-77

ENCLOSURE 2
Page 4 of 7
HCP 28353
PAGE

Brown & Root, Inc.
P. O. Box 1001
Clen Rose, Texas 76043

RE: Texas Utilities Services, Inc.
Comanche Peak Steam Electric Station
1980-1982 Units 1 & 2
Job No. 35-1195
B & R Subcontract No. 35-1195-0225
Hunt Project No. 513

Gentlemen:

We report results of Concrete Compression Tests, ASTM C-39 (Hunt E1001)

Pour No. 002-5810-001 Slump Inches 4 1/2"
Ticket No. 32959 Temperature °F 70°
Date Made 7-22-77 Air Content % 4.4%
Date Tested 7-29-77 Concrete Mix 126
Age Days 7 Unit Weight 144.08

	STANDARD CURED		FIELD CURED (JOB)	
Cylinder No.	<u>C4399</u>	<u>C4400</u>	<u>N/A</u>	<u>N/A</u>
Strength lbs. PSI.	<u>3323</u>	<u>3296</u>	<u>N/A</u>	<u>N/A</u>
Max. Load - lbs.	<u>94000</u>	<u>94000</u>	<u>N/A</u>	<u>N/A</u>
Type of Fracture	<u>R₁₉</u>	<u>R₁₉</u>	<u>N/A</u>	<u>N/A</u>
Date Received	<u>7-23-77</u>	<u>7-23-77</u>	<u>N/A</u>	<u>N/A</u>
Area	<u>28.29</u>	<u>28.52</u>	<u>N/A</u>	<u>N/A</u>

Tested by: SD
Checked by: DDO

Respectfully submitted,
ROBERT W. HUNT COMPANY

Jerry Sander
Level II



ENCLOSURE 2
Page 5 of 7
Report
Page

File 3777-6
Order 13-C-9927

Date: 8-19-77

Brown & Root, Inc.
P.O. Box 1001
Glen Rose, Texas 76043

Subject: Texas Utilities Services, Inc.
Comanche Peak Steam Electric Station
1980-1982 Units 1 & 2
Job No. 35-1195
B & R Subcontract No. 35-1195-0225
Hunt Project No. 513

Re: B & R/TUSI retention time
for the attached documents
Lifetime years after plant
begins operation.

Gentlemen:

Please acknowledge receipt of the following item by signing and returning a copy of this letter.

HCP # 28939 To 28940 COMPRESSION TEST ON CONCRETE CYLINDERS
CONCRETE MIX # 126
CONCRETE POUR # 002-5810-012

BROWN & ROOT, INC
RECEIVED
AUG 22 1977

FILES NOTED
QUALITY ASSURANCE

ROBERT W. HUNT COMPANY

Rec. by Brown & Root, Inc.

by [Signature]

[Signature]
LEWIS II

Title Q.C. CIVIL

Date 8-22-77

QA RECORD ROUTING

RTN	QA REVIEW
6	022
FILE NO.	CCT-2
SUBFILE NO.	002-5810-012

1. _____
2. _____
3. _____
4. _____
5. _____

Form HCP-9

FOR INFORMATION ONLY

FILE NO. 3777-6
ORDER 13-C-9927

Date: 8-19-77

ENCLOSURE 2
Page 6 of 7
REPORT HCP 28939
PAGE

Brown & Root, Inc.
P. O. Box 1001
Glen Rose, Texas 76043

RE: Texas Utilities Services, Inc.
Comanche Peak Steam Electric Station
1980-1982 Units 1 & 2
Job No. 35-1195
B & R Subcontract No. 35-1195-0225
Hunt Project No. 513

Gentlemen:

We report results of Concrete Compression Tests, ASTM C-39 (Hunt E1001)

Pour No. 002-5810-012 Slump Inches 2 3/4"
Ticket No. 32873 Temperature °F. 65°
Date Made 7-22-77 Air Content % 4.3%
Date Tested 8-19-77 Concrete Mix 126
Age Days 28 Unit Weight 145.70

	STANDARD CURED		FIELD CURED (JOB)	
Cylinder No.	C-4329	C-4330	C-4333	C-4334
Strength lbs. PSI.	5200	5309	5437	5483
Max. Load - lbs.	147000	151000	153500	154500
Type of Fracture	Reg	Reg	Reg	Reg
Date Received	7-23-77	7-23-77	8-11-77	8-11-77
Area	28.27	28.44	28.23	28.18

Tested by: L.T.
Checked by: SD

Respectfully submitted,
ROBERT W. HUNT COMPANY

Jerry Smith
Lynch II

FILE NO. 3777-6
ORDER 13-C-9927

Date: 8-19-77

ENCLOSURE 2
Page 7 of 7
REPORT HCP 28940
PAGE

Brown & Root, Inc.
P. O. Box 1001
Glen Rose, Texas 76043

RE: Texas Utilities Services, Inc.
Comanche Peak Steam Electric Station
1980-1982 Units 1 & 2
Job No. 35-1195
B & R Subcontract No. 35-1195-0225
Hunt Project No. 513

Gentlemen:


We report results of Concrete Compression Tests, ASTM C-39 (Hunt E1001)

Pour No. 002-5810-012 Slump Inches 3 3/4"
Ticket No. 32886 Temperature °F 66°
Date Made 7-22-77 Air Content % 4.58
Date Tested 8-19-77 Concrete Mix 126
Age Days 28 Unit Weight 145.88

	STANDARD CURED		FIELD CURED (JOB)	
Cylinder No.	C-4339	C-4340	C-4343	N/A
Strength lbs. PSI.	5370	5389	5143	N/A
Max. Load - lbs.	153000	152500	146000	N/A
Type of Fracture	Reg	Reg	Reg	N/A
Date Received	7-23-77	7-23-77	8-11-77	N/A
Area	28.49	28.30	28.39	N/A

Tested by: LT
Checked by: SL

Respectfully submitted,
ROBERT W. HUNT COMPANY


Robert W. Hunt II

COMANCHE PEAK STEAM ELECTRIC STATION
 REPORT ON COMPRESSIVE TESTS OF CONCRETE
 PROCEDURE DT-91-11.1-41

FAILED MEASURE 3 DATE 2-5-80
 HOUR NO 205-7852-004
 CYL SET NO 1577
 Page 1 of 2
 C.820

MIX	COMPLETE DATA AS APPLICABLE FROM BATCH TICKET	(%) MOIST AGGR	F.A.	H ₂ O F.A.	C.A.	H ₂ O C.A.	TOTAL WATER/BATCH	TYPE OF CURING
	CEMENT / CU YD.	H ₂ O ADDED	H ₂ O/CEMENT RATIO	AIR CU YD.	TOTAL AIR	SPECIFIED DESIGN STRENGTH		
	6609 LBS	13 GAL	434	9.9 OZ	99 OZ	4000 PSI	28 DAYS	

MATERIALS	BRAND OF CEMENT	TYPE OF CEMENT	BRAND OF AIR ENTRAINING ADMIXTURE	BRAND OF WATER REDUCING ADMIXTURE	MAX SIZE C.A.
	GH	II	MBVR	NA	3/8
	SOURCE C.A.	SP. GR. C.A.	SOURCE F.A.	SP. GR. F.A.	FINENESS MODULES F.A.
	Ty. Cleburne	2.60	Ty. Cleburne	2.62	274

SAMPLING	TYPE OF MIXING	BATCH LOAD	TICKET NO.	SAMPLE TAKEN AT:
	PLANT 2	10 C.Y.	57989	<input type="checkbox"/> CENTRAL MIXER <input type="checkbox"/> FORMS <input checked="" type="checkbox"/> POINT OF DISCHARGE

METHOD OF PLACING	<input checked="" type="checkbox"/> PUMP <input type="checkbox"/> BUCKET	DATE SAMPLED	HOUR	WEATHER	AIR TEMP.	CONC. TEMP.	SLUMP
<input type="checkbox"/> BUGGIES <input type="checkbox"/> BELT <input type="checkbox"/> CHUTE		2-5-80	0950	FAIR	48°F	63°F	3 3/4 IN
TIME OF MIXING AT CENTRAL PLANT	UNIT WT. CU. FT.	MIX I.D.	SPECIMEN TAKEN BY	SPECIMEN CAST BY	AIR		
1 1/2 MIN.	140.28 LBS	128	Jerry Reynolds	H.W.B.O.A.S.D.O	6.0%		

TESTS	CYLINDER ID	AGE	MEASURED DIA IN	AVG DIA IN	DATE CAPPED	CAPPED BY	TIME TESTED	DATE TESTED	MAX/LOAD LB.	COMPRESSIVE STRENGTH	CAP CHECKED BY	CYLINDER TESTED BY	TYPE OF BREAK
LAB CURED	1577A	7	6.016 6.014	6.015	2-7-80	F	0735	2-12-80	91500	3220	Q	Q	Reg
	1577B	7	6.000 6.082	6.011	2-7-80	F	0658	2-12-80	92000	3240	BD	BD	Reg
	1577C	28	6.021 6.014	6.014	2-25-80	Q	0708	3-4-80	162500	5730	Q	Q	Reg
	1577D	28	6.012 6.011	6.012	2-25-80	Q	0730	3-4-80	160500	5650	Q	Q	Reg
FIELD CURED	1577E	28	6.034 6.035	6.035	2-25-80	Q	0820	3-4-80	147500	5160	Q	Q	Reg
	1577F	28	6.014 6.014	6.014	2-25-80	Q	0635	3-4-80	141000	4960	Q	Q	Reg
	NA												
	NA												

DATE & TIME STRIPPED 2-8-80 0630 PM REMARKS PERM. PLT. RECORD

CURING CONTROL TEST RESULTS FOR 28 DAY BREAK

RTN L FILE LOC. 172.94.1
 DUPLICATE LOC. 205-7852-004

LABORATORY CURED CYLINDER(S)	FIELD CURED CYLINDERS
STRENGTH (PSI) <u>5720</u> (c)	STRENGTH (PSI) <u>5160</u> (a)
<u>5650</u> (d)	<u>4960</u> (b)
1 (c)+(d) + (c)+(d) = <u>11370</u> .89 *	2 (a)+(b) + 2 = <u>5060</u> *

MAR 10 1980

FILL - *NOTE: (1) ABOVE MUST BE EQUAL TO OR GREATER THAN 0.85; OR (2) ABOVE NEED NOT EXCEED THE DESIGN STRENGTH BY MORE THAN 500 PSI, EVEN IF THE 0.85 CRITERION IS NOT MET.

QUALITY AS

FOR INFORMATION ONLY

MICROMETER OR CALIPERS NO TTG 1392
 COMPRESSION MACHINE NO TTG 3031
 CAPPING MOLD NO LAL 402

7 DAY PREPARED BY [Signature] CHECKED BY [Signature]
 28 DAY PREPARED BY [Signature] CHECKED BY [Signature]

DESIGN ENGINEERS COMMENTS (IF APPLICABLE)

ENCLOSURE 3
 Page 2 of 2

DATE: 2-5-80
 POUR NO: 805-7752-004
 CYL SET NO: 1578
C820

MIX	COMPLETE DATA AS APPLICABLE FROM BATCH TICKET	(W) MOIST AGGR	F.A.	H ₂ O FA	C.A.	H ₂ O CA	TOTAL WATER/BATCH	TYPE OF CURING
	CEMENT / CU YD.	H ₂ O ADDED	H ₂ O/CEMENT RATIO	AIR CU. YD.	TOTAL AIR	SPECIFIED DESIGN STRENGTH		

MATERIALS	BRAND OF CEMENT	TYPE OF CEMENT	BRAND OF AIR ENTRAINING ADMIXTURE	BRAND OF WATER REDUCING ADMIXTURE	MAX SIZE C.A.
	SOURCE C.A.	SP GR C.A.	SOURCE F.A.	SP. GR. F.A.	FINENESS MODULES F.A.

SAMPLING	TYPE OF MIXING	BATCH LOAD	TICKET NO.	SAMPLE TAKEN AT:		
	METHOD OF PLACING	DATE SAMPLED	HOUR	WEATHER	AIR TEMP.	CONC. TEMP.
	TIME OF MIXING AT CENTRAL PLANT	UNIT WT CU. FT.	MIX I.D.	SPECIMEN TAKEN BY	SPECIMEN CAST BY	AIR

TESTS	CYLINDER ID	AGE	MEASUREMENT DIA. IN	AVG DIA IN	DATE CAPPED	CAPPED BY	TIME TESTED	DATE TESTED	MAX. LOAD LB.	COMPRESSIVE STRENGTH	CAP (IN) BY	CYLINDER TESTED BY	TYPE OF BREAK
	1578B	7	6.019	6.019	2-7-80	F	0202	2-12-80	87500	3080	BD	BD	Reg
	1578C	28	6.029	6.020	2-25-80	Q	0645	3-4-80	157500	5530	Q	Q	Reg
	1578D	28	6.017	6.018	2-25-80	Q	0648	3-4-80	158000	5560	Q	Q	Reg
	1578E	28	6.019	6.021	2-25-80	Q	0813	3-4-80	138000	4850	Q	Q	Reg
	1578F	28	6.004	6.015	2-25-80	Q	0750	3-4-80	136000	4790	Q	Q	Reg
	NA												
	NA												

DATE & TIME STRIPPED: 2-6-80 0630 AM REMARKS:

CURING CONTROL TEST RESULTS FOR 28 DAY BREAK

LABORATORY CURED CYLINDER(S):	FIELD CURED CYLINDER(S)
STRENGTH (PSI): <u>5530</u> (C)	STRENGTH (PSI): <u>4850</u> (D)
<u>5560</u> (D)	<u>4790</u> (B)
1. (C)+(D) = (C)+(D) = <u>.87</u> *	2. (D)+(B) + 2 = <u>4830</u> *

* NOTE: (1) ABOVE MUST BE EQUAL TO OR GREATER THAN 0.85. (2) MUST NOT EXCEED THE DESIGN STRENGTH BY MORE THAN 10% EVEN THOUGH THE 0.85 CRITERION IS NOT MET.

FOR INFORMATION ONLY

MICROMETER OR CALIPERS NO. MTC-1392
 COMPRESSION MACHINE NO. MTC-303
 CAPPING MOLD NO. L101 L102

7 DAY PREPARED BY: BD CHECKED BY: Q
 28 DAY PREPARED BY: Q CHECKED BY: Q

DESIGN ENGINEERS COMMENTS (IF APPLICABLE)

TUGCO LAB SUPERVISOR

COMANCHE PEAK STEAM ELECTRIC STATION
 REPORT ON COMPRESSIVE TESTS OF CONCRETE
 PROCEDURE QT-QP-11.1-41 R1

002-9852-093 C
 002-9852-031 B
 104-9778-051,052

DATE 5-18-84
 POUR NO. SEE NOTE
 CYL. SET NO. 2499

MIX	COMPLETE DATA AS APPLICABLE FROM BATCH TICKET	(g) MOIST AGGR.	F.A.	H ₂ O F.A.	C.A.	H ₂ O C.A.	TOTAL WATER/BATCH	TYPE OF CURING
	CEMENT / CU YD		LBS	LBS	LBS	LBS	LBS	M + N
	3157		6150	150	8460	0	1155	
		H ₂ O ADDED	H ₂ O/CEMENT RATIO	AIR CU. YD.	TOTAL AIR	SPECIFIED DESIGN STRENGTH		
		0 GAL	.366	9.4%	47%	4000 PSI	28	DAYS

MATERIALS	BRAND OF CEMENT	TYPE OF CEMENT	BRAND OF AIR ENTRAINING ADMIXTURE	BRAND OF WATER REDUCING ADMIXTURE	MAX SIZE C.A.
	B-H	II	MBVR	NA	3/4
	SOURCE C.A.	SP. GR. C.A.	SOURCE F.A.	SP. GR. F.A.	FINENESS MODULES F.A.
	TXI-TIN TOP	2.65	TXI-TIN TOP	2.63	2.52

SAMPLING	TYPE OF MIXING	BATCH LOAD	TICKET NO.	SAMPLE TAKEN AT:					
	PLANT 1	5 C.Y.	63149	<input type="checkbox"/> CENTRAL MIXER	<input type="checkbox"/> FORMS	<input checked="" type="checkbox"/> POINT OF DISCHARGE			
	METHOD OF PLACING	<input type="checkbox"/> PUMP	<input type="checkbox"/> BUCKET	DATE SAMPLED	HOUR	WEATHER	AIR TEMP	CONC. TEMP.	SLUMP
	<input type="checkbox"/> BUGGIES	<input type="checkbox"/> BELT	<input checked="" type="checkbox"/> CHUTE	5-18-84	1343 AM	RAIN	74 °	64 °	3 1/2 IN.

TIME OF MIXING AT CENTRAL PLANT	UNIT WT. CU. FT.	MIX ID.	SPECIMEN TAKEN BY	SPECIMEN CAST BY	AIR
70 MIN	144.46 LBS	132	BIRCHFIELD	DO-RO-JAS	5.1%

TESTS	CYLINDER ID	SIZE	MEASURED DIA. IN.	AVG DIA. IN.	DATE CAPPED	CAPPED BY	TIME TESTED	DATE TESTED	MAX. LOAD LB.	COMPRESSIVE STRENGTH	CAP CHECKED BY	CYLINDER TESTED BY	TYPE OF BREAK
	2499A	7	5.998 6.210	6.004	5-24-84	(1)	0700	5-25-84	115000	4060	Ch	Ch	Reg
	2499B	7	6.005 6.007	6.006	5-24-84	(2)	0703	5-25-84	112500	3970	Ch	Ch	Reg
	2499C	28	6.004 6.012	6.008	6-15-84	(2)	10:43	6-15-84	149500	5240	Ch	Ch	Reg
	2499D	28	6.028 6.009	6.016	6-15-84	(2)	10:40	6-15-84	150000	5280	Ch	Ch	Reg
	2499E	28	6.023 5.955	6.004	6-15-84	(2)	10:53	6-15-84	135000	4770	Ch	Ch	Reg
	2499F	28	6.010 6.008	6.009	6-15-84	(2)	10:59	6-15-84	135000	4760	Ch	Ch	Reg
	NA												
	NA												

DATE & TIME STRIPPED: 5-19-84 0700 PM
 REMARKS:

CURING CONTROL TEST RESULTS FOR 28 DAY BREAK

ENCLOSURE 4
 Page 1 of 2

LABORATORY CURED CYLINDER(S)	FIELD CURED CYLINDERS
STRENGTH (PSI) <u>5240</u> (c)	STRENGTH (PSI) <u>4770</u> (d)
<u>5280</u> (d)	<u>4760</u> (d)
1 (c)+(d) + (c)+(d) = <u>0.91</u> *	2 (d)+(d) + 2 = <u>4765</u> *

*NOTE: (1)-ABOVE MUST BE EQUAL TO OR GREATER THAN 0.85; OR (2) ABOVE NEED NOT EXCEED THE DESIGN STRENGTH BY MORE THAN 500 PSI; EVEN THOUGH THE 0.85 CRITERION IS NOT MET.

MICROMETER OR CALIPERS NO. MTE-1892
 COMPRESSION MACHINE NO. MTE-3031
 CAPPING MOLD NO. 101 2102

7 DAY PREPARED BY Ch CHECKED BY JAS
 28 DAY PREPARED BY Ch CHECKED BY JAS

DESIGN ENGINEERS COMMENTS (IF APPLICABLE)

FOR INFORMATION ONLY
JAS
 YUGCO LAB SUPERVISOR

MIX	COMPLETE DATA AS APPLICABLE FROM BATCH TICKET	(b) MOIST AGGR.	F.A.	H ₂ O F.A.	C.A.	H ₂ O C.A.	TOTAL WATER/BATCH	TYPE OF CURING
	CEMENT / CU YD	H ₂ O ADDED	H ₂ O/CEMENT RATIO	AIR CU. %	TOTAL AIR	SPECIFIED DESIGN STRENGTH		
MATERIALS	BRAND OF CEMENT	TYPE OF CEMENT	BRAND OF AIR ENTRAINING ADMIXTURE	BRAND OF WATER REDUCING ADMIXTURE	MAX SIZE C.A.			
	SOURCE C.A.	SP. GR. C.A.	SOURCE F.A.	SP. GR. F.A.	FINENESS MODULES F.A.			
SAMPLING	TYPE OF MIXING	BATCH LOAD	TICKET NO.	SAMPLE TAKEN AT:				
	METHOD OF PLACING	<input type="checkbox"/> PUMP <input type="checkbox"/> BUCKET	DATE SAMPLED	HOUR	WEATHER	AIR TEMP.	CONC. TEMP.	SLUMP
	TIME OF MIXING AT CENTRAL PLANT	UNIT WT. CU. FT.	MIX ID.	SPECIMEN TAKEN BY	SPECIMEN CAST BY	AIR		

TESTS	CYLINDER ID	AGE	MEASURED DIA IN	AVG DIA IN	DATE CAPPED	CAPPED BY	TIME TESTED	DATE TESTED	MAX. LOAD LB	COMPRESSIVE STRENGTH	CAP CHECKED BY	CYLINDER TESTED BY	TYPE OF BREAK
	NA												
	NA												
	NA												
	NA												
	2499G	3	5.994 6.005	6.001	5-21-84	(1)	7:20	5-21-84	84500	2990	(2)	(2)	Reg
	2499H	5	6.006 6.002	6.004	5-23-84	(2)	10:30	5-23-84	97500	3440	Ch	Ch	Reg
	2499I	10	6.004 6.006	6.005	5-28-84	(2)	10:50	5-28-84	125000	4410	(2)	(2)	Reg
	NA												

DATE & TIME STRIPPED: 5-18-84 0700 REMARKS: EXTRA CYLINDERS PER REQUEST CONCRETE DEPT.

CURING CONTROL TEST RESULTS FOR 28 DAY BREAK

ENCLOSURE 4
Page 2 of 2

LABORATORY CURED CYLINDER(S)	FIELD CURED CYLINDERS
STRENGTH (P.S.I.) <u>N/A</u> (C)	STRENGTH (P.S.I.) <u>N/A</u> (D)
1. (C)+(D) + (C)+(D) = <u>✓</u> *	2. (C)+(D) + 2 = <u>✓</u> *

* NOTE: (1) ABOVE MUST BE EQUAL TO OR GREATER THAN 0.85; OR (2) ABOVE NEED NOT EXCEED THE DESIGN STRENGTH BY MORE THAN 500 PSI EVEN THOUGH THE 0.85 CRITERION IS NOT MET

MICROMETER OR CALIPERS NO. MATE 1392
 COMPRESSION MACHINE NO. MATE 9031
 CAPPING MOLD NO. L101 & L102

3 DAY PREPARED BY Ch CHECKED BY IAS
 5 DAY PREPARED BY Ch CHECKED BY IAS
 10 DAY PREPARED BY Ch CHECKED BY IAS

DESIGN ENGINEERS COMMENTS (IF APPLICABLE):

FOR INFORMATION ONLY
Joe Seeger
 TUGCO LAB SUPERVISOR

ENCLOSURE 5
Page 1 of 3

ROBERT W. HUNT COMPANY, ENGINEERS
CHICAGO 7, ILLINOIS

FILE NO 3777-6
ORGA 13-C-9927

Date: 7-9-76

REPORT
PAGE

Brown & Root, Inc.
P.O. Box 1001
Glen Rose, Texas 76043

Subject: Texas Utilities Services, Inc.
Comanche Peak Steam Electric Station
1980-1982 Units 1 & 2
Job No. 35-1195
B & R Subcontract No. 35-1195-0225
Hunt Project No. 513

Re: B & R/TUSI retention time
for the attached documents
1 1/2 years after plant
begins operation.
AS-7-12-76

Gentlemen:

Please acknowledge receipt of the following item by signing and returning a copy of this letter.

HCP 13426 - UNIFORMITY test - TRUCK # RET-01.

BROWN & ROOT, INC.
RECEIVED
JUL 12 1976
FILES NOTED
QUALITY ASSURANCE

ROBERT W. HUNT COMPANY

Henry Hewitt
Level II

Rec. by Brown & Root, Inc.
by Bill Walker

Title Level II

Date 7-12-76

QA RECORD ROUTING

RTN.	QA REVIEW
<u>LR</u>	<u>LM</u>
FILE NO.	
<u>CST</u>	
SUBFILE NO.	
<u>26</u>	

1. SM
2. _____
3. _____
4. _____
5. _____

ENCLOSURE 5

Page 2 of 3

ROBERT W. HUNT COMPANY, ENGINEERS
CHICAGO 7, ILLINOISFILE NO. 3777-6
ORDER 13-C-9927154
REPORT HCP
PAGE 13426
10/2Brown & Root, Inc.
Post Office Box 1001
Glen Rose, Texas 76043Attention: Mr. P. L. Bussolini
Project Quality Assurance Manager

Subject:

Reference: Texas Utilities Services, Inc.
Comanche Peak Steam Electric Station
1980-1982 Units 1 & 2
Job Number 1195
B & R Subcontract Number 35-1195-0225
Hunt Project 513

Gentlemen:

We report results of tests in accordance with requirements of ASTM:
C94-73a Appendix XI Concrete Uniformity Requirements made on the following
equipment -

Ready Mix Truck #RET 01

Weight per cubic foot (air-free basis)

Sample #1 = 153.32 lb/cu. ft.
Sample #2 = 153.91 lb/cu. ft.
Difference in results = 0.59 lb/cu. ft.
Maximum Permissible difference in results = 1.00 lb/cu. ft.

Air Content, Volume % of Concrete

Sample #1 = 4.2%
Sample #2 = 4.5%
Difference in results = 0.3%
Maximum Permissible difference in results = 1.0%

FOR INFORMATION ONLY

FILE NO. 3777-6
ORDER

ENCLOSURE 5
Page 3 of 3

REPORT HCP 13426
PAGE 2 of 2

Sample #1 = 4.0 inches
Sample #2 = 5½ inches
Difference in results = 1½ inches
Maximum permissible difference in results = 1.5 inches

Coarse Aggregate content, portion by weight of each sample retained on No. 4 sieve, percent:

Sample #1 = 63.67%
Sample #2 = 65.70%
Difference in results = 2.03%
Maximum permissible difference in results = 6.00%

Average compressive strength at 7 days for each sample, based on average strength of all comparative test specimens, percent.

Sample #1 = 102.49%
Sample #2 = 97.50%
Difference in results = 4.99%
Maximum permissible difference in results = 7.5%

The above results comply with project requirements.

Respectfully submitted,

ROBERT W. HUNT COMPANY

Byron K. Kinkade
Byron K. Kinkade
Level III

BKK/pw