

TABLE 3.7-1

MAXIMUM ALLOWABLE POWER RANGE NEUTRON FLUX HIGH SETPOINT WITH  
INOPERABLE STEAM LINE SAFETY VALVES DURING FOUR LOOP OPERATION

MAXIMUM NUMBER OF INOPERABLE  
SAFETY VALVES ON ANY  
OPERATING STEAM GENERATOR

MAXIMUM ALLOWABLE POWER RANGE  
NEUTRON FLUX HIGH SETPOINT  
(PERCENT OF RATED THERMAL POWER)

1	87
2	65
3	43
4 or 5	*

8609260072 860917  
PDR ADOCK 05000413  
P PDR

---

\* Unit operation shall be restricted to no greater than Mode 3.