APPENDIX A Operating Data Report

۲

Docket No.: 50-219 Date: Completed By: Rick Nash Telephone: (609) 971-4 (609) 971-4851

1

August 13, 1997

REPORTING PERIOD: July, 1997

	 Production of the second s	MONTH	YEAR TO DATE	CUMULATIVE	
1.	DESIGN ELECTRICAL RATING (MWe NET). The nominal net electrical output of the unit specified by the utility and used for the purpose of plant design.	650	*		
2.	MAXIMUM DEPENDABLE CA [¬] ACITY (MWe NET). The gross electrical output as measured at the output terminals of the turbine generator during the most restrictive seasonal conditions minus the normal station service loads.	619	*	*	
3.	NUMBER OF HOURS REACTOR WAS CRITICAL. The total number of hours during the gross hours of the reporting period that the reactor was critical.	744	4,835.4	166,424.2	
4.	HOURS GENERATOR ON LINE. (Service Hours) The total number of hours during the gross hours of the reporting period that the unit operated with the breakers closed to the station bus. The sum of the hours that the generator was on line plus the total outage hours in the reporting period.	744	4,790.5	162,708.3	
5.	UNIT RESERVE SHUTDOWN HOURS. The total number of hours during the gross hours of the reporting period that the unit was removed from service for economic or similar reasons but was available for operation.	0	0	0	
6.	NET ELECTRICAL ENERGY (MWH) The gross electrical output of the unit measured at the output terminals of the turbine generator minus the normal station service loads during the gross hours of the reporting period, expressed in magawatt hours. Negative quantities should not be used.	438,092	2,957,946	94,965,533	

9708210045 970814 PDR ADOCK 05000219 R PDR

* Design values have no "Year to Date" or "Cumulative" significance.

Appendix B

Unit Shutdowns

Docket No. 50-219 Date: Completed By: David M Egan (609)971-4818 Telephone:

Reporting Period July 1997							
No.	Date	Type*	Duration (Hours)	Reason ¹	Method of Shutting Down Reactor ²	Cause & Corrective Action to Prevent Recurrence	
4	970712	S	0	b	1	Planned power reduction to perform quarterly main steam isolation valves testing.	

1 F Forced Reason: A-Equipment Failure (Explain) S Scheduled B-Maintenance or Test C-Refueling D-Regulatory Pestriction E-Operator Training & Licensing Examination F-Administrative G-Operational Error (Explain) H-Other (Explain)

.

3

6

2 Method: 1-Manual 2-Manual Scram 3-Automatic Scram 4-Other (Explain)

Summary: Oyster Creek generated 438,092 MWH ne: electric during July which was 94.7% of its MDC rated capacity.