

Commonwealth Edison Company
Quad Cities Generating Station
22710 206th Avenue North
Cordova, IL 61242-9740
Tel 809-654-2241

ComEd

LWP-97-079

August 12, 1997

U.S. Nuclear Regulatory Commission
Washington, DC 20555

Attn: Document Control Desk

Reference: Quad Cities Nuclear Power Station
Docket Number 50-254, DPR-29, Unit One

Enclosed is Licensee Event Report (LER) 97-015, Revision 1, for Quad Cities Nuclear Power Station. This event dealt with the loss of the 1B RPS bus due to a failed breaker.


This report is being submitted to include the following information in LER 97-015, Revision 0:

1) The 1/2 scram, 2) Primary Containment Isolation (PCI) 1/2 Group I, II, and III isolation, 3) Reactor Water Clean-up (RWCU) A & B pumps trip, 4) Reactor Building Vent isolation and the 5) loss of the Residual Heat Removal (RHR) shutdown cooling system.

If there are any questions or comments concerning this letter, please refer them to Charles Peterson, Regulatory Affairs Manager at 309-654-2241, ext. 3609.

Respectfully,

COMMONWEALTH EDISON COMPANY
QUAD CITIES NUCLEAR POWER STATION


L. W. Pearce
Station Manager

IE221

LWP/CP/plm
Enclosure

cc: A. B. Beach, Regional Administrator, Region III
R. M. Pulsifer, Project Manager, NRR
C. G. Miller, Senior Resident Inspector, Quad Cities
W. D. Leech, MidAmerican Energy Company
D. C. Tubbs, MidAmerican Energy Company
M. E. Wagner, Licensing, ComEd
F. A. Spangenberg, Regulatory Affairs Manager, Dresden
INPO Records Center

9708210349 970812
PDR ADJCK 05000254
S PDR

STMGR\LER\97079



A Unicom Company