

10 CFR 50.90

JAFP-20-0064

July 28, 2020

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555-0001

James A. FitzPatrick Nuclear Power Plant
Renewed Facility Operating License No. DPR-59
NRC Docket No. 50-333

Subject: Withdrawal of License Amendment Request to Revise the Allowable Value for Reactor Water Cleanup (RWCU) System Primary Containment Isolation

Reference: 1) Letter from J. Barstow (Exelon Generation Company, LLC) to U.S. Nuclear Regulatory Commission, "License Amendment Request – Proposed Change to Technical Specifications to Revise the Allowable Value for Reactor Water Cleanup (RWCU) System Primary Containment Isolation" (ML19248B085) dated September 5, 2019

By letter dated September 5, 2019, (Reference 1) and supplemented by letters dated November 6, 2019, February 21, 2020, and March 31, 2020, Exelon Generation Company, LLC (Exelon) requested a change to the James A. FitzPatrick (JAF) Technical Specifications (TS) in accordance with 10 CFR 50.90. The proposed amendment request would have revised the TS Allowable Value for Reactor Water Clean Up (RWCU) isolation on low Reactor Pressure Vessel (RPV) water level from Level 3 (≥ 177 inches) to Level 2 (≥ 107 inches).

Due to COVID-19 concerns and to minimize the amount of personnel on site, Exelon elected to reduce the scope of the upcoming refueling outage (RFO). As a result of this decision, the planned setpoint modification needed in support of this License Amendment Request (LAR) is being delayed until the next scheduled RFO. Consequently, Exelon is withdrawing this LAR.

In accordance with 10 CFR 50.91, "Notice for public comment; State consultation," paragraph (b), Exelon will notify the State of New York of this withdrawal by transmitting a copy of this letter to the designated State Official.

Withdrawal of LAR to Revise the Allowable Value for
RWCU System Primary Containment Isolation
July 28, 2020
Page 2

Should you have any questions concerning this letter, please contact Mr. Enrique Villar at
(610) 765-5736.

Respectfully,

David T. Gudger

David T. Gudger
Senior Manager, Licensing
Exelon Generation Company, LLC

cc: Regional Administrator - NRC Region I
NRC Senior Resident Inspector - JAF
NRC Project Manager, NRR - JAF
A. L. Peterson, NYSERDA