

LICENSEE EVENT REPORT (LER)

FACILITY NAME (1) Joseph M. Farley - Unit 1 DOCKET NUMBER (2) 050003481 OF 011 PAGE (3)

TITLE (4) Special Report: Fire Detectors Inoperable For Longer Than Allowed By Technical Specifications

EVENT DATE (5)			LER NUMBER (6)		REPORT DATE (7)			OTHER FACILITIES INVOLVED (8)					
MONTH	DAY	YEAR	YEAR	SEQUENTIAL NUMBER	REVISION NUMBER	MONTH	DAY	YEAR	FACILITY NAMES				
0	9	02	8	6	8	6	0	9	2	5	8	6	

THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR § (Check one or more of the following) (11)

OPERATING MODE (9) 1	20.402(b)	20.406(c)	50.73(a)(2)(iv)	73.71(b)
POWER LEVEL (10) 0, 9, 9	20.406(a)(1)(i)	50.38(e)(1)	50.73(a)(2)(v)	73.71(c)
	20.406(a)(1)(ii)	50.38(e)(2)	50.73(a)(2)(vii)	<input checked="" type="checkbox"/> OTHER (Specify in Abstract below and in Text, NRC Form 366A)
	20.406(a)(1)(iii)	50.73(a)(2)(ii)	50.73(a)(2)(viii)(A)	Special Report per
	20.406(a)(1)(iv)	50.73(a)(2)(iii)	50.73(a)(2)(viii)(B)	Tech. Spec. 3.3.3.9
	20.406(a)(1)(v)	50.73(a)(2)(iii)	50.73(a)(2)(ix)	

LICENSEE CONTACT FOR THIS LER (12) J. D. Woodard, General Manager - Nuclear Plant TELEPHONE NUMBER 205 899-5156

COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13)

CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NPROS	CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NPROS

SUPPLEMENTAL REPORT EXPECTED (14) YES (If yes, complete EXPECTED SUBMISSION DATE) NO MONTH DAY YEAR

ABSTRACT (Limit to 1400 spaces, i.e. approximately fifteen single-space typewritten lines) (16)

This Special Report is being submitted in accordance with Technical Specification 3.3.3.9.

At 1400 on 8-19-86, fire protection system 1A-108 was disabled in order to support extensive architectural modifications to the Auxiliary Building Access Control Area. Technical Specifications require that an hourly fire watch patrol remain in effect while the system is inoperable and that the system be returned to operable status within 14 days. The hourly fire watch patrol was established and maintained. However, due to the scope of the modifications in progress, the system could not be returned to service within 14 days. The smoke detectors could not be reinstalled until the wall modifications were completed. Fire protection system 1A-108 was returned to service on 9-16-86.

8610060601 860925
PDR ADOCK 05000348
S PDR

EE 22
111

Alabama Power Company
600 North 18th Street
Post Office Box 2641
Birmingham, Alabama 35291
Telephone 205 250-1000



September 25, 1986

Docket No. 50-348

Document Control Desk
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

Dear Sir:

Joseph M. Farley Nuclear Plant - Unit 1
Licensee Event Report No. LER 86-016-00

Joseph M. Farley Nuclear Plant, Unit 1, Licensee Event Report No. LER 86-016-00 is being submitted in accordance with 10CFR50.73.

If you have any questions, please advise.

Respectfully submitted,

R. P. McDonald

RPM/JAR:dst-D-LER

Enclosure

cc: IE, Region II

IE22
1/1